



City of Chowchilla

Sidewalks

Access Compliance Survey Report

DRAFT



TABLE OF CONTENTS

- I. Access Compliance Survey Report
 - i. Report Navigation and Legend, Abbreviations
 - ii. Master Street List
 - iii. Cost Summary

- II. Survey Data for Sidewalks
 - i. Survey Data





NAVIGATION & LEGEND

NAVIGATION

City of Chowchilla		Access Compliance Survey Report - Sidewalks							Chowchilla	
Funding Source: TBD									Year to be Completed TBD	
Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority	
NE	1908200948	CHOWCHILLA BLVD	ROBERTSON BLVD	SIDEWALK ENDS					TBD	
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total		
234	0.0 to 19.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	144	SF	\$120	\$17,280		
1	0.8 to 1.8 feet	Continuous Width		8 ft	8	SF	\$120	\$900		
46978	4.0 to 5.0 feet	Vertical Change	-43	8 ft	8	REF				
57699	13.8 to 61.6 feet	Driveway				REF				
52326	17.0 to 18.0 feet	Vertical Change	-28	8 ft	8	REF				
237	21.2 to 59.7 feet	Cross Slope (Driveway)	7.0-8.0%	8 ft	289	SF	\$40	\$11,550		
46526	39.9 to 40.9 feet	Vertical Change	-45	8 ft	8	REF				
39961	57.5 to 59.4 feet	Running Slope	5.0-6.0%	8 ft	14	REF				
240	62.7 to 108.0 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	340	SF	\$120	\$40,770		

1. Street Side: Corresponds to the side of the street surveyed:
- N, S, E and W.
2. Dist. from Corner: The location of the identified barrier, measured in feet from the intersection/starting street.
3. Survey Street: Name of arterial/primary Street for which barriers are being surveyed.
4. Barrier Type: Type of Barrier recorded.
5. Starting Street: Name of the intersecting starting street from which barrier locations are being measured.
6. Measurement: Existing condition/dimension.
7. Sidewalk Width: Width of the sidewalk measured in feet.
8. Qty: Number of solutions required.
9. End Street: Name of the intersecting ending street from which barrier locations are being measured.
10. Unit: Unit of measurement used to compute estimate. LF=linear feet; SF=square feet; JOB=lump sum; REF=reference
11. Cost: Estimated cost of specific solution per one unit (The final cost of barrier removal may exceed this estimate based on the year of mitigation, design approach, and chosen method of mitigation.
12. Total: Total estimated cost for removing identified barrier (multiplied Qty by Cost).
13. Priority: Priority number assigned to specific barrier based on prioritization criteria which include: expected frequency of use and severity of the barrier. Measured on a scale of 0 to 200, with 200 being the highest priority and 0 being the least.

LEGEND ABBREVIATIONS

ADA	Americans with Disabilities Act
ADAAG	ADA Accessibility Guidelines
E	East
Fig.	Figure
JOB	per one job (lump sum)
lbs.	Pounds
LF	Linear foot
MUTCD	Manual on Uniform Traffic Control Devices
N	North
NE	Northeast
NW	Northwest
POT	Path of travel
PROW	Public Right-of-Way
PROWAG	Public Right-of-Way Accesible Guidelines
Qty	Quantity
REF	Reference; Provided in locations with overlapping issue; indicates no addition cost required for mitigation
S	South
SE	Southeast
SF	Square foot
SW	Southwest
TBD	To be determined
W	West





MASTER STREET LIST



	<i>Total Cost for Street:</i>
Street: 10TH ST	\$663,563.50
Street: 11TH ST	\$955,670.00
Street: 12TH ST	\$164,166.75
Street: 13TH ST	\$1,380,533.00
Street: 14TH ST	\$571,868.00
Street: 15TH ST	\$2,092,862.75
Street: 1ST ST	\$1,126,369.00
Street: 2ND ST	\$1,184,786.00
Street: 3RD ST	\$2,455,344.00
Street: 4TH ST	\$2,083,540.25
Street: 5TH ST	\$2,554,292.00
Street: 6TH ST	\$1,553,018.25
Street: 7TH ST	\$1,095,229.25
Street: 8TH ST	\$1,283,584.00
Street: 9TH ST	\$997,335.25
Street: ACACIA CT	\$249,525.00
Street: ADAMS DR	\$125,785.00
Street: ALAMEDA AVE	\$1,077,885.00
Street: ALMA CT	\$60,637.50
Street: ALMOND CT	\$120,515.00
Street: AMADOR ST	\$304,100.00
Street: AUTUMN WAY	\$804,972.50
Street: AVE 26	\$3,419,322.50
Street: BIDAN AVE	\$304,042.50
Street: BIRCH CT	\$161,905.00
Street: BLOSSOM DR	\$77,462.00
Street: CALAVERAS ST	\$2,030,101.50
Street: CALIFA DR	\$507,635.00
Street: CAMELLIA DR	\$69,434.75
Street: CANAL DR	\$476,917.00
Street: CARLYLE WAY	\$198,255.00
Street: CEDAR CT	\$175,900.00
Street: CHARLENE DR	\$194,788.00
Street: CHERRY CT	\$204,942.50
Street: CHERRY WAY	\$192,860.00
Street: CHESTNUT DR	\$69,965.50
Street: CHOWCHILLA BLVD	\$1,268,539.50
Street: CIRCLE DR	\$1,523,007.00
Street: CLUBHOUSE DR	\$576,270.00
Street: COLUSA AVE	\$1,442,260.00
Street: CONADRIA AVE	\$336,640.00
Street: COOLIDGE AVE	\$568,164.00
Street: CORDELIA AVE	\$345,930.00
Street: COTTONWOOD DR	\$773,120.00
Street: CYPRESS LN	\$463,547.50
Street: DANNIELLE ST	\$309,715.00
Street: DEBORAH WAY	\$192,176.00
Street: DOROTHY WAY	\$273,792.00
Street: ELM AVE	\$1,418,467.50
Street: ENGLEWOOD AVE	\$195,885.00
Street: FALLEN LEAF WAY	\$434,362.50
Street: FRONT ST	\$509,592.75
Street: GILL WAY	\$607,223.00
Street: GOLF DR W	\$105,060.00
Street: GRANITE FALLS WAY	\$619,635.00
Street: GRANT DR	\$847,020.00
Street: HARDING AVE	\$190,663.00
Street: HARRISON CT	\$338,020.00
Street: HOLIDAY WAY	\$804,879.00

	<i>Total Cost for Street:</i>
Street: HOOVER AVE	\$516,914.00
Street: HOSPITAL DR	\$111,940.00
Street: HOWELL RD	\$1,285,698.25
Street: HUMBOLDT AVE	\$2,276,370.50
Street: JACKSON CT	\$161,085.00
Street: JEFFERSON ST	\$545,235.00
Street: JUNIPER CT	\$137,240.00
Street: KADOTA AVE	\$56,460.00
Street: KENNEDY CT	\$175,840.00
Street: KINGS AVE	\$1,932,685.25
Street: KITES WAY	\$681,320.00
Street: LAKE AVE	\$771,221.00
Street: LARK AVE	\$349,557.50
Street: LINCOLN AVE	\$681,680.00
Street: MADISON CT	\$306,210.00
Street: MAGNOLIA CT	\$143,315.00
Street: MAPLE ST	\$370,495.00
Street: MARIPOSA AVE	\$467,501.50
Street: MICHELLE CT	\$79,720.00
Street: MISSION AVE	\$27,510.00
Street: MOLLY AVE	\$528,195.00
Street: MONROE CT	\$227,280.00
Street: MONTEREY AVE	\$1,295,551.50
Street: MYER ST	\$943,215.00
Street: N FIG TREE BLVD	\$206,340.00
Street: OAK CT	\$240,810.00
Street: OLEANDER DR	\$494,167.50
Street: ORANGE AVE	\$2,274,740.00
Street: PALM PKY	\$1,331,315.00
Street: PARKRIDGE CT	\$135,340.00
Street: PARKRIDGE DR	\$1,107,685.00
Street: PEACH CT	\$69,977.50
Street: PEACH DR	\$901,375.00
Street: PENNY ST	\$365,470.00
Street: PHILLIP CT	\$140,480.00
Street: PHILLIP WAY	\$655,995.00
Street: PINE CT	\$210,860.00
Street: PINE ST	\$963,950.00
Street: PISTACHIO CT	\$239,854.00
Street: PLUM CT	\$235,375.00
Street: PLUM WAY	\$226,847.50
Street: PROSPERITY RD	\$1,411,645.00
Street: RD 15 1/2	\$153,263.00
Street: RIVERSIDE AVE	\$1,551,799.75
Street: ROBERTSON BLVD	\$5,654,626.50
Street: ROBERTSON-TRINITY ALLEY	\$101,004.75
Street: ROOSEVELT DR	\$1,444,578.00
Street: ROSE AVE	\$737,020.00
Street: ROSEHILL DR	\$1,427,610.00
Street: S FIG TREE BLVD	\$575,645.00
Street: S GENOA LAKE WAY	\$860,107.50
Street: S LAKE TAHOE DR	\$259,485.00
Street: S MONTGOMERY LAKE WAY	\$2,529,672.75
Street: SANTA CRUZ BLVD	\$1,526,415.00
Street: SHASTA CT	\$175,887.50
Street: SONOMA AVE	\$539,044.00
Street: SPRUCE CT	\$156,235.00
Street: TAFT CT	\$220,035.00
Street: THOMAS CHIDLAW DR	\$436,340.00

	<i>Total Cost for Street:</i>
Street: TRINITY AVE	\$2,424,549.25
Street: TRUMAN DR	\$1,428,006.00
Street: VAN BUREN ST	\$68,775.00
Street: VENTURA AVE	\$2,763,117.50
Street: VERDONE ST	\$191,125.00
Street: VERNAL DR	\$268,902.50
Street: VERTE ST	\$143,387.50
Street: W GOLF DR	\$207,375.00
Street: WALNUT WAY	\$181,130.00
Street: WASHINGTON DR	\$694,750.00
Street: WASHINGTON RD	\$1,577,807.50
Street: WILLOW CT	\$54,335.00
Street: WILSON WAY	\$733,421.38
	<i>Total Cost for County Sidewalks:</i>
	\$99,502,998.38



COST SUMMARY



10TH ST**Total Cost for Street: \$663,563.50**

Survey Street	Start Street	End Street	Orientation	
10TH ST	KINGS AVE	SIDEWALK ENDS	NE	\$23,861.75
10TH ST	LAKE AVE	SIDEWALK ENDS	NE	\$53,740.50
10TH ST	MONTEREY AVE	SIDEWALK ENDS	SW	\$38,637.50
10TH ST	ORANGE AVE	TRINITY AVE	NE	\$128,426.50
10TH ST	ROBERTSON BLVD	KINGS AVE	NE	\$81,394.50
10TH ST	SIDEWALK BEGINS	SIDEWALK ENDS	NE	\$189,267.75
10TH ST	SONOMA AVE	SIDEWALK ENDS	SW	\$25,162.50
10TH ST	TRINITY AVE	SIDEWALK ENDS	SW	\$55,098.00
10TH ST	VENTURA AVE	SIDEWALK ENDS	SW	\$67,974.50

11TH ST**Total Cost for Street: \$955,670.00**

Survey Street	Start Street	End Street	Orientation	
11TH ST	530 11TH ST	SONOMA AVE	NE	\$77,214.50
11TH ST	ENTRANCE TO SCHOOL	ORANGE AVE	NE	\$6,405.00
11TH ST	HUMBOLDT AVE	ENTRANCE TO SCHOOL	NE	\$29,340.00
11TH ST	KINGS AVE	SIDEWALK ENDS	NE	\$106,705.50
11TH ST	LAKE AVE	MONTEREY AVE	NE	\$13,563.00
11TH ST	MONTEREY AVE	RIVERSIDE AVE	SW	\$283,778.00
11TH ST	ORANGE AVE	SIDEWALK ENDS	NE	\$58,878.00
11TH ST	RIVERSIDE AVE	LAKE AVE	NE	\$114,240.50
11TH ST	ROBERTSON BLVD	SIDEWALK ENDS	NE	\$203,536.50
11TH ST	SIDEWALK BEGINS	ROBERTSON BLVD	NE	\$49,788.00
11TH ST	SONOMA AVE	MONTEREY AVE	SW	\$2,634.50
11TH ST	VENTURA AVE	SONOMA AVE	SW	\$9,586.50

12TH ST**Total Cost for Street: \$164,166.75**

Survey Street	Start Street	End Street	Orientation	
12TH ST	COLUSA AVE	SIDEWALK ENDS	SW	\$21,007.25
12TH ST	HUMBOLDT AVE	SIDEWALK ENDS	NE	\$52,822.00
12TH ST	SIDEWALK BEGINS	SONOMA AVE	SW	\$90,337.50

13TH ST**Total Cost for Street: \$1,380,533.00**

Survey Street	Start Street	End Street	Orientation	
13TH ST	ALAMEDA AVE	SIDEWALK ENDS	SW	\$65,395.00
13TH ST	COLUSA AVE	ALAMEDA AVE	NE	\$97,328.00
13TH ST	HUMBOLDT AVE	SIDEWALK ENDS	SW	\$4,158.00
13TH ST	KINGS AVE	ROBERTSON BLVD	SW	\$88,632.50
13TH ST	ORANGE AVE	ROBERTSON BLVD	NE	\$323,345.00
13TH ST	RIVERSIDE AVE	MONTEREY AVE	NE	\$202,477.00
13TH ST	ROBERTSON BLVD	TRINITY AVE	SW	\$145,178.00
13TH ST	SIDEWALK BEGINS	SIDEWALK ENDS	NE	\$356,361.50
13TH ST	TRINITY AVE	ORANGE AVE	SW	\$97,658.00

14TH ST**Total Cost for Street: \$571,868.00**

Survey Street	Start Street	End Street	Orientation	
14TH ST	COLUSA AVE	SIDEWALK ENDS	SW	\$49,599.00
14TH ST	LAKE AVE	SIDEWALK ENDS	NE	\$59,884.00
14TH ST	MONTEREY AVE	SIDEWALK ENDS	NE	\$13,035.00
14TH ST	ORANGE AVE	SIDEWALK ENDS	SW	\$44,632.50
14TH ST	SIDEWALK BEGINS	TRINITY AVE	NE	\$393,145.50
14TH ST	VENTURA AVE	SIDEWALK ENDS	SW	\$11,572.00

15TH ST**Total Cost for Street: \$2,092,862.75**

Survey Street	Start Street	End Street	Orientation	
15TH ST	ALAMEDA AVE	HUMBOLDT AVE	NE	\$127,402.00
15TH ST	COLUSA AVE	ALAMEDA AVE	NE	\$81,878.50
15TH ST	COOLIDGE AVE	HARDING AVE	SW	\$71,610.00
15TH ST	DEFENDER ST	ROBERTSON BLVD	SW	\$264,492.25
15TH ST	HARDING AVE	TRUMAN DR	SW	\$7,282.00
15TH ST	HOOVER AVE	COOLIDGE AVE	SW	\$94,776.00
15TH ST	HUMBOLDT AVE	ORANGE AVE	NE	\$109,450.00
15TH ST	KINGS AVE	RIVERSIDE AVE	NE	\$38,747.50
15TH ST	LAKE AVE	MONTEREY AVE	NE	\$100,083.50
15TH ST	MONTEREY AVE	SONOMA AVE	NE	\$113,404.50
15TH ST	ORANGE AVE	TRINITY AVE	NE	\$42,641.50
15TH ST	RIVERSIDE AVE	LAKE AVE	NE	\$119,878.00
15TH ST	ROBERTSON BLVD	ROOSEVELT DR	SW	\$222,700.50
15TH ST	ROOSEVELT DR	HOOVER AVE	SW	\$106,414.00
15TH ST	SONOMA AVE	VENTURA AVE	NE	\$104,879.50
15TH ST	TRINITY AVE	ROBERTSON BLVD	NE	\$60,802.50
15TH ST	VENTURA AVE	DEFENDER ST	SW	\$426,420.50

1ST ST**Total Cost for Street: \$1,126,369.00**

Survey Street	Start Street	End Street	Orientation	
1ST ST	325 1ST ST	325 1ST ST	NE	\$25,440.00
1ST ST	440 1ST ST	440 1ST ST	SW	\$375.00
1ST ST	ALAMEDA AVE	540 1ST ST	SW	\$67,666.50
1ST ST	COLUSA AVE	SIDEWALK ENDS	SW	\$66,708.00
1ST ST	KINGS AVE	ROBERTSON BLVD	SW	\$78,380.50
1ST ST	ORANGE AVE	SIDEWALK ENDS	SW	\$57,654.00
1ST ST	ROBERTSON BLVD	TRINITY AVE	SW	\$224,193.00
1ST ST	SIDEWALK BEGINS	TRINITY AVE	NE	\$265,308.00
1ST ST	TRINITY AVE	ROBERTSON BLVD	NE	\$340,644.00

2ND ST**Total Cost for Street: \$1,184,786.00**

Survey Street	Start Street	End Street	Orientation	
2ND ST	535 2ND ST	525 2ND ST	NE	\$39,343.50
2ND ST	HUMBOLDT AVE	SIDEWALK ENDS	SW	\$9,477.00
2ND ST	KINGS AVE	RIVERSIDE AVE	NE	\$67,584.00
2ND ST	MONTEREY AVE	SIDEWALK ENDS	NE	\$126,985.00
2ND ST	ORANGE AVE	TRINITY AVE	NE	\$96,630.00
2ND ST	RIVERSIDE AVE	SIDEWALK ENDS	NE	\$116,820.00
2ND ST	ROBERTSON BLVD	SIDEWALK ENDS	NE	\$23,702.50
2ND ST	ROBERTSON-TRINITY ALLEY	TRINITY AVE	SW	\$126,258.00
2ND ST	SIDEWALK BEGINS	RIVERSIDE AVE	NE	\$270,007.00
2ND ST	TRINITY AVE	ROBERTSON BLVD	NE	\$307,979.00

3RD ST**Total Cost for Street: \$2,455,344.00**

Survey Street	Start Street	End Street	Orientation	
3RD ST	655 3RD ST	SONOMA AVE	SW	\$88,847.00
3RD ST	ALAMEDA AVE	HUMBOLDT AVE	NE	\$119,119.50
3RD ST	COLUSA AVE	MARIPOSA AVE	SW	\$242,876.00
3RD ST	HUMBOLDT AVE	ORANGE AVE	NE	\$244,180.00
3RD ST	KINGS AVE	ROBERTSON BLVD	SW	\$97,945.00

3RD ST	LAKE AVE	RIVERSIDE AVE	SW	\$131,318.00
3RD ST	MARIPOSA AVE	SIDEWALK ENDS	SW/	\$474,014.00
3RD ST	MONTEREY AVE	SONOMA AVE	NE	\$195,151.00
3RD ST	ORANGE AVE	TRINITY AVE	NE	\$275,870.00
3RD ST	RIVERSIDE AVE	KINGS AVE	SW	\$84,139.00
3RD ST	ROBERTSON BLVD	TRINITY AVE	SW	\$148,005.00
3RD ST	SIDEWALK BEGINS	KINGS AVE	NE	\$29,733.00
3RD ST	SONOMA AVE	CALAVERAS ST	NE /	\$103,746.50
3RD ST	TRINITY AVE	ROBERTSON BLVD	NE	\$220,400.00

4TH ST Total Cost for Street: \$2,083,540.25

Survey Street	Start Street	End Street	Orientation	
4TH ST	ALAMEDA AVE	SIDEWALK ENDS	SW	\$61,300.00
4TH ST	COLUSA AVE	MARIPOSA AVE	SW	\$166,803.00
4TH ST	KINGS AVE	ROBERTSON BLVD	SW	\$320,839.50
4TH ST	LAKE AVE	SIDEWALK ENDS	SW	\$115,648.50
4TH ST	MARIPOSA AVE	SIDEWALK ENDS	NE	\$46,440.00
4TH ST	MONTEREY AVE	LAKE AVE	SW	\$80,319.25
4TH ST	ORANGE AVE	TRINITY AVE	NE	\$133,110.00
4TH ST	RIVERSIDE AVE	SIDEWALK ENDS	NE	\$122,721.50
4TH ST	ROBERTSON BLVD	TRINITY AVE	SW	\$329,991.00
4TH ST	SIDEWALK BEGINS	SONOMA AVE	NE	\$183,615.00
4TH ST	SONOMA AVE	SIDEWALK ENDS	NE	\$91,756.50
4TH ST	TRINITY AVE	ROBERTSON BLVD	NE	\$430,996.00

5TH ST Total Cost for Street: \$2,554,292.00

Survey Street	Start Street	End Street	Orientation	
5TH ST	ALAMEDA AVE	HUMBOLDT AVE	NE	\$216,125.00
5TH ST	COLUSA AVE	SIDEWALK ENDS	SW	\$223,460.00
5TH ST	HUMBOLDT AVE	ORANGE AVE	NE	\$251,670.00
5TH ST	KINGS AVE	ROBERTSON BLVD	SW	\$250,685.50
5TH ST	LAKE AVE	MONTEREY AVE	NE	\$108,047.50
5TH ST	MONTEREY AVE	SONOMA AVE	NE	\$225,885.00
5TH ST	ORANGE AVE	TRINITY AVE	NE	\$236,435.00
5TH ST	RIVERSIDE AVE	LAKE AVE	NE	\$188,826.00
5TH ST	ROBERTSON BLVD	TRINITY AVE	SW	\$268,375.00
5TH ST	SIDEWALK BEGINS	COLUSA AVE	NE	\$156,015.00
5TH ST	SONOMA AVE	VENTURA AVE	NE	\$156,040.50
5TH ST	TRINITY AVE	ROBERTSON BLVD	NE	\$206,425.00
5TH ST	VENTURA AVE	SONOMA AVE	SW	\$66,302.50

6TH ST Total Cost for Street: \$1,553,018.25

Survey Street	Start Street	End Street	Orientation	
6TH ST	330 6TH ST	MONTEREY AVE	NE	\$210,023.00
6TH ST	HUMBOLDT AVE	ORANGE AVE	NE	\$158,809.50
6TH ST	KINGS AVE	ROBERTSON BLVD	SW	\$104,695.25
6TH ST	LAKE AVE	SIDEWALK ENDS	SW	\$99,495.00
6TH ST	MONTEREY AVE	LAKE AVE	SW	\$198,204.00
6TH ST	ORANGE AVE	TRINITY AVE	NE	\$86,180.00
6TH ST	RIVERSIDE AVE	SIDEWALK ENDS	NE	\$117,188.50
6TH ST	ROBERTSON BLVD	TRINITY AVE	SW	\$202,970.00
6TH ST	SIDEWALK BEGINS	SIDEWALK ENDS	NE	\$160,622.00
6TH ST	TRINITY AVE	ROBERTSON BLVD	NE	\$107,350.00

6TH ST	VENTURA AVE	SONOMA AVE	SW	\$107,481.00
--------	-------------	------------	----	--------------

7TH ST **Total Cost for Street: \$1,095,229.25**

Survey Street	Start Street	End Street	Orientation	
7TH ST	ALAMEDA AVE	HUMBOLDT AVE	NE	\$117,085.50
7TH ST	COLUSA AVE	SIDEWALK ENDS	SW	\$57,690.00
7TH ST	HUMBOLDT AVE	ORANGE AVE	NE	\$104,008.50
7TH ST	KINGS AVE	SIDEWALK ENDS	SW	\$11,401.50
7TH ST	ORANGE AVE	TRINITY AVE	NE	\$41,610.00
7TH ST	RIVERSIDE AVE	SIDEWALK ENDS	SW	\$35,244.00
7TH ST	ROBERTSON BLVD	KINGS AVE	NE	\$112,348.50
7TH ST	SIDEWALK BEGINS	VENTURA AVE	NE	\$424,370.75
7TH ST	SONOMA AVE	SIDEWALK ENDS	SW	\$49,450.50
7TH ST	TRINITY AVE	SIDEWALK ENDS	NE	\$142,020.00

8TH ST **Total Cost for Street: \$1,283,584.00**

Survey Street	Start Street	End Street	Orientation	
8TH ST	ALAMEDA AVE	HUMBOLDT AVE	NE	\$132,745.50
8TH ST	COLUSA AVE	SIDEWALK ENDS	SW	\$156,951.00
8TH ST	HUMBOLDT AVE	SIDEWALK ENDS	SW	\$293,530.50
8TH ST	KINGS AVE	ROBERTSON BLVD	SW	\$60,841.00
8TH ST	MONTEREY AVE	SIDEWALK ENDS	NE	\$42,130.00
8TH ST	ORANGE AVE	TRINITY AVE	NE	\$123,088.50
8TH ST	RIVERSIDE AVE	SIDEWALK ENDS	SW	\$66,440.00
8TH ST	ROBERTSON BLVD	SIDEWALK ENDS	SW	\$72,219.00
8TH ST	SIDEWALK BEGINS	SIDEWALK ENDS	NE	\$204,870.50
8TH ST	TRINITY AVE	SIDEWALK ENDS	SW	\$123,750.00
8TH ST	VENTURA AVE	SIDEWALK ENDS	SW	\$7,018.00

9TH ST **Total Cost for Street: \$997,335.25**

Survey Street	Start Street	End Street	Orientation	
9TH ST	HUMBOLDT AVE	ORANGE AVE	NE	\$94,207.50
9TH ST	KINGS AVE	SIDEWALK ENDS	NE	\$137,596.25
9TH ST	LAKE AVE	SIDEWALK ENDS	SW	\$33,316.25
9TH ST	MONTEREY AVE	SIDEWALK ENDS	SW	\$14,960.00
9TH ST	ORANGE AVE	TRINITY AVE	NE	\$109,062.00
9TH ST	RIVERSIDE AVE	SIDEWALK ENDS	SW	\$5,483.50
9TH ST	ROBERTSON BLVD	TRINITY AVE	SW	\$143,273.25
9TH ST	SIDEWALK BEGINS	VENTURA AVE	NE	\$219,090.00
9TH ST	SONOMA AVE	SIDEWALK ENDS	NE	\$17,721.00
9TH ST	TRINITY AVE	SIDEWALK ENDS	SW	\$175,815.00
9TH ST	VENTURA AVE	SIDEWALK ENDS	SW	\$46,810.50

ACACIA CT **Total Cost for Street: \$249,525.00**

Survey Street	Start Street	End Street	Orientation	
ACACIA CT	KITES WAY	AUTUMN WAY	E	\$249,525.00

ADAMS DR **Total Cost for Street: \$125,785.00**

Survey Street	Start Street	End Street	Orientation	
ADAMS DR	COUNTRY WOOD SHOPPING	ROBERTSON BLVD	SW	\$26,925.00
ADAMS DR	SIDEWALK BEGINS	VERNAL DR	S	\$22,080.00
ADAMS DR	VERNAL DR	1 ADAMS DR	N	\$76,780.00

ALAMEDA AVE **Total Cost for Street: \$1,077,885.00**

ALAMEDA AVE	109 ALAMEDA AVE	1ST ST	SE	\$38,259.00
ALAMEDA AVE	121 ALAMEDA AVE	115 ALAMEDA AVE	SE	\$31,536.00
ALAMEDA AVE	12TH ST	SIDEWALK ENDS	NW	\$5,896.00
ALAMEDA AVE	13TH ST	12TH ST	SE	\$54,285.00
ALAMEDA AVE	14TH ST	SIDEWALK ENDS	NW	\$100,760.00
ALAMEDA AVE	15TH ST	SIDEWALK ENDS	SE	\$21,582.00
ALAMEDA AVE	213 ALAMEDA AVE	201 ALAMEDA AVE	SE	\$56,358.00
ALAMEDA AVE	2ND ST	212 ALAMEDA AVE	NW	\$51,570.00
ALAMEDA AVE	301 ALAMEDA AVE	3RD ST	SE	\$13,380.00
ALAMEDA AVE	3RD ST	221 ALAMEDA AVE	SE	\$13,875.00
ALAMEDA AVE	405 ALAMEDA AVE	4TH ST	SE	\$25,140.00
ALAMEDA AVE	408 ALAMEDA AVE	408 ALAMEDA AVE	NW	\$5,022.00
ALAMEDA AVE	416 ALAMEDA AVE	5TH ST	NW	\$42,228.00
ALAMEDA AVE	4TH ST	301 ALAMEDA AVE	SE	\$88,540.00
ALAMEDA AVE	517 ALAMEDA AVE	517 ALAMEDA AVE	SE	\$15,066.00
ALAMEDA AVE	5TH ST	6TH ST	NW	\$134,655.00
ALAMEDA AVE	6TH ST	7TH ST	NW	\$77,547.50
ALAMEDA AVE	705 ALAMEDA AVE	701 ALAMEDA AVE	SE	\$16,002.00
ALAMEDA AVE	717 ALAMEDA AVE	709 ALAMEDA AVE	SE	\$34,506.00
ALAMEDA AVE	7TH ST	8TH ST	NW	\$185,304.00
ALAMEDA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	NW	\$66,373.50

ALMA CT**Total Cost for Street: \$60,637.50**

Survey Street	Start Street	End Street	Orientation	
ALMA CT	VERTE ST	VERTE ST	W	\$60,637.50

ALMOND CT**Total Cost for Street: \$120,515.00**

Survey Street	Start Street	End Street	Orientation	
ALMOND CT	COTTONWOOD DR	COTTONWOOD DR	W	\$120,515.00

AMADOR ST**Total Cost for Street: \$304,100.00**

Survey Street	Start Street	End Street	Orientation	
AMADOR ST	CIRCLE DR	ROSEHILL DR	E	\$140,175.00
AMADOR ST	ROSEHILL DR	CIRCLE DR	W	\$163,925.00

AUTUMN WAY**Total Cost for Street: \$804,972.50**

Survey Street	Start Street	End Street	Orientation	
AUTUMN WAY	ACACIA CT	PARKRIDGE DR	E	\$106,260.00
AUTUMN WAY	CANAL DR	HOWELL RD	W	\$273,348.00
AUTUMN WAY	HOWELL RD	HOLIDAY WAY	E	\$340,564.50
AUTUMN WAY	PARKRIDGE DR	ROSE AVE	W	\$84,800.00

AVE 26**Total Cost for Street: \$3,419,322.50**

Survey Street	Start Street	End Street	Orientation	
AVE 26	CARLYLE WAY	S MONTGOMERY LAKE WAY	S	\$111,909.00
AVE 26	CLUBHOUSE DR	LAKES RV AND GOLF RESORT	S	\$83,415.00
AVE 26	FREEWAY ENTRANCE	CARLYLE WAY	S	\$106,176.00
AVE 26	GOLF DR W	SIDEWALK ENDS	S	\$594,510.00
AVE 26	LAKES RV AND GOLF	GOLF DR W	S	\$618,420.00
AVE 26	PARKING LOT ENTRANCE	S GENOA LAKE WAY	S	\$154,747.50
AVE 26	S FIG TREE BLVD	W GOLF DR	S	\$184,170.00
AVE 26	S GENOA LAKE WAY	S FIG TREE BLVD	S	\$452,902.50
AVE 26	S MONTGOMERY LAKE WAY	PARKING LOT ENTRANCE	S	\$233,482.50
AVE 26	W GOLF DR	W GOLF DR	S	\$879,590.00

BIDAN AVE**Total Cost for Street: \$304,042.50**

Survey Street	Start Street	End Street	Orientation	
BIDAN AVE	VERDONE ST	VERTE ST	N	\$170,322.50
BIDAN AVE	VERTE ST	VERDONE ST	S	\$133,720.00

BIRCH CT**Total Cost for Street: \$161,905.00**

Survey Street	Start Street	End Street	Orientation	
BIRCH CT	ELM AVE	ELM AVE	N	\$161,905.00

BLOSSOM DR**Total Cost for Street: \$77,462.00**

Survey Street	Start Street	End Street	Orientation	
BLOSSOM DR	CHESTNUT DR	SANTA CRUZ BLVD	S	\$33,946.00
BLOSSOM DR	SANTA CRUZ BLVD	CHESTNUT DR	N	\$43,516.00

CALAVERAS ST**Total Cost for Street: \$2,030,101.50**

Survey Street	Start Street	End Street	Orientation	
CALAVERAS ST	CALAVERAS ST	SIDEWALK ENDS	W	\$313,380.00
CALAVERAS ST	CALIFA DR	ROSEHILL DR	S	\$248,900.00
CALAVERAS ST	CIRCLE DR	SIDEWALK ENDS	S	\$595,930.50
CALAVERAS ST	DANNIELLE ST	PENNY ST	S	\$100,170.00
CALAVERAS ST	PENNY ST	CALIFA DR	S	\$276,625.00
CALAVERAS ST	ROSEHILL DR	CIRCLE DR	S	\$383,685.00
CALAVERAS ST	SIDEWALK BEGINS	ROSEHILL DR	W	\$43,155.00
CALAVERAS ST	VENTURA AVE	CIRCLE DR	N	\$68,256.00

CALIFA DR**Total Cost for Street: \$507,635.00**

Survey Street	Start Street	End Street	Orientation	
CALIFA DR	CALAVERAS ST	ROSEHILL DR	W	\$251,655.00
CALIFA DR	ROSEHILL DR	CALAVERAS ST	E	\$255,980.00

CAMELLIA DR**Total Cost for Street: \$69,434.75**

Survey Street	Start Street	End Street	Orientation	
CAMELLIA DR	CHESTNUT DR	SANTA CRUZ BLVD	S	\$41,830.25
CAMELLIA DR	SANTA CRUZ BLVD	CHESTNUT DR	N	\$27,604.50

CANAL DR**Total Cost for Street: \$476,917.00**

Survey Street	Start Street	End Street	Orientation	
CANAL DR	136 CANAL DR	148 CANAL DR	N	\$89,134.50
CANAL DR	144 GILL WAY	GILL WAY	S	\$13,366.50
CANAL DR	148 CANAL DR	AUTUMN WAY	N	\$170,509.50
CANAL DR	DEBORAH WAY	DOROTHY WAY	S	\$35,301.00
CANAL DR	DOROTHY WAY	136 CANAL DR	N	\$67,480.00
CANAL DR	GILL WAY	DEBORAH WAY	S	\$58,411.50
CANAL DR	HOLIDAY WAY	144 GILL WAY	S	\$42,714.00

CARLYLE WAY**Total Cost for Street: \$198,255.00**

Survey Street	Start Street	End Street	Orientation	
CARLYLE WAY	AVE 26	SIDEWALK ENDS	W	\$82,500.00
CARLYLE WAY	SIDEWALK BEGINS	AVE 26	E	\$115,755.00

CEDAR CT**Total Cost for Street: \$175,900.00**

Survey Street	Start Street	End Street	Orientation	
CEDAR CT	ELM AVE	ELM AVE	N	\$175,900.00

CHARLENE DR**Total Cost for Street: \$194,788.00**

Survey Street	Start Street	End Street	Orientation	
---------------	--------------	------------	-------------	--

CHARLENE DR	DEBORAH WAY	GILL WAY	N	\$84,272.50
CHARLENE DR	DOROTHY WAY	DEBORAH WAY	N	\$29,480.00
CHARLENE DR	GILL WAY	DOROTHY WAY	S	\$81,035.50

CHERRY CT**Total Cost for Street: \$204,942.50**

Survey Street	Start Street	End Street	Orientation	
CHERRY CT	SANTA CRUZ BLVD	SANTA CRUZ BLVD	E	\$204,942.50

CHERRY WAY**Total Cost for Street: \$192,860.00**

Survey Street	Start Street	End Street	Orientation	
CHERRY WAY	SANTA CRUZ BLVD	WALNUT WAY	N	\$107,700.00
CHERRY WAY	WALNUT WAY	SANTA CRUZ BLVD	S	\$85,160.00

CHESTNUT DR**Total Cost for Street: \$69,965.50**

Survey Street	Start Street	End Street	Orientation	
CHESTNUT DR	BLOSSOM DR	CAMELLIA DR	W	\$24,986.50
CHESTNUT DR	CAMELLIA DR	BLOSSOM DR	E	\$44,979.00

CHOWCHILLA BLVD**Total Cost for Street: \$1,268,539.50**

Survey Street	Start Street	End Street	Orientation	
CHOWCHILLA BLVD	PROSPERITY RD	SIDEWALK ENDS	W/S	\$449,775.00
CHOWCHILLA BLVD	ROBERTSON BLVD	SIDEWALK ENDS	NE	\$365,445.00
CHOWCHILLA BLVD	SIDEWALK BEGINS	UNNAMED ROAD	NE	\$166,174.50
CHOWCHILLA BLVD	UNNAMED ROAD	SIDEWALK ENDS	NE	\$287,145.00

CIRCLE DR**Total Cost for Street: \$1,523,007.00**

Survey Street	Start Street	End Street	Orientation	
CIRCLE DR	AMADOR ST	VENTURA AVE	W	\$138,888.00
CIRCLE DR	CALAVERAS ST	CALAVERAS ST	N	\$598,441.50
CIRCLE DR	VENTURA AVE	CALAVERAS ST	SE	\$785,677.50

CLUBHOUSE DR**Total Cost for Street: \$576,270.00**

Survey Street	Start Street	End Street	Orientation	
CLUBHOUSE DR	AVE 26	GRANITE FALLS WAY	W	\$291,600.00
CLUBHOUSE DR	GRANITE FALLS WAY	AVE 26	E	\$284,670.00

COLUSA AVE**Total Cost for Street: \$1,442,260.00**

Survey Street	Start Street	End Street	Orientation	
COLUSA AVE	105 COLUSA AVE	1ST ST	SE	\$24,588.00
COLUSA AVE	13TH ST	SIDEWALK ENDS	NW	\$131,521.50
COLUSA AVE	2ND ST	208 COLUSA AVE	NW	\$61,560.00
COLUSA AVE	3RD ST	4TH ST	NW	\$326,497.50
COLUSA AVE	4TH ST	5TH ST	NW	\$222,858.00
COLUSA AVE	517 COLUSA AVE	513 COLUSA AVE	SE	\$26,235.00
COLUSA AVE	5TH ST	4TH ST	SE	\$140,625.00
COLUSA AVE	7TH ST	8TH ST	NW	\$121,536.00
COLUSA AVE	8TH ST	709 COLUSA AVE	SE	\$84,258.00
COLUSA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	NW	\$302,581.00

CONADRIA AVE**Total Cost for Street: \$336,640.00**

Survey Street	Start Street	End Street	Orientation	
CONADRIA AVE	VERDONE ST	VERTE ST	N	\$177,055.00
CONADRIA AVE	VERTE ST	VERDONE ST	S	\$159,585.00

COOLIDGE AVE**Total Cost for Street: \$568,164.00**

Survey Street	Start Street	End Street	Orientation	
---------------	--------------	------------	-------------	--

COOLIDGE AVE	1524 COOLIDGE AVE	WILSON WAY	W	\$117,312.00
COOLIDGE AVE	1537 COOLIDGE AVE	15TH ST	E	\$279,476.00
COOLIDGE AVE	15TH ST	1524 COOLIDGE AVE	W	\$168,688.00
COOLIDGE AVE	WILSON WAY	1537 COOLIDGE AVE	E	\$2,688.00

CORDELIA AVE**Total Cost for Street: \$345,930.00**

Survey Street	Start Street	End Street	Orientation	
CORDELIA AVE	ALMA CT	KADOTA AVE	S	\$263,265.00
CORDELIA AVE	VERDONE ST	VERTE ST	N	\$82,665.00

COTTONWOOD DR**Total Cost for Street: \$773,120.00**

Survey Street	Start Street	End Street	Orientation	
COTTONWOOD DR	ALMOND CT	PARKRIDGE DR	W	\$116,535.00
COTTONWOOD DR	COTTONWOOD DR	PARKRIDGE DR	E	\$17,595.00
COTTONWOOD DR	HOWELL RD	PEACH CT	W	\$76,530.00
COTTONWOOD DR	JUNIPER CT	SPRUCE CT	E	\$118,950.00
COTTONWOOD DR	PARKRIDGE CT	JUNIPER CT	E	\$109,055.00
COTTONWOOD DR	PEACH DR	SPRUCE CT	W	\$157,905.00
COTTONWOOD DR	SPRUCE CT	PEACH DR	E	\$125,175.00
COTTONWOOD DR	WILLOW CT	ALMOND CT	W	\$51,375.00

CYPRESS LN**Total Cost for Street: \$463,547.50**

Survey Street	Start Street	End Street	Orientation	
CYPRESS LN	GILL WAY	HOLIDAY WAY	N	\$88,447.50
CYPRESS LN	HOLIDAY WAY	OLEANDER DR	N	\$178,807.50
CYPRESS LN	OLEANDER DR	THOMAS CHIDLAW DR	S	\$127,627.50
CYPRESS LN	THOMAS CHIDLAW DR	GILL WAY	S	\$68,665.00

DANNIELLE ST**Total Cost for Street: \$309,715.00**

Survey Street	Start Street	End Street	Orientation	
DANNIELLE ST	CALAVERAS ST	ROSEHILL DR	W	\$150,655.00
DANNIELLE ST	ROSEHILL DR	CALAVERAS ST	E	\$159,060.00

DEBORAH WAY**Total Cost for Street: \$192,176.00**

Survey Street	Start Street	End Street	Orientation	
DEBORAH WAY	CANAL DR	CHARLENE DR	W	\$128,836.00
DEBORAH WAY	CHARLENE DR	CANAL DR	E	\$63,340.00

DOROTHY WAY**Total Cost for Street: \$273,792.00**

Survey Street	Start Street	End Street	Orientation	
DOROTHY WAY	145 DOROTHY WAY	SIDEWALK ENDS	E	\$16,124.00
DOROTHY WAY	CANAL DR	CHARLENE DR	W	\$162,232.00
DOROTHY WAY	CHARLENE DR	HOWELL RD	W	\$10,980.00
DOROTHY WAY	HOWELL RD	145 DOROTHY WAY	E	\$77,012.00
DOROTHY WAY	SIDEWALK BEGINS	CANAL DR	W	\$7,444.00

ELM AVE**Total Cost for Street: \$1,418,467.50**

Survey Street	Start Street	End Street	Orientation	
ELM AVE	BIRCH CT	KITES WAY	N	\$111,000.00
ELM AVE	CEDAR CT	BIRCH CT	N	\$113,640.00
ELM AVE	KITES WAY	PHILLIP WAY	N	\$121,560.00
ELM AVE	MOLLY AVE	SANTA CRUZ BLVD	N	\$55,935.00
ELM AVE	OAK CT	CEDAR CT	N	\$108,180.00
ELM AVE	PHILLIP WAY	MOLLY AVE	N	\$153,440.00
ELM AVE	SANTA CRUZ BLVD	PINE ST	N	\$754,712.50

ENGLEWOOD AVE**Total Cost for Street: \$195,885.00**

Survey Street	Start Street	End Street	Orientation	
ENGLEWOOD AVE	SANTA CRUZ BLVD	SIDEWALK ENDS	N	\$123,185.00
ENGLEWOOD AVE	SIDEWALK BEGINS	SANTA CRUZ BLVD	S	\$72,700.00

FALLEN LEAF WAY**Total Cost for Street: \$434,362.50**

Survey Street	Start Street	End Street	Orientation	
FALLEN LEAF WAY	S LAKE TAHOE DR	SIDEWALK ENDS	E	\$332,947.50
FALLEN LEAF WAY	SIDEWALK BEGINS	S LAKE TAHOE DR	W	\$101,415.00

FRONT ST**Total Cost for Street: \$509,592.75**

Survey Street	Start Street	End Street	Orientation	
FRONT ST	KINGS AVE	ROBERTSON BLVD	SW	\$134,631.25
FRONT ST	ORANGE AVE	SIDEWALK ENDS	SW	\$15,601.50
FRONT ST	ROBERTSON BLVD	TRINITY AVE	SW	\$275,349.50
FRONT ST	SIDEWALK BEGINS	ROBERTSON BLVD	NE	\$84,010.50

GILL WAY**Total Cost for Street: \$607,223.00**

Survey Street	Start Street	End Street	Orientation	
GILL WAY	CANAL DR	HOWELL RD	W	\$61,956.00
GILL WAY	CHARLENE DR	CANAL DR	E	\$148,090.00
GILL WAY	CYPRESS LN	VENTURA AVE	W	\$31,515.00
GILL WAY	HOWELL RD	CYPRESS LN	W	\$116,027.00
GILL WAY	VENTURA AVE	HOWELL RD	E	\$249,635.00

GOLF DR W**Total Cost for Street: \$105,060.00**

Survey Street	Start Street	End Street	Orientation	
GOLF DR W	AVE 26	PRIVATE ROAD	W	\$76,065.00
GOLF DR W	PRIVATE ROAD	AVE 26	E	\$28,995.00

GRANITE FALLS WAY**Total Cost for Street: \$619,635.00**

Survey Street	Start Street	End Street	Orientation	
GRANITE FALLS WAY	CLUBHOUSE DR	GOLDEN SANDS WAY	S	\$275,220.00
GRANITE FALLS WAY	GOLDEN SANDS WAY	SIDEWALK ENDS	S	\$171,075.00
GRANITE FALLS WAY	SIDEWALK BEGINS	CLUBHOUSE DR	N	\$173,340.00

GRANT DR**Total Cost for Street: \$847,020.00**

Survey Street	Start Street	End Street	Orientation	
GRANT DR	TRUMAN DR	VERNAL DR	N	\$444,585.00
GRANT DR	VERNAL DR	TRUMAN DR	S	\$402,435.00

HARDING AVE**Total Cost for Street: \$190,663.00**

Survey Street	Start Street	End Street	Orientation	
HARDING AVE	1505 HARDING AVE	15TH ST	E	\$19,440.00
HARDING AVE	1517 HARDING AVE	1517 HARDING AVE	E	\$26,235.00
HARDING AVE	1520 HARDING AVE	1520 HARDING AVE	W	\$2,208.00
HARDING AVE	1528 HARDING AVE	1528 HARDING AVE	W	\$23,325.00
HARDING AVE	1529 HARDING AVE	1525 HARDING AVE	E	\$67,695.00
HARDING AVE	15TH ST	1508 HARDING AVE	W	\$22,576.00
HARDING AVE	SIDEWALK BEGINS	1509 HARDING AVE	E	\$10,656.00
HARDING AVE	WILSON WAY	525 HARDING AVE	E	\$18,528.00

HARRISON CT**Total Cost for Street: \$338,020.00**

Survey Street	Start Street	End Street	Orientation	
HARRISON CT	2102 HARRISON CT	JEFFERSON ST	W	\$169,560.00

HARRISON CT	JEFFERSON ST	2102 HARRISON CT	E	\$168,460.00
-------------	--------------	------------------	---	--------------

HOLIDAY WAY **Total Cost for Street: \$804,879.00**

Survey Street	Start Street	End Street	Orientation	
HOLIDAY WAY	813 HOLIDAY WAY	CYPRESS LN	W	\$63,153.00
HOLIDAY WAY	860 HOLIDAY WAY	813 HOLIDAY WAY	N	\$30,294.00
HOLIDAY WAY	CANAL DR	HOWELL RD	W	\$300,240.00
HOLIDAY WAY	CYPRESS LN	860 HOLIDAY WAY	E	\$93,042.00
HOLIDAY WAY	HOWELL RD	CANAL DR	E	\$318,150.00

HOOVER AVE **Total Cost for Street: \$516,914.00**

Survey Street	Start Street	End Street	Orientation	
HOOVER AVE	1529 HOOVER AVE	15TH ST	E	\$172,184.00
HOOVER AVE	15TH ST	WILSON WAY	W	\$266,634.00
HOOVER AVE	WILSON WAY	1529 HOOVER DR	E	\$78,096.00

HOSPITAL DR **Total Cost for Street: \$111,940.00**

Survey Street	Start Street	End Street	Orientation	
HOSPITAL DR	SIDEWALK BEGINS	SIDEWALK ENDS	W	\$111,940.00

HOWELL RD **Total Cost for Street: \$1,285,698.25**

Survey Street	Start Street	End Street	Orientation	
HOWELL RD	AUTUMN WAY	SIDEWALK ENDS	N	\$35,478.00
HOWELL RD	COTTONWOOD DR	SANTA CRUZ BLVD	S	\$206,607.50
HOWELL RD	DOROTHY WAY	GILL WAY	N	\$117,547.50
HOWELL RD	GILL WAY	VENTURA AVE	S	\$194,843.00
HOWELL RD	HOLIDAY WAY	AUTUMN WAY	N	\$94,446.00
HOWELL RD	OLEANDER DR	GILL WAY	S	\$286,467.50
HOWELL RD	SANTA CRUZ BLVD	SIDEWALK ENDS	N	\$222,692.25
HOWELL RD	SIDEWALK BEGINS	COTTONWOOD DR	S	\$99,896.50
HOWELL RD	VENTURA AVE	DOROTHY WAY	N	\$27,720.00

HUMBOLDT AVE **Total Cost for Street: \$2,276,370.50**

Survey Street	Start Street	End Street	Orientation	
HUMBOLDT AVE	10TH ST	11TH ST	NW	\$86,940.00
HUMBOLDT AVE	113 HUMBOLDT AVE	105 HUMBOLDT AVE	SE	\$41,900.00
HUMBOLDT AVE	11TH ST	8TH ST	SE	\$451,981.00
HUMBOLDT AVE	12TH ST	13TH ST	NW	\$122,366.00
HUMBOLDT AVE	13TH ST	14TH ST	NW	\$108,164.00
HUMBOLDT AVE	14TH ST	15TH ST	NW	\$150,502.50
HUMBOLDT AVE	15TH ST	14TH ST	SE	\$78,534.00
HUMBOLDT AVE	1ST ST	2ND ST	NW	\$102,208.50
HUMBOLDT AVE	27 HUMBOLDT AVE	23 HUMBOLDT AVE	SE	\$36,550.00
HUMBOLDT AVE	308 HUMBOLDT AVE	312 HUMBOLDT AVE	NW	\$0.00
HUMBOLDT AVE	309 HUMBOLDT AVE	3RD ST	SE	\$62,095.00
HUMBOLDT AVE	3RD ST	304 HUMBOLDT AVE	NW	\$126,847.50
HUMBOLDT AVE	405 HUMBOLDT AVE	405 HUMBOLDT AVE	SE	\$8,545.50
HUMBOLDT AVE	5TH ST	6TH ST	NW	\$83,180.00
HUMBOLDT AVE	6TH ST	7TH ST	NW	\$203,376.00
HUMBOLDT AVE	7TH ST	8TH ST	NW	\$214,455.00
HUMBOLDT AVE	8TH ST	9TH ST	NW	\$204,726.00
HUMBOLDT AVE	912 HUMBOLDT AVE	10TH ST	NW	\$47,425.50
HUMBOLDT AVE	9TH ST	908 HUMBOLDT AVE	NW	\$25,906.50
HUMBOLDT AVE	FRONT ST	10 HUMBOLDT AVE	NW	\$21,708.00

Survey Street	Start Street	End Street	Orientation	
HUMBOLDT AVE	SIDEWALK BEGINS	3RD ST	NW	\$98,959.50
JACKSON CT			Total Cost for Street:	\$161,085.00
JACKSON CT	TRUMAN DR	TRUMAN DR	W	\$161,085.00
JEFFERSON ST			Total Cost for Street:	\$545,235.00
JEFFERSON ST	HARRISON CT	LINCOLN AVE	N	\$107,700.00
JEFFERSON ST	LINCOLN AVE	TRUMAN DR	S	\$241,860.00
JEFFERSON ST	MADISON CT	HARRISON CT	N	\$96,315.00
JEFFERSON ST	TRUMAN DR	MADISON CT	N	\$99,360.00
JUNIPER CT			Total Cost for Street:	\$137,240.00
JUNIPER CT	576 JUNIPER CT	COTTONWOOD DR	N	\$48,795.00
JUNIPER CT	COTTONWOOD DR	574 JUNIPER CT	E / S	\$88,445.00
KADOTA AVE			Total Cost for Street:	\$56,460.00
KADOTA AVE	S FIG TREE BLVD	VERDONE ST	N	\$18,780.00
KADOTA AVE	VERDONE ST	S FIG TREE BLVD	S	\$37,680.00
KENNEDY CT			Total Cost for Street:	\$175,840.00
KENNEDY CT	2127 KENNEDY CT	PALM PKY	E	\$77,380.00
KENNEDY CT	PALM PKY	2127 KENNEDY CT	W	\$98,460.00
KINGS AVE			Total Cost for Street:	\$1,932,685.25
KINGS AVE	10TH ST	9TH ST	SE	\$70,438.50
KINGS AVE	11TH ST	SIDEWALK ENDS	NW	\$13,304.50
KINGS AVE	13TH ST	SIDEWALK ENDS	NW	\$94,402.00
KINGS AVE	1ST ST	SIDEWALK ENDS	NW	\$154,503.00
KINGS AVE	2ND ST	3RD ST	NW	\$156,194.50
KINGS AVE	3RD ST	4TH ST	NW	\$173,478.25
KINGS AVE	4TH ST	5TH ST	NW	\$245,667.50
KINGS AVE	5TH ST	SIDEWALK ENDS	SE	\$127,231.50
KINGS AVE	6TH ST	7TH ST	NW	\$173,206.00
KINGS AVE	7TH ST	8TH ST	NW	\$142,180.50
KINGS AVE	8TH ST	SIDEWALK ENDS	SE	\$53,999.00
KINGS AVE	9TH ST	8TH ST	SE	\$86,465.50
KINGS AVE	FRONT ST	SIDEWALK ENDS	E	\$142,750.50
KINGS AVE	SIDEWALK BEGINS	SIDEWALK ENDS	SE	\$298,864.00
KITES WAY			Total Cost for Street:	\$681,320.00
KITES WAY	ELM AVE	PISTACHIO CT	E	\$152,410.00
KITES WAY	PISTACHIO CT	ACACIA CT	E	\$203,925.00
KITES WAY	ROSE AVE	ELM AVE	W	\$324,985.00
LAKE AVE			Total Cost for Street:	\$771,221.00
LAKE AVE	10TH ST	9TH ST	SE	\$99,418.00
LAKE AVE	11TH ST	10TH ST	SE	\$57,596.00
LAKE AVE	13TH ST	SIDEWALK ENDS	NW	\$412.50

LAKE AVE	15TH ST	SIDEWALK ENDS	SE	\$43,494.00
LAKE AVE	2ND ST	SIDEWALK ENDS	SW	\$20,064.00
LAKE AVE	3RD ST	4TH ST	NW	\$67,468.50
LAKE AVE	4TH ST	3RD ST	SE	\$65,593.00
LAKE AVE	5TH ST	SIDEWALK ENDS	SE	\$1,270.50
LAKE AVE	6TH ST	7TH ST	NW	\$32,048.50
LAKE AVE	7TH ST	8TH ST	NW	\$62,073.00
LAKE AVE	8TH ST	9TH ST	NW	\$53,226.25
LAKE AVE	9TH ST	8TH ST	SE	\$129,747.75
LAKE AVE	SIDEWALK BEGINS	SIDEWALK ENDS	SE	\$138,809.00

LARK AVE**Total Cost for Street: \$349,557.50**

Survey Street	Start Street	End Street	Orientation	
LARK AVE	PINE ST	ROSE AVE	S/E	\$171,162.50
LARK AVE	ROSE AVE	PINE ST	W/N	\$178,395.00

LINCOLN AVE**Total Cost for Street: \$681,680.00**

Survey Street	Start Street	End Street	Orientation	
LINCOLN AVE	2142 LINCOLN AVE	SIDEWALK ENDS	W	\$1,800.00
LINCOLN AVE	JEFFERSON ST	PALM PKY	E	\$161,255.00
LINCOLN AVE	PALM PKY	SIDEWALK ENDS	E	\$366,385.00
LINCOLN AVE	SIDEWALK BEGINS	PALM PKY	W	\$152,240.00

MADISON CT**Total Cost for Street: \$306,210.00**

Survey Street	Start Street	End Street	Orientation	
MADISON CT	JEFFERSON ST	JEFFERSON ST	N	\$306,210.00

MAGNOLIA CT**Total Cost for Street: \$143,315.00**

Survey Street	Start Street	End Street	Orientation	
MAGNOLIA CT	1607 MAGNOLIA CT	THOMAS CHIDLAW DR	W /	\$74,815.00
MAGNOLIA CT	THOMAS CHIDLAW DR	1606 MAGNOLIA CT	N /	\$68,500.00

MAPLE ST**Total Cost for Street: \$370,495.00**

Survey Street	Start Street	End Street	Orientation	
MAPLE ST	ELM AVE	WASHINGTON RD	W	\$145,735.00
MAPLE ST	WASHINGTON RD	OAK CT	E	\$224,760.00

MARIPOSA AVE**Total Cost for Street: \$467,501.50**

Survey Street	Start Street	End Street	Orientation	
MARIPOSA AVE	14TH ST	15TH ST	NW	\$107,371.00
MARIPOSA AVE	1ST ST	3RD ST	NW	\$202,032.00
MARIPOSA AVE	3RD ST	4TH ST	NW	\$119,191.50
MARIPOSA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	NW	\$38,907.00

MICHELLE CT**Total Cost for Street: \$79,720.00**

Survey Street	Start Street	End Street	Orientation	
MICHELLE CT	888 MICHELLE CT	ROSEHILL DR	E	\$36,980.00
MICHELLE CT	ROSEHILL DR	888 MICHELLE CT	W	\$42,740.00

MISSION AVE**Total Cost for Street: \$27,510.00**

Survey Street	Start Street	End Street	Orientation	
MISSION AVE	S GENOA LAKE WAY	VERTE ST	S	\$11,535.00
MISSION AVE	VERTE ST	S GENOA LAKE WAY	N	\$15,975.00

MOLLY AVE**Total Cost for Street: \$528,195.00**

Survey Street	Start Street	End Street	Orientation	
---------------	--------------	------------	-------------	--

MOLLY AVE	342 MOLLY AVE	ELM AVE	W	\$185,080.00
MOLLY AVE	ELM AVE	PHILLIP WAY	E/S	\$251,825.00
MOLLY AVE	PHILLIP WAY	342 MOLLY AVE	N	\$91,290.00

MONROE CT**Total Cost for Street: \$227,280.00**

Survey Street	Start Street	End Street	Orientation	
MONROE CT	2003 MONROE CT	PALM PKY	W	\$118,360.00
MONROE CT	PALM PKY	2003 MONROE CT	E	\$108,920.00

MONTEREY AVE**Total Cost for Street: \$1,295,551.50**

Survey Street	Start Street	End Street	Orientation	
MONTEREY AVE	10TH ST	SIDEWALK ENDS	NW	\$43,994.50
MONTEREY AVE	11TH ST	SIDEWALK ENDS	NW	\$21,516.00
MONTEREY AVE	13TH ST	11TH ST	SE	\$200,783.00
MONTEREY AVE	2ND ST	3RD ST	NW	\$144,204.50
MONTEREY AVE	3RD ST	SIDEWALK ENDS	NW	\$29,491.00
MONTEREY AVE	4TH ST	SIDEWALK ENDS	SE	\$100,270.50
MONTEREY AVE	5TH ST	SIDEWALK ENDS	SE	\$50,060.00
MONTEREY AVE	6TH ST	7TH ST	NW	\$96,228.00
MONTEREY AVE	7TH ST	6TH ST	SE	\$43,417.00
MONTEREY AVE	8TH ST	7TH ST	SE	\$61,611.00
MONTEREY AVE	SIDEWALK BEGINS	SIDEWALK ENDS	SE	\$503,976.00

MYER ST**Total Cost for Street: \$943,215.00**

Survey Street	Start Street	End Street	Orientation	
MYER ST	KITES WAY	SIDEWALK ENDS	S	\$347,040.00
MYER ST	ROBERTSON BLVD	KITES WAY	N	\$596,175.00

N FIG TREE BLVD**Total Cost for Street: \$206,340.00**

Survey Street	Start Street	End Street	Orientation	
N FIG TREE BLVD	AVE 26	S LAKE TAHOE DR	E	\$111,412.50
N FIG TREE BLVD	S LAKE TAHOE DR	AVE 26	W	\$94,927.50

OAK CT**Total Cost for Street: \$240,810.00**

Survey Street	Start Street	End Street	Orientation	
OAK CT	ELM AVE	ELM AVE	N	\$240,810.00

OLEANDER DR**Total Cost for Street: \$494,167.50**

Survey Street	Start Street	End Street	Orientation	
OLEANDER DR	CYPRESS LN	HOWELL RD	E	\$68,665.00
OLEANDER DR	HOWELL RD	PEACH DR	W	\$9,307.50
OLEANDER DR	PARKRIDGE DR	CYPRESS LN	E	\$155,110.00
OLEANDER DR	PEACH DR	PARKRIDGE DR	W	\$261,085.00

ORANGE AVE**Total Cost for Street: \$2,274,740.00**

Survey Street	Start Street	End Street	Orientation	
ORANGE AVE	1004 ORANGE AVE	11TH ST	NW	\$56,559.00
ORANGE AVE	10TH ST	917 ORANGE AVE	SE	\$18,846.00
ORANGE AVE	11 ORANGE AVE	FRONT ST	SE	\$21,073.50
ORANGE AVE	1105 ORANGE AVE	1105 ORANGE AVE	SE	\$19,062.00
ORANGE AVE	11TH ST	13TH ST	NW	\$397,555.00
ORANGE AVE	1205 ORANGE AVE	1205 ORANGE AVE	SE	\$2,015.00
ORANGE AVE	1217 ORANGE AVE	1209 ORANGE AVE	SE	\$48,915.00
ORANGE AVE	12TH ST	SIDEWALK ENDS	SE	\$45,270.00
ORANGE AVE	1305 ORANGE AVE	13TH ST	SE	\$12,597.00

ORANGE AVE	13TH ST	14TH ST	NW	\$51,043.50
ORANGE AVE	14TH ST	15TH ST	NW	\$72,942.75
ORANGE AVE	15TH ST	14TH ST	SE	\$65,649.75
ORANGE AVE	1ST ST	3RD ST	NW	\$515,880.00
ORANGE AVE	23 ORANGE AVE	SIDEWALK ENDS	SE	\$2,722.50
ORANGE AVE	2ND ST	1ST ST	SE	\$128,722.50
ORANGE AVE	3RD ST	4TH ST	NW	\$157,979.00
ORANGE AVE	4TH ST	5TH ST	NW	\$215,017.50
ORANGE AVE	5TH ST	6TH ST	NW	\$114,745.00
ORANGE AVE	6TH ST	7TH ST	NW	\$115,900.00
ORANGE AVE	7TH ST	8TH ST	NW	\$44,950.00
ORANGE AVE	8TH ST	9TH ST	NW	\$148,630.00
ORANGE AVE	908 ORANGE AVE	912 ORANGE AVE	NW	\$10,250.00
ORANGE AVE	917 ORANGE AVE	909 ORANGE AVE	SE	\$8,415.00

PALM PKY

Total Cost for Street: \$1,331,315.00

Survey Street	Start Street	End Street	Orientation	
PALM PKY	KENNEDY CT	LINCOLN AVE	S	\$42,180.00
PALM PKY	LINCOLN AVE	SIDEWALK ENDS	S	\$322,340.00
PALM PKY	MONROE CT	TAFT CT	N	\$108,795.00
PALM PKY	ROBERTSON BLVD	KENNEDY CT	S	\$279,120.00
PALM PKY	SIDEWALK BEGINS	TRUMAN DR	N	\$403,380.00
PALM PKY	TRUMAN DR	SIDEWALK ENDS	S	\$175,500.00

PARKRIDGE CT

Total Cost for Street: \$135,340.00

Survey Street	Start Street	End Street	Orientation	
PARKRIDGE CT	COTTONWOOD DR	COTTONWOOD DR	W	\$135,340.00

PARKRIDGE DR

Total Cost for Street: \$1,107,685.00

Survey Street	Start Street	End Street	Orientation	
PARKRIDGE DR	AUTUMN WAY	THOMAS CHIDLAW DR	S	\$105,735.00
PARKRIDGE DR	COTTONWOOD DR	PINE ST	SE	\$118,360.00
PARKRIDGE DR	OLEANDER DR	SANTA CRUZ BLVD	N	\$127,115.00
PARKRIDGE DR	PINE ST	SANTA CRUZ BLVD	S	\$93,585.00
PARKRIDGE DR	SANTA CRUZ BLVD	COTTONWOOD DR	N	\$522,815.00
PARKRIDGE DR	THOMAS CHIDLAW DR	OLEANDER DR	N	\$140,075.00

PEACH CT

Total Cost for Street: \$69,977.50

Survey Street	Start Street	End Street	Orientation	
PEACH CT	605 PEACH CT	COTTONWOOD DR	S	\$39,920.00
PEACH CT	COTTONWOOD DR	608 PEACH CT	N /	\$30,057.50

PEACH DR

Total Cost for Street: \$901,375.00

Survey Street	Start Street	End Street	Orientation	
PEACH DR	COTTONWOOD DR	SANTA CRUZ BLVD	S	\$209,932.50
PEACH DR	OLEANDER DR	SANTA CRUZ BLVD	N	\$197,217.50
PEACH DR	SANTA CRUZ BLVD	OLEANDER DR	S	\$494,225.00

PENNY ST

Total Cost for Street: \$365,470.00

Survey Street	Start Street	End Street	Orientation	
PENNY ST	CALAVERAS ST	ROSEHILL DR	W	\$145,150.00
PENNY ST	ROSEHILL DR	CALAVERAS ST	E	\$220,320.00

PHILLIP CT

Total Cost for Street: \$140,480.00

Survey Street	Start Street	End Street	Orientation	
---------------	--------------	------------	-------------	--

PHILLIP CT	104 PHILLIP CT	PHILLIP WAY	S	\$74,780.00
PHILLIP CT	PHILLIP WAY	104 PHILLIP CT	N	\$65,700.00

PHILLIP WAY**Total Cost for Street: \$655,995.00**

Survey Street	Start Street	End Street	Orientation	
PHILLIP WAY	ELM AVE	ROSE AVE	E	\$297,015.00
PHILLIP WAY	MOLLY AVE	PHILLIP CT	W	\$103,500.00
PHILLIP WAY	PHILLIP CT	ELM AVE	W	\$140,760.00
PHILLIP WAY	ROSE AVE	MOLLY AVE	W	\$114,720.00

PINE CT**Total Cost for Street: \$210,860.00**

Survey Street	Start Street	End Street	Orientation	
PINE CT	309 PINE CT	PINE ST	N	\$156,235.00
PINE CT	PINE ST	309 PINE CT	S	\$54,625.00

PINE ST**Total Cost for Street: \$963,950.00**

Survey Street	Start Street	End Street	Orientation	
PINE ST	133 PINE ST	SANTA CRUZ BLVD	W/S	\$296,117.50
PINE ST	ELM AVE	PINE CT	E	\$119,220.00
PINE ST	LARK AVE	ROSE AVE	E	\$118,140.00
PINE ST	PARKRIDGE DR	133 PINE ST	W	\$172,127.50
PINE ST	PINE CT	LARK AVE	E	\$130,320.00
PINE ST	ROSE AVE	PARKRIDGE DR	E	\$128,025.00

PISTACHIO CT**Total Cost for Street: \$239,854.00**

Survey Street	Start Street	End Street	Orientation	
PISTACHIO CT	KITES WAY	KITES WAY	E	\$239,854.00

PLUM CT**Total Cost for Street: \$235,375.00**

Survey Street	Start Street	End Street	Orientation	
PLUM CT	SANTA CRUZ BLVD	SANTA CRUZ BLVD	E	\$235,375.00

PLUM WAY**Total Cost for Street: \$226,847.50**

Survey Street	Start Street	End Street	Orientation	
PLUM WAY	SANTA CRUZ BLVD	WALNUT WAY	N	\$90,077.50
PLUM WAY	WALNUT WAY	SANTA CRUZ BLVD	S	\$136,770.00

PROSPERITY RD**Total Cost for Street: \$1,411,645.00**

Survey Street	Start Street	End Street	Orientation	
PROSPERITY RD	SIDEWALK BEGINS	SIDEWALK ENDS	E/S	\$1,411,645.00

RD 15 1/2**Total Cost for Street: \$153,263.00**

Survey Street	Start Street	End Street	Orientation	
RD 15 1/2	MARIPOSA AVE	COLUSA AVE	NE	\$95,634.00
RD 15 1/2	TRUMAN DR	SIDEWALK ENDS	SW	\$57,629.00

RIVERSIDE AVE**Total Cost for Street: \$1,551,799.75**

Survey Street	Start Street	End Street	Orientation	
RIVERSIDE AVE	11TH ST	13TH ST	NW	\$316,882.50
RIVERSIDE AVE	13TH ST	14TH ST	NW	\$115,802.50
RIVERSIDE AVE	14TH ST	15TH ST	NW	\$122,578.50
RIVERSIDE AVE	15TH ST	14TH ST	SE	\$52,624.00
RIVERSIDE AVE	2ND ST	SIDEWALK ENDS	SE	\$128,133.50
RIVERSIDE AVE	3RD ST	SIDEWALK ENDS	SE	\$122,267.75
RIVERSIDE AVE	4TH ST	5TH ST	NW	\$78,958.00
RIVERSIDE AVE	5TH ST	6TH ST	NW	\$120,571.00

RIVERSIDE AVE	6TH ST	5TH ST	SE	\$67,171.50
RIVERSIDE AVE	7TH ST	SIDEWALK ENDS	NW	\$32,802.00
RIVERSIDE AVE	8TH ST	SIDEWALK ENDS	SE	\$84,106.00
RIVERSIDE AVE	SIDEWALK BEGINS	SIDEWALK ENDS	SE	\$309,902.50

ROBERTSON BLVD**Total Cost for Street: \$5,654,626.50**

Survey Street	Start Street	End Street	Orientation	
ROBERTSON BLVD	10TH ST	9TH ST	SE	\$135,414.00
ROBERTSON BLVD	11TH ST	13TH ST	NW	\$373,608.00
ROBERTSON BLVD	13TH ST	15TH ST	NW	\$212,280.00
ROBERTSON BLVD	14TH ST	13TH ST	SE	\$120,600.00
ROBERTSON BLVD	1520 ROBERTSON BLVD	WASHINGTON RD	NW	\$59,520.00
ROBERTSON BLVD	1567 ROBERTSON BLVD	1567 ROBERTSON BLVD	SE	\$21,240.00
ROBERTSON BLVD	15TH ST	14TH ST	SE	\$30,336.00
ROBERTSON BLVD	1ST ST	FRONT ST	SE	\$368,112.00
ROBERTSON BLVD	2ND ST	3RD ST	NW	\$605,632.00
ROBERTSON BLVD	3RD ST	4TH ST	NW	\$504,714.00
ROBERTSON BLVD	4TH ST	5TH ST	NW	\$421,964.00
ROBERTSON BLVD	5TH ST	6TH ST	NW	\$231,894.00
ROBERTSON BLVD	6TH ST	7TH ST	NW	\$236,376.00
ROBERTSON BLVD	7TH ST	8TH ST	NW	\$113,796.00
ROBERTSON BLVD	8TH ST	9TH ST	NW	\$228,024.00
ROBERTSON BLVD	9TH ST	8TH ST	SE	\$187,014.00
ROBERTSON BLVD	CHOWCHILLA BLVD	SIDEWALK ENDS	SE	\$645,670.50
ROBERTSON BLVD	COUNTRY WOOD SHOPPING	MYER ST	NW	\$76,110.00
ROBERTSON BLVD	DOLLAR TREE PARKING	COUNTRY WOOD SHOPPING	S/W/	\$149,100.00
ROBERTSON BLVD	FRONT ST	CHOWCHILLA BLVD	SE	\$589,845.00
ROBERTSON BLVD	SCHOETTLER TIRE	15TH ST	SE	\$66,978.00
ROBERTSON BLVD	SIDEWALK BEGINS	SIDEWALK ENDS	N	\$276,399.00

ROBERTSON-TRINITY ALLEY**Total Cost for Street: \$101,004.75**

Survey Street	Start Street	End Street	Orientation	
ROBERTSON-TRINITY ALLEY	3RD ST	2ND ST	SE	\$101,004.75

ROOSEVELT DR**Total Cost for Street: \$1,444,578.00**

Survey Street	Start Street	End Street	Orientation	
ROOSEVELT DR	1512 ROOSEVELT DR	WASHINGTON DR	W	\$268,124.00
ROOSEVELT DR	15TH ST	1512 ROOSEVELT DR	W	\$99,712.00
ROOSEVELT DR	ADAMS DR	WASHINGTON DR	E	\$26,040.00
ROOSEVELT DR	ROOSEVELT DR	TRUMAN DR	S	\$296,205.00
ROOSEVELT DR	TRUMAN DR	ROOSEVELT DR	N	\$329,425.00
ROOSEVELT DR	WASHINGTON DR	WILSON WAY	E	\$136,252.00
ROOSEVELT DR	WILSON WAY	15TH ST	E	\$288,820.00

ROSE AVE**Total Cost for Street: \$737,020.00**

Survey Street	Start Street	End Street	Orientation	
ROSE AVE	AUTUMN WAY	SANTA CRUZ BLVD	N	\$210,230.00
ROSE AVE	LARK AVE	SANTA CRUZ BLVD	S	\$50,250.00
ROSE AVE	PHILLIP WAY	KITES WAY	S	\$108,255.00
ROSE AVE	PINE ST	LARK AVE	S	\$103,360.00
ROSE AVE	SANTA CRUZ BLVD	PINE ST	N	\$264,925.00

ROSEHILL DR**Total Cost for Street: \$1,427,610.00**

Survey Street	Start Street	End Street	Orientation	
---------------	--------------	------------	-------------	--

ROSEHILL DR	AMADOR ST	CALAVERAS ST	SE	\$481,480.00
ROSEHILL DR	CALAVERAS ST	MICHELLE CT	S	\$439,440.00
ROSEHILL DR	CALIFA DR	PENNY ST	N	\$162,900.00
ROSEHILL DR	DANNIELLE ST	CALAVERAS ST	N	\$110,700.00
ROSEHILL DR	MICHELLE CT	AMADOR ST	S	\$148,515.00
ROSEHILL DR	PENNY ST	DANNIELLE ST	N	\$84,575.00

S FIG TREE BLVD**Total Cost for Street: \$575,645.00**

Survey Street	Start Street	End Street	Orientation	
S FIG TREE BLVD	AVE 26	SIDEWALK ENDS	W	\$406,977.50
S FIG TREE BLVD	SIDEWALK BEGINS	S MONTGOMERY LAKE WAY	W	\$117,712.50
S FIG TREE BLVD	START OF PARKING LOT	END OF PARKING LOT	W	\$50,955.00

S GENOA LAKE WAY**Total Cost for Street: \$860,107.50**

Survey Street	Start Street	End Street	Orientation	
S GENOA LAKE WAY	AVE 26	PARKING LOT ENTRANCE	W	\$159,311.25
S GENOA LAKE WAY	CURB RAMP	PARKING LOT ENTRANCE	W	\$87,097.50
S GENOA LAKE WAY	PARKING LOT ENTRANCE	S MONTGOMERY LAKE WAY	W	\$282,712.50
S GENOA LAKE WAY	SIDEWALK BEGINS	AVE 26	E	\$330,986.25

S LAKE TAHOE DR**Total Cost for Street: \$259,485.00**

Survey Street	Start Street	End Street	Orientation	
S LAKE TAHOE DR	FALLEN LEAF WAY	SIDEWALK ENDS	N	\$44,685.00
S LAKE TAHOE DR	N FIG TREE BLVD	FALLEN LEAF WAY	N	\$45,675.00
S LAKE TAHOE DR	SIDEWALK BEGINS	N FIG TREE BLVD	S	\$169,125.00

S MONTGOMERY LAKE WAY**Total Cost for Street: \$2,529,672.75**

Survey Street	Start Street	End Street	Orientation	
S MONTGOMERY LAKE WAY	AUTO PARK PLACE	SIDEWALK ENDS	W	\$94,176.00
S MONTGOMERY LAKE WAY	AVE 26	AUTO PARK PLACE	W	\$563,463.00
S MONTGOMERY LAKE WAY	PARKING LOT ENTRANCE	PARKING LOT ENTRANCE	E	\$241,515.00
S MONTGOMERY LAKE WAY	S FIG TREE BLVD	SIDEWALK ENDS	NE	\$429,450.00
S MONTGOMERY LAKE WAY	S GENOA LAKE WAY	SIDEWALK ENDS	SW	\$552,101.25
S MONTGOMERY LAKE WAY	SAVE MART PHARMACY	PARKING LOT ENTRANCE	E	\$122,985.00
S MONTGOMERY LAKE WAY	SIDEWALK BEGINS	SIDEWALK ENDS	SW	\$525,982.50

SANTA CRUZ BLVD**Total Cost for Street: \$1,526,415.00**

Survey Street	Start Street	End Street	Orientation	
SANTA CRUZ BLVD	BLOSSOM DR	CAMELLIA DR	W	\$71,676.00
SANTA CRUZ BLVD	CAMELLIA DR	HOWELL RD	W	\$54,466.50
SANTA CRUZ BLVD	CHERRY CT	PLUM CT	E	\$42,870.00
SANTA CRUZ BLVD	CHERRY WAY	PARKRIDGE DR	W	\$86,025.00
SANTA CRUZ BLVD	ELM AVE	ROSE AVE	E	\$196,860.00
SANTA CRUZ BLVD	ENGLEWOOD AVE	WASHINGTON RD	W	\$41,790.00
SANTA CRUZ BLVD	HOWELL RD	PEACH DR	W	\$91,710.00
SANTA CRUZ BLVD	PARKRIDGE DR	ROSE AVE	W	\$121,380.00
SANTA CRUZ BLVD	PEACH DR	PLUM CT	W	\$141,060.00
SANTA CRUZ BLVD	PINE ST	ENGLEWOOD AVE	W	\$83,130.00
SANTA CRUZ BLVD	PLUM CT	PEACH DR	E	\$23,032.50
SANTA CRUZ BLVD	PLUM WAY	CHERRY WAY	W	\$67,830.00
SANTA CRUZ BLVD	ROSE AVE	PARKRIDGE DR	E	\$432,555.00
SANTA CRUZ BLVD	WASHINGTON RD	ELM AVE	E	\$72,030.00

SHASTA CT**Total Cost for Street: \$175,887.50**

SHASTA CT	WASHINGTON RD	WASHINGTON RD	N	\$175,887.50
-----------	---------------	---------------	---	--------------

SONOMA AVE **Total Cost for Street: \$539,044.00**

Survey Street	Start Street	End Street	Orientation	
SONOMA AVE	11TH ST	SIDEWALK ENDS	SE	\$24,838.00
SONOMA AVE	12TH ST	SIDEWALK ENDS	NW	\$8,096.00
SONOMA AVE	3RD ST	SIDEWALK ENDS	NW	\$16,813.50
SONOMA AVE	4TH ST	SIDEWALK ENDS	SE	\$114,644.75
SONOMA AVE	6TH ST	SIDEWALK ENDS	NW	\$47,025.00
SONOMA AVE	7TH ST	SIDEWALK ENDS	NW	\$8,558.00
SONOMA AVE	9TH ST	SIDEWALK ENDS	NW	\$51,906.25
SONOMA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	S	\$267,162.50

SPRUCE CT **Total Cost for Street: \$156,235.00**

Survey Street	Start Street	End Street	Orientation	
SPRUCE CT	COTTONWOOD DR	COTTONWOOD DR	E	\$156,235.00

TAFT CT **Total Cost for Street: \$220,035.00**

Survey Street	Start Street	End Street	Orientation	
TAFT CT	2010 TAFT CT	PALM PKY	W	\$66,500.00
TAFT CT	PALM PKY	2006 TAFT CT	E	\$153,535.00

THOMAS CHIDLAW DR **Total Cost for Street: \$436,340.00**

Survey Street	Start Street	End Street	Orientation	
THOMAS CHIDLAW DR	CYPRESS LN	MAGNOLIA CT	W	\$107,700.00
THOMAS CHIDLAW DR	MAGNOLIA CT	PARKRIDGE DR	W	\$100,120.00
THOMAS CHIDLAW DR	PARKRIDGE DR	CYPRESS LN	E	\$228,520.00

TRINITY AVE **Total Cost for Street: \$2,424,549.25**

Survey Street	Start Street	End Street	Orientation	
TRINITY AVE	1001 TRINITY AVE	10TH ST	SE	\$6,135.00
TRINITY AVE	10TH ST	9TH ST	SE	\$43,825.00
TRINITY AVE	13TH ST	SIDEWALK ENDS	NW	\$23,496.00
TRINITY AVE	14TH ST	SIDEWALK ENDS	NW	\$120,202.50
TRINITY AVE	15TH ST	SIDEWALK ENDS	SE	\$47,382.50
TRINITY AVE	1ST ST	SIDEWALK ENDS	SE	\$418,518.00
TRINITY AVE	2ND ST	3RD ST	SE	\$371,685.00
TRINITY AVE	3RD ST	4TH ST	NW	\$339,840.00
TRINITY AVE	4TH ST	5TH ST	NW	\$208,026.00
TRINITY AVE	5TH ST	6TH ST	NW	\$119,283.75
TRINITY AVE	6TH ST	7TH ST	NW	\$191,895.00
TRINITY AVE	7TH ST	8TH ST	NW	\$95,865.00
TRINITY AVE	804 TRINITY AVE	9TH ST	NW	\$52,930.00
TRINITY AVE	805 TRINITY AVE	8TH ST	SE	\$8,355.00
TRINITY AVE	809 TRINITY AVE	809 TRINITY AVE	SE	\$7,035.00
TRINITY AVE	8TH ST	7TH ST	SE	\$59,170.00
TRINITY AVE	9TH ST	813 TRINITY AVE	SE	\$168,710.00
TRINITY AVE	FRONT ST	1ST ST	NW	\$78,544.00
TRINITY AVE	SIDEWALK BEGINS	SIDEWALK ENDS	NW	\$63,651.50

TRUMAN DR **Total Cost for Street: \$1,428,006.00**

Survey Street	Start Street	End Street	Orientation	
TRUMAN DR	1513 TRUMAN DR	15TH ST	E	\$39,232.00
TRUMAN DR	1537 TRUMAN DR	FREE WILL BAPTIST CHURCH	E	\$30,600.00
TRUMAN DR	15TH ST	SIDEWALK ENDS	W	\$24,942.00

TRUMAN DR	ADAMS DR	WILSON WAY	E	\$205,015.00
TRUMAN DR	GRANT DR	VAN BUREN ST	W	\$86,540.00
TRUMAN DR	JACKSON CT	PALM PKY	W	\$45,020.00
TRUMAN DR	JEFFERSON ST	PALM PKY	E	\$167,210.00
TRUMAN DR	PALM PKY	JEFFERSON ST	W	\$520,055.00
TRUMAN DR	SIDEWALK BEGINS	WASHINGTON DR	W	\$203,632.00
TRUMAN DR	VAN BUREN ST	JACKSON CT	W	\$79,720.00
TRUMAN DR	WASHINGTON DR	ADAMS DR	W	\$26,040.00

VAN BUREN ST**Total Cost for Street: \$68,775.00**

Survey Street	Start Street	End Street	Orientation	
VAN BUREN ST	SIDEWALK BEGINS	TRUMAN DR	S	\$23,415.00
VAN BUREN ST	TRUMAN DR	SIDEWALK ENDS	N	\$45,360.00

VENTURA AVE**Total Cost for Street: \$2,763,117.50**

Survey Street	Start Street	End Street	Orientation	
VENTURA AVE	10TH ST	9TH ST	SE	\$119,108.00
VENTURA AVE	11TH ST	11TH ST	SE	\$232,628.00
VENTURA AVE	13TH ST	12TH ST	SE	\$99,995.50
VENTURA AVE	14TH ST	13TH ST	SE	\$63,844.00
VENTURA AVE	15TH ST	14TH ST	SE	\$56,787.50
VENTURA AVE	4TH ST	3RD ST	SE	\$141,185.00
VENTURA AVE	5TH ST	4TH ST	SE	\$121,836.00
VENTURA AVE	6TH ST	5TH ST	SE	\$123,299.00
VENTURA AVE	7TH ST	6TH ST	SE	\$131,983.50
VENTURA AVE	8TH ST	7TH ST	SE	\$125,554.00
VENTURA AVE	9TH ST	8TH ST	SE	\$134,640.00
VENTURA AVE	CALAVERAS ST	CIRCLE DR	NW	\$704,247.50
VENTURA AVE	CIRCLE DR	HOSPITAL DR	NW	\$245,745.50
VENTURA AVE	HOSPITAL DR	HOWELL RD	NW	\$168,960.00
VENTURA AVE	HOWELL RD	GILL WAY	NW	\$293,304.00

VERDONE ST**Total Cost for Street: \$191,125.00**

Survey Street	Start Street	End Street	Orientation	
VERDONE ST	BIDAN AVE	CORDELIA AVE	W	\$59,670.00
VERDONE ST	CONADRIA AVE	BIDAN AVE	W	\$40,740.00
VERDONE ST	KADOTA AVE	CONADRIA AVE	E	\$90,715.00

VERNAL DR**Total Cost for Street: \$268,902.50**

Survey Street	Start Street	End Street	Orientation	
VERNAL DR	ADAMS DR	GRANT DR	W	\$79,300.00
VERNAL DR	GRANT DR	WASHINGTON DR	E	\$139,867.50
VERNAL DR	WASHINGTON DR	ADAMS DR	W	\$49,735.00

VERTE ST**Total Cost for Street: \$143,387.50**

Survey Street	Start Street	End Street	Orientation	
VERTE ST	BIDAN AVE	CONADRIA AVE	E	\$34,042.50
VERTE ST	CONADRIA AVE	MISSION AVE	W	\$51,975.00
VERTE ST	CORDELIA AVE	BIDAN AVE	E	\$35,280.00
VERTE ST	MISSION AVE	ALMA CT	W	\$22,090.00

W GOLF DR**Total Cost for Street: \$207,375.00**

Survey Street	Start Street	End Street	Orientation	
W GOLF DR	AVE 26	PRIVATE ROAD	W	\$124,395.00
W GOLF DR	PRIVATE ROAD	AVE 26	E	\$82,980.00

WALNUT WAY**Total Cost for Street: \$181,130.00**

Survey Street	Start Street	End Street	Orientation	
WALNUT WAY	PLUM WAY	CHERRY WAY	W	\$181,130.00

WASHINGTON DR**Total Cost for Street: \$694,750.00**

Survey Street	Start Street	End Street	Orientation	
WASHINGTON DR	ROOSEVELT DR	VERNAL DR	N	\$339,130.00
WASHINGTON DR	TRUMAN DR	ROOSEVELT DR	N	\$303,990.00
WASHINGTON DR	VERNAL DR	ROOSEVELT DR	S	\$51,630.00

WASHINGTON RD**Total Cost for Street: \$1,577,807.50**

Survey Street	Start Street	End Street	Orientation	
WASHINGTON RD	1520 ROBERTSON BLVD	DEFENDER ST	N	\$113,100.00
WASHINGTON RD	DEFENDER ST	SIDEWALK ENDS	N	\$28,095.00
WASHINGTON RD	KITES WAY	DEFENDER ST	S	\$581,927.50
WASHINGTON RD	MAPLE ST	SHASTA CT	N	\$339,990.00
WASHINGTON RD	ROBERTSON BLVD	1520 ROBERTSON RD	N	\$45,865.00
WASHINGTON RD	SANTA CRUZ BLVD	WASHINGTON RD	N	\$39,125.00
WASHINGTON RD	SHASTA CT	SANTA CRUZ BLVD	N	\$343,440.00
WASHINGTON RD	SIDEWALK BEGINS	MAPLE ST	N	\$86,265.00

WILLOW CT**Total Cost for Street: \$54,335.00**

Survey Street	Start Street	End Street	Orientation	
WILLOW CT	COTTONWOOD DR	COTTONWOOD DR	W	\$54,335.00

WILSON WAY**Total Cost for Street: \$733,421.38**

Survey Street	Start Street	End Street	Orientation	
WILSON WAY	COOLIDGE AVE	HOOVER AVE	N	\$133,436.00
WILSON WAY	HOOVER AVE	ROOSEVELT DR	N	\$132,192.00
WILSON WAY	ROOSEVELT DR	360 WILSON WAY	S	\$380,484.00
WILSON WAY	SIDEWALK BEGINS	COOLIDGE AVE	N	\$35,160.00
WILSON WAY	TRUMAN DR	HARDING AVE	N	\$52,149.38

Total Cost for County Sidewalks: \$99,502,998.38



SURVEY DATA



Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	1908200944	ROBERTSON BLVD	SIDEWALK BEGINS	CHOWCHILLA BLVD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
215	0.0 to 35.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	266	SF	\$120	\$31,950	
42748	6.0 to 7.0 feet	Vertical Change	-.66	8 ft	8	REF			
44598	22.9 to 23.9 feet	Vertical Change	-.54	8 ft	8	REF			
41850	30.8 to 31.8 feet	Vertical Change	-.81	8 ft	8	REF			
53821	35.0 to 36.0 feet	Vertical Change	-.25	8 ft	8	REF			
219	35.5 to 50.4 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	112	SF	\$120	\$13,410	
57698	45.8 to 94.4 feet	Driveway				REF			
46078	49.7 to 50.7 feet	Vertical Change	-.47	8 ft	8	REF			
221	55.5 to 72.4 feet	Cross Slope (PAR)	7.0-8.0%	8 ft	127	SF	\$120	\$15,210	
223	72.4 to 76.1 feet	Cross Slope (Driveway)	5.0-6.0%	8 ft	28	SF	\$40	\$1,110	
224	76.1 to 90.7 feet	Cross Slope (Driveway)	6.0-7.0%	8 ft	110	SF	\$40	\$4,380	
39960	90.4 to 91.9 feet	Running Slope	5.0-6.0%	8 ft	11	REF			
46296	95.7 to 96.7 feet	Vertical Change	-.46	8 ft	8	LF	\$75	\$563	
225	97.5 to 158.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	456	SF	\$120	\$54,720	
53289	132.1 to 134.8 feet	Vertical Change	-.26	8 ft	20	REF			
43212	134.2 to 135.2 feet	Vertical Change	-.62	8 ft	8	REF			
53290	162.0 to 163.0 feet	Vertical Change	-.26	8 ft	8	LF	\$75	\$563	
48386	170.8 to 171.8 feet	Vertical Change	-.38	8 ft	8	LF	\$75	\$563	
230	178.9 to 195.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	128	SF	\$120	\$15,300	
48952	185.7 to 186.7 feet	Vertical Change	-.36	8 ft	8	REF			
50595	198.9 to 199.9 feet	Vertical Change	-.31	8 ft	8	LF	\$75	\$563	
49239	207.3 to 208.3 feet	Vertical Change	-.35	8 ft	8	LF	\$75	\$563	
231	209.0 to 224.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	119	SF	\$120	\$14,220	
48387	215.7 to 216.7 feet	Vertical Change	-.38	8 ft	8	REF			
48388	223.8 to 224.8 feet	Vertical Change	-.38	8 ft	8	REF			
TOTAL COST FOR: NW							<i>side of</i> ROBERTSON BLVD	<i>Starting at:</i> SIDEWALK BEGINS	\$153,112.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority		
NE	1908200948	CHOWCHILLA BLVD	ROBERTSON BLVD	SIDEWALK ENDS					TBD		
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
234	0.0 to 19.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	144	SF	\$120	\$17,280			
1	0.8 to 1.8 feet	Continuous Width		8 ft	8	SF	\$120	\$900			
46978	4.0 to 5.0 feet	Vertical Change	-.43	8 ft	8	REF					
57699	13.8 to 61.6 feet	Driveway				REF					
52326	17.0 to 18.0 feet	Vertical Change	-.28	8 ft	8	REF					
237	21.2 to 59.7 feet	Cross Slope (Driveway)	7.0-8.0%	8 ft	289	SF	\$40	\$11,550			
46526	39.9 to 40.9 feet	Vertical Change	-.45	8 ft	8	REF					
39961	57.5 to 59.4 feet	Running Slope	5.0-6.0%	8 ft	14	REF					
240	62.7 to 108.0 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	340	SF	\$120	\$40,770			
47450	62.9 to 63.9 feet	Vertical Change	-.41	8 ft	8	REF					
49240	74.6 to 75.6 feet	Vertical Change	-.35	8 ft	8	REF					
53291	91.7 to 92.7 feet	Vertical Change	-.26	8 ft	8	REF					
52327	96.2 to 97.2 feet	Vertical Change	-.28	8 ft	8	REF					
57700	104.6 to 152.6 feet	Driveway				REF					
47451	107.1 to 108.1 feet	Vertical Change	-.41	8 ft	8	REF					
243	111.1 to 136.7 feet	Cross Slope (Driveway)	8.0-9.0%	8 ft	192	SF	\$40	\$7,680			
48103	130.1 to 131.1 feet	Vertical Change	-.39	8 ft	8	REF					
245	136.7 to 148.8 feet	Cross Slope (Driveway)	6.0-7.0%	8 ft	91	SF	\$40	\$3,630			
39962	148.1 to 150.0 feet	Running Slope	6.0-7.0%	8 ft	14	REF					
249	148.8 to 150.5 feet	Cross Slope (Driveway)	8.0-9.0%	8 ft	13	SF	\$40	\$510			
43090	153.2 to 154.2 feet	Vertical Change	-.63	8 ft	8	REF					
250	153.7 to 197.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	331	SF	\$120	\$39,690			
42107	169.8 to 170.8 feet	Vertical Change	-.74	8 ft	8	REF					
TOTAL COST FOR: NE							<i>side of</i>	CHOWCHILLA BLVD	<i>Starting at:</i>	ROBERTSON BLVD	\$122,010.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	1908200951	CHOWCHILLA BLVD	SIDEWALK BEGINS	ROBERTSON BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
255	0.0 to 24.0 feet	Cross Slope (PAR)	3.0-4.0%	8 ft	180	SF	\$120	\$21,600	
41784	18.5 to 19.5 feet	Vertical Change	-.85	8 ft	8	REF			
54128	18.6 to 19.6 feet	Vertical Change	.25	8 ft	8	REF			
46297	21.3 to 25.0 feet	Vertical Change	-.46	8 ft	28	REF			
258	24.0 to 34.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	76	SF	\$120	\$9,090	
57701	27.6 to 91.2 feet	Driveway				REF			
42108	31.0 to 32.0 feet	Vertical Change	-.74	8 ft	8	REF			
261	34.1 to 53.8 feet	Cross Slope (Driveway)	4.0-5.0%	8 ft	148	SF	\$40	\$5,910	
42650	46.7 to 47.7 feet	Vertical Change	-.67	8 ft	8	REF			
263	53.8 to 54.8 feet	Cross Slope (Driveway)	6.0-7.0%	8 ft	8	SF	\$40	\$300	
264	54.8 to 67.3 feet	Cross Slope (Driveway)	5.0-6.0%	8 ft	94	SF	\$40	\$3,750	
41641	61.6 to 62.6 feet	Vertical Change	-.93	8 ft	8	REF			
265	67.3 to 84.8 feet	Cross Slope (Driveway)	6.0-7.0%	8 ft	131	SF	\$40	\$5,250	
49882	77.3 to 78.3 feet	Vertical Change	-.33	8 ft	8	REF			
266	84.8 to 89.7 feet	Cross Slope (Driveway)	5.0-6.0%	8 ft	37	SF	\$40	\$1,470	
268	89.7 to 90.7 feet	Cross Slope (Driveway)	3.0-4.0%	8 ft	8	SF	\$40	\$300	
269	90.7 to 91.8 feet	Cross Slope (Driveway)	2.0-3.0%	8 ft	8	SF	\$40	\$330	
270	96.5 to 124.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	207	SF	\$120	\$24,840	
52328	98.2 to 99.2 feet	Vertical Change	-.28	8 ft	8	REF			
44599	98.3 to 101.5 feet	Vertical Change	-.54	8 ft	24	REF			
43361	107.0 to 108.0 feet	Vertical Change	-.61	8 ft	8	REF			
42364	124.6 to 125.6 feet	Vertical Change	-.7	8 ft	8	SF	\$75	\$563	
272	128.0 to 133.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	38	SF	\$120	\$4,590	
57702	129.1 to 179.3 feet	Driveway				REF			
45873	132.2 to 133.2 feet	Vertical Change	-.48	8 ft	8	REF			
274	135.7 to 175.9 feet	Cross Slope (Driveway)	7.0-8.0%	8 ft	302	SF	\$40	\$12,060	
46979	147.2 to 148.2 feet	Vertical Change	-.43	8 ft	8	REF			
46298	163.4 to 164.4 feet	Vertical Change	-.46	8 ft	8	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1908200951	CHOWCHILLA BLVD	SIDEWALK BEGINS	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39963	174.5 to 176.8 feet	Running Slope	6.0-7.0%	8 ft	17	REF		
280	175.9 to 177.9 feet	Cross Slope (Driveway)	5.0-6.0%	8 ft	15	SF	\$40	\$600
282	177.9 to 193.6 feet	Cross Slope (Driveway)	3.0-4.0%	8 ft	118	SF	\$40	\$4,710
44012	178.3 to 179.3 feet	Vertical Change	-.57	8 ft	8	REF		
44388	188.5 to 189.5 feet	Vertical Change	-.55	8 ft	8	REF		
TOTAL COST FOR: SW side of CHOWCHILLA BLVD Starting at: SIDEWALK BEGINS							\$95,362.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908201003	ROBERTSON BLVD	CHOWCHILLA BLVD	FRONT ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
2	0.5 to 1.5 feet	Continuous Width		7 ft	7	SF	\$120	\$780	
285	0.9 to 39.0 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	248	SF	\$120	\$29,718	
49884	4.0 to 5.0 feet	Vertical Change	-33	7 ft	7	REF			
53292	13.7 to 14.7 feet	Vertical Change	-26	7 ft	7	REF			
48389	18.4 to 19.4 feet	Vertical Change	-38	7 ft	7	REF			
3	24.6 to 25.6 feet	Continuous Width		7 ft	7	SF	\$120	\$780	
48953	25.6 to 26.6 feet	Vertical Change	-36	7 ft	7	REF			
289	39.0 to 126.7 feet	Cross Slope (PAR)	4.0-5.0%	7 ft	570	SF	\$120	\$68,406	
43213	39.7 to 40.7 feet	Vertical Change	-62	7 ft	7	REF			
41493	42.3 to 43.3 feet	Vertical Change	-1.1	7 ft	7	REF			
49561	48.9 to 49.9 feet	Vertical Change	-34	7 ft	7	REF			
48390	58.9 to 62.3 feet	Vertical Change	-38	7 ft	22	REF			
53822	69.0 to 70.0 feet	Vertical Change	-25	7 ft	7	REF			
50596	79.0 to 80.0 feet	Vertical Change	-31	7 ft	7	REF			
45183	99.1 to 100.1 feet	Vertical Change	-51	7 ft	7	REF			
51910	109.2 to 110.2 feet	Vertical Change	-29	7 ft	7	REF			
46079	119.0 to 120.0 feet	Vertical Change	-47	7 ft	7	REF			
297	126.7 to 146.3 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	127	SF	\$120	\$15,288	
49885	129.3 to 130.3 feet	Vertical Change	-33	7 ft	7	REF			
44600	139.0 to 140.0 feet	Vertical Change	-54	7 ft	7	REF			
299	146.3 to 186.9 feet	Cross Slope (PAR)	4.0-5.0%	7 ft	264	SF	\$120	\$31,668	
42651	149.1 to 150.1 feet	Vertical Change	-67	7 ft	7	REF			
45874	159.0 to 160.0 feet	Vertical Change	-48	7 ft	7	REF			
42969	168.9 to 169.9 feet	Vertical Change	-64	7 ft	7	REF			
44808	179.1 to 180.1 feet	Vertical Change	-53	7 ft	7	REF			
301	186.9 to 212.8 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	168	SF	\$120	\$20,202	
42169	189.1 to 190.1 feet	Vertical Change	-73	7 ft	7	REF			
43091	199.0 to 200.0 feet	Vertical Change	-63	7 ft	7	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908201003	ROBERTSON BLVD	CHOWCHILLA BLVD	FRONT ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
41514	209.1 to 210.1 feet	Vertical Change	-1.07	7 ft	7	REF			
303	212.8 to 246.3 feet	Cross Slope (PAR)	4.0-5.0%	7 ft	218	SF	\$120	\$26,130	
41642	219.0 to 220.0 feet	Vertical Change	-.93	7 ft	7	REF			
57334	219.0 to 220.0 feet	Vertical Change	.94	7 ft	7	REF			
42029	229.1 to 230.1 feet	Vertical Change	-.76	7 ft	7	REF			
45454	237.8 to 238.8 feet	Vertical Change	-.5	7 ft	7	REF			
41228	240.0 to 241.0 feet	Vertical Change	-2.05	7 ft	7	REF			
46980	240.2 to 241.2 feet	Vertical Change	-.43	7 ft	7	REF			
307	246.3 to 247.3 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	7	SF	\$120	\$780	
42865	247.1 to 248.1 feet	Vertical Change	-.65	7 ft	7	REF			
41656	247.3 to 248.3 feet	Vertical Change	-.92	7 ft	7	REF			
52798	248.1 to 249.1 feet	Vertical Change	-.27	7 ft	7	LF	\$75	\$488	
57377	249.0 to 250.0 feet	Vertical Change	1.09	7 ft	7	REF			
47864	249.3 to 250.3 feet	Vertical Change	-.4	7 ft	7	REF			
308	249.9 to 280.2 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	197	SF	\$120	\$23,634	
50597	259.0 to 260.0 feet	Vertical Change	-.31	7 ft	7	REF			
4	266.2 to 267.2 feet	Continuous Width		7 ft	7	SF	\$120	\$780	
48954	269.1 to 270.1 feet	Vertical Change	-.36	7 ft	7	REF			
41297	275.2 to 276.2 feet	Vertical Change	-1.58	7 ft	7	REF			
55949	275.4 to 276.4 feet	Vertical Change	.33	7 ft	7	REF			
57703	276.9 to 314.4 feet	Driveway				REF			
42109	277.8 to 278.8 feet	Vertical Change	-.74	7 ft	7	REF			
45184	284.7 to 285.7 feet	Vertical Change	-.51	7 ft	7	SF	\$75	\$488	
41411	286.3 to 287.3 feet	Vertical Change	-1.24	7 ft	7	SF	\$75	\$488	
41612	287.0 to 288.0 feet	Vertical Change	-.96	7 ft	7	SF	\$75	\$488	
57425	287.2 to 288.2 feet	Vertical Change	1.21	7 ft	7	SF	\$75	\$488	
41214	287.4 to 288.4 feet	Vertical Change	-2.2	7 ft	7	SF	\$75	\$488	
57509	287.7 to 288.7 feet	Vertical Change	1.77	7 ft	7	SF	\$75	\$488	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908201003	ROBERTSON BLVD	CHOWCHILLA BLVD	FRONT ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
41261	291.9 to 292.9 feet	Vertical Change	-1.76	7 ft	7	SF	\$75	\$488	
57522	292.2 to 293.2 feet	Vertical Change	1.99	7 ft	7	SF	\$75	\$488	
41475	292.4 to 293.4 feet	Vertical Change	-1.12	7 ft	7	SF	\$75	\$488	
57296	292.6 to 293.6 feet	Vertical Change	.88	7 ft	7	SF	\$75	\$488	
41247	302.1 to 303.1 feet	Vertical Change	-1.87	7 ft	7	SF	\$75	\$488	
57543	302.3 to 303.3 feet	Vertical Change	2.18	7 ft	7	SF	\$75	\$488	
41221	306.6 to 307.6 feet	Vertical Change	-2.11	7 ft	7	SF	\$75	\$488	
57531	306.8 to 307.8 feet	Vertical Change	2.09	7 ft	7	SF	\$75	\$488	
41246	307.0 to 308.0 feet	Vertical Change	-1.89	7 ft	7	SF	\$75	\$488	
313	318.2 to 390.5 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	470	SF	\$120	\$56,394	
41887	318.9 to 319.9 feet	Vertical Change	-.8	7 ft	7	REF			
42652	328.9 to 329.9 feet	Vertical Change	-.67	7 ft	7	REF			
41630	339.2 to 340.2 feet	Vertical Change	-.94	7 ft	7	REF			
43685	349.4 to 350.4 feet	Vertical Change	-.59	7 ft	7	REF			
56972	349.5 to 350.5 feet	Vertical Change	.57	7 ft	7	REF			
46300	359.4 to 360.4 feet	Vertical Change	-.46	7 ft	7	REF			
48391	369.6 to 370.6 feet	Vertical Change	-.38	7 ft	7	REF			
43092	379.8 to 380.8 feet	Vertical Change	-.63	7 ft	7	REF			
45455	389.9 to 390.9 feet	Vertical Change	-.5	7 ft	7	REF			
318	399.3 to 402.0 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	18	SF	\$120	\$2,106	
49562	400.4 to 401.4 feet	Vertical Change	-.34	7 ft	7	REF			
47201	410.4 to 411.4 feet	Vertical Change	-.42	7 ft	7	LF	\$75	\$488	
52799	420.5 to 421.5 feet	Vertical Change	-.27	7 ft	7	LF	\$75	\$488	
319	425.7 to 452.5 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	174	SF	\$120	\$20,904	
47202	430.4 to 431.4 feet	Vertical Change	-.42	7 ft	7	REF			
48662	440.4 to 441.4 feet	Vertical Change	-.37	7 ft	7	REF			
51911	450.6 to 451.6 feet	Vertical Change	-.29	7 ft	7	REF			
47865	460.9 to 461.9 feet	Vertical Change	-.4	7 ft	7	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1908201003	ROBERTSON BLVD	CHOWCHILLA BLVD	FRONT ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
320	461.4 to 476.0 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	95	SF	\$120	\$11,388
44389	472.4 to 475.4 feet	Vertical Change	-.55	7 ft	20	REF		
323	480.3 to 520.6 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	262	SF	\$120	\$31,434
48955	499.7 to 500.7 feet	Vertical Change	-.36	7 ft	7	REF		
52329	509.6 to 510.6 feet	Vertical Change	-.28	7 ft	7	REF		
50598	519.8 to 520.8 feet	Vertical Change	-.31	7 ft	7	REF		
328	524.6 to 529.3 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	31	SF	\$120	\$3,666
329	537.4 to 579.8 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	276	SF	\$120	\$33,072
47866	539.9 to 540.9 feet	Vertical Change	-.4	7 ft	7	REF		
49563	560.0 to 561.0 feet	Vertical Change	-.34	7 ft	7	REF		
51912	569.9 to 570.9 feet	Vertical Change	-.29	7 ft	7	REF		
41969	580.0 to 581.0 feet	Vertical Change	-.78	7 ft	7	SF	\$75	\$488
330	584.0 to 608.1 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	157	SF	\$120	\$18,798
49886	589.8 to 590.8 feet	Vertical Change	-.33	7 ft	7	REF		
41851	599.8 to 600.8 feet	Vertical Change	-.81	7 ft	7	REF		
46981	619.6 to 620.6 feet	Vertical Change	-.43	7 ft	7	REF		
331	620.6 to 623.3 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	18	SF	\$120	\$2,106
332	625.6 to 628.9 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	21	SF	\$120	\$2,574
TOTAL COST FOR: NW side of ROBERTSON BLVD Starting at: CHOWCHILLA BLVD								\$409,870.50

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1908201009	FRONT ST	ROBERTSON BLVD	KINGS AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
333	0.0 to 8.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,676	
335	8.6 to 18.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	54	SF	\$120	\$6,534	
42536	9.0 to 12.0 feet	Vertical Change	-.68	6 ft	17	REF			
46764	15.9 to 22.2 feet	Vertical Change	-.44	6 ft	35	REF			
339	18.5 to 48.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	164	SF	\$120	\$19,668	
41970	22.7 to 23.7 feet	Vertical Change	-.78	6 ft	6	REF			
48663	22.9 to 23.9 feet	Vertical Change	-.37	6 ft	6	REF			
54160	32.0 to 33.0 feet	Vertical Change	.29	6 ft	6	REF			
57704	44.9 to 83.6 feet	Driveway				REF			
49887	47.5 to 48.5 feet	Vertical Change	-.33	6 ft	6	REF			
342	52.3 to 81.4 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	160	SF	\$40	\$6,402	
52800	67.6 to 68.6 feet	Vertical Change	-.27	6 ft	6	REF			
49241	75.5 to 76.5 feet	Vertical Change	-.35	6 ft	6	REF			
39965	79.2 to 80.4 feet	Running Slope	7.0-8.0%	6 ft	7	REF			
43686	83.5 to 84.5 feet	Vertical Change	-.59	6 ft	6	REF			
344	84.3 to 85.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$220	
345	90.4 to 95.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564	
52801	93.5 to 94.5 feet	Vertical Change	-.27	6 ft	6	REF			
53294	98.9 to 99.9 feet	Vertical Change	-.26	6 ft	6	REF			
56615	99.0 to 100.0 feet	Vertical Change	.4	6 ft	6	REF			
346	99.3 to 104.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,366	
52802	102.6 to 104.3 feet	Vertical Change	-.27	6 ft	9	REF			
348	108.2 to 129.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	117	SF	\$120	\$14,058	
42970	111.8 to 112.8 feet	Vertical Change	-.64	6 ft	6	REF			
46527	128.8 to 129.8 feet	Vertical Change	-.45	6 ft	6	REF			
49564	133.2 to 134.2 feet	Vertical Change	-.34	6 ft	6	LF	\$75	\$413	
48664	139.5 to 142.0 feet	Vertical Change	-.37	6 ft	14	LF	\$75	\$1,031	
49242	150.2 to 151.9 feet	Vertical Change	-.35	6 ft	9	LF	\$75	\$701	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1908201009	FRONT ST	ROBERTSON BLVD	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
349	157.3 to 209.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	289	SF	\$120	\$34,650
45875	158.8 to 159.8 feet	Vertical Change	-.48	6 ft	6	REF		
44602	163.2 to 164.2 feet	Vertical Change	-.54	6 ft	6	REF		
51498	166.6 to 167.6 feet	Vertical Change	-.3	6 ft	6	REF		
42454	166.8 to 167.8 feet	Vertical Change	-.69	6 ft	6	REF		
51499	166.8 to 167.8 feet	Vertical Change	-.3	6 ft	6	REF		
47204	171.7 to 172.7 feet	Vertical Change	-.42	6 ft	6	REF		
49565	180.4 to 181.4 feet	Vertical Change	-.34	6 ft	6	REF		
53823	189.8 to 194.5 feet	Vertical Change	-.25	6 ft	26	REF		
42971	201.2 to 202.2 feet	Vertical Change	-.64	6 ft	6	REF		
57705	206.3 to 243.4 feet	Driveway				REF		
41225	208.6 to 209.6 feet	Vertical Change	-2.09	6 ft	6	REF		
353	213.2 to 214.4 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	7	SF	\$40	\$264
354	215.3 to 238.3 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	127	SF	\$40	\$5,060
44603	217.7 to 218.7 feet	Vertical Change	-.54	6 ft	6	REF		
49243	226.7 to 227.7 feet	Vertical Change	-.35	6 ft	6	REF		
46982	235.4 to 236.4 feet	Vertical Change	-.43	6 ft	6	REF		
356	238.3 to 241.1 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	15	SF	\$40	\$616
39966	238.8 to 239.8 feet	Running Slope	6.0-7.0%	6 ft	6	REF		
358	244.2 to 257.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	73	SF	\$120	\$8,712
41189	244.8 to 245.8 feet	Vertical Change	-2.63	6 ft	6	REF		
46301	244.8 to 245.8 feet	Vertical Change	-.46	6 ft	6	REF		
51500	252.3 to 253.3 feet	Vertical Change	-.3	6 ft	6	REF		
359	257.4 to 265.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346
52331	259.9 to 261.1 feet	Vertical Change	-.28	6 ft	7	REF		
48665	263.8 to 270.5 feet	Vertical Change	-.37	6 ft	37	REF		
360	269.1 to 277.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,676
46765	274.6 to 275.6 feet	Vertical Change	-.44	6 ft	6	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1908201009	FRONT ST	ROBERTSON BLVD	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
361	281.7 to 296.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	80	SF	\$120	\$9,570
50223	283.5 to 284.5 feet	Vertical Change	-0.32	6 ft	6	REF		
41327	283.7 to 284.7 feet	Vertical Change	-1.46	6 ft	6	REF		
46983	284.4 to 285.4 feet	Vertical Change	-0.43	6 ft	6	REF		
41279	285.2 to 286.2 feet	Vertical Change	-1.65	6 ft	6	REF		
49567	285.4 to 286.4 feet	Vertical Change	-0.34	6 ft	6	REF		
41462	289.6 to 290.6 feet	Vertical Change	-1.13	6 ft	6	REF		
45456	296.3 to 297.3 feet	Vertical Change	-0.5	6 ft	6	SF	\$75	\$413
TOTAL COST FOR: NE side of FRONT ST Starting at: ROBERTSON BLVD							\$131,939.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908201013	KINGS AVE	FRONT ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
53295	0.0 to 1.0 feet	Vertical Change	-.26	6 ft	6	LF	\$75	\$413
44013	0.2 to 1.2 feet	Vertical Change	-.57	6 ft	6	SF	\$75	\$413
362	3.5 to 90.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	476	SF	\$120	\$57,156
45185	7.1 to 8.1 feet	Vertical Change	-.51	6 ft	6	REF		
49888	19.2 to 20.2 feet	Vertical Change	-.33	6 ft	6	REF		
48105	66.1 to 67.1 feet	Vertical Change	-.39	6 ft	6	REF		
48394	74.7 to 75.7 feet	Vertical Change	-.38	6 ft	6	REF		
5	88.1 to 89.1 feet	Continuous Width		6 ft	6	SF	\$120	\$660
53296	94.9 to 95.9 feet	Vertical Change	-.26	6 ft	6	LF	\$75	\$413
41235	95.1 to 96.1 feet	Vertical Change	-1.99	6 ft	6	SF	\$75	\$413
41361	96.6 to 97.6 feet	Vertical Change	-1.37	6 ft	6	SF	\$75	\$413
52804	97.8 to 101.8 feet	Vertical Change	-.27	6 ft	22	LF	\$75	\$1,650
57706	97.8 to 127.8 feet	Driveway				REF		
373	105.7 to 125.2 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	107	SF	\$40	\$4,290
45671	110.3 to 111.3 feet	Vertical Change	-.49	6 ft	6	REF		
39967	123.3 to 125.8 feet	Running Slope	6.0-7.0%	6 ft	14	REF		
375	138.8 to 147.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,412
52805	143.2 to 144.2 feet	Vertical Change	-.27	6 ft	6	REF		
6	144.1 to 145.1 feet	Continuous Width		6 ft	6	SF	\$120	\$660
TOTAL COST FOR: E side of KINGS AVE Starting at: FRONT ST							\$71,890.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SW	1908201023	FRONT ST	KINGS AVE	ROBERTSON BLVD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
376	14.9 to 28.3 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	87	SF	\$120	\$10,452	
377	32.8 to 42.3 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	62	SF	\$120	\$7,410	
39968	47.0 to 49.8 feet	Running Slope	5.0-6.0%	7 ft	18	SF	\$120	\$2,184	
378	50.8 to 53.9 feet	Cross Slope (PAR)	3.0-4.0%	7 ft	20	SF	\$120	\$2,418	
47868	51.2 to 52.2 feet	Vertical Change	-4	7 ft	7	REF			
41529	54.8 to 55.8 feet	Vertical Change	-1.05	7 ft	7	SF	\$75	\$488	
380	78.8 to 82.3 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	23	SF	\$120	\$2,730	
39969	82.1 to 83.6 feet	Running Slope	8.0-9.0%	7 ft	10	REF			
41382	85.7 to 86.7 feet	Vertical Change	-1.32	7 ft	7	SF	\$75	\$488	
43214	85.8 to 87.1 feet	Vertical Change	-.62	7 ft	8	SF	\$75	\$634	
57132	86.8 to 87.8 feet	Vertical Change	.62	7 ft	7	REF			
382	87.3 to 89.2 feet	Cross Slope (PAR)	>15%	7 ft	12	SF	\$120	\$1,482	
39970	89.7 to 91.3 feet	Running Slope	5.0-6.0%	7 ft	10	SF	\$120	\$1,248	
383	93.0 to 96.0 feet	Cross Slope (PAR)	8.0-9.0%	7 ft	20	SF	\$120	\$2,340	
48395	94.5 to 95.5 feet	Vertical Change	-.38	7 ft	7	REF			
49890	98.4 to 99.5 feet	Vertical Change	-.33	7 ft	7	REF			
384	99.3 to 100.5 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	8	SF	\$120	\$936	
385	104.8 to 150.7 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	298	SF	\$120	\$35,802	
57707	147.6 to 181.9 feet	Driveway				REF			
50599	153.1 to 154.1 feet	Vertical Change	-.31	7 ft	7	REF			
392	153.5 to 180.4 feet	Cross Slope (Driveway)	7.0-8.0%	7 ft	175	SF	\$40	\$6,994	
51913	161.9 to 162.9 feet	Vertical Change	-.29	7 ft	7	REF			
47453	171.0 to 172.0 feet	Vertical Change	-.41	7 ft	7	REF			
53297	180.1 to 181.1 feet	Vertical Change	-.26	7 ft	7	REF			
51502	183.7 to 184.7 feet	Vertical Change	-.3	7 ft	7	LF	\$75	\$488	
46080	191.8 to 192.8 feet	Vertical Change	-.47	7 ft	7	LF	\$75	\$488	
399	199.9 to 254.7 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	356	SF	\$120	\$42,744	
52807	201.9 to 202.9 feet	Vertical Change	-.27	7 ft	7	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1908201023	FRONT ST	KINGS AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44173	212.1 to 213.1 feet	Vertical Change	-.56	7 ft	7	REF		
47454	222.1 to 223.1 feet	Vertical Change	-.41	7 ft	7	REF		
49891	232.1 to 233.1 feet	Vertical Change	-.33	7 ft	7	REF		
42537	251.9 to 252.9 feet	Vertical Change	-.68	7 ft	7	REF		
404	259.0 to 278.0 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	124	SF	\$120	\$14,820
49568	261.9 to 262.9 feet	Vertical Change	-.34	7 ft	7	REF		
47869	266.3 to 269.6 feet	Vertical Change	-.4	7 ft	21	REF		
49892	273.5 to 274.5 feet	Vertical Change	-.33	7 ft	7	REF		
46302	276.8 to 277.8 feet	Vertical Change	-.46	7 ft	7	REF		
46528	286.8 to 287.8 feet	Vertical Change	-.45	7 ft	7	LF	\$75	\$488
TOTAL COST FOR: SW side of FRONT ST Starting at: KINGS AVE								\$134,631.25

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
SE	1908201034	ROBERTSON BLVD	FRONT ST	CHOWCHILLA BLVD				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
408	3.5 to 40.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	278	SF	\$120	\$33,300
44174	8.9 to 9.9 feet	Vertical Change	-.56	8 ft	8	REF		
44175	19.8 to 20.8 feet	Vertical Change	-.56	8 ft	8	REF		
414	40.5 to 46.6 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	46	SF	\$120	\$5,490
416	46.6 to 93.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	355	SF	\$120	\$42,570
51914	47.3 to 48.3 feet	Vertical Change	-.29	8 ft	8	REF		
48666	77.7 to 78.7 feet	Vertical Change	-.37	8 ft	8	REF		
419	93.9 to 102.1 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	62	SF	\$120	\$7,380
49244	97.5 to 98.5 feet	Vertical Change	-.35	8 ft	8	REF		
55938	97.6 to 98.6 feet	Vertical Change	.3	8 ft	8	REF		
421	102.1 to 105.8 feet	Cross Slope (PAR)	6.0-7.0%	8 ft	28	SF	\$120	\$3,330
422	105.8 to 108.6 feet	Cross Slope (PAR)	5.0-6.0%	8 ft	21	SF	\$120	\$2,520
424	108.6 to 159.8 feet	Cross Slope (PAR)	3.0-4.0%	8 ft	384	SF	\$120	\$46,080
430	159.8 to 209.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	374	SF	\$120	\$44,910
42653	168.2 to 169.2 feet	Vertical Change	-.67	8 ft	8	REF		
435	209.7 to 223.0 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	100	SF	\$120	\$11,970
437	223.0 to 273.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	380	SF	\$120	\$45,630
53824	257.9 to 258.9 feet	Vertical Change	-.25	8 ft	8	REF		
46766	267.5 to 268.5 feet	Vertical Change	-.44	8 ft	8	REF		
441	273.7 to 302.7 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	218	SF	\$120	\$26,100
49569	287.9 to 288.9 feet	Vertical Change	-.34	8 ft	8	REF		
48667	297.9 to 298.9 feet	Vertical Change	-.37	8 ft	8	REF		
443	302.7 to 312.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	72	SF	\$120	\$8,640
7	304.2 to 305.2 feet	Continuous Width		8 ft	8	SF	\$120	\$900
57708	311.9 to 348.7 feet	Driveway				REF		
445	312.3 to 317.4 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	38	SF	\$120	\$4,590
42110	315.0 to 316.0 feet	Vertical Change	-.74	8 ft	8	REF		
447	317.4 to 318.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	11	SF	\$120	\$1,260

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908201034	ROBERTSON BLVD	FRONT ST	CHOWCHILLA BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
50224	320.7 to 321.7 feet	Vertical Change	-.32	8 ft	8	LF	\$75	\$563
41463	322.9 to 323.9 feet	Vertical Change	-1.13	8 ft	8	SF	\$75	\$563
57374	323.1 to 324.1 feet	Vertical Change	1.04	8 ft	8	SF	\$75	\$563
41307	323.3 to 324.3 feet	Vertical Change	-1.54	8 ft	8	SF	\$75	\$563
57506	323.6 to 324.6 feet	Vertical Change	1.7	8 ft	8	SF	\$75	\$563
41218	327.8 to 328.8 feet	Vertical Change	-2.16	8 ft	8	SF	\$75	\$563
57508	328.1 to 329.1 feet	Vertical Change	1.76	8 ft	8	SF	\$75	\$563
41522	328.3 to 329.3 feet	Vertical Change	-1.06	8 ft	8	SF	\$75	\$563
51503	328.3 to 329.3 feet	Vertical Change	-.3	8 ft	8	LF	\$75	\$563
57464	328.5 to 329.5 feet	Vertical Change	1.45	8 ft	8	SF	\$75	\$563
41671	337.9 to 338.9 feet	Vertical Change	-.91	8 ft	8	SF	\$75	\$563
57335	338.1 to 339.1 feet	Vertical Change	.94	8 ft	8	SF	\$75	\$563
41268	338.4 to 339.4 feet	Vertical Change	-1.72	8 ft	8	SF	\$75	\$563
57512	338.6 to 339.6 feet	Vertical Change	1.84	8 ft	8	SF	\$75	\$563
41249	342.8 to 343.8 feet	Vertical Change	-1.86	8 ft	8	SF	\$75	\$563
41737	342.9 to 343.9 feet	Vertical Change	-.87	8 ft	8	SF	\$75	\$563
57513	343.1 to 344.1 feet	Vertical Change	1.85	8 ft	8	SF	\$75	\$563
41422	343.3 to 344.3 feet	Vertical Change	-1.21	8 ft	8	SF	\$75	\$563
57342	343.5 to 344.5 feet	Vertical Change	.99	8 ft	8	SF	\$75	\$563
448	351.5 to 381.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	227	SF	\$120	\$27,180
41464	356.8 to 357.8 feet	Vertical Change	-1.13	8 ft	8	REF		
49570	366.8 to 367.8 feet	Vertical Change	-.34	8 ft	8	REF		
49893	376.9 to 377.9 feet	Vertical Change	-.33	8 ft	8	REF		
451	395.3 to 441.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	348	SF	\$120	\$41,760
48396	396.5 to 397.5 feet	Vertical Change	-.38	8 ft	8	REF		
53825	406.3 to 407.3 feet	Vertical Change	-.25	8 ft	8	REF		
53298	436.0 to 437.0 feet	Vertical Change	-.26	8 ft	8	REF		
50225	446.1 to 447.1 feet	Vertical Change	-.32	8 ft	8	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908201034	ROBERTSON BLVD	FRONT ST	CHOWCHILLA BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
455	446.6 to 472.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	194	SF	\$120	\$23,220
44176	461.6 to 462.6 feet	Vertical Change	-.56	8 ft	8	REF		
56978	461.7 to 462.7 feet	Vertical Change	.58	8 ft	8	REF		
48956	466.1 to 467.1 feet	Vertical Change	-.36	8 ft	8	REF		
51504	476.3 to 477.3 feet	Vertical Change	-.3	8 ft	8	REF		
460	476.5 to 487.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	83	SF	\$120	\$9,900
41852	478.9 to 479.9 feet	Vertical Change	-.81	8 ft	8	REF		
48957	480.1 to 481.1 feet	Vertical Change	-.36	8 ft	8	REF		
49894	486.5 to 487.5 feet	Vertical Change	-.33	8 ft	8	REF		
461	496.8 to 603.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	802	SF	\$120	\$96,300
50600	506.7 to 507.7 feet	Vertical Change	-.31	8 ft	8	REF		
8	519.7 to 520.7 feet	Continuous Width		8 ft	8	SF	\$120	\$900
468	603.8 to 613.0 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	69	SF	\$120	\$8,280
9	611.4 to 612.4 feet	Continuous Width		8 ft	8	SF	\$120	\$900
TOTAL COST FOR: SE side of ROBERTSON BLVD Starting at: FRONT ST							\$503,797.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	1908201042	CHOWCHILLA BLVD	ROBERTSON BLVD	PROSPERITY RD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
469	0.0 to 10.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	81	SF	\$120	\$9,720	
471	10.8 to 14.0 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	24	SF	\$120	\$2,880	
57709	28.6 to 67.4 feet	Driveway				REF			
472	33.3 to 34.3 feet	Cross Slope (Driveway)	2.0-3.0%	8 ft	8	SF	\$40	\$300	
473	36.3 to 64.8 feet	Cross Slope (Driveway)	6.0-7.0%	8 ft	214	SF	\$40	\$8,550	
43687	49.6 to 50.6 feet	Vertical Change	-.59	8 ft	8	REF			
56619	49.8 to 50.8 feet	Vertical Change	.42	8 ft	8	REF			
39971	62.0 to 64.6 feet	Running Slope	5.0-6.0%	8 ft	19	REF			
477	67.3 to 68.7 feet	Cross Slope (Driveway)	3.0-4.0%	8 ft	11	SF	\$40	\$420	
478	68.7 to 76.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	59	SF	\$120	\$7,020	
480	76.5 to 85.3 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	66	SF	\$120	\$7,920	
57710	82.6 to 126.3 feet	Driveway				REF			
43552	83.6 to 84.6 feet	Vertical Change	-.6	8 ft	8	REF			
482	85.3 to 90.3 feet	Cross Slope (Driveway)	6.0-7.0%	8 ft	38	SF	\$40	\$1,500	
484	90.3 to 124.3 feet	Cross Slope (Driveway)	8.0-9.0%	8 ft	255	SF	\$40	\$10,200	
39972	121.9 to 124.5 feet	Running Slope	5.0-6.0%	8 ft	20	REF			
49571	128.5 to 129.5 feet	Vertical Change	-.34	8 ft	8	LF	\$75	\$563	
486	131.1 to 146.0 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	112	SF	\$120	\$13,410	
53826	151.0 to 152.0 feet	Vertical Change	-.25	8 ft	8	LF	\$75	\$563	
489	153.5 to 229.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	573	SF	\$120	\$68,760	
46529	162.6 to 163.6 feet	Vertical Change	-.45	8 ft	8	REF			
50601	172.4 to 173.4 feet	Vertical Change	-.31	8 ft	8	REF			
48397	182.3 to 183.3 feet	Vertical Change	-.38	8 ft	8	REF			
50226	211.9 to 212.9 feet	Vertical Change	-.32	8 ft	8	REF			
53827	221.6 to 223.3 feet	Vertical Change	-.25	8 ft	13	REF			
57711	225.1 to 257.6 feet	Driveway				REF			
496	232.6 to 254.2 feet	Cross Slope (Driveway)	8.0-9.0%	8 ft	162	SF	\$40	\$6,480	
47456	238.0 to 239.0 feet	Vertical Change	-.41	8 ft	8	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1908201042	CHOWCHILLA BLVD	ROBERTSON BLVD	PROSPERITY RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
500	256.7 to 258.4 feet	Cross Slope (Driveway)	3.0-4.0%	8 ft	13	SF	\$40	\$510
42070	258.0 to 259.0 feet	Vertical Change	-.75	8 ft	8	REF		
501	258.4 to 298.6 feet	Cross Slope (Driveway)	2.0-3.0%	8 ft	302	SF	\$40	\$12,060
52808	268.5 to 269.5 feet	Vertical Change	-.27	8 ft	8	REF		
53829	278.6 to 280.4 feet	Vertical Change	-.25	8 ft	13	REF		
502	305.9 to 341.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	268	SF	\$120	\$32,130
49572	309.1 to 310.1 feet	Vertical Change	-.34	8 ft	8	REF		
52332	318.9 to 319.9 feet	Vertical Change	-.28	8 ft	8	REF		
57712	335.6 to 372.4 feet	Driveway				REF		
47870	339.3 to 340.3 feet	Vertical Change	-.4	8 ft	8	REF		
506	343.1 to 356.0 feet	Cross Slope (Driveway)	6.0-7.0%	8 ft	97	SF	\$40	\$3,870
48398	348.1 to 349.1 feet	Vertical Change	-.38	8 ft	8	REF		
508	356.0 to 369.4 feet	Cross Slope (Driveway)	8.0-9.0%	8 ft	101	SF	\$40	\$4,020
45877	356.9 to 357.9 feet	Vertical Change	-.48	8 ft	8	REF		
511	373.3 to 431.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	438	SF	\$120	\$52,560
50602	374.9 to 375.9 feet	Vertical Change	-.31	8 ft	8	REF		
52333	383.9 to 384.9 feet	Vertical Change	-.28	8 ft	8	REF		
45878	396.1 to 397.1 feet	Vertical Change	-.48	8 ft	8	REF		
53830	416.3 to 417.3 feet	Vertical Change	-.25	8 ft	8	REF		
TOTAL COST FOR: SW side of CHOWCHILLA BLVD Starting at: ROBERTSON BLVD							\$243,435.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W/S	1908201047	CHOWCHILLA BLVD	PROSPERITY RD	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
53300	4.5 to 5.5 feet	Vertical Change	-26	8 ft	8	LF	\$75	\$563	
517	8.3 to 10.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	17	SF	\$120	\$2,070	
51915	14.8 to 15.8 feet	Vertical Change	-29	8 ft	8	LF	\$75	\$563	
518	22.1 to 111.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	673	SF	\$120	\$80,730	
43843	32.4 to 33.4 feet	Vertical Change	-58	8 ft	8	REF			
50603	45.3 to 46.3 feet	Vertical Change	-31	8 ft	8	REF			
43362	52.1 to 53.1 feet	Vertical Change	-61	8 ft	8	REF			
52334	72.1 to 73.1 feet	Vertical Change	-28	8 ft	8	REF			
49895	77.2 to 78.2 feet	Vertical Change	-33	8 ft	8	REF			
53301	80.5 to 81.5 feet	Vertical Change	-26	8 ft	8	REF			
47205	112.3 to 113.3 feet	Vertical Change	-42	8 ft	8	LF	\$75	\$563	
45672	116.5 to 118.6 feet	Vertical Change	-49	8 ft	16	LF	\$75	\$1,181	
524	122.0 to 123.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	9	SF	\$120	\$1,080	
525	128.8 to 249.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	902	SF	\$120	\$108,270	
45186	134.0 to 135.0 feet	Vertical Change	-51	8 ft	8	REF			
52335	144.7 to 145.7 feet	Vertical Change	-28	8 ft	8	REF			
43688	146.3 to 147.3 feet	Vertical Change	-59	8 ft	8	REF			
53302	155.2 to 156.2 feet	Vertical Change	-26	8 ft	8	REF			
48399	165.4 to 166.4 feet	Vertical Change	-38	8 ft	8	REF			
51506	225.5 to 226.5 feet	Vertical Change	-3	8 ft	8	REF			
48668	236.3 to 237.3 feet	Vertical Change	-37	8 ft	8	REF			
539	253.2 to 258.0 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	36	SF	\$120	\$4,320	
52336	261.8 to 262.8 feet	Vertical Change	-28	8 ft	8	LF	\$75	\$563	
540	263.8 to 267.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	29	SF	\$120	\$3,420	
41924	268.6 to 269.6 feet	Vertical Change	-79	8 ft	8	SF	\$75	\$563	
541	285.1 to 287.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	18	SF	\$120	\$2,160	
542	313.6 to 315.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	12	SF	\$120	\$1,440	
543	319.6 to 329.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	76	SF	\$120	\$9,090	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W/S	1908201047	CHOWCHILLA BLVD	PROSPERITY RD	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
TOTAL COST FOR: W/S							<i>side of</i>	\$216,573.75

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1908201055	CHOWCHILLA BLVD	SIDEWALK BEGINS	UNNAMED ROAD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46984	27.8 to 28.8 feet	Vertical Change	-.43	7 ft	7	REF		
544	28.0 to 73.9 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	321	SF	\$120	\$38,556
49573	51.5 to 52.5 feet	Vertical Change	-.34	7 ft	7	REF		
549	73.9 to 103.9 feet	Cross Slope (PAR)	4.0-5.0%	7 ft	210	SF	\$120	\$25,200
47206	91.5 to 92.5 feet	Vertical Change	-.42	7 ft	7	REF		
551	103.9 to 109.3 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	38	SF	\$120	\$4,536
552	115.3 to 118.3 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	21	SF	\$120	\$2,520
TOTAL COST FOR: NE							<i>side of CHOWCHILLA BLVD Starting at: SIDEWALK BEGINS</i>	\$70,812.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1908201059	CHOWCHILLA BLVD	UNNAMED ROAD	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
553	0.0 to 10.8 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	81	SF	\$120	\$9,720	
555	10.8 to 25.0 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	107	SF	\$120	\$12,780	
556	27.3 to 34.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	54	SF	\$120	\$6,480	
557	37.3 to 115.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	587	SF	\$120	\$70,380	
566	122.3 to 123.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	11	SF	\$120	\$1,350	
53303	133.8 to 134.8 feet	Vertical Change	-0.26	8 ft	8	LF	\$75	\$563	
567	141.7 to 193.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	387	SF	\$120	\$46,440	
57713	188.5 to 228.8 feet	Driveway				REF			
571	196.7 to 206.2 feet	Cross Slope (Driveway)	9.0-10.0%	8 ft	71	SF	\$40	\$2,850	
573	206.2 to 212.3 feet	Cross Slope (Driveway)	11.0-12.0%	8 ft	46	SF	\$40	\$1,830	
575	212.3 to 226.0 feet	Cross Slope (Driveway)	9.0-10.0%	8 ft	103	SF	\$40	\$4,110	
39973	225.5 to 226.8 feet	Running Slope	8.0-9.0%	8 ft	10	REF			
578	229.3 to 231.1 feet	Cross Slope (Driveway)	3.0-4.0%	8 ft	14	SF	\$40	\$540	
579	231.1 to 263.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	245	SF	\$120	\$29,340	
581	263.7 to 300.3 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	275	SF	\$120	\$32,940	
585	300.3 to 303.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	23	SF	\$120	\$2,790	
39974	302.9 to 304.2 feet	Running Slope	5.0-6.0%	8 ft	10	REF			
57478	306.5 to 307.5 feet	Vertical Change	1.57	8 ft	8	SF	\$75	\$563	
57714	306.5 to 349.3 feet	Driveway				REF			
41202	307.6 to 308.6 feet	Vertical Change	-2.38	8 ft	8	REF			
39975	307.6 to 309.2 feet	Running Slope	7.0-8.0%	8 ft	12	REF			
586	311.3 to 317.4 feet	Cross Slope (Driveway)	5.0-6.0%	8 ft	46	SF	\$40	\$1,830	
587	317.4 to 323.9 feet	Cross Slope (Driveway)	6.0-7.0%	8 ft	49	SF	\$40	\$1,950	
588	325.0 to 338.7 feet	Cross Slope (Driveway)	5.0-6.0%	8 ft	103	SF	\$40	\$4,110	
589	338.7 to 346.1 feet	Cross Slope (Driveway)	6.0-7.0%	8 ft	56	SF	\$40	\$2,220	
590	346.1 to 351.8 feet	Cross Slope (Driveway)	5.0-6.0%	8 ft	43	SF	\$40	\$1,710	
48669	348.6 to 350.8 feet	Vertical Change	-0.37	8 ft	17	REF			
592	351.8 to 362.0 feet	Cross Slope (PAR)	3.0-4.0%	8 ft	77	SF	\$120	\$9,180	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1908201059	CHOWCHILLA BLVD	UNNAMED ROAD	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57715	356.4 to 386.9 feet	Driveway				REF		
43093	359.6 to 360.6 feet	Vertical Change	-63	8 ft	8	REF		
48671	360.9 to 361.9 feet	Vertical Change	-.37	8 ft	8	REF		
594	362.0 to 363.5 feet	Cross Slope (Driveway)	5.0-6.0%	8 ft	11	SF	\$40	\$450
595	363.5 to 368.8 feet	Cross Slope (Driveway)	6.0-7.0%	8 ft	40	SF	\$40	\$1,590
51916	366.5 to 367.5 feet	Vertical Change	-.29	8 ft	8	REF		
596	368.8 to 375.2 feet	Cross Slope (Driveway)	5.0-6.0%	8 ft	48	SF	\$40	\$1,920
598	375.2 to 379.6 feet	Cross Slope (Driveway)	3.0-4.0%	8 ft	33	SF	\$40	\$1,320
599	379.6 to 431.4 feet	Cross Slope (Driveway)	2.0-3.0%	8 ft	389	SF	\$40	\$15,540
39976	381.3 to 384.2 feet	Running Slope	7.0-8.0%	8 ft	22	REF		
52809	384.6 to 387.1 feet	Vertical Change	-.27	8 ft	19	REF		
44809	396.1 to 397.1 feet	Vertical Change	-.53	8 ft	8	REF		
49896	406.0 to 410.0 feet	Vertical Change	-.33	8 ft	30	REF		
46767	415.8 to 416.8 feet	Vertical Change	-.44	8 ft	8	REF		
601	431.4 to 447.4 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	120	SF	\$120	\$14,400
44995	434.0 to 435.0 feet	Vertical Change	-.52	8 ft	8	REF		
57716	440.5 to 474.9 feet	Driveway				REF		
43363	442.9 to 443.9 feet	Vertical Change	-.61	8 ft	8	REF		
49245	445.3 to 446.3 feet	Vertical Change	-.35	8 ft	8	REF		
605	447.4 to 465.2 feet	Cross Slope (Driveway)	6.0-7.0%	8 ft	134	SF	\$40	\$5,340
47457	451.5 to 452.5 feet	Vertical Change	-.41	8 ft	8	REF		
51917	461.1 to 462.1 feet	Vertical Change	-.29	8 ft	8	REF		
607	465.2 to 472.7 feet	Cross Slope (Driveway)	8.0-9.0%	8 ft	56	SF	\$40	\$2,250
46985	470.4 to 471.4 feet	Vertical Change	-.43	8 ft	8	REF		
609	472.7 to 474.9 feet	Cross Slope (Driveway)	6.0-7.0%	8 ft	17	SF	\$40	\$660
TOTAL COST FOR: NE side of CHOWCHILLA BLVD Starting at: UNNAMED ROAD							\$287,145.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E/S	1908201118	PROSPERITY RD	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
610	0.0 to 34.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	173	SF	\$120	\$20,700
49246	7.5 to 8.5 feet	Vertical Change	-.35	5 ft	5	REF		
49897	18.8 to 19.8 feet	Vertical Change	-.33	5 ft	5	REF		
46986	30.1 to 31.1 feet	Vertical Change	-.43	5 ft	5	REF		
615	38.2 to 54.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	82	SF	\$120	\$9,840
50604	38.6 to 39.6 feet	Vertical Change	-.31	5 ft	5	REF		
44177	47.8 to 48.8 feet	Vertical Change	-.56	5 ft	5	REF		
52810	57.9 to 58.9 feet	Vertical Change	-.27	5 ft	5	REF		
616	58.0 to 81.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	117	SF	\$120	\$13,980
53304	68.0 to 69.0 feet	Vertical Change	-.26	5 ft	5	REF		
45879	78.2 to 79.2 feet	Vertical Change	-.48	5 ft	5	REF		
50605	85.6 to 92.3 feet	Vertical Change	-.31	5 ft	34	LF	\$75	\$2,513
57717	98.7 to 131.8 feet	Driveway				REF		
47458	100.2 to 101.2 feet	Vertical Change	-.41	5 ft	5	REF		
49898	110.8 to 111.8 feet	Vertical Change	-.33	5 ft	5	REF		
47459	120.8 to 121.8 feet	Vertical Change	-.41	5 ft	5	REF		
617	127.6 to 133.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	30	SF	\$40	\$1,220
48107	131.3 to 134.3 feet	Vertical Change	-.39	5 ft	15	REF		
53306	140.1 to 141.1 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
618	143.3 to 160.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	88	SF	\$120	\$10,500
51508	144.2 to 145.2 feet	Vertical Change	-.3	5 ft	5	REF		
53307	151.1 to 152.1 feet	Vertical Change	-.26	5 ft	5	REF		
47871	155.7 to 156.7 feet	Vertical Change	-.4	5 ft	5	REF		
46304	160.2 to 161.2 feet	Vertical Change	-.46	5 ft	5	REF		
622	169.3 to 213.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	223	SF	\$120	\$26,760
51509	169.8 to 170.8 feet	Vertical Change	-.3	5 ft	5	REF		
52811	174.3 to 175.3 feet	Vertical Change	-.27	5 ft	5	REF		
52338	186.3 to 189.6 feet	Vertical Change	-.28	5 ft	17	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E/S	1908201118	PROSPERITY RD	SIDEWALK BEGINS	SIDEWALK ENDS	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
48108	218.9 to 219.9 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375	
625	245.7 to 271.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	130	SF	\$120	\$15,600	
45673	266.6 to 267.6 feet	Vertical Change	-.49	5 ft	5	REF			
46987	286.2 to 287.2 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375	
626	287.9 to 525.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	1189	SF	\$120	\$142,680	
49574	295.7 to 296.7 feet	Vertical Change	-.34	5 ft	5	REF			
44014	361.8 to 362.8 feet	Vertical Change	-.57	5 ft	5	REF			
44178	394.7 to 395.7 feet	Vertical Change	-.56	5 ft	5	REF			
48673	404.4 to 405.4 feet	Vertical Change	-.37	5 ft	5	REF			
42749	406.9 to 407.9 feet	Vertical Change	-.66	5 ft	5	REF			
45674	414.5 to 415.5 feet	Vertical Change	-.49	5 ft	5	REF			
49575	435.5 to 439.0 feet	Vertical Change	-.34	5 ft	18	REF			
44604	445.4 to 446.4 feet	Vertical Change	-.54	5 ft	5	REF			
48109	450.3 to 451.3 feet	Vertical Change	-.39	5 ft	5	REF			
45457	455.5 to 456.5 feet	Vertical Change	-.5	5 ft	5	REF			
639	552.6 to 563.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,240	
51918	557.0 to 558.0 feet	Vertical Change	-.29	5 ft	5	REF			
640	567.0 to 577.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,120	
642	628.9 to 652.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	116	SF	\$120	\$13,860	
47207	635.8 to 636.8 feet	Vertical Change	-.42	5 ft	5	REF			
645	656.3 to 677.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	104	SF	\$120	\$12,420	
648	724.4 to 739.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	76	SF	\$120	\$9,060	
650	832.6 to 838.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,660	
651	841.5 to 855.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	72	SF	\$120	\$8,580	
654	868.2 to 889.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	108	SF	\$120	\$12,900	
44810	893.7 to 894.7 feet	Vertical Change	-.53	5 ft	5	SF	\$75	\$375	
53308	893.9 to 894.9 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
655	905.8 to 907.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
E/S	1908201118	PROSPERITY RD	SIDEWALK BEGINS	SIDEWALK ENDS				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
656	915.2 to 960.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	225	SF	\$120	\$26,940
660	962.9 to 967.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700
661	973.8 to 979.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,300
662	984.0 to 989.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,480
663	992.8 to 996.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340
664	1000.4 to 1016.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	82	SF	\$120	\$9,780
665	1027.8 to 1029.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900
666	1037.2 to 1039.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
667	1043.8 to 1190.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	733	SF	\$120	\$87,960
48958	1192.9 to 1193.9 feet	Vertical Change	-36	5 ft	5	LF	\$75	\$375
674	1198.2 to 1231.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	169	SF	\$120	\$20,220
675	1234.7 to 1363.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	642	SF	\$120	\$76,980
53831	1254.5 to 1255.5 feet	Vertical Change	-.25	5 ft	5	REF		
49247	1306.6 to 1307.6 feet	Vertical Change	-.35	5 ft	5	REF		
681	1368.4 to 1549.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	903	SF	\$120	\$108,360
46081	1510.2 to 1511.2 feet	Vertical Change	-.47	5 ft	5	REF		
49248	1518.7 to 1519.7 feet	Vertical Change	-.35	5 ft	5	REF		
44996	1522.1 to 1523.1 feet	Vertical Change	-.52	5 ft	5	REF		
44015	1549.3 to 1550.3 feet	Vertical Change	-.57	5 ft	5	SF	\$75	\$375
44811	1553.9 to 1554.9 feet	Vertical Change	-.53	5 ft	5	SF	\$75	\$375
689	1556.0 to 1648.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	461	SF	\$120	\$55,320
46305	1564.2 to 1565.2 feet	Vertical Change	-.46	5 ft	5	REF		
52339	1598.8 to 1599.8 feet	Vertical Change	-.28	5 ft	5	REF		

TOTAL COST FOR: E/S side of PROSPERITY RD Starting at: SIDEWALK BEGINS \$720,492.50

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1908201126	PROSPERITY RD	SIDEWALK BEGINS	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
694	0.0 to 23.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	119	SF	\$120	\$14,220	
41576	11.1 to 12.1 feet	Vertical Change	-1	5 ft	5	REF			
57151	21.6 to 22.6 feet	Vertical Change	.66	5 ft	5	REF			
697	23.7 to 64.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	205	SF	\$120	\$24,600	
42268	31.8 to 32.8 feet	Vertical Change	-.71	5 ft	5	REF			
41714	42.4 to 43.4 feet	Vertical Change	-.88	5 ft	5	REF			
41925	52.5 to 53.5 feet	Vertical Change	-.79	5 ft	5	REF			
41577	62.8 to 63.8 feet	Vertical Change	-1	5 ft	5	REF			
701	64.7 to 93.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	143	SF	\$120	\$17,160	
43215	72.9 to 73.9 feet	Vertical Change	-.62	5 ft	5	REF			
42111	83.1 to 84.1 feet	Vertical Change	-.74	5 ft	5	REF			
41758	92.9 to 93.9 feet	Vertical Change	-.86	5 ft	5	REF			
706	93.3 to 100.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,080	
49576	97.8 to 98.8 feet	Vertical Change	-.34	5 ft	5	REF			
41699	98.0 to 99.0 feet	Vertical Change	-.89	5 ft	5	REF			
41304	98.1 to 99.1 feet	Vertical Change	-1.55	5 ft	5	REF			
48959	98.8 to 99.8 feet	Vertical Change	-.36	5 ft	5	REF			
41586	101.4 to 102.4 feet	Vertical Change	-.99	5 ft	5	REF			
57718	107.4 to 141.3 feet	Driveway				REF			
707	108.2 to 138.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	152	SF	\$40	\$6,060	
44605	120.8 to 121.8 feet	Vertical Change	-.54	5 ft	5	REF			
43844	130.7 to 131.7 feet	Vertical Change	-.58	5 ft	5	REF			
710	149.7 to 161.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,080	
41423	150.9 to 151.9 feet	Vertical Change	-1.21	5 ft	5	REF			
45458	153.6 to 154.6 feet	Vertical Change	-.5	5 ft	5	REF			
41631	158.3 to 159.3 feet	Vertical Change	-.94	5 ft	5	REF			
44606	162.4 to 163.4 feet	Vertical Change	-.54	5 ft	5	SF	\$75	\$375	
711	163.8 to 165.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1908201126	PROSPERITY RD	SIDEWALK BEGINS	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
41237	172.7 to 173.7 feet	Vertical Change	-1.94	5 ft	5	SF	\$75	\$375	
712	174.5 to 185.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,480	
41505	182.7 to 183.7 feet	Vertical Change	-1.08	5 ft	5	REF			
714	185.3 to 209.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	119	SF	\$120	\$14,280	
42365	192.7 to 193.7 feet	Vertical Change	-.7	5 ft	5	REF			
47208	202.8 to 203.8 feet	Vertical Change	-.42	5 ft	5	REF			
720	209.1 to 214.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,300	
49577	212.9 to 213.9 feet	Vertical Change	-.34	5 ft	5	REF			
722	214.6 to 230.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	79	SF	\$120	\$9,480	
41515	223.1 to 224.1 feet	Vertical Change	-1.07	5 ft	5	REF			
724	230.4 to 237.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020	
46768	232.5 to 233.5 feet	Vertical Change	-.44	5 ft	5	REF			
42654	242.3 to 243.3 feet	Vertical Change	-.67	5 ft	5	SF	\$75	\$375	
44179	252.3 to 253.3 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375	
44391	257.8 to 258.8 feet	Vertical Change	-.55	5 ft	5	SF	\$75	\$375	
53309	260.2 to 261.2 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
42538	262.2 to 263.2 feet	Vertical Change	-.68	5 ft	5	SF	\$75	\$375	
725	271.2 to 285.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,820	
41998	281.6 to 282.6 feet	Vertical Change	-.77	5 ft	5	REF			
726	290.1 to 316.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	133	SF	\$120	\$15,960	
41412	291.5 to 292.5 feet	Vertical Change	-1.24	5 ft	5	REF			
41926	300.6 to 301.6 feet	Vertical Change	-.79	5 ft	5	REF			
42269	310.4 to 311.4 feet	Vertical Change	-.71	5 ft	5	REF			
42866	318.7 to 319.7 feet	Vertical Change	-.65	5 ft	5	REF			
727	319.3 to 326.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,560	
41314	325.3 to 326.3 feet	Vertical Change	-1.51	5 ft	5	REF			
57719	330.9 to 366.8 feet	Driveway				REF			
728	334.1 to 341.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	36	SF	\$40	\$1,420	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1908201126	PROSPERITY RD	SIDEWALK BEGINS	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
42112	344.5 to 345.5 feet	Vertical Change	-.74	5 ft	5	REF			
729	350.2 to 365.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	78	SF	\$40	\$3,100	
44180	354.7 to 355.7 feet	Vertical Change	-.56	5 ft	5	REF			
731	365.7 to 368.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	16	SF	\$40	\$620	
733	368.8 to 391.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	112	SF	\$120	\$13,440	
41379	373.1 to 374.1 feet	Vertical Change	-1.33	5 ft	5	REF			
42366	381.6 to 382.6 feet	Vertical Change	-.7	5 ft	5	REF			
43364	391.5 to 392.5 feet	Vertical Change	-.61	5 ft	5	SF	\$75	\$375	
737	412.2 to 603.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	958	SF	\$120	\$114,960	
49249	419.2 to 420.2 feet	Vertical Change	-.35	5 ft	5	REF			
41506	419.4 to 420.4 feet	Vertical Change	-1.08	5 ft	5	REF			
48960	420.9 to 421.9 feet	Vertical Change	-.36	5 ft	5	REF			
50228	493.3 to 494.3 feet	Vertical Change	-.32	5 ft	5	REF			
49250	504.2 to 505.2 feet	Vertical Change	-.35	5 ft	5	REF			
52340	544.0 to 545.0 feet	Vertical Change	-.28	5 ft	5	REF			
755	611.4 to 612.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780	
756	617.1 to 618.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
757	623.3 to 697.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	370	SF	\$120	\$44,400	
762	703.1 to 747.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	221	SF	\$120	\$26,520	
769	759.0 to 948.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	947	SF	\$120	\$113,640	
52812	859.7 to 860.7 feet	Vertical Change	-.27	5 ft	5	REF			
786	952.3 to 990.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	192	SF	\$120	\$23,040	
789	997.5 to 1076.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	393	SF	\$120	\$47,100	
54151	1020.2 to 1021.2 feet	Vertical Change	.27	5 ft	5	REF			
49251	1069.0 to 1072.0 feet	Vertical Change	-.35	5 ft	15	REF			
TOTAL COST FOR: NE							<i>side of PROSPERITY RD Starting at: SIDEWALK BEGINS</i>	\$534,400.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1908201130	PROSPERITY RD	SIDEWALK BEGINS	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
57720	0.0 to 26.1 feet	Driveway				REF			
51510	2.4 to 3.4 feet	Vertical Change	-3	5 ft	5	REF			
47872	25.7 to 26.7 feet	Vertical Change	-4	5 ft	5	REF			
798	33.5 to 102.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	345	SF	\$120	\$41,400	
47209	35.3 to 36.3 feet	Vertical Change	-42	5 ft	5	REF			
49578	45.4 to 46.4 feet	Vertical Change	-34	5 ft	5	REF			
53310	56.2 to 57.2 feet	Vertical Change	-26	5 ft	5	REF			
49899	66.4 to 67.4 feet	Vertical Change	-33	5 ft	5	REF			
51919	87.5 to 88.5 feet	Vertical Change	-29	5 ft	5	REF			
53311	97.4 to 98.4 feet	Vertical Change	-26	5 ft	5	REF			
57721	108.1 to 144.1 feet	Driveway				REF			
44607	122.4 to 123.4 feet	Vertical Change	-54	5 ft	5	REF			
45880	132.5 to 133.5 feet	Vertical Change	-48	5 ft	5	REF			
805	142.5 to 148.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	29	SF	\$40	\$1,160	
46769	143.1 to 144.1 feet	Vertical Change	-44	5 ft	5	REF			
41715	156.9 to 157.9 feet	Vertical Change	-88	5 ft	5	SF	\$75	\$375	
48962	159.2 to 160.2 feet	Vertical Change	-36	5 ft	5	LF	\$75	\$375	
41826	161.7 to 163.9 feet	Vertical Change	-82	5 ft	11	SF	\$75	\$825	
48400	163.2 to 166.5 feet	Vertical Change	-38	5 ft	17	LF	\$75	\$1,238	
806	166.2 to 168.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260	

TOTAL COST FOR:	NE	<i>side of</i>	PROSPERITY RD	<i>Starting at:</i>	SIDEWALK BEGINS			\$46,632.50
------------------------	-----------	----------------	----------------------	---------------------	------------------------	--	--	--------------------

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908201134	PROSPERITY RD	SIDEWALK BEGINS	CHOWCHILLA BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
807	3.8 to 7.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,100	
808	27.3 to 30.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740	
809	32.9 to 138.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	529	SF	\$120	\$63,420	
57722	64.9 to 94.2 feet	Driveway				REF			
57723	135.5 to 179.8 feet	Driveway				REF			
820	140.7 to 179.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	196	SF	\$40	\$7,820	
50229	159.7 to 160.7 feet	Vertical Change	-.32	5 ft	5	REF			
39978	177.3 to 178.6 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
41375	182.9 to 183.9 feet	Vertical Change	-1.34	5 ft	5	SF	\$75	\$375	
830	184.5 to 205.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	103	SF	\$120	\$12,360	
832	208.2 to 216.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,100	
833	220.4 to 226.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,780	
47460	227.5 to 228.5 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375	
835	233.1 to 235.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380	
41534	257.6 to 258.6 feet	Vertical Change	-1.04	5 ft	5	SF	\$75	\$375	
55950	257.6 to 258.6 feet	Vertical Change	.33	5 ft	5	LF	\$75	\$375	
57333	267.4 to 268.4 feet	Vertical Change	.91	5 ft	5	SF	\$75	\$375	
45881	277.4 to 278.4 feet	Vertical Change	-.48	5 ft	5	LF	\$75	\$375	
836	296.7 to 300.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160	
48674	302.0 to 303.0 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375	
49579	306.5 to 307.5 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375	
837	307.8 to 319.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,260	
TOTAL COST FOR: NW side of PROSPERITY RD Starting at: SIDEWALK BEGINS							\$110,120.00		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NE	1908201139	CHOWCHILLA BLVD	PROSPERITY RD	ROBERTSON BLVD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
46770	19.7 to 20.7 feet	Vertical Change	-.44	8 ft	8	LF	\$75	\$563	
840	30.8 to 50.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	149	SF	\$120	\$17,820	
841	78.3 to 98.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	155	SF	\$120	\$18,540	
47873	84.5 to 85.5 feet	Vertical Change	-.4	8 ft	8	REF			
51920	89.7 to 90.7 feet	Vertical Change	-.29	8 ft	8	REF			
57724	97.2 to 142.5 feet	Driveway				REF			
46771	97.9 to 98.9 feet	Vertical Change	-.44	8 ft	8	REF			
57133	97.9 to 98.9 feet	Vertical Change	.62	8 ft	8	REF			
845	98.9 to 100.0 feet	Cross Slope (Driveway)	4.0-5.0%	8 ft	8	SF	\$40	\$330	
846	100.9 to 141.1 feet	Cross Slope (Driveway)	6.0-7.0%	8 ft	302	SF	\$40	\$12,060	
39979	137.8 to 138.8 feet	Running Slope	5.0-6.0%	8 ft	8	REF			
850	143.2 to 225.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	614	SF	\$120	\$73,710	
53832	144.0 to 145.0 feet	Vertical Change	-.25	8 ft	8	REF			
52341	198.3 to 199.3 feet	Vertical Change	-.28	8 ft	8	REF			
53312	204.3 to 205.3 feet	Vertical Change	-.26	8 ft	8	REF			
57725	221.8 to 269.4 feet	Driveway				REF			
52342	224.5 to 225.5 feet	Vertical Change	-.28	8 ft	8	REF			
861	226.9 to 267.8 feet	Cross Slope (Driveway)	7.0-8.0%	8 ft	307	SF	\$40	\$12,270	
39980	265.5 to 267.0 feet	Running Slope	6.0-7.0%	8 ft	11	REF			
867	267.8 to 268.8 feet	Cross Slope (Driveway)	5.0-6.0%	8 ft	8	SF	\$40	\$300	
868	270.2 to 293.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	178	SF	\$120	\$21,330	
57726	291.9 to 338.1 feet	Driveway				REF			
870	298.8 to 323.2 feet	Cross Slope (Driveway)	10.0-11.0%	8 ft	183	SF	\$40	\$7,320	
49900	308.6 to 309.6 feet	Vertical Change	-.33	8 ft	8	REF			
874	323.2 to 334.5 feet	Cross Slope (Driveway)	8.0-9.0%	8 ft	85	SF	\$40	\$3,390	
47874	323.5 to 324.5 feet	Vertical Change	-.4	8 ft	8	REF			
39981	332.4 to 335.2 feet	Running Slope	5.0-6.0%	8 ft	21	REF			
876	337.9 to 339.0 feet	Cross Slope (Driveway)	2.0-3.0%	8 ft	8	SF	\$40	\$330	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1908201139	CHOWCHILLA BLVD	PROSPERITY RD	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57336	350.2 to 354.1 feet	Vertical Change	.94	8 ft	29	SF	\$75	\$2,194
877	354.5 to 412.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	433	SF	\$120	\$51,930
53313	387.4 to 388.4 feet	Vertical Change	-.26	8 ft	8	REF		
47210	414.9 to 415.9 feet	Vertical Change	-.42	8 ft	8	LF	\$75	\$563
884	417.0 to 419.5 feet	Cross Slope (PAR)	3.0-4.0%	8 ft	19	SF	\$120	\$2,250
885	419.5 to 423.0 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	26	SF	\$120	\$3,150
51921	428.9 to 429.9 feet	Vertical Change	-.29	8 ft	8	LF	\$75	\$563
886	430.0 to 435.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	38	SF	\$120	\$4,590
TOTAL COST FOR: NE side of CHOWCHILLA BLVD Starting at: PROSPERITY RD							\$233,201.25	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1908201143	ROBERTSON BLVD	CHOWCHILLA BLVD	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
887	0.0 to 10.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	80	SF	\$120	\$9,630	
46772	10.1 to 11.1 feet	Vertical Change	-.44	8 ft	8	REF			
42214	13.5 to 14.5 feet	Vertical Change	-.72	8 ft	8	REF			
57242	13.6 to 14.6 feet	Vertical Change	.78	8 ft	8	REF			
891	14.1 to 194.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	1355	SF	\$120	\$162,630	
52814	14.5 to 15.5 feet	Vertical Change	-.27	8 ft	8	REF			
56906	14.7 to 15.7 feet	Vertical Change	.5	8 ft	8	REF			
44812	16.0 to 17.0 feet	Vertical Change	-.53	8 ft	8	REF			
41827	19.6 to 20.6 feet	Vertical Change	-.82	8 ft	7	REF			
51511	34.9 to 35.9 feet	Vertical Change	-.3	8 ft	8	REF			
49580	54.9 to 55.9 feet	Vertical Change	-.34	8 ft	8	REF			
51922	114.8 to 115.8 feet	Vertical Change	-.29	8 ft	8	REF			
41927	175.0 to 176.0 feet	Vertical Change	-.79	8 ft	8	REF			
57727	194.8 to 244.1 feet	Driveway				REF			
52343	194.9 to 195.9 feet	Vertical Change	-.28	8 ft	8	REF			
902	200.8 to 231.9 feet	Cross Slope (Driveway)	8.0-9.0%	8 ft	233	SF	\$40	\$9,330	
907	234.1 to 240.8 feet	Cross Slope (Driveway)	8.0-9.0%	8 ft	50	SF	\$40	\$2,010	
39982	240.5 to 241.6 feet	Running Slope	5.0-6.0%	8 ft	8	REF			
908	245.2 to 303.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	435	SF	\$120	\$52,200	
57234	266.4 to 267.4 feet	Vertical Change	.72	8 ft	8	REF			
51923	271.9 to 272.9 feet	Vertical Change	-.29	8 ft	8	REF			
TOTAL COST FOR: SE side of ROBERTSON BLVD Starting at: CHOWCHILLA BLVD							\$235,800.00		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908201247	ROBERTSON BLVD	FRONT ST	1ST ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
53314	4.0 to 5.0 feet	Vertical Change	-.26	11 ft	11	LF	\$75	\$825	
43689	27.9 to 28.9 feet	Vertical Change	-.59	11 ft	11	SF	\$75	\$825	
915	34.2 to 49.8 feet	Cross Slope (PAR)	2.0-3.0%	11 ft	172	SF	\$120	\$20,592	
48401	37.8 to 38.8 feet	Vertical Change	-.38	11 ft	11	REF			
46988	47.9 to 48.9 feet	Vertical Change	-.43	11 ft	11	REF			
916	56.7 to 94.3 feet	Cross Slope (PAR)	2.0-3.0%	11 ft	414	SF	\$120	\$49,632	
48675	68.0 to 69.0 feet	Vertical Change	-.37	11 ft	11	REF			
49252	78.1 to 79.1 feet	Vertical Change	-.35	11 ft	11	REF			
47211	88.0 to 89.0 feet	Vertical Change	-.42	11 ft	11	REF			
47875	98.2 to 99.2 feet	Vertical Change	-.4	11 ft	11	LF	\$75	\$825	
57728	103.3 to 141.6 feet	Driveway				REF			
47212	108.8 to 109.8 feet	Vertical Change	-.42	11 ft	11	REF			
46306	117.5 to 118.5 feet	Vertical Change	-.46	11 ft	11	REF			
49253	135.1 to 136.1 feet	Vertical Change	-.35	11 ft	11	REF			
49901	143.8 to 144.8 feet	Vertical Change	-.33	11 ft	11	LF	\$75	\$825	
44392	164.4 to 165.4 feet	Vertical Change	-.55	11 ft	11	SF	\$75	\$825	
44608	174.4 to 175.4 feet	Vertical Change	-.54	11 ft	11	SF	\$75	\$825	
45187	184.4 to 185.4 feet	Vertical Change	-.51	11 ft	11	SF	\$75	\$825	
49254	194.4 to 196.5 feet	Vertical Change	-.35	11 ft	23	LF	\$75	\$1,733	
46082	204.3 to 205.3 feet	Vertical Change	-.47	11 ft	11	LF	\$75	\$825	
49902	214.4 to 215.4 feet	Vertical Change	-.33	11 ft	11	LF	\$75	\$825	
51924	224.3 to 225.3 feet	Vertical Change	-.29	11 ft	11	LF	\$75	\$825	
917	242.5 to 243.8 feet	Cross Slope (PAR)	2.0-3.0%	11 ft	14	SF	\$120	\$1,716	
44813	244.3 to 245.3 feet	Vertical Change	-.53	11 ft	11	SF	\$75	\$825	
44181	254.3 to 255.3 feet	Vertical Change	-.56	11 ft	11	SF	\$75	\$825	
46530	261.7 to 262.7 feet	Vertical Change	-.45	11 ft	11	LF	\$75	\$825	
50230	265.7 to 266.7 feet	Vertical Change	-.32	11 ft	11	LF	\$75	\$825	
46531	275.2 to 276.2 feet	Vertical Change	-.45	11 ft	11	LF	\$75	\$825	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1908201247	ROBERTSON BLVD	FRONT ST	1ST ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
TOTAL COST FOR: NW							<i>side of</i>	\$86,047.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority			
NW	1908201305	ROBERTSON BLVD	1ST ST	2ND ST				TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
918	5.6 to 38.3 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	441	SF	\$120	\$52,974			
52344	6.8 to 7.8 feet	Vertical Change	-.28	14 ft	14	REF					
919	43.6 to 52.8 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	124	SF	\$120	\$14,904			
57729	50.9 to 70.3 feet	Driveway				REF					
920	57.1 to 64.1 feet	Cross Slope (Driveway)	2.0-3.0%	14 ft	94	SF	\$40	\$3,780			
921	66.8 to 72.3 feet	Cross Slope (Driveway)	2.0-3.0%	14 ft	74	SF	\$40	\$2,970			
922	79.9 to 95.3 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	208	SF	\$120	\$24,948			
923	125.5 to 127.8 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	31	SF	\$120	\$3,726			
57730	173.0 to 210.8 feet	Driveway				REF					
924	219.9 to 225.3 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	73	SF	\$120	\$8,748			
925	230.2 to 254.5 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	328	SF	\$120	\$39,366			
57731	256.1 to 294.9 feet	Driveway				REF					
928	259.2 to 265.6 feet	Cross Slope (Driveway)	2.0-3.0%	14 ft	86	SF	\$40	\$3,456			
TOTAL COST FOR: NW							<i>side of</i>	ROBERTSON BLVD	<i>Starting at:</i>	1ST ST	\$154,872.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1908201308	ROBERTSON BLVD	2ND ST	3RD ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
931	0.0 to 4.1 feet	Cross Slope (PAR)	4.0-5.0%	14 ft	55	SF	\$120	\$6,642
933	4.1 to 10.8 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	90	SF	\$120	\$10,854
935	15.1 to 199.4 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	2488	SF	\$120	\$298,566
950	199.4 to 209.8 feet	Cross Slope (PAR)	4.0-5.0%	14 ft	140	SF	\$120	\$16,848
952	209.8 to 226.8 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	230	SF	\$120	\$27,540
955	231.5 to 261.8 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	409	SF	\$120	\$49,086
46307	261.9 to 262.9 feet	Vertical Change	-46	14 ft	14	REF		
958	262.6 to 265.4 feet	Cross Slope (PAR)	5.0-6.0%	14 ft	38	SF	\$120	\$4,536
959	267.8 to 278.7 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	147	SF	\$120	\$17,658
960	283.1 to 291.8 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	117	SF	\$120	\$14,094
TOTAL COST FOR: NW side of ROBERTSON BLVD Starting at: 2ND ST							\$445,824.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1908201311	ROBERTSON BLVD	3RD ST	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
962	3.8 to 155.4 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	2047	SF	\$120	\$245,592
974	158.5 to 201.5 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	581	SF	\$120	\$69,660
57732	159.6 to 182.4 feet	Driveway				REF		
977	204.2 to 239.0 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	470	SF	\$120	\$56,376
978	242.5 to 248.3 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	78	SF	\$120	\$9,396
979	264.6 to 267.7 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	42	SF	\$120	\$5,022
980	275.7 to 290.7 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	203	SF	\$120	\$24,300
TOTAL COST FOR: NW side of ROBERTSON BLVD Starting at: 3RD ST							\$410,346.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908201315	ROBERTSON BLVD	4TH ST	5TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
981	0.0 to 1.8 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	24	SF	\$120	\$2,916	
57163	7.1 to 8.1 feet	Vertical Change	.69	14 ft	14	REF			
982	7.2 to 21.5 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	193	SF	\$120	\$23,166	
57733	10.4 to 34.0 feet	Driveway				REF			
49256	13.0 to 14.0 feet	Vertical Change	-.35	14 ft	14	REF			
52815	17.8 to 18.8 feet	Vertical Change	-.27	14 ft	14	REF			
984	21.5 to 26.6 feet	Cross Slope (Driveway)	4.0-5.0%	14 ft	69	SF	\$40	\$2,754	
986	26.6 to 87.3 feet	Cross Slope (Driveway)	2.0-3.0%	14 ft	819	SF	\$40	\$32,778	
52345	51.5 to 52.5 feet	Vertical Change	-.28	14 ft	14	REF			
44609	63.3 to 64.3 feet	Vertical Change	-.54	14 ft	14	REF			
57734	95.3 to 147.1 feet	Driveway				REF			
992	97.5 to 111.3 feet	Cross Slope (Driveway)	2.0-3.0%	14 ft	186	SF	\$40	\$7,452	
49257	98.8 to 99.8 feet	Vertical Change	-.35	14 ft	14	REF			
993	116.1 to 142.1 feet	Cross Slope (Driveway)	2.0-3.0%	14 ft	351	SF	\$40	\$14,040	
996	145.5 to 147.7 feet	Cross Slope (Driveway)	2.0-3.0%	14 ft	30	SF	\$40	\$1,188	
997	155.9 to 157.6 feet	Cross Slope (PAR)	9.0-10.0%	14 ft	23	SF	\$120	\$2,754	
998	194.7 to 234.0 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	531	SF	\$120	\$63,666	
57735	208.3 to 235.5 feet	Driveway				REF			
1005	245.3 to 253.7 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	113	SF	\$120	\$13,608	
1006	258.8 to 292.9 feet	Cross Slope (PAR)	2.0-3.0%	14 ft	460	SF	\$120	\$55,242	
48402	264.5 to 265.5 feet	Vertical Change	-.38	14 ft	14	REF			
51925	279.5 to 280.5 feet	Vertical Change	-.29	14 ft	14	REF			
TOTAL COST FOR: NW							<i>side of</i> ROBERTSON BLVD	<i>Starting at:</i> 4TH ST	\$219,564.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908201319	ROBERTSON BLVD	5TH ST	6TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
1012	0.0 to 6.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	37	SF	\$120	\$4,392	
1013	6.1 to 9.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,664	
1014	16.8 to 21.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,528	
1016	21.7 to 36.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	86	SF	\$120	\$10,368	
1018	36.1 to 135.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	598	SF	\$120	\$71,784	
51926	41.5 to 42.5 feet	Vertical Change	-.29	6 ft	6	REF			
53315	74.2 to 75.2 feet	Vertical Change	-.26	6 ft	6	REF			
48403	106.4 to 107.4 feet	Vertical Change	-.38	6 ft	6	REF			
48676	141.9 to 142.9 feet	Vertical Change	-.37	6 ft	6	LF	\$75	\$450	
1027	157.2 to 172.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	93	SF	\$120	\$11,160	
56907	162.9 to 163.9 feet	Vertical Change	.5	6 ft	6	REF			
57736	170.1 to 184.5 feet	Driveway				REF			
1030	175.8 to 184.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	52	SF	\$40	\$2,064	
1031	203.2 to 205.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,728	
1032	212.8 to 220.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,472	
1033	225.8 to 235.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	58	SF	\$120	\$6,912	
1034	257.2 to 261.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168	
1035	265.7 to 267.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,296	
50607	268.5 to 269.5 feet	Vertical Change	-.31	6 ft	6	LF	\$75	\$450	
1036	272.1 to 289.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	103	SF	\$120	\$12,384	
57120	286.2 to 287.2 feet	Vertical Change	.6	6 ft	6	REF			
46532	288.9 to 289.9 feet	Vertical Change	-.45	6 ft	6	REF			
TOTAL COST FOR: NW side of ROBERTSON BLVD Starting at: 5TH ST								\$137,820.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908201322	ROBERTSON BLVD	6TH ST	7TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
46083	1.4 to 2.4 feet	Vertical Change	-.47	6 ft	6	LF	\$75	\$450	
1037	2.6 to 6.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,448	
41643	41.4 to 42.4 feet	Vertical Change	-.93	6 ft	6	SF	\$75	\$450	
55966	41.5 to 42.5 feet	Vertical Change	.36	6 ft	6	LF	\$75	\$450	
50231	63.3 to 64.3 feet	Vertical Change	-.32	6 ft	6	LF	\$75	\$450	
42367	71.6 to 72.6 feet	Vertical Change	-.7	6 ft	6	SF	\$75	\$450	
53833	131.7 to 132.7 feet	Vertical Change	-.25	6 ft	6	LF	\$75	\$450	
46308	161.9 to 162.9 feet	Vertical Change	-.46	6 ft	6	LF	\$75	\$450	
47461	192.1 to 193.1 feet	Vertical Change	-.41	6 ft	6	LF	\$75	\$450	
1038	193.8 to 200.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,112	
1040	204.9 to 205.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$720	
1041	219.0 to 225.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,536	
1043	232.8 to 267.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	208	SF	\$120	\$24,912	
44814	252.2 to 253.2 feet	Vertical Change	-.53	6 ft	6	REF			
1049	279.4 to 281.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,152	
46533	282.2 to 283.2 feet	Vertical Change	-.45	6 ft	6	LF	\$75	\$450	
44610	300.3 to 301.3 feet	Vertical Change	-.54	6 ft	6	SF	\$75	\$450	
41644	307.8 to 308.8 feet	Vertical Change	-.93	6 ft	6	SF	\$75	\$450	
42170	313.9 to 314.9 feet	Vertical Change	-.73	6 ft	6	SF	\$75	\$450	
TOTAL COST FOR: NW side of ROBERTSON BLVD Starting at: 6TH ST								\$44,280.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908201326	ROBERTSON BLVD	7TH ST	8TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
48677	6.5 to 7.5 feet	Vertical Change	-.37	6 ft	6	LF	\$75	\$450	
43690	16.4 to 17.4 feet	Vertical Change	-.59	6 ft	6	SF	\$75	\$450	
1050	23.6 to 29.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,464	
46309	26.6 to 27.6 feet	Vertical Change	-.46	6 ft	6	REF			
45188	36.5 to 37.5 feet	Vertical Change	-.51	6 ft	6	SF	\$75	\$450	
44611	46.5 to 47.5 feet	Vertical Change	-.54	6 ft	6	SF	\$75	\$450	
44612	66.7 to 67.7 feet	Vertical Change	-.54	6 ft	6	SF	\$75	\$450	
46310	76.7 to 77.7 feet	Vertical Change	-.46	6 ft	6	LF	\$75	\$450	
45459	86.5 to 87.5 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$450	
47876	96.5 to 97.5 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$450	
57737	108.7 to 119.3 feet	Driveway				REF			
44613	111.4 to 112.4 feet	Vertical Change	-.54	6 ft	6	REF			
1051	114.8 to 120.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	37	SF	\$40	\$1,464	
52816	134.2 to 135.2 feet	Vertical Change	-.27	6 ft	6	LF	\$75	\$450	
50232	145.9 to 146.9 feet	Vertical Change	-.32	6 ft	6	LF	\$75	\$450	
53316	184.6 to 185.6 feet	Vertical Change	-.26	6 ft	6	LF	\$75	\$450	
44614	234.5 to 235.5 feet	Vertical Change	-.54	6 ft	6	SF	\$75	\$450	
57738	234.5 to 258.5 feet	Driveway				REF			
1052	247.0 to 252.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	30	SF	\$40	\$1,200	
43553	247.1 to 248.1 feet	Vertical Change	-.6	6 ft	6	REF			
43691	269.7 to 270.7 feet	Vertical Change	-.59	6 ft	6	SF	\$75	\$450	
43554	279.6 to 280.6 feet	Vertical Change	-.6	6 ft	6	SF	\$75	\$450	
42171	289.5 to 290.5 feet	Vertical Change	-.73	6 ft	6	SF	\$75	\$450	
TOTAL COST FOR: NW							<i>side of</i> ROBERTSON BLVD	<i>Starting at:</i> 7TH ST	\$13,878.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority		
NW	1908201329	ROBERTSON BLVD	8TH ST	9TH ST					TBD		
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
39983	1.5 to 5.4 feet	Running Slope	5.0-6.0%	6 ft	23	SF	\$120	\$2,808			
49903	1.9 to 2.9 feet	Vertical Change	-.33	6 ft	6	LF	\$75	\$450			
42368	13.7 to 14.7 feet	Vertical Change	-.7	6 ft	6	SF	\$75	\$450			
44182	25.6 to 26.6 feet	Vertical Change	-.56	6 ft	6	SF	\$75	\$450			
1053	39.1 to 47.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	49	SF	\$120	\$5,904			
42172	41.2 to 42.2 feet	Vertical Change	-.73	6 ft	6	REF					
1054	51.3 to 142.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	548	SF	\$120	\$65,808			
57739	54.7 to 64.5 feet	Driveway				REF					
53317	56.2 to 57.2 feet	Vertical Change	-.26	6 ft	6	REF					
42455	75.6 to 76.6 feet	Vertical Change	-.69	6 ft	6	REF					
41828	96.2 to 97.2 feet	Vertical Change	-.82	6 ft	6	REF					
41494	122.5 to 123.5 feet	Vertical Change	-1.1	6 ft	6	REF					
1061	142.7 to 152.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	59	SF	\$120	\$7,128			
1063	152.6 to 196.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	262	SF	\$120	\$31,464			
1068	207.3 to 238.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	185	SF	\$120	\$22,176			
53834	241.5 to 242.5 feet	Vertical Change	-.25	6 ft	6	LF	\$75	\$450			
1069	247.0 to 249.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,016			
1070	258.0 to 267.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	56	SF	\$120	\$6,696			
1071	271.2 to 277.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,680			
43365	271.6 to 272.6 feet	Vertical Change	-.61	6 ft	6	REF					
46084	282.9 to 286.7 feet	Vertical Change	-.47	6 ft	23	LF	\$75	\$1,710			
TOTAL COST FOR: NW							<i>side of</i>	ROBERTSON BLVD	<i>Starting at:</i>	8TH ST	\$152,190.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
NW	1908201331	ROBERTSON BLVD	9TH ST	10TH ST				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
1072	0.0 to 18.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	113	SF	\$120	\$13,536
1075	24.3 to 39.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	92	SF	\$120	\$11,016
1077	48.3 to 137.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	534	SF	\$120	\$64,080
57740	129.8 to 138.5 feet	Driveway				REF		
1088	143.5 to 153.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	62	SF	\$120	\$7,416
57741	147.8 to 158.0 feet	Driveway				REF		
1090	158.2 to 178.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	121	SF	\$40	\$4,848
56635	160.8 to 161.8 feet	Vertical Change	.47	6 ft	6	REF		
1093	182.8 to 198.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	94	SF	\$120	\$11,232
53318	185.0 to 186.0 feet	Vertical Change	-.26	6 ft	6	REF		
1094	202.7 to 232.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	181	SF	\$120	\$21,672
57742	224.8 to 242.3 feet	Driveway				REF		
1096	246.8 to 248.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,368
1097	274.6 to 276.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,152

TOTAL COST FOR: NW side of ROBERTSON BLVD Starting at: 9TH ST \$136,320.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority	
NW	1908201335	ROBERTSON BLVD	10TH ST	11TH ST				TBD	
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
1098	0.8 to 23.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	137	SF	\$120	\$16,488	
48678	35.8 to 36.8 feet	Vertical Change	-.37	6 ft	6	LF	\$75	\$450	
57743	44.6 to 65.8 feet	Driveway				REF			
50233	71.3 to 72.3 feet	Vertical Change	-.32	6 ft	6	LF	\$75	\$450	
1101	75.3 to 83.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	49	SF	\$120	\$5,904	
1102	94.2 to 118.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	148	SF	\$120	\$17,784	
57744	100.5 to 111.7 feet	Driveway				REF			
1103	121.1 to 133.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	75	SF	\$120	\$9,000	
1104	141.8 to 168.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	157	SF	\$120	\$18,864	
1107	173.3 to 177.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,952	
1108	287.0 to 290.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,592	
TOTAL COST FOR: NW							<i>side of</i> ROBERTSON BLVD	<i>Starting at:</i> 10TH ST	\$74,484.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908201340	ROBERTSON BLVD	11TH ST	13TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
53319	5.2 to 9.2 feet	Vertical Change	-.26	6 ft	24	LF	\$75	\$1,800	
1109	12.3 to 17.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,672	
1110	38.8 to 56.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	106	SF	\$120	\$12,744	
57745	47.3 to 91.8 feet	Driveway				REF			
51512	65.5 to 66.5 feet	Vertical Change	-.3	6 ft	6	REF			
1111	71.2 to 81.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	61	SF	\$40	\$2,424	
45883	73.6 to 74.6 feet	Vertical Change	-.48	6 ft	6	REF			
52817	81.6 to 82.6 feet	Vertical Change	-.27	6 ft	6	REF			
1112	86.6 to 116.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	177	SF	\$40	\$7,080	
46085	93.6 to 94.6 feet	Vertical Change	-.47	6 ft	6	REF			
46773	99.1 to 100.1 feet	Vertical Change	-.44	6 ft	6	REF			
46311	111.1 to 112.1 feet	Vertical Change	-.46	6 ft	6	REF			
1116	120.7 to 131.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	66	SF	\$120	\$7,920	
45460	122.7 to 123.7 feet	Vertical Change	-.5	6 ft	6	REF			
46086	134.8 to 135.8 feet	Vertical Change	-.47	6 ft	6	LF	\$75	\$450	
57746	137.8 to 149.0 feet	Driveway				REF			
50234	140.7 to 141.7 feet	Vertical Change	-.32	6 ft	6	REF			
49581	161.3 to 162.3 feet	Vertical Change	-.34	6 ft	6	LF	\$75	\$450	
52818	167.3 to 168.3 feet	Vertical Change	-.27	6 ft	6	LF	\$75	\$450	
52819	177.2 to 178.2 feet	Vertical Change	-.27	6 ft	6	LF	\$75	\$450	
45461	183.2 to 184.2 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$450	
47213	189.3 to 190.3 feet	Vertical Change	-.42	6 ft	6	LF	\$75	\$450	
1117	196.3 to 198.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,584	
1118	200.8 to 201.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
49904	207.2 to 208.2 feet	Vertical Change	-.33	6 ft	6	LF	\$75	\$450	
1119	219.3 to 245.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	157	SF	\$120	\$18,864	
57747	241.8 to 262.8 feet	Driveway				REF			
1120	252.5 to 262.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	59	SF	\$40	\$2,352	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908201340	ROBERTSON BLVD	11TH ST	13TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
44393	256.2 to 257.2 feet	Vertical Change	-.55	6 ft	6	REF			
1122	272.1 to 290.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	108	SF	\$120	\$12,960	
53320	314.3 to 315.3 feet	Vertical Change	-.26	6 ft	6	LF	\$75	\$450	
57748	315.2 to 332.8 feet	Driveway				REF			
48964	317.5 to 318.5 feet	Vertical Change	-.36	6 ft	6	REF			
1124	320.4 to 328.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	50	SF	\$40	\$2,016	
53835	327.3 to 328.3 feet	Vertical Change	-.25	6 ft	6	REF			
44815	336.8 to 339.0 feet	Vertical Change	-.53	6 ft	13	SF	\$75	\$990	
57749	354.3 to 365.5 feet	Driveway				REF			
48679	356.0 to 357.0 feet	Vertical Change	-.37	6 ft	6	REF			
57750	388.3 to 400.2 feet	Driveway				REF			
1125	403.6 to 405.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,440	
49905	405.4 to 406.4 feet	Vertical Change	-.33	6 ft	6	REF			
1126	409.7 to 452.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	259	SF	\$120	\$31,032	
44183	411.5 to 412.5 feet	Vertical Change	-.56	6 ft	6	REF			
47877	417.5 to 418.5 feet	Vertical Change	-.4	6 ft	6	REF			
48111	423.4 to 424.4 feet	Vertical Change	-.39	6 ft	6	REF			
52820	435.4 to 436.4 feet	Vertical Change	-.27	6 ft	6	REF			
57751	438.6 to 450.1 feet	Driveway				REF			
1127	463.6 to 492.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	173	SF	\$120	\$20,736	
53321	491.2 to 492.2 feet	Vertical Change	-.26	6 ft	6	REF			
1128	505.8 to 509.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,592	
57752	514.2 to 536.7 feet	Driveway				REF			
1129	517.6 to 540.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	136	SF	\$40	\$5,424	
51513	531.2 to 532.2 feet	Vertical Change	-.3	6 ft	6	REF			
1132	540.2 to 542.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	16	SF	\$120	\$1,872	
42867	541.2 to 542.2 feet	Vertical Change	-.65	6 ft	6	REF			
1134	542.8 to 545.7 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	17	SF	\$120	\$2,088	
1135	545.7 to 554.2 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	51	SF	\$120	\$6,120	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1908201340	ROBERTSON BLVD	11TH ST	13TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
1137	554.2 to 556.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	13	SF	\$120	\$1,512
1138	556.3 to 593.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	226	SF	\$120	\$27,072
1145	593.9 to 619.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	153	SF	\$120	\$18,360
1147	619.4 to 626.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,824
TOTAL COST FOR: NW side of ROBERTSON BLVD Starting at: 11TH ST							\$201,870.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908201344	ROBERTSON BLVD	13TH ST	15TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
46087	0.3 to 1.3 feet	Vertical Change	-.47	6 ft	6	LF	\$75	\$450	
45189	7.6 to 8.6 feet	Vertical Change	-.51	6 ft	6	SF	\$75	\$450	
1148	32.4 to 42.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	62	SF	\$120	\$7,488	
44394	54.5 to 55.5 feet	Vertical Change	-.55	6 ft	6	SF	\$75	\$450	
1149	58.8 to 73.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	85	SF	\$120	\$10,224	
48680	63.5 to 64.5 feet	Vertical Change	-.37	6 ft	6	REF			
57753	73.1 to 114.3 feet	Driveway				REF			
55951	102.6 to 103.6 feet	Vertical Change	.33	6 ft	6	REF			
1152	141.1 to 155.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	88	SF	\$120	\$10,584	
57754	146.3 to 164.5 feet	Driveway				REF			
1155	164.5 to 196.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	190	SF	\$40	\$7,584	
57755	194.3 to 207.3 feet	Driveway				REF			
57756	225.0 to 239.6 feet	Driveway				REF			
46774	246.4 to 247.4 feet	Vertical Change	-.44	6 ft	6	LF	\$75	\$450	
50608	266.2 to 267.2 feet	Vertical Change	-.31	6 ft	6	LF	\$75	\$450	
48965	276.5 to 277.5 feet	Vertical Change	-.36	6 ft	6	LF	\$75	\$450	
51514	286.3 to 287.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$450	
53322	296.3 to 297.3 feet	Vertical Change	-.26	6 ft	6	LF	\$75	\$450	
47214	320.5 to 321.5 feet	Vertical Change	-.42	6 ft	6	LF	\$75	\$450	
57757	322.6 to 340.1 feet	Driveway				REF			
52346	356.5 to 357.5 feet	Vertical Change	-.28	6 ft	6	LF	\$75	\$450	
1158	364.2 to 367.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,160	
52821	366.6 to 367.6 feet	Vertical Change	-.27	6 ft	6	REF			
49582	376.6 to 377.6 feet	Vertical Change	-.34	6 ft	6	REF			
1159	377.2 to 392.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	94	SF	\$120	\$11,232	
46989	386.5 to 387.5 feet	Vertical Change	-.43	6 ft	6	REF			
1160	396.2 to 404.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,120	
45675	396.9 to 397.9 feet	Vertical Change	-.49	6 ft	6	REF			
46088	406.8 to 407.8 feet	Vertical Change	-.47	6 ft	6	LF	\$75	\$450	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908201344	ROBERTSON BLVD	13TH ST	15TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
44997	416.8 to 417.8 feet	Vertical Change	-.52	6 ft	6	SF	\$75	\$450	
1161	418.7 to 432.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	83	SF	\$120	\$9,936	
46534	426.7 to 427.7 feet	Vertical Change	-.45	6 ft	6	REF			
46535	437.0 to 438.0 feet	Vertical Change	-.45	6 ft	6	REF			
1162	437.8 to 456.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	109	SF	\$120	\$13,104	
57758	441.7 to 463.4 feet	Driveway				REF			
52822	444.9 to 445.9 feet	Vertical Change	-.27	6 ft	6	REF			
52347	468.9 to 469.9 feet	Vertical Change	-.28	6 ft	6	LF	\$75	\$450	
1165	488.6 to 493.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,384	
1166	525.5 to 539.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	86	SF	\$120	\$10,296	
1169	542.7 to 545.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,872	
1170	551.2 to 561.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	60	SF	\$120	\$7,200	
57759	564.3 to 589.2 feet	Driveway				REF			
1171	593.4 to 602.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,408	
51927	595.8 to 596.8 feet	Vertical Change	-.29	6 ft	6	REF			
1174	602.3 to 615.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	78	SF	\$120	\$9,360	
51515	613.0 to 614.0 feet	Vertical Change	-.3	6 ft	6	REF			
1178	615.3 to 622.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,400	
49258	622.1 to 623.1 feet	Vertical Change	-.35	6 ft	6	REF			
TOTAL COST FOR: NW							<i>side of ROBERTSON BLVD Starting at: 13TH ST</i>	\$128,202.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908201350	ROBERTSON BLVD	1520 ROBERTSON BLVD	WASHINGTON RD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
1179	0.0 to 14.3 feet	Cross Slope (PAR)	>15%	5 ft	72	SF	\$120	\$8,580	
57760	0.0 to 17.1 feet	Driveway				REF			
39984	13.3 to 14.8 feet	Running Slope	8.0-9.0%	5 ft	8	REF			
41853	16.3 to 17.3 feet	Vertical Change	-.81	5 ft	5	REF			
1180	17.5 to 38.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	106	SF	\$120	\$12,780	
42113	29.5 to 30.5 feet	Vertical Change	-.74	5 ft	5	REF			
1185	38.8 to 60.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	108	SF	\$120	\$12,960	
41657	44.5 to 45.5 feet	Vertical Change	-.92	5 ft	5	REF			
42369	59.4 to 60.4 feet	Vertical Change	-.7	5 ft	5	REF			
1188	60.4 to 102.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	210	SF	\$120	\$25,200	
49583	63.0 to 64.2 feet	Vertical Change	-.34	5 ft	6	REF			
55957	63.2 to 64.2 feet	Vertical Change	.34	5 ft	5	REF			
49584	63.4 to 64.4 feet	Vertical Change	-.34	5 ft	5	REF			
55967	63.5 to 64.5 feet	Vertical Change	.36	5 ft	5	REF			
47462	63.7 to 65.0 feet	Vertical Change	-.41	5 ft	7	REF			
55971	64.0 to 65.0 feet	Vertical Change	.37	5 ft	5	REF			
48967	64.1 to 65.1 feet	Vertical Change	-.36	5 ft	5	REF			
55946	64.2 to 65.2 feet	Vertical Change	.32	5 ft	5	REF			
48968	64.3 to 65.3 feet	Vertical Change	-.36	5 ft	5	REF			
55972	64.3 to 65.3 feet	Vertical Change	.37	5 ft	5	REF			
48112	64.4 to 65.6 feet	Vertical Change	-.39	5 ft	6	REF			
54139	64.6 to 65.6 feet	Vertical Change	.26	5 ft	5	REF			
49259	64.9 to 65.9 feet	Vertical Change	-.35	5 ft	5	REF			
55979	64.9 to 65.9 feet	Vertical Change	.38	5 ft	5	REF			
51928	65.0 to 66.2 feet	Vertical Change	-.29	5 ft	6	REF			
55944	65.3 to 66.3 feet	Vertical Change	.31	5 ft	5	REF			
44816	74.5 to 75.5 feet	Vertical Change	-.53	5 ft	5	REF			
44016	88.7 to 89.7 feet	Vertical Change	-.57	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1908201350	ROBERTSON BLVD	1520 ROBERTSON BLVD	WASHINGTON RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
49585	93.1 to 94.1 feet	Vertical Change	-.34	5 ft	5	REF		
TOTAL COST FOR: NW side of ROBERTSON BLVD Starting at: 1520 ROBERTSON BLVD							\$59,520.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority		
W/N	1908201356	ROBERTSON BLVD	SIDEWALK BEGINS	DOLLAR TREE PARKING LOT					TBD		
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
1190	6.8 to 37.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	153	SF	\$120	\$18,360			
51516	9.1 to 10.1 feet	Vertical Change	-.3	5 ft	5	REF					
42655	17.6 to 18.6 feet	Vertical Change	-.67	5 ft	5	REF					
51929	26.3 to 27.3 feet	Vertical Change	-.29	5 ft	5	REF					
52823	34.6 to 35.6 feet	Vertical Change	-.27	5 ft	5	REF					
1194	37.4 to 40.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	17	SF	\$120	\$2,040			
45884	39.6 to 40.6 feet	Vertical Change	-.48	5 ft	5	REF					
1196	40.8 to 60.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	98	SF	\$120	\$11,700			
52348	53.2 to 54.2 feet	Vertical Change	-.28	5 ft	5	REF					
53324	77.7 to 78.7 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375			
42750	80.3 to 81.3 feet	Vertical Change	-.66	5 ft	5	SF	\$75	\$375			
1198	85.5 to 122.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	184	SF	\$120	\$22,020			
50609	93.3 to 94.3 feet	Vertical Change	-.31	5 ft	5	REF					
53325	111.1 to 112.1 feet	Vertical Change	-.26	5 ft	5	REF					
48681	125.2 to 126.2 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375			
42000	129.8 to 130.8 feet	Vertical Change	-.77	5 ft	5	SF	\$75	\$375			
TOTAL COST FOR: W/N							<i>side of</i>	ROBERTSON BLVD	<i>Starting at:</i>	SIDEWALK BEGINS	\$55,620.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S/W/N	1908201408	ROBERTSON BLVD	DOLLAR TREE PARKING	COUNTRY WOOD SHOPPING					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
50610	3.1 to 4.1 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
1201	8.6 to 16.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,560	
1202	22.6 to 26.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400	
47215	25.1 to 29.0 feet	Vertical Change	-.42	5 ft	20	REF			
42173	43.6 to 44.6 feet	Vertical Change	-.73	5 ft	5	SF	\$75	\$375	
51517	60.9 to 61.9 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
1203	66.4 to 82.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	79	SF	\$120	\$9,540	
53326	83.9 to 84.9 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
41632	93.6 to 94.6 feet	Vertical Change	-.94	5 ft	5	SF	\$75	\$375	
49586	96.5 to 97.5 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375	
53837	116.6 to 117.6 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375	
1204	132.0 to 140.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,280	
1205	145.8 to 197.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	260	SF	\$120	\$31,200	
48969	168.5 to 169.5 feet	Vertical Change	-.36	5 ft	5	REF			
50611	187.7 to 188.7 feet	Vertical Change	-.31	5 ft	5	REF			
49260	196.7 to 197.7 feet	Vertical Change	-.35	5 ft	5	REF			
10	200.9 to 201.9 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
49261	207.4 to 208.4 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$375	
56979	207.4 to 208.4 feet	Vertical Change	.58	5 ft	5	SF	\$75	\$375	
1210	226.4 to 236.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,820	
1211	254.8 to 263.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$5,040	
52824	267.2 to 268.2 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
39985	308.1 to 309.3 feet	Running Slope	5.0-6.0%	5 ft	6	SF	\$120	\$720	
57225	308.6 to 309.6 feet	Vertical Change	.7	5 ft	5	SF	\$75	\$375	
1212	310.2 to 311.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660	
1213	314.8 to 318.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400	
53327	318.7 to 319.7 feet	Vertical Change	-.26	5 ft	5	REF			
51931	337.8 to 338.8 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S/W/N	1908201408	ROBERTSON BLVD	DOLLAR TREE PARKING	COUNTRY WOOD SHOPPING					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
53838	352.7 to 353.7 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375	
11	354.9 to 355.9 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
1214	377.6 to 378.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600	
1215	393.3 to 405.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,020	
1217	405.0 to 459.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	273	SF	\$120	\$32,760	
50612	413.4 to 414.4 feet	Vertical Change	-.31	5 ft	5	REF			
49262	445.4 to 446.4 feet	Vertical Change	-.35	5 ft	5	REF			
1225	459.6 to 465.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,780	
51518	465.2 to 466.2 feet	Vertical Change	-.3	5 ft	5	REF			
50613	476.4 to 477.4 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
49908	483.9 to 484.9 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375	
47463	490.3 to 491.3 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375	
1226	501.7 to 512.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,180	
1228	512.0 to 547.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	177	SF	\$120	\$21,240	
43366	528.6 to 529.6 feet	Vertical Change	-.61	5 ft	5	REF			
1230	547.4 to 551.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700	
TOTAL COST FOR: S/W/N side of ROBERTSON BLVD Starting at: DOLLAR TREE PARKING LOT							\$149,100.00		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1908201414	ADAMS DR	COUNTRY WOOD	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39986	0.0 to 4.2 feet	Running Slope	6.0-7.0%	5 ft	21	SF	\$120	\$2,520
39987	4.2 to 7.2 feet	Running Slope	5.0-6.0%	5 ft	15	SF	\$120	\$1,800
50614	10.2 to 11.2 feet	Vertical Change	-31	5 ft	5	LF	\$75	\$375
1231	24.8 to 41.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	85	SF	\$120	\$10,200
1232	46.1 to 64.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	94	SF	\$120	\$11,280
45885	52.2 to 53.2 feet	Vertical Change	-.48	5 ft	5	REF		
52825	56.0 to 57.0 feet	Vertical Change	-.27	5 ft	5	REF		
50237	71.6 to 72.6 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375
49587	84.1 to 85.1 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: SW side of ADAMS DR Starting at: COUNTRY WOOD SHOPPING								\$26,925.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908201419	ROBERTSON BLVD	COUNTRY WOOD	MYER ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
1233	0.0 to 13.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	69	SF	\$120	\$8,220	
12	13.7 to 14.7 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
47216	14.9 to 15.9 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375	
1235	23.6 to 28.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000	
53328	25.5 to 26.5 feet	Vertical Change	-.26	5 ft	5	REF			
1236	37.8 to 85.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	238	SF	\$120	\$28,500	
49263	41.1 to 42.1 feet	Vertical Change	-.35	5 ft	5	REF			
49264	58.0 to 59.0 feet	Vertical Change	-.35	5 ft	5	REF			
46775	75.0 to 76.0 feet	Vertical Change	-.44	5 ft	5	REF			
1237	90.5 to 99.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,340	
46536	91.4 to 92.4 feet	Vertical Change	-.45	5 ft	5	REF			
1238	102.2 to 108.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020	
52826	108.3 to 109.3 feet	Vertical Change	-.27	5 ft	5	REF			
53329	115.3 to 116.3 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
13	119.3 to 120.3 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
44817	122.7 to 123.7 feet	Vertical Change	-.53	5 ft	5	SF	\$75	\$375	
1239	132.8 to 135.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560	
53330	142.3 to 143.3 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
1240	148.7 to 154.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,660	
1241	157.7 to 159.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960	
1242	179.0 to 192.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,160	
1244	192.6 to 203.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	52	SF	\$120	\$6,240	
1246	203.0 to 205.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500	
49588	209.1 to 210.1 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375	
53331	222.1 to 223.1 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
52827	226.2 to 227.2 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
47878	243.1 to 244.1 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375	
52349	259.8 to 260.8 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1908201419	ROBERTSON BLVD	COUNTRY WOOD	MYER ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
52350	287.6 to 288.6 feet	Vertical Change	-28	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: NW								\$76,110.00
<i>side of ROBERTSON BLVD Starting at: COUNTRY WOOD SHOPPING</i>								

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908201433	MYER ST	ROBERTSON BLVD	KITES WAY	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
1247	8.2 to 45.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	189	SF	\$120	\$22,620	
53332	20.6 to 21.6 feet	Vertical Change	-.26	5 ft	5	REF			
51519	40.6 to 41.6 feet	Vertical Change	-.3	5 ft	5	REF			
49589	45.7 to 46.7 feet	Vertical Change	-.34	5 ft	5	REF			
1251	50.4 to 74.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	122	SF	\$120	\$14,580	
53333	51.2 to 52.2 feet	Vertical Change	-.26	5 ft	5	REF			
51520	56.3 to 57.3 feet	Vertical Change	-.3	5 ft	5	REF			
53334	71.2 to 72.2 feet	Vertical Change	-.26	5 ft	5	REF			
1254	78.9 to 81.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320	
47464	80.9 to 81.9 feet	Vertical Change	-.41	5 ft	5	REF			
1255	81.8 to 84.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	14	SF	\$120	\$1,620	
1257	86.2 to 100.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,820	
57761	91.3 to 122.3 feet	Driveway				REF			
1260	100.9 to 103.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	14	SF	\$40	\$540	
1262	103.6 to 105.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	11	SF	\$40	\$440	
1264	105.8 to 120.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	73	SF	\$40	\$2,900	
47879	106.1 to 107.1 feet	Vertical Change	-.4	5 ft	5	REF			
56616	107.9 to 108.9 feet	Vertical Change	.4	5 ft	5	REF			
39988	118.8 to 120.1 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
1269	122.8 to 123.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$600	
46776	123.0 to 124.0 feet	Vertical Change	-.44	5 ft	5	REF			
1270	123.8 to 126.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500	
14	124.2 to 125.2 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
15	129.3 to 130.3 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
53335	132.8 to 133.8 feet	Vertical Change	-.26	5 ft	5	REF			
1271	133.3 to 180.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	236	SF	\$120	\$28,380	
53336	145.1 to 146.1 feet	Vertical Change	-.26	5 ft	5	REF			
51932	162.6 to 163.6 feet	Vertical Change	-.29	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908201433	MYER ST	ROBERTSON BLVD	KITES WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
1275	180.6 to 241.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	303	SF	\$120	\$36,300
53839	184.2 to 187.7 feet	Vertical Change	-25	5 ft	18	REF		
48970	196.7 to 197.7 feet	Vertical Change	-36	5 ft	5	REF		
52351	214.4 to 215.4 feet	Vertical Change	-28	5 ft	5	REF		
52829	231.8 to 232.8 feet	Vertical Change	-27	5 ft	5	REF		
1283	241.1 to 245.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520
57762	247.7 to 284.8 feet	Driveway				REF		
1284	249.3 to 250.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240
52352	250.6 to 251.6 feet	Vertical Change	-28	5 ft	5	REF		
1285	254.3 to 270.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	80	SF	\$40	\$3,180
44818	268.0 to 269.0 feet	Vertical Change	-.53	5 ft	5	REF		
57134	268.2 to 269.2 feet	Vertical Change	.62	5 ft	5	REF		
1287	270.2 to 280.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	49	SF	\$40	\$1,960
39989	279.3 to 281.5 feet	Running Slope	6.0-7.0%	5 ft	11	REF		
1289	280.0 to 282.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	13	SF	\$40	\$520
53337	284.8 to 285.8 feet	Vertical Change	-.26	5 ft	5	REF		
1290	286.2 to 318.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	159	SF	\$120	\$19,080
50615	312.0 to 313.0 feet	Vertical Change	-.31	5 ft	5	REF		
1294	318.0 to 349.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	156	SF	\$120	\$18,720
49909	330.1 to 331.1 feet	Vertical Change	-.33	5 ft	5	REF		
1301	349.2 to 397.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	243	SF	\$120	\$29,100
47880	365.9 to 366.9 feet	Vertical Change	-.4	5 ft	5	REF		
48404	384.3 to 385.3 feet	Vertical Change	-.38	5 ft	5	REF		
1305	397.7 to 418.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	106	SF	\$120	\$12,720
52353	402.6 to 403.6 feet	Vertical Change	-28	5 ft	5	REF		
1307	418.9 to 451.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	164	SF	\$120	\$19,680
52830	420.7 to 421.7 feet	Vertical Change	-27	5 ft	5	REF		
53840	443.3 to 444.3 feet	Vertical Change	-.25	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908201433	MYER ST	ROBERTSON BLVD	KITES WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
1309	451.7 to 456.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	24	SF	\$120	\$2,820	
57763	454.1 to 496.1 feet	Driveway				REF			
1311	459.0 to 478.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	96	SF	\$40	\$3,820	
49265	470.2 to 471.2 feet	Vertical Change	-.35	5 ft	5	REF			
52354	477.1 to 478.1 feet	Vertical Change	-.28	5 ft	5	REF			
1315	478.1 to 493.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	76	SF	\$40	\$3,040	
39990	491.3 to 493.4 feet	Running Slope	5.0-6.0%	5 ft	11	REF			
1317	498.8 to 501.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500	
16	501.1 to 502.1 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
17	505.5 to 506.5 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
1318	510.2 to 589.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	397	SF	\$120	\$47,640	
47217	513.8 to 514.8 feet	Vertical Change	-.42	5 ft	5	REF			
45190	540.9 to 541.9 feet	Vertical Change	-.51	5 ft	5	REF			
48405	556.3 to 557.3 feet	Vertical Change	-.38	5 ft	5	REF			
51933	569.1 to 570.1 feet	Vertical Change	-.29	5 ft	5	REF			
52831	587.5 to 588.5 feet	Vertical Change	-.27	5 ft	5	REF			
1327	596.5 to 655.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	294	SF	\$120	\$35,280	
49910	596.7 to 597.7 feet	Vertical Change	-.33	5 ft	5	REF			
52832	605.8 to 606.8 feet	Vertical Change	-.27	5 ft	5	REF			
49911	636.8 to 637.8 feet	Vertical Change	-.33	5 ft	5	REF			
52355	652.1 to 653.1 feet	Vertical Change	-.28	5 ft	5	REF			
1331	657.8 to 667.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$6,000	
57764	663.9 to 699.5 feet	Driveway				REF			
47218	667.4 to 668.4 feet	Vertical Change	-.42	5 ft	5	REF			
1333	671.1 to 687.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	82	SF	\$40	\$3,280	
51521	675.9 to 676.9 feet	Vertical Change	-.3	5 ft	5	REF			
53338	684.1 to 685.1 feet	Vertical Change	-.26	5 ft	5	REF			
1335	687.5 to 695.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	41	SF	\$40	\$1,640	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908201433	MYER ST	ROBERTSON BLVD	KITES WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
1337	695.7 to 696.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	5	SF	\$40	\$200	
43845	699.3 to 700.3 feet	Vertical Change	-.58	5 ft	5	REF			
1338	700.0 to 705.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	25	SF	\$40	\$1,000	
57765	701.8 to 734.8 feet	Driveway				REF			
50616	703.4 to 704.4 feet	Vertical Change	-.31	5 ft	5	REF			
39991	703.6 to 705.6 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
1340	706.7 to 732.6 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	130	SF	\$40	\$5,180	
39992	730.5 to 732.7 feet	Running Slope	6.0-7.0%	5 ft	11	REF			
1346	744.1 to 859.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	578	SF	\$120	\$69,300	
51522	824.6 to 825.6 feet	Vertical Change	-.3	5 ft	5	REF			
48682	839.7 to 840.7 feet	Vertical Change	-.37	5 ft	5	REF			
50617	871.5 to 872.5 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
1357	875.0 to 905.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	154	SF	\$120	\$18,420	
52833	886.4 to 887.4 feet	Vertical Change	-.27	5 ft	5	REF			
1359	913.1 to 914.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900	
1360	917.3 to 954.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	186	SF	\$120	\$22,320	
51934	937.5 to 938.5 feet	Vertical Change	-.29	5 ft	5	REF			
1363	954.5 to 1007.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	264	SF	\$120	\$31,620	
43846	963.5 to 964.5 feet	Vertical Change	-.58	5 ft	5	REF			
53841	983.4 to 984.4 feet	Vertical Change	-.25	5 ft	5	REF			
57766	1003.5 to 1039.0 feet	Driveway				REF			
1366	1010.7 to 1034.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	118	SF	\$40	\$4,700	
45676	1022.4 to 1023.4 feet	Vertical Change	-.49	5 ft	5	REF			
39993	1034.4 to 1035.6 feet	Running Slope	6.0-7.0%	5 ft	6	REF			
1371	1038.3 to 1042.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	23	SF	\$40	\$900	
57343	1043.7 to 1044.7 feet	Vertical Change	.99	5 ft	5	SF	\$75	\$375	
47465	1044.1 to 1045.1 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375	
1372	1045.5 to 1048.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908201433	MYER ST	ROBERTSON BLVD	KITES WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46777	1047.9 to 1048.9 feet	Vertical Change	-.44	5 ft	5	REF		
41372	1048.5 to 1049.5 feet	Vertical Change	-1.35	5 ft	5	SF	\$75	\$375
1373	1052.8 to 1090.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	189	SF	\$120	\$22,620
51935	1053.6 to 1054.6 feet	Vertical Change	-.29	5 ft	5	REF		
49912	1076.1 to 1077.1 feet	Vertical Change	-.33	5 ft	5	REF		
1377	1090.5 to 1117.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	136	SF	\$120	\$16,320
48113	1096.0 to 1097.0 feet	Vertical Change	-.39	5 ft	5	REF		
53842	1103.6 to 1104.6 feet	Vertical Change	-.25	5 ft	5	REF		
50239	1116.1 to 1117.1 feet	Vertical Change	-.32	5 ft	5	REF		
1379	1117.7 to 1127.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,060
52356	1119.2 to 1120.2 feet	Vertical Change	-.28	5 ft	5	REF		
49590	1129.4 to 1130.4 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375
1380	1131.1 to 1217.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	430	SF	\$120	\$51,600
44819	1156.2 to 1157.2 feet	Vertical Change	-.53	5 ft	5	REF		
47466	1176.2 to 1177.2 feet	Vertical Change	-.41	5 ft	5	REF		
57767	1212.8 to 1248.5 feet	Driveway				REF		
52357	1216.2 to 1217.2 feet	Vertical Change	-.28	5 ft	5	REF		
39994	1217.0 to 1218.4 feet	Running Slope	5.0-6.0%	5 ft	7	REF		
1390	1220.0 to 1244.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	125	SF	\$40	\$4,980
48406	1232.8 to 1233.8 feet	Vertical Change	-.38	5 ft	5	REF		
44820	1236.6 to 1237.6 feet	Vertical Change	-.53	5 ft	5	REF		
39995	1245.1 to 1246.5 feet	Running Slope	10.0-11.0%	5 ft	7	REF		
44615	1248.5 to 1254.9 feet	Vertical Change	-.54	5 ft	32	REF		
1394	1248.7 to 1249.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
1395	1259.8 to 1261.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140
TOTAL COST FOR: N side of MYER ST Starting at: ROBERTSON BLVD							\$596,175.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908201441	MYER ST	KITES WAY	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
1396	1.4 to 44.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	216	SF	\$120	\$25,920	
46089	18.3 to 19.3 feet	Vertical Change	-47	5 ft	5	REF			
46778	23.2 to 24.2 feet	Vertical Change	-44	5 ft	5	REF			
42215	33.1 to 34.1 feet	Vertical Change	-72	5 ft	5	REF			
52358	42.7 to 43.7 feet	Vertical Change	-28	5 ft	5	REF			
46990	46.0 to 47.0 feet	Vertical Change	-43	5 ft	5	LF	\$75	\$375	
53339	49.4 to 50.4 feet	Vertical Change	-26	5 ft	5	LF	\$75	\$375	
49592	53.2 to 54.2 feet	Vertical Change	-34	5 ft	5	LF	\$75	\$375	
47219	63.2 to 64.2 feet	Vertical Change	-42	5 ft	5	LF	\$75	\$375	
1401	64.8 to 92.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	140	SF	\$120	\$16,800	
50618	73.0 to 74.0 feet	Vertical Change	-31	5 ft	5	REF			
44184	88.1 to 89.1 feet	Vertical Change	-56	5 ft	5	REF			
57126	88.2 to 89.2 feet	Vertical Change	.61	5 ft	5	REF			
41535	92.4 to 93.4 feet	Vertical Change	-1.04	5 ft	5	REF			
41272	94.7 to 95.7 feet	Vertical Change	-1.7	5 ft	5	REF			
53340	94.7 to 95.7 feet	Vertical Change	-26	5 ft	5	REF			
41354	94.9 to 95.9 feet	Vertical Change	-1.38	5 ft	5	REF			
57293	95.1 to 96.1 feet	Vertical Change	.85	5 ft	5	REF			
1404	95.5 to 163.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	342	SF	\$120	\$40,980	
52834	103.3 to 104.3 feet	Vertical Change	-27	5 ft	5	REF			
42270	123.4 to 124.4 feet	Vertical Change	-71	5 ft	5	REF			
47881	133.4 to 134.4 feet	Vertical Change	-4	5 ft	5	REF			
51524	153.4 to 154.4 feet	Vertical Change	-3	5 ft	5	REF			
41623	163.2 to 164.2 feet	Vertical Change	-95	5 ft	5	REF			
52359	170.8 to 171.8 feet	Vertical Change	-28	5 ft	5	LF	\$75	\$375	
1409	182.2 to 187.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,940	
46991	187.0 to 188.0 feet	Vertical Change	-43	5 ft	5	REF			
45462	194.1 to 195.1 feet	Vertical Change	-5	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908201441	MYER ST	KITES WAY	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
1410	195.1 to 196.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
45677	198.2 to 199.2 feet	Vertical Change	-49	5 ft	5	LF	\$75	\$375
1411	203.0 to 213.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,120
48114	211.1 to 212.1 feet	Vertical Change	-39	5 ft	5	REF		
57768	221.6 to 254.9 feet	Driveway				REF		
46312	225.6 to 226.6 feet	Vertical Change	-46	5 ft	5	REF		
1414	225.9 to 249.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	117	SF	\$40	\$4,660
46313	230.2 to 231.2 feet	Vertical Change	-46	5 ft	5	REF		
43692	234.8 to 235.8 feet	Vertical Change	-59	5 ft	5	REF		
49913	238.6 to 239.6 feet	Vertical Change	-33	5 ft	5	REF		
46090	242.4 to 243.4 feet	Vertical Change	-47	5 ft	5	REF		
52360	246.6 to 247.6 feet	Vertical Change	-28	5 ft	5	REF		
1419	249.2 to 257.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	39	SF	\$40	\$1,560
52835	253.8 to 254.8 feet	Vertical Change	-27	5 ft	5	REF		
1423	257.0 to 258.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960
1424	269.5 to 368.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	496	SF	\$120	\$59,460
51525	287.2 to 288.2 feet	Vertical Change	-3	5 ft	5	REF		
53341	358.4 to 359.4 feet	Vertical Change	-26	5 ft	5	REF		
1432	368.6 to 393.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	125	SF	\$120	\$14,940
1436	393.5 to 409.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	82	SF	\$120	\$9,780
18	408.0 to 409.0 feet	Continuous Width		5 ft	5	SF	\$120	\$600
44185	410.8 to 411.8 feet	Vertical Change	-56	5 ft	5	SF	\$75	\$375
1439	412.3 to 420.2 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	40	SF	\$120	\$4,740
39996	414.3 to 416.8 feet	Running Slope	6.0-7.0%	5 ft	13	REF		
39997	416.8 to 418.9 feet	Running Slope	5.0-6.0%	5 ft	11	REF		
1440	420.2 to 421.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	5	SF	\$120	\$600
1441	421.2 to 433.7 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	63	SF	\$120	\$7,500
1444	434.6 to 437.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	15	SF	\$120	\$1,740

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908201441	MYER ST	KITES WAY	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
52836	434.8 to 435.8 feet	Vertical Change	-.27	5 ft	5	REF		
57769	435.7 to 459.8 feet	Driveway				REF		
1446	437.5 to 442.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	24	SF	\$40	\$960
1448	442.3 to 444.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	12	SF	\$40	\$480
1450	444.7 to 447.7 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	15	SF	\$40	\$600
1451	447.7 to 452.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	23	SF	\$40	\$900
47467	449.8 to 450.8 feet	Vertical Change	-.41	5 ft	5	REF		
1452	452.2 to 457.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	26	SF	\$40	\$1,020
1453	459.7 to 470.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	55	SF	\$40	\$2,200
51936	469.8 to 470.8 feet	Vertical Change	-.29	5 ft	5	REF		
56949	477.5 to 478.5 feet	Vertical Change	.55	5 ft	5	SF	\$75	\$375
1454	502.4 to 514.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,380
1455	524.6 to 544.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	98	SF	\$120	\$11,700
47220	525.3 to 526.3 feet	Vertical Change	-.42	5 ft	5	REF		
1457	544.1 to 556.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	62	SF	\$120	\$7,440
51526	554.7 to 555.7 feet	Vertical Change	-.3	5 ft	5	REF		
1459	556.5 to 595.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	194	SF	\$120	\$23,280
53843	585.3 to 586.3 feet	Vertical Change	-.25	5 ft	5	REF		
1463	595.3 to 638.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	215	SF	\$120	\$25,800
1467	638.3 to 692.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	273	SF	\$120	\$32,760
51527	645.9 to 646.9 feet	Vertical Change	-.3	5 ft	5	REF		
50619	660.7 to 661.7 feet	Vertical Change	-.31	5 ft	5	REF		
46091	675.6 to 676.6 feet	Vertical Change	-.47	5 ft	5	REF		
50620	691.5 to 692.5 feet	Vertical Change	-.31	5 ft	5	REF		
1472	703.1 to 708.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,180
52837	707.3 to 708.3 feet	Vertical Change	-.27	5 ft	5	REF		
1473	732.7 to 760.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	141	SF	\$120	\$16,860
57770	756.8 to 786.5 feet	Driveway				REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908201441	MYER ST	KITES WAY	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
1475	760.8 to 762.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	10	SF	\$40	\$400
1477	762.8 to 768.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	30	SF	\$40	\$1,200
1478	768.8 to 778.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	50	SF	\$40	\$2,000
1479	778.8 to 784.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	29	SF	\$40	\$1,140
39998	781.7 to 782.8 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
1480	784.5 to 785.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200
1481	786.3 to 787.6 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	7	SF	\$40	\$260
1482	787.6 to 794.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,140
TOTAL COST FOR: S side of MYER ST Starting at: KITES WAY							\$347,040.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908201452	ROBERTSON BLVD	1567 ROBERTSON BLVD	1567 ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57771	0.0 to 28.8 feet	Driveway				REF		
1484	3.8 to 26.3 feet	Cross Slope (Driveway)	13.014	5 ft	113	SF	\$40	\$4,500
50621	28.4 to 29.4 feet	Vertical Change	-.31	5 ft	5	REF		
1488	30.8 to 48.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	86	SF	\$120	\$10,320
1489	48.0 to 58.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,420
TOTAL COST FOR: SE side of ROBERTSON BLVD Starting at: 1567 ROBERTSON BLVD							\$21,240.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908201458	ROBERTSON BLVD	SCHOETTLER TIRE	15TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57772	0.0 to 31.4 feet	Driveway				REF		
1491	1.8 to 8.2 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	38	SF	\$40	\$1,536
1493	8.2 to 23.3 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	91	SF	\$40	\$3,624
39999	22.4 to 24.5 feet	Running Slope	6.0-7.0%	6 ft	13	REF		
1495	27.9 to 41.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	80	SF	\$40	\$3,216
57773	40.4 to 83.6 feet	Driveway				REF		
1497	41.3 to 43.9 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	16	SF	\$40	\$624
1498	48.3 to 79.6 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	188	SF	\$40	\$7,512
52838	57.9 to 58.9 feet	Vertical Change	-27	6 ft	6	REF		
1500	79.6 to 81.2 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	10	SF	\$40	\$384
40000	80.0 to 81.1 feet	Running Slope	8.0-9.0%	6 ft	7	REF		
50622	83.4 to 84.4 feet	Vertical Change	-31	6 ft	6	REF		
1501	85.0 to 98.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	82	SF	\$120	\$9,864
50240	93.8 to 94.8 feet	Vertical Change	-32	6 ft	6	REF		
1502	98.7 to 135.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	223	SF	\$120	\$26,712
47468	103.8 to 104.8 feet	Vertical Change	-41	6 ft	6	REF		
53844	122.5 to 123.5 feet	Vertical Change	-25	6 ft	6	REF		
49914	136.8 to 137.8 feet	Vertical Change	-33	6 ft	6	LF	\$75	\$450
19	136.9 to 137.9 feet	Continuous Width		6 ft	6	SF	\$120	\$720
57774	150.0 to 199.7 feet	Driveway				REF		
1503	153.6 to 154.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	7	SF	\$40	\$288
1504	158.8 to 194.8 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	216	SF	\$40	\$8,640
51528	164.5 to 165.5 feet	Vertical Change	-3	6 ft	6	REF		
40001	192.7 to 195.1 feet	Running Slope	6.0-7.0%	6 ft	14	REF		
1507	198.3 to 212.5 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	85	SF	\$40	\$3,408
42656	207.8 to 208.8 feet	Vertical Change	-67	6 ft	6	REF		
TOTAL COST FOR: SE side of ROBERTSON BLVD Starting at: Schoettler Tire							\$66,978.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority		
SE	1908201503	ROBERTSON BLVD	15TH ST	14TH ST					TBD		
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
48115	1.9 to 2.9 feet	Vertical Change	-.39	6 ft	6	LF	\$75	\$450			
1510	7.8 to 8.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$720			
49593	10.5 to 11.5 feet	Vertical Change	-.34	6 ft	6	LF	\$75	\$450			
49594	25.2 to 26.2 feet	Vertical Change	-.34	6 ft	6	LF	\$75	\$450			
57775	31.0 to 61.7 feet	Driveway				REF					
51529	46.2 to 47.2 feet	Vertical Change	-.3	6 ft	6	REF					
1511	68.3 to 75.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,472			
1512	82.4 to 85.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,016			
49915	95.1 to 96.1 feet	Vertical Change	-.33	6 ft	6	LF	\$75	\$450			
47469	111.2 to 112.2 feet	Vertical Change	-.41	6 ft	6	LF	\$75	\$450			
57776	122.9 to 144.1 feet	Driveway				REF					
48407	146.5 to 147.5 feet	Vertical Change	-.38	6 ft	6	LF	\$75	\$450			
1513	154.6 to 174.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	118	SF	\$120	\$14,112			
57344	164.7 to 165.7 feet	Vertical Change	.99	6 ft	6	REF					
57777	167.1 to 191.7 feet	Driveway				REF					
1516	190.3 to 208.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	110	SF	\$40	\$4,416			
51937	207.3 to 208.3 feet	Vertical Change	-.29	6 ft	6	REF					
50623	247.5 to 248.5 feet	Vertical Change	-.31	6 ft	6	LF	\$75	\$450			
52839	257.5 to 258.5 feet	Vertical Change	-.27	6 ft	6	LF	\$75	\$450			
TOTAL COST FOR: SE							<i>side of</i>	ROBERTSON BLVD	<i>Starting at:</i>	15TH ST	\$30,336.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908201505	ROBERTSON BLVD	14TH ST	13TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
1517	0.0 to 40.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	243	SF	\$120	\$29,160
57778	0.0 to 25.5 feet	Driveway				REF		
52361	29.2 to 30.2 feet	Vertical Change	-.28	6 ft	6	REF		
57779	37.9 to 55.0 feet	Driveway				REF		
47470	90.5 to 91.5 feet	Vertical Change	-.41	6 ft	6	REF		
1518	90.8 to 116.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	153	SF	\$120	\$18,360
1523	118.5 to 189.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	428	SF	\$120	\$51,336
57780	189.2 to 223.0 feet	Driveway				REF		
1528	193.5 to 284.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	544	SF	\$40	\$21,744
53342	213.5 to 214.5 feet	Vertical Change	-.26	6 ft	6	REF		
42271	243.7 to 244.7 feet	Vertical Change	-.71	6 ft	6	REF		
57781	245.3 to 279.2 feet	Driveway				REF		
TOTAL COST FOR: SE side of ROBERTSON BLVD Starting at: 14TH ST							\$120,600.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	1908201509	ROBERTSON BLVD	13TH ST	11TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
51938	0.9 to 1.9 feet	Vertical Change	-29	6 ft	6	LF	\$75	\$450	
40002	1.1 to 5.1 feet	Running Slope	5.0-6.0%	6 ft	24	SF	\$120	\$2,880	
48116	9.0 to 10.0 feet	Vertical Change	-39	6 ft	6	LF	\$75	\$450	
46537	14.8 to 15.8 feet	Vertical Change	-45	6 ft	6	LF	\$75	\$450	
48971	27.1 to 28.1 feet	Vertical Change	-36	6 ft	6	LF	\$75	\$450	
1533	33.2 to 40.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,472	
45463	39.5 to 40.5 feet	Vertical Change	-.5	6 ft	6	REF			
46538	51.6 to 52.6 feet	Vertical Change	-.45	6 ft	6	LF	\$75	\$450	
1534	53.3 to 57.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,880	
50241	56.7 to 57.7 feet	Vertical Change	-.32	6 ft	6	REF			
1536	57.3 to 74.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	103	SF	\$120	\$12,384	
1538	74.5 to 86.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	71	SF	\$120	\$8,496	
53343	80.7 to 81.7 feet	Vertical Change	-.26	6 ft	6	REF			
44395	86.6 to 87.6 feet	Vertical Change	-.55	6 ft	6	SF	\$75	\$450	
1541	90.3 to 116.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	158	SF	\$120	\$19,008	
53845	112.6 to 113.6 feet	Vertical Change	-.25	6 ft	6	REF			
53846	117.9 to 118.9 feet	Vertical Change	-.25	6 ft	6	LF	\$75	\$450	
1544	128.6 to 130.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,152	
51939	128.8 to 129.8 feet	Vertical Change	-.29	6 ft	6	REF			
48408	151.8 to 152.8 feet	Vertical Change	-.38	6 ft	6	LF	\$75	\$450	
46992	163.8 to 164.8 feet	Vertical Change	-.43	6 ft	6	LF	\$75	\$450	
46779	176.0 to 177.0 feet	Vertical Change	-.44	6 ft	6	LF	\$75	\$450	
1545	180.7 to 184.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,024	
45191	188.0 to 189.0 feet	Vertical Change	-.51	6 ft	6	SF	\$75	\$450	
43367	199.9 to 200.9 feet	Vertical Change	-.61	6 ft	6	SF	\$75	\$450	
1546	221.0 to 223.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,016	
42868	227.1 to 228.1 feet	Vertical Change	-.65	6 ft	6	SF	\$75	\$450	
1547	237.7 to 246.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	55	SF	\$120	\$6,552	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908201509	ROBERTSON BLVD	13TH ST	11TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44998	239.0 to 240.0 feet	Vertical Change	-.52	6 ft	6	REF		
44396	251.2 to 252.2 feet	Vertical Change	-.55	6 ft	6	SF	\$75	\$450
1548	275.7 to 285.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	60	SF	\$120	\$7,200
43693	277.5 to 278.5 feet	Vertical Change	-.59	6 ft	6	REF		
44017	287.3 to 288.3 feet	Vertical Change	-.57	6 ft	6	SF	\$75	\$450
48409	295.6 to 296.6 feet	Vertical Change	-.38	6 ft	6	LF	\$75	\$450
45886	307.8 to 308.8 feet	Vertical Change	-.48	6 ft	6	LF	\$75	\$450
57782	317.1 to 335.5 feet	Driveway				REF		
47882	329.8 to 330.8 feet	Vertical Change	-.4	6 ft	6	REF		
47883	351.9 to 352.9 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$450
45678	364.0 to 365.0 feet	Vertical Change	-.49	6 ft	6	LF	\$75	\$450
43216	376.0 to 377.0 feet	Vertical Change	-.62	6 ft	6	SF	\$75	\$450
48972	388.1 to 389.1 feet	Vertical Change	-.36	6 ft	6	LF	\$75	\$450
50242	444.9 to 445.9 feet	Vertical Change	-.32	6 ft	6	LF	\$75	\$450
49266	463.0 to 464.0 feet	Vertical Change	-.35	6 ft	6	LF	\$75	\$450
48683	502.0 to 503.0 feet	Vertical Change	-.37	6 ft	6	LF	\$75	\$450
47221	606.2 to 607.2 feet	Vertical Change	-.42	6 ft	6	LF	\$75	\$450
1549	612.5 to 613.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$864
46993	618.2 to 619.2 feet	Vertical Change	-.43	6 ft	6	LF	\$75	\$450
46780	629.8 to 630.8 feet	Vertical Change	-.44	6 ft	6	LF	\$75	\$450

TOTAL COST FOR:	SE	<i>side of</i>	ROBERTSON BLVD	<i>Starting at:</i>	13TH ST	\$84,078.00
------------------------	-----------	----------------	-----------------------	---------------------	----------------	--------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	1908201513	ROBERTSON BLVD	11TH ST	10TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
1550	0.0 to 76.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	456	SF	\$120	\$54,720	
41888	1.4 to 2.4 feet	Vertical Change	-.8	6 ft	6	REF			
57783	83.3 to 100.8 feet	Driveway				REF			
53344	94.0 to 95.0 feet	Vertical Change	-.26	6 ft	6	REF			
1555	104.5 to 158.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	325	SF	\$120	\$38,952	
1556	174.3 to 229.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	329	SF	\$120	\$39,528	
1559	232.7 to 285.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	317	SF	\$120	\$38,088	
52840	245.0 to 246.0 feet	Vertical Change	-.27	6 ft	6	REF			
47222	287.8 to 288.8 feet	Vertical Change	-.42	6 ft	6	LF	\$75	\$450	
TOTAL COST FOR: SE							<i>side of ROBERTSON BLVD Starting at: 11TH ST</i>	\$171,738.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority	
SE	1908201516	ROBERTSON BLVD	10TH ST	9TH ST				TBD	
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
1560	0.0 to 23.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	142	SF	\$120	\$17,064	
52841	4.7 to 5.7 feet	Vertical Change	-27	6 ft	6	REF			
49916	53.1 to 54.1 feet	Vertical Change	-33	6 ft	6	LF	\$75	\$450	
1563	80.7 to 88.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,472	
1564	144.3 to 170.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	160	SF	\$120	\$19,152	
57784	174.1 to 187.3 feet	Driveway				REF			
1566	177.9 to 185.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	43	SF	\$40	\$1,728	
1567	187.8 to 198.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	64	SF	\$120	\$7,632	
51940	197.2 to 198.2 feet	Vertical Change	-29	6 ft	6	REF			
1568	228.8 to 235.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	41	SF	\$120	\$4,968	
57785	229.8 to 242.7 feet	Driveway				REF			
1569	249.0 to 251.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,512	
1570	283.8 to 287.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,952	
TOTAL COST FOR: SE							side of ROBERTSON BLVD	Starting at: 10TH ST	\$60,930.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority			
SE	1908201519	ROBERTSON BLVD	9TH ST	8TH ST				TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
1571	0.0 to 26.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	156	SF	\$120	\$18,720			
51941	16.8 to 17.8 feet	Vertical Change	-29	6 ft	6	REF					
47471	31.7 to 32.7 feet	Vertical Change	-41	6 ft	6	LF	\$75	\$450			
44999	46.5 to 47.5 feet	Vertical Change	-52	6 ft	6	SF	\$75	\$450			
1576	51.1 to 55.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,952			
42539	61.2 to 62.2 feet	Vertical Change	-68	6 ft	6	SF	\$75	\$450			
1577	76.6 to 95.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	113	SF	\$120	\$13,608			
57786	77.3 to 100.9 feet	Driveway				REF					
45887	79.0 to 80.0 feet	Vertical Change	-48	6 ft	6	REF					
1579	147.3 to 158.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	67	SF	\$120	\$7,992			
57787	168.3 to 187.3 feet	Driveway				REF					
1580	172.7 to 177.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	31	SF	\$40	\$1,248			
1581	248.5 to 255.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,824			
TOTAL COST FOR: SE							<i>side of</i>	ROBERTSON BLVD	<i>Starting at:</i>	9TH ST	\$50,694.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority		
SE	1908201521	ROBERTSON BLVD	8TH ST	7TH ST					TBD		
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
45000	3.8 to 4.8 feet	Vertical Change	-.52	6 ft	6	SF	\$75	\$450			
1582	5.5 to 7.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,080			
43847	13.8 to 14.8 feet	Vertical Change	-.58	6 ft	6	SF	\$75	\$450			
46994	23.8 to 24.8 feet	Vertical Change	-.43	6 ft	6	LF	\$75	\$450			
44616	33.8 to 34.8 feet	Vertical Change	-.54	6 ft	6	SF	\$75	\$450			
1583	39.1 to 42.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,304			
1584	44.4 to 134.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	540	SF	\$120	\$64,800			
49917	46.0 to 47.0 feet	Vertical Change	-.33	6 ft	6	REF					
46314	54.7 to 55.7 feet	Vertical Change	-.46	6 ft	6	REF					
51942	108.6 to 109.6 feet	Vertical Change	-.29	6 ft	6	REF					
51943	111.7 to 112.7 feet	Vertical Change	-.29	6 ft	6	REF					
57788	137.2 to 180.5 feet	Driveway				REF					
1592	171.3 to 193.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	135	SF	\$40	\$5,400			
53345	183.6 to 184.6 feet	Vertical Change	-.26	6 ft	6	REF					
50624	249.5 to 250.5 feet	Vertical Change	-.31	6 ft	6	LF	\$75	\$450			
TOTAL COST FOR: SE							<i>side of</i>	ROBERTSON BLVD	<i>Starting at:</i>	8TH ST	\$75,834.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	1908201524	ROBERTSON BLVD	7TH ST	6TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
1593	1.8 to 86.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	506	SF	\$120	\$60,768	
52842	19.2 to 20.2 feet	Vertical Change	-.27	6 ft	6	REF			
48117	52.3 to 53.3 feet	Vertical Change	-.39	6 ft	6	REF			
1600	91.4 to 92.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$1,008	
53847	94.3 to 95.3 feet	Vertical Change	-.25	6 ft	6	LF	\$75	\$450	
1601	124.0 to 126.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,728	
52843	124.5 to 128.5 feet	Vertical Change	-.27	6 ft	24	REF			
1602	130.3 to 132.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,440	
1603	142.8 to 150.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,616	
55973	145.4 to 146.4 feet	Vertical Change	.37	6 ft	6	REF			
1604	155.9 to 158.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,872	
44617	174.8 to 175.8 feet	Vertical Change	-.54	6 ft	6	SF	\$75	\$450	
52844	174.8 to 176.2 feet	Vertical Change	-.27	6 ft	8	LF	\$75	\$630	
1605	197.2 to 201.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168	
1606	243.5 to 267.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	143	SF	\$120	\$17,136	
50625	251.4 to 252.4 feet	Vertical Change	-.31	6 ft	6	REF			
53348	267.7 to 268.7 feet	Vertical Change	-.26	6 ft	6	LF	\$75	\$450	
1609	272.4 to 279.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,752	
53349	278.8 to 279.8 feet	Vertical Change	-.26	6 ft	6	REF			
48410	286.9 to 287.9 feet	Vertical Change	-.38	6 ft	6	LF	\$75	\$450	
TOTAL COST FOR: SE side of ROBERTSON BLVD Starting at: 7TH ST								\$99,918.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908201526	ROBERTSON BLVD	6TH ST	5TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
1612	0.0 to 14.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	89	SF	\$120	\$10,728
51530	10.0 to 11.0 feet	Vertical Change	-.3	6 ft	6	REF		
50626	18.9 to 22.9 feet	Vertical Change	-.31	6 ft	24	LF	\$75	\$1,800
1616	21.1 to 44.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	139	SF	\$120	\$16,704
49918	27.8 to 28.8 feet	Vertical Change	-.33	6 ft	6	REF		
1621	44.3 to 57.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	81	SF	\$120	\$9,720
1624	57.8 to 60.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,016
1625	75.6 to 157.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	492	SF	\$120	\$59,040
1633	157.6 to 199.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	250	SF	\$120	\$29,952
1636	199.2 to 246.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	281	SF	\$120	\$33,768
1642	249.8 to 289.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	236	SF	\$120	\$28,368
51531	263.5 to 264.5 feet	Vertical Change	-.3	6 ft	6	REF		
48684	284.1 to 285.1 feet	Vertical Change	-.37	6 ft	6	REF		
TOTAL COST FOR: SE side of ROBERTSON BLVD Starting at: 6TH ST							\$192,096.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1908201530	ROBERTSON BLVD	5TH ST	4TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
1649	0.0 to 8.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	53	SF	\$120	\$6,336	
57789	0.0 to 24.8 feet	Driveway				REF			
1650	8.8 to 19.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	63	SF	\$40	\$2,520	
51944	9.5 to 10.5 feet	Vertical Change	-.29	6 ft	6	REF			
1651	29.2 to 37.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	49	SF	\$120	\$5,832	
1654	38.1 to 40.2 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	13	SF	\$120	\$1,512	
1655	40.2 to 43.5 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	20	SF	\$120	\$2,376	
1656	43.5 to 46.5 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	18	SF	\$120	\$2,160	
1658	46.5 to 51.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	29	SF	\$120	\$3,456	
1660	51.3 to 57.5 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	37	SF	\$120	\$4,464	
57790	51.7 to 89.5 feet	Driveway				REF			
56950	57.4 to 58.4 feet	Vertical Change	.55	6 ft	6	REF			
1662	57.5 to 59.5 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	12	SF	\$40	\$480	
1663	59.5 to 71.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	73	SF	\$40	\$2,928	
1664	93.3 to 98.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,816	
1665	104.7 to 109.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168	
1666	118.6 to 123.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,600	
1667	145.3 to 147.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,296	
1668	175.8 to 183.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	49	SF	\$120	\$5,832	
1669	188.0 to 202.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	86	SF	\$120	\$10,296	
57791	206.9 to 227.8 feet	Driveway				REF			
1672	211.4 to 214.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	16	SF	\$40	\$648	
1673	219.1 to 226.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	45	SF	\$40	\$1,800	
54140	236.6 to 237.6 feet	Vertical Change	.26	6 ft	6	LF	\$75	\$450	
1674	244.1 to 284.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	242	SF	\$120	\$29,016	
41829	271.8 to 272.8 feet	Vertical Change	-.82	6 ft	6	REF			
51532	279.4 to 280.4 feet	Vertical Change	-.3	6 ft	6	REF			
1676	289.1 to 292.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,088	

TOTAL COST FOR: SE side of ROBERTSON BLVD Starting at: 5TH ST \$94,074.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908201534	ROBERTSON BLVD	4TH ST	3RD ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
1677	3.8 to 16.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	99	SF	\$120	\$11,904
1680	18.3 to 25.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	55	SF	\$120	\$6,624
1682	25.2 to 28.6 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	27	SF	\$120	\$3,264
1684	28.6 to 40.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	93	SF	\$120	\$11,136
57792	31.3 to 73.5 feet	Driveway				REF		
1686	40.2 to 50.8 feet	Cross Slope (Driveway)	4.0-5.0%	8 ft	85	SF	\$40	\$3,392
1690	50.8 to 67.4 feet	Cross Slope (Driveway)	2.0-3.0%	8 ft	133	SF	\$40	\$5,312
1694	67.4 to 72.7 feet	Cross Slope (Driveway)	4.0-5.0%	8 ft	42	SF	\$40	\$1,696
1696	72.7 to 101.8 feet	Cross Slope (Driveway)	2.0-3.0%	8 ft	233	SF	\$40	\$9,312
1703	106.3 to 110.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	33	SF	\$120	\$3,936
53351	115.7 to 116.7 feet	Vertical Change	-.26	8 ft	8	LF	\$75	\$600
1704	129.1 to 166.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	298	SF	\$120	\$35,712
1707	169.5 to 172.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	22	SF	\$120	\$2,592
53848	173.1 to 179.3 feet	Vertical Change	-.25	8 ft	50	LF	\$75	\$3,720
1708	175.8 to 186.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	83	SF	\$120	\$9,984
1709	191.5 to 215.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	190	SF	\$120	\$22,752
1714	218.9 to 292.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	587	SF	\$120	\$70,464
47884	274.8 to 275.8 feet	Vertical Change	-.4	8 ft	8	REF		
TOTAL COST FOR: SE side of ROBERTSON BLVD Starting at: 4TH ST							\$202,400.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908201536	ROBERTSON BLVD	3RD ST	2ND ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
1719	0.0 to 1.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	12	SF	\$120	\$1,440
1720	10.4 to 13.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	24	SF	\$120	\$2,880
57793	21.6 to 53.4 feet	Driveway				REF		
46781	37.2 to 38.2 feet	Vertical Change	-.44	8 ft	8	REF		
1721	47.4 to 50.7 feet	Cross Slope (Driveway)	2.0-3.0%	8 ft	26	SF	\$40	\$1,056
1723	50.7 to 56.9 feet	Cross Slope (Driveway)	4.0-5.0%	8 ft	50	SF	\$40	\$1,984
49920	53.3 to 54.3 feet	Vertical Change	-.33	8 ft	8	REF		
1725	56.9 to 58.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	16	SF	\$120	\$1,920
57794	104.6 to 139.5 feet	Driveway				REF		
1726	114.4 to 127.4 feet	Cross Slope (Driveway)	2.0-3.0%	8 ft	104	SF	\$40	\$4,160
56636	134.8 to 135.8 feet	Vertical Change	.47	8 ft	8	REF		
1727	138.0 to 139.8 feet	Cross Slope (Driveway)	2.0-3.0%	8 ft	14	SF	\$40	\$576
1728	163.2 to 197.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	272	SF	\$120	\$32,640
46995	205.8 to 209.8 feet	Vertical Change	-.43	8 ft	32	LF	\$75	\$2,400
1731	209.3 to 215.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	48	SF	\$120	\$5,760
1732	226.8 to 233.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	54	SF	\$120	\$6,528
53849	228.5 to 229.5 feet	Vertical Change	-.25	8 ft	8	REF		
1735	237.6 to 244.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	58	SF	\$120	\$6,912
1736	249.3 to 264.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	119	SF	\$120	\$14,304
1737	266.9 to 279.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	98	SF	\$120	\$11,808

TOTAL COST FOR:	SE	<i>side of</i>	ROBERTSON BLVD	<i>Starting at:</i>	3RD ST	\$94,368.00
------------------------	-----------	----------------	-----------------------	---------------------	---------------	--------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority		
SE	1908201541	ROBERTSON BLVD	2ND ST	1ST ST					TBD		
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
1739	0.0 to 6.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	54	SF	\$120	\$6,528			
1740	34.4 to 53.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	155	SF	\$120	\$18,624			
1742	110.1 to 162.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	421	SF	\$120	\$50,496			
1747	162.7 to 173.8 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	89	SF	\$120	\$10,656			
1749	173.8 to 224.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	408	SF	\$120	\$48,960			
57795	219.9 to 266.7 feet	Driveway				REF					
1755	224.8 to 265.7 feet	Cross Slope (Driveway)	4.0-5.0%	8 ft	327	SF	\$40	\$13,088			
50627	225.1 to 227.6 feet	Vertical Change	-.31	8 ft	20	REF					
40003	262.4 to 264.1 feet	Running Slope	5.0-6.0%	8 ft	14	REF					
1759	265.7 to 268.5 feet	Cross Slope (Driveway)	2.0-3.0%	8 ft	22	SF	\$40	\$896			
1760	274.3 to 285.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	88	SF	\$120	\$10,560			
TOTAL COST FOR: SE							<i>side of</i>	ROBERTSON BLVD	<i>Starting at:</i>	2ND ST	\$159,808.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
SE	1908201546	ROBERTSON BLVD	1ST ST	FRONT ST				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
1761	0.0 to 23.7 feet	Cross Slope (PAR)	3.0-4.0%	8 ft	190	SF	\$120	\$22,752
53353	1.0 to 2.0 feet	Vertical Change	-.26	8 ft	8	REF		
57796	10.8 to 45.8 feet	Driveway				REF		
1765	23.7 to 33.4 feet	Cross Slope (Driveway)	5.0-6.0%	8 ft	78	SF	\$40	\$3,104
1768	33.4 to 35.7 feet	Cross Slope (Driveway)	3.0-4.0%	8 ft	18	SF	\$40	\$736
1769	35.7 to 50.1 feet	Cross Slope (Driveway)	2.0-3.0%	8 ft	115	SF	\$40	\$4,608
1773	50.1 to 76.5 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	211	SF	\$120	\$25,344
1777	76.5 to 89.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	101	SF	\$120	\$12,096
1779	89.1 to 105.5 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	131	SF	\$120	\$15,744
57226	99.2 to 100.2 feet	Vertical Change	.7	8 ft	8	REF		
1783	105.5 to 139.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	270	SF	\$120	\$32,448
48685	145.1 to 146.1 feet	Vertical Change	-.37	8 ft	8	LF	\$75	\$600
1788	146.8 to 244.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	784	SF	\$120	\$94,080
50244	170.8 to 171.8 feet	Vertical Change	-.32	8 ft	8	REF		
55984	238.4 to 239.4 feet	Vertical Change	.39	8 ft	8	REF		
57797	249.7 to 273.6 feet	Driveway				REF		
43848	255.7 to 256.7 feet	Vertical Change	-.58	8 ft	8	REF		
48411	260.4 to 262.7 feet	Vertical Change	-.38	8 ft	18	REF		
56939	271.8 to 272.8 feet	Vertical Change	.54	8 ft	8	REF		
1802	272.0 to 277.4 feet	Cross Slope (Driveway)	2.0-3.0%	8 ft	43	SF	\$40	\$1,728

TOTAL COST FOR:	SE	<i>side of</i>	ROBERTSON BLVD	<i>Starting at:</i>	1ST ST			\$213,240.00
------------------------	-----------	----------------	-----------------------	---------------------	---------------	--	--	---------------------

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1908201551	FRONT ST	SIDEWALK BEGINS	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
1803	0.0 to 38.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	171	SF	\$120	\$20,574
50246	19.8 to 20.8 feet	Vertical Change	-.32	5 ft	5	REF		
51533	29.6 to 30.6 feet	Vertical Change	-.3	5 ft	5	REF		
1809	38.1 to 41.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,998
TOTAL COST FOR: NE side of FRONT ST Starting at: SIDEWALK BEGINS							\$22,572.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1908201600	FRONT ST	ROBERTSON BLVD	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
1810	8.3 to 127.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	597	SF	\$120	\$71,700
50628	9.5 to 10.5 feet	Vertical Change	-.31	5 ft	5	REF		
57798	24.3 to 115.9 feet	Driveway				REF		
41476	73.2 to 74.2 feet	Vertical Change	-1.12	5 ft	5	REF		
48973	106.0 to 107.0 feet	Vertical Change	-.36	5 ft	5	REF		
57799	128.7 to 143.0 feet	Driveway				REF		
1824	131.3 to 151.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	101	SF	\$40	\$4,060
57800	147.5 to 200.5 feet	Driveway				REF		
1826	154.6 to 191.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	182	SF	\$40	\$7,280
50247	170.4 to 171.4 feet	Vertical Change	-.32	5 ft	5	REF		
1830	191.0 to 196.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	25	SF	\$40	\$1,000
1832	196.0 to 198.4 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	12	SF	\$40	\$480
1833	201.2 to 232.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	156	SF	\$120	\$18,660
53354	203.6 to 207.0 feet	Vertical Change	-.26	5 ft	17	REF		
53355	225.8 to 231.8 feet	Vertical Change	-.26	5 ft	30	REF		
50629	235.0 to 236.0 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375
50248	238.9 to 239.9 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375
1834	240.9 to 306.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	329	SF	\$120	\$39,480
51534	244.1 to 259.9 feet	Vertical Change	-.3	5 ft	79	REF		
53356	264.0 to 265.0 feet	Vertical Change	-.26	5 ft	5	REF		
49921	274.4 to 277.3 feet	Vertical Change	-.33	5 ft	15	REF		
50630	281.2 to 282.2 feet	Vertical Change	-.31	5 ft	5	REF		
50249	285.5 to 286.5 feet	Vertical Change	-.32	5 ft	5	REF		
49596	292.0 to 302.7 feet	Vertical Change	-.34	5 ft	54	REF		
TOTAL COST FOR: SW side of FRONT ST Starting at: ROBERTSON BLVD							\$143,410.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908201602	TRINITY AVE	FRONT ST	1ST ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
53357	5.5 to 8.8 feet	Vertical Change	-.26	4 ft	13	REF			
1839	5.5 to 29.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	95	SF	\$120	\$11,424	
50631	12.7 to 16.1 feet	Vertical Change	-.31	4 ft	14	REF			
51536	20.1 to 21.1 feet	Vertical Change	-.3	4 ft	4	REF			
53358	25.6 to 26.6 feet	Vertical Change	-.26	4 ft	4	REF			
57801	25.6 to 62.0 feet	Driveway				REF			
49268	30.0 to 31.0 feet	Vertical Change	-.35	4 ft	4	REF			
1840	33.6 to 58.4 feet	Cross Slope (Driveway)	9.0-10.0%	4 ft	99	SF	\$40	\$3,968	
49269	45.6 to 46.6 feet	Vertical Change	-.35	4 ft	4	REF			
40004	57.0 to 59.3 feet	Running Slope	5.0-6.0%	4 ft	9	REF			
1844	61.7 to 63.1 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	6	SF	\$40	\$224	
1845	63.1 to 87.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	97	SF	\$120	\$11,664	
51537	65.4 to 66.4 feet	Vertical Change	-.3	4 ft	4	REF			
52365	80.4 to 83.9 feet	Vertical Change	-.28	4 ft	14	REF			
50633	87.8 to 96.3 feet	Vertical Change	-.31	4 ft	34	LF	\$75	\$2,550	
1849	99.8 to 101.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	7	SF	\$120	\$864	
49598	100.1 to 111.3 feet	Vertical Change	-.34	4 ft	45	REF			
57802	110.7 to 135.5 feet	Driveway				REF			
1850	111.8 to 113.7 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	8	SF	\$40	\$304	
1851	117.3 to 131.9 feet	Cross Slope (Driveway)	9.0-10.0%	4 ft	58	SF	\$40	\$2,336	
1853	135.2 to 137.3 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	8	SF	\$40	\$336	
50252	139.5 to 140.5 feet	Vertical Change	-.32	4 ft	4	LF	\$75	\$300	
51947	144.6 to 148.1 feet	Vertical Change	-.29	4 ft	14	LF	\$75	\$1,050	
1854	146.6 to 180.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	136	SF	\$120	\$16,272	
52366	152.1 to 153.1 feet	Vertical Change	-.28	4 ft	4	REF			
51948	157.1 to 175.7 feet	Vertical Change	-.29	4 ft	74	REF			
53852	182.2 to 193.2 feet	Vertical Change	-.25	4 ft	44	LF	\$75	\$3,300	
1855	184.5 to 193.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	38	SF	\$120	\$4,512	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1908201602	TRINITY AVE	FRONT ST	1ST ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
1856	197.0 to 218.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	87	SF	\$120	\$10,464
50256	199.9 to 215.8 feet	Vertical Change	-.32	4 ft	64	REF		
57803	224.2 to 258.7 feet	Driveway				REF		
1859	224.3 to 228.9 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	18	SF	\$40	\$736
52852	227.3 to 228.3 feet	Vertical Change	-.27	4 ft	4	REF		
1860	231.7 to 255.7 feet	Cross Slope (Driveway)	7.0-8.0%	4 ft	96	SF	\$40	\$3,840
40005	254.4 to 256.3 feet	Running Slope	6.0-7.0%	4 ft	8	REF		
1865	259.1 to 286.6 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	110	SF	\$40	\$4,400
52370	261.2 to 262.2 feet	Vertical Change	-.28	4 ft	4	REF		
51950	266.4 to 267.4 feet	Vertical Change	-.29	4 ft	4	REF		
48686	271.4 to 282.2 feet	Vertical Change	-.37	4 ft	43	REF		
48119	286.2 to 287.2 feet	Vertical Change	-.39	4 ft	4	REF		
TOTAL COST FOR: NW side of TRINITY AVE Starting at: FRONT ST							\$78,544.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908210828	AVE 26	FREEWAY ENTRANCE	CARLYLE WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
1868	0.0 to 35.7 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	250	SF	\$120	\$29,988
48688	5.9 to 9.2 feet	Vertical Change	-.37	7 ft	23	REF		
44397	14.6 to 15.6 feet	Vertical Change	-.55	7 ft	7	REF		
42751	34.3 to 35.3 feet	Vertical Change	-.66	7 ft	7	REF		
1870	35.7 to 56.0 feet	Cross Slope (PAR)	4.0-5.0%	7 ft	142	SF	\$120	\$17,052
47223	44.2 to 45.2 feet	Vertical Change	-.42	7 ft	7	REF		
48120	55.1 to 56.1 feet	Vertical Change	-.39	7 ft	7	REF		
1872	56.0 to 120.9 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	454	SF	\$120	\$54,516
41477	67.7 to 68.7 feet	Vertical Change	-1.12	7 ft	7	REF		
41658	80.4 to 81.4 feet	Vertical Change	-.92	7 ft	7	REF		
57292	80.5 to 81.5 feet	Vertical Change	.84	7 ft	7	REF		
48689	84.8 to 85.8 feet	Vertical Change	-.37	7 ft	7	REF		
41716	103.0 to 104.0 feet	Vertical Change	-.88	7 ft	7	REF		
41556	117.8 to 118.8 feet	Vertical Change	-1.01	7 ft	7	REF		
1879	130.3 to 135.8 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	39	SF	\$120	\$4,620
41495	132.2 to 133.2 feet	Vertical Change	-1.1	7 ft	7	REF		
TOTAL COST FOR: S							<i>side of AVE 26 Starting at: FREEWAY ENTRANCE</i>	\$106,176.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
W	1908210831	CARLYLE WAY	AVE 26	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
1880	3.9 to 14.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,480	
57804	9.6 to 51.6 feet	Driveway				REF			
46539	13.4 to 15.4 feet	Vertical Change	-45	5 ft	10	REF			
1883	19.1 to 25.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	30	SF	\$40	\$1,200	
1885	25.1 to 49.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	121	SF	\$40	\$4,840	
43849	52.1 to 53.1 feet	Vertical Change	-58	5 ft	5	REF			
1886	52.2 to 64.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	63	SF	\$40	\$2,500	
48977	61.2 to 62.2 feet	Vertical Change	-36	5 ft	5	REF			
1887	69.8 to 133.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	320	SF	\$120	\$38,400	
49271	72.5 to 73.5 feet	Vertical Change	-35	5 ft	5	REF			
41389	89.6 to 90.6 feet	Vertical Change	-1.29	5 ft	5	REF			
50638	108.1 to 109.1 feet	Vertical Change	-31	5 ft	5	REF			
51951	123.3 to 124.3 feet	Vertical Change	-29	5 ft	5	REF			
1889	137.8 to 175.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	186	SF	\$120	\$22,320	
46540	138.3 to 139.3 feet	Vertical Change	-45	5 ft	5	REF			
45679	153.4 to 154.4 feet	Vertical Change	-49	5 ft	5	REF			
48412	166.5 to 167.5 feet	Vertical Change	-38	5 ft	5	REF			
57805	170.4 to 211.8 feet	Driveway				REF			
49600	174.0 to 175.0 feet	Vertical Change	-34	5 ft	5	REF			
1891	178.0 to 205.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	139	SF	\$40	\$5,540	
48413	182.1 to 183.1 feet	Vertical Change	-38	5 ft	5	REF			
1893	205.7 to 211.8 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	31	SF	\$40	\$1,220	
TOTAL COST FOR: W							side of CARLYLE WAY Starting at: AVE 26	\$82,500.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1908210838	CARLYLE WAY	SIDEWALK BEGINS	AVE 26	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
1894	2.1 to 50.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	240	SF	\$120	\$28,800	
48414	3.6 to 4.6 feet	Vertical Change	-.38	5 ft	5	REF			
50639	11.0 to 12.0 feet	Vertical Change	-.31	5 ft	5	REF			
41717	31.3 to 32.3 feet	Vertical Change	-.88	5 ft	5	REF			
52371	36.5 to 37.5 feet	Vertical Change	-.28	5 ft	5	REF			
20	52.9 to 53.9 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
1900	66.4 to 70.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400	
1901	103.5 to 110.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,140	
48690	120.5 to 121.5 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375	
1902	126.2 to 131.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,420	
49272	144.4 to 145.4 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$375	
1903	153.1 to 162.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,700	
53359	156.5 to 157.5 feet	Vertical Change	-.26	5 ft	5	REF			
1905	183.6 to 197.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,100	
52853	189.9 to 190.9 feet	Vertical Change	-.27	5 ft	5	REF			
57806	193.8 to 231.7 feet	Driveway				REF			
50259	194.3 to 195.3 feet	Vertical Change	-.32	5 ft	5	REF			
1906	201.7 to 228.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	132	SF	\$40	\$5,280	
40006	226.7 to 229.6 feet	Running Slope	5.0-6.0%	5 ft	15	REF			
51542	231.2 to 232.2 feet	Vertical Change	-.3	5 ft	5	REF			
1911	231.8 to 244.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	65	SF	\$40	\$2,600	
1913	244.8 to 254.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,820	
1914	270.5 to 274.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220	
46782	276.0 to 277.0 feet	Vertical Change	-.44	5 ft	5	LF	\$75	\$375	
57297	278.8 to 279.8 feet	Vertical Change	.88	5 ft	5	SF	\$75	\$375	
57807	290.5 to 328.4 feet	Driveway				REF			
1915	295.0 to 297.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	12	SF	\$40	\$460	
1917	299.5 to 303.9 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	22	SF	\$40	\$880	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908210838	CARLYLE WAY	SIDEWALK BEGINS	AVE 26	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
45464	302.4 to 303.4 feet	Vertical Change	-.5	5 ft	5	REF		
1919	303.9 to 323.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	100	SF	\$40	\$3,980
47224	311.7 to 312.7 feet	Vertical Change	-.42	5 ft	5	REF		
46541	320.3 to 321.3 feet	Vertical Change	-.45	5 ft	5	REF		
1921	323.8 to 325.0 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	6	SF	\$40	\$240
1922	328.0 to 329.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240
21	328.8 to 329.8 feet	Continuous Width		5 ft	5	SF	\$120	\$600
47472	332.6 to 333.6 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375
1923	334.8 to 344.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,820
50260	343.5 to 344.5 feet	Vertical Change	-.32	5 ft	5	REF		
44821	353.5 to 354.5 feet	Vertical Change	-.53	5 ft	5	SF	\$75	\$375
41854	354.9 to 355.9 feet	Vertical Change	-.81	5 ft	5	REF		
1926	355.6 to 357.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140
57808	369.2 to 414.5 feet	Driveway				REF		
1927	373.8 to 374.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$220
1928	378.8 to 411.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	161	SF	\$40	\$6,440
55980	419.7 to 420.7 feet	Vertical Change	.38	5 ft	5	LF	\$75	\$375
41195	421.4 to 422.4 feet	Vertical Change	-2.48	5 ft	5	SF	\$75	\$375
49273	434.1 to 435.1 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$375
47225	462.0 to 463.0 feet	Vertical Change	-.42	5 ft	5	REF		
1935	462.8 to 478.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	77	SF	\$120	\$9,180
50261	474.3 to 475.3 feet	Vertical Change	-.32	5 ft	5	REF		
1936	482.0 to 493.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,780
1938	493.3 to 497.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	19	SF	\$120	\$2,280
1940	497.1 to 504.1 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	35	SF	\$120	\$4,200
1942	507.1 to 508.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
TOTAL COST FOR: E side of CARLYLE WAY Starting at: SIDEWALK BEGINS							\$115,755.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908210840	AVE 26	CARLYLE WAY	S MONTGOMERY LAKE WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
1943	19.2 to 44.3 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	176	SF	\$120	\$21,084
41855	25.4 to 26.4 feet	Vertical Change	-.81	7 ft	7	REF		
48691	40.6 to 41.6 feet	Vertical Change	-.37	7 ft	7	REF		
1944	51.4 to 103.8 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	367	SF	\$120	\$44,016
46542	55.6 to 56.6 feet	Vertical Change	-.45	7 ft	7	REF		
42370	70.9 to 71.9 feet	Vertical Change	-.7	7 ft	7	REF		
50262	101.0 to 102.0 feet	Vertical Change	-.32	7 ft	7	REF		
1948	112.5 to 131.2 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	131	SF	\$120	\$15,708
42371	116.3 to 117.3 feet	Vertical Change	-.7	7 ft	7	REF		
52854	131.3 to 132.3 feet	Vertical Change	-.27	7 ft	7	LF	\$75	\$525
1949	136.0 to 146.4 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	73	SF	\$120	\$8,736
1950	152.6 to 163.1 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	74	SF	\$120	\$8,820
1952	167.6 to 171.3 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	26	SF	\$120	\$3,108
1953	187.0 to 198.8 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	83	SF	\$120	\$9,912
TOTAL COST FOR: S							side of AVE 26 Starting at: CARLYLE WAY	\$111,909.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908210843	S MONTGOMERY LAKE	AVE 26	AUTO PARK PLACE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
1954	10.6 to 20.3 feet	Cross Slope (PAR)	2.0-3.0%	9 ft	87	SF	\$120	\$10,476
1955	23.6 to 103.4 feet	Cross Slope (PAR)	2.0-3.0%	9 ft	718	SF	\$120	\$86,184
49601	87.1 to 88.1 feet	Vertical Change	-34	9 ft	9	REF		
57809	100.4 to 138.0 feet	Driveway				REF		
1965	107.5 to 108.5 feet	Cross Slope (Driveway)	10.0-11.0%	9 ft	9	SF	\$40	\$360
1966	110.3 to 130.9 feet	Cross Slope (Driveway)	7.0-8.0%	9 ft	185	SF	\$40	\$7,416
51952	115.9 to 116.9 feet	Vertical Change	-29	9 ft	9	REF		
1970	130.9 to 133.9 feet	Cross Slope (Driveway)	9.0-10.0%	9 ft	27	SF	\$40	\$1,080
52855	131.7 to 132.7 feet	Vertical Change	-27	9 ft	9	REF		
1972	137.8 to 207.2 feet	Cross Slope (Driveway)	2.0-3.0%	9 ft	625	SF	\$40	\$24,984
53360	176.7 to 177.7 feet	Vertical Change	-26	9 ft	9	REF		
57810	201.8 to 229.9 feet	Driveway				REF		
50263	206.3 to 207.3 feet	Vertical Change	-32	9 ft	9	REF		
1981	207.2 to 208.2 feet	Cross Slope (Driveway)	4.0-5.0%	9 ft	9	SF	\$40	\$360
1982	208.9 to 227.2 feet	Cross Slope (Driveway)	6.0-7.0%	9 ft	165	SF	\$40	\$6,588
1989	229.5 to 232.8 feet	Cross Slope (Driveway)	2.0-3.0%	9 ft	30	SF	\$40	\$1,188
1990	235.7 to 325.4 feet	Cross Slope (PAR)	2.0-3.0%	9 ft	807	SF	\$120	\$96,876
1997	327.8 to 367.9 feet	Cross Slope (PAR)	2.0-3.0%	9 ft	361	SF	\$120	\$43,308
1998	379.8 to 380.9 feet	Cross Slope (PAR)	2.0-3.0%	9 ft	10	SF	\$120	\$1,188
1999	385.5 to 463.9 feet	Cross Slope (PAR)	2.0-3.0%	9 ft	706	SF	\$120	\$84,672
57811	457.0 to 482.3 feet	Driveway				REF		
2001	463.9 to 466.2 feet	Cross Slope (Driveway)	4.0-5.0%	9 ft	21	SF	\$40	\$828
2003	466.2 to 482.3 feet	Cross Slope (Driveway)	6.0-7.0%	9 ft	145	SF	\$40	\$5,796
53854	473.4 to 474.4 feet	Vertical Change	-25	9 ft	9	REF		
40008	483.7 to 485.4 feet	Running Slope	7.0-8.0%	9 ft	15	SF	\$120	\$1,836
2006	483.8 to 489.4 feet	Cross Slope (PAR)	3.0-4.0%	9 ft	50	SF	\$120	\$6,048
57697	486.7 to 487.7 feet	Vertical Change	5.73	9 ft	9	REF		
2008	489.4 to 586.9 feet	Cross Slope (PAR)	2.0-3.0%	9 ft	878	SF	\$120	\$105,300

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908210843	S MONTGOMERY LAKE	AVE 26	AUTO PARK PLACE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
49602	523.1 to 524.1 feet	Vertical Change	-.34	9 ft	9	REF		
2015	590.3 to 616.6 feet	Cross Slope (PAR)	2.0-3.0%	9 ft	237	SF	\$120	\$28,404
53855	618.3 to 619.3 feet	Vertical Change	-.25	9 ft	9	LF	\$75	\$675
2016	621.9 to 661.8 feet	Cross Slope (PAR)	2.0-3.0%	9 ft	359	SF	\$120	\$43,092
53856	643.8 to 644.8 feet	Vertical Change	-.25	9 ft	9	REF		
2017	664.9 to 671.2 feet	Cross Slope (PAR)	2.0-3.0%	9 ft	57	SF	\$120	\$6,804
TOTAL COST FOR: W side of S MONTGOMERY LAKE Starting at: AVE 26							\$563,463.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908210846	S MONTGOMERY LAKE	AUTO PARK PLACE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
2018	0.0 to 55.3 feet	Cross Slope (PAR)	2.0-3.0%	9 ft	498	SF	\$120	\$59,724
46996	4.2 to 5.2 feet	Vertical Change	-.43	9 ft	9	REF		
52372	12.6 to 13.6 feet	Vertical Change	-.28	9 ft	9	REF		
45465	21.5 to 22.5 feet	Vertical Change	-.5	9 ft	9	REF		
49274	38.0 to 39.0 feet	Vertical Change	-.35	9 ft	9	REF		
46315	51.6 to 52.6 feet	Vertical Change	-.46	9 ft	9	REF		
2025	57.9 to 89.8 feet	Cross Slope (PAR)	2.0-3.0%	9 ft	287	SF	\$120	\$34,452
42540	67.9 to 68.9 feet	Vertical Change	-.68	9 ft	9	REF		
44186	80.2 to 81.2 feet	Vertical Change	-.56	9 ft	9	REF		
TOTAL COST FOR: W side of S MONTGOMERY LAKE Starting at: AUTO PARK PLACE							\$94,176.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908210848	S MONTGOMERY LAKE	SAVE MART PHARMACY	PARKING LOT ENTRANCE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
41928	4.2 to 5.2 feet	Vertical Change	-.79	8 ft	8	SF	\$75	\$563	
47473	10.8 to 11.8 feet	Vertical Change	-.41	8 ft	8	LF	\$75	\$563	
2027	14.8 to 29.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	110	SF	\$120	\$13,230	
48415	17.7 to 20.5 feet	Vertical Change	-.38	8 ft	21	REF			
52857	23.2 to 31.5 feet	Vertical Change	-.27	8 ft	62	REF			
42272	32.2 to 33.2 feet	Vertical Change	-.71	8 ft	8	SF	\$75	\$563	
2028	33.3 to 35.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	19	SF	\$120	\$2,250	
52858	34.6 to 38.0 feet	Vertical Change	-.27	8 ft	26	REF			
42071	41.9 to 42.9 feet	Vertical Change	-.75	8 ft	8	SF	\$75	\$563	
53858	44.4 to 45.4 feet	Vertical Change	-.25	8 ft	8	LF	\$75	\$563	
2029	46.3 to 50.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	30	SF	\$120	\$3,600	
42001	51.9 to 52.9 feet	Vertical Change	-.77	8 ft	8	SF	\$75	\$563	
2030	54.1 to 59.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	43	SF	\$120	\$5,130	
46997	61.9 to 62.9 feet	Vertical Change	-.43	8 ft	8	LF	\$75	\$563	
56631	62.0 to 63.0 feet	Vertical Change	.46	8 ft	8	LF	\$75	\$563	
2031	63.4 to 78.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	114	SF	\$120	\$13,680	
42030	71.7 to 72.7 feet	Vertical Change	-.76	8 ft	8	REF			
42372	81.4 to 82.4 feet	Vertical Change	-.7	8 ft	7	REF			
2033	82.3 to 85.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	26	SF	\$120	\$3,150	
2034	90.0 to 107.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	133	SF	\$120	\$15,930	
49275	91.1 to 92.1 feet	Vertical Change	-.35	8 ft	8	REF			
46783	101.0 to 102.0 feet	Vertical Change	-.44	8 ft	8	REF			
53363	108.3 to 109.3 feet	Vertical Change	-.26	8 ft	8	LF	\$75	\$563	
44822	110.8 to 111.8 feet	Vertical Change	-.53	8 ft	8	SF	\$75	\$563	
2035	112.9 to 117.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	33	SF	\$120	\$3,960	
42456	120.6 to 121.6 feet	Vertical Change	-.69	8 ft	8	REF			
2036	121.3 to 184.0 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	470	SF	\$120	\$56,430	
53364	123.2 to 126.7 feet	Vertical Change	-.26	8 ft	26	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908210848	S MONTGOMERY LAKE	SAVE MART PHARMACY	PARKING LOT ENTRANCE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
42031	130.6 to 131.6 feet	Vertical Change	-.76	8 ft	8	REF		
46316	134.1 to 135.1 feet	Vertical Change	-.46	8 ft	8	REF		
45001	139.2 to 140.2 feet	Vertical Change	-.52	8 ft	8	REF		
52859	147.7 to 148.7 feet	Vertical Change	-.27	8 ft	8	REF		
46092	157.6 to 158.6 feet	Vertical Change	-.47	8 ft	8	REF		
51953	167.6 to 168.6 feet	Vertical Change	-.29	8 ft	8	REF		
44398	180.8 to 181.8 feet	Vertical Change	-.55	8 ft	8	REF		
56931	183.1 to 184.1 feet	Vertical Change	.53	8 ft	8	REF		

TOTAL COST FOR: E side of S MONTGOMERY LAKE Starting at: SAVE MART PHARMACY \$122,985.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908210850	S MONTGOMERY LAKE	PARKING LOT ENTRANCE	PARKING LOT ENTRANCE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
2043	0.0 to 9.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	73	SF	\$120	\$8,730
52860	2.8 to 5.7 feet	Vertical Change	-27	8 ft	22	REF		
41465	8.3 to 9.3 feet	Vertical Change	-1.13	8 ft	8	REF		
43556	18.4 to 19.4 feet	Vertical Change	-6	8 ft	8	SF	\$75	\$563
2044	22.1 to 75.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	402	SF	\$120	\$48,240
47474	28.3 to 29.3 feet	Vertical Change	-.41	8 ft	8	REF		
53366	45.3 to 46.3 feet	Vertical Change	-.26	8 ft	8	REF		
42174	50.2 to 51.2 feet	Vertical Change	-.73	8 ft	8	REF		
53859	52.8 to 53.8 feet	Vertical Change	-.25	8 ft	8	REF		
41759	89.0 to 90.0 feet	Vertical Change	-.86	8 ft	8	SF	\$75	\$563
2046	90.3 to 97.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	55	SF	\$120	\$6,570
46093	101.5 to 102.5 feet	Vertical Change	-.47	8 ft	8	LF	\$75	\$563
51954	114.1 to 115.1 feet	Vertical Change	-.29	8 ft	8	LF	\$75	\$563
2047	121.7 to 124.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	23	SF	\$120	\$2,790
42373	139.1 to 140.1 feet	Vertical Change	-.7	8 ft	8	SF	\$75	\$563
2048	141.3 to 160.0 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	140	SF	\$120	\$16,830
42175	151.5 to 152.5 feet	Vertical Change	-.73	8 ft	8	REF		
53860	161.6 to 162.6 feet	Vertical Change	-.25	8 ft	8	LF	\$75	\$563
45194	164.2 to 165.2 feet	Vertical Change	-.51	8 ft	8	SF	\$75	\$563
44187	168.7 to 170.9 feet	Vertical Change	-.56	8 ft	17	SF	\$75	\$1,238
2049	187.2 to 189.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	18	SF	\$120	\$2,160
42541	189.0 to 190.0 feet	Vertical Change	-.68	8 ft	8	REF		
2050	194.0 to 220.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	196	SF	\$120	\$23,490
42542	200.7 to 201.7 feet	Vertical Change	-.68	8 ft	8	REF		
48121	211.2 to 212.2 feet	Vertical Change	-.39	8 ft	8	REF		
41266	221.7 to 222.7 feet	Vertical Change	-1.73	8 ft	8	SF	\$75	\$563
52861	225.4 to 226.4 feet	Vertical Change	-.27	8 ft	8	LF	\$75	\$563

TOTAL COST FOR: E side of S MONTGOMERY LAKE Starting at: PARKING LOT ENTRANCE \$115,110.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908210851	S MONTGOMERY LAKE	PARKING LOT ENTRANCE	AVE 26					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
45680	1.9 to 2.9 feet	Vertical Change	-.49	8 ft	8	REF			
2051	2.8 to 45.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	320	SF	\$120	\$38,340	
44823	5.6 to 6.6 feet	Vertical Change	-.53	8 ft	8	REF			
41830	9.0 to 10.0 feet	Vertical Change	-.82	8 ft	8	REF			
43217	12.7 to 13.7 feet	Vertical Change	-.62	8 ft	8	REF			
41380	21.6 to 22.6 feet	Vertical Change	-1.33	8 ft	8	REF			
49276	25.0 to 27.8 feet	Vertical Change	-.35	8 ft	21	REF			
42216	35.8 to 36.8 feet	Vertical Change	-.72	8 ft	8	REF			
45466	45.6 to 46.6 feet	Vertical Change	-.5	8 ft	8	SF	\$75	\$563	
2053	48.1 to 51.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	26	SF	\$120	\$3,060	
2054	54.5 to 74.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	150	SF	\$120	\$18,000	
51543	65.5 to 69.0 feet	Vertical Change	-.3	8 ft	26	REF			
48122	85.5 to 86.5 feet	Vertical Change	-.39	8 ft	8	LF	\$75	\$563	
2056	87.3 to 137.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	379	SF	\$120	\$45,450	
43094	95.2 to 96.2 feet	Vertical Change	-.63	8 ft	8	REF			
45002	105.1 to 106.1 feet	Vertical Change	-.52	8 ft	8	REF			
46784	114.9 to 115.9 feet	Vertical Change	-.44	8 ft	8	REF			
51544	134.3 to 135.3 feet	Vertical Change	-.3	8 ft	8	REF			
42374	144.2 to 145.2 feet	Vertical Change	-.7	8 ft	8	SF	\$75	\$563	
2061	153.0 to 161.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	62	SF	\$120	\$7,470	
48978	163.4 to 164.4 feet	Vertical Change	-.36	8 ft	8	LF	\$75	\$563	
2063	165.8 to 167.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	14	SF	\$120	\$1,620	
46544	173.2 to 174.2 feet	Vertical Change	-.45	8 ft	8	LF	\$75	\$563	
47887	182.8 to 183.8 feet	Vertical Change	-.4	8 ft	8	LF	\$75	\$563	
49604	195.2 to 196.2 feet	Vertical Change	-.34	8 ft	8	REF			
2064	195.9 to 206.0 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	76	SF	\$120	\$9,090	
47888	205.3 to 206.3 feet	Vertical Change	-.4	8 ft	8	REF			
TOTAL COST FOR:		E	<i>side of</i> S MONTGOMERY LAKE	<i>Starting at:</i> PARKING LOT ENTRANCE				\$126,405.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908210855	AVE 26	S MONTGOMERY LAKE	PARKING LOT ENTRANCE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
2065	0.0 to 1.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960	
40009	0.0 to 2.9 feet	Running Slope	6.0-7.0%	5 ft	15	REF			
40010	2.9 to 4.3 feet	Running Slope	5.0-6.0%	5 ft	7	SF	\$120	\$840	
41718	28.9 to 29.9 feet	Vertical Change	-88	5 ft	5	SF	\$75	\$375	
46998	38.5 to 39.5 feet	Vertical Change	-43	5 ft	5	LF	\$75	\$375	
2066	48.4 to 74.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	130	SF	\$120	\$15,540	
44824	48.7 to 49.7 feet	Vertical Change	-.53	5 ft	5	REF			
53862	50.9 to 54.1 feet	Vertical Change	-.25	5 ft	16	REF			
53367	57.6 to 58.6 feet	Vertical Change	-.26	5 ft	5	REF			
42375	59.8 to 60.8 feet	Vertical Change	-.7	5 ft	5	REF			
52375	62.5 to 66.2 feet	Vertical Change	-.28	5 ft	19	REF			
41856	70.2 to 71.2 feet	Vertical Change	-.81	5 ft	5	REF			
52376	75.0 to 76.0 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
2067	78.1 to 127.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	247	SF	\$120	\$29,640	
42072	79.9 to 80.9 feet	Vertical Change	-.75	5 ft	5	REF			
52862	82.2 to 83.2 feet	Vertical Change	-.27	5 ft	5	REF			
53863	87.1 to 88.1 feet	Vertical Change	-.25	5 ft	5	REF			
52377	99.4 to 100.4 feet	Vertical Change	-.28	5 ft	5	REF			
48123	119.2 to 120.2 feet	Vertical Change	-.39	5 ft	5	REF			
46094	129.0 to 132.7 feet	Vertical Change	-.47	5 ft	18	LF	\$75	\$1,388	
2074	132.3 to 142.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$6,060	
45888	139.6 to 140.6 feet	Vertical Change	-.48	5 ft	5	REF			
50640	144.9 to 145.9 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
2075	147.9 to 296.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	744	SF	\$120	\$89,220	
42752	149.8 to 150.8 feet	Vertical Change	-.66	5 ft	5	REF			
52379	152.4 to 158.5 feet	Vertical Change	-.28	5 ft	31	REF			
44188	160.1 to 161.1 feet	Vertical Change	-.56	5 ft	5	REF			
47475	169.6 to 170.6 feet	Vertical Change	-.41	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908210855	AVE 26	S MONTGOMERY LAKE	PARKING LOT ENTRANCE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56959	169.7 to 170.7 feet	Vertical Change	.56	5 ft	5	REF		
51957	174.5 to 175.5 feet	Vertical Change	-.29	5 ft	5	REF		
51958	177.7 to 178.7 feet	Vertical Change	-.29	5 ft	5	REF		
53864	183.1 to 186.7 feet	Vertical Change	-.25	5 ft	18	REF		
43850	188.3 to 189.3 feet	Vertical Change	-.58	5 ft	5	REF		
51959	193.5 to 197.1 feet	Vertical Change	-.29	5 ft	18	REF		
43694	198.7 to 199.7 feet	Vertical Change	-.59	5 ft	5	REF		
53369	204.1 to 212.8 feet	Vertical Change	-.26	5 ft	44	REF		
51960	219.3 to 220.3 feet	Vertical Change	-.29	5 ft	5	REF		
41857	221.0 to 222.0 feet	Vertical Change	-.81	5 ft	5	REF		
52380	223.6 to 224.6 feet	Vertical Change	-.28	5 ft	5	REF		
53866	228.7 to 232.2 feet	Vertical Change	-.25	5 ft	18	REF		
41971	232.3 to 233.3 feet	Vertical Change	-.78	5 ft	5	REF		
52863	233.7 to 234.7 feet	Vertical Change	-.27	5 ft	5	REF		
52382	238.7 to 242.3 feet	Vertical Change	-.28	5 ft	18	REF		
41929	243.6 to 244.6 feet	Vertical Change	-.79	5 ft	5	REF		
52864	251.1 to 254.6 feet	Vertical Change	-.27	5 ft	18	REF		
50264	261.1 to 264.6 feet	Vertical Change	-.32	5 ft	18	REF		
42002	265.9 to 266.9 feet	Vertical Change	-.77	5 ft	5	REF		
50643	268.4 to 269.4 feet	Vertical Change	-.31	5 ft	5	REF		
51547	273.4 to 274.4 feet	Vertical Change	-.3	5 ft	5	REF		
42869	277.1 to 278.1 feet	Vertical Change	-.65	5 ft	5	REF		
51962	282.2 to 288.2 feet	Vertical Change	-.29	5 ft	30	REF		
42176	288.5 to 289.5 feet	Vertical Change	-.73	5 ft	5	REF		
53372	289.7 to 290.7 feet	Vertical Change	-.26	5 ft	5	REF		
53373	297.5 to 298.5 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
42870	300.2 to 301.2 feet	Vertical Change	-.65	5 ft	5	REF		
2089	301.0 to 330.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	146	SF	\$120	\$17,460

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908210855	AVE 26	S MONTGOMERY LAKE	PARKING LOT ENTRANCE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51548	305.5 to 306.5 feet	Vertical Change	-.3	5 ft	5	REF		
42003	310.5 to 311.5 feet	Vertical Change	-.77	5 ft	5	REF		
51549	315.3 to 316.3 feet	Vertical Change	-.3	5 ft	5	REF		
50265	320.4 to 330.8 feet	Vertical Change	-.32	5 ft	52	REF		
2093	330.1 to 343.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	67	SF	\$120	\$8,040
42217	337.6 to 338.6 feet	Vertical Change	-.72	5 ft	5	REF		
2095	343.5 to 354.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,420
53375	349.0 to 350.0 feet	Vertical Change	-.26	5 ft	5	REF		
54156	349.0 to 350.0 feet	Vertical Change	.28	5 ft	5	REF		
2098	357.2 to 361.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400
52384	359.4 to 360.4 feet	Vertical Change	-.28	5 ft	5	REF		
2099	364.7 to 442.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	390	SF	\$120	\$46,800
42457	368.9 to 369.9 feet	Vertical Change	-.69	5 ft	5	REF		
52385	371.5 to 377.8 feet	Vertical Change	-.28	5 ft	32	REF		
43695	379.6 to 380.6 feet	Vertical Change	-.59	5 ft	5	REF		
53868	384.8 to 385.8 feet	Vertical Change	-.25	5 ft	5	REF		
43696	389.5 to 390.5 feet	Vertical Change	-.59	5 ft	5	REF		
50644	394.5 to 395.5 feet	Vertical Change	-.31	5 ft	5	REF		
45003	399.3 to 400.3 feet	Vertical Change	-.52	5 ft	5	REF		
52386	406.5 to 409.8 feet	Vertical Change	-.28	5 ft	17	REF		
54161	408.8 to 409.8 feet	Vertical Change	.29	5 ft	5	REF		
49277	411.3 to 412.3 feet	Vertical Change	-.35	5 ft	5	REF		
41858	419.0 to 420.0 feet	Vertical Change	-.81	5 ft	5	REF		
52387	426.5 to 429.6 feet	Vertical Change	-.28	5 ft	16	REF		
53377	438.3 to 441.7 feet	Vertical Change	-.26	5 ft	17	REF		
43557	448.9 to 449.9 feet	Vertical Change	-.6	5 ft	5	REF		
2107	449.8 to 461.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,840
44618	458.4 to 462.2 feet	Vertical Change	-.54	5 ft	19	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908210855	AVE 26	S MONTGOMERY LAKE	PARKING LOT ENTRANCE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
TOTAL COST FOR: S								\$233,482.50

side of AVE 26 Starting at: S MONTGOMERY LAKE WAY

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908210857	AVE 26	PARKING LOT ENTRANCE	S GENOA LAKE WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
53378	2.3 to 3.3 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
41446	4.9 to 5.9 feet	Vertical Change	-1.16	5 ft	5	SF	\$75	\$375	
51966	7.2 to 14.8 feet	Vertical Change	-.29	5 ft	38	LF	\$75	\$2,850	
2108	14.6 to 78.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	321	SF	\$120	\$38,520	
49605	18.6 to 19.6 feet	Vertical Change	-.34	5 ft	5	REF			
44619	22.2 to 23.2 feet	Vertical Change	-.54	5 ft	5	REF			
52390	26.3 to 31.7 feet	Vertical Change	-.28	5 ft	27	REF			
51551	35.7 to 36.7 feet	Vertical Change	-.3	5 ft	5	REF			
42972	38.0 to 39.0 feet	Vertical Change	-.64	5 ft	5	REF			
52865	45.5 to 46.5 feet	Vertical Change	-.27	5 ft	5	REF			
44189	47.8 to 48.8 feet	Vertical Change	-.56	5 ft	5	REF			
53380	50.2 to 51.2 feet	Vertical Change	-.26	5 ft	5	REF			
41587	57.0 to 58.0 feet	Vertical Change	-.99	5 ft	5	REF			
48124	66.6 to 67.6 feet	Vertical Change	-.39	5 ft	5	REF			
53381	71.7 to 77.8 feet	Vertical Change	-.26	5 ft	31	REF			
45005	86.9 to 87.9 feet	Vertical Change	-.52	5 ft	5	SF	\$75	\$375	
53870	92.0 to 93.0 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375	
41496	96.6 to 97.6 feet	Vertical Change	-1.1	5 ft	5	SF	\$75	\$375	
57400	96.7 to 97.7 feet	Vertical Change	1.13	5 ft	5	SF	\$75	\$375	
2113	99.3 to 106.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,440	
46999	106.8 to 107.8 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375	
2114	109.9 to 112.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560	
2115	114.6 to 123.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,340	
47476	116.6 to 117.6 feet	Vertical Change	-.41	5 ft	5	REF			
2116	125.8 to 173.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	240	SF	\$120	\$28,740	
41930	127.2 to 128.2 feet	Vertical Change	-.79	5 ft	5	REF			
41516	137.0 to 138.0 feet	Vertical Change	-1.07	5 ft	5	REF			
51967	141.9 to 147.3 feet	Vertical Change	-.29	5 ft	27	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908210857	AVE 26	PARKING LOT ENTRANCE	S GENOA LAKE WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47889	155.3 to 156.3 feet	Vertical Change	-.4	5 ft	5	REF		
54157	165.4 to 166.4 feet	Vertical Change	.28	5 ft	5	REF		
41972	175.6 to 176.6 feet	Vertical Change	-.78	5 ft	5	SF	\$75	\$375
2126	177.9 to 180.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320
2127	184.1 to 186.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200
53382	185.1 to 188.6 feet	Vertical Change	-.26	5 ft	18	REF		
2128	197.0 to 199.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380
52866	197.7 to 198.7 feet	Vertical Change	-.27	5 ft	5	REF		
49925	204.9 to 205.9 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375
51968	212.7 to 213.7 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375
52867	222.8 to 223.8 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
43368	224.9 to 225.9 feet	Vertical Change	-.61	5 ft	5	SF	\$75	\$375
2129	231.6 to 249.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	89	SF	\$120	\$10,620
44190	234.7 to 235.7 feet	Vertical Change	-.56	5 ft	5	REF		
53871	237.4 to 238.4 feet	Vertical Change	-.25	5 ft	5	REF		
44191	244.7 to 245.7 feet	Vertical Change	-.56	5 ft	5	REF		
53384	247.2 to 248.2 feet	Vertical Change	-.26	5 ft	5	REF		
52868	251.9 to 255.2 feet	Vertical Change	-.27	5 ft	17	LF	\$75	\$1,238
2132	254.2 to 261.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,200
52869	259.0 to 260.0 feet	Vertical Change	-.27	5 ft	5	REF		
46318	263.5 to 264.5 feet	Vertical Change	-.46	5 ft	5	LF	\$75	\$375
2133	264.8 to 267.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380
2134	270.1 to 274.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,640
46545	273.1 to 274.1 feet	Vertical Change	-.45	5 ft	5	REF		
48416	283.2 to 284.2 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375
53385	290.7 to 301.9 feet	Vertical Change	-.26	5 ft	56	LF	\$75	\$4,200
42753	303.0 to 304.0 feet	Vertical Change	-.66	5 ft	5	SF	\$75	\$375
50646	308.2 to 309.2 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908210857	AVE 26	PARKING LOT ENTRANCE	S GENOA LAKE WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47890	312.9 to 313.9 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375
2135	321.6 to 336.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	76	SF	\$120	\$9,180
48125	323.4 to 324.4 feet	Vertical Change	-.39	5 ft	5	REF		
46095	333.1 to 336.6 feet	Vertical Change	-.47	5 ft	18	REF		
2136	340.7 to 353.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,440
2137	357.7 to 359.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780
47891	361.3 to 364.9 feet	Vertical Change	-.4	5 ft	18	LF	\$75	\$1,350
44192	371.9 to 372.9 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375
44193	381.3 to 382.3 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375
50647	389.0 to 390.0 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375
43095	391.3 to 392.3 feet	Vertical Change	-.63	5 ft	5	SF	\$75	\$375
53386	399.0 to 404.8 feet	Vertical Change	-.26	5 ft	29	LF	\$75	\$2,175
46546	411.6 to 412.6 feet	Vertical Change	-.45	5 ft	5	LF	\$75	\$375
44194	421.0 to 422.0 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375
52871	428.5 to 442.1 feet	Vertical Change	-.27	5 ft	68	LF	\$75	\$5,100
2138	435.2 to 440.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,940
2139	443.2 to 454.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,780
52393	446.0 to 447.0 feet	Vertical Change	-.28	5 ft	5	REF		
53387	454.5 to 455.5 feet	Vertical Change	-.26	5 ft	5	REF		
41613	456.4 to 457.4 feet	Vertical Change	-.96	5 ft	5	SF	\$75	\$375
46785	461.5 to 462.5 feet	Vertical Change	-.44	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: S side of AVE 26 Starting at: PARKING LOT ENTRANCE							\$154,747.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908210858	S GENOA LAKE WAY	AVE 26	PARKING LOT ENTRANCE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
47226	0.3 to 4.0 feet	Vertical Change	-42	8 ft	28	LF	\$75	\$2,081	
2140	4.1 to 47.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	326	SF	\$120	\$39,060	
51970	7.1 to 8.1 feet	Vertical Change	-29	8 ft	8	REF			
42114	13.7 to 14.7 feet	Vertical Change	-74	8 ft	8	REF			
44620	30.8 to 31.8 feet	Vertical Change	-54	8 ft	8	REF			
42219	40.7 to 41.7 feet	Vertical Change	-72	8 ft	7	REF			
2141	69.3 to 90.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	162	SF	\$120	\$19,440	
42073	70.3 to 71.3 feet	Vertical Change	-75	8 ft	8	REF			
53388	80.1 to 81.1 feet	Vertical Change	-26	8 ft	8	REF			
52873	89.7 to 90.7 feet	Vertical Change	-27	8 ft	8	REF			
46319	99.5 to 100.5 feet	Vertical Change	-46	8 ft	8	REF			
2144	99.7 to 140.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	305	SF	\$120	\$36,540	
43369	109.3 to 110.3 feet	Vertical Change	-61	8 ft	8	REF			
42871	119.0 to 120.0 feet	Vertical Change	-65	8 ft	8	REF			
44621	128.8 to 129.8 feet	Vertical Change	-54	8 ft	8	REF			
42657	138.9 to 139.9 feet	Vertical Change	-67	8 ft	8	REF			
2145	146.5 to 162.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	122	SF	\$120	\$14,670	
41443	148.5 to 149.5 feet	Vertical Change	-1.17	8 ft	8	REF			
42074	158.6 to 159.6 feet	Vertical Change	-75	8 ft	8	REF			
43218	161.9 to 162.9 feet	Vertical Change	-62	8 ft	8	REF			
45682	167.0 to 168.0 feet	Vertical Change	-49	8 ft	8	LF	\$75	\$563	
49278	170.3 to 171.3 feet	Vertical Change	-35	8 ft	8	LF	\$75	\$563	
2146	174.6 to 183.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	65	SF	\$120	\$7,830	
42220	181.1 to 182.1 feet	Vertical Change	-72	8 ft	8	REF			
42543	191.1 to 192.1 feet	Vertical Change	-68	8 ft	8	SF	\$75	\$563	
41672	200.9 to 201.9 feet	Vertical Change	-91	8 ft	8	REF			
2147	201.7 to 210.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	68	SF	\$120	\$8,190	
44825	210.9 to 211.9 feet	Vertical Change	-53	8 ft	8	SF	\$75	\$563	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908210858	S GENOA LAKE WAY	AVE 26	PARKING LOT ENTRANCE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
2148	213.3 to 245.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	244	SF	\$120	\$29,250
45006	220.7 to 221.7 feet	Vertical Change	-.52	8 ft	8	REF		
42872	230.3 to 231.3 feet	Vertical Change	-.65	8 ft	8	REF		
53389	238.4 to 239.4 feet	Vertical Change	-.26	8 ft	8	REF		
42544	241.1 to 242.1 feet	Vertical Change	-.68	8 ft	8	REF		
41931	244.9 to 245.9 feet	Vertical Change	-.79	8 ft	8	REF		
TOTAL COST FOR: W side of S GENOA LAKE WAY Starting at: AVE 26							\$159,311.25	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908210900	S GENOA LAKE WAY	PARKING LOT ENTRANCE	CURB RAMP					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
45467	1.8 to 5.2 feet	Vertical Change	-.5	8 ft	26	SF	\$75	\$1,913	
2153	11.7 to 17.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	46	SF	\$120	\$5,580	
2155	22.7 to 26.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	32	SF	\$120	\$3,780	
52874	25.3 to 26.3 feet	Vertical Change	-.27	8 ft	8	REF			
48126	34.9 to 38.3 feet	Vertical Change	-.39	8 ft	25	LF	\$75	\$1,913	
53390	47.3 to 50.8 feet	Vertical Change	-.26	8 ft	26	LF	\$75	\$1,969	
45007	54.6 to 55.6 feet	Vertical Change	-.52	8 ft	8	SF	\$75	\$563	
53391	59.5 to 63.1 feet	Vertical Change	-.26	8 ft	27	LF	\$75	\$2,025	
2156	63.3 to 64.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	11	SF	\$120	\$1,350	
44826	74.5 to 75.5 feet	Vertical Change	-.53	8 ft	8	SF	\$75	\$563	
53392	79.4 to 80.4 feet	Vertical Change	-.26	8 ft	8	LF	\$75	\$563	
45468	84.3 to 87.7 feet	Vertical Change	-.5	8 ft	26	SF	\$75	\$1,913	
51971	96.5 to 97.5 feet	Vertical Change	-.29	8 ft	8	LF	\$75	\$563	
53875	101.5 to 104.8 feet	Vertical Change	-.25	8 ft	25	LF	\$75	\$1,856	
2157	140.8 to 151.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	77	SF	\$120	\$9,270	
51972	143.5 to 144.5 feet	Vertical Change	-.29	8 ft	8	REF			
2158	155.1 to 156.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	11	SF	\$120	\$1,260	
48694	163.4 to 164.4 feet	Vertical Change	-.37	8 ft	8	REF			
2159	163.8 to 179.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	121	SF	\$120	\$14,490	
48127	179.4 to 180.8 feet	Vertical Change	-.39	8 ft	11	REF			

TOTAL COST FOR:	W	<i>side of</i>	S GENOA LAKE WAY	<i>Starting at:</i>	PARKING LOT ENTRANCE	\$49,567.50
------------------------	----------	----------------	-------------------------	---------------------	-----------------------------	--------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908210902	S GENOA LAKE WAY	CURB RAMP	PARKING LOT ENTRANCE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
45008	3.1 to 4.1 feet	Vertical Change	-.52	8 ft	7	SF	\$75	\$563	
2160	6.6 to 63.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	426	SF	\$120	\$51,120	
48419	12.9 to 13.9 feet	Vertical Change	-.38	8 ft	8	REF			
51973	18.0 to 19.0 feet	Vertical Change	-.29	8 ft	8	REF			
47477	42.5 to 43.5 feet	Vertical Change	-.41	8 ft	8	REF			
52877	49.8 to 53.1 feet	Vertical Change	-.27	8 ft	25	REF			
53393	59.6 to 60.6 feet	Vertical Change	-.26	8 ft	8	REF			
2162	72.8 to 86.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	102	SF	\$120	\$12,240	
52878	120.6 to 121.6 feet	Vertical Change	-.27	8 ft	8	LF	\$75	\$563	
2163	125.4 to 132.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	50	SF	\$120	\$6,030	
52879	130.4 to 131.4 feet	Vertical Change	-.27	8 ft	8	REF			
2164	135.3 to 143.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	61	SF	\$120	\$7,290	
53394	150.1 to 151.1 feet	Vertical Change	-.26	8 ft	8	LF	\$75	\$563	
2166	154.3 to 155.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	12	SF	\$120	\$1,440	
2167	177.3 to 185.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	61	SF	\$120	\$7,290	
46320	179.7 to 180.7 feet	Vertical Change	-.46	8 ft	8	REF			
TOTAL COST FOR: W							<i>side of S GENOA LAKE WAY Starting at: CURB RAMP</i>	\$87,097.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908210907	S GENOA LAKE WAY	PARKING LOT ENTRANCE	S MONTGOMERY LAKE WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
51974	0.2 to 1.2 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
51554	4.1 to 5.1 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
2168	8.6 to 72.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	322	SF	\$120	\$38,580	
52395	13.0 to 14.0 feet	Vertical Change	-.28	5 ft	5	REF			
50648	20.7 to 21.7 feet	Vertical Change	-.31	5 ft	5	REF			
51975	31.0 to 37.0 feet	Vertical Change	-.29	5 ft	30	REF			
52881	44.0 to 45.0 feet	Vertical Change	-.27	5 ft	5	REF			
53395	51.7 to 57.7 feet	Vertical Change	-.26	5 ft	30	REF			
49279	61.5 to 65.0 feet	Vertical Change	-.35	5 ft	18	REF			
53396	76.4 to 77.4 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
2176	81.1 to 98.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	87	SF	\$120	\$10,380	
2177	106.2 to 116.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$6,000	
2178	128.2 to 135.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,380	
2179	140.7 to 146.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,360	
2180	159.0 to 163.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,580	
2181	214.7 to 217.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440	
50269	236.2 to 237.2 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
2182	238.8 to 245.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,900	
2184	247.8 to 250.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740	
2185	258.7 to 262.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520	
2186	274.8 to 282.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,680	
2188	287.2 to 288.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$1,020	
2189	291.7 to 299.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,860	
2190	302.8 to 359.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	282	SF	\$120	\$33,840	
52396	325.4 to 326.4 feet	Vertical Change	-.28	5 ft	5	REF			
53876	330.3 to 331.3 feet	Vertical Change	-.25	5 ft	5	REF			
53877	342.5 to 343.5 feet	Vertical Change	-.25	5 ft	5	REF			
51977	349.8 to 350.8 feet	Vertical Change	-.29	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908210907	S GENOA LAKE WAY	PARKING LOT ENTRANCE	S MONTGOMERY LAKE WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
2194	370.7 to 379.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,220
53878	384.0 to 385.0 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375
2195	386.3 to 387.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
2196	388.8 to 390.7 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	10	SF	\$120	\$1,140
2197	411.7 to 417.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,660
2198	437.5 to 448.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,720
49280	452.2 to 453.2 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$375
2199	453.4 to 457.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,580
2200	466.6 to 479.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,500
2201	484.1 to 499.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	79	SF	\$120	\$9,480
2204	508.8 to 514.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,600
2205	528.9 to 531.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
2206	533.7 to 553.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	96	SF	\$120	\$11,580
50270	549.8 to 550.8 feet	Vertical Change	-.32	5 ft	5	REF		
2207	556.3 to 576.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	101	SF	\$120	\$12,120
47228	567.5 to 568.5 feet	Vertical Change	-.42	5 ft	5	REF		
2208	579.1 to 581.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
50271	585.5 to 586.5 feet	Vertical Change	-.32	5 ft	5	REF		
2209	585.7 to 587.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960
2210	590.1 to 593.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800
53879	593.0 to 594.0 feet	Vertical Change	-.25	5 ft	5	REF		
2211	595.8 to 598.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380
2212	600.3 to 603.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,980
2213	606.8 to 636.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	149	SF	\$120	\$17,820
53880	607.4 to 608.4 feet	Vertical Change	-.25	5 ft	5	REF		
2217	640.7 to 674.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	167	SF	\$120	\$20,100
48981	675.5 to 676.5 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375

TOTAL COST FOR: W side of S GENOA LAKE WAY Starting at: PARKING LOT ENTRANCE \$233,145.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908210911	MISSION AVE	S GENOA LAKE WAY	VERTE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41309	5.0 to 6.0 feet	Vertical Change	-1.53	5 ft	5	SF	\$75	\$375
57477	5.0 to 6.0 feet	Vertical Change	1.54	5 ft	5	SF	\$75	\$375
57689	5.2 to 6.2 feet	Vertical Change	3.77	5 ft	5	SF	\$75	\$375
41168	5.9 to 6.9 feet	Vertical Change	-3.8	5 ft	5	SF	\$75	\$375
2218	17.8 to 25.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,740
48128	33.9 to 34.9 feet	Vertical Change	-.39	5 ft	5	REF		
2219	34.8 to 40.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,540
53397	53.8 to 54.8 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
2221	79.0 to 81.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380
TOTAL COST FOR: S side of MISSION AVE Starting at: S GENOA LAKE WAY							\$11,535.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908210914	VERTE ST	MISSION AVE	ALMA CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
51556	2.0 to 3.0 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
2222	13.8 to 18.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520	
52882	16.3 to 17.3 feet	Vertical Change	-.27	5 ft	5	REF			
57812	23.8 to 57.8 feet	Driveway				REF			
2223	30.3 to 46.0 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	79	SF	\$40	\$3,140	
47892	36.4 to 37.4 feet	Vertical Change	-.4	5 ft	5	REF			
2226	46.0 to 55.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	47	SF	\$40	\$1,880	
40011	53.7 to 55.3 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
48695	56.8 to 58.7 feet	Vertical Change	-.37	5 ft	10	REF			
2229	58.6 to 69.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,780	
51557	62.6 to 63.6 feet	Vertical Change	-.3	5 ft	5	REF			
2233	125.8 to 127.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900	
2234	156.2 to 161.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,180	
2236	165.3 to 170.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,940	
52397	172.6 to 173.6 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
TOTAL COST FOR: W							side of VERTE ST	Starting at: MISSION AVE	\$22,090.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908210917	ALMA CT	VERTE ST	VERTE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
48129	1.8 to 4.1 feet	Vertical Change	-.39	5 ft	11	LF	\$75	\$863	
2237	9.6 to 22.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,560	
48420	12.9 to 13.9 feet	Vertical Change	-.38	5 ft	5	REF			
48130	20.0 to 21.0 feet	Vertical Change	-.39	5 ft	5	REF			
57814	26.6 to 60.1 feet	Driveway				REF			
2238	33.1 to 57.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	122	SF	\$40	\$4,860	
50649	49.9 to 50.9 feet	Vertical Change	-.31	5 ft	5	REF			
40015	56.3 to 58.2 feet	Running Slope	6.0-7.0%	5 ft	10	REF			
45009	59.4 to 60.4 feet	Vertical Change	-.52	5 ft	5	REF			
48696	65.2 to 66.2 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375	
2243	70.0 to 74.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520	
52398	70.8 to 71.8 feet	Vertical Change	-.28	5 ft	5	REF			
45469	88.9 to 89.9 feet	Vertical Change	-.5	5 ft	5	SF	\$75	\$375	
57815	94.8 to 133.9 feet	Driveway				REF			
53398	95.6 to 96.6 feet	Vertical Change	-.26	5 ft	5	REF			
46786	98.7 to 99.7 feet	Vertical Change	-.44	5 ft	5	REF			
2244	103.6 to 121.6 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	90	SF	\$40	\$3,600	
2248	121.6 to 131.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	48	SF	\$40	\$1,920	
40016	130.6 to 132.0 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
46321	133.5 to 134.5 feet	Vertical Change	-.46	5 ft	5	REF			
48131	141.5 to 142.5 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375	
57816	145.3 to 183.9 feet	Driveway				REF			
48697	146.2 to 150.1 feet	Vertical Change	-.37	5 ft	20	REF			
2251	152.8 to 165.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	64	SF	\$40	\$2,560	
2254	165.6 to 180.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	76	SF	\$40	\$3,020	
40017	179.7 to 182.0 feet	Running Slope	5.0-6.0%	5 ft	12	REF			
43851	183.4 to 184.4 feet	Vertical Change	-.58	5 ft	5	REF			
2259	184.8 to 199.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,700	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908210917	ALMA CT	VERTE ST	VERTE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
49927	190.8 to 192.5 feet	Vertical Change	-.33	5 ft	9	REF		
48698	196.1 to 197.1 feet	Vertical Change	-.37	5 ft	5	REF		
52399	200.6 to 201.6 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375
57817	201.8 to 239.0 feet	Driveway				REF		
2260	202.5 to 204.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	11	SF	\$40	\$420
43370	204.2 to 205.2 feet	Vertical Change	-.61	5 ft	5	REF		
2261	208.5 to 211.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	17	SF	\$40	\$660
2263	211.8 to 229.2 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	87	SF	\$40	\$3,480
2265	229.2 to 236.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	38	SF	\$40	\$1,520
40018	235.3 to 237.8 feet	Running Slope	5.0-6.0%	5 ft	13	REF		
44399	238.7 to 239.7 feet	Vertical Change	-.55	5 ft	5	REF		
41859	241.6 to 242.6 feet	Vertical Change	-.81	5 ft	5	SF	\$75	\$375
46096	246.2 to 247.2 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375
57818	252.0 to 289.4 feet	Driveway				REF		
2266	254.2 to 255.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200
47478	254.6 to 255.6 feet	Vertical Change	-.41	5 ft	5	REF		
2267	258.6 to 286.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	139	SF	\$40	\$5,560
40019	285.2 to 286.5 feet	Running Slope	5.0-6.0%	5 ft	7	REF		
47229	288.6 to 289.6 feet	Vertical Change	-.42	5 ft	5	REF		
2270	301.4 to 306.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060
2271	312.1 to 314.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560
51978	317.1 to 318.1 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375
57819	322.8 to 356.1 feet	Driveway				REF		
2272	323.8 to 326.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	11	SF	\$40	\$440
52400	325.8 to 326.8 feet	Vertical Change	-.28	5 ft	5	REF		
2273	329.4 to 353.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	119	SF	\$40	\$4,760
40020	352.2 to 353.8 feet	Running Slope	5.0-6.0%	5 ft	8	REF		
50650	355.4 to 356.4 feet	Vertical Change	-.31	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908210917	ALMA CT	VERTE ST	VERTE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
45010	362.9 to 363.9 feet	Vertical Change	-.52	5 ft	5	SF	\$75	\$375
52884	369.0 to 370.0 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: W side of ALMA CT Starting at: VERTE ST							\$60,637.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908210924	CORDELIA AVE	ALMA CT	KADOTA AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
46097	1.2 to 2.2 feet	Vertical Change	-47	5 ft	5	LF	\$75	\$375	
2277	6.9 to 30.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	120	SF	\$120	\$14,340	
49609	10.1 to 11.1 feet	Vertical Change	-34	5 ft	5	REF			
53881	26.4 to 27.4 feet	Vertical Change	-25	5 ft	5	REF			
2279	50.0 to 86.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	181	SF	\$120	\$21,660	
44400	62.9 to 63.9 feet	Vertical Change	-55	5 ft	5	REF			
57820	81.1 to 118.6 feet	Driveway				REF			
49281	84.8 to 85.8 feet	Vertical Change	-35	5 ft	5	REF			
2282	90.0 to 115.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	128	SF	\$40	\$5,100	
42115	94.8 to 95.8 feet	Vertical Change	-74	5 ft	5	REF			
44622	118.4 to 122.1 feet	Vertical Change	-54	5 ft	19	REF			
2287	119.3 to 127.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	43	SF	\$40	\$1,700	
52401	121.7 to 123.3 feet	Vertical Change	-28	5 ft	8	REF			
57821	123.2 to 160.8 feet	Driveway				REF			
45684	127.0 to 128.0 feet	Vertical Change	-49	5 ft	5	REF			
40021	129.8 to 133.6 feet	Running Slope	5.0-6.0%	5 ft	19	REF			
2289	130.7 to 158.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	140	SF	\$40	\$5,600	
45011	138.9 to 139.9 feet	Vertical Change	-52	5 ft	5	REF			
52403	149.8 to 150.8 feet	Vertical Change	-28	5 ft	5	REF			
40023	157.2 to 158.7 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
53882	162.6 to 163.6 feet	Vertical Change	-25	5 ft	5	REF			
2295	163.0 to 198.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	176	SF	\$120	\$21,120	
45685	171.3 to 172.3 feet	Vertical Change	-49	5 ft	5	REF			
51979	178.1 to 179.1 feet	Vertical Change	-29	5 ft	5	REF			
45686	195.1 to 196.1 feet	Vertical Change	-49	5 ft	5	REF			
57822	201.7 to 235.7 feet	Driveway				REF			
44019	204.9 to 205.9 feet	Vertical Change	-57	5 ft	5	REF			
2296	208.3 to 232.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	120	SF	\$40	\$4,780	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908210924	CORDELIA AVE	ALMA CT	KADOTA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51980	215.1 to 216.1 feet	Vertical Change	-.29	5 ft	5	REF		
47230	225.1 to 226.1 feet	Vertical Change	-.42	5 ft	5	REF		
45195	235.1 to 236.1 feet	Vertical Change	-.51	5 ft	5	REF		
49610	238.5 to 239.5 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375
2301	240.4 to 244.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400
57823	240.8 to 274.9 feet	Driveway				REF		
48132	241.6 to 245.6 feet	Vertical Change	-.39	5 ft	20	REF		
2302	248.0 to 271.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	119	SF	\$40	\$4,780
50651	264.9 to 265.9 feet	Vertical Change	-.31	5 ft	5	REF		
40024	271.5 to 272.8 feet	Running Slope	5.0-6.0%	5 ft	7	REF		
45687	274.8 to 275.8 feet	Vertical Change	-.49	5 ft	5	REF		
2306	277.0 to 285.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$5,040
48699	283.0 to 284.0 feet	Vertical Change	-.37	5 ft	5	REF		
48133	290.9 to 291.9 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375
57824	347.3 to 382.8 feet	Driveway				REF		
52885	350.6 to 351.6 feet	Vertical Change	-.27	5 ft	5	REF		
2307	354.1 to 379.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	126	SF	\$40	\$5,040
50272	371.0 to 372.0 feet	Vertical Change	-.32	5 ft	5	REF		
40025	377.7 to 379.8 feet	Running Slope	6.0-7.0%	5 ft	11	REF		
49611	381.2 to 385.1 feet	Vertical Change	-.34	5 ft	20	REF		
45197	388.7 to 392.7 feet	Vertical Change	-.51	5 ft	20	SF	\$75	\$1,500
57825	388.7 to 423.5 feet	Driveway				REF		
2313	395.7 to 420.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	123	SF	\$40	\$4,900
49612	412.5 to 413.5 feet	Vertical Change	-.34	5 ft	5	REF		
40026	420.3 to 421.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
47480	422.5 to 423.5 feet	Vertical Change	-.41	5 ft	5	REF		
48700	429.9 to 430.9 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375
2317	436.0 to 439.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,920

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908210924	CORDELIA AVE	ALMA CT	KADOTA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
2318	443.3 to 453.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$5,940
2322	468.1 to 498.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	152	SF	\$120	\$18,240
57826	494.3 to 529.1 feet	Driveway				REF		
48134	497.7 to 498.7 feet	Vertical Change	-0.39	5 ft	5	REF		
2327	501.3 to 511.8 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	53	SF	\$40	\$2,100
47894	507.9 to 508.9 feet	Vertical Change	-0.4	5 ft	5	REF		
2330	511.8 to 516.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	25	SF	\$40	\$980
2331	516.7 to 519.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	14	SF	\$40	\$560
2333	519.5 to 522.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	13	SF	\$40	\$500
2335	522.0 to 524.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	14	SF	\$40	\$560
40027	525.3 to 527.3 feet	Running Slope	5.0-6.0%	5 ft	10	REF		
47481	528.4 to 539.7 feet	Vertical Change	-0.41	5 ft	57	REF		
2337	529.8 to 532.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740
57827	536.0 to 570.5 feet	Driveway				REF		
2338	542.2 to 567.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	125	SF	\$40	\$5,000
50273	559.0 to 560.0 feet	Vertical Change	-0.32	5 ft	5	REF		
40028	565.6 to 567.7 feet	Running Slope	6.0-7.0%	5 ft	11	REF		
46099	569.2 to 570.2 feet	Vertical Change	-0.47	5 ft	5	REF		
44827	576.9 to 577.9 feet	Vertical Change	-0.53	5 ft	5	SF	\$75	\$375
2339	626.5 to 642.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	78	SF	\$120	\$9,360
57828	641.0 to 675.3 feet	Driveway				REF		
2340	647.8 to 672.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	121	SF	\$40	\$4,840
40029	670.8 to 673.0 feet	Running Slope	5.0-6.0%	5 ft	11	REF		
45198	674.9 to 682.5 feet	Vertical Change	-0.51	5 ft	38	REF		
2347	675.4 to 684.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	46	SF	\$40	\$1,840
57829	680.9 to 715.9 feet	Driveway				REF		
45012	684.6 to 685.6 feet	Vertical Change	-0.52	5 ft	5	REF		
2348	689.2 to 713.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	120	SF	\$40	\$4,780
40030	711.8 to 713.5 feet	Running Slope	5.0-6.0%	5 ft	9	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908210924	CORDELIA AVE	ALMA CT	KADOTA AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
50652	715.2 to 716.2 feet	Vertical Change	-.31	5 ft	5	REF			
2353	717.8 to 723.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,480	
50274	723.2 to 724.2 feet	Vertical Change	-.32	5 ft	5	REF			
2354	729.4 to 731.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380	
51558	731.5 to 732.5 feet	Vertical Change	-.3	5 ft	5	REF			
50275	741.5 to 742.5 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
2355	757.9 to 768.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,240	
2356	777.0 to 789.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	61	SF	\$120	\$7,320	
57830	787.9 to 820.9 feet	Driveway				REF			
51559	791.2 to 792.2 feet	Vertical Change	-.3	5 ft	5	REF			
2357	794.4 to 799.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	25	SF	\$40	\$980	
2359	799.3 to 807.4 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	41	SF	\$40	\$1,620	
48422	801.4 to 802.4 feet	Vertical Change	-.38	5 ft	5	REF			
2361	807.4 to 817.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	52	SF	\$40	\$2,080	
51981	811.4 to 812.4 feet	Vertical Change	-.29	5 ft	5	REF			
51560	821.1 to 822.1 feet	Vertical Change	-.3	5 ft	5	REF			
2362	825.4 to 829.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,280	
57831	829.1 to 861.7 feet	Driveway				REF			
46787	831.5 to 832.5 feet	Vertical Change	-.44	5 ft	5	REF			
2363	836.0 to 841.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	27	SF	\$40	\$1,060	
2365	841.3 to 859.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	89	SF	\$40	\$3,560	
40031	857.8 to 859.7 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
47895	868.3 to 869.3 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375	
57832	901.3 to 935.3 feet	Driveway				REF			
49282	904.3 to 905.3 feet	Vertical Change	-.35	5 ft	5	REF			
2367	908.2 to 932.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	122	SF	\$40	\$4,860	
46323	934.7 to 935.7 feet	Vertical Change	-.46	5 ft	5	REF			
48423	940.3 to 941.3 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908210924	CORDELIA AVE	ALMA CT	KADOTA AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
50276	988.7 to 989.7 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
2371	990.4 to 1006.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	79	SF	\$120	\$9,480	
48701	997.9 to 998.9 feet	Vertical Change	-.37	5 ft	5	REF			
57833	1003.0 to 1037.9 feet	Driveway				REF			
2372	1009.1 to 1018.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	45	SF	\$40	\$1,800	
2374	1018.1 to 1034.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	80	SF	\$40	\$3,200	
2377	1037.9 to 1042.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	21	SF	\$40	\$840	
57834	1038.9 to 1077.1 feet	Driveway				REF			
56617	1045.1 to 1046.1 feet	Vertical Change	.41	5 ft	5	REF			
2379	1045.8 to 1050.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	23	SF	\$40	\$900	
2381	1050.3 to 1074.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	123	SF	\$40	\$4,900	
47482	1052.5 to 1053.5 feet	Vertical Change	-.41	5 ft	5	REF			
53399	1062.6 to 1066.2 feet	Vertical Change	-.26	5 ft	18	REF			
50653	1077.4 to 1078.4 feet	Vertical Change	-.31	5 ft	5	REF			
2387	1077.5 to 1079.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,080	
2388	1081.7 to 1085.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160	
57835	1081.9 to 1120.7 feet	Driveway				REF			
51562	1082.6 to 1086.4 feet	Vertical Change	-.3	5 ft	19	REF			
2389	1088.7 to 1117.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	144	SF	\$40	\$5,780	
40032	1088.7 to 1091.2 feet	Running Slope	5.0-6.0%	5 ft	13	REF			
40033	1116.4 to 1118.1 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
50654	1120.2 to 1121.2 feet	Vertical Change	-.31	5 ft	5	REF			
52887	1127.0 to 1128.0 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
2398	1138.5 to 1166.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	140	SF	\$120	\$16,800	
57836	1159.8 to 1195.1 feet	Driveway				REF			
48135	1164.1 to 1165.1 feet	Vertical Change	-.39	5 ft	5	REF			
2401	1166.5 to 1189.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	115	SF	\$40	\$4,580	
51563	1174.5 to 1175.5 feet	Vertical Change	-.3	5 ft	5	REF			
2404	1190.9 to 1193.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	12	SF	\$40	\$480	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
S	1908210924	CORDELIA AVE	ALMA CT	KADOTA AVE	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
48702	1194.9 to 1198.8 feet	Vertical Change	-.37	5 ft	19	REF					
57837	1200.3 to 1235.6 feet	Driveway				REF					
49928	1201.8 to 1205.6 feet	Vertical Change	-.33	5 ft	19	REF					
2405	1203.2 to 1204.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$300			
2406	1208.1 to 1214.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	34	SF	\$40	\$1,360			
2408	1214.9 to 1227.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	63	SF	\$40	\$2,520			
53883	1225.2 to 1226.2 feet	Vertical Change	-.25	5 ft	5	REF					
2410	1227.5 to 1232.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	25	SF	\$40	\$980			
40034	1231.2 to 1233.5 feet	Running Slope	5.0-6.0%	5 ft	12	REF					
48136	1234.8 to 1235.8 feet	Vertical Change	-.39	5 ft	5	REF					
41497	1238.1 to 1239.1 feet	Vertical Change	-1.1	5 ft	5	REF					
2411	1238.3 to 1256.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	90	SF	\$120	\$10,800			
46100	1245.0 to 1246.0 feet	Vertical Change	-.47	5 ft	5	REF					
47000	1259.5 to 1260.5 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375			
TOTAL COST FOR: S							<i>side of</i>	CORDELIA AVE	<i>Starting at:</i>	ALMA CT	\$263,265.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908210926	KADOTA AVE	VERDONE ST	S FIG TREE BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44402	1.4 to 2.4 feet	Vertical Change	-.55	5 ft	5	REF		
57143	1.5 to 2.5 feet	Vertical Change	.64	5 ft	5	REF		
2412	1.8 to 26.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	125	SF	\$120	\$14,940
2416	33.9 to 38.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,460
2417	43.8 to 55.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,140
2420	58.8 to 73.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	75	SF	\$120	\$9,000
2421	99.4 to 106.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,140
TOTAL COST FOR: S							side of KADOTA AVE Starting at: VERDONE ST	\$37,680.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908210929	KADOTA AVE	S FIG TREE BLVD	VERDONE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47897	28.0 to 29.0 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375
49283	34.5 to 35.5 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$375
41288	45.2 to 46.2 feet	Vertical Change	-1.62	5 ft	5	SF	\$75	\$375
2422	50.9 to 55.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,580
2423	65.4 to 66.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$660
2424	79.4 to 95.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	82	SF	\$120	\$9,840
2426	104.3 to 111.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,200
51564	118.7 to 119.7 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: N side of KADOTA AVE Starting at: S FIG TREE BLVD							\$18,780.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908210931	VERDONE ST	KADOTA AVE	CONADRIA AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
49929	1.0 to 2.0 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375	
2427	6.2 to 18.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,380	
2428	22.4 to 32.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,300	
50277	23.0 to 24.0 feet	Vertical Change	-.32	5 ft	5	REF			
57838	30.0 to 63.3 feet	Driveway				REF			
47483	33.0 to 34.0 feet	Vertical Change	-.41	5 ft	5	REF			
2430	37.1 to 60.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	119	SF	\$40	\$4,740	
46788	63.1 to 72.9 feet	Vertical Change	-.44	5 ft	49	REF			
2434	64.0 to 72.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,920	
57839	67.4 to 102.8 feet	Driveway				REF			
2435	77.8 to 83.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	30	SF	\$40	\$1,200	
2437	83.8 to 100.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	83	SF	\$40	\$3,300	
42075	102.3 to 103.3 feet	Vertical Change	-.75	5 ft	5	REF			
50278	105.2 to 106.2 feet	Vertical Change	-.32	5 ft	5	REF			
2439	106.1 to 121.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	79	SF	\$120	\$9,420	
42873	109.7 to 110.7 feet	Vertical Change	-.65	5 ft	5	REF			
2440	126.6 to 128.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900	
50279	127.4 to 128.4 feet	Vertical Change	-.32	5 ft	5	REF			
50280	140.5 to 142.1 feet	Vertical Change	-.32	5 ft	8	LF	\$75	\$600	
48425	145.5 to 146.5 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375	
43371	149.1 to 150.1 feet	Vertical Change	-.61	5 ft	5	SF	\$75	\$375	
2441	153.1 to 154.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020	
52406	156.2 to 157.2 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
2442	161.3 to 165.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520	
48983	163.3 to 164.3 feet	Vertical Change	-.36	5 ft	5	REF			
57840	180.1 to 213.4 feet	Driveway				REF			
41362	180.4 to 181.4 feet	Vertical Change	-1.37	5 ft	5	REF			
41270	180.5 to 181.5 feet	Vertical Change	-1.71	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908210931	VERDONE ST	KADOTA AVE	CONADRIA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55947	180.5 to 181.5 feet	Vertical Change	.32	5 ft	5	REF		
2443	182.4 to 183.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240
43698	182.9 to 183.9 feet	Vertical Change	-.59	5 ft	5	REF		
2444	186.4 to 192.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	31	SF	\$40	\$1,220
2446	192.5 to 206.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	69	SF	\$40	\$2,740
2448	206.2 to 208.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	14	SF	\$40	\$540
51565	213.2 to 216.6 feet	Vertical Change	-.3	5 ft	17	REF		
2449	213.7 to 223.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,820
57841	217.9 to 253.8 feet	Driveway				REF		
2450	228.1 to 239.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	59	SF	\$40	\$2,340
2452	239.8 to 245.0 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	26	SF	\$40	\$1,040
2454	245.0 to 251.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	30	SF	\$40	\$1,200
40035	250.3 to 252.6 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
53401	253.7 to 254.7 feet	Vertical Change	-.26	5 ft	5	REF		
2456	254.4 to 261.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	34	SF	\$40	\$1,340
2458	261.1 to 278.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	85	SF	\$120	\$10,260
53884	276.9 to 277.9 feet	Vertical Change	-.25	5 ft	5	REF		
2462	291.3 to 294.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,860
57427	304.8 to 305.8 feet	Vertical Change	1.22	5 ft	5	SF	\$75	\$375
57842	304.8 to 416.8 feet	Driveway				REF		
2463	306.2 to 308.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	11	SF	\$40	\$420
57694	306.4 to 307.4 feet	Vertical Change	3.96	5 ft	5	REF		
41165	306.5 to 307.5 feet	Vertical Change	-4.02	5 ft	5	REF		
43372	308.1 to 309.1 feet	Vertical Change	-.61	5 ft	5	REF		
2464	311.2 to 331.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	102	SF	\$40	\$4,080
2468	331.6 to 338.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	35	SF	\$40	\$1,400
40036	338.2 to 339.2 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
2470	341.7 to 343.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	8	SF	\$40	\$320

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908210931	VERDONE ST	KADOTA AVE	CONADRIA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
2471	345.3 to 351.1 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	29	SF	\$40	\$1,160
2473	351.1 to 374.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	119	SF	\$40	\$4,740
49613	354.6 to 355.6 feet	Vertical Change	-.34	5 ft	5	REF		
50655	366.8 to 367.8 feet	Vertical Change	-.31	5 ft	5	REF		
2476	374.8 to 376.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	7	SF	\$40	\$280
2477	376.2 to 377.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$320
49930	381.1 to 382.1 feet	Vertical Change	-.33	5 ft	5	REF		
2478	387.7 to 391.8 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	21	SF	\$40	\$820
2480	391.8 to 413.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	110	SF	\$40	\$4,400
52888	393.5 to 394.5 feet	Vertical Change	-.27	5 ft	5	REF		
49614	416.9 to 417.9 feet	Vertical Change	-.34	5 ft	5	REF		
TOTAL COST FOR: E side of VERDONE ST Starting at: KADOTA AVE							\$90,715.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908210935	CONADRIA AVE	VERDONE ST	VERTE ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
52889	0.2 to 1.2 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
2485	4.4 to 34.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	152	SF	\$120	\$18,240	
56989	6.9 to 7.9 feet	Vertical Change	.59	5 ft	5	REF			
48984	15.1 to 16.1 feet	Vertical Change	-.36	5 ft	5	REF			
49615	44.9 to 45.9 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375	
53402	54.9 to 55.9 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
2486	56.0 to 69.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,800	
46789	64.8 to 65.8 feet	Vertical Change	-.44	5 ft	5	REF			
57843	69.7 to 106.3 feet	Driveway				REF			
44020	74.6 to 75.6 feet	Vertical Change	-.57	5 ft	5	REF			
2487	79.0 to 101.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	113	SF	\$40	\$4,520	
48985	84.5 to 85.5 feet	Vertical Change	-.36	5 ft	5	REF			
46548	104.3 to 108.1 feet	Vertical Change	-.45	5 ft	19	REF			
57844	110.3 to 143.6 feet	Driveway				REF			
2489	111.6 to 113.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	11	SF	\$40	\$440	
44195	111.8 to 115.3 feet	Vertical Change	-.56	5 ft	18	REF			
2490	117.7 to 122.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	22	SF	\$40	\$880	
2492	122.1 to 141.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	95	SF	\$40	\$3,820	
49931	134.8 to 135.8 feet	Vertical Change	-.33	5 ft	5	REF			
48704	144.6 to 145.6 feet	Vertical Change	-.37	5 ft	5	REF			
2495	145.0 to 147.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380	
2496	152.1 to 153.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840	
2497	157.0 to 164.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,560	
51983	168.1 to 169.1 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
2499	176.3 to 178.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260	
52407	177.9 to 178.9 feet	Vertical Change	-.28	5 ft	5	REF			
2500	181.1 to 188.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320	
57845	185.3 to 218.8 feet	Driveway				REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908210935	CONADRIA AVE	VERDONE ST	VERTE ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
2501	191.7 to 196.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	23	SF	\$40	\$920	
2503	196.3 to 215.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	95	SF	\$40	\$3,800	
40037	215.0 to 216.7 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
45688	218.2 to 219.2 feet	Vertical Change	-.49	5 ft	5	REF			
2507	219.3 to 242.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	116	SF	\$40	\$4,620	
46549	224.1 to 225.1 feet	Vertical Change	-.45	5 ft	5	REF			
47898	228.0 to 229.0 feet	Vertical Change	-.4	5 ft	5	REF			
53885	235.8 to 236.8 feet	Vertical Change	-.25	5 ft	5	REF			
50281	251.9 to 252.9 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
57846	257.4 to 292.3 feet	Driveway				REF			
2508	259.8 to 261.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$300	
44196	261.3 to 262.3 feet	Vertical Change	-.56	5 ft	5	REF			
2509	264.9 to 289.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	123	SF	\$40	\$4,900	
47484	291.7 to 292.7 feet	Vertical Change	-.41	5 ft	5	REF			
2513	297.2 to 299.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
45890	299.4 to 300.4 feet	Vertical Change	-.48	5 ft	5	LF	\$75	\$375	
2514	321.1 to 323.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,260	
48705	357.4 to 358.4 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375	
57847	364.2 to 398.1 feet	Driveway				REF			
50282	367.1 to 368.1 feet	Vertical Change	-.32	5 ft	5	REF			
2515	370.0 to 371.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	8	SF	\$40	\$320	
2516	372.4 to 395.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	116	SF	\$40	\$4,640	
51566	387.4 to 388.4 feet	Vertical Change	-.3	5 ft	5	REF			
40038	394.4 to 395.8 feet	Running Slope	6.0-7.0%	5 ft	7	REF			
45199	397.5 to 401.2 feet	Vertical Change	-.51	5 ft	19	REF			
57848	403.3 to 438.0 feet	Driveway				REF			
47233	404.4 to 408.2 feet	Vertical Change	-.42	5 ft	19	REF			
2519	410.0 to 420.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	52	SF	\$40	\$2,060	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908210935	CONADRIA AVE	VERDONE ST	VERTE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
50283	417.9 to 418.9 feet	Vertical Change	-.32	5 ft	5	REF			
2521	420.3 to 433.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	66	SF	\$40	\$2,640	
2523	433.5 to 435.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	8	SF	\$40	\$300	
40039	434.1 to 435.7 feet	Running Slope	8.0-9.0%	5 ft	8	REF			
48426	437.2 to 438.2 feet	Vertical Change	-.38	5 ft	5	REF			
48137	445.8 to 446.8 feet	Vertical Change	-.39	5 ft	5	REF			
2524	446.2 to 449.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800	
2525	453.7 to 473.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	101	SF	\$120	\$12,060	
2527	477.4 to 479.8 feet	Cross Slope (PAR)	9.0-10.0%	5 ft	12	SF	\$120	\$1,440	
2529	483.2 to 513.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	149	SF	\$120	\$17,880	
51567	494.2 to 495.2 feet	Vertical Change	-.3	5 ft	5	REF			
57849	511.4 to 544.7 feet	Driveway				REF			
48138	513.8 to 514.8 feet	Vertical Change	-.39	5 ft	5	REF			
2532	516.8 to 524.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	39	SF	\$40	\$1,560	
2534	524.6 to 541.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	83	SF	\$40	\$3,320	
42458	534.5 to 535.5 feet	Vertical Change	-.69	5 ft	5	REF			
48986	544.3 to 548.1 feet	Vertical Change	-.36	5 ft	19	REF			
2536	545.2 to 551.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	29	SF	\$40	\$1,160	
57850	549.8 to 584.6 feet	Driveway				REF			
47485	550.6 to 551.6 feet	Vertical Change	-.41	5 ft	5	REF			
47486	553.9 to 554.9 feet	Vertical Change	-.41	5 ft	5	REF			
2537	556.9 to 582.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	127	SF	\$40	\$5,060	
49932	564.0 to 565.0 feet	Vertical Change	-.33	5 ft	5	REF			
49284	573.9 to 574.9 feet	Vertical Change	-.35	5 ft	5	REF			
48706	584.1 to 585.1 feet	Vertical Change	-.37	5 ft	5	REF			
2539	596.7 to 612.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	78	SF	\$120	\$9,360	
45471	610.6 to 611.6 feet	Vertical Change	-.5	5 ft	5	REF			
2540	626.1 to 653.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	136	SF	\$120	\$16,260	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908210935	CONADRIA AVE	VERDONE ST	VERTE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57851	657.3 to 689.7 feet	Driveway				REF		
48427	660.2 to 661.2 feet	Vertical Change	-38	5 ft	5	REF		
2545	664.1 to 687.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	116	SF	\$40	\$4,620
53403	690.0 to 693.9 feet	Vertical Change	-.26	5 ft	20	REF		
2549	690.7 to 700.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,640
57852	695.9 to 731.0 feet	Driveway				REF		
51568	700.3 to 701.3 feet	Vertical Change	-.3	5 ft	5	REF		
2550	704.5 to 710.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	31	SF	\$40	\$1,220
2552	710.6 to 728.2 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	88	SF	\$40	\$3,520
40040	727.0 to 728.7 feet	Running Slope	5.0-6.0%	5 ft	9	REF		
52408	730.3 to 731.3 feet	Vertical Change	-.28	5 ft	5	REF		
2556	731.3 to 746.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	77	SF	\$40	\$3,080
2557	755.8 to 761.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,180
41163	770.1 to 771.1 feet	Vertical Change	-4.25	5 ft	5	SF	\$75	\$375
57696	770.1 to 771.1 feet	Vertical Change	4.44	5 ft	5	SF	\$75	\$375
57690	771.6 to 772.6 feet	Vertical Change	3.8	5 ft	5	REF		
2558	771.7 to 773.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	9	SF	\$120	\$1,020
53886	771.8 to 772.8 feet	Vertical Change	-.25	5 ft	5	REF		
2559	775.0 to 776.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
2560	779.3 to 784.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,180
57581	780.8 to 781.8 feet	Vertical Change	2.72	5 ft	5	REF		
45689	791.0 to 792.0 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$375
49616	794.4 to 795.4 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375
50656	798.8 to 799.8 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375
47900	813.4 to 814.4 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375
2561	814.8 to 817.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320

TOTAL COST FOR: N side of CONADRIA AVE Starting at: VERDONE ST \$177,055.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908210937	VERTE ST	CONADRIA AVE	MISSION AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
57853	0.0 to 66.6 feet	Driveway				REF			
2562	0.6 to 3.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	12	SF	\$40	\$480	
44403	2.3 to 3.3 feet	Vertical Change	-.55	5 ft	5	REF			
2563	5.9 to 15.0 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	46	SF	\$40	\$1,820	
44623	10.3 to 11.3 feet	Vertical Change	-.54	5 ft	5	REF			
2567	15.0 to 27.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	65	SF	\$40	\$2,580	
46791	20.5 to 21.5 feet	Vertical Change	-.44	5 ft	5	REF			
2570	33.8 to 34.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200	
2571	37.3 to 43.4 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	31	SF	\$40	\$1,220	
2573	43.4 to 48.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	27	SF	\$40	\$1,080	
2575	48.8 to 61.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	64	SF	\$40	\$2,560	
2577	61.6 to 63.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	9	SF	\$40	\$340	
2578	66.5 to 74.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	41	SF	\$40	\$1,640	
50285	66.6 to 67.6 feet	Vertical Change	-.32	5 ft	5	REF			
57854	69.4 to 109.3 feet	Driveway				REF			
49933	72.4 to 75.3 feet	Vertical Change	-.33	5 ft	14	REF			
2580	77.8 to 83.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	26	SF	\$40	\$1,040	
2582	83.0 to 103.4 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	102	SF	\$40	\$4,080	
40041	104.0 to 105.7 feet	Running Slope	7.0-8.0%	5 ft	9	REF			
2583	105.6 to 106.6 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	5	SF	\$40	\$200	
40042	106.6 to 107.6 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
49285	108.6 to 112.1 feet	Vertical Change	-.35	5 ft	18	REF			
2584	113.7 to 115.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260	
2585	120.4 to 130.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,760	
50287	135.7 to 136.7 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
57855	140.1 to 174.8 feet	Driveway				REF			
41692	142.0 to 143.0 feet	Vertical Change	-.9	5 ft	5	REF			
57491	142.1 to 143.1 feet	Vertical Change	1.68	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908210937	VERTE ST	CONADRIA AVE	MISSION AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
45472	144.2 to 145.2 feet	Vertical Change	-.5	5 ft	5	REF		
2586	147.6 to 171.5 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	120	SF	\$40	\$4,780
56625	168.2 to 169.2 feet	Vertical Change	.44	5 ft	5	REF		
42116	168.3 to 169.3 feet	Vertical Change	-.74	5 ft	5	REF		
40043	171.8 to 173.3 feet	Running Slope	5.0-6.0%	5 ft	8	REF		
47001	174.7 to 179.1 feet	Vertical Change	-.43	5 ft	22	REF		
2593	176.8 to 177.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$660
2594	177.9 to 179.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
47487	182.2 to 183.2 feet	Vertical Change	-.41	5 ft	5	REF		
2595	182.7 to 184.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960
57856	182.9 to 213.5 feet	Driveway				REF		
2596	187.7 to 210.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	116	SF	\$40	\$4,620
46792	194.0 to 195.0 feet	Vertical Change	-.44	5 ft	5	REF		
47488	204.4 to 205.4 feet	Vertical Change	-.41	5 ft	5	REF		
40044	210.1 to 211.6 feet	Running Slope	7.0-8.0%	5 ft	8	REF		
50657	214.1 to 215.1 feet	Vertical Change	-.31	5 ft	5	REF		
2598	214.8 to 224.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$5,940
48987	220.8 to 221.8 feet	Vertical Change	-.36	5 ft	5	REF		
2599	229.5 to 245.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	80	SF	\$120	\$9,540
TOTAL COST FOR: W side of VERTE ST Starting at: CONADRIA AVE							\$51,975.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908210939	MISSION AVE	VERTE ST	S GENOA LAKE WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
2601	24.6 to 26.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900	
54141	33.1 to 34.1 feet	Vertical Change	.26	5 ft	5	LF	\$75	\$375	
2602	47.4 to 71.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	123	SF	\$120	\$14,700	
48707	58.8 to 59.8 feet	Vertical Change	-.37	5 ft	5	REF			
TOTAL COST FOR:		N	<i>side of</i> MISSION AVE	<i>Starting at:</i> VERTE ST				\$15,975.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908210944	VERTE ST	BIDAN AVE	CONADRIA AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
50658	3.5 to 4.5 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
2605	8.5 to 15.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,380	
2608	31.1 to 35.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700	
52890	35.7 to 36.7 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
53887	104.9 to 108.4 feet	Vertical Change	-.25	5 ft	18	LF	\$75	\$1,313	
51984	114.8 to 115.8 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
49934	144.6 to 145.6 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375	
2610	151.1 to 155.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,460	
51985	158.1 to 159.1 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
2611	162.1 to 182.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	100	SF	\$120	\$11,940	
50288	162.5 to 163.5 feet	Vertical Change	-.32	5 ft	5	REF			
48708	166.6 to 167.6 feet	Vertical Change	-.37	5 ft	5	REF			
47489	183.7 to 184.7 feet	Vertical Change	-.41	5 ft	5	REF			
2614	184.4 to 196.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,960	
2615	204.1 to 207.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040	
49935	207.6 to 208.6 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375	
TOTAL COST FOR:		E	<i>side of</i> VERTE ST	<i>Starting at:</i> BIDAN AVE				\$34,042.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908210949	CONADRIA AVE	VERTE ST	VERDONE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
2616	6.2 to 15.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,400	
45473	10.2 to 11.2 feet	Vertical Change	-.5	5 ft	5	REF			
50659	21.6 to 22.6 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
50289	26.0 to 27.6 feet	Vertical Change	-.32	5 ft	8	LF	\$75	\$600	
2617	31.3 to 33.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020	
2618	36.6 to 43.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020	
51986	36.7 to 37.7 feet	Vertical Change	-.29	5 ft	5	REF			
57858	39.6 to 73.5 feet	Driveway				REF			
50290	43.3 to 44.3 feet	Vertical Change	-.32	5 ft	5	REF			
2619	46.7 to 71.5 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	124	SF	\$40	\$4,960	
53406	53.8 to 54.8 feet	Vertical Change	-.26	5 ft	5	REF			
40047	70.7 to 71.8 feet	Running Slope	6.0-7.0%	5 ft	6	REF			
40048	71.8 to 72.8 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
48142	73.9 to 74.9 feet	Vertical Change	-.39	5 ft	5	REF			
2623	74.8 to 77.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740	
57859	78.4 to 113.8 feet	Driveway				REF			
51987	80.9 to 84.7 feet	Vertical Change	-.29	5 ft	19	REF			
2624	81.4 to 83.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	10	SF	\$40	\$400	
2625	87.4 to 111.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	122	SF	\$40	\$4,860	
40049	110.5 to 112.3 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
49286	113.8 to 114.8 feet	Vertical Change	-.35	5 ft	5	REF			
47490	121.8 to 122.8 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375	
43220	160.1 to 161.1 feet	Vertical Change	-.62	5 ft	5	SF	\$75	\$375	
2631	172.9 to 179.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020	
2632	182.6 to 189.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,380	
57860	190.0 to 222.8 feet	Driveway				REF			
47234	190.2 to 191.2 feet	Vertical Change	-.42	5 ft	5	REF			
2634	193.2 to 217.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	122	SF	\$40	\$4,880	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
S	1908210949	CONADRIA AVE	VERTE ST	VERDONE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
40050	216.8 to 219.2 feet	Running Slope	5.0-6.0%	5 ft	12	REF			
43558	220.2 to 224.1 feet	Vertical Change	-6	5 ft	20	REF			
2638	226.8 to 230.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,100	
43559	228.1 to 232.0 feet	Vertical Change	-6	5 ft	20	REF			
57861	228.3 to 258.9 feet	Driveway				REF			
2639	233.7 to 257.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	119	SF	\$40	\$4,760	
40051	256.2 to 258.2 feet	Running Slope	6.0-7.0%	5 ft	10	REF			
47901	259.8 to 260.8 feet	Vertical Change	-4	5 ft	5	REF			
2643	260.5 to 270.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,760	
53407	267.7 to 268.7 feet	Vertical Change	-.26	5 ft	5	REF			
2644	294.8 to 299.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760	
2645	304.0 to 305.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840	
45200	315.5 to 316.5 feet	Vertical Change	-.51	5 ft	5	SF	\$75	\$375	
2646	324.8 to 330.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,360	
2647	331.3 to 334.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	16	SF	\$120	\$1,920	
57239	332.1 to 333.1 feet	Vertical Change	.76	5 ft	5	REF			
57862	332.8 to 366.3 feet	Driveway				REF			
40052	334.3 to 335.8 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
49617	335.3 to 336.3 feet	Vertical Change	-.34	5 ft	5	REF			
2649	337.1 to 338.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	8	SF	\$40	\$320	
2650	339.2 to 363.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	122	SF	\$40	\$4,860	
40053	362.2 to 363.8 feet	Running Slope	6.0-7.0%	5 ft	8	REF			
47002	365.6 to 366.6 feet	Vertical Change	-.43	5 ft	5	REF			
47003	368.8 to 369.8 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375	
57863	372.9 to 408.5 feet	Driveway				REF			
44828	374.0 to 377.5 feet	Vertical Change	-.53	5 ft	18	REF			
2656	374.6 to 376.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	9	SF	\$40	\$340	
2657	379.6 to 404.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	125	SF	\$40	\$5,000	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908210949	CONADRIA AVE	VERTE ST	VERDONE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40054	403.3 to 405.4 feet	Running Slope	6.0-7.0%	5 ft	11	REF		
49288	406.8 to 407.8 feet	Vertical Change	-.35	5 ft	5	REF		
2664	408.2 to 419.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	59	SF	\$40	\$2,340
50291	409.9 to 410.9 feet	Vertical Change	-.32	5 ft	5	REF		
53889	414.7 to 415.7 feet	Vertical Change	-.25	5 ft	5	REF		
2666	419.9 to 425.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	30	SF	\$120	\$3,600
57449	420.4 to 421.4 feet	Vertical Change	1.37	5 ft	5	REF		
41273	421.1 to 422.8 feet	Vertical Change	-1.7	5 ft	9	REF		
57428	422.0 to 423.0 feet	Vertical Change	1.25	5 ft	5	REF		
41549	422.2 to 423.2 feet	Vertical Change	-1.02	5 ft	5	REF		
48709	422.2 to 423.2 feet	Vertical Change	-.37	5 ft	5	REF		
57135	422.4 to 423.4 feet	Vertical Change	.62	5 ft	5	REF		
41219	422.9 to 423.9 feet	Vertical Change	-2.13	5 ft	5	REF		
42659	425.1 to 426.1 feet	Vertical Change	-.67	5 ft	5	REF		
2668	425.9 to 465.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	199	SF	\$120	\$23,820
2672	469.8 to 481.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,020
48710	478.8 to 482.8 feet	Vertical Change	-.37	5 ft	20	REF		
57864	478.9 to 512.4 feet	Driveway				REF		
2674	484.5 to 509.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	127	SF	\$40	\$5,080
50292	501.9 to 502.9 feet	Vertical Change	-.32	5 ft	5	REF		
40055	508.5 to 509.9 feet	Running Slope	6.0-7.0%	5 ft	7	REF		
47491	511.8 to 515.7 feet	Vertical Change	-.41	5 ft	20	REF		
2679	513.1 to 521.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,220
57865	518.6 to 553.1 feet	Driveway				REF		
48143	519.4 to 523.1 feet	Vertical Change	-.39	5 ft	19	REF		
2680	524.9 to 550.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	127	SF	\$40	\$5,060
40056	548.8 to 550.9 feet	Running Slope	5.0-6.0%	5 ft	11	REF		
48988	552.4 to 553.4 feet	Vertical Change	-.36	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908210949	CONADRIA AVE	VERTE ST	VERDONE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
2687	553.5 to 555.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140
49936	558.6 to 559.6 feet	Vertical Change	-33	5 ft	5	LF	\$75	\$375
53408	587.5 to 588.5 feet	Vertical Change	-26	5 ft	5	LF	\$75	\$375
41183	589.9 to 590.9 feet	Vertical Change	-2.92	5 ft	5	SF	\$75	\$375
57604	590.0 to 591.0 feet	Vertical Change	2.93	5 ft	5	SF	\$75	\$375
52893	602.6 to 603.6 feet	Vertical Change	-27	5 ft	5	LF	\$75	\$375
2688	613.4 to 627.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	71	SF	\$120	\$8,520
57866	625.3 to 658.3 feet	Driveway				REF		
2690	631.3 to 651.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	99	SF	\$40	\$3,960
2692	652.3 to 655.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	16	SF	\$40	\$640
40057	654.3 to 656.4 feet	Running Slope	5.0-6.0%	5 ft	11	REF		
50660	657.8 to 661.7 feet	Vertical Change	-31	5 ft	20	REF		
2693	658.7 to 668.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,580
57867	663.8 to 698.3 feet	Driveway				REF		
47902	665.2 to 669.2 feet	Vertical Change	-4	5 ft	20	REF		
2695	671.2 to 695.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	120	SF	\$40	\$4,780
40058	694.3 to 696.0 feet	Running Slope	6.0-7.0%	5 ft	9	REF		
47235	697.9 to 698.9 feet	Vertical Change	-42	5 ft	5	REF		
2696	728.3 to 730.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380
57868	737.1 to 771.3 feet	Driveway				REF		
2697	738.2 to 740.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	13	SF	\$40	\$520
51570	740.9 to 741.9 feet	Vertical Change	-3	5 ft	5	REF		
2698	745.0 to 768.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	117	SF	\$40	\$4,660
40059	769.0 to 770.0 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
2700	775.6 to 782.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,840
53890	804.2 to 805.2 feet	Vertical Change	-25	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: S side of CONADRIA AVE Starting at: VERTE ST							\$159,585.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908210950	VERDONE ST	CONADRIA AVE	BIDAN AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47903	4.3 to 5.3 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375
2702	38.3 to 46.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,100
2703	68.9 to 74.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120
52410	80.7 to 81.7 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375
2704	124.3 to 133.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,340
2705	142.9 to 145.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620
51571	150.2 to 151.2 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375
52894	158.9 to 159.9 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
2706	161.8 to 172.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,600
2708	178.6 to 190.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	61	SF	\$120	\$7,260
2709	195.8 to 212.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	85	SF	\$120	\$10,200
56628	207.8 to 208.8 feet	Vertical Change	.45	5 ft	5	REF		
46326	207.9 to 208.9 feet	Vertical Change	-.46	5 ft	5	REF		
41424	208.3 to 209.3 feet	Vertical Change	-1.21	5 ft	5	REF		
57424	208.3 to 209.3 feet	Vertical Change	1.2	5 ft	5	REF		
57480	209.3 to 210.3 feet	Vertical Change	1.59	5 ft	5	REF		
41276	209.5 to 210.5 feet	Vertical Change	-1.66	5 ft	5	REF		
57463	209.8 to 210.8 feet	Vertical Change	1.43	5 ft	5	REF		
41335	209.9 to 210.9 feet	Vertical Change	-1.43	5 ft	5	REF		
57514	211.6 to 212.6 feet	Vertical Change	1.88	5 ft	5	REF		
41267	211.7 to 212.7 feet	Vertical Change	-1.73	5 ft	5	REF		
TOTAL COST FOR: W side of VERDONE ST Starting at: CONADRIA AVE							\$40,740.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908210955	BIDAN AVE	VERDONE ST	VERTE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
2710	3.4 to 11.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,740	
49289	5.2 to 6.2 feet	Vertical Change	-.35	5 ft	5	REF			
57429	6.6 to 7.6 feet	Vertical Change	1.25	5 ft	5	REF			
41294	6.7 to 7.7 feet	Vertical Change	-1.6	5 ft	5	REF			
55958	6.8 to 7.8 feet	Vertical Change	.34	5 ft	5	REF			
41328	6.9 to 7.9 feet	Vertical Change	-1.46	5 ft	5	REF			
41252	7.2 to 8.2 feet	Vertical Change	-1.85	5 ft	5	REF			
57869	28.8 to 63.9 feet	Driveway				REF			
2711	30.3 to 32.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	11	SF	\$40	\$420	
48711	32.2 to 33.2 feet	Vertical Change	-.37	5 ft	5	REF			
2712	35.8 to 60.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	123	SF	\$40	\$4,900	
53891	62.6 to 63.6 feet	Vertical Change	-.25	5 ft	5	REF			
2713	81.4 to 87.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,600	
2714	94.5 to 98.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,100	
52411	95.4 to 96.4 feet	Vertical Change	-.28	5 ft	5	REF			
2715	100.7 to 104.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,460	
57870	101.8 to 136.7 feet	Driveway				REF			
52895	105.3 to 106.3 feet	Vertical Change	-.27	5 ft	5	REF			
2716	108.8 to 133.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	125	SF	\$40	\$5,000	
40060	133.2 to 134.3 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
48144	135.8 to 139.8 feet	Vertical Change	-.39	5 ft	20	REF			
2721	141.1 to 145.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520	
41478	141.3 to 142.3 feet	Vertical Change	-1.12	5 ft	5	REF			
45474	141.5 to 142.5 feet	Vertical Change	-.5	5 ft	5	REF			
54152	141.5 to 142.5 feet	Vertical Change	.27	5 ft	5	REF			
41700	141.6 to 143.2 feet	Vertical Change	-.89	5 ft	8	REF			
57871	141.9 to 176.3 feet	Driveway				REF			
57670	142.3 to 143.3 feet	Vertical Change	3.53	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908210955	BIDAN AVE	VERDONE ST	VERTE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
41175	142.7 to 143.7 feet	Vertical Change	-3.19	5 ft	5	REF			
57298	143.9 to 144.9 feet	Vertical Change	.88	5 ft	5	REF			
41785	144.0 to 145.0 feet	Vertical Change	-.85	5 ft	5	REF			
48145	145.5 to 146.5 feet	Vertical Change	-.39	5 ft	5	REF			
2722	148.7 to 173.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	125	SF	\$40	\$4,980	
57290	156.1 to 157.1 feet	Vertical Change	.83	5 ft	5	REF			
41760	156.2 to 157.2 feet	Vertical Change	-.86	5 ft	5	REF			
51989	165.8 to 166.8 feet	Vertical Change	-.29	5 ft	5	REF			
40061	172.5 to 174.1 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
46550	175.7 to 176.7 feet	Vertical Change	-.45	5 ft	5	REF			
2727	177.1 to 178.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900	
48429	181.8 to 182.8 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375	
2728	187.1 to 237.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	251	SF	\$120	\$30,120	
57691	207.7 to 208.7 feet	Vertical Change	3.88	5 ft	5	REF			
57492	209.0 to 210.0 feet	Vertical Change	1.68	5 ft	5	REF			
41263	209.1 to 210.1 feet	Vertical Change	-1.74	5 ft	5	REF			
49937	211.5 to 213.2 feet	Vertical Change	-.33	5 ft	9	REF			
45690	216.1 to 217.1 feet	Vertical Change	-.49	5 ft	5	REF			
45475	220.3 to 221.3 feet	Vertical Change	-.5	5 ft	5	REF			
41932	248.2 to 249.2 feet	Vertical Change	-.79	5 ft	5	SF	\$75	\$375	
57872	249.3 to 283.5 feet	Driveway				REF			
2731	251.0 to 252.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$220	
52897	251.9 to 252.9 feet	Vertical Change	-.27	5 ft	5	REF			
2732	255.8 to 260.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	24	SF	\$40	\$940	
57159	259.4 to 260.4 feet	Vertical Change	.68	5 ft	5	REF			
41973	259.5 to 260.5 feet	Vertical Change	-.78	5 ft	5	REF			
48146	259.6 to 260.6 feet	Vertical Change	-.39	5 ft	5	REF			
2734	260.5 to 280.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	98	SF	\$40	\$3,920	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908210955	BIDAN AVE	VERDONE ST	VERTE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
40062	278.4 to 280.1 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
52412	282.1 to 283.1 feet	Vertical Change	-.28	5 ft	5	REF			
2738	283.2 to 284.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200	
48990	285.2 to 286.2 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375	
57337	287.3 to 288.3 feet	Vertical Change	.94	5 ft	5	SF	\$75	\$375	
41831	287.5 to 288.5 feet	Vertical Change	-.82	5 ft	5	SF	\$75	\$375	
57873	288.3 to 322.5 feet	Driveway				REF			
46793	292.1 to 293.1 feet	Vertical Change	-.44	5 ft	5	REF			
2739	295.3 to 320.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	128	SF	\$40	\$5,100	
40063	319.4 to 321.6 feet	Running Slope	6.0-7.0%	5 ft	11	REF			
2746	324.2 to 340.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	83	SF	\$120	\$9,900	
2749	348.4 to 354.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,660	
2750	361.1 to 362.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840	
2751	369.7 to 371.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900	
2752	373.5 to 376.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620	
53892	374.2 to 375.2 feet	Vertical Change	-.25	5 ft	5	REF			
2753	383.8 to 386.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500	
2754	392.3 to 397.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000	
57874	394.8 to 427.4 feet	Driveway				REF			
47236	397.4 to 398.4 feet	Vertical Change	-.42	5 ft	5	REF			
2755	400.6 to 418.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	91	SF	\$40	\$3,620	
2757	418.7 to 425.4 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	34	SF	\$40	\$1,340	
40064	424.5 to 426.4 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
48147	427.7 to 431.6 feet	Vertical Change	-.39	5 ft	20	LF	\$75	\$1,463	
2758	433.2 to 437.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,580	
57875	433.9 to 467.8 feet	Driveway				REF			
53409	435.1 to 438.7 feet	Vertical Change	-.26	5 ft	18	REF			
2759	440.5 to 464.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	121	SF	\$40	\$4,820	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908210955	BIDAN AVE	VERDONE ST	VERTE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
2763	464.6 to 465.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	5	SF	\$40	\$200	
40065	464.8 to 466.3 feet	Running Slope	6.0-7.0%	5 ft	8	REF			
49290	467.8 to 468.8 feet	Vertical Change	-.35	5 ft	5	REF			
2764	469.4 to 473.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700	
57671	470.7 to 471.7 feet	Vertical Change	3.57	5 ft	5	REF			
41169	470.9 to 471.9 feet	Vertical Change	-3.61	5 ft	5	REF			
2765	480.7 to 502.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	111	SF	\$120	\$13,260	
2766	508.5 to 513.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,820	
57876	541.5 to 575.4 feet	Driveway				REF			
44404	544.2 to 545.2 feet	Vertical Change	-.55	5 ft	5	REF			
2767	547.2 to 552.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	28	SF	\$40	\$1,100	
2769	552.7 to 555.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	13	SF	\$40	\$520	
2771	555.3 to 558.1 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	14	SF	\$40	\$560	
2773	558.1 to 566.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	41	SF	\$40	\$1,620	
2775	566.2 to 571.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	24	SF	\$40	\$980	
2777	571.1 to 573.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	13	SF	\$40	\$520	
2779	573.7 to 574.7 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200	
50293	575.0 to 576.0 feet	Vertical Change	-.32	5 ft	5	REF			
43221	578.6 to 579.6 feet	Vertical Change	-.62	5 ft	5	SF	\$75	\$375	
57877	581.8 to 615.7 feet	Driveway				REF			
51990	584.7 to 585.7 feet	Vertical Change	-.29	5 ft	5	REF			
2780	587.8 to 597.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	49	SF	\$40	\$1,940	
2784	597.5 to 605.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	38	SF	\$40	\$1,500	
52413	604.8 to 605.8 feet	Vertical Change	-.28	5 ft	5	REF			
2786	605.0 to 613.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	41	SF	\$40	\$1,620	
49939	615.0 to 616.0 feet	Vertical Change	-.33	5 ft	5	REF			
2789	615.9 to 616.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200	
51991	660.5 to 661.5 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908210955	BIDAN AVE	VERDONE ST	VERTE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
49291	680.4 to 681.4 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$375	
2790	683.7 to 690.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,780	
57878	687.8 to 722.0 feet	Driveway				REF			
49940	690.7 to 691.7 feet	Vertical Change	-.33	5 ft	5	REF			
2791	693.1 to 697.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	20	SF	\$40	\$800	
2793	697.1 to 718.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	106	SF	\$40	\$4,220	
47237	721.2 to 725.1 feet	Vertical Change	-.42	5 ft	20	REF			
57879	727.0 to 761.4 feet	Driveway				REF			
49941	728.6 to 732.4 feet	Vertical Change	-.33	5 ft	19	REF			
2797	735.3 to 758.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	116	SF	\$40	\$4,620	
52898	751.3 to 752.3 feet	Vertical Change	-.27	5 ft	5	REF			
40066	757.7 to 759.3 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
46328	761.1 to 762.1 feet	Vertical Change	-.46	5 ft	5	REF			
2800	762.3 to 790.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	140	SF	\$120	\$16,800	
48991	767.5 to 768.5 feet	Vertical Change	-.36	5 ft	5	REF			
53893	782.2 to 783.2 feet	Vertical Change	-.25	5 ft	5	REF			
TOTAL COST FOR:								\$170,322.50	
N side of BIDAN AVE Starting at: VERDONE ST									

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908211001	BIDAN AVE	VERTE ST	VERDONE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
2802	1.8 to 13.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,900	
42974	3.6 to 6.6 feet	Vertical Change	-.64	5 ft	15	REF			
50661	8.7 to 9.7 feet	Vertical Change	-.31	5 ft	5	REF			
49942	12.6 to 13.6 feet	Vertical Change	-.33	5 ft	5	REF			
2805	16.4 to 28.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,440	
48149	26.8 to 27.8 feet	Vertical Change	-.39	5 ft	5	REF			
57880	29.8 to 64.7 feet	Driveway				REF			
48992	30.4 to 34.4 feet	Vertical Change	-.36	5 ft	20	REF			
2806	36.4 to 61.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	125	SF	\$40	\$4,980	
40067	60.1 to 62.2 feet	Running Slope	5.0-6.0%	5 ft	11	REF			
45014	63.9 to 67.8 feet	Vertical Change	-.52	5 ft	20	REF			
57881	69.4 to 103.7 feet	Driveway				REF			
45477	71.1 to 74.5 feet	Vertical Change	-.5	5 ft	17	REF			
2811	71.2 to 75.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	20	SF	\$40	\$800	
2812	76.8 to 77.9 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$220	
2813	77.9 to 78.9 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	5	SF	\$40	\$200	
2814	78.9 to 84.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	27	SF	\$40	\$1,080	
2816	84.3 to 89.6 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	27	SF	\$40	\$1,060	
2818	89.6 to 91.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	8	SF	\$40	\$320	
2819	91.2 to 97.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	32	SF	\$40	\$1,280	
2821	97.6 to 101.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	21	SF	\$40	\$820	
40068	100.5 to 102.4 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
50662	104.1 to 105.1 feet	Vertical Change	-.31	5 ft	5	REF			
46329	112.1 to 113.1 feet	Vertical Change	-.46	5 ft	5	LF	\$75	\$375	
2823	139.2 to 141.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560	
53894	147.5 to 151.0 feet	Vertical Change	-.25	5 ft	18	LF	\$75	\$1,313	
45478	160.0 to 161.0 feet	Vertical Change	-.5	5 ft	5	SF	\$75	\$375	
49293	170.0 to 171.0 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$375	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211001	BIDAN AVE	VERTE ST	VERDONE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57882	176.1 to 209.8 feet	Driveway				REF		
50663	177.0 to 178.0 feet	Vertical Change	-31	5 ft	5	REF		
44021	179.8 to 180.8 feet	Vertical Change	-.57	5 ft	5	REF		
2824	183.5 to 207.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	121	SF	\$40	\$4,840
40069	206.7 to 208.5 feet	Running Slope	7.0-8.0%	5 ft	9	REF		
44197	210.2 to 221.4 feet	Vertical Change	-.56	5 ft	56	REF		
57883	215.6 to 251.7 feet	Driveway				REF		
2829	224.3 to 243.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	94	SF	\$40	\$3,740
42032	240.9 to 241.9 feet	Vertical Change	-.76	5 ft	5	REF		
2831	243.0 to 247.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	22	SF	\$40	\$860
40070	247.2 to 249.8 feet	Running Slope	5.0-6.0%	5 ft	13	REF		
46794	251.2 to 252.2 feet	Vertical Change	-.44	5 ft	5	REF		
46795	259.1 to 260.1 feet	Vertical Change	-.44	5 ft	5	LF	\$75	\$375
2832	278.0 to 293.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	76	SF	\$120	\$9,120
48430	317.4 to 318.4 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375
57884	320.1 to 358.0 feet	Driveway				REF		
45201	327.0 to 328.0 feet	Vertical Change	-.51	5 ft	5	REF		
2833	330.7 to 345.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	73	SF	\$40	\$2,920
2837	345.3 to 355.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	50	SF	\$40	\$1,980
40072	353.7 to 355.9 feet	Running Slope	6.0-7.0%	5 ft	11	REF		
45015	357.6 to 361.4 feet	Vertical Change	-.52	5 ft	19	REF		
57885	363.6 to 397.0 feet	Driveway				REF		
47493	363.9 to 367.7 feet	Vertical Change	-.41	5 ft	19	REF		
2840	371.3 to 394.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	115	SF	\$40	\$4,600
52899	396.9 to 397.9 feet	Vertical Change	-.27	5 ft	5	REF		
47239	404.7 to 405.7 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375
2842	429.6 to 433.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,580
2843	440.7 to 445.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060
50294	463.4 to 464.4 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908211001	BIDAN AVE	VERTE ST	VERDONE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
57886	468.3 to 503.8 feet	Driveway				REF			
47240	473.2 to 474.2 feet	Vertical Change	-42	5 ft	5	REF			
2844	476.4 to 500.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	120	SF	\$40	\$4,780	
50295	503.5 to 504.5 feet	Vertical Change	-32	5 ft	5	REF			
57887	508.3 to 545.6 feet	Driveway				REF			
2850	517.6 to 541.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	120	SF	\$40	\$4,780	
50296	533.6 to 534.6 feet	Vertical Change	-32	5 ft	5	REF			
48993	543.7 to 544.7 feet	Vertical Change	-36	5 ft	5	REF			
2852	548.4 to 551.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680	
46796	549.5 to 550.5 feet	Vertical Change	-44	5 ft	5	REF			
2853	555.2 to 576.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	104	SF	\$120	\$12,480	
53895	575.8 to 576.8 feet	Vertical Change	-25	5 ft	5	REF			
2855	578.5 to 593.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	76	SF	\$120	\$9,060	
47904	580.0 to 581.0 feet	Vertical Change	-4	5 ft	5	REF			
51992	584.2 to 585.2 feet	Vertical Change	-29	5 ft	5	REF			
44405	587.1 to 588.1 feet	Vertical Change	-55	5 ft	5	REF			
2856	596.8 to 605.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,100	
47905	609.4 to 610.4 feet	Vertical Change	-4	5 ft	5	LF	\$75	\$375	
57888	616.7 to 649.3 feet	Driveway				REF			
48712	619.1 to 620.1 feet	Vertical Change	-37	5 ft	5	REF			
2857	622.4 to 629.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	38	SF	\$40	\$1,500	
48431	629.5 to 630.5 feet	Vertical Change	-38	5 ft	5	REF			
2859	629.9 to 645.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	78	SF	\$40	\$3,120	
52900	639.4 to 640.4 feet	Vertical Change	-27	5 ft	5	REF			
2861	645.5 to 646.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	6	SF	\$40	\$220	
45692	649.5 to 653.2 feet	Vertical Change	-49	5 ft	19	LF	\$75	\$1,388	
57889	655.2 to 690.0 feet	Driveway				REF			
2862	655.6 to 659.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	22	SF	\$40	\$860	
45892	656.5 to 660.4 feet	Vertical Change	-48	5 ft	20	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
S	1908211001	BIDAN AVE	VERTE ST	VERDONE ST				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
2863	663.7 to 686.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	116	SF	\$40	\$4,640
52415	689.5 to 690.5 feet	Vertical Change	-.28	5 ft	5	REF		
2864	690.2 to 696.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	30	SF	\$40	\$1,180
51572	695.9 to 696.9 feet	Vertical Change	-.3	5 ft	5	REF		
2865	708.7 to 714.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,180
53410	722.6 to 723.6 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
2866	726.9 to 731.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520
57890	728.7 to 763.3 feet	Driveway				REF		
41444	730.6 to 731.6 feet	Vertical Change	-1.17	5 ft	5	REF		
57404	730.6 to 731.6 feet	Vertical Change	1.16	5 ft	5	REF		
46330	732.3 to 733.3 feet	Vertical Change	-.46	5 ft	5	REF		
2867	736.0 to 759.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	119	SF	\$40	\$4,760
49294	742.8 to 743.8 feet	Vertical Change	-.35	5 ft	5	REF		
40073	759.2 to 761.1 feet	Running Slope	5.0-6.0%	5 ft	10	REF		
48432	762.9 to 763.9 feet	Vertical Change	-.38	5 ft	5	REF		
2869	764.2 to 769.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,420
52901	770.4 to 771.4 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
52416	778.6 to 779.6 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375
2870	788.1 to 792.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,880
55974	788.2 to 789.2 feet	Vertical Change	.37	5 ft	5	REF		
57521	788.4 to 789.4 feet	Vertical Change	1.97	5 ft	5	REF		
41200	788.5 to 789.5 feet	Vertical Change	-2.4	5 ft	5	REF		
46552	790.7 to 791.7 feet	Vertical Change	-.45	5 ft	5	REF		
45693	794.2 to 795.2 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: S							<i>side of BIDAN AVE Starting at: VERTE ST</i>	\$133,720.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority		
W	1908211003	VERDONE ST	BIDAN AVE	CORDELIA AVE					TBD		
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
47494	3.5 to 4.5 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375			
2871	10.8 to 21.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,600			
53411	24.9 to 25.9 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375			
2875	26.6 to 32.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,240			
51993	35.0 to 36.0 feet	Vertical Change	-.29	5 ft	5	REF					
2876	35.0 to 48.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	69	SF	\$120	\$8,280			
48994	45.1 to 46.1 feet	Vertical Change	-.36	5 ft	5	REF					
2879	110.3 to 111.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960			
2880	115.1 to 141.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	130	SF	\$120	\$15,660			
53896	143.1 to 144.1 feet	Vertical Change	-.25	5 ft	5	REF					
2882	143.5 to 154.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,780			
2883	158.4 to 183.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	128	SF	\$120	\$15,300			
2884	205.7 to 209.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,100			
TOTAL COST FOR: W							<i>side of</i>	VERDONE ST	<i>Starting at:</i>	BIDAN AVE	\$59,670.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908211007	CORDELIA AVE	VERDONE ST	VERTE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
53897	0.0 to 1.0 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375	
2885	2.8 to 17.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	72	SF	\$120	\$8,580	
50664	12.4 to 13.4 feet	Vertical Change	-.31	5 ft	5	REF			
53412	20.3 to 21.7 feet	Vertical Change	-.26	5 ft	7	LF	\$75	\$525	
47495	28.7 to 29.7 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375	
2886	32.1 to 37.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,240	
57892	34.3 to 69.6 feet	Driveway				REF			
47242	38.0 to 39.0 feet	Vertical Change	-.42	5 ft	5	REF			
2887	41.3 to 48.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	38	SF	\$40	\$1,500	
2889	48.8 to 65.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	85	SF	\$40	\$3,400	
40077	64.6 to 67.0 feet	Running Slope	5.0-6.0%	5 ft	12	REF			
48713	68.3 to 69.3 feet	Vertical Change	-.37	5 ft	5	REF			
41192	71.4 to 72.4 feet	Vertical Change	-2.56	5 ft	5	SF	\$75	\$375	
48996	74.8 to 75.8 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375	
57617	108.0 to 109.0 feet	Vertical Change	3.06	5 ft	5	SF	\$75	\$375	
41180	108.1 to 109.1 feet	Vertical Change	-3	5 ft	5	SF	\$75	\$375	
57893	108.4 to 143.3 feet	Driveway				REF			
41302	108.8 to 109.8 feet	Vertical Change	-1.56	5 ft	5	REF			
53898	111.6 to 112.6 feet	Vertical Change	-.25	5 ft	5	REF			
2893	114.8 to 140.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	128	SF	\$40	\$5,100	
40078	139.3 to 140.8 feet	Running Slope	8.0-9.0%	5 ft	8	REF			
48714	142.2 to 148.8 feet	Vertical Change	-.37	5 ft	33	REF			
57894	147.4 to 181.9 feet	Driveway				REF			
40079	150.8 to 152.7 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
44022	151.2 to 152.2 feet	Vertical Change	-.57	5 ft	5	REF			
2894	155.2 to 179.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	121	SF	\$40	\$4,820	
40080	178.3 to 179.8 feet	Running Slope	6.0-7.0%	5 ft	8	REF			
52903	181.3 to 182.3 feet	Vertical Change	-.27	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908211007	CORDELIA AVE	VERDONE ST	VERTE ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
2895	185.8 to 187.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200	
52904	218.2 to 219.2 feet	Vertical Change	-27	5 ft	5	LF	\$75	\$375	
49619	228.1 to 229.1 feet	Vertical Change	-34	5 ft	5	LF	\$75	\$375	
49295	248.0 to 249.0 feet	Vertical Change	-35	5 ft	5	LF	\$75	\$375	
57895	254.5 to 288.0 feet	Driveway				REF			
46797	257.8 to 258.8 feet	Vertical Change	-44	5 ft	5	REF			
2896	261.1 to 285.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	123	SF	\$40	\$4,900	
40081	284.7 to 286.4 feet	Running Slope	7.0-8.0%	5 ft	8	REF			
47496	287.8 to 293.8 feet	Vertical Change	-41	5 ft	30	REF			
57896	293.8 to 328.9 feet	Driveway				REF			
2898	296.6 to 297.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240	
43560	297.8 to 298.8 feet	Vertical Change	-6	5 ft	5	REF			
2899	301.1 to 324.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	116	SF	\$40	\$4,640	
52417	308.2 to 309.2 feet	Vertical Change	-28	5 ft	5	REF			
40082	325.5 to 326.7 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
48150	328.3 to 329.3 feet	Vertical Change	-39	5 ft	5	REF			
42033	331.2 to 332.2 feet	Vertical Change	-76	5 ft	5	SF	\$75	\$375	
53899	336.3 to 337.3 feet	Vertical Change	-25	5 ft	5	LF	\$75	\$375	
2902	354.0 to 356.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560	
57897	400.5 to 434.5 feet	Driveway				REF			
2903	402.6 to 403.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200	
46103	403.7 to 404.7 feet	Vertical Change	-47	5 ft	5	REF			
2904	406.8 to 426.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	96	SF	\$40	\$3,840	
2906	426.0 to 431.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	28	SF	\$40	\$1,120	
40083	431.0 to 432.2 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
51573	434.1 to 438.1 feet	Vertical Change	-3	5 ft	20	REF			
57898	439.1 to 475.4 feet	Driveway				REF			
48151	440.8 to 444.8 feet	Vertical Change	-39	5 ft	20	REF			
2909	447.1 to 452.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	26	SF	\$40	\$1,040	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908211007	CORDELIA AVE	VERDONE ST	VERTE ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
2911	452.3 to 456.8 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	23	SF	\$40	\$900	
2913	456.8 to 458.0 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$240	
2914	458.0 to 461.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	19	SF	\$40	\$760	
2916	461.8 to 472.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	55	SF	\$40	\$2,200	
45202	474.8 to 475.8 feet	Vertical Change	-.51	5 ft	5	REF			
46331	482.7 to 483.7 feet	Vertical Change	-.46	5 ft	5	LF	\$75	\$375	
2919	489.3 to 492.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800	
2920	528.0 to 532.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520	
50298	540.6 to 541.6 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
57899	546.4 to 581.3 feet	Driveway				REF			
49944	546.5 to 547.5 feet	Vertical Change	-.33	5 ft	5	REF			
57228	547.4 to 548.4 feet	Vertical Change	.71	5 ft	5	REF			
41498	547.6 to 548.6 feet	Vertical Change	-1.1	5 ft	5	REF			
49945	550.2 to 551.2 feet	Vertical Change	-.33	5 ft	5	REF			
2921	553.5 to 577.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	121	SF	\$40	\$4,860	
52905	580.7 to 584.4 feet	Vertical Change	-.27	5 ft	18	REF			
57900	586.6 to 621.0 feet	Driveway				REF			
2925	594.2 to 618.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	120	SF	\$40	\$4,820	
50665	623.9 to 624.9 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
2927	659.2 to 660.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020	
57901	693.3 to 727.2 feet	Driveway				REF			
49296	696.7 to 697.7 feet	Vertical Change	-.35	5 ft	5	REF			
2928	700.6 to 723.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	117	SF	\$40	\$4,660	
40084	723.2 to 725.1 feet	Running Slope	6.0-7.0%	5 ft	10	REF			
48716	726.6 to 727.6 feet	Vertical Change	-.37	5 ft	5	REF			
51574	742.2 to 743.2 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
2930	746.2 to 748.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
57902	757.4 to 791.4 feet	Driveway				REF			
47907	760.4 to 761.4 feet	Vertical Change	-.4	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908211007	CORDELIA AVE	VERDONE ST	VERTE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
2931	764.3 to 774.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	51	SF	\$40	\$2,040
2933	774.5 to 776.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	12	SF	\$40	\$480
2935	776.9 to 778.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	7	SF	\$40	\$260
2936	778.2 to 785.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	37	SF	\$40	\$1,480
2939	785.6 to 786.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	5	SF	\$40	\$200
2940	787.3 to 789.4 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	11	SF	\$40	\$420
2941	792.6 to 794.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020
51575	800.7 to 801.7 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: N side of CORDELIA AVE Starting at: VERDONE ST							\$82,665.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908211009	VERTE ST	CORDELIA AVE	BIDAN AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
2942	0.7 to 10.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,700
52418	17.2 to 18.2 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375
47243	23.4 to 24.4 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375
2943	42.1 to 49.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,260
2945	88.2 to 89.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660
2946	93.5 to 95.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
2947	98.2 to 106.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800
2948	120.3 to 131.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,420
2949	191.3 to 209.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	91	SF	\$120	\$10,860
53900	192.8 to 196.2 feet	Vertical Change	-.25	5 ft	17	REF		
45895	210.5 to 211.5 feet	Vertical Change	-.48	5 ft	5	LF	\$75	\$375
42076	214.0 to 215.0 feet	Vertical Change	-.75	5 ft	5	SF	\$75	\$375
TOTAL COST FOR: E side of VERTE ST Starting at: CORDELIA AVE							\$35,280.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908211017	S GENOA LAKE WAY	SIDEWALK BEGINS	AVE 26					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
53414	1.9 to 2.9 feet	Vertical Change	-.26	8 ft	8	LF	\$75	\$563	
2952	5.5 to 9.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	30	SF	\$120	\$3,600	
2953	66.3 to 70.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	35	SF	\$120	\$4,140	
51576	77.4 to 78.4 feet	Vertical Change	-.3	8 ft	8	LF	\$75	\$563	
2954	100.0 to 106.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	51	SF	\$120	\$6,120	
57430	107.5 to 108.5 feet	Vertical Change	1.29	8 ft	8	SF	\$75	\$563	
57229	117.2 to 118.2 feet	Vertical Change	.71	8 ft	8	SF	\$75	\$563	
42660	117.5 to 118.5 feet	Vertical Change	-.67	8 ft	8	REF			
2955	118.3 to 136.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	135	SF	\$120	\$16,200	
49946	127.6 to 128.6 feet	Vertical Change	-.33	8 ft	8	REF			
50666	137.8 to 138.8 feet	Vertical Change	-.31	8 ft	8	LF	\$75	\$563	
2957	163.1 to 165.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	18	SF	\$120	\$2,160	
48717	168.2 to 169.2 feet	Vertical Change	-.37	8 ft	8	LF	\$75	\$563	
2958	172.9 to 174.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	14	SF	\$120	\$1,710	
49297	178.1 to 179.1 feet	Vertical Change	-.35	8 ft	8	LF	\$75	\$563	
53415	195.5 to 196.5 feet	Vertical Change	-.26	8 ft	8	LF	\$75	\$563	
52906	219.7 to 220.7 feet	Vertical Change	-.27	8 ft	8	LF	\$75	\$563	
51994	224.7 to 228.1 feet	Vertical Change	-.29	8 ft	26	LF	\$75	\$1,913	
53416	234.5 to 240.2 feet	Vertical Change	-.26	8 ft	43	LF	\$75	\$3,206	
2959	241.6 to 249.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	56	SF	\$120	\$6,750	
2961	254.5 to 260.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	43	SF	\$120	\$5,130	
46554	256.4 to 257.4 feet	Vertical Change	-.45	8 ft	8	REF			
2962	266.7 to 273.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	49	SF	\$120	\$5,850	
50299	276.1 to 277.1 feet	Vertical Change	-.32	8 ft	8	LF	\$75	\$563	
45479	306.3 to 307.3 feet	Vertical Change	-.5	8 ft	8	SF	\$75	\$563	
53417	323.8 to 324.8 feet	Vertical Change	-.26	8 ft	8	LF	\$75	\$563	
54129	350.1 to 351.1 feet	Vertical Change	.25	8 ft	8	LF	\$75	\$563	
49947	355.2 to 359.0 feet	Vertical Change	-.33	8 ft	29	LF	\$75	\$2,138	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1908211017	S GENOA LAKE WAY	SIDEWALK BEGINS	AVE 26	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
2963	363.1 to 364.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	14	SF	\$120	\$1,620	
49948	372.2 to 373.2 feet	Vertical Change	-.33	8 ft	8	LF	\$75	\$563	
2964	384.8 to 388.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	31	SF	\$120	\$3,690	
2965	392.3 to 396.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	30	SF	\$120	\$3,600	
2966	399.1 to 406.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	57	SF	\$120	\$6,840	
53902	409.6 to 410.6 feet	Vertical Change	-.25	8 ft	8	LF	\$75	\$563	
56632	422.7 to 423.7 feet	Vertical Change	.46	8 ft	8	LF	\$75	\$563	
46104	422.8 to 423.8 feet	Vertical Change	-.47	8 ft	8	LF	\$75	\$563	
2967	432.8 to 435.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	21	SF	\$120	\$2,520	
48433	452.1 to 453.1 feet	Vertical Change	-.38	8 ft	8	LF	\$75	\$563	
2968	480.8 to 485.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	38	SF	\$120	\$4,590	
2969	493.5 to 495.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	17	SF	\$120	\$1,980	
48152	522.2 to 525.8 feet	Vertical Change	-.39	8 ft	27	LF	\$75	\$2,025	
47244	532.2 to 533.2 feet	Vertical Change	-.42	8 ft	8	LF	\$75	\$563	
52907	537.3 to 538.3 feet	Vertical Change	-.27	8 ft	8	LF	\$75	\$563	
54130	542.3 to 543.3 feet	Vertical Change	.25	8 ft	8	LF	\$75	\$563	
2970	552.7 to 559.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	52	SF	\$120	\$6,210	
2971	562.1 to 566.0 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	29	SF	\$120	\$3,510	
2972	569.6 to 582.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	94	SF	\$120	\$11,250	
50300	572.5 to 573.5 feet	Vertical Change	-.32	8 ft	8	REF			
2974	585.3 to 593.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	65	SF	\$120	\$7,740	
2975	596.8 to 599.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	19	SF	\$120	\$2,250	
2976	603.1 to 604.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	11	SF	\$120	\$1,350	
2977	613.4 to 634.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	155	SF	\$120	\$18,630	
2978	638.8 to 639.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	8	SF	\$120	\$990	
2979	642.5 to 646.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	32	SF	\$120	\$3,780	
2980	660.6 to 661.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	10	SF	\$120	\$1,170	
46332	662.7 to 663.7 feet	Vertical Change	-.46	8 ft	8	LF	\$75	\$563	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908211017	S GENOA LAKE WAY	SIDEWALK BEGINS	AVE 26	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
2981	666.9 to 667.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	8	SF	\$120	\$900
2982	686.3 to 694.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	62	SF	\$120	\$7,380
2984	697.8 to 731.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	251	SF	\$120	\$30,150
53904	704.9 to 705.9 feet	Vertical Change	-.25	8 ft	8	REF		
2985	739.3 to 755.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	123	SF	\$120	\$14,760
2986	761.3 to 771.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	75	SF	\$120	\$9,000
50301	763.5 to 764.5 feet	Vertical Change	-.32	8 ft	8	REF		
2987	776.1 to 779.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	26	SF	\$120	\$3,060
2988	787.7 to 831.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	329	SF	\$120	\$39,510
2989	835.3 to 890.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	412	SF	\$120	\$49,410
47908	858.9 to 859.9 feet	Vertical Change	-.4	8 ft	8	REF		
2993	895.7 to 919.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	182	SF	\$120	\$21,780
TOTAL COST FOR: E side of S GENOA LAKE WAY Starting at: SIDEWALK BEGINS							\$330,986.25	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211021	AVE 26	S GENOA LAKE WAY	S FIG TREE BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
2995	0.0 to 54.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	273	SF	\$120	\$32,700
45896	4.1 to 5.1 feet	Vertical Change	-48	5 ft	5	REF		
53418	8.3 to 11.5 feet	Vertical Change	-26	5 ft	16	REF		
53419	14.9 to 15.9 feet	Vertical Change	-26	5 ft	5	REF		
49949	19.3 to 20.3 feet	Vertical Change	-33	5 ft	5	REF		
55985	19.3 to 20.3 feet	Vertical Change	.39	5 ft	5	REF		
53420	31.6 to 32.6 feet	Vertical Change	-26	5 ft	5	REF		
52909	43.6 to 44.6 feet	Vertical Change	-27	5 ft	5	REF		
50302	47.8 to 48.8 feet	Vertical Change	-32	5 ft	5	REF		
3001	62.5 to 63.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
3002	83.6 to 96.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	67	SF	\$120	\$7,980
53421	88.3 to 89.3 feet	Vertical Change	-26	5 ft	5	REF		
3003	100.8 to 111.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,300
3004	113.8 to 117.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,460
3005	121.5 to 126.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760
3006	130.3 to 156.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	129	SF	\$120	\$15,480
3008	166.3 to 192.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	129	SF	\$120	\$15,420
3011	205.2 to 208.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860
47005	205.5 to 206.5 feet	Vertical Change	-43	5 ft	5	REF		
42117	205.8 to 206.8 feet	Vertical Change	-74	5 ft	5	REF		
57240	205.8 to 206.8 feet	Vertical Change	.77	5 ft	5	REF		
3012	212.6 to 218.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,720
52910	213.0 to 216.4 feet	Vertical Change	-27	5 ft	17	REF		
52911	220.5 to 221.5 feet	Vertical Change	-27	5 ft	5	LF	\$75	\$375
3013	228.1 to 260.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	160	SF	\$120	\$19,140
48718	235.2 to 236.2 feet	Vertical Change	-37	5 ft	5	REF		
41974	244.8 to 245.8 feet	Vertical Change	-78	5 ft	5	REF		
53905	251.9 to 252.9 feet	Vertical Change	-25	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211021	AVE 26	S GENOA LAKE WAY	S FIG TREE BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
42459	254.1 to 255.1 feet	Vertical Change	-.69	5 ft	5	REF		
44406	273.4 to 274.4 feet	Vertical Change	-.55	5 ft	5	SF	\$75	\$375
3015	301.1 to 302.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
3016	319.9 to 329.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,520
43852	323.6 to 324.6 feet	Vertical Change	-.58	5 ft	5	REF		
3017	333.2 to 336.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160
41815	333.4 to 334.4 feet	Vertical Change	-.83	5 ft	5	REF		
52912	338.5 to 339.5 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
3018	340.4 to 343.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620
3019	345.6 to 372.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	132	SF	\$120	\$15,840
53906	352.7 to 353.7 feet	Vertical Change	-.25	5 ft	5	REF		
55952	352.7 to 353.7 feet	Vertical Change	.33	5 ft	5	REF		
51578	355.0 to 356.0 feet	Vertical Change	-.3	5 ft	5	REF		
41719	362.0 to 363.0 feet	Vertical Change	-.88	5 ft	5	REF		
53422	364.6 to 365.6 feet	Vertical Change	-.26	5 ft	5	REF		
41975	371.9 to 372.9 feet	Vertical Change	-.78	5 ft	5	REF		
53423	377.1 to 378.1 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
51995	381.9 to 385.5 feet	Vertical Change	-.29	5 ft	18	LF	\$75	\$1,350
47497	391.7 to 392.7 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375
53424	396.9 to 397.9 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
3024	399.5 to 401.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440
3025	406.2 to 409.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,100
46799	411.4 to 412.4 feet	Vertical Change	-.44	5 ft	5	LF	\$75	\$375
48434	431.8 to 432.8 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375
3026	436.6 to 460.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	119	SF	\$120	\$14,220
48153	441.5 to 445.0 feet	Vertical Change	-.39	5 ft	18	REF		
52914	448.8 to 449.8 feet	Vertical Change	-.27	5 ft	5	REF		
42222	451.0 to 452.0 feet	Vertical Change	-.72	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211021	AVE 26	S GENOA LAKE WAY	S FIG TREE BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
52915	460.8 to 461.8 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
3028	463.1 to 488.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	126	SF	\$120	\$15,120
43223	470.7 to 471.7 feet	Vertical Change	-.62	5 ft	5	REF		
41693	480.5 to 481.5 feet	Vertical Change	-.9	5 ft	5	REF		
47006	490.4 to 491.4 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375
50667	510.8 to 511.8 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375
55939	510.9 to 511.9 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
44626	520.9 to 521.9 feet	Vertical Change	-.54	5 ft	5	SF	\$75	\$375
3031	526.2 to 578.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	260	SF	\$120	\$31,200
42223	531.1 to 532.1 feet	Vertical Change	-.72	5 ft	5	REF		
53908	540.9 to 544.3 feet	Vertical Change	-.25	5 ft	17	REF		
41761	550.1 to 551.1 feet	Vertical Change	-.86	5 ft	5	REF		
51579	552.5 to 553.5 feet	Vertical Change	-.3	5 ft	5	REF		
53425	557.0 to 558.0 feet	Vertical Change	-.26	5 ft	5	REF		
53909	564.3 to 565.3 feet	Vertical Change	-.25	5 ft	5	REF		
41786	569.2 to 570.2 feet	Vertical Change	-.85	5 ft	5	REF		
52916	571.8 to 580.0 feet	Vertical Change	-.27	5 ft	41	REF		
41976	588.8 to 589.8 feet	Vertical Change	-.78	5 ft	5	SF	\$75	\$375
53910	591.3 to 594.8 feet	Vertical Change	-.25	5 ft	18	LF	\$75	\$1,313
49950	598.9 to 599.9 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375
55961	599.0 to 600.0 feet	Vertical Change	.35	5 ft	5	LF	\$75	\$375
50668	604.1 to 605.1 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375
52423	609.2 to 615.4 feet	Vertical Change	-.28	5 ft	31	LF	\$75	\$2,325
44407	619.2 to 620.2 feet	Vertical Change	-.55	5 ft	5	SF	\$75	\$375
3037	623.4 to 626.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,740
51580	624.5 to 628.1 feet	Vertical Change	-.3	5 ft	18	REF		
3038	629.3 to 667.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	193	SF	\$120	\$23,160
43561	629.7 to 630.7 feet	Vertical Change	-.6	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211021	AVE 26	S GENOA LAKE WAY	S FIG TREE BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
52918	632.3 to 646.5 feet	Vertical Change	-0.27	5 ft	71	REF		
42975	650.2 to 651.2 feet	Vertical Change	-0.64	5 ft	5	REF		
53911	652.0 to 653.0 feet	Vertical Change	-0.25	5 ft	5	REF		
51997	656.9 to 660.4 feet	Vertical Change	-0.29	5 ft	18	REF		
42976	664.2 to 665.2 feet	Vertical Change	-0.64	5 ft	5	REF		
3041	673.3 to 677.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520
42754	674.1 to 675.1 feet	Vertical Change	-0.66	5 ft	5	REF		
3042	679.7 to 687.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,500
41762	684.1 to 685.1 feet	Vertical Change	-0.86	5 ft	5	REF		
43224	694.1 to 695.1 feet	Vertical Change	-0.62	5 ft	5	SF	\$75	\$375
3043	696.8 to 705.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$5,040
48436	704.2 to 705.2 feet	Vertical Change	-0.38	5 ft	5	REF		
44627	714.2 to 715.2 feet	Vertical Change	-0.54	5 ft	5	SF	\$75	\$375
3044	722.5 to 732.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,880
41417	724.1 to 725.1 feet	Vertical Change	-1.23	5 ft	5	REF		
42874	734.1 to 735.1 feet	Vertical Change	-0.65	5 ft	5	SF	\$75	\$375
3046	735.3 to 737.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440
3047	740.2 to 805.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	326	SF	\$120	\$39,060
42977	744.0 to 745.0 feet	Vertical Change	-0.64	5 ft	5	REF		
44829	754.0 to 755.0 feet	Vertical Change	-0.53	5 ft	5	REF		
42004	764.1 to 765.1 feet	Vertical Change	-0.77	5 ft	5	REF		
43373	774.1 to 775.1 feet	Vertical Change	-0.61	5 ft	5	REF		
42661	784.0 to 785.0 feet	Vertical Change	-0.67	5 ft	5	REF		
42545	794.0 to 795.0 feet	Vertical Change	-0.68	5 ft	5	REF		
41977	803.9 to 804.9 feet	Vertical Change	-0.78	5 ft	5	REF		
3050	809.7 to 817.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,920
46333	813.9 to 814.9 feet	Vertical Change	-0.46	5 ft	5	REF		
3051	821.4 to 831.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$6,000

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211021	AVE 26	S GENOA LAKE WAY	S FIG TREE BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
43096	823.9 to 824.9 feet	Vertical Change	-.63	5 ft	5	REF		
44830	834.0 to 835.0 feet	Vertical Change	-.53	5 ft	5	SF	\$75	\$375
41336	843.9 to 844.9 feet	Vertical Change	-1.43	5 ft	5	REF		
3052	844.4 to 849.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760
3053	851.2 to 882.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	156	SF	\$120	\$18,660
45695	853.9 to 854.9 feet	Vertical Change	-.49	5 ft	5	REF		
42273	863.9 to 864.9 feet	Vertical Change	-.71	5 ft	5	REF		
41889	883.9 to 884.9 feet	Vertical Change	-.8	5 ft	5	REF		
3055	884.4 to 887.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,100
3056	892.2 to 918.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	133	SF	\$120	\$15,900
42460	893.9 to 894.9 feet	Vertical Change	-.69	5 ft	5	REF		
46800	903.9 to 904.9 feet	Vertical Change	-.44	5 ft	5	REF		
43374	913.9 to 914.9 feet	Vertical Change	-.61	5 ft	5	REF		
3057	923.3 to 1085.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	813	SF	\$120	\$97,500
44023	923.9 to 924.9 feet	Vertical Change	-.57	5 ft	5	REF		
45897	933.9 to 934.9 feet	Vertical Change	-.48	5 ft	5	REF		
42461	944.0 to 945.0 feet	Vertical Change	-.69	5 ft	5	REF		
42034	954.0 to 955.0 feet	Vertical Change	-.76	5 ft	5	REF		
42118	963.9 to 964.9 feet	Vertical Change	-.74	5 ft	5	REF		
42274	973.9 to 974.9 feet	Vertical Change	-.71	5 ft	5	REF		
42376	983.8 to 984.8 feet	Vertical Change	-.7	5 ft	5	REF		
42662	993.8 to 994.8 feet	Vertical Change	-.67	5 ft	5	REF		
45203	1003.8 to 1004.8 feet	Vertical Change	-.51	5 ft	5	REF		
42546	1013.8 to 1014.8 feet	Vertical Change	-.68	5 ft	5	REF		
42875	1023.7 to 1024.7 feet	Vertical Change	-.65	5 ft	5	REF		
41816	1033.7 to 1034.7 feet	Vertical Change	-.83	5 ft	5	REF		
54131	1043.8 to 1044.8 feet	Vertical Change	.25	5 ft	5	REF		
42377	1053.6 to 1054.6 feet	Vertical Change	-.7	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211021	AVE 26	S GENOA LAKE WAY	S FIG TREE BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
43225	1063.6 to 1064.6 feet	Vertical Change	-.62	5 ft	5	REF		
41451	1073.5 to 1074.5 feet	Vertical Change	-1.15	5 ft	5	REF		
41223	1083.6 to 1084.6 feet	Vertical Change	-2.1	5 ft	5	REF		
3062	1089.7 to 1090.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660
42119	1093.5 to 1094.5 feet	Vertical Change	-.74	5 ft	5	SF	\$75	\$375
3063	1101.3 to 1102.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$780
42005	1103.5 to 1104.5 feet	Vertical Change	-.77	5 ft	5	SF	\$75	\$375
3064	1107.3 to 1115.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800
45480	1114.7 to 1115.7 feet	Vertical Change	-.5	5 ft	5	REF		
49298	1120.9 to 1121.9 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$375
3066	1122.0 to 1126.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400
TOTAL COST FOR: S side of AVE 26 Starting at: S GENOA LAKE WAY							\$452,902.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908211025	S FIG TREE BLVD	AVE 26	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
42978	1.8 to 4.9 feet	Vertical Change	-.64	5 ft	16	SF	\$75	\$1,163	
3067	8.8 to 21.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	61	SF	\$120	\$7,380	
48155	10.6 to 11.6 feet	Vertical Change	-.39	5 ft	5	REF			
52921	18.0 to 19.0 feet	Vertical Change	-.27	5 ft	5	REF			
43226	20.3 to 21.3 feet	Vertical Change	-.62	5 ft	5	REF			
3068	26.8 to 40.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,160	
42755	30.3 to 31.3 feet	Vertical Change	-.66	5 ft	5	REF			
45898	40.3 to 41.3 feet	Vertical Change	-.48	5 ft	5	REF			
3069	47.4 to 192.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	727	SF	\$120	\$87,240	
49620	50.4 to 51.4 feet	Vertical Change	-.34	5 ft	5	REF			
42006	60.4 to 61.4 feet	Vertical Change	-.77	5 ft	5	REF			
43227	80.6 to 81.6 feet	Vertical Change	-.62	5 ft	5	REF			
41222	90.5 to 91.5 feet	Vertical Change	-2.11	5 ft	5	REF			
43228	100.6 to 101.6 feet	Vertical Change	-.62	5 ft	5	REF			
44024	110.5 to 111.5 feet	Vertical Change	-.57	5 ft	5	REF			
43699	120.6 to 121.6 feet	Vertical Change	-.59	5 ft	5	REF			
41373	130.5 to 131.5 feet	Vertical Change	-1.35	5 ft	5	REF			
42756	140.5 to 141.5 feet	Vertical Change	-.66	5 ft	5	REF			
42275	150.5 to 151.5 feet	Vertical Change	-.71	5 ft	5	REF			
42757	160.4 to 161.4 feet	Vertical Change	-.66	5 ft	5	REF			
41258	170.4 to 171.4 feet	Vertical Change	-1.77	5 ft	5	REF			
41285	180.4 to 181.4 feet	Vertical Change	-1.63	5 ft	5	REF			
57903	183.4 to 234.4 feet	Driveway				REF			
43097	187.0 to 188.0 feet	Vertical Change	-.63	5 ft	5	REF			
3072	193.7 to 198.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	25	SF	\$40	\$1,000	
3074	198.7 to 205.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	36	SF	\$40	\$1,420	
42547	201.0 to 202.0 feet	Vertical Change	-.68	5 ft	5	REF			
3075	205.8 to 225.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	99	SF	\$40	\$3,940	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908211025	S FIG TREE BLVD	AVE 26	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
42979	211.4 to 212.4 feet	Vertical Change	-.64	5 ft	5	REF			
44199	221.8 to 222.8 feet	Vertical Change	-.56	5 ft	5	REF			
3079	225.5 to 228.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	14	SF	\$40	\$540	
3081	228.2 to 231.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	17	SF	\$40	\$680	
3082	232.3 to 246.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	70	SF	\$40	\$2,800	
41215	236.0 to 237.0 feet	Vertical Change	-2.19	5 ft	5	REF			
42548	245.8 to 246.8 feet	Vertical Change	-.68	5 ft	5	REF			
3085	246.3 to 380.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	670	SF	\$120	\$80,340	
42035	255.8 to 256.8 feet	Vertical Change	-.76	5 ft	5	REF			
41817	265.9 to 266.9 feet	Vertical Change	-.83	5 ft	5	REF			
41832	275.9 to 276.9 feet	Vertical Change	-.82	5 ft	5	REF			
42758	286.0 to 287.0 feet	Vertical Change	-.66	5 ft	5	REF			
42462	295.9 to 296.9 feet	Vertical Change	-.69	5 ft	5	REF			
43098	306.0 to 307.0 feet	Vertical Change	-.63	5 ft	5	REF			
41367	315.9 to 316.9 feet	Vertical Change	-1.36	5 ft	5	REF			
42463	326.0 to 327.0 feet	Vertical Change	-.69	5 ft	5	REF			
42980	346.0 to 347.0 feet	Vertical Change	-.64	5 ft	5	REF			
41187	355.9 to 356.9 feet	Vertical Change	-2.71	5 ft	5	REF			
42276	365.9 to 366.9 feet	Vertical Change	-.71	5 ft	5	REF			
42981	375.9 to 376.9 feet	Vertical Change	-.64	5 ft	5	REF			
3098	385.2 to 387.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260	
42982	385.8 to 386.8 feet	Vertical Change	-.64	5 ft	5	REF			
42077	395.9 to 396.9 feet	Vertical Change	-.75	5 ft	5	SF	\$75	\$375	
42277	405.9 to 406.9 feet	Vertical Change	-.71	5 ft	5	SF	\$75	\$375	
3099	407.6 to 410.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,980	
3100	415.6 to 443.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	138	SF	\$120	\$16,500	
42464	415.9 to 416.9 feet	Vertical Change	-.69	5 ft	5	REF			
42983	425.8 to 426.8 feet	Vertical Change	-.64	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908211025	S FIG TREE BLVD	AVE 26	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57904	439.7 to 489.3 feet	Driveway				REF		
46801	445.6 to 446.6 feet	Vertical Change	-44	5 ft	5	REF		
3101	447.6 to 451.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	21	SF	\$40	\$820
3103	451.7 to 453.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	7	SF	\$40	\$260
3104	453.0 to 455.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	11	SF	\$40	\$440
43099	456.9 to 457.9 feet	Vertical Change	-63	5 ft	5	REF		
3105	463.8 to 484.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	104	SF	\$40	\$4,140
44200	467.3 to 468.3 feet	Vertical Change	-56	5 ft	5	REF		
42876	477.7 to 478.7 feet	Vertical Change	-65	5 ft	5	REF		
3108	484.5 to 490.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	29	SF	\$40	\$1,140
49299	489.2 to 490.2 feet	Vertical Change	-35	5 ft	5	REF		
3112	490.2 to 531.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	207	SF	\$120	\$24,780
43700	493.0 to 494.0 feet	Vertical Change	-59	5 ft	5	REF		
44628	496.6 to 497.6 feet	Vertical Change	-54	5 ft	5	REF		
52424	512.0 to 513.0 feet	Vertical Change	-28	5 ft	5	REF		
42378	522.0 to 523.0 feet	Vertical Change	-.7	5 ft	5	REF		
42120	532.1 to 533.1 feet	Vertical Change	-.74	5 ft	5	SF	\$75	\$375
3115	533.6 to 537.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160
3116	539.3 to 609.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	351	SF	\$120	\$42,120
42078	542.0 to 543.0 feet	Vertical Change	-.75	5 ft	5	REF		
42759	562.0 to 563.0 feet	Vertical Change	-.66	5 ft	5	REF		
42379	572.0 to 573.0 feet	Vertical Change	-.7	5 ft	5	REF		
41933	581.9 to 582.9 feet	Vertical Change	-.79	5 ft	5	REF		
41376	591.8 to 592.8 feet	Vertical Change	-1.34	5 ft	5	REF		
43375	601.7 to 602.7 feet	Vertical Change	-.61	5 ft	5	REF		
57905	606.3 to 650.4 feet	Driveway				REF		
45696	607.5 to 608.5 feet	Vertical Change	-.49	5 ft	5	REF		
43701	611.3 to 612.3 feet	Vertical Change	-.59	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
W	1908211025	S FIG TREE BLVD	AVE 26	SIDEWALK ENDS	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
3120	612.3 to 615.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	17	SF	\$40	\$680	
3122	615.7 to 644.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	142	SF	\$40	\$5,680	
42984	619.3 to 620.3 feet	Vertical Change	-.64	5 ft	5	REF			
43376	629.4 to 630.4 feet	Vertical Change	-.61	5 ft	5	REF			
45899	639.4 to 640.4 feet	Vertical Change	-.48	5 ft	5	REF			
40085	645.2 to 646.6 feet	Running Slope	6.0-7.0%	5 ft	7	REF			
3126	645.9 to 647.1 feet	Cross Slope (Driveway)	13.014	5 ft	6	SF	\$40	\$240	
44025	647.4 to 648.4 feet	Vertical Change	-.57	5 ft	5	REF			
3127	650.4 to 688.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	192	SF	\$40	\$7,680	
44201	651.1 to 652.1 feet	Vertical Change	-.56	5 ft	5	REF			
41614	659.8 to 660.8 feet	Vertical Change	-.96	5 ft	5	REF			
44629	679.5 to 680.5 feet	Vertical Change	-.54	5 ft	5	REF			
3130	688.8 to 789.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	503	SF	\$120	\$60,300	
50303	699.4 to 700.4 feet	Vertical Change	-.32	5 ft	5	REF			
45481	709.4 to 710.4 feet	Vertical Change	-.5	5 ft	5	REF			
48156	719.3 to 720.3 feet	Vertical Change	-.39	5 ft	5	REF			
45482	729.2 to 730.2 feet	Vertical Change	-.5	5 ft	5	REF			
50670	749.1 to 750.1 feet	Vertical Change	-.31	5 ft	5	REF			
53426	777.1 to 778.1 feet	Vertical Change	-.26	5 ft	5	REF			
51583	788.6 to 789.6 feet	Vertical Change	-.3	5 ft	5	REF			
48157	793.7 to 794.7 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375	
3133	796.3 to 821.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	127	SF	\$120	\$15,240	
47498	807.1 to 808.1 feet	Vertical Change	-.41	5 ft	5	REF			
48719	817.1 to 818.1 feet	Vertical Change	-.37	5 ft	5	REF			
49953	827.0 to 828.0 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375	
3135	858.0 to 899.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	209	SF	\$120	\$25,020	
48720	866.9 to 867.9 feet	Vertical Change	-.37	5 ft	5	REF			
51998	896.6 to 897.6 feet	Vertical Change	-.29	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908211025	S FIG TREE BLVD	AVE 26	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
TOTAL COST FOR: W								\$406,977.50

side of S FIG TREE BLVD Starting at: AVE 26

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908211031	S FIG TREE BLVD	START OF PARKING LOT	END OF PARKING LOT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
3136	0.0 to 1.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	10	SF	\$120	\$1,140
47909	0.3 to 1.8 feet	Vertical Change	-.4	5 ft	8	REF		
55968	0.9 to 1.9 feet	Vertical Change	.36	5 ft	5	REF		
3137	1.9 to 4.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260
3138	7.8 to 23.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	81	SF	\$120	\$9,660
49621	8.0 to 9.0 feet	Vertical Change	-.34	5 ft	5	REF		
52426	14.4 to 15.4 feet	Vertical Change	-.28	5 ft	5	REF		
52427	20.8 to 21.8 feet	Vertical Change	-.28	5 ft	5	REF		
53427	26.4 to 27.4 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
49954	31.3 to 35.1 feet	Vertical Change	-.33	5 ft	19	LF	\$75	\$1,425
51999	42.3 to 46.0 feet	Vertical Change	-.29	5 ft	19	LF	\$75	\$1,388
3141	44.5 to 49.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000
52429	53.1 to 57.0 feet	Vertical Change	-.28	5 ft	20	LF	\$75	\$1,463
3142	54.7 to 62.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,380
52923	91.4 to 92.4 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
51585	100.3 to 104.3 feet	Vertical Change	-.3	5 ft	20	LF	\$75	\$1,500
3143	101.9 to 121.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	100	SF	\$120	\$12,000
52924	109.2 to 110.2 feet	Vertical Change	-.27	5 ft	5	REF		
52925	115.1 to 119.1 feet	Vertical Change	-.27	5 ft	20	REF		
51587	124.1 to 125.1 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375
50304	141.9 to 142.9 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375
3148	157.1 to 160.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,920
49955	159.7 to 163.3 feet	Vertical Change	-.33	5 ft	18	REF		
3149	193.6 to 210.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,320
48997	201.6 to 202.6 feet	Vertical Change	-.36	5 ft	5	REF		
52000	207.3 to 208.3 feet	Vertical Change	-.29	5 ft	5	REF		
TOTAL COST FOR: W							side of S FIG TREE BLVD Starting at: START OF PARKING LOT	\$50,955.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
W	1908211040	S FIG TREE BLVD	SIDEWALK BEGINS	S MONTGOMERY LAKE WAY	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
53912	12.0 to 13.0 feet	Vertical Change	-25	5 ft	5	LF	\$75	\$375	
3150	19.8 to 38.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	96	SF	\$120	\$11,460	
52927	22.1 to 23.1 feet	Vertical Change	-27	5 ft	5	REF			
57582	23.2 to 24.2 feet	Vertical Change	2.76	5 ft	5	REF			
41188	23.3 to 24.3 feet	Vertical Change	-2.7	5 ft	5	SF	\$75	\$375	
57672	25.2 to 26.2 feet	Vertical Change	3.57	5 ft	5	REF			
45900	25.3 to 26.3 feet	Vertical Change	-.48	5 ft	5	REF			
41182	25.4 to 26.4 feet	Vertical Change	-2.98	5 ft	5	REF			
47007	34.6 to 35.6 feet	Vertical Change	-.43	5 ft	5	REF			
3152	43.9 to 47.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340	
3153	54.9 to 65.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,240	
3157	71.7 to 76.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,640	
53428	79.2 to 80.2 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
3158	87.4 to 91.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700	
52928	104.5 to 105.5 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
51588	124.0 to 125.0 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
53913	149.1 to 150.1 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375	
51589	163.9 to 164.9 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
53429	178.7 to 179.7 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
3159	181.8 to 188.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,140	
40091	187.8 to 188.8 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
53430	198.4 to 199.4 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
53431	208.3 to 209.3 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
41197	233.2 to 234.2 feet	Vertical Change	-2.45	5 ft	5	SF	\$75	\$375	
57693	242.4 to 243.4 feet	Vertical Change	3.92	5 ft	5	SF	\$75	\$375	
41167	242.6 to 243.6 feet	Vertical Change	-3.84	5 ft	5	SF	\$75	\$375	
3160	262.1 to 266.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,820	
3161	272.7 to 311.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	193	SF	\$120	\$23,220	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
W	1908211040	S FIG TREE BLVD	SIDEWALK BEGINS	S MONTGOMERY LAKE WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
53432	275.1 to 276.1 feet	Vertical Change	-.26	5 ft	5	REF			
52430	280.2 to 281.2 feet	Vertical Change	-.28	5 ft	5	REF			
53433	297.7 to 298.7 feet	Vertical Change	-.26	5 ft	5	REF			
52929	317.2 to 318.2 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
53914	324.6 to 325.6 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375	
3163	370.8 to 371.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660	
53434	384.1 to 385.1 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
52930	398.7 to 401.8 feet	Vertical Change	-.27	5 ft	16	LF	\$75	\$1,163	
3164	406.0 to 415.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,460	
56960	413.4 to 414.4 feet	Vertical Change	.56	5 ft	5	REF			
3166	441.2 to 449.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,920	
41275	453.1 to 454.1 feet	Vertical Change	-1.67	5 ft	5	SF	\$75	\$375	
57654	483.4 to 484.4 feet	Vertical Change	3.42	5 ft	5	SF	\$75	\$375	
41162	483.7 to 484.7 feet	Vertical Change	-4.45	5 ft	5	SF	\$75	\$375	
3167	485.2 to 518.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	165	SF	\$120	\$19,800	
52932	497.8 to 498.8 feet	Vertical Change	-.27	5 ft	5	REF			
41171	522.5 to 523.5 feet	Vertical Change	-3.48	5 ft	5	SF	\$75	\$375	
53915	537.2 to 538.2 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375	
56932	539.1 to 540.1 feet	Vertical Change	.53	5 ft	5	SF	\$75	\$375	
44408	539.3 to 540.3 feet	Vertical Change	-.55	5 ft	5	SF	\$75	\$375	
41280	542.6 to 543.6 feet	Vertical Change	-1.65	5 ft	5	SF	\$75	\$375	
3169	577.1 to 597.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	101	SF	\$120	\$12,120	
41172	601.3 to 602.3 feet	Vertical Change	-3.34	5 ft	5	SF	\$75	\$375	
3170	603.3 to 608.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,300	
3172	612.8 to 617.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,820	
54142	619.6 to 620.6 feet	Vertical Change	.26	5 ft	5	LF	\$75	\$375	
3173	621.8 to 625.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160	
TOTAL COST FOR: W							side of S FIG TREE BLVD Starting at: SIDEWALK BEGINS	\$117,712.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1908211046	S MONTGOMERY LAKE	S FIG TREE BLVD	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
3174	0.0 to 10.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,480	
55959	6.3 to 7.3 feet	Vertical Change	.34	5 ft	5	REF			
48721	6.4 to 7.6 feet	Vertical Change	-.37	5 ft	6	REF			
3175	13.9 to 23.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,880	
53435	15.5 to 16.5 feet	Vertical Change	-.26	5 ft	5	REF			
3176	44.6 to 46.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020	
3177	52.5 to 59.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,260	
53436	54.1 to 55.1 feet	Vertical Change	-.26	5 ft	5	REF			
3179	63.3 to 67.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340	
46555	73.5 to 74.5 feet	Vertical Change	-.45	5 ft	5	LF	\$75	\$375	
3180	121.4 to 169.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	240	SF	\$120	\$28,740	
3182	172.3 to 217.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	226	SF	\$120	\$27,060	
48722	190.2 to 191.2 feet	Vertical Change	-.37	5 ft	5	REF			
52933	199.9 to 200.9 feet	Vertical Change	-.27	5 ft	5	REF			
53437	204.8 to 205.8 feet	Vertical Change	-.26	5 ft	5	REF			
49300	213.6 to 215.2 feet	Vertical Change	-.35	5 ft	8	REF			
48998	218.6 to 222.4 feet	Vertical Change	-.36	5 ft	19	LF	\$75	\$1,425	
57695	223.6 to 224.6 feet	Vertical Change	4.25	5 ft	5	SF	\$75	\$375	
41164	223.7 to 224.7 feet	Vertical Change	-4.25	5 ft	5	SF	\$75	\$375	
3183	226.7 to 238.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,140	
51590	231.9 to 232.9 feet	Vertical Change	-.3	5 ft	5	REF			
50673	239.6 to 240.6 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
3184	246.2 to 271.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	124	SF	\$120	\$14,880	
44630	249.4 to 250.4 feet	Vertical Change	-.54	5 ft	5	REF			
53916	254.3 to 255.3 feet	Vertical Change	-.25	5 ft	5	REF			
45204	269.1 to 270.1 feet	Vertical Change	-.51	5 ft	5	REF			
49622	279.0 to 280.0 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375	
3185	318.4 to 325.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,260	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1908211046	S MONTGOMERY LAKE	S FIG TREE BLVD	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
48999	318.9 to 319.9 feet	Vertical Change	-.36	5 ft	5	REF			
49000	328.8 to 329.8 feet	Vertical Change	-.36	5 ft	5	REF			
3186	329.1 to 330.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780	
3187	337.8 to 342.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060	
50305	348.6 to 349.6 feet	Vertical Change	-.32	5 ft	5	REF			
3188	349.1 to 351.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380	
47008	358.4 to 359.4 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375	
48723	368.4 to 369.4 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375	
3189	386.3 to 388.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	11	SF	\$120	\$1,260	
52001	388.2 to 389.2 feet	Vertical Change	-.29	5 ft	5	REF			
44409	397.7 to 398.7 feet	Vertical Change	-.55	5 ft	5	SF	\$75	\$375	
46105	407.7 to 408.7 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375	
3190	412.6 to 424.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,140	
52934	417.8 to 418.8 feet	Vertical Change	-.27	5 ft	5	REF			
44831	437.8 to 438.8 feet	Vertical Change	-.53	5 ft	5	SF	\$75	\$375	
3191	447.2 to 450.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	19	SF	\$120	\$2,220	
3192	450.9 to 465.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,700	
52432	462.8 to 463.8 feet	Vertical Change	-.28	5 ft	5	REF			
52433	467.9 to 468.9 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
3194	477.9 to 492.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	71	SF	\$120	\$8,460	
51591	498.5 to 499.5 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
3195	536.2 to 556.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	100	SF	\$120	\$12,060	
3198	567.7 to 572.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,580	
53439	581.1 to 584.5 feet	Vertical Change	-.26	5 ft	17	LF	\$75	\$1,275	
53441	613.5 to 614.5 feet	Vertical Change	-.26	5 ft	5	REF			
49001	698.6 to 699.6 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375	
53442	703.5 to 704.5 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
52002	708.4 to 712.0 feet	Vertical Change	-.29	5 ft	18	LF	\$75	\$1,350	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1908211046	S MONTGOMERY LAKE	S FIG TREE BLVD	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
3199	722.8 to 732.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,060	
53444	728.3 to 729.3 feet	Vertical Change	-26	5 ft	5	REF			
3201	748.7 to 761.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,380	
53917	750.8 to 751.8 feet	Vertical Change	-25	5 ft	5	REF			
3202	765.3 to 776.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	57	SF	\$120	\$6,780	
53445	768.5 to 769.5 feet	Vertical Change	-26	5 ft	5	REF			
3203	777.9 to 858.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	402	SF	\$120	\$48,180	
52935	778.3 to 781.9 feet	Vertical Change	-27	5 ft	18	REF			
52936	788.8 to 789.8 feet	Vertical Change	-27	5 ft	5	REF			
53919	801.5 to 802.5 feet	Vertical Change	-25	5 ft	5	REF			
53446	827.7 to 828.7 feet	Vertical Change	-26	5 ft	5	REF			
52937	835.3 to 838.8 feet	Vertical Change	-27	5 ft	18	REF			
53447	850.6 to 859.5 feet	Vertical Change	-26	5 ft	45	REF			
3208	872.3 to 877.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,240	
3209	888.7 to 893.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,940	
3210	895.7 to 906.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,300	
52939	897.2 to 898.2 feet	Vertical Change	-27	5 ft	5	REF			
3211	913.8 to 956.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	215	SF	\$120	\$25,740	
52940	915.4 to 916.4 feet	Vertical Change	-27	5 ft	5	REF			
53448	931.1 to 932.1 feet	Vertical Change	-26	5 ft	5	REF			
50306	938.9 to 939.9 feet	Vertical Change	-32	5 ft	5	REF			
53449	943.6 to 944.6 feet	Vertical Change	-26	5 ft	5	REF			
50307	955.3 to 956.3 feet	Vertical Change	-32	5 ft	5	REF			
53923	980.1 to 981.1 feet	Vertical Change	-25	5 ft	5	LF	\$75	\$375	
3214	983.2 to 989.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,540	
3215	993.0 to 1000.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,380	
3218	1033.7 to 1035.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960	
53450	1039.6 to 1040.6 feet	Vertical Change	-26	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1908211046	S MONTGOMERY LAKE	S FIG TREE BLVD	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
41166	1066.0 to 1067.0 feet	Vertical Change	-3.86	5 ft	5	SF	\$75	\$375	
57692	1066.0 to 1067.0 feet	Vertical Change	3.9	5 ft	5	SF	\$75	\$375	
3219	1081.0 to 1087.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,600	
3220	1091.7 to 1094.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440	
3221	1098.3 to 1123.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	126	SF	\$120	\$15,180	
50674	1099.3 to 1100.3 feet	Vertical Change	-.31	5 ft	5	REF			
41205	1103.0 to 1104.0 feet	Vertical Change	-2.37	5 ft	5	REF			
51592	1111.5 to 1114.8 feet	Vertical Change	-.3	5 ft	17	REF			
52435	1121.1 to 1124.6 feet	Vertical Change	-.28	5 ft	18	REF			
52941	1128.5 to 1129.5 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
3224	1137.5 to 1139.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200	
3225	1153.3 to 1154.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660	
3226	1165.8 to 1166.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660	
3227	1181.2 to 1191.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,420	
3228	1194.7 to 1197.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,740	
3229	1204.4 to 1207.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680	
52003	1215.1 to 1216.1 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
55953	1215.1 to 1216.1 feet	Vertical Change	.33	5 ft	5	LF	\$75	\$375	
48724	1215.2 to 1216.2 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375	
57557	1220.2 to 1221.2 feet	Vertical Change	2.3	5 ft	5	SF	\$75	\$375	
41206	1220.3 to 1221.3 feet	Vertical Change	-2.37	5 ft	5	SF	\$75	\$375	
57515	1221.9 to 1222.9 feet	Vertical Change	1.89	5 ft	5	SF	\$75	\$375	
41259	1222.1 to 1223.1 feet	Vertical Change	-1.77	5 ft	5	SF	\$75	\$375	
3230	1239.4 to 1257.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	89	SF	\$120	\$10,740	
52942	1242.9 to 1243.9 feet	Vertical Change	-.27	5 ft	5	REF			
3233	1260.7 to 1280.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	99	SF	\$120	\$11,880	
51593	1263.8 to 1264.8 feet	Vertical Change	-.3	5 ft	5	REF			
3236	1283.7 to 1308.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	124	SF	\$120	\$14,940	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1908211046	S MONTGOMERY LAKE	S FIG TREE BLVD	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
52004	1304.9 to 1305.9 feet	Vertical Change	-.29	5 ft	5	REF		
52943	1332.2 to 1333.2 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
48725	1335.5 to 1336.5 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375
3241	1342.6 to 1347.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,640
3242	1351.3 to 1354.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,100
3243	1365.0 to 1374.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,460
3245	1378.7 to 1386.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,920
3247	1386.9 to 1390.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	17	SF	\$120	\$2,040
53925	1389.3 to 1390.3 feet	Vertical Change	-.25	5 ft	5	REF		
3250	1391.3 to 1402.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,840
3252	1418.5 to 1420.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960
3253	1423.5 to 1462.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	194	SF	\$120	\$23,220
49956	1452.3 to 1453.3 feet	Vertical Change	-.33	5 ft	5	REF		
3257	1472.8 to 1485.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,800
47911	1478.1 to 1479.1 feet	Vertical Change	-.4	5 ft	5	REF		
52944	1485.0 to 1486.0 feet	Vertical Change	-.27	5 ft	5	REF		
3259	1488.2 to 1501.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	69	SF	\$120	\$8,220
3262	1507.7 to 1528.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	103	SF	\$120	\$12,300
3264	1536.2 to 1541.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060

TOTAL COST FOR: NE side of S MONTGOMERY LAKE Starting at: S FIG TREE BLVD \$429,450.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1908211051	S MONTGOMERY LAKE	S GENOA LAKE WAY	SAVE MART PHARMACY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
43562	2.4 to 6.4 feet	Vertical Change	-.6	5 ft	20	SF	\$75	\$1,500	
3266	15.9 to 20.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,880	
3267	22.8 to 26.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220	
52436	32.0 to 33.0 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
3269	33.3 to 48.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	78	SF	\$120	\$9,300	
44832	35.4 to 36.4 feet	Vertical Change	-.53	5 ft	5	REF			
3270	51.1 to 58.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,680	
3271	82.6 to 93.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,600	
3272	127.8 to 141.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	70	SF	\$120	\$8,400	
3273	147.3 to 158.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,540	
3274	174.1 to 214.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	203	SF	\$120	\$24,360	
3278	217.5 to 220.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040	
3279	232.3 to 234.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200	
3280	238.3 to 240.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200	
3281	243.9 to 245.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660	
3282	247.2 to 250.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160	
3283	261.2 to 264.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800	
52437	294.7 to 295.7 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
48437	299.1 to 300.7 feet	Vertical Change	-.38	5 ft	8	LF	\$75	\$600	
45205	303.1 to 304.1 feet	Vertical Change	-.51	5 ft	5	SF	\$75	\$375	
3284	308.9 to 310.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840	
3285	324.8 to 327.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800	
3286	334.7 to 338.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040	
3287	354.2 to 356.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440	
3288	366.2 to 369.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220	
3289	416.5 to 422.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,540	
3290	433.4 to 437.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340	
51595	435.8 to 436.8 feet	Vertical Change	-.3	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1908211051	S MONTGOMERY LAKE	S GENOA LAKE WAY	SAVE MART PHARMACY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
3291	442.6 to 452.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,880
3292	483.6 to 484.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720
51596	495.2 to 496.2 feet	Vertical Change	-3	5 ft	5	LF	\$75	\$375
3293	525.4 to 527.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
3294	561.3 to 563.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440
3295	573.4 to 579.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,420
3296	586.8 to 598.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,960
3297	622.8 to 626.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400
3298	674.8 to 677.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440
3299	680.8 to 702.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	110	SF	\$120	\$13,140
3301	706.5 to 712.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,480
3303	715.8 to 718.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740
48438	750.7 to 751.7 feet	Vertical Change	-38	5 ft	5	LF	\$75	\$375
3304	754.3 to 763.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,640
53452	761.4 to 762.4 feet	Vertical Change	-26	5 ft	5	REF		
3305	769.1 to 776.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,200
3306	779.2 to 782.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800
3307	788.7 to 792.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,280
3308	837.2 to 840.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860
3309	844.8 to 851.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,900
3310	867.3 to 869.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260
3311	894.6 to 902.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,740
3312	910.8 to 913.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800
3313	923.7 to 927.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,280
3314	963.9 to 989.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	130	SF	\$120	\$15,600
48158	983.8 to 984.8 feet	Vertical Change	-39	5 ft	5	REF		
TOTAL COST FOR:		NE	<i>side of</i> S MONTGOMERY LAKE	<i>Starting at:</i> S GENOA LAKE WAY				\$179,295.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	1908211100	S MONTGOMERY LAKE	SIDEWALK BEGINS	S GENOA LAKE WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
52439	9.1 to 10.1 feet	Vertical Change	-.28	8 ft	8	LF	\$75	\$563	
52440	16.2 to 17.2 feet	Vertical Change	-.28	8 ft	8	LF	\$75	\$563	
53453	23.7 to 24.7 feet	Vertical Change	-.26	8 ft	8	LF	\$75	\$563	
52441	28.8 to 29.8 feet	Vertical Change	-.28	8 ft	8	LF	\$75	\$563	
52005	33.6 to 39.6 feet	Vertical Change	-.29	8 ft	45	LF	\$75	\$3,375	
50675	43.6 to 49.8 feet	Vertical Change	-.31	8 ft	47	REF			
3318	43.6 to 47.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	28	SF	\$120	\$3,330	
52006	56.0 to 59.5 feet	Vertical Change	-.29	8 ft	26	LF	\$75	\$1,969	
3319	57.6 to 62.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	38	SF	\$120	\$4,500	
52007	63.7 to 69.6 feet	Vertical Change	-.29	8 ft	44	LF	\$75	\$3,319	
3320	72.3 to 86.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	108	SF	\$120	\$12,960	
53455	73.5 to 74.5 feet	Vertical Change	-.26	8 ft	8	REF			
53926	78.5 to 79.5 feet	Vertical Change	-.25	8 ft	8	REF			
3321	92.0 to 100.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	66	SF	\$120	\$7,920	
3322	104.7 to 109.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	34	SF	\$120	\$4,050	
52946	115.5 to 119.1 feet	Vertical Change	-.27	8 ft	27	LF	\$75	\$2,025	
3323	119.8 to 125.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	41	SF	\$120	\$4,950	
52446	123.2 to 126.8 feet	Vertical Change	-.28	8 ft	27	REF			
3324	129.6 to 140.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	84	SF	\$120	\$10,080	
51598	135.9 to 136.9 feet	Vertical Change	-.3	8 ft	8	REF			
53927	143.4 to 144.4 feet	Vertical Change	-.25	8 ft	8	LF	\$75	\$563	
3325	148.0 to 159.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	84	SF	\$120	\$10,080	
3326	178.3 to 184.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	47	SF	\$120	\$5,670	
3327	186.7 to 189.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	24	SF	\$120	\$2,880	
57230	190.0 to 191.0 feet	Vertical Change	.71	8 ft	8	SF	\$75	\$563	
3328	192.9 to 227.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	258	SF	\$120	\$30,960	
3329	231.9 to 236.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	32	SF	\$120	\$3,780	
3330	279.6 to 285.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	43	SF	\$120	\$5,220	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SW	1908211100	S MONTGOMERY LAKE	SIDEWALK BEGINS	S GENOA LAKE WAY	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
52009	291.0 to 292.0 feet	Vertical Change	-.29	8 ft	8	LF	\$75	\$563	
3331	296.0 to 311.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	119	SF	\$120	\$14,220	
3332	323.5 to 334.0 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	79	SF	\$120	\$9,450	
3333	337.7 to 339.0 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	10	SF	\$120	\$1,170	
3334	354.1 to 360.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	51	SF	\$120	\$6,120	
3335	375.6 to 395.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	148	SF	\$120	\$17,730	
3336	397.5 to 416.0 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	139	SF	\$120	\$16,650	
3337	418.4 to 471.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	397	SF	\$120	\$47,610	
48159	478.6 to 479.6 feet	Vertical Change	-.39	8 ft	8	LF	\$75	\$563	
3341	484.6 to 492.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	59	SF	\$120	\$7,020	
50676	488.6 to 489.6 feet	Vertical Change	-.31	8 ft	8	REF			
49002	498.5 to 499.5 feet	Vertical Change	-.36	8 ft	8	LF	\$75	\$563	
3342	522.8 to 543.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	158	SF	\$120	\$18,990	
3343	546.1 to 561.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	118	SF	\$120	\$14,130	
3345	565.2 to 615.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	379	SF	\$120	\$45,450	
52447	597.2 to 598.2 feet	Vertical Change	-.28	8 ft	8	REF			
3347	623.5 to 745.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	913	SF	\$120	\$109,530	
52010	685.9 to 686.9 feet	Vertical Change	-.29	8 ft	8	REF			
47245	689.2 to 690.2 feet	Vertical Change	-.42	8 ft	8	REF			
49003	705.4 to 706.4 feet	Vertical Change	-.36	8 ft	8	REF			
3354	748.3 to 765.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	132	SF	\$120	\$15,840	
53456	752.9 to 753.9 feet	Vertical Change	-.26	8 ft	8	REF			
3355	769.8 to 773.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	26	SF	\$120	\$3,150	
3356	776.8 to 787.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	82	SF	\$120	\$9,810	
3357	798.7 to 806.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	62	SF	\$120	\$7,380	
52011	804.6 to 805.6 feet	Vertical Change	-.29	8 ft	8	REF			
3359	815.9 to 841.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	191	SF	\$120	\$22,950	
48160	953.5 to 954.5 feet	Vertical Change	-.39	8 ft	8	LF	\$75	\$563	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1908211100	S MONTGOMERY LAKE	SIDEWALK BEGINS	S GENOA LAKE WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46556	958.5 to 959.5 feet	Vertical Change	-.45	8 ft	8	LF	\$75	\$563
53928	968.0 to 969.0 feet	Vertical Change	-.25	8 ft	8	LF	\$75	\$563
52448	981.6 to 983.0 feet	Vertical Change	-.28	8 ft	11	LF	\$75	\$788
3362	984.0 to 985.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	13	SF	\$120	\$1,530
TOTAL COST FOR: SW side of S MONTGOMERY LAKE Starting at: SIDEWALK BEGINS							\$493,335.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	1908211103	S MONTGOMERY LAKE	S GENOA LAKE WAY	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
3363	27.0 to 36.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	69	SF	\$120	\$8,280	
3364	50.8 to 60.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	71	SF	\$120	\$8,550	
52450	52.8 to 53.8 feet	Vertical Change	-28	8 ft	8	REF			
53458	60.3 to 63.8 feet	Vertical Change	-26	8 ft	26	REF			
3365	65.4 to 89.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	183	SF	\$120	\$21,960	
52949	72.7 to 78.6 feet	Vertical Change	-27	8 ft	44	REF			
48439	85.1 to 86.1 feet	Vertical Change	-38	8 ft	8	REF			
48726	89.6 to 90.6 feet	Vertical Change	-37	8 ft	8	REF			
49004	98.5 to 99.5 feet	Vertical Change	-36	8 ft	8	LF	\$75	\$563	
3367	100.7 to 102.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	15	SF	\$120	\$1,800	
52451	105.9 to 106.9 feet	Vertical Change	-28	8 ft	8	REF			
3368	106.2 to 108.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	15	SF	\$120	\$1,800	
3369	122.8 to 128.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	44	SF	\$120	\$5,220	
48161	124.1 to 125.1 feet	Vertical Change	-39	8 ft	8	REF			
3370	132.6 to 146.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	104	SF	\$120	\$12,510	
52452	132.7 to 133.7 feet	Vertical Change	-28	8 ft	8	REF			
3371	151.0 to 160.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	69	SF	\$120	\$8,280	
52951	162.4 to 165.8 feet	Vertical Change	-27	8 ft	26	LF	\$75	\$1,913	
53460	194.5 to 195.5 feet	Vertical Change	-26	8 ft	8	LF	\$75	\$563	
3372	204.3 to 226.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	169	SF	\$120	\$20,250	
48727	204.5 to 205.5 feet	Vertical Change	-37	8 ft	8	REF			
52454	214.8 to 215.8 feet	Vertical Change	-28	8 ft	8	REF			
3373	234.8 to 235.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	8	SF	\$120	\$990	
3374	239.2 to 400.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	1211	SF	\$120	\$145,260	
53929	256.9 to 260.4 feet	Vertical Change	-25	8 ft	26	REF			
52455	321.3 to 324.5 feet	Vertical Change	-28	8 ft	24	REF			
52953	335.9 to 336.9 feet	Vertical Change	-27	8 ft	8	REF			
52954	348.5 to 349.5 feet	Vertical Change	-27	8 ft	8	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1908211103	S MONTGOMERY LAKE	S GENOA LAKE WAY	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57476	392.7 to 393.7 feet	Vertical Change	1.51	8 ft	8	REF		
41431	392.9 to 393.9 feet	Vertical Change	-1.2	8 ft	8	REF		
3379	407.2 to 413.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	47	SF	\$120	\$5,580
52955	408.0 to 411.5 feet	Vertical Change	-.27	8 ft	26	REF		
51600	418.0 to 419.0 feet	Vertical Change	-.3	8 ft	8	LF	\$75	\$563
3380	422.7 to 426.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	27	SF	\$120	\$3,240
52456	427.9 to 431.4 feet	Vertical Change	-.28	8 ft	26	LF	\$75	\$1,969
3381	433.7 to 436.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	21	SF	\$120	\$2,520
49301	442.6 to 443.6 feet	Vertical Change	-.35	8 ft	8	LF	\$75	\$563
3382	444.0 to 449.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	39	SF	\$120	\$4,680
3383	452.7 to 485.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	244	SF	\$120	\$29,250
53462	462.5 to 463.5 feet	Vertical Change	-.26	8 ft	8	REF		
53463	470.0 to 471.0 feet	Vertical Change	-.26	8 ft	8	REF		
53464	477.1 to 478.1 feet	Vertical Change	-.26	8 ft	8	REF		
49302	482.2 to 486.2 feet	Vertical Change	-.35	8 ft	30	REF		
3386	493.9 to 500.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	53	SF	\$120	\$6,300
48728	494.0 to 495.0 feet	Vertical Change	-.37	8 ft	8	REF		
3387	506.0 to 512.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	52	SF	\$120	\$6,210
52457	515.3 to 516.3 feet	Vertical Change	-.28	8 ft	8	LF	\$75	\$563
3388	525.5 to 529.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	28	SF	\$120	\$3,420
3389	532.4 to 544.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	88	SF	\$120	\$10,530
53465	540.2 to 541.2 feet	Vertical Change	-.26	8 ft	8	REF		
53931	557.7 to 558.7 feet	Vertical Change	-.25	8 ft	8	REF		
3390	558.6 to 573.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	115	SF	\$120	\$13,770
53466	562.7 to 563.7 feet	Vertical Change	-.26	8 ft	8	REF		
3391	580.4 to 596.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	119	SF	\$120	\$14,310
3393	619.9 to 627.1 feet	Cross Slope (Driveway)	2.0-3.0%	8 ft	54	SF	\$40	\$2,160
3394	630.6 to 633.8 feet	Cross Slope (Driveway)	2.0-3.0%	8 ft	24	SF	\$40	\$960

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1908211103	S MONTGOMERY LAKE	S GENOA LAKE WAY	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
52458	634.5 to 635.5 feet	Vertical Change	-.28	8 ft	8	REF		
3395	638.7 to 675.6 feet	Cross Slope (Driveway)	2.0-3.0%	8 ft	277	SF	\$40	\$11,070
3396	725.4 to 726.9 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	11	SF	\$120	\$1,350
53932	731.5 to 732.5 feet	Vertical Change	-.25	8 ft	8	LF	\$75	\$563
3397	739.8 to 744.0 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	32	SF	\$120	\$3,780
3398	757.3 to 770.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	96	SF	\$120	\$11,520
TOTAL COST FOR: SW side of S MONTGOMERY LAKE Starting at: S GENOA LAKE WAY							\$372,806.25	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	1908211104	S MONTGOMERY LAKE	SIDEWALK BEGINS	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
50308	4.4 to 5.4 feet	Vertical Change	-.32	8 ft	7	LF	\$75	\$563	
49957	11.9 to 12.9 feet	Vertical Change	-.33	8 ft	8	LF	\$75	\$563	
3400	72.0 to 78.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	49	SF	\$120	\$5,850	
52956	80.6 to 81.6 feet	Vertical Change	-.27	8 ft	8	LF	\$75	\$563	
3401	94.8 to 97.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	19	SF	\$120	\$2,250	
3402	128.3 to 129.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	8	SF	\$120	\$900	
3403	136.0 to 141.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	41	SF	\$120	\$4,950	
41329	140.0 to 141.0 feet	Vertical Change	-1.46	8 ft	8	REF			
47246	143.0 to 144.0 feet	Vertical Change	-.42	8 ft	8	LF	\$75	\$563	
50677	147.8 to 149.0 feet	Vertical Change	-.31	8 ft	9	LF	\$75	\$675	
3404	149.5 to 163.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	107	SF	\$120	\$12,870	
49005	160.4 to 161.4 feet	Vertical Change	-.36	8 ft	8	REF			
49958	168.2 to 169.2 feet	Vertical Change	-.33	8 ft	8	LF	\$75	\$563	
3406	171.8 to 174.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	20	SF	\$120	\$2,340	
TOTAL COST FOR: SW side of S MONTGOMERY LAKE Starting at: SIDEWALK BEGINS								\$32,647.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211121	AVE 26	S FIG TREE BLVD	W GOLF DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
53467	1.2 to 2.2 feet	Vertical Change	-.26	5 ft	5	REF		
3407	1.2 to 33.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	161	SF	\$120	\$19,320
45016	12.1 to 13.1 feet	Vertical Change	-.52	5 ft	5	REF		
47912	21.9 to 22.9 feet	Vertical Change	-.4	5 ft	5	REF		
47499	31.8 to 32.8 feet	Vertical Change	-.41	5 ft	5	REF		
41394	41.6 to 42.6 feet	Vertical Change	-1.28	5 ft	5	SF	\$75	\$375
3411	54.9 to 59.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520
47247	61.5 to 62.5 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375
46106	71.4 to 72.4 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375
42079	81.3 to 82.3 feet	Vertical Change	-.75	5 ft	5	SF	\$75	\$375
44202	86.7 to 87.7 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375
48162	91.4 to 92.4 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375
3413	92.5 to 94.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200
50679	99.5 to 100.5 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375
3414	102.2 to 103.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660
49623	107.4 to 108.4 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375
3415	111.3 to 138.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	138	SF	\$120	\$16,500
41308	115.6 to 116.6 feet	Vertical Change	-1.54	5 ft	5	REF		
57507	115.7 to 116.7 feet	Vertical Change	1.72	5 ft	5	REF		
42224	121.3 to 122.3 feet	Vertical Change	-.72	5 ft	5	REF		
43702	125.5 to 126.5 feet	Vertical Change	-.59	5 ft	5	REF		
52012	131.6 to 132.6 feet	Vertical Change	-.29	5 ft	5	REF		
41262	136.3 to 137.3 feet	Vertical Change	-1.75	5 ft	5	REF		
57908	136.7 to 178.8 feet	Driveway				REF		
50309	140.1 to 141.1 feet	Vertical Change	-.32	5 ft	5	REF		
42549	143.1 to 144.1 feet	Vertical Change	-.68	5 ft	5	REF		
3416	144.9 to 149.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	24	SF	\$40	\$960
3417	149.7 to 172.9 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	116	SF	\$40	\$4,640

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211121	AVE 26	S FIG TREE BLVD	W GOLF DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
45206	153.4 to 154.4 feet	Vertical Change	-.51	5 ft	5	REF		
43854	163.3 to 164.3 feet	Vertical Change	-.58	5 ft	5	REF		
40096	173.0 to 174.0 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
50680	173.2 to 177.2 feet	Vertical Change	-.31	5 ft	20	REF		
3421	174.3 to 175.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	5	SF	\$40	\$200
41236	179.9 to 180.9 feet	Vertical Change	-1.95	5 ft	5	SF	\$75	\$375
51601	194.7 to 195.7 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375
42036	214.5 to 215.5 feet	Vertical Change	-.76	5 ft	5	SF	\$75	\$375
47500	224.5 to 225.5 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375
49959	234.4 to 235.4 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375
3422	240.3 to 245.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,240
53468	244.2 to 245.2 feet	Vertical Change	-.26	5 ft	5	REF		
3423	248.9 to 254.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,360
49303	263.9 to 264.9 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$375
3424	266.4 to 283.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,260
47249	273.8 to 274.8 feet	Vertical Change	-.42	5 ft	5	REF		
47250	293.6 to 294.6 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375
44833	303.5 to 304.5 feet	Vertical Change	-.53	5 ft	5	SF	\$75	\$375
3425	313.7 to 324.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,420
57909	320.0 to 363.5 feet	Driveway				REF		
41320	322.0 to 323.0 feet	Vertical Change	-1.49	5 ft	5	REF		
47010	325.9 to 329.9 feet	Vertical Change	-.43	5 ft	20	REF		
3426	327.9 to 329.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	8	SF	\$40	\$300
3427	330.0 to 334.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	22	SF	\$40	\$880
3429	334.4 to 352.7 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	92	SF	\$40	\$3,660
50681	339.1 to 340.1 feet	Vertical Change	-.31	5 ft	5	REF		
52957	349.1 to 350.1 feet	Vertical Change	-.27	5 ft	5	REF		
3433	352.7 to 358.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	30	SF	\$40	\$1,200

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
S	1908211121	AVE 26	S FIG TREE BLVD	W GOLF DR	TBD				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
49960	359.1 to 360.1 feet	Vertical Change	-.33	5 ft	5	REF			
40097	359.2 to 361.3 feet	Running Slope	6.0-7.0%	5 ft	11	REF			
3434	359.4 to 361.1 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	9	SF	\$40	\$340	
41600	365.5 to 366.5 feet	Vertical Change	-.98	5 ft	5	SF	\$75	\$375	
3435	367.9 to 373.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,360	
49304	368.7 to 369.7 feet	Vertical Change	-.35	5 ft	5	REF			
50682	372.7 to 373.7 feet	Vertical Change	-.31	5 ft	5	REF			
41934	376.4 to 377.4 feet	Vertical Change	-.79	5 ft	5	SF	\$75	\$375	
3436	382.0 to 386.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700	
44203	384.3 to 385.3 feet	Vertical Change	-.56	5 ft	5	REF			
41345	392.4 to 393.4 feet	Vertical Change	-1.4	5 ft	5	SF	\$75	\$375	
44631	402.6 to 403.6 feet	Vertical Change	-.54	5 ft	5	SF	\$75	\$375	
42877	412.3 to 413.3 feet	Vertical Change	-.65	5 ft	5	SF	\$75	\$375	
45017	422.4 to 423.4 feet	Vertical Change	-.52	5 ft	5	SF	\$75	\$375	
49305	432.3 to 433.3 feet	Vertical Change	-.35	5 ft	5	REF			
3437	432.3 to 434.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440	
42225	442.2 to 443.2 feet	Vertical Change	-.72	5 ft	5	SF	\$75	\$375	
3438	447.6 to 454.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,260	
46802	452.1 to 453.1 feet	Vertical Change	-.44	5 ft	5	REF			
3439	457.1 to 464.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,440	
41588	461.8 to 462.8 feet	Vertical Change	-.99	5 ft	5	REF			
3440	470.5 to 578.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	539	SF	\$120	\$64,620	
41738	471.7 to 472.7 feet	Vertical Change	-.87	5 ft	5	REF			
42007	481.7 to 482.7 feet	Vertical Change	-.77	5 ft	5	REF			
46334	511.3 to 512.3 feet	Vertical Change	-.46	5 ft	5	REF			
47251	531.2 to 532.2 feet	Vertical Change	-.42	5 ft	5	REF			
42550	540.8 to 541.8 feet	Vertical Change	-.68	5 ft	5	REF			
46335	550.6 to 551.6 feet	Vertical Change	-.46	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211121	AVE 26	S FIG TREE BLVD	W GOLF DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46803	560.5 to 561.5 feet	Vertical Change	-.44	5 ft	5	REF		
50683	570.7 to 571.7 feet	Vertical Change	-.31	5 ft	5	REF		
45901	574.4 to 575.4 feet	Vertical Change	-.48	5 ft	5	REF		
47913	580.4 to 583.2 feet	Vertical Change	-.4	5 ft	14	LF	\$75	\$1,050
45698	588.6 to 589.6 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$375
3447	591.1 to 601.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$5,940
50310	596.0 to 597.0 feet	Vertical Change	-.32	5 ft	5	REF		
3449	601.0 to 604.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	20	SF	\$120	\$2,340
3451	604.9 to 609.2 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	22	SF	\$120	\$2,580
44026	606.2 to 607.2 feet	Vertical Change	-.57	5 ft	5	REF		
3452	609.2 to 611.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	13	SF	\$120	\$1,560
52958	610.0 to 612.3 feet	Vertical Change	-.27	5 ft	11	REF		
3454	611.8 to 613.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$900
3455	613.3 to 620.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320
47914	618.9 to 619.9 feet	Vertical Change	-.4	5 ft	5	REF		
TOTAL COST FOR: S							side of AVE 26 Starting at: S FIG TREE BLVD	\$184,170.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908211129	W GOLF DR	AVE 26	PRIVATE ROAD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
3456	5.8 to 14.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,920	
52959	10.7 to 11.7 feet	Vertical Change	-27	5 ft	5	REF			
3458	14.0 to 63.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	246	SF	\$120	\$29,520	
46804	20.1 to 21.1 feet	Vertical Change	-44	5 ft	5	REF			
47501	30.5 to 31.5 feet	Vertical Change	-41	5 ft	5	REF			
46557	40.8 to 41.8 feet	Vertical Change	-45	5 ft	5	REF			
52459	53.3 to 54.3 feet	Vertical Change	-28	5 ft	5	REF			
47915	60.9 to 61.9 feet	Vertical Change	-4	5 ft	5	REF			
3464	63.2 to 110.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	236	SF	\$120	\$28,320	
49007	70.8 to 71.8 feet	Vertical Change	-36	5 ft	5	REF			
42278	80.9 to 81.9 feet	Vertical Change	-71	5 ft	5	REF			
49624	101.5 to 102.5 feet	Vertical Change	-34	5 ft	5	REF			
49306	111.3 to 112.3 feet	Vertical Change	-35	5 ft	5	LF	\$75	\$375	
3469	119.8 to 142.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	112	SF	\$120	\$13,380	
49961	121.7 to 122.7 feet	Vertical Change	-33	5 ft	5	REF			
48440	131.8 to 132.8 feet	Vertical Change	-38	5 ft	5	REF			
51602	142.1 to 143.1 feet	Vertical Change	-3	5 ft	5	REF			
3474	146.6 to 193.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	234	SF	\$120	\$28,020	
47011	152.0 to 153.0 feet	Vertical Change	-43	5 ft	5	REF			
47012	162.2 to 163.2 feet	Vertical Change	-43	5 ft	5	REF			
45700	172.4 to 173.4 feet	Vertical Change	-49	5 ft	5	REF			
41694	182.7 to 183.7 feet	Vertical Change	-9	5 ft	5	REF			
49625	193.0 to 194.0 feet	Vertical Change	-34	5 ft	5	REF			
3482	197.3 to 230.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	166	SF	\$120	\$19,860	
41578	203.5 to 204.5 feet	Vertical Change	-1	5 ft	5	REF			
45207	214.0 to 215.0 feet	Vertical Change	-51	5 ft	5	REF			
47916	219.9 to 220.9 feet	Vertical Change	-4	5 ft	5	REF			
52013	223.9 to 224.9 feet	Vertical Change	-29	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908211129	W GOLF DR	AVE 26	PRIVATE ROAD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
TOTAL COST FOR: W								\$124,395.00

side of W GOLF DR Starting at: AVE 26

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211135	AVE 26	W GOLF DR	W GOLF DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41701	18.2 to 19.2 feet	Vertical Change	-.89	5 ft	5	SF	\$75	\$375
41398	25.8 to 26.8 feet	Vertical Change	-1.27	5 ft	5	SF	\$75	\$375
TOTAL COST FOR: S							<i>side of AVE 26 Starting at: W GOLF DR</i>	\$750.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908211141	W GOLF DR	PRIVATE ROAD	AVE 26	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
53469	6.5 to 7.5 feet	Vertical Change	-.26	5 ft	5	REF		
3483	6.5 to 55.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	244	SF	\$120	\$29,280
49307	14.2 to 15.2 feet	Vertical Change	-.35	5 ft	5	REF		
56633	14.2 to 15.2 feet	Vertical Change	.46	5 ft	5	REF		
49626	21.8 to 22.8 feet	Vertical Change	-.34	5 ft	5	REF		
46558	52.5 to 53.5 feet	Vertical Change	-.45	5 ft	5	REF		
3487	55.3 to 144.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	448	SF	\$120	\$53,700
48441	72.1 to 73.1 feet	Vertical Change	-.38	5 ft	5	REF		
50684	81.9 to 82.9 feet	Vertical Change	-.31	5 ft	5	REF		
50685	96.8 to 97.8 feet	Vertical Change	-.31	5 ft	5	REF		
45701	112.0 to 113.0 feet	Vertical Change	-.49	5 ft	5	REF		
49308	121.5 to 122.5 feet	Vertical Change	-.35	5 ft	5	REF		
47502	129.9 to 130.9 feet	Vertical Change	-.41	5 ft	5	REF		
47013	138.5 to 139.5 feet	Vertical Change	-.43	5 ft	5	REF		
TOTAL COST FOR: E							<i>side of W GOLF DR Starting at: PRIVATE ROAD</i>	\$82,980.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908211146	AVE 26	W GOLF DR	CLUBHOUSE DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
3496	0.0 to 9.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,580	
50686	7.9 to 8.9 feet	Vertical Change	-.31	5 ft	5	REF			
3498	9.3 to 26.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	84	SF	\$120	\$10,140	
49309	17.2 to 18.2 feet	Vertical Change	-.35	5 ft	5	REF			
52014	21.0 to 22.0 feet	Vertical Change	-.29	5 ft	5	REF			
50311	25.6 to 26.6 feet	Vertical Change	-.32	5 ft	5	REF			
3504	26.2 to 49.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	119	SF	\$120	\$14,220	
46107	36.8 to 37.8 feet	Vertical Change	-.47	5 ft	5	REF			
49627	45.5 to 46.5 feet	Vertical Change	-.34	5 ft	5	REF			
3508	49.9 to 83.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	170	SF	\$120	\$20,340	
50312	55.1 to 56.1 feet	Vertical Change	-.32	5 ft	5	REF			
3512	83.8 to 109.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	127	SF	\$120	\$15,240	
48729	84.8 to 85.8 feet	Vertical Change	-.37	5 ft	5	REF			
48442	94.4 to 95.4 feet	Vertical Change	-.38	5 ft	5	REF			
48730	103.9 to 104.9 feet	Vertical Change	-.37	5 ft	5	REF			
3513	111.4 to 211.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	501	SF	\$120	\$60,120	
46108	112.6 to 113.6 feet	Vertical Change	-.47	5 ft	5	REF			
50687	121.4 to 122.4 feet	Vertical Change	-.31	5 ft	5	REF			
42760	122.6 to 123.6 feet	Vertical Change	-.66	5 ft	5	REF			
48443	132.1 to 133.1 feet	Vertical Change	-.38	5 ft	5	REF			
46559	151.2 to 152.2 feet	Vertical Change	-.45	5 ft	5	REF			
46109	175.9 to 176.9 feet	Vertical Change	-.47	5 ft	5	REF			
46805	180.8 to 181.8 feet	Vertical Change	-.44	5 ft	5	REF			
57127	190.5 to 191.5 feet	Vertical Change	.61	5 ft	5	REF			
52015	200.4 to 201.4 feet	Vertical Change	-.29	5 ft	5	REF			
3522	211.6 to 237.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	129	SF	\$120	\$15,420	
47252	213.8 to 214.8 feet	Vertical Change	-.42	5 ft	5	REF			
52960	219.9 to 220.9 feet	Vertical Change	-.27	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908211146	AVE 26	W GOLF DR	CLUBHOUSE DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
49310	229.4 to 230.4 feet	Vertical Change	-.35	5 ft	5	REF			
46806	236.1 to 237.1 feet	Vertical Change	-.44	5 ft	5	REF			
3524	237.3 to 250.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,100	
46110	243.6 to 244.6 feet	Vertical Change	-.47	5 ft	5	REF			
47917	248.6 to 249.6 feet	Vertical Change	-.4	5 ft	5	REF			
3525	269.3 to 271.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380	
3526	274.7 to 349.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	373	SF	\$120	\$44,760	
49008	277.6 to 278.6 feet	Vertical Change	-.36	5 ft	5	REF			
49962	315.7 to 316.7 feet	Vertical Change	-.33	5 ft	5	REF			
3536	349.3 to 371.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	111	SF	\$120	\$13,260	
3540	371.4 to 458.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	434	SF	\$120	\$52,080	
47918	385.1 to 386.1 feet	Vertical Change	-.4	5 ft	5	REF			
53470	424.2 to 425.2 feet	Vertical Change	-.26	5 ft	5	REF			
53933	492.9 to 493.9 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375	
3561	498.3 to 584.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	430	SF	\$120	\$51,540	
52961	522.2 to 523.2 feet	Vertical Change	-.27	5 ft	5	REF			
50313	542.0 to 543.0 feet	Vertical Change	-.32	5 ft	5	REF			
49963	552.0 to 553.0 feet	Vertical Change	-.33	5 ft	5	REF			
52460	561.6 to 562.6 feet	Vertical Change	-.28	5 ft	5	REF			
53471	571.4 to 572.4 feet	Vertical Change	-.26	5 ft	5	REF			
49311	582.8 to 583.8 feet	Vertical Change	-.35	5 ft	5	REF			
3572	584.2 to 587.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	18	SF	\$120	\$2,100	
3574	587.7 to 604.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	83	SF	\$120	\$9,960	
53934	590.7 to 591.7 feet	Vertical Change	-.25	5 ft	5	REF			
53935	600.4 to 601.4 feet	Vertical Change	-.25	5 ft	5	REF			
54132	600.5 to 601.5 feet	Vertical Change	.25	5 ft	5	REF			
53472	620.1 to 621.1 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
3579	624.5 to 628.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,280	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211146	AVE 26	W GOLF DR	CLUBHOUSE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
3580	631.0 to 634.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160
3581	637.3 to 683.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	232	SF	\$120	\$27,780
50314	639.4 to 640.4 feet	Vertical Change	-32	5 ft	5	REF		
3584	683.6 to 698.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	76	SF	\$120	\$9,120
3586	698.8 to 703.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520
3587	705.5 to 708.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800
50688	784.7 to 785.7 feet	Vertical Change	-31	5 ft	5	LF	\$75	\$375
3588	799.1 to 805.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,960
47014	804.0 to 805.0 feet	Vertical Change	-43	5 ft	5	REF		
3590	805.7 to 860.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	275	SF	\$120	\$33,000
42878	842.2 to 843.2 feet	Vertical Change	-65	5 ft	5	REF		
52962	852.4 to 853.4 feet	Vertical Change	-27	5 ft	5	REF		
57910	853.5 to 882.8 feet	Driveway				REF		
3594	860.7 to 877.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	86	SF	\$40	\$3,420
3598	877.8 to 883.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	27	SF	\$40	\$1,080
3602	883.2 to 1020.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	685	SF	\$40	\$27,380
56951	897.3 to 898.3 feet	Vertical Change	.55	5 ft	5	REF		
48731	930.3 to 931.3 feet	Vertical Change	-37	5 ft	5	REF		
49628	999.1 to 1000.1 feet	Vertical Change	-34	5 ft	5	REF		
3610	1022.6 to 1025.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680
3611	1038.8 to 1043.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760
3612	1049.6 to 1079.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	152	SF	\$120	\$18,180
3613	1092.2 to 1113.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	107	SF	\$120	\$12,840
3617	1113.6 to 1138.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	127	SF	\$120	\$15,180
51603	1125.2 to 1126.2 feet	Vertical Change	-3	5 ft	5	REF		
3621	1138.9 to 1167.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	141	SF	\$120	\$16,980
52016	1154.3 to 1155.3 feet	Vertical Change	-29	5 ft	5	REF		
3624	1169.8 to 1182.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,740

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211146	AVE 26	W GOLF DR	CLUBHOUSE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
52963	1173.6 to 1174.6 feet	Vertical Change	-.27	5 ft	5	REF		
3628	1182.7 to 1193.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	53	SF	\$120	\$6,300
48444	1183.1 to 1184.1 feet	Vertical Change	-.38	5 ft	5	REF		
3630	1193.2 to 1202.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,640
49629	1202.4 to 1203.4 feet	Vertical Change	-.34	5 ft	5	REF		
3631	1205.3 to 1216.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,420
54143	1221.0 to 1222.0 feet	Vertical Change	.26	5 ft	5	LF	\$75	\$375
3632	1229.0 to 1231.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560
3633	1240.3 to 1246.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,540
57144	1240.5 to 1241.5 feet	Vertical Change	.64	5 ft	5	REF		
3635	1246.2 to 1272.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	129	SF	\$120	\$15,480
49964	1260.0 to 1261.0 feet	Vertical Change	-.33	5 ft	5	REF		
55954	1260.0 to 1261.0 feet	Vertical Change	.33	5 ft	5	REF		
3637	1272.0 to 1317.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	230	SF	\$120	\$27,540
51604	1317.5 to 1318.5 feet	Vertical Change	-.3	5 ft	5	REF		
3638	1320.8 to 1322.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720
3639	1328.0 to 1364.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	185	SF	\$120	\$22,140
3643	1364.9 to 1394.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	147	SF	\$120	\$17,580
51605	1375.0 to 1376.0 feet	Vertical Change	-.3	5 ft	5	REF		
55940	1375.1 to 1376.1 feet	Vertical Change	.3	5 ft	5	REF		
3645	1394.2 to 1443.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	246	SF	\$120	\$29,460
53473	1394.7 to 1395.7 feet	Vertical Change	-.26	5 ft	5	REF		
52461	1443.1 to 1444.1 feet	Vertical Change	-.28	5 ft	5	REF		
3649	1443.3 to 1487.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	221	SF	\$120	\$26,520
46111	1472.1 to 1473.1 feet	Vertical Change	-.47	5 ft	5	REF		
49630	1481.7 to 1482.7 feet	Vertical Change	-.34	5 ft	5	REF		
3652	1487.5 to 1544.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	286	SF	\$120	\$34,320
53474	1491.4 to 1492.4 feet	Vertical Change	-.26	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211146	AVE 26	W GOLF DR	CLUBHOUSE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
3654	1544.7 to 1627.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	413	SF	\$120	\$49,560
3658	1627.3 to 1691.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	321	SF	\$120	\$38,460
49965	1667.3 to 1668.3 feet	Vertical Change	-33	5 ft	5	REF		
49966	1676.7 to 1677.7 feet	Vertical Change	-33	5 ft	5	REF		
49312	1686.1 to 1687.1 feet	Vertical Change	-35	5 ft	5	REF		
3664	1691.4 to 1817.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	629	SF	\$120	\$75,480
52017	1700.0 to 1701.0 feet	Vertical Change	-29	5 ft	5	REF		
52018	1712.1 to 1713.1 feet	Vertical Change	-29	5 ft	5	REF		
47253	1754.8 to 1758.4 feet	Vertical Change	-42	5 ft	18	REF		
52019	1767.0 to 1768.0 feet	Vertical Change	-29	5 ft	5	REF		
53475	1785.8 to 1786.8 feet	Vertical Change	-26	5 ft	5	REF		
52462	1804.7 to 1805.7 feet	Vertical Change	-28	5 ft	5	REF		
3674	1817.2 to 1821.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520
52020	1818.6 to 1819.6 feet	Vertical Change	-29	5 ft	5	REF		
TOTAL COST FOR: S							side of AVE 26 Starting at: W GOLF DR	\$878,840.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
W	1908211149	CLUBHOUSE DR	AVE 26	GRANITE FALLS WAY				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
3675	2.3 to 10.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,860
51606	6.8 to 7.8 feet	Vertical Change	-3	5 ft	5	REF		
3677	10.4 to 52.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	210	SF	\$120	\$25,140
53936	29.2 to 30.2 feet	Vertical Change	-25	5 ft	5	REF		
46560	48.6 to 49.6 feet	Vertical Change	-45	5 ft	5	REF		
3679	52.3 to 129.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	385	SF	\$120	\$46,200
46336	67.8 to 68.8 feet	Vertical Change	-46	5 ft	5	REF		
50316	77.2 to 78.2 feet	Vertical Change	-32	5 ft	5	REF		
49631	86.8 to 87.8 feet	Vertical Change	-34	5 ft	5	REF		
3686	129.3 to 147.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	88	SF	\$120	\$10,620
53937	135.5 to 136.5 feet	Vertical Change	-25	5 ft	5	REF		
3692	147.0 to 281.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	674	SF	\$120	\$80,940
46112	183.4 to 184.4 feet	Vertical Change	-47	5 ft	5	REF		
51607	280.2 to 281.2 feet	Vertical Change	-3	5 ft	5	REF		
3700	281.9 to 352.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	352	SF	\$120	\$42,180
52463	328.7 to 329.7 feet	Vertical Change	-28	5 ft	5	REF		
53476	348.2 to 349.2 feet	Vertical Change	-26	5 ft	5	REF		
3706	352.2 to 379.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	137	SF	\$120	\$16,440
53477	376.9 to 377.9 feet	Vertical Change	-26	5 ft	5	REF		
3712	379.6 to 411.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	160	SF	\$120	\$19,200
52964	410.2 to 411.2 feet	Vertical Change	-27	5 ft	5	REF		
3717	411.6 to 488.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	384	SF	\$120	\$46,020
45018	454.7 to 455.7 feet	Vertical Change	-52	5 ft	5	REF		
42226	472.8 to 473.8 feet	Vertical Change	-72	5 ft	5	REF		
46561	479.6 to 480.6 feet	Vertical Change	-45	5 ft	5	REF		
TOTAL COST FOR: W							side of CLUBHOUSE DR Starting at: AVE 26	\$291,600.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908211153	GRANITE FALLS WAY	CLUBHOUSE DR	GOLDEN SANDS WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
3722	2.3 to 19.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	85	SF	\$120	\$10,140	
41645	4.9 to 5.9 feet	Vertical Change	-93	5 ft	5	REF			
47919	14.8 to 15.8 feet	Vertical Change	-4	5 ft	5	REF			
42279	25.6 to 26.6 feet	Vertical Change	-71	5 ft	5	SF	\$75	\$375	
3723	31.1 to 42.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,080	
43563	36.9 to 37.9 feet	Vertical Change	-6	5 ft	5	REF			
3724	45.8 to 73.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	136	SF	\$120	\$16,380	
52464	47.1 to 48.1 feet	Vertical Change	-28	5 ft	5	REF			
44204	56.5 to 57.5 feet	Vertical Change	-56	5 ft	5	REF			
48445	65.2 to 66.2 feet	Vertical Change	-38	5 ft	5	REF			
43703	74.9 to 75.9 feet	Vertical Change	-59	5 ft	5	SF	\$75	\$375	
3726	76.1 to 80.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520	
3728	80.3 to 89.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	44	SF	\$120	\$5,220	
44632	81.4 to 82.4 feet	Vertical Change	-54	5 ft	5	REF			
3730	89.0 to 92.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860	
45484	91.2 to 92.2 feet	Vertical Change	-5	5 ft	5	REF			
3731	102.0 to 108.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,960	
48164	102.9 to 103.9 feet	Vertical Change	-39	5 ft	5	REF			
49632	115.9 to 116.9 feet	Vertical Change	-34	5 ft	5	LF	\$75	\$375	
3732	121.7 to 160.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	192	SF	\$120	\$22,980	
47254	123.5 to 124.5 feet	Vertical Change	-42	5 ft	5	REF			
45485	141.4 to 142.4 feet	Vertical Change	-5	5 ft	5	REF			
57911	157.0 to 198.7 feet	Driveway				REF			
53938	158.4 to 159.4 feet	Vertical Change	-25	5 ft	5	REF			
3738	160.0 to 171.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	57	SF	\$40	\$2,280	
48165	164.5 to 165.5 feet	Vertical Change	-39	5 ft	5	REF			
3742	171.4 to 195.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	120	SF	\$40	\$4,780	
49313	180.7 to 181.7 feet	Vertical Change	-35	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
S	1908211153	GRANITE FALLS WAY	CLUBHOUSE DR	GOLDEN SANDS WAY				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40098	194.1 to 196.2 feet	Running Slope	5.0-6.0%	5 ft	11	REF		
3746	195.3 to 197.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	10	SF	\$40	\$380
41385	198.5 to 199.5 feet	Vertical Change	-1.31	5 ft	5	REF		
52021	199.7 to 200.9 feet	Vertical Change	-.29	5 ft	6	LF	\$75	\$450
40099	201.7 to 203.4 feet	Running Slope	5.0-6.0%	5 ft	9	SF	\$120	\$1,020
57155	202.0 to 203.0 feet	Vertical Change	.67	5 ft	5	SF	\$75	\$375
45486	204.5 to 205.5 feet	Vertical Change	-.5	5 ft	5	SF	\$75	\$375
48732	208.7 to 209.7 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375
3747	215.6 to 257.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	209	SF	\$120	\$25,080
42227	228.4 to 229.4 feet	Vertical Change	-.72	5 ft	5	REF		
45487	241.1 to 242.1 feet	Vertical Change	-.5	5 ft	5	REF		
50317	255.6 to 259.4 feet	Vertical Change	-.32	5 ft	19	REF		
3752	257.4 to 262.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	28	SF	\$120	\$3,300
41795	260.4 to 261.4 feet	Vertical Change	-.84	5 ft	5	REF		
3754	262.9 to 271.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$5,040
50318	263.0 to 268.7 feet	Vertical Change	-.32	5 ft	29	REF		
49010	289.0 to 290.0 feet	Vertical Change	-.36	5 ft	5	REF		
50689	298.2 to 299.2 feet	Vertical Change	-.31	5 ft	5	REF		
47015	303.0 to 304.0 feet	Vertical Change	-.43	5 ft	5	REF		
53478	308.1 to 309.1 feet	Vertical Change	-.26	5 ft	5	REF		
52465	313.3 to 314.3 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375
3758	315.0 to 334.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	96	SF	\$120	\$11,520
48447	318.4 to 319.4 feet	Vertical Change	-.38	5 ft	5	REF		
50690	323.2 to 324.2 feet	Vertical Change	-.31	5 ft	5	REF		
45702	330.8 to 334.3 feet	Vertical Change	-.49	5 ft	18	REF		
47255	337.7 to 345.9 feet	Vertical Change	-.42	5 ft	41	LF	\$75	\$3,075
3760	339.0 to 358.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	97	SF	\$120	\$11,640
41383	347.3 to 348.3 feet	Vertical Change	-1.32	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908211153	GRANITE FALLS WAY	CLUBHOUSE DR	GOLDEN SANDS WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
49967	352.4 to 355.9 feet	Vertical Change	-.33	5 ft	18	REF			
49314	362.5 to 370.9 feet	Vertical Change	-.35	5 ft	42	LF	\$75	\$3,150	
3761	367.9 to 375.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320	
53480	374.9 to 375.9 feet	Vertical Change	-.26	5 ft	5	REF			
44410	377.4 to 378.4 feet	Vertical Change	-.55	5 ft	5	SF	\$75	\$375	
49012	384.9 to 385.9 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375	
41507	387.3 to 388.3 feet	Vertical Change	-1.08	5 ft	5	SF	\$75	\$375	
3762	390.4 to 480.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	451	SF	\$120	\$54,060	
46807	397.8 to 398.8 feet	Vertical Change	-.44	5 ft	5	REF			
49315	407.8 to 408.8 feet	Vertical Change	-.35	5 ft	5	REF			
41239	414.2 to 415.2 feet	Vertical Change	-1.92	5 ft	5	REF			
57490	414.2 to 415.2 feet	Vertical Change	1.65	5 ft	5	REF			
50692	414.5 to 415.5 feet	Vertical Change	-.31	5 ft	5	REF			
50693	418.1 to 419.1 feet	Vertical Change	-.31	5 ft	5	REF			
47016	438.1 to 439.1 feet	Vertical Change	-.43	5 ft	5	REF			
49968	448.4 to 449.4 feet	Vertical Change	-.33	5 ft	5	REF			
41536	468.3 to 469.3 feet	Vertical Change	-1.04	5 ft	5	REF			
42280	477.7 to 478.7 feet	Vertical Change	-.71	5 ft	5	REF			
3767	482.7 to 543.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	305	SF	\$120	\$36,600	
45488	487.3 to 488.3 feet	Vertical Change	-.5	5 ft	5	REF			
43377	507.7 to 508.7 feet	Vertical Change	-.61	5 ft	5	REF			
42037	517.6 to 518.6 feet	Vertical Change	-.76	5 ft	5	REF			
46337	536.8 to 537.8 feet	Vertical Change	-.46	5 ft	5	REF			
3776	543.7 to 597.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	270	SF	\$120	\$32,460	
51610	576.3 to 577.3 feet	Vertical Change	-.3	5 ft	5	REF			
51611	585.8 to 586.8 feet	Vertical Change	-.3	5 ft	5	REF			
50320	589.0 to 590.0 feet	Vertical Change	-.32	5 ft	5	REF			
51612	594.2 to 598.3 feet	Vertical Change	-.3	5 ft	20	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211153	GRANITE FALLS WAY	CLUBHOUSE DR	GOLDEN SANDS WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
3786	597.8 to 600.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800
53481	602.2 to 603.2 feet	Vertical Change	-26	5 ft	5	LF	\$75	\$375
TOTAL COST FOR:		S	<i>side of</i> GRANITE FALLS WAY <i>Starting at:</i> CLUBHOUSE DR					\$275,220.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211155	GRANITE FALLS WAY	GOLDEN SANDS WAY	GOLDEN SANDS WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
3787	0.0 to 181.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	906	SF	\$120	\$108,660
43564	1.7 to 4.5 feet	Vertical Change	-.6	5 ft	14	REF		
41439	6.9 to 7.9 feet	Vertical Change	-1.19	5 ft	5	REF		
48733	12.1 to 13.1 feet	Vertical Change	-.37	5 ft	5	REF		
53482	17.1 to 18.1 feet	Vertical Change	-.26	5 ft	5	REF		
50694	77.2 to 78.2 feet	Vertical Change	-.31	5 ft	5	REF		
53483	96.7 to 97.7 feet	Vertical Change	-.26	5 ft	5	REF		
53484	116.8 to 117.8 feet	Vertical Change	-.26	5 ft	5	REF		
52024	155.5 to 156.5 feet	Vertical Change	-.29	5 ft	5	REF		
3808	181.1 to 187.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	31	SF	\$40	\$1,220
3810	187.2 to 210.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	118	SF	\$40	\$4,720
49013	210.1 to 211.1 feet	Vertical Change	-.36	5 ft	5	REF		

TOTAL COST FOR: S side of GRANITE FALLS WAY Starting at: GOLDEN SANDS WAY \$114,600.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211156	GRANITE FALLS WAY	GOLDEN SANDS WAY	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47017	2.1 to 3.1 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375
3813	5.9 to 82.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	381	SF	\$120	\$45,720
47921	7.8 to 8.8 feet	Vertical Change	-.4	5 ft	5	REF		
52466	18.8 to 19.8 feet	Vertical Change	-.28	5 ft	5	REF		
48448	28.5 to 29.5 feet	Vertical Change	-.38	5 ft	5	REF		
3822	86.6 to 103.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	87	SF	\$120	\$10,380
TOTAL COST FOR: S side of GRANITE FALLS WAY Starting at: GOLDEN SANDS WAY							\$56,475.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908211200	GRANITE FALLS WAY	SIDEWALK BEGINS	CLUBHOUSE DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
57913	0.0 to 25.8 feet	Driveway				REF			
3824	0.7 to 15.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	73	SF	\$40	\$2,920	
49969	4.2 to 5.2 feet	Vertical Change	-33	5 ft	5	REF			
3826	15.3 to 24.2 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	45	SF	\$40	\$1,780	
40101	22.3 to 23.5 feet	Running Slope	6.0-7.0%	5 ft	6	REF			
3828	27.1 to 40.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	68	SF	\$120	\$8,100	
47922	36.4 to 37.4 feet	Vertical Change	-4	5 ft	5	REF			
3830	40.6 to 45.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060	
57914	41.5 to 78.7 feet	Driveway				REF			
41445	46.0 to 47.0 feet	Vertical Change	-1.17	5 ft	5	REF			
3832	49.3 to 75.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	129	SF	\$40	\$5,160	
42663	56.7 to 57.7 feet	Vertical Change	-67	5 ft	5	REF			
42121	67.4 to 68.4 feet	Vertical Change	-74	5 ft	5	REF			
41363	77.9 to 78.9 feet	Vertical Change	-1.37	5 ft	5	REF			
46338	87.4 to 88.4 feet	Vertical Change	-46	5 ft	5	LF	\$75	\$375	
42985	97.5 to 98.5 feet	Vertical Change	-64	5 ft	5	SF	\$75	\$375	
43565	107.8 to 108.8 feet	Vertical Change	-6	5 ft	5	SF	\$75	\$375	
41615	117.9 to 118.9 feet	Vertical Change	-96	5 ft	5	SF	\$75	\$375	
44411	126.6 to 127.6 feet	Vertical Change	-55	5 ft	5	SF	\$75	\$375	
42080	136.1 to 137.1 feet	Vertical Change	-75	5 ft	5	SF	\$75	\$375	
41312	144.5 to 145.5 feet	Vertical Change	-1.52	5 ft	5	REF			
3837	144.6 to 155.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,540	
43378	154.6 to 155.6 feet	Vertical Change	-61	5 ft	5	REF			
44027	164.4 to 165.4 feet	Vertical Change	-57	5 ft	5	SF	\$75	\$375	
57915	171.2 to 207.4 feet	Driveway				REF			
3838	173.0 to 174.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240	
41440	174.0 to 175.0 feet	Vertical Change	-1.19	5 ft	5	REF			
3839	177.0 to 204.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	138	SF	\$40	\$5,520	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
N	1908211200	GRANITE FALLS WAY	SIDEWALK BEGINS	CLUBHOUSE DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
42380	185.9 to 186.9 feet	Vertical Change	-.7	5 ft	5	REF			
42122	196.5 to 197.5 feet	Vertical Change	-.74	5 ft	5	REF			
47256	207.0 to 208.0 feet	Vertical Change	-.42	5 ft	5	REF			
3842	207.7 to 208.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$600	
3843	208.7 to 213.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760	
44205	217.0 to 218.0 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375	
3844	220.6 to 226.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,600	
57916	221.7 to 259.4 feet	Driveway				REF			
41253	226.3 to 227.3 feet	Vertical Change	-1.84	5 ft	5	REF			
3846	229.8 to 256.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	132	SF	\$40	\$5,260	
46562	237.8 to 238.8 feet	Vertical Change	-.45	5 ft	5	REF			
42552	248.2 to 249.2 feet	Vertical Change	-.68	5 ft	5	REF			
40102	255.9 to 257.8 feet	Running Slope	6.0-7.0%	5 ft	10	REF			
3850	259.8 to 261.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,260	
45703	263.5 to 264.5 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$375	
3851	267.4 to 293.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	131	SF	\$120	\$15,720	
42879	273.9 to 274.9 feet	Vertical Change	-.65	5 ft	5	REF			
43229	294.0 to 295.0 feet	Vertical Change	-.62	5 ft	5	SF	\$75	\$375	
3854	297.1 to 353.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	283	SF	\$120	\$33,960	
42381	304.5 to 305.5 feet	Vertical Change	-.7	5 ft	5	REF			
48449	324.7 to 325.7 feet	Vertical Change	-.38	5 ft	5	REF			
42761	334.6 to 335.6 feet	Vertical Change	-.66	5 ft	5	REF			
42986	344.4 to 345.4 feet	Vertical Change	-.64	5 ft	5	REF			
57917	349.5 to 386.7 feet	Driveway				REF			
41295	354.0 to 355.0 feet	Vertical Change	-1.6	5 ft	5	REF			
3856	357.6 to 375.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	92	SF	\$40	\$3,660	
45902	364.5 to 365.5 feet	Vertical Change	-.48	5 ft	5	REF			
42553	375.1 to 376.1 feet	Vertical Change	-.68	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908211200	GRANITE FALLS WAY	SIDEWALK BEGINS	CLUBHOUSE DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
3858	375.9 to 384.0 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	41	SF	\$40	\$1,620	
41466	386.1 to 387.1 feet	Vertical Change	-1.13	5 ft	5	REF			
50321	395.3 to 396.3 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
57918	402.6 to 439.2 feet	Driveway				REF			
41890	406.2 to 407.2 feet	Vertical Change	-.8	5 ft	5	REF			
3859	409.1 to 416.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	36	SF	\$40	\$1,440	
3861	416.3 to 436.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	100	SF	\$40	\$4,000	
42554	416.9 to 417.9 feet	Vertical Change	-.68	5 ft	5	REF			
44836	427.8 to 428.8 feet	Vertical Change	-.53	5 ft	5	REF			
49316	438.4 to 439.4 feet	Vertical Change	-.35	5 ft	5	REF			
3864	439.6 to 459.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	99	SF	\$120	\$11,880	
47257	448.2 to 452.8 feet	Vertical Change	-.42	5 ft	23	REF			
52025	455.7 to 457.4 feet	Vertical Change	-.29	5 ft	9	REF			
41333	459.3 to 460.3 feet	Vertical Change	-1.44	5 ft	5	REF			
52026	462.2 to 463.2 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
43230	465.0 to 466.0 feet	Vertical Change	-.62	5 ft	5	SF	\$75	\$375	
52027	467.4 to 470.9 feet	Vertical Change	-.29	5 ft	18	LF	\$75	\$1,313	
45489	474.9 to 481.0 feet	Vertical Change	-.5	5 ft	31	SF	\$75	\$2,288	
53486	485.0 to 486.0 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
53943	512.3 to 513.3 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375	
53487	519.8 to 525.6 feet	Vertical Change	-.26	5 ft	29	LF	\$75	\$2,175	
57919	530.0 to 567.5 feet	Driveway				REF			
42123	534.3 to 535.3 feet	Vertical Change	-.74	5 ft	5	REF			
3867	537.7 to 547.6 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	49	SF	\$40	\$1,980	
42081	545.3 to 546.3 feet	Vertical Change	-.75	5 ft	5	REF			
3869	547.6 to 558.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	55	SF	\$40	\$2,180	
45209	556.1 to 557.1 feet	Vertical Change	-.51	5 ft	5	REF			
3871	558.5 to 564.2 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	29	SF	\$40	\$1,140	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908211200	GRANITE FALLS WAY	SIDEWALK BEGINS	CLUBHOUSE DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
40103	563.7 to 565.8 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
46808	566.6 to 567.6 feet	Vertical Change	-.44	5 ft	5	REF			
49633	576.3 to 577.3 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375	
55986	576.3 to 577.3 feet	Vertical Change	.39	5 ft	5	LF	\$75	\$375	
3872	577.8 to 586.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,100	
57920	582.8 to 619.8 feet	Driveway				REF			
43100	586.5 to 587.5 feet	Vertical Change	-.63	5 ft	5	REF			
3873	589.7 to 616.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	133	SF	\$40	\$5,340	
44633	598.1 to 599.1 feet	Vertical Change	-.54	5 ft	5	REF			
44837	608.6 to 609.6 feet	Vertical Change	-.53	5 ft	5	REF			
3874	620.4 to 637.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	87	SF	\$40	\$3,480	
53488	621.3 to 624.3 feet	Vertical Change	-.26	5 ft	15	REF			
44634	627.2 to 628.2 feet	Vertical Change	-.54	5 ft	5	REF			
52468	634.5 to 635.5 feet	Vertical Change	-.28	5 ft	5	REF			
41860	646.9 to 647.9 feet	Vertical Change	-.81	5 ft	5	SF	\$75	\$375	
3875	648.3 to 661.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	64	SF	\$120	\$7,620	
47504	656.8 to 657.8 feet	Vertical Change	-.41	5 ft	5	REF			
3876	664.9 to 676.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,080	
46809	666.8 to 667.8 feet	Vertical Change	-.44	5 ft	5	REF			
57921	670.7 to 708.7 feet	Driveway				REF			
41480	676.3 to 677.3 feet	Vertical Change	-1.12	5 ft	5	REF			
3878	679.6 to 688.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	44	SF	\$40	\$1,740	
44635	687.0 to 688.0 feet	Vertical Change	-.54	5 ft	5	REF			
3880	688.3 to 705.7 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	87	SF	\$40	\$3,480	
43231	697.8 to 698.8 feet	Vertical Change	-.62	5 ft	5	REF			
41277	708.4 to 709.4 feet	Vertical Change	-1.66	5 ft	5	REF			
3881	719.8 to 721.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780	
46339	720.9 to 721.9 feet	Vertical Change	-.46	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908211200	GRANITE FALLS WAY	SIDEWALK BEGINS	CLUBHOUSE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
3882	725.7 to 728.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440
43855	740.9 to 741.9 feet	Vertical Change	-.58	5 ft	5	SF	\$75	\$375
TOTAL COST FOR:		N	<i>side of</i> GRANITE FALLS WAY	<i>Starting at:</i> SIDEWALK BEGINS				\$173,340.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908211202	CLUBHOUSE DR	GRANITE FALLS WAY	AVE 26					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
3883	0.0 to 21.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	110	SF	\$120	\$13,140	
53489	0.3 to 1.3 feet	Vertical Change	-26	5 ft	5	REF			
43566	4.6 to 5.6 feet	Vertical Change	-6	5 ft	5	REF			
3884	21.9 to 75.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	269	SF	\$120	\$32,280	
47258	22.9 to 23.9 feet	Vertical Change	-42	5 ft	5	REF			
41432	57.3 to 58.3 feet	Vertical Change	-1.2	5 ft	5	REF			
50695	68.7 to 69.7 feet	Vertical Change	-31	5 ft	5	REF			
53490	73.2 to 82.5 feet	Vertical Change	-26	5 ft	47	REF			
3890	75.7 to 85.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	50	SF	\$120	\$5,940	
54133	81.9 to 82.9 feet	Vertical Change	.25	5 ft	5	REF			
48450	85.8 to 86.8 feet	Vertical Change	-38	5 ft	5	LF	\$75	\$375	
41330	86.4 to 87.4 feet	Vertical Change	-1.45	5 ft	5	REF			
3892	87.0 to 89.5 feet	Cross Slope (PAR)	7.0-8.0%	5 ft	13	SF	\$120	\$1,500	
41833	87.5 to 88.5 feet	Vertical Change	-.82	5 ft	5	REF			
3893	90.5 to 104.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	70	SF	\$120	\$8,340	
48166	95.9 to 96.9 feet	Vertical Change	-.39	5 ft	5	REF			
3895	104.4 to 119.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	75	SF	\$120	\$8,940	
49014	107.3 to 108.3 feet	Vertical Change	-.36	5 ft	5	REF			
52969	122.2 to 123.2 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
3898	124.3 to 142.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	93	SF	\$120	\$11,100	
48735	131.9 to 132.9 feet	Vertical Change	-.37	5 ft	5	REF			
50696	141.5 to 142.5 feet	Vertical Change	-.31	5 ft	5	REF			
3899	148.3 to 156.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,100	
3900	159.3 to 167.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800	
3901	177.3 to 209.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	161	SF	\$120	\$19,260	
50322	180.0 to 181.0 feet	Vertical Change	-.32	5 ft	5	REF			
50323	208.3 to 209.3 feet	Vertical Change	-.32	5 ft	5	REF			
3902	212.2 to 215.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908211202	CLUBHOUSE DR	GRANITE FALLS WAY	AVE 26	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
3903	217.7 to 306.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	442	SF	\$120	\$52,980
53491	217.8 to 218.8 feet	Vertical Change	-26	5 ft	5	REF		
3906	310.8 to 370.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	298	SF	\$120	\$35,760
52970	331.4 to 332.4 feet	Vertical Change	-27	5 ft	5	REF		
52028	350.3 to 351.3 feet	Vertical Change	-29	5 ft	5	REF		
53492	370.0 to 371.0 feet	Vertical Change	-26	5 ft	5	REF		
3910	370.4 to 504.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	672	SF	\$120	\$80,640
49015	382.1 to 383.1 feet	Vertical Change	-36	5 ft	5	REF		
52971	389.5 to 390.5 feet	Vertical Change	-27	5 ft	5	REF		
53493	408.5 to 409.5 feet	Vertical Change	-26	5 ft	5	REF		
49016	418.4 to 419.4 feet	Vertical Change	-36	5 ft	5	REF		
50324	428.5 to 429.5 feet	Vertical Change	-32	5 ft	5	REF		
46563	448.0 to 449.0 feet	Vertical Change	-45	5 ft	5	REF		
47018	457.5 to 458.5 feet	Vertical Change	-43	5 ft	5	REF		
44838	466.7 to 467.7 feet	Vertical Change	-53	5 ft	5	REF		
45903	475.8 to 476.8 feet	Vertical Change	-48	5 ft	5	REF		
43856	485.2 to 486.2 feet	Vertical Change	-58	5 ft	5	REF		
42465	494.7 to 495.7 feet	Vertical Change	-69	5 ft	5	REF		
45704	501.3 to 502.3 feet	Vertical Change	-49	5 ft	5	REF		
3929	504.8 to 508.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,280
52029	507.3 to 508.3 feet	Vertical Change	-29	5 ft	5	REF		
TOTAL COST FOR: E side of CLUBHOUSE DR Starting at: GRANITE FALLS WAY							\$284,670.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
S	1908211203	AVE 26	CLUBHOUSE DR	LAKES RV AND GOLF RESORT	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
46340	9.1 to 10.1 feet	Vertical Change	-.46	5 ft	5	LF	\$75	\$375	
53944	13.0 to 14.0 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375	
3930	25.0 to 36.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,660	
3931	58.4 to 70.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,380	
49970	68.5 to 69.5 feet	Vertical Change	-.33	5 ft	5	REF			
3933	82.5 to 88.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,480	
50697	88.6 to 89.6 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
3934	114.0 to 136.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	113	SF	\$120	\$13,560	
52972	118.4 to 119.4 feet	Vertical Change	-.27	5 ft	5	REF			
48451	188.1 to 189.1 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375	
3935	202.6 to 204.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320	
52469	237.4 to 238.4 feet	Vertical Change	-.28	5 ft	5	REF			
3936	237.8 to 254.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	84	SF	\$120	\$10,020	
3938	258.2 to 264.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,600	
3939	269.7 to 307.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	191	SF	\$120	\$22,860	
52030	296.8 to 297.8 feet	Vertical Change	-.29	5 ft	5	REF			
3945	331.5 to 340.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,220	
3946	348.9 to 361.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,440	
45904	357.8 to 358.8 feet	Vertical Change	-.48	5 ft	5	REF			
47505	363.3 to 364.3 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375	

TOTAL COST FOR:	S	<i>side of AVE 26</i>	Starting at: CLUBHOUSE DR	\$83,415.00
------------------------	----------	-----------------------	----------------------------------	--------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211207	AVE 26	LAKES RV AND GOLF	GOLF DR W	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
3947	3.0 to 12.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,520
42664	8.2 to 9.2 feet	Vertical Change	-.67	5 ft	5	REF		
3948	15.6 to 32.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,260
52470	25.4 to 26.4 feet	Vertical Change	-.28	5 ft	5	REF		
49971	69.7 to 70.7 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375
53494	119.4 to 120.4 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
3949	139.7 to 171.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	158	SF	\$120	\$18,960
53495	149.5 to 150.5 feet	Vertical Change	-.26	5 ft	5	REF		
3951	178.2 to 179.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720
3952	233.3 to 248.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	75	SF	\$120	\$8,940
3953	250.3 to 367.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	586	SF	\$120	\$70,260
52471	277.9 to 278.9 feet	Vertical Change	-.28	5 ft	5	REF		
53945	287.9 to 288.9 feet	Vertical Change	-.25	5 ft	5	REF		
53946	307.6 to 308.6 feet	Vertical Change	-.25	5 ft	5	REF		
53947	315.8 to 316.8 feet	Vertical Change	-.25	5 ft	5	REF		
46113	324.5 to 325.5 feet	Vertical Change	-.47	5 ft	5	REF		
54134	363.2 to 364.2 feet	Vertical Change	.25	5 ft	5	REF		
3966	370.2 to 420.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	254	SF	\$120	\$30,420
49318	392.3 to 393.3 feet	Vertical Change	-.35	5 ft	5	REF		
49972	402.3 to 403.3 feet	Vertical Change	-.33	5 ft	5	REF		
49319	412.2 to 413.2 feet	Vertical Change	-.35	5 ft	5	REF		
3971	420.9 to 437.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	85	SF	\$120	\$10,200
49634	431.9 to 432.9 feet	Vertical Change	-.34	5 ft	5	REF		
3975	437.9 to 444.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020
3977	444.6 to 455.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	57	SF	\$120	\$6,780
49973	451.8 to 452.8 feet	Vertical Change	-.33	5 ft	5	REF		
3979	455.9 to 469.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,160
3982	469.5 to 657.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	940	SF	\$120	\$112,740

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211207	AVE 26	LAKES RV AND GOLF	GOLF DR W	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51616	475.8 to 476.8 feet	Vertical Change	-.3	5 ft	5	REF		
48452	535.5 to 536.5 feet	Vertical Change	-.38	5 ft	5	REF		
44839	545.3 to 546.3 feet	Vertical Change	-.53	5 ft	5	REF		
45210	555.2 to 556.2 feet	Vertical Change	-.51	5 ft	5	REF		
56645	555.3 to 556.3 feet	Vertical Change	.49	5 ft	5	REF		
52973	594.7 to 595.7 feet	Vertical Change	-.27	5 ft	5	REF		
52031	614.4 to 615.4 feet	Vertical Change	-.29	5 ft	5	REF		
51617	634.2 to 635.2 feet	Vertical Change	-.3	5 ft	5	REF		
52974	644.1 to 645.1 feet	Vertical Change	-.27	5 ft	5	REF		
52032	653.9 to 657.4 feet	Vertical Change	-.29	5 ft	18	REF		
4002	657.4 to 668.4 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	55	SF	\$120	\$6,600
47923	663.7 to 664.7 feet	Vertical Change	-.4	5 ft	5	REF		
4003	668.4 to 674.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	29	SF	\$120	\$3,480
4005	674.2 to 714.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	202	SF	\$120	\$24,240
53496	693.2 to 694.2 feet	Vertical Change	-.26	5 ft	5	REF		
46114	712.9 to 713.9 feet	Vertical Change	-.47	5 ft	5	REF		
4012	714.6 to 782.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	341	SF	\$120	\$40,920
46564	722.8 to 723.8 feet	Vertical Change	-.45	5 ft	5	REF		
53497	761.9 to 762.9 feet	Vertical Change	-.26	5 ft	5	REF		
50325	781.4 to 782.4 feet	Vertical Change	-.32	5 ft	5	REF		
4021	782.8 to 930.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	738	SF	\$120	\$88,560
49320	820.6 to 821.6 feet	Vertical Change	-.35	5 ft	5	REF		
48736	830.3 to 831.3 feet	Vertical Change	-.37	5 ft	5	REF		
48453	840.1 to 841.1 feet	Vertical Change	-.38	5 ft	5	REF		
48167	879.2 to 880.2 feet	Vertical Change	-.39	5 ft	5	REF		
47019	898.7 to 899.7 feet	Vertical Change	-.43	5 ft	5	REF		
46565	905.1 to 906.1 feet	Vertical Change	-.45	5 ft	5	REF		
50699	913.6 to 914.6 feet	Vertical Change	-.31	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908211207	AVE 26	LAKES RV AND GOLF	GOLF DR W					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
50700	918.3 to 919.3 feet	Vertical Change	-.31	5 ft	5	REF			
4039	930.4 to 953.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	116	SF	\$120	\$13,860	
47924	938.1 to 939.1 feet	Vertical Change	-.4	5 ft	5	REF			
4043	953.5 to 970.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	87	SF	\$120	\$10,440	
48168	957.6 to 958.6 feet	Vertical Change	-.39	5 ft	5	REF			
4045	970.9 to 1003.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	165	SF	\$120	\$19,740	
4048	1006.9 to 1009.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440	
4049	1011.5 to 1014.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560	
4050	1018.1 to 1052.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	174	SF	\$120	\$20,880	
53498	1026.4 to 1027.4 feet	Vertical Change	-.26	5 ft	5	REF			
4054	1052.9 to 1077.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	122	SF	\$120	\$14,640	
47506	1055.8 to 1056.8 feet	Vertical Change	-.41	5 ft	5	REF			
53499	1065.5 to 1066.5 feet	Vertical Change	-.26	5 ft	5	REF			
46810	1075.2 to 1076.2 feet	Vertical Change	-.44	5 ft	5	REF			
4056	1077.3 to 1130.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	268	SF	\$120	\$32,100	
43379	1094.9 to 1095.9 feet	Vertical Change	-.61	5 ft	5	REF			
41702	1104.9 to 1105.9 feet	Vertical Change	-.89	5 ft	5	REF			
46115	1115.1 to 1116.1 feet	Vertical Change	-.47	5 ft	5	REF			
45491	1125.4 to 1126.4 feet	Vertical Change	-.5	5 ft	5	REF			
4060	1130.8 to 1143.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	65	SF	\$120	\$7,740	
46341	1135.3 to 1136.3 feet	Vertical Change	-.46	5 ft	5	REF			
4062	1143.7 to 1154.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,660	
41499	1145.2 to 1146.2 feet	Vertical Change	-1.1	5 ft	5	REF			
4064	1154.8 to 1214.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	296	SF	\$120	\$35,520	
43101	1155.1 to 1156.1 feet	Vertical Change	-.63	5 ft	5	REF			
46342	1165.1 to 1166.1 feet	Vertical Change	-.46	5 ft	5	REF			
53500	1174.7 to 1175.7 feet	Vertical Change	-.26	5 ft	5	REF			
41199	1184.4 to 1185.4 feet	Vertical Change	-2.44	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211207	AVE 26	LAKES RV AND GOLF	GOLF DR W	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46566	1189.8 to 1190.8 feet	Vertical Change	-.45	5 ft	5	REF		
46116	1193.3 to 1194.3 feet	Vertical Change	-.47	5 ft	5	REF		
52975	1198.2 to 1199.2 feet	Vertical Change	-.27	5 ft	5	REF		
41935	1201.6 to 1202.6 feet	Vertical Change	-.79	5 ft	5	REF		
41601	1206.0 to 1207.0 feet	Vertical Change	-.98	5 ft	5	REF		
4072	1214.0 to 1216.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,260
42281	1214.8 to 1215.8 feet	Vertical Change	-.71	5 ft	5	REF		
42665	1221.8 to 1224.6 feet	Vertical Change	-.67	5 ft	14	SF	\$75	\$1,050
TOTAL COST FOR: S side of AVE 26 Starting at: LAKES RV AND GOLF RESORT								\$618,420.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908211209	GOLF DR W	AVE 26	PRIVATE ROAD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
42466	2.8 to 3.8 feet	Vertical Change	-.69	5 ft	5	SF	\$75	\$375
4073	4.3 to 14.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,300
45019	7.8 to 11.1 feet	Vertical Change	-.52	5 ft	17	REF		
41254	18.8 to 19.8 feet	Vertical Change	-1.83	5 ft	5	SF	\$75	\$375
4074	24.0 to 36.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	64	SF	\$120	\$7,680
47507	25.6 to 26.6 feet	Vertical Change	-.41	5 ft	5	REF		
49635	34.9 to 35.9 feet	Vertical Change	-.34	5 ft	5	REF		
48169	45.9 to 46.9 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375
49974	56.2 to 57.2 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375
4075	66.0 to 134.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	340	SF	\$120	\$40,800
42555	66.3 to 67.3 feet	Vertical Change	-.68	5 ft	5	REF		
41264	76.3 to 77.3 feet	Vertical Change	-1.74	5 ft	5	REF		
46118	86.5 to 87.5 feet	Vertical Change	-.47	5 ft	5	REF		
47020	96.5 to 97.5 feet	Vertical Change	-.43	5 ft	5	REF		
42177	116.4 to 117.4 feet	Vertical Change	-.73	5 ft	5	REF		
46119	136.5 to 137.5 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375
42467	146.3 to 147.3 feet	Vertical Change	-.69	5 ft	5	SF	\$75	\$375
4082	157.7 to 159.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
4083	163.8 to 170.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,200
49321	170.5 to 171.5 feet	Vertical Change	-.35	5 ft	5	REF		
42382	177.4 to 178.4 feet	Vertical Change	-.7	5 ft	5	SF	\$75	\$375
4084	182.8 to 205.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	112	SF	\$120	\$13,380
43704	185.2 to 186.2 feet	Vertical Change	-.59	5 ft	5	REF		
45492	195.9 to 196.9 feet	Vertical Change	-.5	5 ft	5	REF		
TOTAL COST FOR: W side of GOLF DR W Starting at: AVE 26							\$76,065.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority	
E	1908211212	GOLF DR W	PRIVATE ROAD	AVE 26					TBD	
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total		
41673	3.5 to 4.5 feet	Vertical Change	-.91	5 ft	5	SF	\$75	\$375		
4087	7.4 to 16.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,280		
46343	14.4 to 15.4 feet	Vertical Change	-.46	5 ft	5	REF				
41739	25.4 to 26.4 feet	Vertical Change	-.87	5 ft	5	SF	\$75	\$375		
4088	37.8 to 60.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	114	SF	\$120	\$13,620		
41203	39.5 to 40.5 feet	Vertical Change	-2.38	5 ft	5	REF				
41322	48.2 to 49.2 feet	Vertical Change	-1.48	5 ft	5	REF				
52033	55.1 to 56.1 feet	Vertical Change	-.29	5 ft	5	REF				
50701	64.8 to 65.8 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375		
42762	77.7 to 78.7 feet	Vertical Change	-.66	5 ft	5	SF	\$75	\$375		
4089	81.3 to 83.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500		
50702	87.7 to 88.7 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375		
44206	97.6 to 98.6 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375		
4090	105.6 to 107.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320		
50703	107.8 to 108.8 feet	Vertical Change	-.31	5 ft	5	REF				
46811	117.9 to 118.9 feet	Vertical Change	-.44	5 ft	5	LF	\$75	\$375		
56621	118.0 to 119.0 feet	Vertical Change	.43	5 ft	5	LF	\$75	\$375		
45211	128.0 to 129.0 feet	Vertical Change	-.51	5 ft	5	SF	\$75	\$375		
45493	137.9 to 138.9 feet	Vertical Change	-.5	5 ft	5	SF	\$75	\$375		
42383	148.0 to 149.0 feet	Vertical Change	-.7	5 ft	5	SF	\$75	\$375		
46567	158.1 to 159.1 feet	Vertical Change	-.45	5 ft	5	LF	\$75	\$375		
41616	168.3 to 169.3 feet	Vertical Change	-.96	5 ft	5	SF	\$75	\$375		
45905	179.6 to 180.6 feet	Vertical Change	-.48	5 ft	5	LF	\$75	\$375		
41212	188.6 to 189.6 feet	Vertical Change	-2.23	5 ft	5	SF	\$75	\$375		
48170	194.9 to 198.3 feet	Vertical Change	-.39	5 ft	17	LF	\$75	\$1,275		
47508	200.7 to 201.7 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375		
TOTAL COST FOR:							E	<i>side of</i> GOLF DR W	<i>Starting at:</i> PRIVATE ROAD	\$28,995.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908211214	AVE 26	GOLF DR W	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
48737	3.5 to 4.5 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375	
45906	7.4 to 8.4 feet	Vertical Change	-.48	5 ft	5	LF	\$75	\$375	
4091	10.9 to 41.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	152	SF	\$120	\$18,240	
51618	21.5 to 22.5 feet	Vertical Change	-.3	5 ft	5	REF			
44028	24.1 to 27.7 feet	Vertical Change	-.57	5 ft	18	REF			
53501	29.2 to 32.8 feet	Vertical Change	-.26	5 ft	18	REF			
42384	34.3 to 35.3 feet	Vertical Change	-.7	5 ft	5	REF			
46344	44.0 to 47.6 feet	Vertical Change	-.46	5 ft	18	LF	\$75	\$1,350	
4093	47.8 to 77.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	151	SF	\$120	\$18,060	
42763	54.1 to 55.1 feet	Vertical Change	-.66	5 ft	5	REF			
41674	64.1 to 65.1 feet	Vertical Change	-.91	5 ft	5	REF			
41633	74.3 to 75.3 feet	Vertical Change	-.94	5 ft	5	REF			
4097	77.9 to 102.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	123	SF	\$120	\$14,820	
46812	95.9 to 96.9 feet	Vertical Change	-.44	5 ft	5	REF			
4101	102.6 to 133.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	154	SF	\$120	\$18,420	
46813	105.7 to 106.7 feet	Vertical Change	-.44	5 ft	5	REF			
43102	115.6 to 116.6 feet	Vertical Change	-.63	5 ft	5	REF			
42282	125.6 to 126.6 feet	Vertical Change	-.71	5 ft	5	REF			
4105	133.3 to 172.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	197	SF	\$120	\$23,640	
53502	145.9 to 146.9 feet	Vertical Change	-.26	5 ft	5	REF			
55948	146.0 to 147.0 feet	Vertical Change	.32	5 ft	5	REF			
47021	155.9 to 156.9 feet	Vertical Change	-.43	5 ft	5	REF			
4109	172.7 to 181.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,160	
52976	175.8 to 176.8 feet	Vertical Change	-.27	5 ft	5	REF			
4111	181.3 to 216.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	175	SF	\$120	\$20,940	
4117	216.2 to 231.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	76	SF	\$120	\$9,060	
4119	231.3 to 303.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	362	SF	\$120	\$43,380	
53948	284.5 to 285.5 feet	Vertical Change	-.25	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211214	AVE 26	GOLF DR W	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
52035	294.6 to 295.6 feet	Vertical Change	-.29	5 ft	5	REF		
4127	303.6 to 375.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	360	SF	\$120	\$43,200
52977	304.5 to 305.5 feet	Vertical Change	-.27	5 ft	5	REF		
52472	334.1 to 335.1 feet	Vertical Change	-.28	5 ft	5	REF		
42764	383.5 to 384.5 feet	Vertical Change	-.66	5 ft	5	SF	\$75	\$375
46345	393.3 to 394.3 feet	Vertical Change	-.46	5 ft	5	REF		
4130	394.0 to 509.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	580	SF	\$120	\$69,540
53949	403.2 to 404.2 feet	Vertical Change	-.25	5 ft	5	REF		
48172	423.1 to 424.1 feet	Vertical Change	-.39	5 ft	5	REF		
49976	442.9 to 443.9 feet	Vertical Change	-.33	5 ft	5	REF		
48173	502.4 to 503.4 feet	Vertical Change	-.39	5 ft	5	REF		
4140	509.9 to 524.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	74	SF	\$120	\$8,940
56908	522.2 to 523.2 feet	Vertical Change	.5	5 ft	5	REF		
4142	524.8 to 535.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,600
51619	531.9 to 532.9 feet	Vertical Change	-.3	5 ft	5	REF		
4145	542.6 to 545.9 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	17	SF	\$120	\$1,980
47259	543.9 to 544.9 feet	Vertical Change	-.42	5 ft	5	REF		
4147	545.9 to 559.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	68	SF	\$120	\$8,160
52978	555.3 to 558.6 feet	Vertical Change	-.27	5 ft	17	REF		
4150	559.5 to 653.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	472	SF	\$120	\$56,640
53503	577.3 to 580.8 feet	Vertical Change	-.26	5 ft	18	REF		
49636	592.0 to 593.0 feet	Vertical Change	-.34	5 ft	5	REF		
53505	597.0 to 598.0 feet	Vertical Change	-.26	5 ft	5	REF		
53950	614.3 to 615.3 feet	Vertical Change	-.25	5 ft	5	REF		
47023	621.6 to 622.6 feet	Vertical Change	-.43	5 ft	5	REF		
55969	621.7 to 622.7 feet	Vertical Change	.36	5 ft	5	REF		
55962	631.5 to 632.5 feet	Vertical Change	.35	5 ft	5	REF		
4160	656.2 to 748.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	461	SF	\$120	\$55,320

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211214	AVE 26	GOLF DR W	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
53506	661.1 to 662.1 feet	Vertical Change	-.26	5 ft	5	REF		
54144	661.1 to 662.1 feet	Vertical Change	.26	5 ft	5	REF		
52473	670.9 to 671.9 feet	Vertical Change	-.28	5 ft	5	REF		
44029	690.7 to 691.7 feet	Vertical Change	-.57	5 ft	5	REF		
50326	710.3 to 711.3 feet	Vertical Change	-.32	5 ft	5	REF		
52474	720.1 to 721.1 feet	Vertical Change	-.28	5 ft	5	REF		
50704	740.1 to 741.1 feet	Vertical Change	-.31	5 ft	5	REF		
53507	749.8 to 750.8 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
4168	751.3 to 764.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,800
48738	759.7 to 760.7 feet	Vertical Change	-.37	5 ft	5	REF		
4170	764.3 to 772.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	40	SF	\$120	\$4,800
4172	772.3 to 808.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	182	SF	\$120	\$21,840
52979	779.3 to 780.3 feet	Vertical Change	-.27	5 ft	5	REF		
53951	789.3 to 790.3 feet	Vertical Change	-.25	5 ft	5	REF		
4174	808.7 to 819.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	55	SF	\$120	\$6,540
56961	809.1 to 810.1 feet	Vertical Change	.56	5 ft	5	REF		
53508	811.7 to 812.7 feet	Vertical Change	-.26	5 ft	5	REF		
4176	819.6 to 824.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700
4177	832.8 to 859.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	132	SF	\$120	\$15,840
4181	859.2 to 871.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	60	SF	\$120	\$7,200
53509	868.5 to 869.5 feet	Vertical Change	-.26	5 ft	5	REF		
4183	871.2 to 888.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,260
4185	888.3 to 892.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	23	SF	\$120	\$2,700
4187	892.8 to 930.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	187	SF	\$120	\$22,440
4191	930.2 to 945.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	79	SF	\$120	\$9,420
4193	945.9 to 1042.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	483	SF	\$120	\$58,020
TOTAL COST FOR: S							side of AVE 26 Starting at: GOLF DR W	\$594,510.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908211230	N FIG TREE BLVD	AVE 26	S LAKE TAHOE DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
48174	2.7 to 3.7 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375	
4204	5.8 to 20.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,760	
49977	20.5 to 21.5 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375	
42468	34.5 to 35.5 feet	Vertical Change	-.69	5 ft	5	SF	\$75	\$375	
49978	65.0 to 66.0 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375	
52475	85.3 to 86.3 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
46120	95.3 to 96.3 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375	
4206	101.2 to 124.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	117	SF	\$120	\$14,040	
49018	118.1 to 121.5 feet	Vertical Change	-.36	5 ft	17	REF			
52980	140.6 to 141.6 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
52476	148.1 to 154.0 feet	Vertical Change	-.28	5 ft	30	LF	\$75	\$2,213	
4208	171.1 to 176.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120	
52477	173.2 to 174.2 feet	Vertical Change	-.28	5 ft	5	REF			
53510	183.1 to 184.1 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
50705	195.6 to 196.6 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
50327	205.6 to 206.6 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
53952	215.5 to 219.0 feet	Vertical Change	-.25	5 ft	18	LF	\$75	\$1,313	
4210	218.7 to 220.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960	
4211	235.8 to 292.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	283	SF	\$120	\$33,960	
53953	240.4 to 241.4 feet	Vertical Change	-.25	5 ft	5	REF			
49322	275.0 to 276.0 feet	Vertical Change	-.35	5 ft	5	REF			
4214	296.7 to 298.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320	
52037	305.4 to 306.4 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
4215	320.5 to 326.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,300	
49637	344.7 to 345.7 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375	
53511	354.8 to 355.8 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
52038	374.3 to 375.3 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
50328	414.0 to 415.0 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908211230	N FIG TREE BLVD	AVE 26	S LAKE TAHOE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
45020	433.9 to 434.9 feet	Vertical Change	-.52	5 ft	5	SF	\$75	\$375
47925	443.9 to 444.9 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375
53512	448.7 to 449.7 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
53954	453.7 to 454.7 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375
4216	466.3 to 490.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	119	SF	\$120	\$14,280
50329	489.2 to 490.2 feet	Vertical Change	-.32	5 ft	5	REF		
49323	494.3 to 505.4 feet	Vertical Change	-.35	5 ft	56	LF	\$75	\$4,163
4217	497.1 to 505.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,920
50330	509.2 to 510.2 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375
53513	516.6 to 517.6 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
53955	526.8 to 527.8 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375
53956	542.1 to 548.0 feet	Vertical Change	-.25	5 ft	30	LF	\$75	\$2,213
52039	552.3 to 560.8 feet	Vertical Change	-.29	5 ft	43	LF	\$75	\$3,188
52480	564.6 to 565.6 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375
4218	568.7 to 577.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$5,040
48175	575.2 to 576.2 feet	Vertical Change	-.39	5 ft	5	REF		
TOTAL COST FOR: E side of N FIG TREE BLVD Starting at: AVE 26							\$111,412.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908211231	S LAKE TAHOE DR	N FIG TREE BLVD	FALLEN LEAF WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
4219	0.0 to 9.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,820
47025	3.5 to 4.5 feet	Vertical Change	-.43	5 ft	5	REF		
50707	18.6 to 19.6 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375
53515	35.1 to 36.1 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
48454	47.7 to 48.7 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375
51620	58.1 to 59.1 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375
52042	85.0 to 86.0 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375
4222	114.9 to 121.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,140
41796	118.0 to 119.0 feet	Vertical Change	-.84	5 ft	5	REF		
4223	128.6 to 157.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	144	SF	\$120	\$17,220
52481	141.4 to 142.4 feet	Vertical Change	-.28	5 ft	5	REF		
52985	146.2 to 147.2 feet	Vertical Change	-.27	5 ft	5	REF		
50708	169.3 to 170.3 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375
52482	179.4 to 180.4 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375
55955	179.5 to 180.5 feet	Vertical Change	.33	5 ft	5	LF	\$75	\$375
52986	199.8 to 200.8 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
52987	219.9 to 220.9 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
54135	239.6 to 240.6 feet	Vertical Change	.25	5 ft	5	LF	\$75	\$375
52988	248.1 to 251.5 feet	Vertical Change	-.27	5 ft	17	LF	\$75	\$1,275
4224	249.6 to 256.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,380
53958	260.8 to 261.8 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375
53959	268.4 to 271.9 feet	Vertical Change	-.25	5 ft	18	REF		
4225	268.9 to 282.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	70	SF	\$120	\$8,340
52483	278.4 to 282.0 feet	Vertical Change	-.28	5 ft	18	REF		
TOTAL COST FOR: N side of S LAKE TAHOE DR Starting at: N FIG TREE BLVD							\$45,675.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
E	1908211234	FALLEN LEAF WAY	S LAKE TAHOE DR	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
4227	0.0 to 6.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	32	SF	\$120	\$3,780	
51621	1.2 to 2.2 feet	Vertical Change	-3	5 ft	5	REF			
4228	6.3 to 38.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	160	SF	\$120	\$19,200	
53516	23.6 to 24.6 feet	Vertical Change	-.26	5 ft	5	REF			
49020	36.1 to 37.1 feet	Vertical Change	-.36	5 ft	5	REF			
4232	79.2 to 101.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	110	SF	\$120	\$13,200	
53960	89.2 to 90.2 feet	Vertical Change	-.25	5 ft	5	REF			
52484	112.2 to 113.2 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
50709	117.1 to 118.1 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
4233	126.4 to 131.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,180	
4234	137.3 to 138.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900	
4235	147.7 to 167.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	101	SF	\$120	\$12,060	
53517	157.3 to 158.3 feet	Vertical Change	-.26	5 ft	5	REF			
53518	174.9 to 175.9 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
4238	179.6 to 201.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	109	SF	\$120	\$13,020	
53519	183.3 to 184.3 feet	Vertical Change	-.26	5 ft	5	REF			
4240	214.1 to 221.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,560	
4241	226.3 to 238.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,440	
4242	295.6 to 309.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	67	SF	\$120	\$8,040	
41399	324.3 to 325.3 feet	Vertical Change	-1.27	5 ft	5	SF	\$75	\$375	
57448	324.3 to 325.3 feet	Vertical Change	1.32	5 ft	5	SF	\$75	\$375	
4243	326.8 to 328.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	9	SF	\$120	\$1,080	
41467	327.2 to 328.2 feet	Vertical Change	-1.13	5 ft	5	REF			
52485	345.9 to 347.0 feet	Vertical Change	-.28	5 ft	6	LF	\$75	\$413	
41468	351.3 to 352.3 feet	Vertical Change	-1.13	5 ft	5	SF	\$75	\$375	
57339	351.3 to 352.3 feet	Vertical Change	.97	5 ft	5	SF	\$75	\$375	
47026	369.0 to 370.0 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375	
4244	371.8 to 382.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,300	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908211234	FALLEN LEAF WAY	S LAKE TAHOE DR	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
4245	392.8 to 398.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,300
52990	397.1 to 398.1 feet	Vertical Change	-27	5 ft	5	REF		
4246	429.8 to 430.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
4247	435.4 to 627.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	963	SF	\$120	\$115,500
49324	449.0 to 450.0 feet	Vertical Change	-.35	5 ft	5	REF		
50710	488.5 to 489.5 feet	Vertical Change	-.31	5 ft	5	REF		
51622	508.6 to 509.6 feet	Vertical Change	-.3	5 ft	5	REF		
52991	540.1 to 541.1 feet	Vertical Change	-.27	5 ft	5	REF		
52992	544.7 to 545.7 feet	Vertical Change	-.27	5 ft	5	REF		
50331	549.7 to 550.7 feet	Vertical Change	-.32	5 ft	5	REF		
52486	569.3 to 570.3 feet	Vertical Change	-.28	5 ft	5	REF		
46346	588.8 to 589.8 feet	Vertical Change	-.46	5 ft	5	REF		
52487	638.8 to 639.8 feet	Vertical Change	-.28	5 ft	5	REF		
4252	639.2 to 660.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	106	SF	\$120	\$12,780
49325	648.8 to 649.8 feet	Vertical Change	-.35	5 ft	5	REF		
52993	668.4 to 669.4 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
4253	670.7 to 699.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	145	SF	\$120	\$17,400
52044	676.0 to 686.9 feet	Vertical Change	-.29	5 ft	55	REF		
4254	740.0 to 744.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,820
4255	751.3 to 779.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	140	SF	\$120	\$16,800
4257	787.6 to 809.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	111	SF	\$120	\$13,260
4259	816.9 to 906.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	450	SF	\$120	\$53,940
52994	876.4 to 877.4 feet	Vertical Change	-.27	5 ft	5	REF		
52046	903.8 to 904.8 feet	Vertical Change	-.29	5 ft	5	REF		

TOTAL COST FOR: E side of FALLEN LEAF WAY Starting at: S LAKE TAHOE DR \$332,947.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908211237	FALLEN LEAF WAY	SIDEWALK BEGINS	S LAKE TAHOE DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
4266	0.0 to 1.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020	
41281	0.6 to 1.6 feet	Vertical Change	-1.65	5 ft	5	REF			
49326	2.8 to 16.4 feet	Vertical Change	-.35	5 ft	68	LF	\$75	\$5,100	
4267	11.9 to 13.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780	
43380	18.0 to 19.0 feet	Vertical Change	-.61	5 ft	5	REF			
4268	18.2 to 36.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	93	SF	\$120	\$11,100	
52995	20.6 to 26.8 feet	Vertical Change	-.27	5 ft	31	REF			
41589	38.4 to 39.4 feet	Vertical Change	-.99	5 ft	5	SF	\$75	\$375	
50332	48.7 to 49.7 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
4269	51.7 to 65.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	71	SF	\$120	\$8,520	
47926	58.7 to 59.7 feet	Vertical Change	-.4	5 ft	5	REF			
4270	68.9 to 70.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,140	
41703	79.1 to 80.1 feet	Vertical Change	-.89	5 ft	5	SF	\$75	\$375	
42385	94.6 to 95.6 feet	Vertical Change	-.7	5 ft	5	SF	\$75	\$375	
53522	97.2 to 98.2 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
53523	102.1 to 103.1 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
42082	104.6 to 105.6 feet	Vertical Change	-.75	5 ft	5	SF	\$75	\$375	
53524	107.3 to 108.3 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
52996	112.4 to 113.4 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
44840	115.1 to 116.1 feet	Vertical Change	-.53	5 ft	5	SF	\$75	\$375	
4271	120.3 to 132.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	61	SF	\$120	\$7,260	
48456	125.3 to 126.3 feet	Vertical Change	-.38	5 ft	5	REF			
53525	130.4 to 131.4 feet	Vertical Change	-.26	5 ft	5	REF			
47509	135.4 to 138.7 feet	Vertical Change	-.41	5 ft	16	LF	\$75	\$1,238	
52997	142.8 to 143.8 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
42178	145.5 to 146.5 feet	Vertical Change	-.73	5 ft	5	SF	\$75	\$375	
46347	155.6 to 156.6 feet	Vertical Change	-.46	5 ft	5	LF	\$75	\$375	
52489	165.7 to 166.7 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908211237	FALLEN LEAF WAY	SIDEWALK BEGINS	S LAKE TAHOE DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
45705	176.3 to 177.3 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$375	
49327	186.3 to 187.3 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$375	
55975	193.2 to 194.2 feet	Vertical Change	.37	5 ft	5	LF	\$75	\$375	
52048	193.3 to 194.3 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
52490	207.3 to 208.3 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
52998	214.8 to 218.4 feet	Vertical Change	-.27	5 ft	18	LF	\$75	\$1,350	
41740	227.6 to 228.6 feet	Vertical Change	-.87	5 ft	5	SF	\$75	\$375	
42469	237.9 to 238.9 feet	Vertical Change	-.69	5 ft	5	SF	\$75	\$375	
53526	240.5 to 249.0 feet	Vertical Change	-.26	5 ft	43	LF	\$75	\$3,188	
44637	258.1 to 259.1 feet	Vertical Change	-.54	5 ft	5	SF	\$75	\$375	
48457	268.5 to 269.5 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375	
52491	276.3 to 279.8 feet	Vertical Change	-.28	5 ft	18	LF	\$75	\$1,313	
41936	289.2 to 290.2 feet	Vertical Change	-.79	5 ft	5	SF	\$75	\$375	
52999	291.8 to 300.6 feet	Vertical Change	-.27	5 ft	44	LF	\$75	\$3,300	
53962	307.6 to 308.6 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375	
43103	310.2 to 311.2 feet	Vertical Change	-.63	5 ft	5	SF	\$75	\$375	
53000	315.3 to 316.3 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
45021	320.3 to 321.3 feet	Vertical Change	-.52	5 ft	5	SF	\$75	\$375	
52493	327.8 to 338.9 feet	Vertical Change	-.28	5 ft	56	LF	\$75	\$4,163	
42765	340.4 to 341.4 feet	Vertical Change	-.66	5 ft	5	SF	\$75	\$375	
49021	347.3 to 348.3 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375	
44638	350.5 to 351.5 feet	Vertical Change	-.54	5 ft	5	SF	\$75	\$375	
57922	352.9 to 396.2 feet	Driveway				REF			
4272	353.7 to 360.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	35	SF	\$40	\$1,400	
44639	354.7 to 355.7 feet	Vertical Change	-.54	5 ft	5	REF			
56973	354.8 to 355.8 feet	Vertical Change	.57	5 ft	5	REF			
43232	356.2 to 357.2 feet	Vertical Change	-.62	5 ft	5	REF			
4273	366.4 to 374.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	39	SF	\$40	\$1,560	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
W	1908211237	FALLEN LEAF WAY	SIDEWALK BEGINS	S LAKE TAHOE DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
43104	366.8 to 367.8 feet	Vertical Change	-.63	5 ft	5	REF			
47260	377.1 to 378.1 feet	Vertical Change	-.42	5 ft	5	REF			
43381	387.5 to 388.5 feet	Vertical Change	-.61	5 ft	5	REF			
4274	396.4 to 404.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	43	SF	\$40	\$1,700	
45212	398.0 to 400.6 feet	Vertical Change	-.51	5 ft	13	REF			
56962	399.7 to 400.7 feet	Vertical Change	.56	5 ft	5	REF			
41624	403.7 to 404.7 feet	Vertical Change	-.95	5 ft	5	REF			
50333	412.4 to 413.4 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
46568	419.1 to 420.1 feet	Vertical Change	-.45	5 ft	5	LF	\$75	\$375	
53963	424.2 to 427.7 feet	Vertical Change	-.25	5 ft	18	LF	\$75	\$1,313	
41537	429.3 to 430.3 feet	Vertical Change	-1.04	5 ft	5	SF	\$75	\$375	
42228	439.7 to 440.7 feet	Vertical Change	-.72	5 ft	5	SF	\$75	\$375	
52494	442.4 to 448.4 feet	Vertical Change	-.28	5 ft	30	LF	\$75	\$2,250	
42766	450.1 to 451.1 feet	Vertical Change	-.66	5 ft	5	SF	\$75	\$375	
42666	460.2 to 461.2 feet	Vertical Change	-.67	5 ft	5	SF	\$75	\$375	
41269	470.6 to 471.6 feet	Vertical Change	-1.72	5 ft	5	SF	\$75	\$375	
44412	480.8 to 481.8 feet	Vertical Change	-.55	5 ft	5	SF	\$75	\$375	
43105	491.1 to 492.1 feet	Vertical Change	-.63	5 ft	5	SF	\$75	\$375	
45908	501.2 to 502.2 feet	Vertical Change	-.48	5 ft	5	LF	\$75	\$375	
41625	511.8 to 512.8 feet	Vertical Change	-.95	5 ft	5	SF	\$75	\$375	
43382	521.9 to 522.9 feet	Vertical Change	-.61	5 ft	5	SF	\$75	\$375	
44842	532.3 to 533.3 feet	Vertical Change	-.53	5 ft	5	SF	\$75	\$375	
43233	542.7 to 543.7 feet	Vertical Change	-.62	5 ft	5	SF	\$75	\$375	
41834	552.7 to 553.7 feet	Vertical Change	-.82	5 ft	5	SF	\$75	\$375	
42038	563.1 to 564.1 feet	Vertical Change	-.76	5 ft	5	SF	\$75	\$375	
48458	573.2 to 576.8 feet	Vertical Change	-.38	5 ft	18	LF	\$75	\$1,350	
44640	583.3 to 584.3 feet	Vertical Change	-.54	5 ft	5	SF	\$75	\$375	
4277	587.8 to 592.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908211237	FALLEN LEAF WAY	SIDEWALK BEGINS	S LAKE TAHOE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
52051	592.7 to 593.8 feet	Vertical Change	-0.29	5 ft	5	LF	\$75	\$413
42667	602.4 to 603.4 feet	Vertical Change	-0.67	5 ft	5	SF	\$75	\$375
44207	612.0 to 613.0 feet	Vertical Change	-0.56	5 ft	5	SF	\$75	\$375
46815	621.5 to 622.5 feet	Vertical Change	-0.44	5 ft	5	LF	\$75	\$375
57923	627.8 to 675.9 feet	Driveway				REF		
41386	628.3 to 629.3 feet	Vertical Change	-1.31	5 ft	5	REF		
41634	631.5 to 632.5 feet	Vertical Change	-0.94	5 ft	5	REF		
45022	636.9 to 637.9 feet	Vertical Change	-0.52	5 ft	5	REF		
4278	643.1 to 644.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200
42083	646.9 to 647.9 feet	Vertical Change	-0.75	5 ft	5	REF		
42229	656.6 to 657.6 feet	Vertical Change	-0.72	5 ft	5	REF		
4279	666.2 to 670.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	20	SF	\$40	\$800
42880	666.3 to 667.3 feet	Vertical Change	-0.65	5 ft	5	REF		
45496	675.8 to 676.8 feet	Vertical Change	-0.5	5 ft	5	REF		
4280	677.7 to 680.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560
41283	681.2 to 682.2 feet	Vertical Change	-1.64	5 ft	5	SF	\$75	\$375
53532	685.6 to 686.6 feet	Vertical Change	-0.26	5 ft	5	LF	\$75	\$375
44208	690.5 to 691.5 feet	Vertical Change	-0.56	5 ft	5	SF	\$75	\$375
42084	700.2 to 701.2 feet	Vertical Change	-0.75	5 ft	5	SF	\$75	\$375
53533	702.6 to 706.0 feet	Vertical Change	-0.26	5 ft	17	LF	\$75	\$1,275
43383	709.7 to 712.9 feet	Vertical Change	-0.61	5 ft	16	SF	\$75	\$1,200
43567	717.7 to 720.5 feet	Vertical Change	-0.6	5 ft	14	SF	\$75	\$1,050
46816	729.1 to 730.1 feet	Vertical Change	-0.44	5 ft	5	LF	\$75	\$375
43106	738.7 to 739.7 feet	Vertical Change	-0.63	5 ft	5	SF	\$75	\$375
42881	748.4 to 749.4 feet	Vertical Change	-0.65	5 ft	5	SF	\$75	\$375
44030	757.9 to 758.9 feet	Vertical Change	-0.57	5 ft	5	SF	\$75	\$375
45706	762.4 to 766.1 feet	Vertical Change	-0.49	5 ft	19	LF	\$75	\$1,388
57924	764.8 to 803.3 feet	Driveway				REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority		
W	1908211237	FALLEN LEAF WAY	SIDEWALK BEGINS	S LAKE TAHOE DR					TBD		
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
41339	767.8 to 768.8 feet	Vertical Change	-1.41	5 ft	5	REF					
4281	768.4 to 773.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	24	SF	\$40	\$940			
53534	770.1 to 772.1 feet	Vertical Change	-.26	5 ft	10	REF					
56940	771.2 to 772.2 feet	Vertical Change	.54	5 ft	5	REF					
44209	773.3 to 774.3 feet	Vertical Change	-.56	5 ft	5	REF					
53535	780.7 to 781.7 feet	Vertical Change	-.26	5 ft	5	REF					
43234	783.1 to 784.1 feet	Vertical Change	-.62	5 ft	5	REF					
53002	785.6 to 791.8 feet	Vertical Change	-.27	5 ft	31	REF					
42179	793.2 to 794.2 feet	Vertical Change	-.73	5 ft	5	REF					
53005	795.2 to 798.7 feet	Vertical Change	-.27	5 ft	18	REF					
44843	802.6 to 805.0 feet	Vertical Change	-.53	5 ft	12	REF					
4282	807.2 to 811.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,460			
41413	808.0 to 809.0 feet	Vertical Change	-1.24	5 ft	5	REF					
47927	812.4 to 815.9 feet	Vertical Change	-.4	5 ft	18	LF	\$75	\$1,313			
42668	821.8 to 822.8 feet	Vertical Change	-.67	5 ft	5	SF	\$75	\$375			
42283	831.9 to 832.9 feet	Vertical Change	-.71	5 ft	5	SF	\$75	\$375			
43235	841.9 to 842.9 feet	Vertical Change	-.62	5 ft	5	SF	\$75	\$375			
41313	851.9 to 852.9 feet	Vertical Change	-1.52	5 ft	5	SF	\$75	\$375			
42988	862.0 to 863.0 feet	Vertical Change	-.64	5 ft	5	SF	\$75	\$375			
43705	872.1 to 873.1 feet	Vertical Change	-.59	5 ft	5	SF	\$75	\$375			
44210	882.1 to 883.1 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375			
42386	892.2 to 893.2 feet	Vertical Change	-.7	5 ft	5	SF	\$75	\$375			
50713	901.5 to 902.5 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375			
41508	903.5 to 904.5 feet	Vertical Change	-1.08	5 ft	5	SF	\$75	\$375			
4283	905.3 to 907.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200			
41891	907.2 to 908.2 feet	Vertical Change	-.8	5 ft	5	REF					
TOTAL COST FOR: W							<i>side of</i>	FALLEN LEAF WAY	<i>Starting at:</i>	SIDEWALK BEGINS	\$101,415.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908211240	S LAKE TAHOE DR	FALLEN LEAF WAY	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
4284	1.5 to 4.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,980	
43857	2.0 to 3.0 feet	Vertical Change	-.58	5 ft	5	REF			
51629	11.0 to 12.0 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
46348	18.9 to 19.9 feet	Vertical Change	-.46	5 ft	5	LF	\$75	\$375	
44211	26.5 to 27.5 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375	
54158	34.7 to 35.7 feet	Vertical Change	.28	5 ft	5	LF	\$75	\$375	
43568	36.7 to 37.7 feet	Vertical Change	-.6	5 ft	5	SF	\$75	\$375	
42230	47.0 to 48.0 feet	Vertical Change	-.72	5 ft	5	SF	\$75	\$375	
41447	57.0 to 58.0 feet	Vertical Change	-1.16	5 ft	5	SF	\$75	\$375	
45707	67.5 to 68.5 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$375	
47261	77.6 to 78.6 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375	
45909	87.9 to 88.9 feet	Vertical Change	-.48	5 ft	5	LF	\$75	\$375	
47512	95.0 to 97.5 feet	Vertical Change	-.41	5 ft	13	LF	\$75	\$938	
57925	95.8 to 132.2 feet	Driveway				REF			
41695	98.0 to 99.0 feet	Vertical Change	-.9	5 ft	5	REF			
4285	98.5 to 106.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	41	SF	\$40	\$1,620	
44642	101.9 to 104.7 feet	Vertical Change	-.54	5 ft	14	REF			
52053	105.7 to 111.6 feet	Vertical Change	-.29	5 ft	30	REF			
43384	113.1 to 114.1 feet	Vertical Change	-.61	5 ft	5	REF			
52497	115.1 to 121.2 feet	Vertical Change	-.28	5 ft	31	REF			
41937	122.6 to 123.6 feet	Vertical Change	-.79	5 ft	5	REF			
52054	124.7 to 130.1 feet	Vertical Change	-.29	5 ft	27	REF			
4286	131.4 to 138.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	36	SF	\$40	\$1,460	
42085	131.7 to 132.7 feet	Vertical Change	-.75	5 ft	5	REF			
53536	134.5 to 135.5 feet	Vertical Change	-.26	5 ft	5	REF			
41469	137.6 to 138.6 feet	Vertical Change	-1.13	5 ft	5	REF			
57378	137.7 to 138.7 feet	Vertical Change	1.09	5 ft	5	REF			
53537	139.5 to 140.5 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908211240	S LAKE TAHOE DR	FALLEN LEAF WAY	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
44212	146.5 to 147.5 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375	
49979	154.6 to 155.6 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375	
42180	165.2 to 166.2 feet	Vertical Change	-.73	5 ft	5	SF	\$75	\$375	
41405	175.3 to 176.3 feet	Vertical Change	-1.25	5 ft	5	SF	\$75	\$375	
4287	185.5 to 198.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	66	SF	\$120	\$7,860	
43236	185.6 to 186.6 feet	Vertical Change	-.62	5 ft	5	REF			
43385	196.0 to 197.0 feet	Vertical Change	-.61	5 ft	5	REF			
43706	206.3 to 207.3 feet	Vertical Change	-.59	5 ft	5	SF	\$75	\$375	
45497	216.5 to 217.5 feet	Vertical Change	-.5	5 ft	5	SF	\$75	\$375	
42882	226.8 to 227.8 feet	Vertical Change	-.65	5 ft	5	SF	\$75	\$375	
4288	228.8 to 241.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,800	
45024	237.2 to 238.2 feet	Vertical Change	-.52	5 ft	5	REF			
41696	257.4 to 258.4 feet	Vertical Change	-.9	5 ft	5	SF	\$75	\$375	
42556	267.6 to 268.6 feet	Vertical Change	-.68	5 ft	5	SF	\$75	\$375	
45708	277.9 to 278.9 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$375	
51630	288.3 to 289.3 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
46349	293.3 to 294.3 feet	Vertical Change	-.46	5 ft	5	LF	\$75	\$375	
57926	295.3 to 334.5 feet	Driveway				REF			
41646	298.5 to 299.5 feet	Vertical Change	-.93	5 ft	5	REF			
49640	304.0 to 305.0 feet	Vertical Change	-.34	5 ft	5	REF			
42181	314.5 to 315.5 feet	Vertical Change	-.73	5 ft	5	REF			
43569	325.1 to 326.1 feet	Vertical Change	-.6	5 ft	5	REF			
45709	335.7 to 336.7 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$375	
41346	341.2 to 342.2 feet	Vertical Change	-1.4	5 ft	5	SF	\$75	\$375	
46570	346.8 to 347.8 feet	Vertical Change	-.45	5 ft	5	LF	\$75	\$375	
41470	356.9 to 357.9 feet	Vertical Change	-1.13	5 ft	5	SF	\$75	\$375	
42039	367.1 to 368.1 feet	Vertical Change	-.76	5 ft	5	SF	\$75	\$375	
42008	377.5 to 378.5 feet	Vertical Change	-.77	5 ft	5	SF	\$75	\$375	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908211240	S LAKE TAHOE DR	FALLEN LEAF WAY	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
43707	387.8 to 388.8 feet	Vertical Change	-.59	5 ft	5	SF	\$75	\$375	
50715	398.1 to 399.1 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
4289	401.3 to 402.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780	
4290	404.7 to 405.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660	
42883	408.4 to 409.4 feet	Vertical Change	-.65	5 ft	5	SF	\$75	\$375	
4291	415.7 to 417.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200	
43386	418.5 to 419.5 feet	Vertical Change	-.61	5 ft	5	SF	\$75	\$375	
44031	429.1 to 430.1 feet	Vertical Change	-.57	5 ft	5	SF	\$75	\$375	
41425	439.4 to 440.4 feet	Vertical Change	-1.21	5 ft	5	SF	\$75	\$375	
43858	449.7 to 450.7 feet	Vertical Change	-.58	5 ft	5	SF	\$75	\$375	
42124	460.0 to 461.0 feet	Vertical Change	-.74	5 ft	5	SF	\$75	\$375	
41557	470.2 to 471.2 feet	Vertical Change	-1.01	5 ft	5	SF	\$75	\$375	
53007	480.3 to 481.3 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
45498	490.8 to 491.8 feet	Vertical Change	-.5	5 ft	5	SF	\$75	\$375	
52056	500.8 to 501.8 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
52057	505.8 to 506.8 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
44844	511.1 to 512.1 feet	Vertical Change	-.53	5 ft	5	SF	\$75	\$375	
50716	516.2 to 517.2 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
57927	518.4 to 560.3 feet	Driveway				REF			
41305	521.4 to 522.4 feet	Vertical Change	-1.55	5 ft	5	REF			
4292	525.0 to 530.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	30	SF	\$40	\$1,180	
45910	526.2 to 527.2 feet	Vertical Change	-.48	5 ft	5	REF			
44413	535.9 to 536.9 feet	Vertical Change	-.55	5 ft	5	REF			
49022	545.4 to 546.4 feet	Vertical Change	-.36	5 ft	5	REF			
45911	555.0 to 556.0 feet	Vertical Change	-.48	5 ft	5	REF			
41347	560.8 to 561.8 feet	Vertical Change	-1.4	5 ft	5	SF	\$75	\$375	
53008	563.3 to 566.6 feet	Vertical Change	-.27	5 ft	17	LF	\$75	\$1,238	
4293	566.4 to 567.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908211240	S LAKE TAHOE DR	FALLEN LEAF WAY	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41763	570.7 to 571.7 feet	Vertical Change	-.86	5 ft	5	SF	\$75	\$375
TOTAL COST FOR: N side of S LAKE TAHOE DR Starting at: FALLEN LEAF WAY							\$44,685.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908211244	S LAKE TAHOE DR	SIDEWALK BEGINS	N FIG TREE BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
53009	3.9 to 4.9 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
47027	12.3 to 13.3 feet	Vertical Change	-.43	5 ft	5	REF			
4294	12.3 to 13.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660	
57164	12.8 to 13.8 feet	Vertical Change	.69	5 ft	5	REF			
43237	12.9 to 13.9 feet	Vertical Change	-.62	5 ft	5	REF			
53010	20.6 to 21.6 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
4295	31.2 to 34.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160	
48739	41.4 to 42.4 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375	
43107	51.5 to 52.5 feet	Vertical Change	-.63	5 ft	5	SF	\$75	\$375	
48740	101.5 to 102.5 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375	
4296	108.7 to 136.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	141	SF	\$120	\$16,920	
53011	121.7 to 122.7 feet	Vertical Change	-.27	5 ft	5	REF			
49328	131.7 to 132.7 feet	Vertical Change	-.35	5 ft	5	REF			
4297	154.7 to 156.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020	
53966	174.7 to 175.7 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375	
4298	186.9 to 205.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	93	SF	\$120	\$11,100	
4300	209.0 to 220.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,020	
4302	225.2 to 232.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,080	
53538	250.7 to 251.7 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
53539	258.3 to 259.3 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
4304	273.2 to 292.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	95	SF	\$120	\$11,340	
52058	304.0 to 305.0 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
4306	413.2 to 452.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	198	SF	\$120	\$23,700	
47513	426.4 to 427.4 feet	Vertical Change	-.41	5 ft	5	REF			
4307	455.0 to 456.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
52059	456.9 to 457.9 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
53540	466.7 to 467.7 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
4308	476.6 to 538.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	308	SF	\$120	\$36,900	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908211244	S LAKE TAHOE DR	SIDEWALK BEGINS	N FIG TREE BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
49023	517.6 to 518.6 feet	Vertical Change	-.36	5 ft	5	REF		
4310	571.0 to 583.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,440
52060	572.0 to 573.0 feet	Vertical Change	-.29	5 ft	5	REF		
52500	677.0 to 678.0 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375
4311	717.4 to 753.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	181	SF	\$120	\$21,720
4314	756.9 to 765.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$4,980
53012	760.0 to 765.8 feet	Vertical Change	-.27	5 ft	29	REF		
52061	769.9 to 778.5 feet	Vertical Change	-.29	5 ft	43	LF	\$75	\$3,225
4315	771.4 to 776.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760
49641	782.6 to 783.6 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375
51632	790.2 to 791.2 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375
51633	798.1 to 799.1 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375
49025	808.1 to 809.1 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375
4317	814.3 to 822.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,680
4318	891.9 to 895.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340
49329	894.6 to 895.6 feet	Vertical Change	-.35	5 ft	5	REF		

TOTAL COST FOR: S side of S LAKE TAHOE DR Starting at: SIDEWALK BEGINS \$169,125.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908211246	N FIG TREE BLVD	S LAKE TAHOE DR	AVE 26					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
4319	3.5 to 6.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680	
51634	66.8 to 67.8 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
50336	97.5 to 98.5 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
4320	100.2 to 128.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	143	SF	\$120	\$17,160	
49026	128.3 to 129.3 feet	Vertical Change	-.36	5 ft	5	REF			
4321	130.9 to 133.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260	
53014	138.6 to 139.6 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
47028	200.4 to 201.4 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375	
4322	228.3 to 234.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,540	
4323	268.2 to 270.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200	
4324	304.3 to 313.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,760	
52501	317.5 to 321.0 feet	Vertical Change	-.28	5 ft	18	LF	\$75	\$1,313	
52503	330.1 to 331.1 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
51635	348.5 to 352.0 feet	Vertical Change	-.3	5 ft	18	LF	\$75	\$1,313	
53015	356.5 to 362.5 feet	Vertical Change	-.27	5 ft	30	LF	\$75	\$2,250	
4325	363.6 to 366.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560	
52504	371.8 to 372.8 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
53017	382.1 to 383.1 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
53542	387.4 to 391.1 feet	Vertical Change	-.26	5 ft	19	LF	\$75	\$1,388	
4326	398.8 to 404.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,660	
52063	400.4 to 404.1 feet	Vertical Change	-.29	5 ft	19	REF			
53543	428.8 to 429.8 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
43570	456.8 to 457.8 feet	Vertical Change	-.6	5 ft	5	SF	\$75	\$375	
53544	461.9 to 462.9 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
52064	474.5 to 475.5 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
52065	487.3 to 488.3 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
55941	487.4 to 488.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
4327	496.7 to 567.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	354	SF	\$120	\$42,480	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908211246	N FIG TREE BLVD	S LAKE TAHOE DR	AVE 26	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46817	528.0 to 529.0 feet	Vertical Change	-.44	5 ft	5	REF		
44845	567.9 to 568.9 feet	Vertical Change	-.53	5 ft	5	SF	\$75	\$375
50337	577.8 to 578.8 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375
4334	598.9 to 606.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,740
TOTAL COST FOR: W side of N FIG TREE BLVD Starting at: S LAKE TAHOE DR							\$94,927.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1908211444	TRINITY AVE	1ST ST	2ND ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
4336	4.3 to 302.8 feet	Cross Slope (PAR)	2.0-3.0%	12 ft	3433	SF	\$120	\$411,930
43859	5.4 to 6.4 feet	Vertical Change	-.58	12 ft	12	REF		
47262	35.6 to 36.6 feet	Vertical Change	-.42	12 ft	12	REF		
52506	65.8 to 66.8 feet	Vertical Change	-.28	12 ft	12	REF		
44213	95.8 to 96.8 feet	Vertical Change	-.56	12 ft	12	REF		
53018	104.7 to 105.7 feet	Vertical Change	-.27	12 ft	12	REF		
46350	114.9 to 115.9 feet	Vertical Change	-.46	12 ft	12	REF		
47263	120.9 to 121.9 feet	Vertical Change	-.42	12 ft	12	REF		
49642	124.0 to 126.8 feet	Vertical Change	-.34	12 ft	32	REF		
45912	134.8 to 135.8 feet	Vertical Change	-.48	12 ft	12	REF		
46351	143.9 to 144.9 feet	Vertical Change	-.46	12 ft	12	REF		
47264	161.2 to 162.2 feet	Vertical Change	-.42	12 ft	12	REF		
45913	164.3 to 165.3 feet	Vertical Change	-.48	12 ft	12	REF		
42767	186.0 to 187.0 feet	Vertical Change	-.66	12 ft	12	REF		
44414	216.3 to 217.3 feet	Vertical Change	-.55	12 ft	12	REF		
57929	243.3 to 282.1 feet	Driveway				REF		
49982	244.6 to 245.6 feet	Vertical Change	-.33	12 ft	12	REF		
50717	294.7 to 295.7 feet	Vertical Change	-.31	12 ft	12	REF		
TOTAL COST FOR: NW side of TRINITY AVE Starting at: 1ST ST								\$411,930.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NE	1908211449	2ND ST	TRINITY AVE	ROBERTSON BLVD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
4350	3.9 to 50.9 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	447	SF	\$120	\$53,580	
4358	62.8 to 96.9 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	324	SF	\$120	\$38,874	
53545	73.5 to 74.5 feet	Vertical Change	-.26	10 ft	10	REF			
55987	83.0 to 84.0 feet	Vertical Change	.39	10 ft	10	REF			
4362	101.4 to 105.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	40	SF	\$120	\$4,788	
4363	118.6 to 129.5 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	104	SF	\$120	\$12,426	
57930	137.7 to 172.8 feet	Driveway				REF			
50338	140.3 to 141.3 feet	Vertical Change	-.32	10 ft	10	REF			
4364	141.6 to 142.6 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	10	SF	\$40	\$380	
4365	145.9 to 149.8 feet	Cross Slope (Driveway)	8.0-9.0%	10 ft	37	SF	\$40	\$1,482	
4367	149.8 to 152.4 feet	Cross Slope (Driveway)	6.0-7.0%	10 ft	25	SF	\$40	\$988	
4368	152.4 to 161.8 feet	Cross Slope (Driveway)	5.0-6.0%	10 ft	89	SF	\$40	\$3,572	
50718	156.5 to 157.5 feet	Vertical Change	-.31	10 ft	10	REF			
4371	161.8 to 167.6 feet	Cross Slope (Driveway)	6.0-7.0%	10 ft	55	SF	\$40	\$2,204	
40107	164.8 to 168.2 feet	Running Slope	5.0-6.0%	10 ft	32	REF			
4372	167.6 to 169.9 feet	Cross Slope (Driveway)	5.0-6.0%	10 ft	22	SF	\$40	\$874	
4374	169.9 to 170.9 feet	Cross Slope (Driveway)	3.0-4.0%	10 ft	10	SF	\$40	\$380	
4375	170.9 to 172.7 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	17	SF	\$40	\$684	
42669	174.9 to 175.9 feet	Vertical Change	-.67	10 ft	10	SF	\$75	\$713	
4376	176.5 to 180.1 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	34	SF	\$120	\$4,104	
4377	182.3 to 183.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	12	SF	\$120	\$1,482	
45214	183.5 to 184.5 feet	Vertical Change	-.51	10 ft	10	REF			
44415	192.6 to 193.6 feet	Vertical Change	-.55	10 ft	10	SF	\$75	\$713	
50339	195.8 to 196.8 feet	Vertical Change	-.32	10 ft	10	LF	\$75	\$713	
49643	208.0 to 209.0 feet	Vertical Change	-.34	10 ft	10	LF	\$75	\$713	
4378	216.2 to 253.4 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	353	SF	\$120	\$42,408	
53019	240.9 to 241.9 feet	Vertical Change	-.27	10 ft	10	REF			
50340	252.9 to 253.9 feet	Vertical Change	-.32	10 ft	10	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1908211449	2ND ST	TRINITY AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
4383	265.7 to 276.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	105	SF	\$120	\$12,540
50719	267.9 to 268.9 feet	Vertical Change	-.31	10 ft	10	REF		
46571	271.5 to 274.4 feet	Vertical Change	-.45	10 ft	28	REF		
53546	276.7 to 277.7 feet	Vertical Change	-.26	10 ft	10	REF		
4386	290.3 to 308.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	168	SF	\$120	\$20,178
TOTAL COST FOR: NE side of 2ND ST Starting at: TRINITY AVE							\$203,794.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1908211451	2ND ST	ROBERTSON BLVD	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
4387	0.0 to 4.4 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	42	SF	\$120	\$5,016
4388	4.4 to 6.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	23	SF	\$120	\$2,736
51636	38.7 to 39.7 feet	Vertical Change	-3	10 ft	10	LF	\$75	\$713
4389	65.0 to 67.5 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	24	SF	\$120	\$2,850
57931	99.1 to 139.3 feet	Driveway				REF		
4390	106.7 to 139.3 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	310	SF	\$40	\$12,388
TOTAL COST FOR: NE side of 2ND ST Starting at: ROBERTSON BLVD								\$23,702.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1908211455	ROBERTSON-TRINITY	3RD ST	2ND ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
4393	0.0 to 1.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,122	
42232	0.4 to 1.4 feet	Vertical Change	-72	6 ft	6	REF			
4394	1.7 to 34.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	182	SF	\$120	\$21,846	
43708	7.1 to 8.1 feet	Vertical Change	-59	6 ft	6	REF			
42284	14.1 to 17.4 feet	Vertical Change	-71	6 ft	18	REF			
49983	20.7 to 21.7 feet	Vertical Change	-33	6 ft	6	REF			
41368	23.9 to 25.8 feet	Vertical Change	-1.36	6 ft	10	REF			
48741	25.0 to 26.0 feet	Vertical Change	-37	6 ft	6	REF			
46818	30.6 to 31.6 feet	Vertical Change	-44	6 ft	6	REF			
4397	47.4 to 51.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772	
42989	50.6 to 51.6 feet	Vertical Change	-64	6 ft	6	REF			
49984	56.9 to 57.9 feet	Vertical Change	-33	6 ft	6	REF			
41720	57.1 to 58.1 feet	Vertical Change	-88	6 ft	6	REF			
4398	57.7 to 72.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	82	SF	\$120	\$9,834	
22	57.9 to 58.9 feet	Continuous Width		6 ft	6	SF	\$120	\$660	
51637	58.1 to 59.1 feet	Vertical Change	-3	6 ft	6	REF			
42387	70.3 to 71.3 feet	Vertical Change	-7	6 ft	6	REF			
45215	74.2 to 75.7 feet	Vertical Change	-51	6 ft	8	SF	\$75	\$619	
4400	79.0 to 93.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	79	SF	\$120	\$9,438	
42670	90.2 to 91.2 feet	Vertical Change	-67	6 ft	6	REF			
23	120.3 to 121.3 feet	Continuous Width		6 ft	6	SF	\$120	\$660	
43860	120.9 to 121.9 feet	Vertical Change	-58	6 ft	6	REF			
4404	121.9 to 125.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	21	SF	\$120	\$2,574	
4405	125.8 to 203.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	429	SF	\$120	\$51,480	
53020	127.5 to 128.5 feet	Vertical Change	-27	6 ft	6	REF			
51638	137.7 to 138.7 feet	Vertical Change	-3	6 ft	6	REF			
45216	147.5 to 148.5 feet	Vertical Change	-51	6 ft	6	REF			
43239	151.8 to 153.2 feet	Vertical Change	-62	6 ft	8	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908211455	ROBERTSON-TRINITY	3RD ST	2ND ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
45710	157.7 to 158.7 feet	Vertical Change	-.49	6 ft	6	REF		
42040	177.6 to 178.6 feet	Vertical Change	-.76	6 ft	6	REF		
41452	187.6 to 188.6 feet	Vertical Change	-1.15	6 ft	6	REF		
42884	189.0 to 190.5 feet	Vertical Change	-.65	6 ft	8	REF		
43241	197.5 to 198.5 feet	Vertical Change	-.62	6 ft	6	REF		
TOTAL COST FOR: SE side of ROBERTSON-TRINITY Starting at: 3RD ST							\$101,004.75	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1908211457	2ND ST	ROBERTSON-TRINITY	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
4418	0.0 to 6.4 feet	Cross Slope (PAR)	3.0-4.0%	11 ft	70	SF	\$120	\$8,448
41818	0.8 to 1.8 feet	Vertical Change	-83	11 ft	11	REF		
4419	6.4 to 32.7 feet	Cross Slope (PAR)	2.0-3.0%	11 ft	289	SF	\$120	\$34,716
44416	6.7 to 7.7 feet	Vertical Change	-55	11 ft	11	REF		
50341	19.5 to 20.5 feet	Vertical Change	-32	11 ft	11	REF		
44214	39.7 to 42.7 feet	Vertical Change	-56	11 ft	33	REF		
4420	40.0 to 68.6 feet	Cross Slope (PAR)	2.0-3.0%	11 ft	315	SF	\$120	\$37,752
53021	44.8 to 45.8 feet	Vertical Change	-27	11 ft	11	REF		
43388	59.0 to 62.1 feet	Vertical Change	-61	11 ft	34	REF		
45027	71.2 to 72.2 feet	Vertical Change	-52	11 ft	11	SF	\$75	\$825
45711	76.4 to 77.4 feet	Vertical Change	-49	11 ft	11	LF	\$75	\$825
4421	81.1 to 102.2 feet	Cross Slope (PAR)	2.0-3.0%	11 ft	232	SF	\$120	\$27,852
41617	82.6 to 83.6 feet	Vertical Change	-96	11 ft	11	REF		
42885	92.4 to 93.4 feet	Vertical Change	-65	11 ft	11	REF		
53547	102.4 to 103.4 feet	Vertical Change	-26	11 ft	11	LF	\$75	\$825
4423	105.4 to 112.8 feet	Cross Slope (PAR)	2.0-3.0%	11 ft	81	SF	\$120	\$9,768
41978	111.4 to 112.4 feet	Vertical Change	-78	11 ft	11	REF		
43108	117.6 to 118.6 feet	Vertical Change	-63	11 ft	11	SF	\$75	\$825
44643	121.8 to 122.8 feet	Vertical Change	-54	11 ft	11	SF	\$75	\$825
45217	132.3 to 133.3 feet	Vertical Change	-51	11 ft	11	SF	\$75	\$825
4424	135.2 to 137.3 feet	Cross Slope (PAR)	2.0-3.0%	11 ft	23	SF	\$120	\$2,772
TOTAL COST FOR: SW side of 2ND ST Starting at: ROBERTSON-TRINITY ALLEY								\$126,258.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1908211501	TRINITY AVE	2ND ST	3RD ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
41979	3.2 to 4.2 feet	Vertical Change	-.78	4 ft	4	REF			
4425	4.2 to 12.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	32	SF	\$120	\$3,888	
42125	9.1 to 10.1 feet	Vertical Change	-.74	4 ft	4	REF			
4428	15.5 to 20.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	19	SF	\$120	\$2,304	
46572	19.0 to 20.0 feet	Vertical Change	-.45	4 ft	4	REF			
48742	40.1 to 41.1 feet	Vertical Change	-.37	4 ft	4	LF	\$75	\$300	
4429	48.2 to 58.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	39	SF	\$120	\$4,704	
43389	50.2 to 51.2 feet	Vertical Change	-.61	4 ft	4	REF			
41861	60.2 to 62.5 feet	Vertical Change	-.81	4 ft	9	SF	\$75	\$690	
46122	62.1 to 63.1 feet	Vertical Change	-.47	4 ft	4	LF	\$75	\$300	
4430	64.9 to 147.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	332	SF	\$120	\$39,792	
49331	70.1 to 71.1 feet	Vertical Change	-.35	4 ft	4	REF			
44417	75.0 to 76.0 feet	Vertical Change	-.55	4 ft	4	REF			
45028	82.2 to 83.2 feet	Vertical Change	-.52	4 ft	4	REF			
54145	82.3 to 83.3 feet	Vertical Change	.26	4 ft	4	REF			
42086	99.4 to 101.1 feet	Vertical Change	-.75	4 ft	7	REF			
43861	115.9 to 116.9 feet	Vertical Change	-.58	4 ft	4	REF			
41819	126.0 to 127.0 feet	Vertical Change	-.83	4 ft	4	REF			
44215	134.9 to 137.0 feet	Vertical Change	-.56	4 ft	8	REF			
45712	145.9 to 146.9 feet	Vertical Change	-.49	4 ft	4	REF			
46123	150.7 to 151.7 feet	Vertical Change	-.47	4 ft	4	LF	\$75	\$300	
40110	151.3 to 153.3 feet	Running Slope	5.0-6.0%	4 ft	8	SF	\$120	\$960	
40111	153.3 to 154.9 feet	Running Slope	6.0-7.0%	4 ft	6	SF	\$120	\$768	
40112	154.9 to 157.5 feet	Running Slope	5.0-6.0%	4 ft	10	SF	\$120	\$1,248	
45218	156.2 to 157.2 feet	Vertical Change	-.51	4 ft	4	SF	\$75	\$300	
45713	174.7 to 175.7 feet	Vertical Change	-.49	4 ft	4	LF	\$75	\$300	
45714	177.8 to 178.8 feet	Vertical Change	-.49	4 ft	4	LF	\$75	\$300	
46573	185.5 to 186.5 feet	Vertical Change	-.45	4 ft	4	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908211501	TRINITY AVE	2ND ST	3RD ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
4434	186.3 to 197.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	44	SF	\$120	\$5,328
49644	193.4 to 197.4 feet	Vertical Change	-.34	4 ft	16	REF		
44846	204.4 to 205.4 feet	Vertical Change	-.53	4 ft	4	REF		
4435	205.2 to 244.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	158	SF	\$120	\$18,960
24	211.5 to 212.5 feet	Continuous Width		4 ft	4	SF	\$120	\$480
42087	212.6 to 213.6 feet	Vertical Change	-.75	4 ft	4	REF		
48176	215.6 to 216.6 feet	Vertical Change	-.39	4 ft	4	REF		
46124	223.6 to 224.6 feet	Vertical Change	-.47	4 ft	4	REF		
25	230.5 to 231.5 feet	Continuous Width		4 ft	4	SF	\$120	\$480
47029	231.5 to 235.5 feet	Vertical Change	-.43	4 ft	16	REF		
44216	242.4 to 243.4 feet	Vertical Change	-.56	4 ft	4	REF		
4440	249.3 to 253.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,968
44217	250.5 to 251.5 feet	Vertical Change	-.56	4 ft	4	REF		
TOTAL COST FOR: SE side of TRINITY AVE Starting at: 2ND ST							\$83,370.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908211506	TRINITY AVE	3RD ST	4TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
4441	0.0 to 9.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	71	SF	\$120	\$8,460	
52507	2.6 to 6.1 feet	Vertical Change	-28	8 ft	26	REF			
57933	5.8 to 33.4 feet	Driveway				REF			
4443	9.4 to 65.3 feet	Cross Slope (Driveway)	4.0-5.0%	8 ft	419	SF	\$40	\$16,770	
46820	20.8 to 21.8 feet	Vertical Change	-.44	8 ft	8	REF			
48177	37.5 to 38.5 feet	Vertical Change	-.39	8 ft	8	REF			
46353	47.3 to 48.3 feet	Vertical Change	-.46	8 ft	8	REF			
47928	51.7 to 52.7 feet	Vertical Change	-.4	8 ft	8	REF			
43711	61.8 to 67.5 feet	Vertical Change	-.59	8 ft	43	REF			
4447	65.3 to 140.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	561	SF	\$120	\$67,320	
46126	72.5 to 73.5 feet	Vertical Change	-.47	8 ft	8	REF			
50720	80.0 to 81.0 feet	Vertical Change	-.31	8 ft	8	REF			
46821	84.4 to 85.4 feet	Vertical Change	-.44	8 ft	8	REF			
47514	92.1 to 93.1 feet	Vertical Change	-.41	8 ft	8	REF			
57934	95.0 to 119.2 feet	Driveway				REF			
49332	97.2 to 98.2 feet	Vertical Change	-.35	8 ft	8	REF			
44418	122.3 to 123.3 feet	Vertical Change	-.55	8 ft	8	REF			
49646	126.9 to 127.9 feet	Vertical Change	-.34	8 ft	8	REF			
51639	130.9 to 131.9 feet	Vertical Change	-.3	8 ft	8	REF			
50721	139.0 to 142.6 feet	Vertical Change	-.31	8 ft	27	REF			
4455	140.1 to 156.6 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	124	SF	\$120	\$14,850	
53548	149.0 to 150.0 feet	Vertical Change	-.26	8 ft	8	REF			
46574	154.4 to 155.4 feet	Vertical Change	-.45	8 ft	8	REF			
4457	156.6 to 220.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	482	SF	\$120	\$57,780	
57935	158.7 to 184.3 feet	Driveway				REF			
43712	158.8 to 159.8 feet	Vertical Change	-.59	8 ft	8	REF			
50722	173.3 to 174.3 feet	Vertical Change	-.31	8 ft	8	REF			
50723	187.9 to 188.9 feet	Vertical Change	-.31	8 ft	8	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1908211506	TRINITY AVE	3RD ST	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47929	203.9 to 204.9 feet	Vertical Change	-4	8 ft	8	REF		
47930	219.2 to 221.8 feet	Vertical Change	-4	8 ft	20	REF		
4465	220.8 to 232.9 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	91	SF	\$120	\$10,890
4467	232.9 to 255.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	171	SF	\$120	\$20,520
48743	233.8 to 234.8 feet	Vertical Change	-.37	8 ft	8	REF		
48744	238.3 to 239.3 feet	Vertical Change	-.37	8 ft	8	REF		
46354	251.0 to 252.0 feet	Vertical Change	-.46	8 ft	8	REF		
4469	255.7 to 267.0 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	85	SF	\$120	\$10,170
51640	263.9 to 264.9 feet	Vertical Change	-.3	8 ft	8	REF		
4471	267.0 to 291.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	184	SF	\$120	\$22,050
42042	268.4 to 269.4 feet	Vertical Change	-.76	8 ft	8	REF		
52508	282.0 to 283.0 feet	Vertical Change	-.28	8 ft	8	REF		

TOTAL COST FOR: NW	<i>side of TRINITY AVE Starting at: 3RD ST</i>	\$228,810.00
---------------------------	--	---------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908211511	TRINITY AVE	4TH ST	5TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
4474	0.0 to 33.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	166	SF	\$120	\$19,860	
46822	12.2 to 13.2 feet	Vertical Change	-.44	5 ft	5	REF			
45715	24.7 to 25.7 feet	Vertical Change	-.49	5 ft	5	REF			
4475	33.1 to 57.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	124	SF	\$120	\$14,820	
47030	37.0 to 38.0 feet	Vertical Change	-.43	5 ft	5	REF			
46823	49.3 to 50.3 feet	Vertical Change	-.44	5 ft	5	REF			
4476	62.8 to 93.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	151	SF	\$120	\$18,120	
45716	86.9 to 87.9 feet	Vertical Change	-.49	5 ft	5	REF			
4477	104.3 to 112.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,100	
47931	106.1 to 107.1 feet	Vertical Change	-.4	5 ft	5	REF			
50724	117.6 to 118.6 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
53549	138.8 to 139.8 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
49028	155.3 to 156.3 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375	
4478	160.0 to 167.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320	
53022	168.4 to 169.4 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
4480	171.2 to 175.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,460	
44847	197.4 to 198.4 feet	Vertical Change	-.53	5 ft	5	SF	\$75	\$375	
50342	206.3 to 207.3 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
4482	211.3 to 245.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	172	SF	\$120	\$20,640	
49647	220.4 to 221.4 feet	Vertical Change	-.34	5 ft	5	REF			
52509	227.5 to 228.5 feet	Vertical Change	-.28	5 ft	5	REF			
53550	257.9 to 258.9 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
4485	274.8 to 280.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,540	
47266	276.8 to 277.8 feet	Vertical Change	-.42	5 ft	5	REF			
52067	293.7 to 294.7 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
TOTAL COST FOR: NW side of TRINITY AVE Starting at: 4TH ST								\$91,860.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908211515	TRINITY AVE	5TH ST	6TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
4486	0.0 to 5.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,060	
4487	8.1 to 20.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	64	SF	\$120	\$7,620	
57936	15.4 to 37.2 feet	Driveway				REF			
4488	22.9 to 37.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	72	SF	\$40	\$2,880	
46127	48.7 to 49.7 feet	Vertical Change	-47	5 ft	5	LF	\$75	\$375	
52510	58.8 to 59.8 feet	Vertical Change	-28	5 ft	5	LF	\$75	\$375	
4489	60.8 to 63.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860	
44033	66.3 to 67.3 feet	Vertical Change	-57	5 ft	5	SF	\$75	\$375	
40113	75.6 to 76.7 feet	Running Slope	6.0-7.0%	5 ft	6	SF	\$120	\$660	
57405	78.7 to 79.7 feet	Vertical Change	1.18	5 ft	5	SF	\$75	\$375	
41544	78.8 to 79.8 feet	Vertical Change	-1.03	5 ft	5	SF	\$75	\$375	
57549	78.9 to 79.9 feet	Vertical Change	2.23	5 ft	5	SF	\$75	\$375	
57937	94.6 to 105.9 feet	Driveway				REF			
53971	119.3 to 120.3 feet	Vertical Change	-25	5 ft	5	LF	\$75	\$375	
52068	159.3 to 160.3 feet	Vertical Change	-29	5 ft	5	LF	\$75	\$375	
4490	161.1 to 164.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,920	
4491	168.7 to 173.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,880	
52511	169.4 to 172.2 feet	Vertical Change	-28	5 ft	14	REF			
53023	174.4 to 175.4 feet	Vertical Change	-27	5 ft	5	LF	\$75	\$375	
53972	179.4 to 180.4 feet	Vertical Change	-25	5 ft	5	LF	\$75	\$375	
47932	184.4 to 185.4 feet	Vertical Change	-4	5 ft	5	LF	\$75	\$375	
57938	185.2 to 207.6 feet	Driveway				REF			
50343	189.4 to 190.4 feet	Vertical Change	-32	5 ft	5	REF			
45219	194.4 to 195.4 feet	Vertical Change	-51	5 ft	5	REF			
4492	195.6 to 200.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	26	SF	\$40	\$1,040	
4493	224.1 to 226.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620	
4494	246.0 to 251.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,420	
4495	254.2 to 258.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,640	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1908211515	TRINITY AVE	5TH ST	6TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
53973	254.5 to 255.5 feet	Vertical Change	-.25	5 ft	5	REF		
4497	262.7 to 274.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,080
4498	278.2 to 291.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,160
47516	299.2 to 300.2 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: NW side of TRINITY AVE Starting at: 5TH ST							\$49,340.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1908211533	TRINITY AVE	6TH ST	5TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
4499	0.0 to 78.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	390	SF	\$120	\$46,800	
50344	2.6 to 3.6 feet	Vertical Change	-32	5 ft	5	REF			
49648	12.7 to 13.7 feet	Vertical Change	-34	5 ft	5	REF			
50345	32.9 to 33.9 feet	Vertical Change	-32	5 ft	5	REF			
57939	44.4 to 64.2 feet	Driveway				REF			
52069	49.3 to 50.3 feet	Vertical Change	-29	5 ft	5	REF			
45717	57.6 to 58.6 feet	Vertical Change	-49	5 ft	5	REF			
52070	66.9 to 67.9 feet	Vertical Change	-29	5 ft	5	REF			
47517	72.9 to 73.9 feet	Vertical Change	-41	5 ft	5	REF			
4508	78.0 to 97.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	99	SF	\$120	\$11,880	
4510	97.8 to 102.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,580	
53024	98.5 to 99.5 feet	Vertical Change	-27	5 ft	5	REF			
57940	99.3 to 117.5 feet	Driveway				REF			
4511	105.1 to 120.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	79	SF	\$40	\$3,140	
49649	114.5 to 115.5 feet	Vertical Change	-34	5 ft	5	REF			
40114	119.9 to 120.9 feet	Running Slope	7.0-8.0%	5 ft	5	REF			
57573	122.0 to 123.0 feet	Vertical Change	2.65	5 ft	5	SF	\$75	\$375	
42286	123.7 to 124.7 feet	Vertical Change	-71	5 ft	5	SF	\$75	\$375	
4512	124.8 to 129.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000	
45220	130.8 to 131.8 feet	Vertical Change	-.51	5 ft	5	SF	\$75	\$375	
4513	133.1 to 178.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	226	SF	\$120	\$27,120	
53025	139.7 to 140.7 feet	Vertical Change	-27	5 ft	5	REF			
46824	148.5 to 149.5 feet	Vertical Change	-44	5 ft	5	REF			
57941	152.8 to 187.1 feet	Driveway				REF			
42886	157.3 to 158.3 feet	Vertical Change	-.65	5 ft	5	REF			
51641	168.6 to 169.6 feet	Vertical Change	-.3	5 ft	5	REF			
4516	188.8 to 198.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,640	
4517	201.5 to 203.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140	
57942	206.6 to 236.9 feet	Driveway				REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908211533	TRINITY AVE	6TH ST	5TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
42233	207.7 to 208.7 feet	Vertical Change	-.72	5 ft	5	REF		
4518	212.8 to 235.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	115	SF	\$40	\$4,600
52071	231.7 to 232.7 feet	Vertical Change	-.29	5 ft	5	REF		
40115	241.4 to 242.5 feet	Running Slope	8.0-9.0%	5 ft	6	SF	\$120	\$660
42126	241.8 to 242.8 feet	Vertical Change	-.74	5 ft	5	SF	\$75	\$375
57145	241.9 to 242.9 feet	Vertical Change	.64	5 ft	5	SF	\$75	\$375
57295	246.1 to 247.1 feet	Vertical Change	.87	5 ft	5	SF	\$75	\$375
41198	246.8 to 247.8 feet	Vertical Change	-2.45	5 ft	5	SF	\$75	\$375
40116	248.7 to 250.6 feet	Running Slope	6.0-7.0%	5 ft	10	SF	\$120	\$1,140
4521	251.4 to 252.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
57943	253.4 to 289.8 feet	Driveway				REF		
4522	254.1 to 260.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	33	SF	\$40	\$1,300
4524	260.6 to 266.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	30	SF	\$40	\$1,220
4526	266.7 to 271.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	26	SF	\$40	\$1,020
4527	271.8 to 281.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	49	SF	\$40	\$1,940
50725	273.8 to 274.8 feet	Vertical Change	-.31	5 ft	5	REF		
4528	288.7 to 298.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	48	SF	\$40	\$1,920
47267	295.3 to 296.3 feet	Vertical Change	-.42	5 ft	5	REF		
TOTAL COST FOR: SE side of TRINITY AVE Starting at: 6TH ST							\$118,565.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1908211536	TRINITY AVE	5TH ST	4TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
4529	0.0 to 11.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	111	SF	\$120	\$13,338	
47518	0.9 to 5.8 feet	Vertical Change	-41	10 ft	47	REF			
53026	9.8 to 10.8 feet	Vertical Change	-27	10 ft	9	REF			
50346	20.7 to 21.7 feet	Vertical Change	-32	10 ft	10	LF	\$75	\$713	
52072	25.2 to 26.2 feet	Vertical Change	-29	10 ft	10	LF	\$75	\$713	
49985	36.3 to 37.3 feet	Vertical Change	-33	10 ft	10	LF	\$75	\$713	
47268	42.4 to 46.9 feet	Vertical Change	-42	10 ft	43	LF	\$75	\$3,206	
57944	61.2 to 87.1 feet	Driveway				REF			
45221	64.7 to 65.7 feet	Vertical Change	-51	10 ft	10	REF			
45499	110.8 to 111.8 feet	Vertical Change	-5	10 ft	10	SF	\$75	\$713	
44218	115.2 to 116.2 feet	Vertical Change	-56	10 ft	10	SF	\$75	\$713	
44644	118.4 to 121.1 feet	Vertical Change	-54	10 ft	26	SF	\$75	\$1,924	
57945	126.6 to 161.2 feet	Driveway				REF			
52512	138.8 to 139.8 feet	Vertical Change	-28	10 ft	10	REF			
4531	140.3 to 141.6 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	12	SF	\$40	\$494	
51642	148.6 to 149.6 feet	Vertical Change	-3	10 ft	10	REF			
4532	158.3 to 163.5 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	49	SF	\$40	\$1,976	
4533	172.6 to 174.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	21	SF	\$120	\$2,508	
43109	175.4 to 178.8 feet	Vertical Change	-63	10 ft	32	SF	\$75	\$2,423	
4534	183.2 to 185.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	25	SF	\$120	\$2,964	
46355	186.4 to 187.4 feet	Vertical Change	-46	10 ft	10	LF	\$75	\$713	
4535	192.4 to 198.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	60	SF	\$120	\$7,182	
49986	196.3 to 197.3 feet	Vertical Change	-33	10 ft	10	REF			
49650	201.1 to 202.1 feet	Vertical Change	-34	10 ft	10	LF	\$75	\$713	
43572	205.5 to 206.5 feet	Vertical Change	-6	10 ft	10	SF	\$75	\$713	
4536	207.3 to 217.5 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	97	SF	\$120	\$11,628	
47269	216.0 to 217.0 feet	Vertical Change	-42	10 ft	10	REF			
53974	231.3 to 232.3 feet	Vertical Change	-25	10 ft	10	LF	\$75	\$713	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908211536	TRINITY AVE	5TH ST	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
53027	235.7 to 236.7 feet	Vertical Change	-.27	10 ft	10	LF	\$75	\$713
49334	246.3 to 248.8 feet	Vertical Change	-.35	10 ft	24	LF	\$75	\$1,781
53028	261.3 to 262.3 feet	Vertical Change	-.27	10 ft	10	LF	\$75	\$713
45718	270.5 to 271.5 feet	Vertical Change	-.49	10 ft	10	LF	\$75	\$713
4537	271.8 to 282.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	100	SF	\$120	\$11,970
53552	277.0 to 278.0 feet	Vertical Change	-.26	10 ft	10	REF		
49335	281.1 to 282.1 feet	Vertical Change	-.35	10 ft	10	REF		
TOTAL COST FOR: SE side of TRINITY AVE Starting at: 5TH ST							\$69,943.75	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1908211539	TRINITY AVE	4TH ST	3RD ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
44034	1.8 to 7.9 feet	Vertical Change	-.57	10 ft	58	SF	\$75	\$4,346	
4539	8.7 to 27.1 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	175	SF	\$120	\$20,976	
49651	26.9 to 27.9 feet	Vertical Change	-.34	10 ft	10	REF			
48745	31.4 to 32.4 feet	Vertical Change	-.37	10 ft	10	LF	\$75	\$713	
4540	32.6 to 54.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	206	SF	\$120	\$24,738	
48178	36.1 to 37.1 feet	Vertical Change	-.39	10 ft	10	REF			
52073	45.9 to 46.9 feet	Vertical Change	-.29	10 ft	10	REF			
44419	56.9 to 57.9 feet	Vertical Change	-.55	10 ft	10	SF	\$75	\$713	
49652	61.4 to 62.4 feet	Vertical Change	-.34	10 ft	10	LF	\$75	\$713	
50726	65.9 to 66.9 feet	Vertical Change	-.31	10 ft	10	LF	\$75	\$713	
47032	73.7 to 77.0 feet	Vertical Change	-.43	10 ft	31	LF	\$75	\$2,351	
53553	87.1 to 88.1 feet	Vertical Change	-.26	10 ft	10	LF	\$75	\$713	
49988	91.5 to 92.5 feet	Vertical Change	-.33	10 ft	10	LF	\$75	\$713	
4542	109.4 to 117.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	75	SF	\$120	\$9,006	
4543	121.7 to 123.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	20	SF	\$120	\$2,394	
4544	127.8 to 136.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	78	SF	\$120	\$9,348	
49989	145.7 to 146.7 feet	Vertical Change	-.33	10 ft	10	LF	\$75	\$713	
4545	151.4 to 152.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	13	SF	\$120	\$1,596	
44035	152.5 to 153.5 feet	Vertical Change	-.57	10 ft	10	REF			
43865	155.7 to 156.7 feet	Vertical Change	-.58	10 ft	10	SF	\$75	\$713	
4546	159.2 to 172.4 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	125	SF	\$120	\$15,048	
42888	160.2 to 161.2 feet	Vertical Change	-.65	10 ft	10	REF			
57946	162.4 to 193.5 feet	Driveway				REF			
44220	176.0 to 179.9 feet	Vertical Change	-.56	10 ft	37	REF			
43390	187.3 to 188.3 feet	Vertical Change	-.61	10 ft	10	REF			
53554	198.7 to 199.7 feet	Vertical Change	-.26	10 ft	10	LF	\$75	\$713	
42183	210.0 to 211.0 feet	Vertical Change	-.73	10 ft	10	SF	\$75	\$713	
43573	214.5 to 215.5 feet	Vertical Change	-.6	10 ft	10	SF	\$75	\$713	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908211539	TRINITY AVE	4TH ST	3RD ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44221	218.8 to 219.8 feet	Vertical Change	-.56	10 ft	10	SF	\$75	\$713
44222	227.8 to 228.8 feet	Vertical Change	-.56	10 ft	10	SF	\$75	\$713
50727	229.4 to 230.4 feet	Vertical Change	-.31	10 ft	10	LF	\$75	\$713
46577	237.9 to 238.9 feet	Vertical Change	-.45	10 ft	10	LF	\$75	\$713
46128	242.2 to 243.2 feet	Vertical Change	-.47	10 ft	10	LF	\$75	\$713
49030	246.7 to 247.7 feet	Vertical Change	-.36	10 ft	10	LF	\$75	\$713
4547	249.0 to 261.5 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	119	SF	\$120	\$14,250
50347	255.1 to 256.1 feet	Vertical Change	-.32	10 ft	10	REF		
57947	259.8 to 291.6 feet	Driveway				REF		
44848	260.7 to 261.7 feet	Vertical Change	-.53	10 ft	10	REF		
42234	277.3 to 278.3 feet	Vertical Change	-.72	10 ft	10	REF		
46578	285.9 to 286.9 feet	Vertical Change	-.45	10 ft	10	REF		
TOTAL COST FOR: SE							<i>side of TRINITY AVE Starting at: 4TH ST</i>	\$116,166.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1908211543	TRINITY AVE	3RD ST	2ND ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
43110	1.3 to 2.3 feet	Vertical Change	-.63	5 ft	5	SF	\$75	\$375	
53975	12.5 to 13.5 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375	
42889	15.0 to 16.0 feet	Vertical Change	-.65	5 ft	5	SF	\$75	\$375	
4548	16.9 to 28.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,140	
44645	20.1 to 21.1 feet	Vertical Change	-.54	5 ft	5	REF			
26	26.7 to 27.7 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
46579	28.3 to 29.3 feet	Vertical Change	-.45	5 ft	5	REF			
41797	28.9 to 29.9 feet	Vertical Change	-.84	5 ft	5	SF	\$75	\$375	
52075	28.9 to 29.9 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
47033	39.4 to 40.4 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375	
57398	39.4 to 40.4 feet	Vertical Change	1.1	5 ft	5	SF	\$75	\$375	
4549	41.8 to 51.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	50	SF	\$120	\$6,000	
48459	51.6 to 52.6 feet	Vertical Change	-.38	5 ft	5	REF			
4552	51.8 to 71.9 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	101	SF	\$120	\$12,060	
41647	61.6 to 62.6 feet	Vertical Change	-.93	5 ft	5	REF			
47271	71.7 to 72.7 feet	Vertical Change	-.42	5 ft	5	REF			
4554	71.9 to 81.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	47	SF	\$120	\$5,640	
4555	81.3 to 102.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	108	SF	\$120	\$12,960	
42184	81.9 to 82.9 feet	Vertical Change	-.73	5 ft	5	REF			
57231	82.0 to 83.0 feet	Vertical Change	.71	5 ft	5	REF			
4560	121.5 to 124.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	13	SF	\$120	\$1,560	
48179	122.4 to 123.4 feet	Vertical Change	-.39	5 ft	5	REF			
4561	124.1 to 126.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320	
49990	140.3 to 141.3 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375	
4562	145.0 to 148.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,100	
53029	146.6 to 147.6 feet	Vertical Change	-.27	5 ft	5	REF			
51643	153.8 to 154.8 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
4563	165.2 to 167.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	1908211543	TRINITY AVE	3RD ST	2ND ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
43111	166.4 to 167.4 feet	Vertical Change	-.63	5 ft	5	REF			
4564	172.2 to 175.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040	
53555	173.9 to 177.4 feet	Vertical Change	-.26	5 ft	18	REF			
4565	178.7 to 217.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	193	SF	\$120	\$23,160	
43243	185.7 to 186.7 feet	Vertical Change	-.62	5 ft	5	REF			
41433	205.6 to 206.6 feet	Vertical Change	-1.2	5 ft	5	REF			
4569	217.3 to 233.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	79	SF	\$120	\$9,480	
41517	225.7 to 226.7 feet	Vertical Change	-1.07	5 ft	5	REF			
4571	233.1 to 244.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,540	
53556	246.2 to 247.2 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
47933	259.8 to 260.8 feet	Vertical Change	-.4	5 ft	5	REF			
4572	260.6 to 267.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,080	
53030	265.7 to 266.7 feet	Vertical Change	-.27	5 ft	5	REF			
50348	273.2 to 274.2 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
4573	278.1 to 279.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720	
4574	280.2 to 285.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	28	SF	\$120	\$3,360	
50349	280.5 to 281.5 feet	Vertical Change	-.32	5 ft	5	REF			
46356	284.0 to 285.0 feet	Vertical Change	-.46	5 ft	5	REF			
4576	285.8 to 291.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120	
44036	287.2 to 288.2 feet	Vertical Change	-.57	5 ft	5	REF			
50728	288.8 to 289.8 feet	Vertical Change	-.31	5 ft	5	REF			
43574	302.3 to 303.3 feet	Vertical Change	-.6	5 ft	5	SF	\$75	\$375	
53976	313.5 to 314.5 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375	
50729	320.3 to 321.3 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
4577	327.8 to 331.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340	
45500	331.2 to 332.2 feet	Vertical Change	-.5	5 ft	5	REF			
TOTAL COST FOR: SE							side of TRINITY AVE	Starting at: 3RD ST	\$111,030.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1908211547	2ND ST	TRINITY AVE	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
42185	20.6 to 21.6 feet	Vertical Change	-.73	5 ft	5	SF	\$75	\$375
57948	21.8 to 40.8 feet	Driveway				REF		
40117	23.3 to 24.7 feet	Running Slope	5.0-6.0%	5 ft	7	REF		
4579	27.9 to 37.7 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	49	SF	\$40	\$1,960
40118	37.5 to 39.3 feet	Running Slope	7.0-8.0%	5 ft	9	REF		
42890	41.4 to 42.4 feet	Vertical Change	-.65	5 ft	5	REF		
4581	60.6 to 62.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320
44647	61.4 to 62.4 feet	Vertical Change	-.54	5 ft	5	REF		
57160	61.5 to 62.5 feet	Vertical Change	.68	5 ft	5	REF		
4583	62.8 to 94.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	158	SF	\$120	\$18,900
41892	79.0 to 80.0 feet	Vertical Change	-.8	5 ft	5	REF		
49991	80.8 to 81.8 feet	Vertical Change	-.33	5 ft	5	REF		
42992	86.2 to 87.2 feet	Vertical Change	-.64	5 ft	5	REF		
49336	86.2 to 87.2 feet	Vertical Change	-.35	5 ft	5	REF		
45501	92.8 to 93.8 feet	Vertical Change	-.5	5 ft	5	REF		
4589	94.3 to 95.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780
46580	97.5 to 98.5 feet	Vertical Change	-.45	5 ft	5	LF	\$75	\$375
40119	98.8 to 100.1 feet	Running Slope	5.0-6.0%	5 ft	7	SF	\$120	\$780
57338	99.7 to 100.7 feet	Vertical Change	.94	5 ft	5	SF	\$75	\$375
40120	100.1 to 109.5 feet	Running Slope	6.0-7.0%	5 ft	47	REF		
4590	101.4 to 111.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,180
44648	107.0 to 114.1 feet	Vertical Change	-.54	5 ft	36	REF		
4592	111.7 to 113.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	11	SF	\$120	\$1,260
4594	113.8 to 121.0 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	36	SF	\$120	\$4,320
42768	120.1 to 121.1 feet	Vertical Change	-.66	5 ft	5	REF		
4596	121.0 to 139.3 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	92	SF	\$120	\$10,980
43391	126.9 to 127.9 feet	Vertical Change	-.61	5 ft	5	REF		
41626	133.8 to 134.8 feet	Vertical Change	-.95	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	1908211547	2ND ST	TRINITY AVE	ORANGE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
4600	139.3 to 140.9 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	8	SF	\$120	\$960	
47272	140.9 to 141.9 feet	Vertical Change	-42	5 ft	5	REF			
4601	140.9 to 144.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	17	SF	\$120	\$2,040	
4603	144.3 to 160.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	80	SF	\$120	\$9,600	
53031	147.9 to 148.9 feet	Vertical Change	-.27	5 ft	5	REF			
41471	155.5 to 156.5 feet	Vertical Change	-1.13	5 ft	5	REF			
4604	160.3 to 164.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400	
42671	160.4 to 161.4 feet	Vertical Change	-.67	5 ft	5	REF			
42672	165.3 to 166.3 feet	Vertical Change	-.67	5 ft	5	SF	\$75	\$375	
4605	167.7 to 193.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	128	SF	\$120	\$15,360	
44420	169.9 to 170.9 feet	Vertical Change	-.55	5 ft	5	REF			
44649	174.7 to 175.7 feet	Vertical Change	-.54	5 ft	5	REF			
53032	187.8 to 188.8 feet	Vertical Change	-.27	5 ft	5	REF			
48180	192.7 to 193.7 feet	Vertical Change	-.39	5 ft	5	REF			
47273	197.6 to 198.6 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375	
52514	202.9 to 203.9 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
41420	208.1 to 209.1 feet	Vertical Change	-1.22	5 ft	5	SF	\$75	\$375	
57288	208.1 to 209.1 feet	Vertical Change	.82	5 ft	5	SF	\$75	\$375	
4607	209.7 to 213.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400	
49992	213.3 to 214.4 feet	Vertical Change	-.33	5 ft	6	REF			
52515	218.5 to 219.5 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
51644	223.8 to 224.8 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
49993	234.3 to 235.3 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375	
53033	239.6 to 240.6 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
49994	244.7 to 245.7 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375	
41523	249.9 to 250.9 feet	Vertical Change	-1.06	5 ft	5	SF	\$75	\$375	
41635	265.0 to 266.0 feet	Vertical Change	-.94	5 ft	5	SF	\$75	\$375	
4609	266.1 to 276.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,420	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1908211547	2ND ST	TRINITY AVE	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
52076	270.6 to 271.6 feet	Vertical Change	-.29	5 ft	5	REF		
4611	276.8 to 283.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	32	SF	\$120	\$3,840
49031	281.7 to 282.7 feet	Vertical Change	-.36	5 ft	5	REF		
4613	283.2 to 284.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720
46357	287.3 to 288.3 feet	Vertical Change	-.46	5 ft	5	LF	\$75	\$375
57238	287.3 to 288.3 feet	Vertical Change	.74	5 ft	5	SF	\$75	\$375
4614	290.4 to 301.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,840
45222	297.1 to 298.1 feet	Vertical Change	-.51	5 ft	5	REF		
47036	309.3 to 310.3 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375
49995	315.8 to 316.8 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: SW side of 2ND ST Starting at: TRINITY AVE							\$104,185.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1908211549	2ND ST	ORANGE AVE	TRINITY AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
50350	2.2 to 3.2 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
4615	3.8 to 23.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	96	SF	\$120	\$11,520	
52077	12.0 to 13.0 feet	Vertical Change	-.29	5 ft	5	REF			
47037	17.5 to 18.5 feet	Vertical Change	-.43	5 ft	5	REF			
48746	23.1 to 24.1 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375	
4618	27.2 to 36.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,340	
44421	28.4 to 29.4 feet	Vertical Change	-.55	5 ft	5	REF			
46581	34.0 to 35.0 feet	Vertical Change	-.45	5 ft	5	REF			
50351	57.9 to 58.9 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
4619	64.2 to 65.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$600	
41538	64.4 to 65.4 feet	Vertical Change	-1.04	5 ft	5	REF			
4620	66.0 to 67.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	5	SF	\$120	\$660	
4621	67.1 to 71.2 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	21	SF	\$120	\$2,460	
45502	70.0 to 71.0 feet	Vertical Change	-.5	5 ft	5	REF			
4622	71.2 to 78.0 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	34	SF	\$120	\$4,080	
41518	74.9 to 75.9 feet	Vertical Change	-1.07	5 ft	5	REF			
4624	78.0 to 79.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$900	
4625	79.5 to 80.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600	
41530	79.9 to 80.9 feet	Vertical Change	-1.05	5 ft	5	REF			
48460	85.0 to 86.0 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375	
47274	90.1 to 91.1 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375	
4626	102.2 to 107.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,940	
46825	105.0 to 106.0 feet	Vertical Change	-.44	5 ft	5	REF			
43245	109.3 to 110.3 feet	Vertical Change	-.62	5 ft	5	SF	\$75	\$375	
47038	114.0 to 115.0 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375	
45719	126.4 to 127.4 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$375	
42186	131.0 to 132.0 feet	Vertical Change	-.73	5 ft	5	SF	\$75	\$375	
46582	136.5 to 137.5 feet	Vertical Change	-.45	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1908211549	2ND ST	ORANGE AVE	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51645	141.5 to 142.5 feet	Vertical Change	-3	5 ft	5	LF	\$75	\$375
4627	144.8 to 154.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,520
47275	147.0 to 148.0 feet	Vertical Change	-.42	5 ft	5	REF		
44650	151.2 to 152.2 feet	Vertical Change	-.54	5 ft	5	REF		
43112	162.8 to 166.2 feet	Vertical Change	-.63	5 ft	17	SF	\$75	\$1,275
4628	170.4 to 176.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,540
44422	175.1 to 176.1 feet	Vertical Change	-.55	5 ft	5	REF		
4629	180.6 to 183.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740
4630	188.3 to 190.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200
46129	190.6 to 191.6 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375
41248	203.6 to 204.6 feet	Vertical Change	-1.87	5 ft	5	SF	\$75	\$375
4631	210.5 to 215.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,880
47039	216.1 to 217.1 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375
53034	219.7 to 220.7 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
4632	221.4 to 225.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	21	SF	\$120	\$2,520
40122	221.7 to 225.8 feet	Running Slope	5.0-6.0%	5 ft	21	REF		
44223	224.6 to 225.6 feet	Vertical Change	-.56	5 ft	5	REF		
4634	225.6 to 230.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120
47040	239.0 to 240.0 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375
47934	245.1 to 246.1 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: NE side of 2ND ST Starting at: ORANGE AVE							\$57,270.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908211553	TRINITY AVE	2ND ST	1ST ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
4635	0.0 to 58.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	437	SF	\$120	\$52,470	
50730	9.2 to 10.2 feet	Vertical Change	-31	8 ft	7	REF			
47041	16.7 to 17.7 feet	Vertical Change	-43	8 ft	8	REF			
42127	26.1 to 27.1 feet	Vertical Change	-74	8 ft	8	REF			
41741	35.2 to 36.2 feet	Vertical Change	-87	8 ft	8	REF			
43246	44.6 to 45.6 feet	Vertical Change	-62	8 ft	8	REF			
44037	51.5 to 55.1 feet	Vertical Change	-57	8 ft	27	REF			
43113	63.9 to 64.9 feet	Vertical Change	-63	8 ft	8	SF	\$75	\$563	
4638	72.3 to 82.0 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	73	SF	\$120	\$8,730	
42388	75.3 to 76.3 feet	Vertical Change	-7	8 ft	8	REF			
4640	82.0 to 191.6 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	822	SF	\$120	\$98,640	
48747	82.3 to 83.3 feet	Vertical Change	-37	8 ft	8	REF			
44423	85.5 to 86.5 feet	Vertical Change	-55	8 ft	8	REF			
42128	95.4 to 96.4 feet	Vertical Change	-74	8 ft	8	REF			
42389	105.5 to 106.5 feet	Vertical Change	-7	8 ft	8	REF			
41893	115.7 to 116.7 feet	Vertical Change	-8	8 ft	8	REF			
47935	125.6 to 126.6 feet	Vertical Change	-4	8 ft	8	REF			
42088	135.6 to 136.6 feet	Vertical Change	-75	8 ft	8	REF			
46583	142.5 to 143.5 feet	Vertical Change	-45	8 ft	8	REF			
46358	149.3 to 150.3 feet	Vertical Change	-46	8 ft	8	REF			
46130	157.4 to 158.4 feet	Vertical Change	-47	8 ft	8	REF			
48461	165.7 to 166.7 feet	Vertical Change	-38	8 ft	8	REF			
45915	175.8 to 176.8 feet	Vertical Change	-48	8 ft	8	REF			
50731	185.6 to 186.6 feet	Vertical Change	-31	8 ft	8	REF			
4648	191.6 to 329.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	1033	SF	\$120	\$123,930	
45916	195.7 to 196.7 feet	Vertical Change	-48	8 ft	8	REF			
54146	205.6 to 206.6 feet	Vertical Change	.26	8 ft	8	REF			
47042	215.8 to 216.8 feet	Vertical Change	-43	8 ft	8	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1908211553	TRINITY AVE	2ND ST	1ST ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44849	225.7 to 226.7 feet	Vertical Change	-.53	8 ft	8	REF		
46584	235.9 to 236.9 feet	Vertical Change	-.45	8 ft	8	REF		
45031	245.7 to 246.7 feet	Vertical Change	-.52	8 ft	8	REF		
49996	250.8 to 252.8 feet	Vertical Change	-.33	8 ft	15	REF		
46359	255.9 to 256.9 feet	Vertical Change	-.46	8 ft	7	REF		
42470	265.7 to 266.7 feet	Vertical Change	-.69	8 ft	8	REF		
49654	274.7 to 276.7 feet	Vertical Change	-.34	8 ft	15	REF		
45504	285.7 to 286.7 feet	Vertical Change	-.5	8 ft	8	REF		
42993	294.9 to 295.9 feet	Vertical Change	-.64	8 ft	8	REF		
42557	304.7 to 305.7 feet	Vertical Change	-.68	8 ft	8	REF		
43247	314.3 to 315.3 feet	Vertical Change	-.62	8 ft	8	REF		
40123	328.8 to 330.2 feet	Running Slope	5.0-6.0%	8 ft	11	REF		
47043	329.8 to 330.8 feet	Vertical Change	-.43	8 ft	8	LF	\$75	\$563
40124	330.2 to 332.2 feet	Running Slope	6.0-7.0%	8 ft	15	SF	\$120	\$1,800
40125	332.2 to 334.0 feet	Running Slope	5.0-6.0%	8 ft	14	SF	\$120	\$1,620
TOTAL COST FOR: NW side of TRINITY AVE Starting at: 2ND ST								\$288,315.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	1908211559	1ST ST	TRINITY AVE	ORANGE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
42089	2.3 to 3.3 feet	Vertical Change	-.75	8 ft	8	SF	\$75	\$600	
4665	12.4 to 197.1 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	1478	SF	\$120	\$177,312	
43866	13.7 to 14.7 feet	Vertical Change	-.58	8 ft	8	REF			
49337	20.6 to 22.6 feet	Vertical Change	-.35	8 ft	16	REF			
50352	33.3 to 34.3 feet	Vertical Change	-.32	8 ft	8	REF			
47520	53.0 to 54.0 feet	Vertical Change	-.41	8 ft	8	REF			
47276	72.6 to 73.6 feet	Vertical Change	-.42	8 ft	8	REF			
48181	123.9 to 124.9 feet	Vertical Change	-.39	8 ft	8	REF			
46585	131.1 to 132.1 feet	Vertical Change	-.45	8 ft	8	REF			
46586	140.6 to 141.6 feet	Vertical Change	-.45	8 ft	8	REF			
48462	150.1 to 151.1 feet	Vertical Change	-.38	8 ft	8	REF			
53035	190.0 to 191.0 feet	Vertical Change	-.27	8 ft	8	REF			
44224	198.8 to 199.8 feet	Vertical Change	-.56	8 ft	8	SF	\$75	\$600	
4675	204.2 to 206.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	17	SF	\$120	\$2,016	
4676	213.5 to 220.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	57	SF	\$120	\$6,816	
4678	220.6 to 249.3 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	230	SF	\$120	\$27,552	
46361	229.6 to 230.6 feet	Vertical Change	-.46	8 ft	8	REF			
49997	239.5 to 240.5 feet	Vertical Change	-.33	8 ft	8	REF			
4681	249.3 to 289.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	321	SF	\$120	\$38,496	
50732	249.5 to 250.5 feet	Vertical Change	-.31	8 ft	8	REF			
45223	256.9 to 257.9 feet	Vertical Change	-.51	8 ft	8	REF			
47277	269.0 to 270.0 feet	Vertical Change	-.42	8 ft	8	REF			
41590	290.8 to 291.8 feet	Vertical Change	-.99	8 ft	8	SF	\$75	\$600	
46587	297.5 to 298.5 feet	Vertical Change	-.45	8 ft	8	LF	\$75	\$600	
56990	297.5 to 298.5 feet	Vertical Change	.59	8 ft	8	SF	\$75	\$600	
TOTAL COST FOR: SW side of 1ST ST Starting at: TRINITY AVE								\$255,192.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1908211602	1ST ST	SIDEWALK BEGINS	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
4683	0.0 to 16.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,802
27	11.1 to 12.1 feet	Continuous Width		5 ft	5	SF	\$120	\$540
57949	15.2 to 52.2 feet	Driveway				REF		
4684	22.1 to 49.0 feet	Cross Slope (Driveway)	>15%	5 ft	121	SF	\$40	\$4,842
40126	48.2 to 49.8 feet	Running Slope	8.0-9.0%	5 ft	7	REF		
4685	70.0 to 73.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,890
4686	93.8 to 108.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	66	SF	\$120	\$7,884
49033	119.2 to 120.2 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$338
4687	121.3 to 122.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$594
4688	135.4 to 144.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,968
28	140.8 to 141.8 feet	Continuous Width		5 ft	5	SF	\$120	\$540
TOTAL COST FOR: NE							<i>side of 1ST ST Starting at: SIDEWALK BEGINS</i>	\$30,397.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908211604	TRINITY AVE	1ST ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
4690	0.0 to 4.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,538
4691	29.2 to 33.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,106
4692	48.2 to 51.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,944
TOTAL COST FOR: SE side of TRINITY AVE Starting at: 1ST ST							\$6,588.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1908211607	1ST ST	TRINITY AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
4693	0.0 to 17.0 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	68	SF	\$120	\$8,160
47936	2.2 to 18.1 feet	Vertical Change	-4	4 ft	64	REF		
4697	17.0 to 63.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	187	SF	\$120	\$22,464
49998	20.2 to 32.2 feet	Vertical Change	-33	4 ft	48	REF		
53036	43.6 to 44.6 feet	Vertical Change	-27	4 ft	4	REF		
52078	51.1 to 61.9 feet	Vertical Change	-29	4 ft	43	REF		
53037	65.4 to 66.4 feet	Vertical Change	-27	4 ft	4	LF	\$75	\$300
4700	71.5 to 118.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	187	SF	\$120	\$22,464
53978	72.1 to 73.1 feet	Vertical Change	-25	4 ft	4	REF		
52520	113.5 to 114.5 feet	Vertical Change	-28	4 ft	4	REF		
4703	124.3 to 137.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	53	SF	\$120	\$6,336
57950	132.3 to 158.8 feet	Driveway				REF		
50733	137.0 to 138.0 feet	Vertical Change	-31	4 ft	4	REF		
4705	137.5 to 146.5 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	36	SF	\$40	\$1,440
4709	146.5 to 150.4 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	16	SF	\$40	\$624
40127	148.3 to 149.7 feet	Running Slope	5.0-6.0%	4 ft	6	REF		
40128	149.7 to 152.5 feet	Running Slope	6.0-7.0%	4 ft	11	REF		
4711	150.4 to 153.0 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	10	SF	\$40	\$416
40130	152.5 to 155.0 feet	Running Slope	8.0-9.0%	4 ft	10	REF		
4713	155.3 to 156.3 feet	Cross Slope (Driveway)	7.0-8.0%	4 ft	4	SF	\$40	\$160
4714	158.5 to 189.3 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	123	SF	\$40	\$4,928
53979	169.1 to 170.1 feet	Vertical Change	-25	4 ft	4	REF		
53560	172.2 to 173.2 feet	Vertical Change	-26	4 ft	4	REF		
51646	175.3 to 176.3 feet	Vertical Change	-3	4 ft	4	REF		
57951	188.3 to 203.4 feet	Driveway				REF		
4716	190.5 to 192.5 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	8	SF	\$40	\$320
4717	194.3 to 202.4 feet	Cross Slope (Driveway)	7.0-8.0%	4 ft	32	SF	\$40	\$1,296
40131	198.7 to 200.3 feet	Running Slope	9.0-10.0%	4 ft	6	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1908211607	1ST ST	TRINITY AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
4721	202.4 to 216.3 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	56	SF	\$40	\$2,224
53038	208.7 to 209.7 feet	Vertical Change	-.27	4 ft	4	REF		
4725	216.3 to 218.0 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	7	SF	\$120	\$816
4726	218.0 to 229.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	47	SF	\$120	\$5,664
57952	234.3 to 289.8 feet	Driveway				REF		
4727	246.2 to 290.0 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	175	SF	\$40	\$7,008
53561	246.9 to 247.9 feet	Vertical Change	-.26	4 ft	4	REF		
47938	255.6 to 256.6 feet	Vertical Change	-.4	4 ft	4	REF		
56618	268.4 to 269.4 feet	Vertical Change	.41	4 ft	4	REF		
4729	290.0 to 295.2 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	21	SF	\$40	\$832
TOTAL COST FOR: NE side of 1ST ST Starting at: TRINITY AVE							\$85,452.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	1908211611	1ST ST	ROBERTSON BLVD	TRINITY AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
44424	1.1 to 2.1 feet	Vertical Change	-.55	10 ft	9	SF	\$75	\$713	
4730	8.3 to 62.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	517	SF	\$120	\$62,016	
52521	11.7 to 12.7 feet	Vertical Change	-.28	10 ft	10	REF			
57953	57.8 to 103.9 feet	Driveway				REF			
42129	60.2 to 61.2 feet	Vertical Change	-.74	10 ft	10	REF			
4733	62.7 to 64.9 feet	Cross Slope (Driveway)	4.0-5.0%	10 ft	21	SF	\$40	\$836	
45917	63.1 to 65.3 feet	Vertical Change	-.48	10 ft	21	REF			
4735	64.9 to 70.5 feet	Cross Slope (Driveway)	6.0-7.0%	10 ft	53	SF	\$40	\$2,128	
4737	70.5 to 100.7 feet	Cross Slope (Driveway)	8.0-9.0%	10 ft	287	SF	\$40	\$11,476	
49339	82.7 to 83.7 feet	Vertical Change	-.35	10 ft	10	REF			
4744	100.7 to 102.0 feet	Cross Slope (Driveway)	6.0-7.0%	10 ft	12	SF	\$40	\$494	
48464	100.8 to 103.0 feet	Vertical Change	-.38	10 ft	21	REF			
4745	102.0 to 104.7 feet	Cross Slope (Driveway)	5.0-6.0%	10 ft	26	SF	\$40	\$1,026	
4747	104.7 to 106.6 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	18	SF	\$120	\$2,166	
4748	106.6 to 136.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	282	SF	\$120	\$33,858	
53980	122.3 to 124.7 feet	Vertical Change	-.25	10 ft	23	REF			
57954	127.7 to 149.8 feet	Driveway				REF			
47521	129.1 to 130.1 feet	Vertical Change	-.41	10 ft	10	REF			
4753	136.3 to 151.5 feet	Cross Slope (Driveway)	4.0-5.0%	10 ft	144	SF	\$40	\$5,776	
49340	141.7 to 142.7 feet	Vertical Change	-.35	10 ft	10	REF			
4757	151.5 to 156.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	46	SF	\$120	\$5,472	
4759	166.1 to 168.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	24	SF	\$120	\$2,850	
54153	173.4 to 174.4 feet	Vertical Change	.27	10 ft	10	LF	\$75	\$713	
4760	180.8 to 186.1 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	50	SF	\$120	\$6,042	
57955	183.3 to 269.3 feet	Driveway				REF			
4762	189.8 to 196.7 feet	Cross Slope (Driveway)	10.0-11.0%	10 ft	66	SF	\$40	\$2,622	
4764	196.7 to 201.4 feet	Cross Slope (Driveway)	8.0-9.0%	10 ft	45	SF	\$40	\$1,786	
4766	201.4 to 214.2 feet	Cross Slope (Driveway)	6.0-7.0%	10 ft	122	SF	\$40	\$4,864	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1908211611	1ST ST	ROBERTSON BLVD	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
50734	210.1 to 211.1 feet	Vertical Change	-.31	10 ft	10	REF		
4767	214.2 to 241.7 feet	Cross Slope (Driveway)	5.0-6.0%	10 ft	261	SF	\$40	\$10,450
4769	241.7 to 270.3 feet	Cross Slope (Driveway)	3.0-4.0%	10 ft	272	SF	\$40	\$10,868
4771	270.3 to 280.4 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	96	SF	\$120	\$11,514
4774	287.8 to 293.9 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	58	SF	\$120	\$6,954
48182	293.4 to 294.4 feet	Vertical Change	-.39	10 ft	10	REF		
TOTAL COST FOR: SW side of 1ST ST Starting at: ROBERTSON BLVD							\$184,623.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908220813	CALAVERAS ST	VENTURA AVE	CIRCLE DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
4775	0.0 to 6.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,402	
57956	2.7 to 30.2 feet	Driveway				REF			
40132	6.3 to 7.4 feet	Running Slope	7.0-8.0%	5 ft	5	REF			
4776	10.3 to 26.2 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	72	SF	\$40	\$2,862	
40133	25.6 to 26.8 feet	Running Slope	8.0-9.0%	5 ft	5	REF			
29	54.6 to 55.6 feet	Continuous Width		5 ft	5	SF	\$120	\$540	
4779	58.4 to 66.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,158	
57957	65.9 to 94.6 feet	Driveway				REF			
4782	66.1 to 68.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	12	SF	\$40	\$486	
4783	72.9 to 83.1 feet	Cross Slope (Driveway)	>15%	5 ft	46	SF	\$40	\$1,836	
47279	82.2 to 83.2 feet	Vertical Change	-.42	5 ft	5	REF			
4785	83.1 to 90.9 feet	Cross Slope (Driveway)	13.014	5 ft	35	SF	\$40	\$1,404	
40134	90.7 to 92.3 feet	Running Slope	7.0-8.0%	5 ft	7	REF			
4786	97.5 to 120.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	102	SF	\$120	\$12,204	
4788	120.1 to 139.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	88	SF	\$120	\$10,584	
4791	139.7 to 163.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	107	SF	\$120	\$12,798	
56909	146.2 to 147.2 feet	Vertical Change	.5	5 ft	5	REF			
47940	153.5 to 154.5 feet	Vertical Change	-.4	5 ft	5	REF			
57958	159.8 to 189.9 feet	Driveway				REF			
4793	167.6 to 185.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	82	SF	\$40	\$3,276	
40135	185.6 to 186.7 feet	Running Slope	8.0-9.0%	5 ft	5	REF			
49341	188.5 to 189.5 feet	Vertical Change	-.35	5 ft	5	REF			
4795	189.8 to 202.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	56	SF	\$40	\$2,232	
50353	198.4 to 199.4 feet	Vertical Change	-.32	5 ft	5	REF			
4799	202.2 to 225.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	104	SF	\$120	\$12,474	
TOTAL COST FOR:								\$68,256.00	
N side of CALAVERAS ST Starting at: VENTURA AVE									

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908220816	CIRCLE DR	CALAVERAS ST	CALAVERAS ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
4803	0.0 to 47.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	212	SF	\$120	\$25,380	
48465	8.5 to 9.5 feet	Vertical Change	-38	5 ft	5	REF			
46588	36.3 to 37.3 feet	Vertical Change	-45	5 ft	5	REF			
57959	42.0 to 81.2 feet	Driveway				REF			
49035	46.7 to 47.7 feet	Vertical Change	-36	5 ft	5	REF			
4807	51.0 to 72.0 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	95	SF	\$40	\$3,780	
45032	65.2 to 66.2 feet	Vertical Change	-52	5 ft	5	REF			
4809	72.0 to 77.2 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	23	SF	\$40	\$936	
40136	77.4 to 78.4 feet	Running Slope	8.0-9.0%	5 ft	5	REF			
51647	79.7 to 80.7 feet	Vertical Change	-3	5 ft	5	REF			
4810	80.8 to 84.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	15	SF	\$40	\$594	
57960	81.8 to 107.6 feet	Driveway				REF			
40137	84.1 to 85.7 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
41524	85.2 to 86.2 feet	Vertical Change	-1.06	5 ft	5	REF			
4811	87.9 to 104.6 feet	Cross Slope (Driveway)	13.014	5 ft	75	SF	\$40	\$3,006	
4813	108.3 to 124.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	72	SF	\$40	\$2,898	
44038	109.5 to 110.5 feet	Vertical Change	-57	5 ft	5	REF			
47522	122.8 to 123.8 feet	Vertical Change	-41	5 ft	5	REF			
4814	124.4 to 201.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	345	SF	\$120	\$41,418	
44850	135.5 to 136.5 feet	Vertical Change	-53	5 ft	5	REF			
47045	146.1 to 147.1 feet	Vertical Change	-43	5 ft	5	REF			
41835	171.5 to 172.5 feet	Vertical Change	-82	5 ft	5	REF			
57961	197.5 to 221.0 feet	Driveway				REF			
42769	199.9 to 200.9 feet	Vertical Change	-66	5 ft	5	REF			
4819	204.4 to 217.7 feet	Cross Slope (Driveway)	13.014	5 ft	60	SF	\$40	\$2,394	
40138	218.0 to 219.1 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
4823	221.2 to 222.5 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$234	
41659	221.6 to 222.6 feet	Vertical Change	-92	5 ft	5	REF			

TOTAL COST FOR: N side of CIRCLE DR Starting at: CALAVERAS ST \$80,640.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908220821	CALAVERAS ST	CIRCLE DR	PENNY ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
4824	0.0 to 25.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	113	SF	\$120	\$13,608	
41591	25.1 to 26.1 feet	Vertical Change	-.99	5 ft	5	REF			
4827	25.2 to 27.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,134	
4828	35.3 to 53.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	81	SF	\$120	\$9,720	
49657	50.9 to 51.9 feet	Vertical Change	-.34	5 ft	5	REF			
4831	53.3 to 125.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	324	SF	\$120	\$38,880	
50735	55.2 to 56.2 feet	Vertical Change	-.31	5 ft	5	REF			
53562	67.9 to 74.0 feet	Vertical Change	-.26	5 ft	27	REF			
53981	82.9 to 83.9 feet	Vertical Change	-.25	5 ft	5	REF			
49658	87.9 to 88.9 feet	Vertical Change	-.34	5 ft	5	REF			
48183	101.8 to 102.8 feet	Vertical Change	-.39	5 ft	5	REF			
53563	112.7 to 113.7 feet	Vertical Change	-.26	5 ft	5	REF			
57962	126.5 to 151.9 feet	Driveway				REF			
53564	130.7 to 131.7 feet	Vertical Change	-.26	5 ft	5	REF			
4839	133.4 to 148.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	69	SF	\$40	\$2,754	
4842	151.9 to 172.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	93	SF	\$40	\$3,708	
52522	165.5 to 166.5 feet	Vertical Change	-.28	5 ft	5	REF			
4844	172.5 to 192.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	91	SF	\$120	\$10,908	
42043	181.7 to 182.7 feet	Vertical Change	-.76	5 ft	5	REF			
51648	190.1 to 191.1 feet	Vertical Change	-.3	5 ft	5	REF			
49659	195.5 to 196.5 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$338	
4847	199.7 to 209.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,454	
57963	209.1 to 235.2 feet	Driveway				REF			
40139	211.8 to 213.4 feet	Running Slope	6.0-7.0%	5 ft	7	REF			
4852	216.0 to 231.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	71	SF	\$40	\$2,826	
4854	235.2 to 244.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	40	SF	\$40	\$1,584	
57964	240.0 to 265.2 feet	Driveway				REF			
40140	243.3 to 245.4 feet	Running Slope	5.0-6.0%	5 ft	9	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908220821	CALAVERAS ST	CIRCLE DR	PENNY ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
48184	244.0 to 245.0 feet	Vertical Change	-.39	5 ft	5	REF		
4856	247.2 to 260.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	61	SF	\$40	\$2,448
51649	253.4 to 254.4 feet	Vertical Change	-.3	5 ft	5	REF		
4858	260.8 to 261.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	5	SF	\$40	\$180
4859	264.7 to 289.5 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	112	SF	\$40	\$4,464
53982	266.5 to 267.5 feet	Vertical Change	-.25	5 ft	5	REF		
4863	289.5 to 295.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	28	SF	\$120	\$3,402
4864	295.8 to 303.4 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	34	SF	\$120	\$4,104
52523	296.8 to 297.8 feet	Vertical Change	-.28	5 ft	5	REF		
53565	301.8 to 302.8 feet	Vertical Change	-.26	5 ft	5	REF		
4867	303.4 to 352.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	220	SF	\$120	\$26,352
48749	313.8 to 314.8 feet	Vertical Change	-.37	5 ft	5	REF		
45224	343.6 to 344.6 feet	Vertical Change	-.51	5 ft	5	REF		
4871	352.2 to 363.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	50	SF	\$120	\$5,940
4874	363.2 to 389.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	118	SF	\$120	\$14,202
44851	374.5 to 375.5 feet	Vertical Change	-.53	5 ft	5	REF		
57965	385.5 to 411.4 feet	Driveway				REF		
48750	389.5 to 390.5 feet	Vertical Change	-.37	5 ft	5	REF		
4879	393.2 to 408.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	68	SF	\$40	\$2,736
40141	406.8 to 408.8 feet	Running Slope	5.0-6.0%	5 ft	9	REF		
4882	412.2 to 471.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	266	SF	\$120	\$31,860
4886	471.2 to 475.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	21	SF	\$120	\$2,484
57966	473.3 to 496.6 feet	Driveway				REF		
4887	479.3 to 492.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	61	SF	\$40	\$2,448
40142	492.3 to 493.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
42044	495.4 to 496.4 feet	Vertical Change	-.76	5 ft	5	REF		
41210	510.3 to 511.3 feet	Vertical Change	-2.3	5 ft	5	SF	\$75	\$338
52080	510.5 to 511.5 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$338

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908220821	CALAVERAS ST	CIRCLE DR	PENNY ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
41234	510.6 to 511.6 feet	Vertical Change	-2	5 ft	5	SF	\$75	\$338	
52524	510.7 to 511.7 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$338	
53983	514.5 to 515.5 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$338	
4890	517.3 to 561.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	200	SF	\$120	\$23,976	
52081	519.1 to 520.1 feet	Vertical Change	-.29	5 ft	5	REF			
45505	531.5 to 532.5 feet	Vertical Change	-.5	5 ft	5	REF			
48751	546.0 to 547.0 feet	Vertical Change	-.37	5 ft	5	REF			
57967	557.1 to 580.8 feet	Driveway				REF			
4896	564.8 to 577.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	55	SF	\$40	\$2,214	
4898	581.3 to 586.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	21	SF	\$40	\$846	
4900	586.0 to 645.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	268	SF	\$120	\$32,130	
4904	645.5 to 653.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,158	
57968	649.9 to 673.5 feet	Driveway				REF			
4906	656.9 to 669.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	55	SF	\$40	\$2,214	
4908	674.1 to 675.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$306	
4909	678.0 to 681.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,106	
57969	679.2 to 702.2 feet	Driveway				REF			
57401	682.3 to 683.3 feet	Vertical Change	1.14	5 ft	5	REF			
4911	685.7 to 698.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	59	SF	\$40	\$2,358	
40143	697.9 to 699.4 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
4913	703.1 to 720.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	77	SF	\$120	\$9,180	
53566	719.3 to 720.3 feet	Vertical Change	-.26	5 ft	5	REF			
4916	720.1 to 755.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	161	SF	\$120	\$19,332	
53984	733.7 to 734.7 feet	Vertical Change	-.25	5 ft	5	REF			
45033	748.5 to 749.5 feet	Vertical Change	-.52	5 ft	5	REF			
4919	763.0 to 790.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	123	SF	\$120	\$14,742	
50736	763.2 to 764.2 feet	Vertical Change	-.31	5 ft	5	REF			
50737	778.3 to 779.3 feet	Vertical Change	-.31	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908220821	CALAVERAS ST	CIRCLE DR	PENNY ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
4922	792.7 to 814.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	97	SF	\$120	\$11,610
53567	793.2 to 794.2 feet	Vertical Change	-26	5 ft	5	REF		
4927	814.2 to 822.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	36	SF	\$120	\$4,374
57970	818.9 to 842.7 feet	Driveway				REF		
53040	822.6 to 823.6 feet	Vertical Change	-27	5 ft	5	REF		
4928	825.2 to 838.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	59	SF	\$40	\$2,358
44425	841.5 to 842.5 feet	Vertical Change	-55	5 ft	5	REF		
4930	843.2 to 848.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	22	SF	\$40	\$882
4931	848.1 to 855.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,780
50354	856.1 to 857.1 feet	Vertical Change	-32	5 ft	5	LF	\$75	\$338
53568	860.5 to 861.5 feet	Vertical Change	-26	5 ft	5	LF	\$75	\$338
4932	862.3 to 887.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	112	SF	\$120	\$13,446
44852	870.1 to 871.1 feet	Vertical Change	-53	5 ft	5	REF		
48752	874.6 to 875.6 feet	Vertical Change	-37	5 ft	5	REF		
48466	878.9 to 879.9 feet	Vertical Change	-38	5 ft	5	REF		
48467	883.2 to 884.2 feet	Vertical Change	-38	5 ft	5	REF		
4936	891.5 to 912.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	96	SF	\$120	\$11,556
43867	899.4 to 900.4 feet	Vertical Change	-58	5 ft	5	REF		
57971	910.7 to 935.2 feet	Driveway				REF		
57146	913.9 to 914.9 feet	Vertical Change	.64	5 ft	5	REF		
4937	916.6 to 932.5 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	72	SF	\$40	\$2,862
42009	934.4 to 935.4 feet	Vertical Change	-77	5 ft	5	REF		
45225	934.4 to 935.4 feet	Vertical Change	-51	5 ft	5	REF		
4939	936.0 to 944.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	40	SF	\$120	\$4,752
57972	941.1 to 964.9 feet	Driveway				REF		
46826	945.6 to 946.6 feet	Vertical Change	-44	5 ft	5	REF		
4940	947.8 to 951.0 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	14	SF	\$40	\$576
4942	951.0 to 961.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	46	SF	\$40	\$1,854

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908220821	CALAVERAS ST	CIRCLE DR	PENNY ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
40144	961.3 to 962.6 feet	Running Slope	6.0-7.0%	5 ft	6	REF			
4944	968.2 to 979.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,102	
4946	979.5 to 1024.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	203	SF	\$120	\$24,300	
4951	1024.5 to 1035.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$5,994	
50355	1035.0 to 1036.0 feet	Vertical Change	-32	5 ft	5	REF			
4953	1035.6 to 1087.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	234	SF	\$120	\$28,026	
52082	1044.2 to 1045.2 feet	Vertical Change	-29	5 ft	5	REF			
57973	1084.1 to 1107.0 feet	Driveway				REF			
4959	1090.9 to 1104.5 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	61	SF	\$40	\$2,448	
40145	1103.7 to 1104.7 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
4963	1108.4 to 1164.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	251	SF	\$120	\$30,078	
53041	1128.2 to 1129.2 feet	Vertical Change	-27	5 ft	5	REF			
4967	1164.1 to 1172.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,482	
47046	1168.0 to 1169.0 feet	Vertical Change	-43	5 ft	5	REF			
57974	1169.2 to 1192.7 feet	Driveway				REF			
53569	1173.8 to 1174.8 feet	Vertical Change	-26	5 ft	5	REF			
4969	1175.9 to 1189.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	62	SF	\$40	\$2,484	
40146	1188.5 to 1189.7 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
4971	1192.2 to 1215.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	106	SF	\$40	\$4,248	
42471	1202.4 to 1203.4 feet	Vertical Change	-69	5 ft	5	REF			
4975	1215.8 to 1217.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$918	
43868	1215.9 to 1216.9 feet	Vertical Change	-58	5 ft	5	REF			
49999	1231.1 to 1232.1 feet	Vertical Change	-33	5 ft	5	REF			
4976	1231.6 to 1246.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,776	
57975	1242.9 to 1266.3 feet	Driveway				REF			
4978	1249.6 to 1263.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	63	SF	\$40	\$2,538	
40147	1262.6 to 1264.1 feet	Running Slope	6.0-7.0%	5 ft	7	REF			
4982	1267.5 to 1284.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	75	SF	\$120	\$8,964	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908220821	CALAVERAS ST	CIRCLE DR	PENNY ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
4984	1284.1 to 1289.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	23	SF	\$120	\$2,700
4986	1289.1 to 1291.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	11	SF	\$120	\$1,296
4987	1291.5 to 1297.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,970
4989	1297.0 to 1314.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	77	SF	\$120	\$9,180
4993	1314.0 to 1316.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,188
52525	1332.3 to 1333.3 feet	Vertical Change	-28	5 ft	5	LF	\$75	\$338
53042	1361.6 to 1362.6 feet	Vertical Change	-27	5 ft	5	LF	\$75	\$338
53570	1549.9 to 1550.9 feet	Vertical Change	-26	5 ft	5	LF	\$75	\$338
4994	1563.2 to 1577.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,452
49343	1564.0 to 1565.0 feet	Vertical Change	-35	5 ft	5	REF		
TOTAL COST FOR: N side of CALAVERAS ST Starting at: CIRCLE DR							\$519,664.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908220838	CALAVERAS ST	PENNY ST	CALAVERAS ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
4997	0.0 to 9.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,820	
57976	37.8 to 62.9 feet	Driveway				REF			
51650	39.6 to 40.6 feet	Vertical Change	-3	5 ft	5	REF			
4998	46.0 to 59.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	65	SF	\$40	\$2,600	
40148	58.5 to 60.1 feet	Running Slope	6.0-7.0%	5 ft	8	REF			
47047	81.6 to 82.6 feet	Vertical Change	-43	5 ft	5	LF	\$75	\$375	
48185	86.4 to 87.4 feet	Vertical Change	-39	5 ft	5	LF	\$75	\$375	
52526	92.0 to 93.0 feet	Vertical Change	-28	5 ft	5	LF	\$75	\$375	
53043	96.5 to 97.5 feet	Vertical Change	-27	5 ft	5	LF	\$75	\$375	
52527	101.6 to 102.6 feet	Vertical Change	-28	5 ft	5	LF	\$75	\$375	
57977	102.5 to 140.7 feet	Driveway				REF			
5001	112.7 to 137.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	122	SF	\$40	\$4,860	
50356	119.7 to 120.7 feet	Vertical Change	-32	5 ft	5	REF			
49344	127.7 to 130.8 feet	Vertical Change	-35	5 ft	16	REF			
40149	136.8 to 138.3 feet	Running Slope	6.0-7.0%	5 ft	8	REF			
50739	140.8 to 144.5 feet	Vertical Change	-31	5 ft	18	REF			
51651	147.0 to 148.0 feet	Vertical Change	-3	5 ft	5	LF	\$75	\$375	
47523	157.2 to 158.2 feet	Vertical Change	-41	5 ft	5	REF			
5005	157.7 to 175.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	87	SF	\$120	\$10,380	
48186	162.8 to 163.8 feet	Vertical Change	-39	5 ft	5	REF			
43869	167.4 to 168.4 feet	Vertical Change	-58	5 ft	5	REF			
45720	172.7 to 178.9 feet	Vertical Change	-49	5 ft	31	REF			
49036	182.8 to 183.8 feet	Vertical Change	-36	5 ft	5	LF	\$75	\$375	
49037	188.2 to 189.2 feet	Vertical Change	-36	5 ft	5	LF	\$75	\$375	
57978	192.3 to 229.4 feet	Driveway				REF			
49345	195.8 to 196.8 feet	Vertical Change	-35	5 ft	5	REF			
5006	201.4 to 227.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	128	SF	\$40	\$5,120	
49038	210.7 to 211.7 feet	Vertical Change	-36	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908220838	CALAVERAS ST	PENNY ST	CALAVERAS ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40150	225.7 to 227.4 feet	Running Slope	6.0-7.0%	5 ft	9	REF		
51652	229.9 to 230.9 feet	Vertical Change	-3	5 ft	5	LF	\$75	\$375
57979	233.7 to 255.8 feet	Driveway				REF		
49039	238.8 to 239.8 feet	Vertical Change	-36	5 ft	5	REF		
5010	243.2 to 252.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	49	SF	\$40	\$1,940
40151	252.3 to 253.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
57980	258.6 to 278.1 feet	Driveway				REF		
5013	264.9 to 273.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	44	SF	\$40	\$1,760
5017	273.7 to 274.7 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	5	SF	\$40	\$200
40152	273.9 to 275.5 feet	Running Slope	7.0-8.0%	5 ft	8	REF		
50357	280.5 to 281.5 feet	Vertical Change	-32	5 ft	5	LF	\$75	\$375
49346	285.0 to 286.0 feet	Vertical Change	-35	5 ft	5	LF	\$75	\$375
57981	285.6 to 320.7 feet	Driveway				REF		
5018	292.8 to 318.0 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	126	SF	\$40	\$5,040
45506	299.8 to 300.8 feet	Vertical Change	-5	5 ft	5	REF		
47941	308.1 to 311.0 feet	Vertical Change	-4	5 ft	14	REF		
40153	316.9 to 318.5 feet	Running Slope	6.0-7.0%	5 ft	8	REF		
50000	324.2 to 325.2 feet	Vertical Change	-33	5 ft	5	LF	\$75	\$375
48468	338.9 to 339.9 feet	Vertical Change	-38	5 ft	5	LF	\$75	\$375
50740	348.3 to 349.3 feet	Vertical Change	-31	5 ft	5	LF	\$75	\$375
5020	354.1 to 401.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	236	SF	\$120	\$28,320
51653	359.1 to 360.1 feet	Vertical Change	-3	5 ft	5	REF		
49660	363.3 to 364.3 feet	Vertical Change	-34	5 ft	5	REF		
49661	378.0 to 379.0 feet	Vertical Change	-34	5 ft	5	REF		
53985	382.7 to 383.7 feet	Vertical Change	-25	5 ft	5	REF		
49662	396.8 to 397.8 feet	Vertical Change	-34	5 ft	5	REF		
57982	398.3 to 422.4 feet	Driveway				REF		
5026	404.9 to 419.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	72	SF	\$40	\$2,860
52529	411.3 to 412.3 feet	Vertical Change	-28	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
N	1908220838	CALAVERAS ST	PENNY ST	CALAVERAS ST				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40154	418.7 to 419.8 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
5027	423.2 to 457.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	171	SF	\$120	\$20,460
53044	426.6 to 427.6 feet	Vertical Change	-27	5 ft	5	REF		
44039	441.8 to 442.8 feet	Vertical Change	-.57	5 ft	5	REF		
47280	446.9 to 447.9 feet	Vertical Change	-.42	5 ft	5	REF		
42558	451.7 to 452.7 feet	Vertical Change	-.68	5 ft	5	REF		
57983	452.8 to 483.2 feet	Driveway				REF		
47049	456.5 to 458.6 feet	Vertical Change	-.43	5 ft	11	REF		
5032	461.3 to 480.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	98	SF	\$40	\$3,920
47281	471.6 to 472.6 feet	Vertical Change	-.42	5 ft	5	REF		
40155	479.9 to 481.6 feet	Running Slope	5.0-6.0%	5 ft	9	REF		
47524	483.2 to 484.2 feet	Vertical Change	-.41	5 ft	5	REF		
5035	484.3 to 499.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	75	SF	\$120	\$9,000
50359	488.9 to 489.9 feet	Vertical Change	-.32	5 ft	5	REF		
43114	491.2 to 492.2 feet	Vertical Change	-.63	5 ft	5	REF		
46589	496.1 to 497.1 feet	Vertical Change	-.45	5 ft	5	REF		
5036	499.3 to 544.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	225	SF	\$120	\$27,000
50360	500.9 to 501.9 feet	Vertical Change	-.32	5 ft	5	REF		
46590	506.3 to 507.3 feet	Vertical Change	-.45	5 ft	5	REF		
44853	510.7 to 511.7 feet	Vertical Change	-.53	5 ft	5	REF		
48469	515.1 to 516.1 feet	Vertical Change	-.38	5 ft	5	REF		
46828	520.0 to 521.0 feet	Vertical Change	-.44	5 ft	5	REF		
45226	525.0 to 526.0 feet	Vertical Change	-.51	5 ft	5	REF		
45919	529.9 to 530.9 feet	Vertical Change	-.48	5 ft	5	REF		
44426	533.6 to 534.6 feet	Vertical Change	-.55	5 ft	5	REF		
46362	537.0 to 538.0 feet	Vertical Change	-.46	5 ft	5	REF		
45507	540.2 to 541.2 feet	Vertical Change	-.5	5 ft	5	REF		
45227	544.0 to 545.0 feet	Vertical Change	-.51	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908220838	CALAVERAS ST	PENNY ST	CALAVERAS ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
5038	544.3 to 559.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	76	SF	\$120	\$9,060
45721	548.4 to 549.4 feet	Vertical Change	-.49	5 ft	5	REF		
45228	552.7 to 553.7 feet	Vertical Change	-.51	5 ft	5	REF		
48753	556.8 to 557.8 feet	Vertical Change	-.37	5 ft	5	REF		
5040	559.4 to 575.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	83	SF	\$120	\$9,900
49040	561.2 to 562.2 feet	Vertical Change	-.36	5 ft	5	REF		
49347	566.5 to 567.5 feet	Vertical Change	-.35	5 ft	5	REF		
52530	571.7 to 572.7 feet	Vertical Change	-.28	5 ft	5	REF		
48470	577.1 to 578.1 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: N side of CALAVERAS ST Starting at: PENNY ST							\$153,865.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
W	1908220840	CALAVERAS ST	CALAVERAS ST	SIDEWALK ENDS	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
50001	11.0 to 12.0 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375	
5041	13.6 to 42.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	147	SF	\$120	\$17,580	
46363	16.1 to 17.1 feet	Vertical Change	-.46	5 ft	5	REF			
48187	21.4 to 22.4 feet	Vertical Change	-.39	5 ft	5	REF			
44651	26.7 to 27.7 feet	Vertical Change	-.54	5 ft	5	REF			
46131	36.6 to 37.6 feet	Vertical Change	-.47	5 ft	5	REF			
46364	41.3 to 42.3 feet	Vertical Change	-.46	5 ft	5	REF			
5045	42.9 to 75.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	163	SF	\$120	\$19,500	
44854	46.3 to 47.3 feet	Vertical Change	-.53	5 ft	5	REF			
41660	51.2 to 52.2 feet	Vertical Change	-.92	5 ft	5	REF			
45508	55.8 to 56.8 feet	Vertical Change	-.5	5 ft	5	REF			
46591	60.5 to 61.5 feet	Vertical Change	-.45	5 ft	5	REF			
43870	65.7 to 66.7 feet	Vertical Change	-.58	5 ft	5	REF			
46592	71.0 to 72.0 feet	Vertical Change	-.45	5 ft	5	REF			
5048	75.4 to 99.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	118	SF	\$120	\$14,220	
47050	76.0 to 77.0 feet	Vertical Change	-.43	5 ft	5	REF			
45229	81.1 to 82.1 feet	Vertical Change	-.51	5 ft	5	REF			
44427	86.3 to 87.3 feet	Vertical Change	-.55	5 ft	5	REF			
47942	96.4 to 97.4 feet	Vertical Change	-.4	5 ft	5	REF			
52531	101.7 to 102.7 feet	Vertical Change	-.28	5 ft	5	REF			
5049	102.7 to 110.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,680	
51654	106.8 to 107.8 feet	Vertical Change	-.3	5 ft	5	REF			
46132	112.0 to 113.0 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375	
5050	113.9 to 115.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020	
47525	117.2 to 118.2 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375	
46365	122.5 to 123.5 feet	Vertical Change	-.46	5 ft	5	LF	\$75	\$375	
5051	126.4 to 155.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	147	SF	\$120	\$17,640	
49663	127.4 to 128.4 feet	Vertical Change	-.34	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908220840	CALAVERAS ST	CALAVERAS ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47051	137.8 to 138.8 feet	Vertical Change	-.43	5 ft	5	REF		
47943	143.3 to 144.3 feet	Vertical Change	-.4	5 ft	5	REF		
45034	148.0 to 149.0 feet	Vertical Change	-.52	5 ft	5	REF		
46366	152.8 to 153.8 feet	Vertical Change	-.46	5 ft	5	REF		
46133	157.6 to 158.6 feet	Vertical Change	-.47	5 ft	5	REF		
5052	158.6 to 172.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	71	SF	\$120	\$8,520
47052	167.6 to 168.6 feet	Vertical Change	-.43	5 ft	5	REF		
5053	175.0 to 308.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	666	SF	\$120	\$79,860
47053	177.3 to 178.3 feet	Vertical Change	-.43	5 ft	5	REF		
47526	187.0 to 188.0 feet	Vertical Change	-.41	5 ft	5	REF		
49041	197.0 to 198.0 feet	Vertical Change	-.36	5 ft	5	REF		
46134	206.9 to 207.9 feet	Vertical Change	-.47	5 ft	5	REF		
53045	211.7 to 212.7 feet	Vertical Change	-.27	5 ft	5	REF		
52532	216.5 to 217.5 feet	Vertical Change	-.28	5 ft	5	REF		
50741	226.2 to 227.2 feet	Vertical Change	-.31	5 ft	5	REF		
51655	231.1 to 232.1 feet	Vertical Change	-.3	5 ft	5	REF		
53046	236.1 to 237.1 feet	Vertical Change	-.27	5 ft	5	REF		
53572	246.1 to 247.1 feet	Vertical Change	-.26	5 ft	5	REF		
49042	255.8 to 256.8 feet	Vertical Change	-.36	5 ft	5	REF		
48188	265.6 to 266.6 feet	Vertical Change	-.39	5 ft	5	REF		
48754	270.7 to 271.7 feet	Vertical Change	-.37	5 ft	5	REF		
47527	275.7 to 276.7 feet	Vertical Change	-.41	5 ft	5	REF		
53573	280.6 to 281.6 feet	Vertical Change	-.26	5 ft	5	REF		
48189	285.6 to 286.6 feet	Vertical Change	-.39	5 ft	5	REF		
47282	295.0 to 296.0 feet	Vertical Change	-.42	5 ft	5	REF		
42559	299.4 to 300.4 feet	Vertical Change	-.68	5 ft	5	REF		
50742	304.8 to 305.8 feet	Vertical Change	-.31	5 ft	5	REF		
51656	310.3 to 311.3 feet	Vertical Change	-.3	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908220840	CALAVERAS ST	CALAVERAS ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
5069	311.2 to 328.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	88	SF	\$120	\$10,560
48755	316.8 to 317.8 feet	Vertical Change	-37	5 ft	5	REF		
53047	323.1 to 324.1 feet	Vertical Change	-27	5 ft	5	REF		
TOTAL COST FOR: W side of CALAVERAS ST Starting at: CALAVERAS ST							\$175,080.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908220855	CALAVERAS ST	SIDEWALK BEGINS	ROSEHILL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
5071	0.7 to 13.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	65	SF	\$120	\$7,740
45230	1.7 to 2.7 feet	Vertical Change	-.51	5 ft	5	REF		
45920	7.4 to 8.4 feet	Vertical Change	-.48	5 ft	5	REF		
45921	12.2 to 13.2 feet	Vertical Change	-.48	5 ft	5	REF		
5072	13.6 to 27.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,160
41661	16.1 to 17.1 feet	Vertical Change	-.92	5 ft	5	REF		
46829	21.2 to 22.2 feet	Vertical Change	-.44	5 ft	5	LF	\$75	\$375
5077	27.2 to 31.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	22	SF	\$120	\$2,640
45922	27.3 to 28.3 feet	Vertical Change	-.48	5 ft	5	REF		
5079	31.6 to 72.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	202	SF	\$120	\$24,240
45722	33.4 to 34.4 feet	Vertical Change	-.49	5 ft	5	REF		
50002	37.5 to 38.5 feet	Vertical Change	-.33	5 ft	5	REF		
43115	41.3 to 42.3 feet	Vertical Change	-.63	5 ft	5	REF		
46135	46.8 to 47.8 feet	Vertical Change	-.47	5 ft	5	REF		
46367	52.3 to 53.3 feet	Vertical Change	-.46	5 ft	5	REF		
45923	57.8 to 58.8 feet	Vertical Change	-.48	5 ft	5	REF		
44040	63.3 to 64.3 feet	Vertical Change	-.57	5 ft	5	REF		
47528	69.1 to 70.1 feet	Vertical Change	-.41	5 ft	5	REF		
TOTAL COST FOR: W side of CALAVERAS ST Starting at: SIDEWALK BEGINS							\$43,155.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908220859	ROSEHILL DR	CALAVERAS ST	MICHELLE CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5086	0.0 to 4.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	24	SF	\$120	\$2,820	
44225	3.2 to 4.2 feet	Vertical Change	-.56	5 ft	5	REF			
5087	4.7 to 37.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	165	SF	\$120	\$19,860	
50003	8.0 to 9.0 feet	Vertical Change	-.33	5 ft	5	REF			
46593	11.3 to 12.3 feet	Vertical Change	-.45	5 ft	5	REF			
46368	15.1 to 16.1 feet	Vertical Change	-.46	5 ft	5	REF			
45509	18.3 to 19.3 feet	Vertical Change	-.5	5 ft	5	REF			
48190	22.1 to 23.1 feet	Vertical Change	-.39	5 ft	5	REF			
45924	26.7 to 27.7 feet	Vertical Change	-.48	5 ft	5	REF			
46830	31.5 to 35.3 feet	Vertical Change	-.44	5 ft	19	REF			
57984	32.8 to 62.7 feet	Driveway				REF			
43116	38.2 to 39.2 feet	Vertical Change	-.63	5 ft	5	REF			
5091	41.8 to 58.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	85	SF	\$40	\$3,380	
44652	48.7 to 49.7 feet	Vertical Change	-.54	5 ft	5	REF			
40156	58.3 to 59.8 feet	Running Slope	6.0-7.0%	5 ft	8	REF			
53049	61.5 to 62.5 feet	Vertical Change	-.27	5 ft	5	REF			
5095	62.7 to 63.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$220	
5096	63.8 to 84.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	105	SF	\$120	\$12,600	
48756	65.2 to 66.2 feet	Vertical Change	-.37	5 ft	5	REF			
51657	69.1 to 70.1 feet	Vertical Change	-.3	5 ft	5	REF			
47529	73.6 to 74.6 feet	Vertical Change	-.41	5 ft	5	REF			
57985	80.8 to 118.3 feet	Driveway				REF			
47530	82.9 to 86.0 feet	Vertical Change	-.41	5 ft	16	REF			
5097	88.7 to 114.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	131	SF	\$40	\$5,240	
46594	95.5 to 96.5 feet	Vertical Change	-.45	5 ft	5	REF			
46136	106.0 to 107.0 feet	Vertical Change	-.47	5 ft	5	REF			
53574	117.5 to 120.9 feet	Vertical Change	-.26	5 ft	17	REF			
5104	118.3 to 119.5 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$240	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908220859	ROSEHILL DR	CALAVERAS ST	MICHELLE CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
5105	119.5 to 263.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	719	SF	\$120	\$86,280
47283	124.6 to 125.6 feet	Vertical Change	-.42	5 ft	5	REF		
46369	128.9 to 129.9 feet	Vertical Change	-.46	5 ft	5	REF		
46595	134.0 to 135.0 feet	Vertical Change	-.45	5 ft	5	REF		
47531	138.4 to 139.4 feet	Vertical Change	-.41	5 ft	5	REF		
48471	143.1 to 144.1 feet	Vertical Change	-.38	5 ft	5	REF		
49043	147.5 to 148.5 feet	Vertical Change	-.36	5 ft	5	REF		
50361	152.7 to 153.7 feet	Vertical Change	-.32	5 ft	5	REF		
48757	157.0 to 158.0 feet	Vertical Change	-.37	5 ft	5	REF		
48472	166.5 to 167.5 feet	Vertical Change	-.38	5 ft	5	REF		
47284	176.1 to 177.1 feet	Vertical Change	-.42	5 ft	5	REF		
46596	181.1 to 182.1 feet	Vertical Change	-.45	5 ft	5	REF		
48473	185.9 to 186.9 feet	Vertical Change	-.38	5 ft	5	REF		
46137	190.7 to 191.7 feet	Vertical Change	-.47	5 ft	5	REF		
52083	200.5 to 201.5 feet	Vertical Change	-.29	5 ft	5	REF		
49348	209.9 to 210.9 feet	Vertical Change	-.35	5 ft	5	REF		
50743	214.5 to 215.5 feet	Vertical Change	-.31	5 ft	5	REF		
49349	219.8 to 220.8 feet	Vertical Change	-.35	5 ft	5	REF		
48758	224.3 to 225.3 feet	Vertical Change	-.37	5 ft	5	REF		
50362	229.1 to 230.1 feet	Vertical Change	-.32	5 ft	5	REF		
47944	233.7 to 234.7 feet	Vertical Change	-.4	5 ft	5	REF		
45723	238.8 to 239.8 feet	Vertical Change	-.49	5 ft	5	REF		
49664	243.6 to 244.6 feet	Vertical Change	-.34	5 ft	5	REF		
48474	248.4 to 249.4 feet	Vertical Change	-.38	5 ft	5	REF		
52533	261.3 to 262.3 feet	Vertical Change	-.28	5 ft	5	REF		
TOTAL COST FOR: S							side of ROSEHILL DR Starting at: CALAVERAS ST	\$130,640.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908220901	MICHELLE CT	ROSEHILL DR	888 MICHELLE CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5112	0.0 to 9.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,880	
48759	5.5 to 12.5 feet	Vertical Change	-.37	5 ft	35	REF			
5114	9.8 to 24.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	75	SF	\$120	\$9,000	
50744	15.8 to 16.8 feet	Vertical Change	-.31	5 ft	5	REF			
53986	19.9 to 20.9 feet	Vertical Change	-.25	5 ft	5	REF			
5117	24.8 to 31.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020	
57986	26.4 to 53.9 feet	Driveway				REF			
52084	31.7 to 32.7 feet	Vertical Change	-.29	5 ft	5	REF			
5118	35.6 to 50.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	76	SF	\$40	\$3,040	
49665	43.9 to 44.9 feet	Vertical Change	-.34	5 ft	5	REF			
5119	54.3 to 72.6 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	91	SF	\$40	\$3,660	
49350	60.7 to 61.7 feet	Vertical Change	-.35	5 ft	5	REF			
57987	66.9 to 94.4 feet	Driveway				REF			
5120	76.0 to 90.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	73	SF	\$40	\$2,900	
53050	82.3 to 83.3 feet	Vertical Change	-.27	5 ft	5	REF			
40157	90.1 to 91.3 feet	Running Slope	6.0-7.0%	5 ft	6	REF			
40158	91.3 to 92.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
5122	94.2 to 110.9 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	84	SF	\$40	\$3,340	
52085	105.0 to 106.0 feet	Vertical Change	-.29	5 ft	5	REF			
5124	110.9 to 112.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$840	
5125	112.3 to 118.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,660	
57988	115.2 to 139.4 feet	Driveway				REF			
47054	116.5 to 119.2 feet	Vertical Change	-.43	5 ft	14	REF			
5127	121.8 to 136.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	73	SF	\$40	\$2,920	
43871	129.7 to 130.7 feet	Vertical Change	-.58	5 ft	5	REF			
5131	140.2 to 145.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	24	SF	\$120	\$2,880	
49044	140.9 to 144.6 feet	Vertical Change	-.36	5 ft	19	REF			
30	143.3 to 144.3 feet	Continuous Width		5 ft	5	SF	\$120	\$600	

TOTAL COST FOR: W side of MICHELLE CT Starting at: ROSEHILL DR \$42,740.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908220903	MICHELLE CT	888 MICHELLE CT	ROSEHILL DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5132	0.0 to 2.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	14	SF	\$120	\$1,680	
57989	0.0 to 33.4 feet	Driveway				REF			
5133	7.3 to 30.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	118	SF	\$40	\$4,700	
40159	29.7 to 30.7 feet	Running Slope	6.0-7.0%	5 ft	5	REF			
47945	33.3 to 34.3 feet	Vertical Change	-4	5 ft	5	REF			
5137	34.8 to 40.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	28	SF	\$120	\$3,300	
57990	37.1 to 71.8 feet	Driveway				REF			
5138	45.2 to 69.2 feet	Cross Slope (Driveway)	13.014	5 ft	120	SF	\$40	\$4,800	
52086	52.0 to 54.8 feet	Vertical Change	-29	5 ft	14	REF			
52534	61.7 to 62.7 feet	Vertical Change	-28	5 ft	5	REF			
40160	67.7 to 69.1 feet	Running Slope	6.0-7.0%	5 ft	7	REF			
52535	71.5 to 72.5 feet	Vertical Change	-28	5 ft	5	REF			
5142	72.7 to 78.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	27	SF	\$120	\$3,240	
5144	78.1 to 83.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,240	
57991	80.3 to 118.5 feet	Driveway				REF			
5146	83.5 to 84.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	6	SF	\$40	\$220	
5147	88.0 to 116.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	142	SF	\$40	\$5,660	
49351	95.0 to 96.0 feet	Vertical Change	-35	5 ft	5	REF			
47532	105.2 to 108.1 feet	Vertical Change	-41	5 ft	15	REF			
40161	115.0 to 116.5 feet	Running Slope	6.0-7.0%	5 ft	8	REF			
41369	118.4 to 119.4 feet	Vertical Change	-1.36	5 ft	5	REF			
5155	119.4 to 135.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	80	SF	\$120	\$9,540	
52087	120.4 to 121.4 feet	Vertical Change	-29	5 ft	5	REF			
47055	124.6 to 125.6 feet	Vertical Change	-43	5 ft	5	REF			
41355	129.7 to 130.7 feet	Vertical Change	-1.38	5 ft	5	REF			
46138	132.8 to 133.8 feet	Vertical Change	-47	5 ft	5	REF			
5157	135.3 to 136.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600	
45925	136.1 to 137.1 feet	Vertical Change	-48	5 ft	5	REF			

TOTAL COST FOR:	E	<i>side of</i> MICHELLE CT	<i>Starting at:</i> 888 MICHELLE CT	\$36,980.00
------------------------	----------	-----------------------------------	--	--------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908220905	ROSEHILL DR	MICHELLE CT	AMADOR ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5158	0.0 to 8.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800	
45511	4.1 to 5.1 feet	Vertical Change	-5	5 ft	5	REF			
5160	8.0 to 27.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	100	SF	\$120	\$11,940	
45231	8.8 to 9.8 feet	Vertical Change	-51	5 ft	5	REF			
51658	13.9 to 14.9 feet	Vertical Change	-3	5 ft	5	REF			
47946	19.2 to 20.2 feet	Vertical Change	-4	5 ft	5	REF			
47056	24.1 to 25.1 feet	Vertical Change	-43	5 ft	5	REF			
5162	27.9 to 36.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,280	
46831	29.3 to 30.3 feet	Vertical Change	-44	5 ft	5	REF			
46371	33.9 to 34.9 feet	Vertical Change	-46	5 ft	5	REF			
46139	39.6 to 40.6 feet	Vertical Change	-47	5 ft	5	LF	\$75	\$375	
5163	43.6 to 59.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	79	SF	\$120	\$9,420	
44042	44.2 to 45.2 feet	Vertical Change	-57	5 ft	5	REF			
45512	50.0 to 51.0 feet	Vertical Change	-5	5 ft	5	REF			
40162	50.3 to 51.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
40163	51.3 to 57.3 feet	Running Slope	6.0-7.0%	5 ft	30	REF			
45724	54.8 to 55.8 feet	Vertical Change	-49	5 ft	5	REF			
5165	59.3 to 89.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	149	SF	\$120	\$17,820	
41894	60.2 to 61.2 feet	Vertical Change	-8	5 ft	5	REF			
44653	65.2 to 66.2 feet	Vertical Change	-54	5 ft	5	REF			
47947	70.7 to 71.7 feet	Vertical Change	-4	5 ft	5	REF			
50364	75.3 to 76.3 feet	Vertical Change	-32	5 ft	5	REF			
50004	80.5 to 81.5 feet	Vertical Change	-33	5 ft	5	REF			
50745	84.1 to 85.1 feet	Vertical Change	-31	5 ft	5	REF			
49666	87.8 to 88.8 feet	Vertical Change	-34	5 ft	5	REF			
5171	89.0 to 139.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	254	SF	\$120	\$30,480	
49045	91.4 to 92.4 feet	Vertical Change	-36	5 ft	5	REF			
49352	100.5 to 101.5 feet	Vertical Change	-35	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908220905	ROSEHILL DR	MICHELLE CT	AMADOR ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47285	120.9 to 121.9 feet	Vertical Change	-.42	5 ft	5	REF		
52536	135.8 to 136.8 feet	Vertical Change	-.28	5 ft	5	REF		
5178	139.8 to 180.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	201	SF	\$120	\$24,180
53575	141.1 to 142.1 feet	Vertical Change	-.26	5 ft	5	REF		
47057	146.1 to 147.1 feet	Vertical Change	-.43	5 ft	5	REF		
46597	151.1 to 152.1 feet	Vertical Change	-.45	5 ft	5	REF		
50005	160.9 to 161.9 feet	Vertical Change	-.33	5 ft	5	REF		
5182	180.1 to 200.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	103	SF	\$120	\$12,360
49046	192.1 to 193.1 feet	Vertical Change	-.36	5 ft	5	REF		
5184	200.7 to 221.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	106	SF	\$120	\$12,660
5188	221.8 to 225.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040
5189	228.2 to 234.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,720
5191	234.4 to 242.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	42	SF	\$120	\$4,980
49667	235.6 to 236.6 feet	Vertical Change	-.34	5 ft	5	REF		
5193	242.7 to 251.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,280
5195	251.5 to 256.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	27	SF	\$120	\$3,180
TOTAL COST FOR: S							side of ROSEHILL DR Starting at: MICHELLE CT	\$148,515.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908220907	AMADOR ST	ROSEHILL DR	CIRCLE DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5196	0.6 to 4.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	17	SF	\$120	\$2,040	
5198	4.0 to 10.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	32	SF	\$120	\$3,780	
48761	7.6 to 8.6 feet	Vertical Change	-37	5 ft	5	REF			
5200	10.3 to 23.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	66	SF	\$120	\$7,920	
53576	12.1 to 13.1 feet	Vertical Change	-26	5 ft	5	REF			
46832	21.7 to 22.7 feet	Vertical Change	-44	5 ft	5	REF			
5202	23.5 to 35.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,080	
46372	28.4 to 29.4 feet	Vertical Change	-46	5 ft	5	REF			
57992	32.8 to 57.4 feet	Driveway				REF			
50006	35.6 to 36.6 feet	Vertical Change	-33	5 ft	5	REF			
5205	39.1 to 53.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	71	SF	\$40	\$2,840	
40164	51.8 to 53.9 feet	Running Slope	6.0-7.0%	5 ft	11	REF			
5207	56.8 to 78.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	106	SF	\$40	\$4,260	
47948	63.6 to 64.6 feet	Vertical Change	-4	5 ft	5	REF			
43392	70.7 to 71.7 feet	Vertical Change	-61	5 ft	5	REF			
57993	72.9 to 97.4 feet	Driveway				REF			
41742	77.7 to 78.7 feet	Vertical Change	-87	5 ft	5	REF			
5209	81.8 to 95.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	69	SF	\$40	\$2,760	
47058	88.3 to 89.3 feet	Vertical Change	-43	5 ft	5	REF			
40165	94.3 to 95.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
46598	98.8 to 99.8 feet	Vertical Change	-45	5 ft	5	REF			
5211	99.4 to 107.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,860	
45035	105.6 to 106.6 feet	Vertical Change	-52	5 ft	5	REF			
5212	112.8 to 130.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	90	SF	\$120	\$10,800	
48193	113.0 to 114.0 feet	Vertical Change	-39	5 ft	5	REF			
44226	120.2 to 121.2 feet	Vertical Change	-56	5 ft	5	REF			
46373	127.5 to 128.5 feet	Vertical Change	-46	5 ft	5	REF			
46833	131.1 to 132.1 feet	Vertical Change	-44	5 ft	5	LF	\$75	\$375	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908220907	AMADOR ST	ROSEHILL DR	CIRCLE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
5217	139.8 to 158.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	93	SF	\$120	\$11,100
47286	141.7 to 142.7 feet	Vertical Change	-42	5 ft	5	REF		
52088	148.8 to 149.8 feet	Vertical Change	-29	5 ft	5	REF		
49047	160.8 to 161.8 feet	Vertical Change	-36	5 ft	5	REF		
5220	161.2 to 165.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760
57994	161.8 to 188.5 feet	Driveway				REF		
44428	166.0 to 167.0 feet	Vertical Change	-55	5 ft	5	REF		
5221	169.5 to 178.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	46	SF	\$40	\$1,840
52089	177.4 to 178.4 feet	Vertical Change	-29	5 ft	5	REF		
5223	178.7 to 186.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	38	SF	\$40	\$1,520
40166	185.0 to 186.8 feet	Running Slope	5.0-6.0%	5 ft	9	REF		
5225	190.1 to 200.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$5,940
45926	196.4 to 197.4 feet	Vertical Change	-48	5 ft	5	REF		
47287	203.1 to 204.1 feet	Vertical Change	-42	5 ft	5	LF	\$75	\$375
5226	210.1 to 216.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020
47949	217.8 to 218.8 feet	Vertical Change	-4	5 ft	5	LF	\$75	\$375
57995	219.7 to 262.8 feet	Driveway				REF		
49048	223.0 to 224.0 feet	Vertical Change	-36	5 ft	5	REF		
5227	225.8 to 231.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	26	SF	\$40	\$1,040
47288	230.8 to 231.8 feet	Vertical Change	-42	5 ft	5	REF		
5229	231.0 to 244.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	70	SF	\$40	\$2,780
45232	238.1 to 239.1 feet	Vertical Change	-51	5 ft	5	REF		
5233	245.6 to 248.9 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	17	SF	\$40	\$660
5236	250.3 to 259.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	47	SF	\$40	\$1,880
40167	259.1 to 261.0 feet	Running Slope	5.0-6.0%	5 ft	9	REF		
49668	262.5 to 263.5 feet	Vertical Change	-34	5 ft	5	REF		
5238	263.7 to 277.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	71	SF	\$120	\$8,520
47533	277.2 to 278.2 feet	Vertical Change	-41	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908220907	AMADOR ST	ROSEHILL DR	CIRCLE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
5240	277.9 to 318.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	202	SF	\$120	\$24,180
44855	290.0 to 291.1 feet	Vertical Change	-.53	5 ft	6	REF		
50007	297.5 to 298.5 feet	Vertical Change	-.33	5 ft	5	REF		
57299	310.0 to 311.0 feet	Vertical Change	.89	5 ft	5	REF		
57375	317.4 to 318.4 feet	Vertical Change	1.07	5 ft	5	REF		
5245	318.2 to 324.1 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	30	SF	\$120	\$3,540
5246	324.1 to 339.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	75	SF	\$120	\$9,060
5248	339.2 to 340.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$600
47534	340.0 to 341.0 feet	Vertical Change	-.41	5 ft	5	REF		
5249	340.2 to 342.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
5250	360.7 to 402.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	208	SF	\$120	\$24,960
53051	370.1 to 371.1 feet	Vertical Change	-.27	5 ft	5	REF		
5259	406.5 to 424.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	92	SF	\$120	\$10,980
TOTAL COST FOR: W side of AMADOR ST Starting at: ROSEHILL DR							\$163,925.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1908220910	AMADOR ST	CIRCLE DR	ROSEHILL DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5262	0.0 to 24.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	108	SF	\$120	\$13,014	
49353	8.2 to 9.2 feet	Vertical Change	-.35	5 ft	5	REF			
42090	24.1 to 25.1 feet	Vertical Change	-.75	5 ft	5	REF			
41862	44.1 to 45.1 feet	Vertical Change	-.81	5 ft	5	SF	\$75	\$338	
42235	75.5 to 76.5 feet	Vertical Change	-.72	5 ft	5	SF	\$75	\$338	
5267	96.5 to 136.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	180	SF	\$120	\$21,546	
44856	105.6 to 106.6 feet	Vertical Change	-.53	5 ft	5	REF			
57996	135.6 to 159.5 feet	Driveway				REF			
5272	136.4 to 140.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	20	SF	\$40	\$792	
44654	140.9 to 141.9 feet	Vertical Change	-.54	5 ft	5	REF			
5273	144.2 to 156.0 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	53	SF	\$40	\$2,124	
53987	159.4 to 160.4 feet	Vertical Change	-.25	5 ft	5	REF			
5277	159.8 to 178.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	84	SF	\$40	\$3,366	
5279	178.5 to 276.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	440	SF	\$120	\$52,758	
49050	180.3 to 181.3 feet	Vertical Change	-.36	5 ft	5	REF			
46140	206.7 to 207.7 feet	Vertical Change	-.47	5 ft	5	REF			
42045	220.1 to 221.1 feet	Vertical Change	-.76	5 ft	5	REF			
45927	233.4 to 234.4 feet	Vertical Change	-.48	5 ft	5	REF			
57997	272.1 to 299.4 feet	Driveway				REF			
5284	279.7 to 285.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	27	SF	\$40	\$1,098	
5286	285.8 to 296.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	50	SF	\$40	\$1,980	
5288	300.0 to 376.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	344	SF	\$120	\$41,310	
53577	315.7 to 316.7 feet	Vertical Change	-.26	5 ft	5	REF			
51659	372.5 to 373.5 feet	Vertical Change	-.3	5 ft	5	REF			
5298	376.5 to 379.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,512	
TOTAL COST FOR: E							side of AMADOR ST Starting at: CIRCLE DR	\$140,175.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	1908220915	ROSEHILL DR	AMADOR ST	CALAVERAS ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5299	1.0 to 125.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	624	SF	\$120	\$74,820	
53578	118.4 to 119.4 feet	Vertical Change	-26	5 ft	5	REF			
57998	122.1 to 147.1 feet	Driveway				REF			
5314	130.7 to 144.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	70	SF	\$40	\$2,800	
40168	143.3 to 145.6 feet	Running Slope	5.0-6.0%	5 ft	11	REF			
52537	146.6 to 147.6 feet	Vertical Change	-28	5 ft	5	REF			
5316	148.2 to 154.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	33	SF	\$120	\$3,960	
57999	150.8 to 176.1 feet	Driveway				REF			
5318	158.3 to 172.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	71	SF	\$40	\$2,840	
40170	172.8 to 173.8 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
49051	175.5 to 176.5 feet	Vertical Change	-36	5 ft	5	REF			
5320	180.1 to 203.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	118	SF	\$120	\$14,160	
49669	188.9 to 189.9 feet	Vertical Change	-34	5 ft	5	REF			
5322	203.7 to 269.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	331	SF	\$120	\$39,720	
53579	204.4 to 205.4 feet	Vertical Change	-26	5 ft	5	REF			
47950	240.1 to 241.1 feet	Vertical Change	-4	5 ft	5	REF			
44655	254.8 to 255.8 feet	Vertical Change	-54	5 ft	5	REF			
5331	269.9 to 296.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	135	SF	\$120	\$16,140	
58000	292.8 to 316.8 feet	Driveway				REF			
5335	300.5 to 314.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	69	SF	\$40	\$2,760	
40171	313.3 to 315.8 feet	Running Slope	5.0-6.0%	5 ft	13	REF			
5337	318.1 to 326.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800	
58001	321.8 to 346.1 feet	Driveway				REF			
52090	326.8 to 327.8 feet	Vertical Change	-29	5 ft	5	REF			
5338	330.2 to 342.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	63	SF	\$40	\$2,500	
40172	342.7 to 345.2 feet	Running Slope	5.0-6.0%	5 ft	13	REF			
5341	346.3 to 411.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	327	SF	\$40	\$13,060	
5349	411.6 to 441.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	151	SF	\$120	\$18,060	
50008	418.6 to 419.6 feet	Vertical Change	-33	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	1908220915	ROSEHILL DR	AMADOR ST	CALAVERAS ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5356	444.2 to 470.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	133	SF	\$120	\$15,960	
58002	466.1 to 489.6 feet	Driveway				REF			
5363	474.3 to 486.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	60	SF	\$40	\$2,400	
5364	490.0 to 551.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	309	SF	\$40	\$12,340	
50009	523.0 to 524.0 feet	Vertical Change	-.33	5 ft	5	REF			
44227	537.3 to 538.3 feet	Vertical Change	-.56	5 ft	5	REF			
5371	551.7 to 566.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	73	SF	\$120	\$8,760	
58003	561.8 to 587.2 feet	Driveway				REF			
50746	563.9 to 564.9 feet	Vertical Change	-.31	5 ft	5	REF			
5375	569.7 to 582.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	64	SF	\$40	\$2,560	
5377	582.5 to 585.0 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	13	SF	\$40	\$500	
40174	584.2 to 586.1 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
5379	588.3 to 596.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	39	SF	\$120	\$4,680	
58004	591.3 to 616.5 feet	Driveway				REF			
50747	596.5 to 597.5 feet	Vertical Change	-.31	5 ft	5	REF			
5380	599.5 to 613.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	70	SF	\$40	\$2,800	
53052	616.0 to 617.0 feet	Vertical Change	-.27	5 ft	5	REF			
5382	617.9 to 657.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	200	SF	\$120	\$23,940	
44857	620.9 to 623.8 feet	Vertical Change	-.53	5 ft	14	REF			
41434	624.3 to 625.3 feet	Vertical Change	-1.2	5 ft	5	REF			
42010	628.1 to 629.1 feet	Vertical Change	-.77	5 ft	5	REF			
41579	642.3 to 643.3 feet	Vertical Change	-1	5 ft	5	REF			
43117	656.9 to 657.9 feet	Vertical Change	-.63	5 ft	5	REF			
5386	657.8 to 707.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	248	SF	\$120	\$29,760	
42994	671.6 to 672.6 feet	Vertical Change	-.64	5 ft	5	REF			
41798	685.6 to 686.6 feet	Vertical Change	-.84	5 ft	5	REF			
45233	700.3 to 701.3 feet	Vertical Change	-.51	5 ft	5	REF			
53580	704.9 to 705.9 feet	Vertical Change	-.26	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	1908220915	ROSEHILL DR	AMADOR ST	CALAVERAS ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5390	707.4 to 743.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	183	SF	\$120	\$21,900	
52091	714.5 to 715.5 feet	Vertical Change	-29	5 ft	5	REF			
58005	740.2 to 766.4 feet	Driveway				REF			
53988	744.7 to 745.7 feet	Vertical Change	-25	5 ft	5	REF			
5394	748.2 to 763.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	75	SF	\$40	\$2,980	
40175	762.2 to 764.7 feet	Running Slope	5.0-6.0%	5 ft	13	REF			
5397	766.7 to 776.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	47	SF	\$120	\$5,640	
58006	772.8 to 796.9 feet	Driveway				REF			
5399	779.7 to 793.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	69	SF	\$40	\$2,740	
40177	793.3 to 794.7 feet	Running Slope	6.0-7.0%	5 ft	7	REF			
42187	796.0 to 797.0 feet	Vertical Change	-73	5 ft	5	REF			
5401	797.0 to 798.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200	
5402	798.0 to 857.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	300	SF	\$120	\$35,940	
52538	831.4 to 832.4 feet	Vertical Change	-28	5 ft	5	REF			
58007	856.9 to 883.3 feet	Driveway				REF			
49354	861.5 to 862.5 feet	Vertical Change	-35	5 ft	5	REF			
5407	864.2 to 880.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	82	SF	\$40	\$3,280	
40178	879.4 to 881.7 feet	Running Slope	6.0-7.0%	5 ft	12	REF			
51660	883.1 to 884.1 feet	Vertical Change	-3	5 ft	5	REF			
5410	883.5 to 884.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$720	
5411	884.7 to 893.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$4,980	
5413	893.0 to 951.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	291	SF	\$120	\$34,920	
51661	915.6 to 916.6 feet	Vertical Change	-3	5 ft	5	REF			
46834	944.4 to 945.4 feet	Vertical Change	-44	5 ft	5	REF			
5417	951.2 to 961.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,120	
52539	958.8 to 959.8 feet	Vertical Change	-28	5 ft	5	REF			
5419	961.4 to 986.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	127	SF	\$120	\$15,240	
49670	973.8 to 974.8 feet	Vertical Change	-34	5 ft	5	REF			
58008	984.3 to 1012.3 feet	Driveway				REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
SE	1908220915	ROSEHILL DR	AMADOR ST	CALAVERAS ST	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
52092	986.7 to 990.3 feet	Vertical Change	-.29	5 ft	18	REF					
5421	986.8 to 988.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$300			
5422	992.7 to 1002.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	50	SF	\$40	\$2,000			
5424	1002.7 to 1009.4 feet	Cross Slope (Driveway)	13.014	5 ft	34	SF	\$40	\$1,340			
40180	1009.2 to 1010.2 feet	Running Slope	7.0-8.0%	5 ft	5	REF					
52093	1011.6 to 1012.6 feet	Vertical Change	-.29	5 ft	5	REF					
5426	1013.3 to 1022.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,280			
5428	1022.1 to 1070.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	241	SF	\$120	\$28,920			
46374	1032.8 to 1033.8 feet	Vertical Change	-.46	5 ft	5	REF					
53053	1048.1 to 1049.1 feet	Vertical Change	-.27	5 ft	5	REF					
55970	1063.2 to 1064.2 feet	Vertical Change	.36	5 ft	5	REF					
5436	1070.3 to 1076.9 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	33	SF	\$120	\$3,960			
5437	1076.9 to 1083.7 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	34	SF	\$120	\$4,080			
5439	1083.7 to 1086.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	14	SF	\$120	\$1,620			
TOTAL COST FOR: SE							<i>side of</i>	ROSEHILL DR	<i>Starting at:</i>	AMADOR ST	\$481,480.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	1908220919	ROSEHILL DR	CALAVERAS ST	CALIFA DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5440	0.0 to 7.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,560	
5442	7.6 to 38.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	155	SF	\$120	\$18,540	
49355	10.0 to 11.0 feet	Vertical Change	-35	5 ft	5	REF			
41980	24.2 to 25.2 feet	Vertical Change	-78	5 ft	5	REF			
5448	38.5 to 50.3 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	59	SF	\$120	\$7,080	
5451	50.3 to 66.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	81	SF	\$120	\$9,780	
53582	52.5 to 53.5 feet	Vertical Change	-26	5 ft	5	REF			
58009	60.9 to 86.8 feet	Driveway				REF			
5454	70.6 to 79.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	44	SF	\$40	\$1,740	
5456	79.3 to 84.7 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	27	SF	\$40	\$1,080	
40181	84.0 to 85.2 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
5457	88.4 to 122.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	170	SF	\$120	\$20,340	
50748	89.8 to 90.8 feet	Vertical Change	-31	5 ft	5	REF			
5461	122.3 to 152.5 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	151	SF	\$120	\$18,120	
5469	152.5 to 167.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	74	SF	\$120	\$8,820	
5471	167.2 to 218.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	256	SF	\$120	\$30,660	
50365	171.9 to 172.9 feet	Vertical Change	-32	5 ft	5	REF			
5477	218.3 to 223.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	28	SF	\$120	\$3,360	
58010	219.2 to 243.6 feet	Driveway				REF			
51662	223.7 to 224.7 feet	Vertical Change	-.3	5 ft	5	REF			
5479	227.2 to 240.4 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	66	SF	\$40	\$2,640	
40182	239.5 to 241.0 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
5484	243.9 to 251.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	40	SF	\$40	\$1,600	
58011	248.8 to 271.9 feet	Driveway				REF			
5487	255.1 to 259.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	21	SF	\$40	\$860	
5489	259.4 to 269.2 feet	Cross Slope (Driveway)	13.014	5 ft	49	SF	\$40	\$1,960	
40183	268.3 to 270.3 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
5491	272.6 to 278.1 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	28	SF	\$120	\$3,300	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	1908220919	ROSEHILL DR	CALAVERAS ST	CALIFA DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5492	278.1 to 283.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	28	SF	\$120	\$3,300	
5494	283.6 to 313.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	150	SF	\$120	\$18,060	
5497	313.7 to 346.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	163	SF	\$120	\$19,560	
5499	346.3 to 381.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	175	SF	\$120	\$20,940	
47951	351.7 to 352.7 feet	Vertical Change	-4	5 ft	5	REF			
43872	366.4 to 367.4 feet	Vertical Change	-.58	5 ft	5	REF			
58012	377.3 to 400.6 feet	Driveway				REF			
44858	381.9 to 382.9 feet	Vertical Change	-.53	5 ft	5	REF			
5503	384.8 to 398.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	69	SF	\$40	\$2,760	
40184	397.8 to 399.2 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
45725	401.1 to 402.1 feet	Vertical Change	-.49	5 ft	5	REF			
5506	402.7 to 409.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,200	
58013	405.6 to 431.7 feet	Driveway				REF			
49052	410.4 to 411.4 feet	Vertical Change	-.36	5 ft	5	REF			
5507	413.3 to 418.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	27	SF	\$40	\$1,060	
5509	418.6 to 425.9 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	37	SF	\$40	\$1,460	
5511	425.9 to 428.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	14	SF	\$40	\$560	
40185	426.9 to 429.3 feet	Running Slope	5.0-6.0%	5 ft	12	REF			
5512	432.4 to 448.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	79	SF	\$40	\$3,160	
49671	438.7 to 439.7 feet	Vertical Change	-.34	5 ft	5	REF			
5514	448.2 to 455.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	35	SF	\$120	\$4,200	
5516	455.2 to 459.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	23	SF	\$120	\$2,760	
5517	459.8 to 469.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,700	
5520	469.3 to 497.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	140	SF	\$120	\$16,800	
58014	493.7 to 518.8 feet	Driveway				REF			
5523	501.1 to 514.9 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	69	SF	\$40	\$2,760	
40186	513.8 to 515.8 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
45234	517.1 to 518.1 feet	Vertical Change	-.51	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1908220919	ROSEHILL DR	CALAVERAS ST	CALIFA DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
5525	518.4 to 568.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	249	SF	\$40	\$9,960
53054	554.2 to 555.2 feet	Vertical Change	-.27	5 ft	5	REF		
58015	562.3 to 585.2 feet	Driveway				REF		
53583	568.4 to 569.4 feet	Vertical Change	-.26	5 ft	5	REF		
5532	571.2 to 583.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	63	SF	\$40	\$2,520
5537	587.4 to 612.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	127	SF	\$120	\$15,240
46375	596.8 to 597.8 feet	Vertical Change	-.46	5 ft	5	REF		
5539	612.8 to 629.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	83	SF	\$120	\$9,900
58016	625.3 to 649.6 feet	Driveway				REF		
5541	629.3 to 630.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$220
5542	633.8 to 647.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	67	SF	\$40	\$2,660
57161	645.3 to 646.3 feet	Vertical Change	.68	5 ft	5	REF		
42472	645.4 to 646.4 feet	Vertical Change	-.69	5 ft	5	REF		
5543	650.4 to 651.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200
5544	651.4 to 662.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,660
58017	657.9 to 681.9 feet	Driveway				REF		
49053	662.7 to 663.7 feet	Vertical Change	-.36	5 ft	5	REF		
5546	666.6 to 679.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	65	SF	\$40	\$2,600
40187	678.5 to 679.8 feet	Running Slope	6.0-7.0%	5 ft	7	REF		
50749	681.4 to 682.4 feet	Vertical Change	-.31	5 ft	5	REF		
5549	682.2 to 767.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	428	SF	\$40	\$17,120
44228	702.5 to 703.5 feet	Vertical Change	-.56	5 ft	5	REF		
52540	708.1 to 709.1 feet	Vertical Change	-.28	5 ft	5	REF		
46835	716.6 to 717.6 feet	Vertical Change	-.44	5 ft	5	REF		
42995	730.8 to 731.8 feet	Vertical Change	-.64	5 ft	5	REF		
44229	745.2 to 746.2 feet	Vertical Change	-.56	5 ft	5	REF		
45513	759.4 to 760.4 feet	Vertical Change	-.5	5 ft	5	REF		
49054	766.3 to 767.3 feet	Vertical Change	-.36	5 ft	5	REF		

TOTAL COST FOR: NW	<i>side of</i> ROSEHILL DR	<i>Starting at:</i> CALAVERAS ST	\$308,800.00
---------------------------	-----------------------------------	---	---------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1908220921	CALIFA DR	ROSEHILL DR	CALAVERAS ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5555	0.0 to 31.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	160	SF	\$120	\$19,140	
42287	30.5 to 31.5 feet	Vertical Change	-71	5 ft	5	REF			
5559	31.9 to 53.9 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	110	SF	\$120	\$13,200	
5561	53.9 to 89.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	177	SF	\$120	\$21,240	
47290	73.5 to 74.5 feet	Vertical Change	-42	5 ft	5	REF			
5564	89.3 to 92.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160	
53055	92.1 to 93.1 feet	Vertical Change	-27	5 ft	5	REF			
5566	92.9 to 153.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	303	SF	\$120	\$36,300	
45235	115.3 to 116.3 feet	Vertical Change	-51	5 ft	5	REF			
47059	143.7 to 144.7 feet	Vertical Change	-43	5 ft	5	REF			
5573	153.4 to 217.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	320	SF	\$120	\$38,400	
45036	172.0 to 173.0 feet	Vertical Change	-52	5 ft	5	REF			
45928	186.4 to 187.4 feet	Vertical Change	-48	5 ft	5	REF			
58018	211.6 to 236.4 feet	Driveway				REF			
46141	217.4 to 218.4 feet	Vertical Change	-47	5 ft	5	REF			
5579	220.6 to 233.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	66	SF	\$40	\$2,640	
40188	233.6 to 234.6 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
5582	237.8 to 250.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	63	SF	\$120	\$7,500	
5584	250.3 to 274.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	120	SF	\$120	\$14,460	
50010	259.4 to 260.4 feet	Vertical Change	-33	5 ft	5	REF			
5588	282.2 to 287.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000	
58019	283.0 to 307.6 feet	Driveway				REF			
52541	287.9 to 288.9 feet	Vertical Change	-28	5 ft	5	REF			
5589	290.8 to 305.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	75	SF	\$40	\$3,000	
40189	303.8 to 306.3 feet	Running Slope	5.0-6.0%	5 ft	13	REF			
5591	309.5 to 315.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	28	SF	\$120	\$3,360	
58020	311.3 to 335.0 feet	Driveway				REF			
5592	318.5 to 333.0 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	73	SF	\$40	\$2,900	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908220921	CALIFA DR	ROSEHILL DR	CALAVERAS ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40190	331.9 to 333.9 feet	Running Slope	6.0-7.0%	5 ft	10	REF		
45929	335.4 to 336.4 feet	Vertical Change	-.48	5 ft	5	REF		
5596	336.6 to 407.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	355	SF	\$120	\$42,540
55981	349.2 to 350.2 feet	Vertical Change	.38	5 ft	5	REF		
53584	354.5 to 355.5 feet	Vertical Change	-.26	5 ft	5	REF		
48475	368.4 to 369.4 feet	Vertical Change	-.38	5 ft	5	REF		
50366	382.7 to 383.7 feet	Vertical Change	-.32	5 ft	5	REF		
5604	407.5 to 419.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,200
5606	419.5 to 469.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	249	SF	\$120	\$29,820
5612	469.2 to 477.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$5,040
5614	477.6 to 484.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	34	SF	\$120	\$4,080
TOTAL COST FOR: E side of CALIFA DR Starting at: ROSEHILL DR							\$255,980.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
W	1908220924	CALIFA DR	CALAVERAS ST	ROSEHILL DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5615	0.0 to 12.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	64	SF	\$120	\$7,680	
50750	9.1 to 10.1 feet	Vertical Change	-.31	5 ft	5	REF			
5617	12.8 to 22.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	48	SF	\$120	\$5,700	
5619	22.3 to 28.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,960	
50367	27.7 to 28.7 feet	Vertical Change	-.32	5 ft	5	REF			
5621	28.9 to 63.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	173	SF	\$120	\$20,760	
53989	42.4 to 43.4 feet	Vertical Change	-.25	5 ft	5	REF			
58021	58.9 to 81.3 feet	Driveway				REF			
5625	66.5 to 79.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	64	SF	\$40	\$2,540	
5628	82.2 to 83.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$780	
5629	83.5 to 116.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	163	SF	\$120	\$19,500	
43873	93.8 to 94.8 feet	Vertical Change	-.58	5 ft	5	REF			
52542	98.7 to 99.7 feet	Vertical Change	-.28	5 ft	5	REF			
42288	108.8 to 109.8 feet	Vertical Change	-.71	5 ft	5	REF			
5634	116.0 to 154.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	192	SF	\$120	\$23,040	
42046	123.5 to 124.5 feet	Vertical Change	-.76	5 ft	5	REF			
43393	138.9 to 139.9 feet	Vertical Change	-.61	5 ft	5	REF			
58022	149.3 to 171.8 feet	Driveway				REF			
47535	154.2 to 155.2 feet	Vertical Change	-.41	5 ft	5	REF			
5638	157.2 to 171.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	70	SF	\$40	\$2,780	
50368	173.2 to 174.2 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
5639	175.3 to 182.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320	
58023	177.9 to 201.8 feet	Driveway				REF			
5640	186.3 to 200.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	70	SF	\$40	\$2,800	
40191	200.1 to 201.8 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
5642	203.8 to 266.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	312	SF	\$120	\$37,440	
5656	266.2 to 277.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,660	
5658	277.3 to 322.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	227	SF	\$120	\$27,240	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908220924	CALIFA DR	CALAVERAS ST	ROSEHILL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46142	308.4 to 309.4 feet	Vertical Change	-47	5 ft	5	REF		
58024	317.3 to 344.3 feet	Driveway				REF		
5664	326.4 to 342.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	79	SF	\$40	\$3,160
40192	341.8 to 343.0 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
46376	343.9 to 344.9 feet	Vertical Change	-46	5 ft	5	REF		
5667	345.6 to 350.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	25	SF	\$120	\$3,000
52094	349.1 to 350.1 feet	Vertical Change	-29	5 ft	5	REF		
58025	349.4 to 374.1 feet	Driveway				REF		
5669	350.6 to 353.6 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	15	SF	\$40	\$600
50751	353.9 to 354.9 feet	Vertical Change	-.31	5 ft	5	REF		
5671	357.6 to 371.7 feet	Cross Slope (Driveway)	13.014	5 ft	71	SF	\$40	\$2,820
40193	371.3 to 373.6 feet	Running Slope	6.0-7.0%	5 ft	12	REF		
5674	375.8 to 436.0 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	301	SF	\$120	\$36,120
44230	383.8 to 384.8 feet	Vertical Change	-.56	5 ft	5	REF		
49356	403.6 to 404.6 feet	Vertical Change	-.35	5 ft	5	REF		
53585	407.2 to 408.2 feet	Vertical Change	-.26	5 ft	5	REF		
48762	414.9 to 415.9 feet	Vertical Change	-.37	5 ft	5	REF		
5682	436.0 to 494.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	291	SF	\$120	\$34,860
5686	494.1 to 501.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	36	SF	\$120	\$4,320
5688	501.3 to 503.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	10	SF	\$120	\$1,200

TOTAL COST FOR: W side of CALIFA DR Starting at: CALAVERAS ST \$251,655.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908220926	ROSEHILL DR	CALIFA DR	PENNY ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5689	0.0 to 8.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$5,040	
5691	8.4 to 100.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	462	SF	\$120	\$55,380	
58026	94.3 to 119.8 feet	Driveway				REF			
5699	104.0 to 110.0 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	30	SF	\$40	\$1,200	
5701	110.0 to 117.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	37	SF	\$40	\$1,480	
40194	117.0 to 119.3 feet	Running Slope	5.0-6.0%	5 ft	12	REF			
49357	120.4 to 121.4 feet	Vertical Change	-35	5 ft	5	REF			
5703	121.1 to 127.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	34	SF	\$120	\$4,020	
40195	125.3 to 127.1 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
57563	127.6 to 128.6 feet	Vertical Change	2.46	5 ft	5	REF			
5705	127.8 to 142.0 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	71	SF	\$120	\$8,520	
5708	142.0 to 146.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	22	SF	\$120	\$2,640	
5710	146.4 to 188.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	211	SF	\$120	\$25,260	
58027	184.9 to 207.7 feet	Driveway				REF			
5719	191.4 to 204.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	65	SF	\$40	\$2,600	
40196	203.9 to 205.8 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
5721	209.3 to 210.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840	
5722	213.5 to 292.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	396	SF	\$120	\$47,460	
49672	214.3 to 217.5 feet	Vertical Change	-34	5 ft	16	REF			
46599	220.7 to 221.7 feet	Vertical Change	-45	5 ft	5	REF			
45514	225.1 to 226.1 feet	Vertical Change	-.5	5 ft	5	REF			
46600	229.6 to 230.6 feet	Vertical Change	-.45	5 ft	5	REF			
45726	233.7 to 234.7 feet	Vertical Change	-.49	5 ft	5	REF			
45930	238.9 to 239.9 feet	Vertical Change	-.48	5 ft	5	REF			
44043	244.4 to 245.4 feet	Vertical Change	-.57	5 ft	5	REF			
46143	249.8 to 250.8 feet	Vertical Change	-.47	5 ft	5	REF			
44429	255.5 to 256.5 feet	Vertical Change	-.55	5 ft	5	REF			
46144	260.4 to 261.4 feet	Vertical Change	-.47	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908220926	ROSEHILL DR	CALIFA DR	PENNY ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
45931	266.2 to 267.2 feet	Vertical Change	-.48	5 ft	5	REF		
49358	271.3 to 272.3 feet	Vertical Change	-.35	5 ft	5	REF		
45932	277.0 to 278.0 feet	Vertical Change	-.48	5 ft	5	REF		
46145	282.1 to 283.1 feet	Vertical Change	-.47	5 ft	5	REF		
46146	287.3 to 288.3 feet	Vertical Change	-.47	5 ft	5	REF		
5731	292.6 to 303.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	56	SF	\$120	\$6,780
47291	301.9 to 302.9 feet	Vertical Change	-.42	5 ft	5	REF		
5733	303.9 to 306.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680
44859	306.3 to 307.3 feet	Vertical Change	-.53	5 ft	5	REF		
TOTAL COST FOR: N side of ROSEHILL DR Starting at: CALIFA DR							\$162,900.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1908220929	PENNY ST	ROSEHILL DR	CALAVERAS ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5734	0.0 to 18.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	93	SF	\$120	\$11,160	
46836	2.5 to 3.5 feet	Vertical Change	-.44	5 ft	5	REF			
41836	6.7 to 7.7 feet	Vertical Change	-.82	5 ft	5	REF			
49359	11.0 to 12.0 feet	Vertical Change	-.35	5 ft	5	REF			
46147	15.5 to 20.5 feet	Vertical Change	-.47	5 ft	25	REF			
5735	18.6 to 36.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	88	SF	\$120	\$10,620	
44231	24.3 to 25.3 feet	Vertical Change	-.56	5 ft	5	REF			
45727	28.7 to 29.7 feet	Vertical Change	-.49	5 ft	5	REF			
58028	33.0 to 56.8 feet	Driveway				REF			
44232	33.5 to 34.5 feet	Vertical Change	-.56	5 ft	5	REF			
41580	36.8 to 37.8 feet	Vertical Change	-1	5 ft	5	REF			
5737	40.0 to 54.5 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	73	SF	\$40	\$2,900	
42390	47.0 to 48.0 feet	Vertical Change	-.7	5 ft	5	REF			
40197	53.7 to 55.3 feet	Running Slope	6.0-7.0%	5 ft	8	REF			
41310	57.5 to 58.5 feet	Vertical Change	-1.53	5 ft	5	REF			
5740	58.5 to 82.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	118	SF	\$120	\$14,100	
49055	62.8 to 63.8 feet	Vertical Change	-.36	5 ft	5	REF			
46148	67.7 to 68.7 feet	Vertical Change	-.47	5 ft	5	REF			
44656	72.6 to 73.6 feet	Vertical Change	-.54	5 ft	5	REF			
46379	77.4 to 78.4 feet	Vertical Change	-.46	5 ft	5	REF			
5743	82.0 to 92.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,180	
45515	82.4 to 83.4 feet	Vertical Change	-.5	5 ft	5	REF			
49673	87.2 to 88.2 feet	Vertical Change	-.34	5 ft	5	REF			
58029	87.3 to 133.4 feet	Driveway				REF			
5745	95.6 to 130.5 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	175	SF	\$40	\$6,980	
48194	103.5 to 104.5 feet	Vertical Change	-.39	5 ft	5	REF			
5746	134.3 to 209.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	375	SF	\$120	\$45,060	
46837	136.0 to 137.0 feet	Vertical Change	-.44	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908220929	PENNY ST	ROSEHILL DR	CALAVERAS ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
50011	140.9 to 141.9 feet	Vertical Change	-.33	5 ft	5	REF		
47292	146.1 to 147.1 feet	Vertical Change	-.42	5 ft	5	REF		
52543	150.6 to 151.6 feet	Vertical Change	-.28	5 ft	5	REF		
47536	156.0 to 157.0 feet	Vertical Change	-.41	5 ft	5	REF		
50369	160.8 to 161.8 feet	Vertical Change	-.32	5 ft	5	REF		
47537	166.1 to 167.1 feet	Vertical Change	-.41	5 ft	5	REF		
46380	171.1 to 172.1 feet	Vertical Change	-.46	5 ft	5	REF		
47538	181.2 to 182.2 feet	Vertical Change	-.41	5 ft	5	REF		
48476	186.9 to 187.9 feet	Vertical Change	-.38	5 ft	5	REF		
52095	192.0 to 193.0 feet	Vertical Change	-.29	5 ft	5	REF		
49674	197.1 to 198.1 feet	Vertical Change	-.34	5 ft	5	REF		
46381	208.0 to 209.0 feet	Vertical Change	-.46	5 ft	5	REF		
5748	209.4 to 215.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,720
58030	211.8 to 236.0 feet	Driveway				REF		
5750	219.2 to 233.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	73	SF	\$40	\$2,900
47539	225.9 to 226.9 feet	Vertical Change	-.41	5 ft	5	REF		
40198	232.3 to 234.6 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
52544	236.2 to 239.9 feet	Vertical Change	-.28	5 ft	19	REF		
5752	237.3 to 257.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	100	SF	\$120	\$11,940
53056	244.4 to 245.4 feet	Vertical Change	-.27	5 ft	5	REF		
50012	249.8 to 250.8 feet	Vertical Change	-.33	5 ft	5	REF		
58031	251.6 to 271.9 feet	Driveway				REF		
50752	255.8 to 256.8 feet	Vertical Change	-.31	5 ft	5	REF		
5757	261.3 to 265.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	22	SF	\$40	\$860
5759	265.6 to 269.2 feet	Cross Slope (Driveway)	13.014	5 ft	18	SF	\$40	\$720
50753	272.9 to 273.9 feet	Vertical Change	-.31	5 ft	5	REF		
5761	273.6 to 287.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	71	SF	\$120	\$8,580
58032	283.0 to 309.3 feet	Driveway				REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
E	1908220929	PENNY ST	ROSEHILL DR	CALAVERAS ST				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
5762	291.6 to 307.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	81	SF	\$40	\$3,240
42091	299.4 to 300.4 feet	Vertical Change	-75	5 ft	5	REF		
52545	310.7 to 313.1 feet	Vertical Change	-28	5 ft	12	REF		
5765	310.9 to 312.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$840
5766	312.3 to 370.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	289	SF	\$120	\$34,620
53586	322.2 to 323.2 feet	Vertical Change	-26	5 ft	5	REF		
53587	327.5 to 328.5 feet	Vertical Change	-26	5 ft	5	REF		
53588	332.8 to 333.8 feet	Vertical Change	-26	5 ft	5	REF		
47952	348.9 to 349.9 feet	Vertical Change	-4	5 ft	5	REF		
47060	354.6 to 355.6 feet	Vertical Change	-43	5 ft	5	REF		
42560	359.4 to 360.4 feet	Vertical Change	-68	5 ft	5	REF		
46601	364.4 to 365.4 feet	Vertical Change	-45	5 ft	5	REF		
58033	365.0 to 401.4 feet	Driveway				REF		
5770	373.3 to 388.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	77	SF	\$40	\$3,060
50754	380.1 to 381.1 feet	Vertical Change	-31	5 ft	5	REF		
5772	388.6 to 399.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	56	SF	\$40	\$2,240
43575	390.5 to 391.5 feet	Vertical Change	-6	5 ft	5	REF		
40199	398.0 to 400.5 feet	Running Slope	5.0-6.0%	5 ft	13	REF		
42673	403.4 to 404.4 feet	Vertical Change	-67	5 ft	5	REF		
5774	403.7 to 421.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	88	SF	\$120	\$10,560
45728	406.6 to 407.6 feet	Vertical Change	-49	5 ft	5	REF		
44657	411.1 to 412.1 feet	Vertical Change	-54	5 ft	5	REF		
45934	416.1 to 417.1 feet	Vertical Change	-48	5 ft	5	REF		
49056	421.1 to 422.1 feet	Vertical Change	-36	5 ft	5	REF		
5777	421.3 to 448.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	137	SF	\$120	\$16,440
46838	426.2 to 427.2 feet	Vertical Change	-44	5 ft	5	REF		
45729	431.8 to 432.8 feet	Vertical Change	-49	5 ft	5	REF		
46602	436.6 to 437.6 feet	Vertical Change	-45	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908220929	PENNY ST	ROSEHILL DR	CALAVERAS ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58034	444.8 to 472.3 feet	Driveway				REF		
5779	448.7 to 451.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	13	SF	\$40	\$500
5780	454.4 to 471.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	86	SF	\$40	\$3,420
5782	474.8 to 497.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	115	SF	\$120	\$13,800
50755	477.1 to 478.1 feet	Vertical Change	-.31	5 ft	5	REF		
50756	487.4 to 488.4 feet	Vertical Change	-.31	5 ft	5	REF		
5786	497.8 to 507.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,880
TOTAL COST FOR: E side of PENNY ST Starting at: ROSEHILL DR							\$220,320.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908220932	PENNY ST	CALAVERAS ST	ROSEHILL DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5789	0.0 to 43.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	217	SF	\$120	\$25,980	
45935	8.1 to 9.1 feet	Vertical Change	-48	5 ft	5	REF			
48477	20.2 to 21.2 feet	Vertical Change	-38	5 ft	5	REF			
47540	24.7 to 25.7 feet	Vertical Change	-41	5 ft	5	REF			
49057	29.6 to 30.6 feet	Vertical Change	-36	5 ft	5	REF			
47953	34.5 to 35.5 feet	Vertical Change	-4	5 ft	5	REF			
58035	38.0 to 69.5 feet	Driveway				REF			
53990	38.9 to 39.9 feet	Vertical Change	-25	5 ft	5	REF			
5793	47.0 to 67.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	102	SF	\$40	\$4,060	
45730	51.2 to 52.2 feet	Vertical Change	-49	5 ft	5	REF			
44044	61.4 to 62.4 feet	Vertical Change	-57	5 ft	5	REF			
40200	66.6 to 67.9 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
49675	69.6 to 73.1 feet	Vertical Change	-34	5 ft	18	REF			
5798	70.4 to 71.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200	
5799	71.4 to 84.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	66	SF	\$120	\$7,980	
53589	76.5 to 77.5 feet	Vertical Change	-26	5 ft	5	REF			
50370	81.3 to 82.3 feet	Vertical Change	-32	5 ft	5	REF			
48763	86.0 to 87.0 feet	Vertical Change	-37	5 ft	5	LF	\$75	\$375	
5802	88.5 to 95.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,140	
49059	91.1 to 92.1 feet	Vertical Change	-36	5 ft	5	REF			
58036	91.7 to 125.1 feet	Driveway				REF			
5803	99.3 to 111.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	61	SF	\$40	\$2,420	
46839	105.3 to 106.3 feet	Vertical Change	-44	5 ft	5	REF			
5807	111.4 to 122.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	57	SF	\$40	\$2,260	
46150	115.3 to 116.3 feet	Vertical Change	-47	5 ft	5	REF			
43248	125.1 to 126.1 feet	Vertical Change	-62	5 ft	5	REF			
5808	125.8 to 132.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,080	
48195	129.4 to 130.4 feet	Vertical Change	-39	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908220932	PENNY ST	CALAVERAS ST	ROSEHILL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
53057	133.4 to 134.4 feet	Vertical Change	-27	5 ft	5	LF	\$75	\$375
52097	138.3 to 139.3 feet	Vertical Change	-29	5 ft	5	LF	\$75	\$375
49060	143.0 to 144.0 feet	Vertical Change	-36	5 ft	5	LF	\$75	\$375
5810	147.4 to 153.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,540
46603	147.9 to 148.9 feet	Vertical Change	-45	5 ft	5	REF		
42561	153.1 to 154.1 feet	Vertical Change	-68	5 ft	5	REF		
47061	157.9 to 158.9 feet	Vertical Change	-43	5 ft	5	LF	\$75	\$375
42391	162.8 to 163.8 feet	Vertical Change	-7	5 ft	5	SF	\$75	\$375
5811	164.7 to 168.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160
48478	167.6 to 168.6 feet	Vertical Change	-38	5 ft	5	REF		
44430	172.5 to 173.5 feet	Vertical Change	-55	5 ft	5	SF	\$75	\$375
48764	177.5 to 178.5 feet	Vertical Change	-37	5 ft	5	LF	\$75	\$375
48479	182.2 to 183.2 feet	Vertical Change	-38	5 ft	5	LF	\$75	\$375
5812	184.5 to 185.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720
47062	187.1 to 188.1 feet	Vertical Change	-43	5 ft	5	LF	\$75	\$375
5813	193.4 to 230.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	185	SF	\$120	\$22,200
48196	197.0 to 198.0 feet	Vertical Change	-39	5 ft	5	REF		
42562	201.8 to 202.8 feet	Vertical Change	-68	5 ft	5	REF		
47063	207.0 to 208.0 feet	Vertical Change	-43	5 ft	5	REF		
46151	211.8 to 212.8 feet	Vertical Change	-47	5 ft	5	REF		
48480	216.5 to 217.5 feet	Vertical Change	-38	5 ft	5	REF		
42891	221.5 to 222.5 feet	Vertical Change	-65	5 ft	5	REF		
58037	225.5 to 255.9 feet	Driveway				REF		
48197	226.4 to 227.4 feet	Vertical Change	-39	5 ft	5	REF		
49676	231.0 to 232.0 feet	Vertical Change	-34	5 ft	5	REF		
5817	234.7 to 252.4 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	89	SF	\$40	\$3,540
46382	237.8 to 238.8 feet	Vertical Change	-46	5 ft	5	REF		
44860	248.5 to 249.5 feet	Vertical Change	-53	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908220932	PENNY ST	CALAVERAS ST	ROSEHILL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40201	252.2 to 253.5 feet	Running Slope	5.0-6.0%	5 ft	7	REF		
41472	254.9 to 255.9 feet	Vertical Change	-1.13	5 ft	5	REF		
5821	256.1 to 265.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	48	SF	\$40	\$1,900
5823	265.6 to 274.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,520
48481	268.5 to 269.5 feet	Vertical Change	-.38	5 ft	5	REF		
5825	274.8 to 305.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	153	SF	\$120	\$18,300
52546	278.8 to 279.8 feet	Vertical Change	-.28	5 ft	5	REF		
48482	289.4 to 290.4 feet	Vertical Change	-.38	5 ft	5	REF		
50013	299.8 to 300.8 feet	Vertical Change	-.33	5 ft	5	REF		
53590	304.9 to 305.9 feet	Vertical Change	-.26	5 ft	5	REF		
5829	305.3 to 359.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	270	SF	\$120	\$32,400
53591	325.4 to 326.4 feet	Vertical Change	-.26	5 ft	5	REF		
48483	335.5 to 336.5 feet	Vertical Change	-.38	5 ft	5	REF		
50371	345.6 to 346.6 feet	Vertical Change	-.32	5 ft	5	REF		
47541	350.5 to 351.5 feet	Vertical Change	-.41	5 ft	5	REF		
53592	355.7 to 356.7 feet	Vertical Change	-.26	5 ft	5	REF		

TOTAL COST FOR:	W	<i>side of</i>	PENNY ST	<i>Starting at:</i>	CALAVERAS ST	\$145,150.00
------------------------	----------	----------------	-----------------	---------------------	---------------------	---------------------

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908220933	ROSEHILL DR	PENNY ST	DANNIELLE ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5838	0.0 to 21.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	109	SF	\$120	\$13,020	
44045	3.4 to 4.4 feet	Vertical Change	-.57	5 ft	5	REF			
49061	9.5 to 10.5 feet	Vertical Change	-.36	5 ft	5	REF			
52547	16.1 to 17.1 feet	Vertical Change	-.28	5 ft	5	REF			
58038	16.6 to 53.1 feet	Driveway				REF			
50372	21.5 to 22.5 feet	Vertical Change	-.32	5 ft	5	REF			
5843	26.4 to 33.3 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	34	SF	\$40	\$1,380	
5845	33.3 to 43.3 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	50	SF	\$40	\$2,000	
48484	43.0 to 44.0 feet	Vertical Change	-.38	5 ft	5	REF			
5847	43.3 to 50.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	38	SF	\$40	\$1,500	
40202	49.6 to 51.7 feet	Running Slope	5.0-6.0%	5 ft	11	REF			
50373	54.1 to 55.1 feet	Vertical Change	-.32	5 ft	5	REF			
5849	54.7 to 76.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	109	SF	\$120	\$13,080	
46840	58.0 to 59.0 feet	Vertical Change	-.44	5 ft	5	REF			
48198	61.9 to 62.9 feet	Vertical Change	-.39	5 ft	5	REF			
47064	65.8 to 66.8 feet	Vertical Change	-.43	5 ft	5	REF			
44861	71.4 to 72.4 feet	Vertical Change	-.53	5 ft	5	REF			
48199	76.5 to 77.5 feet	Vertical Change	-.39	5 ft	5	REF			
5850	76.5 to 140.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	322	SF	\$120	\$38,640	
48200	81.1 to 82.1 feet	Vertical Change	-.39	5 ft	5	REF			
53593	84.2 to 87.8 feet	Vertical Change	-.26	5 ft	18	REF			
49062	92.2 to 93.2 feet	Vertical Change	-.36	5 ft	5	REF			
42392	97.7 to 98.7 feet	Vertical Change	-.7	5 ft	5	REF			
47293	102.8 to 103.8 feet	Vertical Change	-.42	5 ft	5	REF			
43714	108.2 to 109.2 feet	Vertical Change	-.59	5 ft	5	REF			
47542	113.3 to 114.3 feet	Vertical Change	-.41	5 ft	5	REF			
43576	118.3 to 119.3 feet	Vertical Change	-.6	5 ft	5	REF			
47543	123.5 to 124.5 feet	Vertical Change	-.41	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908220933	ROSEHILL DR	PENNY ST	DANNIELLE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
45236	128.6 to 129.6 feet	Vertical Change	-.51	5 ft	5	REF		
47544	133.9 to 134.9 feet	Vertical Change	-.41	5 ft	5	REF		
44658	139.2 to 140.2 feet	Vertical Change	-.54	5 ft	5	REF		
5858	140.9 to 153.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	61	SF	\$120	\$7,380
47545	144.3 to 145.3 feet	Vertical Change	-.41	5 ft	5	REF		
45037	149.6 to 150.6 feet	Vertical Change	-.52	5 ft	5	REF		
5860	153.2 to 165.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,200
48765	154.7 to 155.7 feet	Vertical Change	-.37	5 ft	5	REF		
44233	159.5 to 160.5 feet	Vertical Change	-.56	5 ft	5	REF		
47294	163.8 to 164.8 feet	Vertical Change	-.42	5 ft	5	REF		
46152	168.3 to 169.3 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: N side of ROSEHILL DR Starting at: PENNY ST								\$84,575.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908220935	DANNIELLE ST	ROSEHILL DR	CALAVERAS ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5863	0.0 to 7.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,380	
44431	6.6 to 7.6 feet	Vertical Change	-55	5 ft	5	REF			
5865	7.3 to 26.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	98	SF	\$120	\$11,700	
52098	12.7 to 13.7 feet	Vertical Change	-29	5 ft	5	REF			
42770	19.0 to 20.0 feet	Vertical Change	-66	5 ft	5	REF			
46153	23.8 to 24.8 feet	Vertical Change	-47	5 ft	5	REF			
5870	26.8 to 47.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	103	SF	\$120	\$12,300	
44234	28.7 to 29.7 feet	Vertical Change	-56	5 ft	5	REF			
47295	33.6 to 34.6 feet	Vertical Change	-42	5 ft	5	REF			
53058	38.5 to 39.5 feet	Vertical Change	-27	5 ft	5	REF			
48766	42.1 to 43.1 feet	Vertical Change	-37	5 ft	5	REF			
49678	45.8 to 49.1 feet	Vertical Change	-34	5 ft	17	REF			
5874	47.3 to 54.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	35	SF	\$120	\$4,140	
51663	53.0 to 54.0 feet	Vertical Change	-3	5 ft	5	REF			
5876	54.2 to 62.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,860	
58039	61.8 to 87.7 feet	Driveway				REF			
5878	62.3 to 68.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	31	SF	\$40	\$1,240	
47954	62.6 to 63.6 feet	Vertical Change	-4	5 ft	5	REF			
45936	67.5 to 68.5 feet	Vertical Change	-48	5 ft	5	REF			
5879	69.4 to 71.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	10	SF	\$40	\$420	
5881	71.5 to 84.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	67	SF	\$40	\$2,660	
44432	77.2 to 78.2 feet	Vertical Change	-55	5 ft	5	REF			
42892	87.2 to 88.2 feet	Vertical Change	-65	5 ft	5	REF			
5883	88.1 to 113.5 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	127	SF	\$40	\$5,080	
45731	96.7 to 97.7 feet	Vertical Change	-49	5 ft	5	REF			
48202	101.4 to 102.4 feet	Vertical Change	-39	5 ft	5	REF			
58040	108.8 to 129.9 feet	Driveway				REF			
47955	111.0 to 112.0 feet	Vertical Change	-4	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908220935	DANNIELLE ST	ROSEHILL DR	CALAVERAS ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
5884	117.3 to 127.1 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	49	SF	\$40	\$1,960
49679	121.5 to 122.5 feet	Vertical Change	-.34	5 ft	5	REF		
40203	126.2 to 127.9 feet	Running Slope	6.0-7.0%	5 ft	9	REF		
50757	129.5 to 130.5 feet	Vertical Change	-.31	5 ft	5	REF		
5886	130.8 to 163.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	165	SF	\$120	\$19,800
47296	134.2 to 135.2 feet	Vertical Change	-.42	5 ft	5	REF		
52099	138.6 to 139.6 feet	Vertical Change	-.29	5 ft	5	REF		
53594	148.0 to 149.0 feet	Vertical Change	-.26	5 ft	5	REF		
47065	152.6 to 153.6 feet	Vertical Change	-.43	5 ft	5	REF		
49063	157.2 to 158.2 feet	Vertical Change	-.36	5 ft	5	REF		
58041	159.0 to 185.2 feet	Driveway				REF		
5889	167.1 to 182.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	79	SF	\$40	\$3,140
53059	174.1 to 175.1 feet	Vertical Change	-.27	5 ft	5	REF		
5894	185.7 to 231.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	231	SF	\$120	\$27,660
52548	194.2 to 195.2 feet	Vertical Change	-.28	5 ft	5	REF		
49680	213.2 to 214.2 feet	Vertical Change	-.34	5 ft	5	REF		
47546	222.4 to 223.4 feet	Vertical Change	-.41	5 ft	5	REF		
49681	227.1 to 228.1 feet	Vertical Change	-.34	5 ft	5	REF		
50014	231.8 to 232.8 feet	Vertical Change	-.33	5 ft	5	REF		
5898	231.8 to 255.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	121	SF	\$120	\$14,460
48767	236.7 to 237.7 feet	Vertical Change	-.37	5 ft	5	REF		
51664	242.3 to 243.3 feet	Vertical Change	-.3	5 ft	5	REF		
43715	247.8 to 248.8 feet	Vertical Change	-.59	5 ft	5	REF		
58042	249.3 to 276.7 feet	Driveway				REF		
47066	253.4 to 254.4 feet	Vertical Change	-.43	5 ft	5	REF		
5902	259.3 to 273.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	73	SF	\$40	\$2,920
45732	266.1 to 267.1 feet	Vertical Change	-.49	5 ft	5	REF		
40204	274.0 to 275.2 feet	Running Slope	6.0-7.0%	5 ft	6	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908220935	DANNIELLE ST	ROSEHILL DR	CALAVERAS ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
5903	277.5 to 318.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	207	SF	\$120	\$24,840
43394	280.2 to 281.2 feet	Vertical Change	-61	5 ft	5	REF		
47956	285.5 to 286.5 feet	Vertical Change	-4	5 ft	5	REF		
43395	290.7 to 291.7 feet	Vertical Change	-61	5 ft	5	REF		
50015	296.1 to 297.1 feet	Vertical Change	-33	5 ft	5	REF		
43118	301.5 to 302.5 feet	Vertical Change	-63	5 ft	5	REF		
42674	311.9 to 312.9 feet	Vertical Change	-67	5 ft	5	REF		
58043	313.3 to 340.8 feet	Driveway				REF		
50374	317.8 to 318.8 feet	Vertical Change	-32	5 ft	5	REF		
5906	322.9 to 338.4 feet	Cross Slope (Driveway)	13.014	5 ft	78	SF	\$40	\$3,100
43249	330.1 to 331.1 feet	Vertical Change	-62	5 ft	5	REF		
40205	336.8 to 338.7 feet	Running Slope	6.0-7.0%	5 ft	10	REF		
5909	342.2 to 360.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	94	SF	\$120	\$11,220
41820	343.5 to 344.5 feet	Vertical Change	-83	5 ft	5	REF		
49682	348.9 to 349.9 feet	Vertical Change	-34	5 ft	5	REF		
42893	353.9 to 354.9 feet	Vertical Change	-65	5 ft	5	REF		
5912	360.9 to 366.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,180
57399	364.2 to 365.2 feet	Vertical Change	1.12	5 ft	5	REF		
TOTAL COST FOR: E side of DANNIELLE ST Starting at: ROSEHILL DR							\$159,060.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908220937	DANNIELLE ST	CALAVERAS ST	ROSEHILL DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5914	0.9 to 25.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	125	SF	\$120	\$14,940	
50016	4.7 to 5.7 feet	Vertical Change	-33	5 ft	5	REF			
53991	11.9 to 12.9 feet	Vertical Change	-25	5 ft	5	REF			
54136	15.7 to 16.7 feet	Vertical Change	.25	5 ft	5	REF			
51665	21.2 to 22.2 feet	Vertical Change	-.3	5 ft	5	REF			
58044	22.3 to 45.7 feet	Driveway				REF			
44235	25.8 to 26.8 feet	Vertical Change	-.56	5 ft	5	REF			
5919	29.3 to 43.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	71	SF	\$40	\$2,840	
53595	36.1 to 37.1 feet	Vertical Change	-.26	5 ft	5	REF			
51666	45.9 to 46.9 feet	Vertical Change	-.3	5 ft	5	REF			
5923	50.2 to 82.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	159	SF	\$120	\$19,080	
49683	56.4 to 57.4 feet	Vertical Change	-.34	5 ft	5	REF			
43396	61.6 to 62.6 feet	Vertical Change	-.61	5 ft	5	REF			
48485	66.1 to 67.1 feet	Vertical Change	-.38	5 ft	5	REF			
47067	76.9 to 77.9 feet	Vertical Change	-.43	5 ft	5	REF			
50375	82.2 to 83.2 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
5927	87.2 to 135.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	240	SF	\$120	\$28,740	
46383	87.4 to 88.4 feet	Vertical Change	-.46	5 ft	5	REF			
46384	93.1 to 94.1 feet	Vertical Change	-.46	5 ft	5	REF			
46841	99.7 to 100.7 feet	Vertical Change	-.44	5 ft	5	REF			
49360	105.4 to 106.4 feet	Vertical Change	-.35	5 ft	5	REF			
48768	111.4 to 112.4 feet	Vertical Change	-.37	5 ft	5	REF			
49684	117.4 to 118.4 feet	Vertical Change	-.34	5 ft	5	REF			
52549	122.9 to 123.9 feet	Vertical Change	-.28	5 ft	5	REF			
48769	128.5 to 129.5 feet	Vertical Change	-.37	5 ft	5	REF			
58045	129.7 to 156.2 feet	Driveway				REF			
44862	134.8 to 135.8 feet	Vertical Change	-.53	5 ft	5	REF			
5929	138.2 to 146.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	43	SF	\$40	\$1,720	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908220937	DANNIELLE ST	CALAVERAS ST	ROSEHILL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47297	144.7 to 145.7 feet	Vertical Change	-42	5 ft	5	REF		
5931	146.8 to 153.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	33	SF	\$40	\$1,320
46604	155.8 to 156.8 feet	Vertical Change	-45	5 ft	5	REF		
5932	157.6 to 166.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,580
58046	161.1 to 187.3 feet	Driveway				REF		
5936	170.6 to 185.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	74	SF	\$40	\$2,960
46605	178.2 to 179.2 feet	Vertical Change	-45	5 ft	5	REF		
5938	188.4 to 195.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	36	SF	\$120	\$4,260
49064	188.7 to 189.7 feet	Vertical Change	-36	5 ft	5	REF		
49361	194.0 to 195.0 feet	Vertical Change	-35	5 ft	5	REF		
5939	195.5 to 226.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	154	SF	\$120	\$18,480
49685	199.5 to 200.5 feet	Vertical Change	-34	5 ft	5	REF		
41895	205.0 to 206.0 feet	Vertical Change	-8	5 ft	5	REF		
48486	210.4 to 211.4 feet	Vertical Change	-38	5 ft	5	REF		
47068	215.7 to 216.7 feet	Vertical Change	-43	5 ft	5	REF		
58047	221.3 to 247.0 feet	Driveway				REF		
5944	229.5 to 243.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	70	SF	\$40	\$2,800
42996	246.7 to 247.7 feet	Vertical Change	-64	5 ft	5	REF		
5946	247.7 to 292.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	226	SF	\$120	\$27,060
45937	266.1 to 267.1 feet	Vertical Change	-48	5 ft	5	REF		
43716	271.5 to 272.5 feet	Vertical Change	-59	5 ft	5	REF		
47069	287.3 to 288.3 feet	Vertical Change	-43	5 ft	5	REF		
58048	287.3 to 323.3 feet	Driveway				REF		
49362	292.4 to 293.4 feet	Vertical Change	-35	5 ft	5	REF		
5952	295.9 to 319.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	117	SF	\$40	\$4,660
50017	304.0 to 305.0 feet	Vertical Change	-33	5 ft	5	REF		
46842	314.6 to 315.6 feet	Vertical Change	-44	5 ft	5	REF		
52100	323.3 to 324.3 feet	Vertical Change	-29	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908220937	DANNIELLE ST	CALAVERAS ST	ROSEHILL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
5956	323.8 to 325.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$780
5957	325.1 to 350.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	125	SF	\$120	\$15,060
49686	328.4 to 329.4 feet	Vertical Change	-.34	5 ft	5	REF		
47298	343.4 to 344.4 feet	Vertical Change	-.42	5 ft	5	REF		
48203	347.3 to 348.3 feet	Vertical Change	-.39	5 ft	5	REF		
TOTAL COST FOR: W side of DANNIELLE ST Starting at: CALAVERAS ST							\$150,655.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908220939	ROSEHILL DR	DANNIELLE ST	CALAVERAS ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
5960	0.0 to 59.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	299	SF	\$120	\$35,820	
46606	4.1 to 5.1 feet	Vertical Change	-45	5 ft	5	REF			
46843	8.8 to 9.8 feet	Vertical Change	-44	5 ft	5	REF			
53060	20.3 to 21.3 feet	Vertical Change	-27	5 ft	5	REF			
47547	25.5 to 26.5 feet	Vertical Change	-41	5 ft	5	REF			
53992	30.0 to 31.0 feet	Vertical Change	-25	5 ft	5	REF			
49363	34.7 to 35.7 feet	Vertical Change	-35	5 ft	5	REF			
47548	44.6 to 45.6 feet	Vertical Change	-41	5 ft	5	REF			
47957	48.9 to 49.9 feet	Vertical Change	-4	5 ft	5	REF			
48204	53.9 to 54.9 feet	Vertical Change	-39	5 ft	5	REF			
5962	63.7 to 176.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	566	SF	\$120	\$67,860	
48205	72.4 to 73.4 feet	Vertical Change	-39	5 ft	5	REF			
45237	77.8 to 78.8 feet	Vertical Change	-51	5 ft	5	REF			
48487	82.5 to 83.5 feet	Vertical Change	-38	5 ft	5	REF			
48488	87.3 to 88.3 feet	Vertical Change	-38	5 ft	5	REF			
49687	91.9 to 92.9 feet	Vertical Change	-34	5 ft	5	REF			
47549	96.7 to 97.7 feet	Vertical Change	-41	5 ft	5	REF			
49364	101.5 to 102.5 feet	Vertical Change	-35	5 ft	5	REF			
50758	106.1 to 107.1 feet	Vertical Change	-31	5 ft	5	REF			
47299	110.9 to 111.9 feet	Vertical Change	-42	5 ft	5	REF			
48206	115.8 to 116.8 feet	Vertical Change	-39	5 ft	5	REF			
53596	120.6 to 121.6 feet	Vertical Change	-26	5 ft	5	REF			
48770	125.4 to 126.4 feet	Vertical Change	-37	5 ft	5	REF			
47958	130.1 to 131.1 feet	Vertical Change	-4	5 ft	5	REF			
53061	135.2 to 136.2 feet	Vertical Change	-27	5 ft	5	REF			
44659	139.7 to 140.7 feet	Vertical Change	-54	5 ft	5	REF			
52101	144.9 to 145.9 feet	Vertical Change	-29	5 ft	5	REF			
46154	149.6 to 150.6 feet	Vertical Change	-47	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908220939	ROSEHILL DR	DANNIELLE ST	CALAVERAS ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46155	154.7 to 155.7 feet	Vertical Change	-.47	5 ft	5	REF		
47070	159.4 to 160.4 feet	Vertical Change	-.43	5 ft	5	REF		
48771	164.5 to 165.5 feet	Vertical Change	-.37	5 ft	5	REF		
42289	173.4 to 174.4 feet	Vertical Change	-.71	5 ft	5	REF		
5975	176.8 to 188.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	59	SF	\$120	\$7,020
47300	177.4 to 178.4 feet	Vertical Change	-.42	5 ft	5	REF		
46385	181.4 to 182.4 feet	Vertical Change	-.46	5 ft	5	REF		
45516	187.9 to 188.9 feet	Vertical Change	-.5	5 ft	5	REF		
TOTAL COST FOR: N side of ROSEHILL DR Starting at: DANNIELLE ST							\$110,700.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908220942	CALAVERAS ST	ROSEHILL DR	CALAVERAS ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
5978	0.0 to 14.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	73	SF	\$120	\$8,700
47550	4.4 to 5.4 feet	Vertical Change	-41	5 ft	5	REF		
5981	14.5 to 31.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	87	SF	\$120	\$10,440
53993	16.6 to 17.6 feet	Vertical Change	-25	5 ft	5	REF		
47301	21.3 to 22.3 feet	Vertical Change	-42	5 ft	5	REF		
45517	25.9 to 26.9 feet	Vertical Change	-5	5 ft	5	REF		
58049	28.0 to 53.6 feet	Driveway				REF		
50376	31.8 to 32.8 feet	Vertical Change	-32	5 ft	5	REF		
5982	35.8 to 51.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	78	SF	\$40	\$3,100
47071	42.9 to 43.9 feet	Vertical Change	-43	5 ft	5	REF		
40206	50.4 to 51.5 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
5985	55.2 to 60.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000
58050	63.7 to 88.3 feet	Driveway				REF		
49688	66.9 to 70.2 feet	Vertical Change	-34	5 ft	16	REF		
5986	68.5 to 69.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240
5987	72.8 to 85.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	63	SF	\$40	\$2,500
50377	89.0 to 90.0 feet	Vertical Change	-32	5 ft	5	LF	\$75	\$375
5989	90.3 to 125.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	175	SF	\$120	\$21,000
48489	93.9 to 94.9 feet	Vertical Change	-38	5 ft	5	REF		
48490	98.9 to 99.9 feet	Vertical Change	-38	5 ft	5	LF	\$75	\$375
53994	104.2 to 105.2 feet	Vertical Change	-25	5 ft	5	REF		
49365	109.6 to 110.6 feet	Vertical Change	-35	5 ft	5	REF		
50759	114.8 to 115.8 feet	Vertical Change	-31	5 ft	5	REF		
50760	120.7 to 121.7 feet	Vertical Change	-31	5 ft	5	REF		
5993	130.2 to 188.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	290	SF	\$120	\$34,740
48491	131.4 to 132.4 feet	Vertical Change	-38	5 ft	5	REF		
45938	142.0 to 143.0 feet	Vertical Change	-48	5 ft	5	REF		
48207	146.9 to 147.9 feet	Vertical Change	-39	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908220942	CALAVERAS ST	ROSEHILL DR	CALAVERAS ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
45733	152.1 to 153.1 feet	Vertical Change	-.49	5 ft	5	REF		
42130	157.1 to 158.1 feet	Vertical Change	-.74	5 ft	5	REF		
45038	162.4 to 166.4 feet	Vertical Change	-.52	5 ft	20	REF		
45518	168.9 to 169.9 feet	Vertical Change	-.5	5 ft	5	REF		
46388	172.4 to 173.4 feet	Vertical Change	-.46	5 ft	5	REF		
42131	178.0 to 179.0 feet	Vertical Change	-.74	5 ft	5	REF		
48492	183.2 to 184.2 feet	Vertical Change	-.38	5 ft	5	REF		
58051	184.3 to 208.9 feet	Driveway				REF		
42771	187.4 to 188.4 feet	Vertical Change	-.66	5 ft	5	REF		
6006	191.8 to 205.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	71	SF	\$40	\$2,820
42188	199.0 to 200.0 feet	Vertical Change	-.73	5 ft	5	REF		
40207	205.4 to 207.3 feet	Running Slope	6.0-7.0%	5 ft	10	REF		
6009	210.2 to 231.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	108	SF	\$120	\$12,960
46156	210.4 to 211.4 feet	Vertical Change	-.47	5 ft	5	REF		
42189	213.6 to 214.6 feet	Vertical Change	-.73	5 ft	5	REF		
45039	219.5 to 220.5 feet	Vertical Change	-.52	5 ft	5	REF		
49065	224.7 to 225.7 feet	Vertical Change	-.36	5 ft	5	REF		
58052	226.0 to 251.6 feet	Driveway				REF		
45519	229.7 to 232.6 feet	Vertical Change	-.5	5 ft	15	REF		
6012	235.2 to 249.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	71	SF	\$40	\$2,840
44046	241.8 to 242.8 feet	Vertical Change	-.57	5 ft	5	REF		
40208	248.1 to 250.5 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
41400	252.1 to 253.1 feet	Vertical Change	-1.27	5 ft	5	REF		
6015	252.9 to 294.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	208	SF	\$120	\$24,960
48494	256.3 to 257.3 feet	Vertical Change	-.38	5 ft	5	REF		
43717	261.5 to 262.5 feet	Vertical Change	-.59	5 ft	5	REF		
45939	266.5 to 267.5 feet	Vertical Change	-.48	5 ft	5	REF		
44863	271.4 to 272.4 feet	Vertical Change	-.53	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908220942	CALAVERAS ST	ROSEHILL DR	CALAVERAS ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41896	276.4 to 277.4 feet	Vertical Change	-.8	5 ft	5	REF		
42563	281.1 to 282.1 feet	Vertical Change	-.68	5 ft	5	REF		
43874	286.1 to 287.1 feet	Vertical Change	-.58	5 ft	5	REF		
58053	288.1 to 314.5 feet	Driveway				REF		
41799	290.9 to 291.9 feet	Vertical Change	-.84	5 ft	5	REF		
52102	293.1 to 294.1 feet	Vertical Change	-.29	5 ft	5	REF		
6020	298.3 to 312.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	69	SF	\$40	\$2,760
45940	304.7 to 305.7 feet	Vertical Change	-.48	5 ft	5	REF		
40209	311.0 to 313.3 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
6023	312.1 to 313.1 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	5	SF	\$40	\$200
6024	315.2 to 316.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$840
6025	316.6 to 332.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	77	SF	\$120	\$9,300
45238	317.6 to 321.0 feet	Vertical Change	-.51	5 ft	17	REF		
55976	324.9 to 325.9 feet	Vertical Change	.37	5 ft	5	REF		
44433	329.2 to 330.2 feet	Vertical Change	-.55	5 ft	5	REF		
48772	333.5 to 334.5 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375

TOTAL COST FOR: E side of CALAVERAS ST Starting at: ROSEHILL DR \$141,525.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908220943	CALAVERAS ST	CALAVERAS ST	DANNIELLE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
6026	0.0 to 3.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,920	
45941	3.0 to 4.0 feet	Vertical Change	-.48	5 ft	5	REF			
6027	5.6 to 29.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	121	SF	\$120	\$14,460	
47072	6.7 to 7.7 feet	Vertical Change	-.43	5 ft	5	REF			
46607	11.5 to 12.5 feet	Vertical Change	-.45	5 ft	5	REF			
48208	15.3 to 16.3 feet	Vertical Change	-.39	5 ft	5	REF			
45942	20.8 to 21.8 feet	Vertical Change	-.48	5 ft	5	REF			
49066	25.7 to 26.7 feet	Vertical Change	-.36	5 ft	5	REF			
6029	29.7 to 76.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	233	SF	\$120	\$27,960	
46608	35.5 to 36.5 feet	Vertical Change	-.45	5 ft	5	REF			
44660	40.4 to 41.4 feet	Vertical Change	-.54	5 ft	5	REF			
46157	45.3 to 46.3 feet	Vertical Change	-.47	5 ft	5	REF			
43119	50.0 to 51.0 feet	Vertical Change	-.63	5 ft	5	REF			
50761	55.0 to 56.0 feet	Vertical Change	-.31	5 ft	5	REF			
50762	59.4 to 60.4 feet	Vertical Change	-.31	5 ft	5	REF			
49366	64.2 to 65.2 feet	Vertical Change	-.35	5 ft	5	REF			
47302	69.1 to 70.1 feet	Vertical Change	-.42	5 ft	5	REF			
51667	73.9 to 74.9 feet	Vertical Change	-.3	5 ft	5	REF			
6035	76.3 to 86.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,060	
48495	83.6 to 84.6 feet	Vertical Change	-.38	5 ft	5	REF			
6037	86.4 to 113.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	138	SF	\$120	\$16,500	
44236	88.2 to 89.2 feet	Vertical Change	-.56	5 ft	5	REF			
47959	93.1 to 94.1 feet	Vertical Change	-.4	5 ft	5	REF			
48773	103.0 to 104.0 feet	Vertical Change	-.37	5 ft	5	REF			
48774	112.9 to 113.9 feet	Vertical Change	-.37	5 ft	5	REF			
6041	113.9 to 122.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,920	
6043	122.1 to 175.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	265	SF	\$120	\$31,800	
49367	131.5 to 132.5 feet	Vertical Change	-.35	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908220943	CALAVERAS ST	CALAVERAS ST	DANNIELLE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
50378	160.3 to 161.3 feet	Vertical Change	-.32	5 ft	5	REF		
47551	165.2 to 166.2 feet	Vertical Change	-.41	5 ft	5	REF		
49689	169.8 to 170.8 feet	Vertical Change	-.34	5 ft	5	REF		
6047	175.1 to 232.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	289	SF	\$120	\$34,680
49067	179.2 to 180.2 feet	Vertical Change	-.36	5 ft	5	REF		
50018	183.9 to 184.9 feet	Vertical Change	-.33	5 ft	5	REF		
50379	188.6 to 189.6 feet	Vertical Change	-.32	5 ft	5	REF		
49690	193.5 to 194.5 feet	Vertical Change	-.34	5 ft	5	REF		
52550	197.7 to 198.7 feet	Vertical Change	-.28	5 ft	5	REF		
48496	203.1 to 204.1 feet	Vertical Change	-.38	5 ft	5	REF		
52551	207.7 to 208.7 feet	Vertical Change	-.28	5 ft	5	REF		
49368	216.7 to 217.7 feet	Vertical Change	-.35	5 ft	5	REF		
49068	221.1 to 222.1 feet	Vertical Change	-.36	5 ft	5	REF		
49691	224.8 to 225.8 feet	Vertical Change	-.34	5 ft	5	REF		
50763	229.4 to 230.4 feet	Vertical Change	-.31	5 ft	5	REF		
TOTAL COST FOR: S							side of CALAVERAS ST Starting at: CALAVERAS ST	\$138,300.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908220945	CALAVERAS ST	DANNIELLE ST	PENNY ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
6052	0.0 to 3.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	17	SF	\$120	\$1,980
6053	3.3 to 23.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	101	SF	\$120	\$12,120
41453	3.4 to 4.4 feet	Vertical Change	-1.15	5 ft	5	REF		
46844	8.8 to 9.8 feet	Vertical Change	-.44	5 ft	5	REF		
48775	19.2 to 20.2 feet	Vertical Change	-.37	5 ft	5	REF		
6055	23.5 to 24.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	6	SF	\$120	\$660
47073	24.3 to 25.3 feet	Vertical Change	-.43	5 ft	5	REF		
56980	24.3 to 25.3 feet	Vertical Change	.58	5 ft	5	REF		
6056	26.3 to 44.5 feet	Cross Slope (PAR)	7.0-8.0%	5 ft	91	SF	\$120	\$10,920
48776	29.9 to 30.9 feet	Vertical Change	-.37	5 ft	5	REF		
42190	35.1 to 36.1 feet	Vertical Change	-.73	5 ft	5	REF		
6058	44.5 to 46.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	12	SF	\$120	\$1,380
49069	45.0 to 46.0 feet	Vertical Change	-.36	5 ft	5	REF		
57244	45.0 to 46.0 feet	Vertical Change	.79	5 ft	5	REF		
6060	46.8 to 51.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	24	SF	\$120	\$2,820
6061	51.5 to 76.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	127	SF	\$120	\$15,240
52552	55.6 to 56.6 feet	Vertical Change	-.28	5 ft	5	REF		
49692	74.3 to 75.3 feet	Vertical Change	-.34	5 ft	5	REF		
6064	76.9 to 85.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	42	SF	\$120	\$5,040
44661	85.0 to 86.1 feet	Vertical Change	-.54	5 ft	6	REF		
6066	85.3 to 86.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
49070	99.4 to 100.4 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375
53597	104.3 to 105.3 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
6067	126.7 to 179.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	263	SF	\$120	\$31,500
49693	137.8 to 138.8 feet	Vertical Change	-.34	5 ft	5	REF		
50764	142.9 to 143.9 feet	Vertical Change	-.31	5 ft	5	REF		
47960	147.8 to 148.8 feet	Vertical Change	-.4	5 ft	5	REF		
49694	152.4 to 153.4 feet	Vertical Change	-.34	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908220945	CALAVERAS ST	DANNIELLE ST	PENNY ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51668	156.9 to 157.9 feet	Vertical Change	-.3	5 ft	5	REF		
48209	161.9 to 162.9 feet	Vertical Change	-.39	5 ft	5	REF		
47552	166.3 to 167.3 feet	Vertical Change	-.41	5 ft	5	REF		
47303	171.4 to 172.4 feet	Vertical Change	-.42	5 ft	5	REF		
47961	175.6 to 176.6 feet	Vertical Change	-.4	5 ft	5	REF		
6071	179.2 to 205.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	131	SF	\$120	\$15,660
47304	180.7 to 181.7 feet	Vertical Change	-.42	5 ft	5	REF		
50019	185.1 to 186.1 feet	Vertical Change	-.33	5 ft	5	REF		
47074	189.7 to 190.7 feet	Vertical Change	-.43	5 ft	5	REF		
50765	193.6 to 194.6 feet	Vertical Change	-.31	5 ft	5	REF		
45734	198.2 to 199.2 feet	Vertical Change	-.49	5 ft	5	REF		
47553	203.5 to 204.5 feet	Vertical Change	-.41	5 ft	5	REF		
6075	205.3 to 207.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
TOTAL COST FOR: S side of CALAVERAS ST Starting at: DANNIELLE ST							\$100,170.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908220947	CALAVERAS ST	PENNY ST	CALIFA DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
6076	0.0 to 24.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	123	SF	\$120	\$14,760
50766	9.0 to 10.0 feet	Vertical Change	-31	5 ft	5	REF		
50020	12.5 to 13.5 feet	Vertical Change	-33	5 ft	5	REF		
53062	16.2 to 17.2 feet	Vertical Change	-27	5 ft	5	REF		
6078	24.6 to 28.7 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	21	SF	\$120	\$2,460
40210	28.2 to 30.8 feet	Running Slope	5.0-6.0%	5 ft	13	REF		
6079	28.7 to 38.2 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	48	SF	\$120	\$5,700
40211	35.7 to 37.0 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
43718	39.0 to 40.0 feet	Vertical Change	-59	5 ft	5	REF		
6082	39.1 to 168.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	649	SF	\$120	\$77,880
49695	43.6 to 44.6 feet	Vertical Change	-34	5 ft	5	REF		
53598	53.3 to 54.3 feet	Vertical Change	-26	5 ft	5	REF		
53599	82.8 to 83.8 feet	Vertical Change	-26	5 ft	5	REF		
51669	92.5 to 93.5 feet	Vertical Change	-3	5 ft	5	REF		
48777	146.3 to 147.3 feet	Vertical Change	-37	5 ft	5	REF		
49696	160.8 to 161.8 feet	Vertical Change	-34	5 ft	5	REF		
6098	168.9 to 184.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	77	SF	\$120	\$9,240
45239	176.2 to 177.2 feet	Vertical Change	-51	5 ft	5	REF		
6100	184.3 to 199.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	78	SF	\$120	\$9,360
52553	188.0 to 189.0 feet	Vertical Change	-28	5 ft	5	REF		
52103	198.7 to 199.7 feet	Vertical Change	-29	5 ft	5	REF		
6102	199.9 to 205.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,360
TOTAL COST FOR: S side of CALAVERAS ST Starting at: PENNY ST							\$122,760.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
S	1908220950	CALAVERAS ST	CALIFA DR	ROSEHILL DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
6103	0.0 to 11.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,140	
6106	11.9 to 48.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	182	SF	\$120	\$21,840	
58054	44.8 to 68.6 feet	Driveway				REF			
6108	51.8 to 60.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	43	SF	\$40	\$1,700	
6110	60.3 to 66.1 feet	Cross Slope (Driveway)	13.014	5 ft	29	SF	\$40	\$1,160	
40212	64.9 to 66.5 feet	Running Slope	6.0-7.0%	5 ft	8	REF			
53600	68.0 to 69.0 feet	Vertical Change	-26	5 ft	5	REF			
6111	69.3 to 84.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	75	SF	\$40	\$3,000	
58055	78.7 to 104.6 feet	Driveway				REF			
6114	87.5 to 102.2 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	74	SF	\$40	\$2,940	
40213	100.4 to 101.4 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
40214	101.4 to 102.7 feet	Running Slope	6.0-7.0%	5 ft	7	REF			
50380	104.6 to 105.6 feet	Vertical Change	-.32	5 ft	5	REF			
6117	106.6 to 202.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	481	SF	\$120	\$57,720	
43577	116.8 to 117.8 feet	Vertical Change	-.6	5 ft	5	REF			
53063	125.7 to 126.7 feet	Vertical Change	-.27	5 ft	5	REF			
46609	146.2 to 147.2 feet	Vertical Change	-.45	5 ft	5	REF			
50381	188.6 to 189.6 feet	Vertical Change	-.32	5 ft	5	REF			
58056	196.7 to 221.8 feet	Driveway				REF			
51670	203.1 to 204.1 feet	Vertical Change	-.3	5 ft	5	REF			
6126	206.0 to 220.0 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	70	SF	\$40	\$2,800	
40215	217.6 to 220.6 feet	Running Slope	5.0-6.0%	5 ft	15	REF			
6128	223.3 to 237.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	71	SF	\$120	\$8,460	
6130	237.4 to 272.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	174	SF	\$120	\$20,880	
52554	244.5 to 245.5 feet	Vertical Change	-.28	5 ft	5	REF			
6134	272.2 to 287.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	78	SF	\$120	\$9,300	
58057	283.3 to 308.0 feet	Driveway				REF			
6135	291.1 to 304.6 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	68	SF	\$40	\$2,700	
40217	303.3 to 304.4 feet	Running Slope	7.0-8.0%	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
S	1908220950	CALAVERAS ST	CALIFA DR	ROSEHILL DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
6137	308.5 to 316.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	39	SF	\$40	\$1,560	
58058	313.3 to 336.2 feet	Driveway				REF			
6138	320.3 to 333.5 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	66	SF	\$40	\$2,640	
40218	332.2 to 333.7 feet	Running Slope	6.0-7.0%	5 ft	8	REF			
45520	335.5 to 336.5 feet	Vertical Change	-.5	5 ft	5	REF			
6140	337.1 to 362.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	128	SF	\$120	\$15,300	
6143	362.6 to 377.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	75	SF	\$120	\$9,000	
6145	377.6 to 413.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	180	SF	\$120	\$21,540	
6146	413.5 to 423.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,060	
6147	434.3 to 457.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	116	SF	\$120	\$13,920	
46610	440.1 to 441.1 feet	Vertical Change	-.45	5 ft	5	REF			
51671	457.0 to 458.0 feet	Vertical Change	-.3	5 ft	5	REF			
6149	457.5 to 520.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	314	SF	\$120	\$37,620	
48497	471.2 to 472.2 feet	Vertical Change	-.38	5 ft	5	REF			
44662	485.7 to 486.7 feet	Vertical Change	-.54	5 ft	5	REF			
52555	500.6 to 501.6 feet	Vertical Change	-.28	5 ft	5	REF			
6154	520.2 to 522.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,620	
TOTAL COST FOR: S							side of CALAVERAS ST	Starting at: CALIFA DR	\$248,900.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
S	1908220954	CALAVERAS ST	ROSEHILL DR	CIRCLE DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
6155	0.0 to 5.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120	
6157	5.2 to 52.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	238	SF	\$120	\$28,560	
42772	6.4 to 7.4 feet	Vertical Change	-.66	5 ft	5	REF			
6161	52.8 to 60.3 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	38	SF	\$120	\$4,500	
6162	60.3 to 76.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	80	SF	\$120	\$9,600	
53064	61.9 to 62.9 feet	Vertical Change	-.27	5 ft	5	REF			
58059	71.3 to 95.4 feet	Driveway				REF			
50767	76.9 to 77.9 feet	Vertical Change	-.31	5 ft	5	REF			
6164	79.9 to 87.0 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	35	SF	\$40	\$1,420	
6166	87.0 to 92.9 feet	Cross Slope (Driveway)	13.014	5 ft	30	SF	\$40	\$1,180	
6167	96.4 to 178.0 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	408	SF	\$120	\$48,960	
50768	151.8 to 152.8 feet	Vertical Change	-.31	5 ft	5	REF			
55988	151.9 to 152.9 feet	Vertical Change	.39	5 ft	5	REF			
6176	178.0 to 181.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	19	SF	\$120	\$2,280	
58060	178.4 to 201.8 feet	Driveway				REF			
6178	184.4 to 188.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	19	SF	\$40	\$740	
6180	188.1 to 199.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	59	SF	\$40	\$2,360	
6184	203.0 to 222.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	99	SF	\$120	\$11,880	
6186	222.8 to 247.0 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	121	SF	\$120	\$14,520	
6189	247.0 to 253.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	31	SF	\$120	\$3,720	
6190	253.2 to 270.4 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	86	SF	\$120	\$10,320	
53065	263.5 to 264.5 feet	Vertical Change	-.27	5 ft	5	REF			
6192	270.4 to 276.2 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	29	SF	\$120	\$3,480	
6194	276.2 to 278.7 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	13	SF	\$120	\$1,500	
53601	277.5 to 278.5 feet	Vertical Change	-.26	5 ft	5	REF			
6195	278.7 to 289.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	52	SF	\$120	\$6,240	
58061	284.8 to 313.8 feet	Driveway				REF			
6197	289.1 to 291.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	10	SF	\$40	\$420	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908220954	CALAVERAS ST	ROSEHILL DR	CIRCLE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
6198	294.5 to 311.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	84	SF	\$40	\$3,380
40219	310.9 to 313.2 feet	Running Slope	7.0-8.0%	5 ft	12	REF		
6199	315.2 to 357.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	210	SF	\$120	\$25,200
6204	357.2 to 376.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	98	SF	\$120	\$11,700
6206	376.7 to 378.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900
53995	377.1 to 378.1 feet	Vertical Change	-.25	5 ft	5	REF		
58062	377.4 to 402.8 feet	Driveway				REF		
6207	385.5 to 399.3 feet	Cross Slope (Driveway)	13.014	5 ft	69	SF	\$40	\$2,760
50769	393.4 to 394.4 feet	Vertical Change	-.31	5 ft	5	REF		
40220	398.1 to 399.6 feet	Running Slope	7.0-8.0%	5 ft	8	REF		
47554	402.1 to 403.1 feet	Vertical Change	-.41	5 ft	5	REF		
6209	402.8 to 413.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	52	SF	\$40	\$2,080
6211	413.2 to 467.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	272	SF	\$120	\$32,580
48778	427.2 to 428.2 feet	Vertical Change	-.37	5 ft	5	REF		
50382	465.9 to 466.9 feet	Vertical Change	-.32	5 ft	5	REF		
6217	471.7 to 486.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,760
TOTAL COST FOR: S side of CALAVERAS ST Starting at: ROSEHILL DR							\$242,160.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908220959	CIRCLE DR	CALAVERAS ST	AMADOR ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
6220	0.0 to 49.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	223	SF	\$120	\$26,730	
53602	17.0 to 18.0 feet	Vertical Change	-26	5 ft	5	REF			
53996	26.7 to 27.7 feet	Vertical Change	-25	5 ft	5	REF			
6226	49.5 to 146.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	436	SF	\$120	\$52,326	
47555	75.6 to 76.6 feet	Vertical Change	-41	5 ft	5	REF			
43397	105.1 to 106.1 feet	Vertical Change	-.61	5 ft	5	REF			
44864	135.1 to 136.1 feet	Vertical Change	-.53	5 ft	5	REF			
6238	146.4 to 181.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	157	SF	\$120	\$18,846	
52556	152.3 to 153.3 feet	Vertical Change	-28	5 ft	5	REF			
41981	165.0 to 166.0 feet	Vertical Change	-.78	5 ft	5	REF			
58063	175.0 to 203.5 feet	Driveway				REF			
41404	179.8 to 180.8 feet	Vertical Change	-1.26	5 ft	5	REF			
6240	185.0 to 199.7 feet	Cross Slope (Driveway)	13.014	5 ft	66	SF	\$40	\$2,646	
40221	198.8 to 200.8 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
6241	203.2 to 224.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	96	SF	\$40	\$3,834	
50383	204.9 to 205.9 feet	Vertical Change	-.32	5 ft	5	REF			
45240	209.8 to 210.8 feet	Vertical Change	-.51	5 ft	5	REF			
50021	214.9 to 215.9 feet	Vertical Change	-.33	5 ft	5	REF			
58064	222.7 to 245.9 feet	Driveway				REF			
6243	228.8 to 243.3 feet	Cross Slope (Driveway)	>15%	5 ft	65	SF	\$40	\$2,610	
40222	241.3 to 242.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
40223	242.3 to 243.4 feet	Running Slope	6.0-7.0%	5 ft	5	REF			
6244	247.3 to 248.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$540	
6245	248.3 to 273.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	114	SF	\$120	\$13,716	
51672	267.3 to 268.3 feet	Vertical Change	-.3	5 ft	5	REF			
6246	276.8 to 311.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	158	SF	\$120	\$18,954	
58065	307.8 to 332.3 feet	Driveway				REF			
6250	315.9 to 327.8 feet	Cross Slope (Driveway)	13.014	5 ft	54	SF	\$40	\$2,142	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
NW	1908220959	CIRCLE DR	CALAVERAS ST	AMADOR ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
50022	326.7 to 327.7 feet	Vertical Change	-.33	5 ft	5	REF			
40224	328.2 to 329.9 feet	Running Slope	7.0-8.0%	5 ft	8	REF			
6254	333.1 to 369.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	163	SF	\$120	\$19,548	
49071	367.9 to 368.9 feet	Vertical Change	-.36	5 ft	5	REF			
58066	373.7 to 397.1 feet	Driveway				REF			
6258	382.1 to 394.5 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	56	SF	\$40	\$2,232	
50384	387.7 to 388.7 feet	Vertical Change	-.32	5 ft	5	REF			
40225	393.9 to 395.1 feet	Running Slope	6.0-7.0%	5 ft	5	REF			
6260	403.9 to 413.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,346	
6261	427.6 to 450.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	101	SF	\$120	\$12,096	
58067	446.3 to 471.7 feet	Driveway				REF			
6265	450.0 to 452.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	9	SF	\$40	\$360	
48779	450.3 to 451.3 feet	Vertical Change	-.37	5 ft	5	REF			
6266	455.6 to 468.9 feet	Cross Slope (Driveway)	13.014	5 ft	60	SF	\$40	\$2,394	
40226	468.4 to 470.1 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
6267	472.4 to 481.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	40	SF	\$40	\$1,602	
52104	474.4 to 475.4 feet	Vertical Change	-.29	5 ft	5	REF			
6268	481.3 to 588.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	481	SF	\$120	\$57,672	
58068	581.9 to 608.1 feet	Driveway				REF			
46611	584.8 to 585.8 feet	Vertical Change	-.45	5 ft	5	REF			
6277	591.6 to 605.1 feet	Cross Slope (Driveway)	>15%	5 ft	61	SF	\$40	\$2,430	
40227	604.3 to 606.2 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
6281	608.6 to 626.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	81	SF	\$120	\$9,666	
58069	621.4 to 649.6 feet	Driveway				REF			
6283	630.2 to 647.2 feet	Cross Slope (Driveway)	13.014	5 ft	77	SF	\$40	\$3,060	
40228	645.9 to 647.9 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
6287	650.4 to 674.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	108	SF	\$40	\$4,320	
55960	674.2 to 675.2 feet	Vertical Change	.34	5 ft	5	REF			
6289	674.4 to 691.0 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	75	SF	\$120	\$8,964	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	1908220959	CIRCLE DR	CALAVERAS ST	AMADOR ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
6291	691.0 to 693.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	11	SF	\$120	\$1,296	
6293	693.4 to 702.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	41	SF	\$120	\$4,860	
6294	702.4 to 713.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,778	
6296	713.1 to 742.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	131	SF	\$120	\$15,714	
41501	739.2 to 740.2 feet	Vertical Change	-1.09	5 ft	5	REF			
58070	740.0 to 760.8 feet	Driveway				REF			
43719	742.2 to 743.2 feet	Vertical Change	-.59	5 ft	5	REF			
6300	745.4 to 756.8 feet	Cross Slope (Driveway)	>15%	5 ft	51	SF	\$40	\$2,052	
45241	759.1 to 760.1 feet	Vertical Change	-.51	5 ft	5	REF			
6301	760.5 to 761.9 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$252	
6302	761.9 to 779.3 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	78	SF	\$120	\$9,396	
58071	778.8 to 802.5 feet	Driveway				REF			
6306	779.3 to 783.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	18	SF	\$40	\$720	
6307	783.3 to 784.4 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	5	SF	\$40	\$198	
45735	784.8 to 785.8 feet	Vertical Change	-.49	5 ft	5	REF			
6308	787.3 to 800.1 feet	Cross Slope (Driveway)	>15%	5 ft	58	SF	\$40	\$2,304	
40229	799.2 to 800.9 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
41558	802.2 to 803.2 feet	Vertical Change	-1.01	5 ft	5	REF			
6309	803.8 to 835.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	142	SF	\$120	\$17,064	
6312	835.4 to 841.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	29	SF	\$120	\$3,456	
6313	841.8 to 848.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,510	
52557	866.0 to 867.0 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$338	
58072	896.8 to 922.3 feet	Driveway				REF			
40230	901.7 to 903.7 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
50385	902.2 to 903.2 feet	Vertical Change	-.32	5 ft	5	REF			
6314	905.5 to 908.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	15	SF	\$40	\$612	
6316	908.9 to 912.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	15	SF	\$40	\$594	
6317	912.2 to 916.0 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	17	SF	\$40	\$684	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1908220959	CIRCLE DR	CALAVERAS ST	AMADOR ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
45736	912.6 to 913.6 feet	Vertical Change	-49	5 ft	5	REF			
6318	916.0 to 918.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	12	SF	\$40	\$468	
40231	918.8 to 920.5 feet	Running Slope	9.0-10.0%	5 ft	8	REF			
49072	932.7 to 933.7 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$338	
6320	944.4 to 974.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	135	SF	\$120	\$16,200	
58073	975.7 to 1003.0 feet	Driveway				REF			
42773	981.7 to 982.7 feet	Vertical Change	-.66	5 ft	5	REF			
6322	984.2 to 999.2 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	68	SF	\$40	\$2,700	
40232	998.0 to 999.9 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
6324	1002.9 to 1004.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$288	
50023	1047.5 to 1048.5 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$338	
53066	1059.4 to 1060.4 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$338	
58074	1062.2 to 1087.8 feet	Driveway				REF			
6325	1063.3 to 1065.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	9	SF	\$40	\$378	
6326	1070.4 to 1085.7 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	69	SF	\$40	\$2,754	
41721	1086.0 to 1087.0 feet	Vertical Change	-.88	5 ft	5	REF			
58075	1088.4 to 1108.3 feet	Driveway				REF			
57465	1091.4 to 1092.4 feet	Vertical Change	1.46	5 ft	5	REF			
6332	1095.3 to 1104.7 feet	Cross Slope (Driveway)	13.014	5 ft	42	SF	\$40	\$1,692	
40233	1104.3 to 1105.4 feet	Running Slope	7.0-8.0%	5 ft	5	REF			
6334	1108.3 to 1110.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	9	SF	\$40	\$360	
6335	1112.7 to 1168.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	249	SF	\$120	\$29,862	
50386	1152.2 to 1153.2 feet	Vertical Change	-.32	5 ft	5	REF			
58076	1168.3 to 1187.7 feet	Driveway				REF			
6340	1170.8 to 1172.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$234	
48780	1172.1 to 1173.1 feet	Vertical Change	-.37	5 ft	5	REF			
6341	1175.7 to 1184.2 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	38	SF	\$40	\$1,530	
6343	1188.2 to 1201.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	59	SF	\$40	\$2,340	
6344	1201.2 to 1235.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	155	SF	\$120	\$18,630	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1908220959	CIRCLE DR	CALAVERAS ST	AMADOR ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58077	1232.0 to 1252.0 feet	Driveway				REF		
6349	1235.7 to 1237.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	7	SF	\$40	\$270
6350	1241.0 to 1246.9 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	27	SF	\$40	\$1,062
6352	1246.9 to 1249.5 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	12	SF	\$40	\$468
40234	1248.7 to 1250.0 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
6353	1252.8 to 1257.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	23	SF	\$120	\$2,700
58078	1254.4 to 1277.9 feet	Driveway				REF		
40235	1257.9 to 1259.3 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
6355	1261.6 to 1273.8 feet	Cross Slope (Driveway)	13.014	5 ft	55	SF	\$40	\$2,196
6358	1278.6 to 1333.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	245	SF	\$120	\$29,376
51673	1291.6 to 1292.6 feet	Vertical Change	-3	5 ft	5	REF		
53603	1311.7 to 1312.7 feet	Vertical Change	-26	5 ft	5	REF		
58079	1329.9 to 1347.1 feet	Driveway				REF		
46845	1331.4 to 1332.4 feet	Vertical Change	-.44	5 ft	5	REF		
6364	1337.8 to 1344.1 feet	Cross Slope (Driveway)	13.014	5 ft	28	SF	\$40	\$1,134
6366	1348.1 to 1358.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	45	SF	\$120	\$5,454
6367	1358.2 to 1422.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	291	SF	\$120	\$34,938
46389	1372.4 to 1373.4 feet	Vertical Change	-.46	5 ft	5	REF		
52105	1402.3 to 1403.3 feet	Vertical Change	-.29	5 ft	5	REF		
45737	1417.3 to 1418.3 feet	Vertical Change	-.49	5 ft	5	REF		
45521	1427.9 to 1428.9 feet	Vertical Change	-.5	5 ft	5	SF	\$75	\$338
6373	1433.9 to 1448.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	64	SF	\$120	\$7,722
45522	1437.9 to 1438.9 feet	Vertical Change	-.5	5 ft	5	REF		
58080	1442.0 to 1472.1 feet	Driveway				REF		
43578	1448.0 to 1452.0 feet	Vertical Change	-.6	5 ft	18	REF		
6375	1452.5 to 1468.9 feet	Cross Slope (Driveway)	>15%	5 ft	74	SF	\$40	\$2,952
44434	1460.2 to 1461.2 feet	Vertical Change	-.55	5 ft	5	REF		
40236	1468.6 to 1470.6 feet	Running Slope	6.0-7.0%	5 ft	9	REF		
45944	1470.1 to 1473.3 feet	Vertical Change	-.48	5 ft	14	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1908220959	CIRCLE DR	CALAVERAS ST	AMADOR ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
6377	1473.3 to 1491.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	82	SF	\$120	\$9,882
46612	1482.1 to 1483.1 feet	Vertical Change	-45	5 ft	5	REF		
TOTAL COST FOR: NW side of CIRCLE DR Starting at: CALAVERAS ST							\$517,801.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
W	1908221003	CIRCLE DR	AMADOR ST	VENTURA AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
6380	11.1 to 17.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,618	
58081	26.2 to 44.8 feet	Driveway				REF			
45945	32.2 to 33.2 feet	Vertical Change	-.48	5 ft	5	REF			
6381	35.3 to 42.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	31	SF	\$40	\$1,242	
43250	44.0 to 45.0 feet	Vertical Change	-.62	5 ft	5	REF			
6383	46.0 to 52.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,564	
6384	70.7 to 119.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	219	SF	\$120	\$26,298	
58082	115.2 to 140.6 feet	Driveway				REF			
6388	124.0 to 137.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	63	SF	\$40	\$2,502	
41592	129.6 to 130.6 feet	Vertical Change	-.99	5 ft	5	REF			
40237	137.6 to 139.1 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
6391	141.5 to 147.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,240	
58083	143.4 to 168.4 feet	Driveway				REF			
6392	151.3 to 165.0 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	62	SF	\$40	\$2,466	
40238	164.7 to 165.8 feet	Running Slope	7.0-8.0%	5 ft	5	REF			
6396	168.9 to 181.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	56	SF	\$120	\$6,696	
6397	181.3 to 186.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,916	
6398	202.2 to 279.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	349	SF	\$120	\$41,904	
53067	215.6 to 216.6 feet	Vertical Change	-.27	5 ft	5	REF			
6404	279.8 to 292.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	56	SF	\$120	\$6,750	
58084	287.4 to 328.8 feet	Driveway				REF			
56952	292.8 to 293.8 feet	Vertical Change	.55	5 ft	5	REF			
6406	297.2 to 302.8 feet	Cross Slope (Driveway)	13.014	5 ft	25	SF	\$40	\$1,008	
6408	302.8 to 308.3 feet	Cross Slope (Driveway)	>15%	5 ft	25	SF	\$40	\$990	
6410	308.3 to 309.3 feet	Cross Slope (Driveway)	13.014	5 ft	5	SF	\$40	\$180	
43398	311.9 to 312.9 feet	Vertical Change	-.61	5 ft	5	REF			
6411	315.6 to 325.7 feet	Cross Slope (Driveway)	13.014	5 ft	45	SF	\$40	\$1,818	
47305	328.6 to 329.6 feet	Vertical Change	-.42	5 ft	5	REF			
6414	329.6 to 330.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$540	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221003	CIRCLE DR	AMADOR ST	VENTURA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
6415	333.2 to 394.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	276	SF	\$120	\$33,156
46613	344.5 to 345.5 feet	Vertical Change	-.45	5 ft	5	REF		
47556	355.0 to 356.0 feet	Vertical Change	-.41	5 ft	5	REF		
41764	375.3 to 376.3 feet	Vertical Change	-.86	5 ft	5	REF		
42474	385.6 to 386.6 feet	Vertical Change	-.69	5 ft	5	REF		
TOTAL COST FOR: W side of CIRCLE DR Starting at: AMADOR ST							\$138,888.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1908221012	CIRCLE DR	VENTURA AVE	CALAVERAS ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
6420	0.0 to 10.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,400	
6422	10.0 to 19.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	44	SF	\$120	\$5,292	
6426	19.8 to 52.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	145	SF	\$120	\$17,442	
58085	48.3 to 66.5 feet	Driveway				REF			
6431	56.4 to 63.4 feet	Cross Slope (Driveway)	>15%	5 ft	32	SF	\$40	\$1,260	
6432	67.1 to 68.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$648	
6433	68.3 to 76.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,374	
6437	83.5 to 95.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,264	
6439	95.1 to 167.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	324	SF	\$120	\$38,826	
43251	165.8 to 166.8 feet	Vertical Change	-.62	5 ft	5	REF			
6445	167.0 to 169.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,242	
58086	167.5 to 190.8 feet	Driveway				REF			
6446	173.7 to 187.8 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	63	SF	\$40	\$2,538	
40239	186.8 to 188.4 feet	Running Slope	7.0-8.0%	5 ft	7	REF			
53604	190.5 to 191.5 feet	Vertical Change	-.26	5 ft	5	REF			
6448	191.8 to 283.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	414	SF	\$120	\$49,626	
51674	219.9 to 220.9 feet	Vertical Change	-.3	5 ft	5	REF			
44047	249.5 to 250.5 feet	Vertical Change	-.57	5 ft	5	REF			
6457	293.4 to 362.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	309	SF	\$120	\$37,044	
50387	308.8 to 309.8 feet	Vertical Change	-.32	5 ft	5	REF			
45946	338.3 to 339.3 feet	Vertical Change	-.48	5 ft	5	REF			
58087	357.6 to 382.0 feet	Driveway				REF			
6467	365.6 to 378.9 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	60	SF	\$40	\$2,394	
40240	378.4 to 380.4 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
6469	382.6 to 383.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$648	
6470	383.8 to 612.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	1030	SF	\$120	\$123,660	
50771	387.0 to 388.0 feet	Vertical Change	-.31	5 ft	5	REF			
52558	439.3 to 440.3 feet	Vertical Change	-.28	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908221012	CIRCLE DR	VENTURA AVE	CALAVERAS ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56910	446.5 to 447.5 feet	Vertical Change	.5	5 ft	5	REF		
53997	454.3 to 455.3 feet	Vertical Change	-.25	5 ft	5	REF		
53998	461.9 to 462.9 feet	Vertical Change	-.25	5 ft	5	REF		
47075	536.8 to 537.8 feet	Vertical Change	-.43	5 ft	5	REF		
49369	559.1 to 560.1 feet	Vertical Change	-.35	5 ft	5	REF		
58088	607.3 to 634.7 feet	Driveway				REF		
6489	616.8 to 632.1 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	69	SF	\$40	\$2,754
40241	631.2 to 633.3 feet	Running Slope	5.0-6.0%	5 ft	9	REF		
6494	636.1 to 641.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,808
58089	637.8 to 663.9 feet	Driveway				REF		
51675	640.1 to 641.1 feet	Vertical Change	-.3	5 ft	5	REF		
6496	645.9 to 661.4 feet	Cross Slope (Driveway)	13.014	5 ft	70	SF	\$40	\$2,790
6497	665.2 to 707.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	188	SF	\$120	\$22,572
6499	707.0 to 731.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	112	SF	\$120	\$13,446
58090	728.8 to 754.8 feet	Driveway				REF		
6503	736.0 to 751.6 feet	Cross Slope (Driveway)	>15%	5 ft	70	SF	\$40	\$2,808
40242	750.5 to 752.6 feet	Running Slope	6.0-7.0%	5 ft	9	REF		
6504	755.8 to 799.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	198	SF	\$120	\$23,760
48210	758.6 to 759.6 feet	Vertical Change	-.39	5 ft	5	REF		
6506	799.8 to 834.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	156	SF	\$120	\$18,684
6507	837.4 to 852.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	66	SF	\$120	\$7,938
58091	844.7 to 874.7 feet	Driveway				REF		
51676	852.6 to 853.6 feet	Vertical Change	-.3	5 ft	5	REF		
6509	855.8 to 870.5 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	66	SF	\$40	\$2,646
40243	870.6 to 872.5 feet	Running Slope	6.0-7.0%	5 ft	9	REF		
6512	875.1 to 901.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	117	SF	\$40	\$4,698
52106	877.5 to 878.5 feet	Vertical Change	-.29	5 ft	5	REF		
6515	901.2 to 929.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	128	SF	\$120	\$15,336
49073	915.1 to 916.1 feet	Vertical Change	-.36	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1908221012	CIRCLE DR	VENTURA AVE	CALAVERAS ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
58092	923.4 to 949.5 feet	Driveway				REF			
6519	933.2 to 946.2 feet	Cross Slope (Driveway)	>15%	5 ft	59	SF	\$40	\$2,340	
43875	948.6 to 949.6 feet	Vertical Change	-.58	5 ft	5	REF			
6522	950.5 to 961.4 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	49	SF	\$40	\$1,962	
58093	956.7 to 980.2 feet	Driveway				REF			
49697	958.7 to 959.7 feet	Vertical Change	-.34	5 ft	5	REF			
6523	965.1 to 977.1 feet	Cross Slope (Driveway)	>15%	5 ft	54	SF	\$40	\$2,160	
40244	976.5 to 978.2 feet	Running Slope	6.0-7.0%	5 ft	8	REF			
6525	981.0 to 995.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	66	SF	\$120	\$7,884	
6527	995.6 to 1021.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	115	SF	\$120	\$13,824	
58094	1016.2 to 1036.8 feet	Driveway				REF			
50388	1021.1 to 1022.1 feet	Vertical Change	-.32	5 ft	5	REF			
6530	1023.9 to 1033.8 feet	Cross Slope (Driveway)	>15%	5 ft	45	SF	\$40	\$1,782	
40245	1032.8 to 1035.6 feet	Running Slope	6.0-7.0%	5 ft	13	REF			
53068	1035.8 to 1036.8 feet	Vertical Change	-.27	5 ft	5	REF			
6531	1037.3 to 1077.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	181	SF	\$40	\$7,254	
57149	1051.4 to 1052.4 feet	Vertical Change	.65	5 ft	5	REF			
6537	1077.6 to 1083.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,078	
58095	1087.9 to 1110.8 feet	Driveway				REF			
6539	1088.4 to 1091.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	15	SF	\$40	\$612	
6540	1095.7 to 1107.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	54	SF	\$40	\$2,178	
40246	1107.0 to 1108.9 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
52559	1110.3 to 1111.3 feet	Vertical Change	-.28	5 ft	5	REF			
6543	1111.7 to 1112.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$540	
6544	1119.2 to 1133.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,614	
58096	1130.8 to 1151.3 feet	Driveway				REF			
6546	1137.2 to 1148.8 feet	Cross Slope (Driveway)	>15%	5 ft	52	SF	\$40	\$2,088	
40247	1146.8 to 1149.1 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
48781	1151.0 to 1152.0 feet	Vertical Change	-.37	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	1908221012	CIRCLE DR	VENTURA AVE	CALAVERAS ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
6547	1153.3 to 1179.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	117	SF	\$120	\$14,094	
50389	1174.4 to 1175.4 feet	Vertical Change	-32	5 ft	5	REF			
6550	1179.4 to 1195.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,910	
6552	1195.9 to 1212.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	75	SF	\$120	\$9,018	
47962	1203.9 to 1204.9 feet	Vertical Change	-.4	5 ft	5	REF			
58097	1207.6 to 1230.8 feet	Driveway				REF			
42774	1213.1 to 1214.1 feet	Vertical Change	-.66	5 ft	5	REF			
6556	1216.4 to 1228.6 feet	Cross Slope (Driveway)	>15%	5 ft	55	SF	\$40	\$2,196	
40248	1227.0 to 1228.9 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
45523	1230.5 to 1231.5 feet	Vertical Change	-.5	5 ft	5	REF			
6557	1232.4 to 1240.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	38	SF	\$120	\$4,536	
6558	1240.8 to 1254.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,182	
6560	1254.1 to 1286.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	147	SF	\$120	\$17,604	
46390	1278.8 to 1279.8 feet	Vertical Change	-.46	5 ft	5	REF			
58098	1281.8 to 1307.6 feet	Driveway				REF			
6564	1290.7 to 1305.7 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	68	SF	\$40	\$2,700	
40249	1304.8 to 1306.3 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
6567	1310.0 to 1322.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	55	SF	\$120	\$6,588	
6568	1322.2 to 1350.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	128	SF	\$120	\$15,390	
53069	1338.9 to 1339.9 feet	Vertical Change	-.27	5 ft	5	REF			
6572	1350.7 to 1357.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	28	SF	\$120	\$3,402	
58099	1352.7 to 1389.0 feet	Driveway				REF			
6574	1361.3 to 1386.9 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	115	SF	\$40	\$4,608	
53999	1388.3 to 1389.3 feet	Vertical Change	-.25	5 ft	5	REF			
6580	1391.0 to 1395.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	19	SF	\$120	\$2,322	
6581	1395.3 to 1423.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	126	SF	\$120	\$15,066	
50772	1421.8 to 1422.8 feet	Vertical Change	-.31	5 ft	5	REF			
6585	1423.2 to 1444.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	95	SF	\$120	\$11,394	
58100	1441.0 to 1463.4 feet	Driveway				REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	1908221012	CIRCLE DR	VENTURA AVE	CALAVERAS ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
6589	1448.2 to 1460.7 feet	Cross Slope (Driveway)	>15%	5 ft	56	SF	\$40	\$2,250	
40250	1459.9 to 1461.3 feet	Running Slope	6.0-7.0%	5 ft	6	REF			
6590	1464.5 to 1472.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	37	SF	\$120	\$4,428	
6591	1472.7 to 1481.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,590	
6592	1497.2 to 1498.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$918	
6593	1503.3 to 1571.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	307	SF	\$120	\$36,828	
58101	1566.7 to 1593.2 feet	Driveway				REF			
6597	1576.2 to 1590.5 feet	Cross Slope (Driveway)	13.014	5 ft	64	SF	\$40	\$2,574	
40251	1589.8 to 1592.3 feet	Running Slope	5.0-6.0%	5 ft	11	REF			
6600	1595.4 to 1609.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,560	
50773	1598.9 to 1599.9 feet	Vertical Change	-.31	5 ft	5	REF			
58102	1605.4 to 1627.8 feet	Driveway				REF			
6604	1613.1 to 1625.9 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	58	SF	\$40	\$2,304	
50390	1619.3 to 1620.3 feet	Vertical Change	-.32	5 ft	5	REF			
40252	1625.0 to 1626.8 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
6606	1629.8 to 1679.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	224	SF	\$120	\$26,838	
48782	1636.5 to 1637.5 feet	Vertical Change	-.37	5 ft	5	REF			
47076	1656.7 to 1657.7 feet	Vertical Change	-.43	5 ft	5	REF			
48783	1679.1 to 1680.1 feet	Vertical Change	-.37	5 ft	5	REF			
6612	1683.5 to 1693.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,562	
44435	1696.6 to 1697.6 feet	Vertical Change	-.55	5 ft	5	SF	\$75	\$338	
6613	1701.0 to 1733.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	145	SF	\$120	\$17,388	
53605	1711.6 to 1712.6 feet	Vertical Change	-.26	5 ft	5	REF			
58103	1727.8 to 1753.6 feet	Driveway				REF			
6621	1736.8 to 1750.4 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	61	SF	\$40	\$2,448	
6623	1754.6 to 1755.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$648	
6624	1755.8 to 1770.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	66	SF	\$120	\$7,884	
50774	1759.2 to 1760.2 feet	Vertical Change	-.31	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908221012	CIRCLE DR	VENTURA AVE	CALAVERAS ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
6626	1770.4 to 1790.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	92	SF	\$120	\$11,070
6632	1790.9 to 1802.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,210
41618	1791.7 to 1792.7 feet	Vertical Change	-.96	5 ft	5	REF		
6633	1804.9 to 1816.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,318
58104	1813.7 to 1838.2 feet	Driveway				REF		
49074	1814.4 to 1815.4 feet	Vertical Change	-.36	5 ft	5	REF		
6634	1820.7 to 1834.3 feet	Cross Slope (Driveway)	13.014	5 ft	61	SF	\$40	\$2,448
40253	1834.5 to 1835.7 feet	Running Slope	8.0-9.0%	5 ft	5	REF		
6637	1839.0 to 1911.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	327	SF	\$120	\$39,258
46159	1883.3 to 1884.3 feet	Vertical Change	-.47	5 ft	5	REF		
47077	1911.2 to 1912.2 feet	Vertical Change	-.43	5 ft	5	REF		
6641	1911.7 to 1916.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,592
TOTAL COST FOR: SE side of CIRCLE DR Starting at: VENTURA AVE							\$785,677.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221015	CALAVERAS ST	CIRCLE DR	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
6642	0.7 to 13.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	58	SF	\$120	\$6,912
49075	1.3 to 2.3 feet	Vertical Change	-.36	5 ft	4	REF		
6643	13.5 to 42.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	130	SF	\$120	\$15,552
52560	19.0 to 20.0 feet	Vertical Change	-.28	5 ft	5	REF		
54000	37.8 to 38.8 feet	Vertical Change	-.25	5 ft	5	REF		
6645	42.3 to 132.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	404	SF	\$120	\$48,492
51677	47.9 to 48.9 feet	Vertical Change	-.3	5 ft	5	REF		
44663	77.9 to 78.9 feet	Vertical Change	-.54	5 ft	5	REF		
50391	107.8 to 108.8 feet	Vertical Change	-.32	5 ft	5	REF		
58105	127.3 to 152.6 feet	Driveway				REF		
53070	133.3 to 134.3 feet	Vertical Change	-.27	5 ft	5	REF		
6655	136.3 to 149.8 feet	Cross Slope (Driveway)	>15%	5 ft	61	SF	\$40	\$2,430
40254	148.9 to 150.2 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
46614	152.1 to 153.1 feet	Vertical Change	-.45	5 ft	5	REF		
6656	153.2 to 169.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	72	SF	\$40	\$2,880
52561	157.7 to 158.7 feet	Vertical Change	-.28	5 ft	5	REF		
TOTAL COST FOR: S							<i>side of CALAVERAS ST Starting at: CIRCLE DR</i>	\$76,266.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221025	HOSPITAL DR	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
6658	0.0 to 15.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	76	SF	\$120	\$9,060
58106	10.9 to 48.4 feet	Driveway				REF		
6660	17.3 to 47.1 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	149	SF	\$40	\$5,960
6666	47.1 to 49.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	11	SF	\$40	\$440
48498	49.1 to 50.1 feet	Vertical Change	-.38	5 ft	5	REF		
6668	49.3 to 96.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	237	SF	\$120	\$28,380
47306	52.3 to 53.3 feet	Vertical Change	-.42	5 ft	5	REF		
45947	66.3 to 67.3 feet	Vertical Change	-.48	5 ft	5	REF		
48211	79.8 to 80.8 feet	Vertical Change	-.39	5 ft	5	REF		
42997	93.8 to 94.8 feet	Vertical Change	-.64	5 ft	5	REF		
6671	96.6 to 177.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	403	SF	\$120	\$48,360
46391	108.2 to 109.2 feet	Vertical Change	-.46	5 ft	5	REF		
42475	122.4 to 123.4 feet	Vertical Change	-.69	5 ft	5	REF		
43876	136.9 to 137.9 feet	Vertical Change	-.58	5 ft	5	REF		
46392	151.1 to 152.1 feet	Vertical Change	-.46	5 ft	5	REF		
43252	165.3 to 166.3 feet	Vertical Change	-.62	5 ft	5	REF		
6675	177.2 to 193.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	80	SF	\$120	\$9,540
42092	179.7 to 180.7 feet	Vertical Change	-.75	5 ft	5	REF		
6677	193.1 to 208.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	77	SF	\$120	\$9,180
42093	194.0 to 195.0 feet	Vertical Change	-.75	5 ft	5	REF		
58107	204.0 to 218.5 feet	Driveway				REF		
44237	207.8 to 208.8 feet	Vertical Change	-.56	5 ft	5	REF		
6680	213.4 to 218.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	26	SF	\$40	\$1,020
TOTAL COST FOR: W side of HOSPITAL DR Starting at: SIDEWALK BEGINS							\$111,940.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221030	HOWELL RD	VENTURA AVE	DOROTHY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
6683	0.0 to 3.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,782
56914	1.8 to 2.8 feet	Vertical Change	.51	5 ft	5	REF		
6685	3.3 to 9.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	28	SF	\$120	\$3,348
58108	5.4 to 32.9 feet	Driveway				REF		
41982	9.3 to 10.3 feet	Vertical Change	-.78	5 ft	4	REF		
46846	9.3 to 10.3 feet	Vertical Change	-.44	5 ft	4	REF		
6686	12.7 to 25.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	58	SF	\$40	\$2,322
48212	20.5 to 21.5 feet	Vertical Change	-.39	5 ft	5	REF		
6688	25.6 to 29.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	19	SF	\$40	\$756
40255	28.8 to 30.7 feet	Running Slope	6.0-7.0%	5 ft	9	REF		
47307	32.3 to 33.3 feet	Vertical Change	-.42	5 ft	5	REF		
6689	33.3 to 34.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$180
6690	34.3 to 45.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,210
6691	57.2 to 74.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	77	SF	\$120	\$9,234
42290	71.6 to 72.6 feet	Vertical Change	-.71	5 ft	5	REF		
6694	78.4 to 85.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,888
TOTAL COST FOR: N side of HOWELL RD Starting at: VENTURA AVE							\$27,720.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221036	DOROTHY WAY	HOWELL RD	145 DOROTHY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44436	1.9 to 2.9 feet	Vertical Change	-.55	4 ft	4	SF	\$75	\$300
6696	11.3 to 15.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,872
45040	12.6 to 13.6 feet	Vertical Change	-.52	4 ft	4	REF		
48499	16.1 to 17.1 feet	Vertical Change	-.38	4 ft	4	LF	\$75	\$300
47078	25.4 to 26.4 feet	Vertical Change	-.43	4 ft	4	LF	\$75	\$300
6698	31.6 to 35.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	14	SF	\$120	\$1,680
46160	39.2 to 40.2 feet	Vertical Change	-.47	4 ft	4	REF		
6699	39.3 to 42.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	12	SF	\$120	\$1,440
47308	51.9 to 52.9 feet	Vertical Change	-.42	4 ft	4	LF	\$75	\$300
45242	64.1 to 65.1 feet	Vertical Change	-.51	4 ft	4	SF	\$75	\$300
6700	92.4 to 96.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	18	SF	\$120	\$2,112
45243	93.7 to 94.7 feet	Vertical Change	-.51	4 ft	4	REF		
43120	108.1 to 109.1 feet	Vertical Change	-.63	4 ft	4	REF		
6701	108.2 to 110.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	10	SF	\$120	\$1,248
58109	117.2 to 132.8 feet	Driveway				REF		
44437	122.7 to 123.7 feet	Vertical Change	-.55	4 ft	4	REF		
42998	129.9 to 130.9 feet	Vertical Change	-.64	4 ft	4	REF		
41704	137.1 to 138.1 feet	Vertical Change	-.89	4 ft	4	SF	\$75	\$300
51678	163.1 to 164.1 feet	Vertical Change	-.3	4 ft	4	LF	\$75	\$300
58110	188.7 to 205.7 feet	Driveway				REF		
41550	193.6 to 194.6 feet	Vertical Change	-1.02	4 ft	4	REF		
43579	202.3 to 203.3 feet	Vertical Change	-.6	4 ft	4	REF		
41743	210.7 to 211.7 feet	Vertical Change	-.87	4 ft	4	SF	\$75	\$300
31	218.8 to 219.8 feet	Continuous Width		4 ft	4	SF	\$120	\$480
58111	223.6 to 244.2 feet	Driveway				REF		
42291	226.2 to 227.2 feet	Vertical Change	-.71	4 ft	4	REF		
45739	236.1 to 237.1 feet	Vertical Change	-.49	4 ft	4	REF		
6702	243.7 to 246.9 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	13	SF	\$40	\$512

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221036	DOROTHY WAY	HOWELL RD	145 DOROTHY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
48784	245.5 to 246.5 feet	Vertical Change	-.37	4 ft	4	REF		
6703	253.7 to 260.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	27	SF	\$120	\$3,216
54001	261.2 to 262.2 feet	Vertical Change	-.25	4 ft	4	LF	\$75	\$300
6704	263.7 to 265.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	9	SF	\$120	\$1,056
48785	276.3 to 277.3 feet	Vertical Change	-.37	4 ft	4	LF	\$75	\$300
6705	312.2 to 317.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	21	SF	\$120	\$2,544
58112	345.2 to 361.8 feet	Driveway				REF		
43580	348.9 to 349.9 feet	Vertical Change	-.6	4 ft	4	REF		
45948	357.0 to 358.0 feet	Vertical Change	-.48	4 ft	4	REF		
6707	360.3 to 363.7 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	14	SF	\$40	\$544
46393	364.9 to 365.9 feet	Vertical Change	-.46	4 ft	4	LF	\$75	\$300
58113	388.0 to 401.3 feet	Driveway				REF		
6708	391.3 to 395.7 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	18	SF	\$40	\$704
42999	404.8 to 405.8 feet	Vertical Change	-.64	4 ft	4	SF	\$75	\$300
56941	404.9 to 405.9 feet	Vertical Change	.54	4 ft	4	SF	\$75	\$300
6709	412.5 to 422.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	39	SF	\$120	\$4,656
52107	424.4 to 425.4 feet	Vertical Change	-.29	4 ft	4	LF	\$75	\$300
45949	439.2 to 440.2 feet	Vertical Change	-.48	4 ft	4	LF	\$75	\$300
58114	449.3 to 465.2 feet	Driveway				REF		
46161	453.8 to 454.8 feet	Vertical Change	-.47	4 ft	4	REF		
48786	482.2 to 483.2 feet	Vertical Change	-.37	4 ft	4	LF	\$75	\$300
6710	490.2 to 500.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	42	SF	\$120	\$5,088
58115	490.7 to 520.9 feet	Driveway				REF		
44438	496.6 to 497.6 feet	Vertical Change	-.55	4 ft	4	REF		
45740	510.8 to 511.8 feet	Vertical Change	-.49	4 ft	4	REF		
6711	519.2 to 526.5 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	29	SF	\$40	\$1,168
32	524.2 to 525.2 feet	Continuous Width		4 ft	4	SF	\$120	\$480
50024	526.2 to 527.2 feet	Vertical Change	-.33	4 ft	4	REF		
6712	535.6 to 547.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	46	SF	\$120	\$5,520

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221036	DOROTHY WAY	HOWELL RD	145 DOROTHY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46847	537.2 to 538.2 feet	Vertical Change	-.44	4 ft	4	REF		
48213	553.0 to 554.0 feet	Vertical Change	-.39	4 ft	4	LF	\$75	\$300
6715	565.4 to 568.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	10	SF	\$120	\$1,248
50392	566.6 to 567.6 feet	Vertical Change	-.32	4 ft	4	REF		
6716	574.6 to 605.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	123	SF	\$120	\$14,736
58116	576.1 to 598.8 feet	Driveway				REF		
48214	591.0 to 592.0 feet	Vertical Change	-.39	4 ft	4	REF		
57340	628.3 to 629.3 feet	Vertical Change	.98	4 ft	4	SF	\$75	\$300
41509	628.4 to 629.4 feet	Vertical Change	-1.08	4 ft	4	SF	\$75	\$300
6725	652.3 to 669.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	70	SF	\$120	\$8,352
58117	652.6 to 665.0 feet	Driveway				REF		
47557	656.5 to 657.5 feet	Vertical Change	-.41	4 ft	4	REF		
43121	687.2 to 688.2 feet	Vertical Change	-.63	4 ft	4	SF	\$75	\$300
42236	702.7 to 703.7 feet	Vertical Change	-.72	4 ft	4	SF	\$75	\$300
43253	718.0 to 719.0 feet	Vertical Change	-.62	4 ft	4	SF	\$75	\$300
6728	728.2 to 730.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	11	SF	\$120	\$1,296
58118	728.8 to 775.0 feet	Driveway				REF		
6730	730.9 to 739.2 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	33	SF	\$40	\$1,328
45244	732.8 to 733.8 feet	Vertical Change	-.51	4 ft	4	REF		
6732	739.2 to 783.9 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	179	SF	\$40	\$7,152
48215	749.5 to 750.5 feet	Vertical Change	-.39	4 ft	4	REF		
42292	765.1 to 766.1 feet	Vertical Change	-.71	4 ft	4	REF		
43122	792.1 to 793.1 feet	Vertical Change	-.63	4 ft	4	SF	\$75	\$300
46162	804.4 to 805.4 feet	Vertical Change	-.47	4 ft	4	LF	\$75	\$300
43581	819.5 to 820.5 feet	Vertical Change	-.6	4 ft	4	SF	\$75	\$300
33	828.0 to 829.0 feet	Continuous Width		4 ft	4	SF	\$120	\$480
58119	831.5 to 843.3 feet	Driveway				REF		
45741	847.4 to 848.4 feet	Vertical Change	-.49	4 ft	4	LF	\$75	\$300
58120	863.0 to 902.3 feet	Driveway				REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221036	DOROTHY WAY	HOWELL RD	145 DOROTHY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
49076	864.2 to 865.2 feet	Vertical Change	-.36	4 ft	4	REF		
52562	876.8 to 877.8 feet	Vertical Change	-.28	4 ft	4	REF		
50393	907.1 to 908.1 feet	Vertical Change	-.32	4 ft	4	LF	\$75	\$300
58121	949.4 to 969.5 feet	Driveway				REF		
52563	962.7 to 963.7 feet	Vertical Change	-.28	4 ft	4	REF		
TOTAL COST FOR: E side of DOROTHY WAY Starting at: HOWELL RD							\$77,012.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221039	DOROTHY WAY	145 DOROTHY WAY	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58122	11.6 to 29.3 feet	Driveway				REF		
6737	16.2 to 19.4 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	13	SF	\$40	\$512
44048	24.5 to 25.5 feet	Vertical Change	-.57	4 ft	4	REF		
50394	45.4 to 46.4 feet	Vertical Change	-.32	4 ft	4	LF	\$75	\$300
45524	56.0 to 57.0 feet	Vertical Change	-.5	4 ft	4	SF	\$75	\$300
43399	86.3 to 87.3 feet	Vertical Change	-.61	4 ft	4	SF	\$75	\$300
45525	101.9 to 102.9 feet	Vertical Change	-.5	4 ft	4	SF	\$75	\$300
42675	117.0 to 118.0 feet	Vertical Change	-.67	4 ft	4	SF	\$75	\$300
58123	129.9 to 148.2 feet	Driveway				REF		
6738	131.6 to 154.1 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	90	SF	\$40	\$3,600
42676	142.0 to 143.0 feet	Vertical Change	-.67	4 ft	4	REF		
34	153.2 to 154.2 feet	Continuous Width		4 ft	4	SF	\$120	\$480
6743	154.1 to 159.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	23	SF	\$120	\$2,784
58124	156.8 to 185.5 feet	Driveway				REF		
6745	159.9 to 191.1 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	125	SF	\$40	\$4,992
53606	173.9 to 174.9 feet	Vertical Change	-.26	4 ft	4	REF		
6748	191.1 to 193.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	9	SF	\$120	\$1,056
47558	235.1 to 236.1 feet	Vertical Change	-.41	4 ft	4	LF	\$75	\$300
46394	250.1 to 251.1 feet	Vertical Change	-.46	4 ft	4	LF	\$75	\$300
44664	264.8 to 265.8 feet	Vertical Change	-.54	4 ft	4	SF	\$75	\$300
58125	276.0 to 293.3 feet	Driveway				REF		
48500	279.8 to 280.8 feet	Vertical Change	-.38	4 ft	4	REF		
48216	288.7 to 289.7 feet	Vertical Change	-.39	4 ft	4	REF		
50025	297.0 to 298.0 feet	Vertical Change	-.33	4 ft	4	LF	\$75	\$300
TOTAL COST FOR: E side of DOROTHY WAY Starting at: 145 DOROTHY WAY							\$16,124.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221042	DOROTHY WAY	SIDEWALK BEGINS	CANAL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
6749	0.0 to 2.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	12	SF	\$120	\$1,392
51679	53.7 to 54.7 feet	Vertical Change	-3	4 ft	4	LF	\$75	\$300
48787	63.1 to 64.1 feet	Vertical Change	-37	4 ft	4	LF	\$75	\$300
58126	63.4 to 80.8 feet	Driveway				REF		
6750	68.8 to 101.0 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	129	SF	\$40	\$5,152
53607	97.8 to 98.8 feet	Vertical Change	-26	4 ft	4	REF		
46848	108.5 to 109.5 feet	Vertical Change	-44	4 ft	4	LF	\$75	\$300
TOTAL COST FOR: W side of DOROTHY WAY Starting at: SIDEWALK BEGINS								\$7,444.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908221046	CANAL DR	DOROTHY WAY	136 CANAL DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
6752	0.0 to 9.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	33	SF	\$120	\$3,948	
6753	20.3 to 36.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	57	SF	\$120	\$6,804	
54154	27.3 to 28.3 feet	Vertical Change	.27	4 ft	4	REF			
44439	37.1 to 38.1 feet	Vertical Change	-.55	4 ft	4	SF	\$75	\$263	
53608	39.3 to 40.3 feet	Vertical Change	-.26	4 ft	4	LF	\$75	\$263	
6756	59.8 to 67.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	26	SF	\$120	\$3,150	
6758	67.3 to 79.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	42	SF	\$120	\$5,040	
58127	67.9 to 107.8 feet	Driveway				REF			
46395	68.1 to 69.1 feet	Vertical Change	-.46	4 ft	4	REF			
6762	79.3 to 83.3 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	14	SF	\$40	\$560	
46163	93.6 to 94.6 feet	Vertical Change	-.47	4 ft	4	REF			
6763	95.8 to 198.8 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	361	SF	\$40	\$14,420	
58128	141.5 to 178.8 feet	Driveway				REF			
49077	191.9 to 192.9 feet	Vertical Change	-.36	4 ft	4	REF			
6776	198.8 to 220.2 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	75	SF	\$120	\$8,988	
58129	200.3 to 214.6 feet	Driveway				REF			
50026	204.0 to 205.0 feet	Vertical Change	-.33	4 ft	4	REF			
47559	219.2 to 220.2 feet	Vertical Change	-.41	4 ft	4	REF			
6779	220.2 to 229.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	34	SF	\$120	\$4,032	
44665	233.2 to 234.2 feet	Vertical Change	-.54	4 ft	4	SF	\$75	\$263	
6780	238.6 to 252.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	50	SF	\$120	\$6,006	
45245	247.2 to 248.2 feet	Vertical Change	-.51	4 ft	4	REF			
58130	250.2 to 276.3 feet	Driveway				REF			
48788	279.7 to 280.7 feet	Vertical Change	-.37	4 ft	4	LF	\$75	\$263	
6785	286.5 to 299.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	46	SF	\$120	\$5,502	
58131	332.5 to 352.9 feet	Driveway				REF			
50027	339.4 to 340.4 feet	Vertical Change	-.33	4 ft	4	REF			
6786	349.2 to 406.2 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	200	SF	\$40	\$7,980	
50775	359.6 to 360.6 feet	Vertical Change	-.31	4 ft	4	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221046	CANAL DR	DOROTHY WAY	136 CANAL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54002	370.6 to 371.6 feet	Vertical Change	-25	4 ft	4	REF		
52108	380.8 to 381.8 feet	Vertical Change	-29	4 ft	4	REF		
TOTAL COST FOR: N side of CANAL DR Starting at: DOROTHY WAY							\$67,480.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
N	1908221048	CANAL DR	136 CANAL DR	148 CANAL DR				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
6791	0.0 to 94.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	329	SF	\$120	\$39,522
58132	3.4 to 18.7 feet	Driveway				REF		
53609	58.2 to 59.2 feet	Vertical Change	-.26	4 ft	4	REF		
51680	79.8 to 80.8 feet	Vertical Change	-.3	4 ft	4	REF		
45526	88.3 to 89.3 feet	Vertical Change	-.5	4 ft	4	REF		
56622	88.3 to 89.3 feet	Vertical Change	.43	4 ft	4	REF		
53610	108.2 to 109.2 feet	Vertical Change	-.26	4 ft	4	LF	\$75	\$263
6799	120.5 to 137.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	59	SF	\$120	\$7,098
58133	129.3 to 150.2 feet	Driveway				REF		
6802	140.3 to 143.1 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	10	SF	\$40	\$392
50395	145.9 to 146.9 feet	Vertical Change	-.32	4 ft	4	REF		
6803	145.9 to 149.4 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	12	SF	\$40	\$490
6804	153.3 to 241.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	310	SF	\$120	\$37,170
45742	178.4 to 179.4 feet	Vertical Change	-.49	4 ft	4	REF		
53611	213.4 to 214.4 feet	Vertical Change	-.26	4 ft	4	REF		
40256	237.8 to 239.6 feet	Running Slope	5.0-6.0%	4 ft	6	REF		
46396	238.2 to 239.2 feet	Vertical Change	-.46	4 ft	4	REF		
6811	241.8 to 251.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	35	SF	\$120	\$4,200
TOTAL COST FOR: N							<i>side of CANAL DR Starting at: 136 CANAL DR</i>	\$89,134.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908221054	CANAL DR	148 CANAL DR	AUTUMN WAY	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
6815	0.0 to 28.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	127	SF	\$120	\$15,228	
46397	1.7 to 2.7 feet	Vertical Change	-.46	5 ft	5	REF			
47963	22.5 to 23.5 feet	Vertical Change	-.4	5 ft	5	REF			
6818	28.2 to 34.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,564	
58134	29.8 to 55.8 feet	Driveway				REF			
6820	37.3 to 53.8 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	74	SF	\$40	\$2,970	
43123	55.3 to 56.3 feet	Vertical Change	-.63	5 ft	5	REF			
6822	57.2 to 74.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	79	SF	\$120	\$9,450	
52109	66.9 to 67.9 feet	Vertical Change	-.29	5 ft	5	REF			
58135	69.8 to 92.4 feet	Driveway				REF			
54003	75.3 to 76.3 feet	Vertical Change	-.25	5 ft	5	REF			
6824	78.0 to 91.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	59	SF	\$40	\$2,358	
6826	99.3 to 108.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,914	
44666	108.5 to 109.5 feet	Vertical Change	-.54	5 ft	5	SF	\$75	\$338	
6827	117.0 to 172.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	248	SF	\$120	\$29,808	
6832	172.2 to 188.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	74	SF	\$120	\$8,856	
51681	172.3 to 173.3 feet	Vertical Change	-.3	5 ft	5	REF			
58136	183.0 to 207.7 feet	Driveway				REF			
45950	186.7 to 187.7 feet	Vertical Change	-.48	5 ft	5	REF			
6835	191.9 to 205.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	63	SF	\$40	\$2,502	
6838	209.1 to 229.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	93	SF	\$120	\$11,178	
58137	228.1 to 259.0 feet	Driveway				REF			
56638	228.6 to 229.6 feet	Vertical Change	.47	5 ft	5	REF			
6840	233.4 to 252.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	87	SF	\$40	\$3,474	
6844	252.7 to 256.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	17	SF	\$40	\$666	
6845	260.5 to 311.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	231	SF	\$120	\$27,756	
50776	263.2 to 264.2 feet	Vertical Change	-.31	5 ft	5	REF			
57243	301.7 to 302.7 feet	Vertical Change	.78	5 ft	5	REF			
58138	307.8 to 336.9 feet	Driveway				REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221054	CANAL DR	148 CANAL DR	AUTUMN WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51682	311.4 to 312.4 feet	Vertical Change	-.3	5 ft	5	REF		
6847	311.9 to 313.0 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$198
6848	315.1 to 319.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	18	SF	\$40	\$720
6850	319.1 to 331.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	58	SF	\$40	\$2,304
6852	331.9 to 335.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	15	SF	\$40	\$594
6854	337.4 to 349.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	53	SF	\$40	\$2,106
49078	340.0 to 341.0 feet	Vertical Change	-.36	5 ft	5	REF		
6858	349.1 to 359.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,832
6860	359.9 to 367.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	34	SF	\$120	\$4,050
6862	367.4 to 395.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	128	SF	\$120	\$15,390
46398	378.2 to 379.2 feet	Vertical Change	-.46	5 ft	5	REF		
58139	392.3 to 418.4 feet	Driveway				REF		
6864	395.9 to 398.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	11	SF	\$40	\$432
49079	398.1 to 399.1 feet	Vertical Change	-.36	5 ft	5	REF		
6865	401.8 to 415.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	61	SF	\$40	\$2,430
48789	418.3 to 419.4 feet	Vertical Change	-.37	5 ft	5	REF		
6868	419.3 to 444.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	112	SF	\$120	\$13,392
TOTAL COST FOR: N side of CANAL DR Starting at: 148 CANAL DR							\$170,509.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908221057	AUTUMN WAY	CANAL DR	HOWELL RD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
52110	0.7 to 1.7 feet	Vertical Change	-29	5 ft	5	REF			
6870	0.7 to 7.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	32	SF	\$120	\$3,834	
58140	3.4 to 27.3 feet	Driveway				REF			
44667	8.6 to 9.6 feet	Vertical Change	-.54	5 ft	5	REF			
6871	11.7 to 25.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	64	SF	\$40	\$2,556	
44049	27.3 to 28.3 feet	Vertical Change	-.57	5 ft	5	REF			
6872	29.3 to 74.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	204	SF	\$120	\$24,516	
53071	40.4 to 41.4 feet	Vertical Change	-.27	5 ft	5	REF			
41837	52.5 to 53.5 feet	Vertical Change	-.82	5 ft	5	REF			
6879	74.7 to 84.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,130	
50777	82.1 to 83.1 feet	Vertical Change	-.31	5 ft	5	REF			
58141	84.8 to 109.9 feet	Driveway				REF			
6882	87.6 to 88.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$216	
6883	93.0 to 106.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	60	SF	\$40	\$2,412	
6885	106.4 to 107.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	6	SF	\$40	\$234	
52564	108.5 to 109.5 feet	Vertical Change	-.28	5 ft	5	REF			
53072	112.8 to 113.8 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$338	
6886	116.3 to 137.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	95	SF	\$120	\$11,340	
52111	116.6 to 117.6 feet	Vertical Change	-.29	5 ft	5	REF			
41983	135.8 to 136.8 feet	Vertical Change	-.78	5 ft	5	REF			
6889	137.3 to 163.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	117	SF	\$120	\$14,040	
50028	156.1 to 157.1 feet	Vertical Change	-.33	5 ft	5	REF			
58142	156.8 to 185.9 feet	Driveway				REF			
45246	161.8 to 162.8 feet	Vertical Change	-.51	5 ft	5	REF			
6892	166.9 to 183.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	77	SF	\$40	\$3,060	
46849	174.3 to 175.3 feet	Vertical Change	-.44	5 ft	5	REF			
46399	187.3 to 188.3 feet	Vertical Change	-.46	5 ft	5	REF			
6895	187.4 to 229.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	190	SF	\$120	\$22,788	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221057	AUTUMN WAY	CANAL DR	HOWELL RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46850	217.0 to 218.0 feet	Vertical Change	-.44	5 ft	5	REF		
6898	229.6 to 233.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,214
49370	231.8 to 232.8 feet	Vertical Change	-.35	5 ft	5	REF		
6900	233.7 to 244.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	48	SF	\$120	\$5,724
58143	238.0 to 263.9 feet	Driveway				REF		
6902	244.9 to 246.1 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	5	SF	\$40	\$216
46615	245.0 to 246.0 feet	Vertical Change	-.45	5 ft	5	REF		
6903	247.9 to 261.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	60	SF	\$40	\$2,412
43582	262.9 to 263.9 feet	Vertical Change	-.6	5 ft	5	REF		
6905	265.0 to 293.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	127	SF	\$120	\$15,228
53073	265.5 to 266.5 feet	Vertical Change	-.27	5 ft	5	REF		
47309	272.5 to 273.5 feet	Vertical Change	-.42	5 ft	5	REF		
43124	284.0 to 285.0 feet	Vertical Change	-.63	5 ft	5	REF		
44440	292.4 to 293.4 feet	Vertical Change	-.55	5 ft	5	REF		
6909	293.2 to 306.7 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	61	SF	\$120	\$7,290
58144	303.0 to 326.7 feet	Driveway				REF		
6915	306.7 to 309.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	12	SF	\$40	\$486
46616	308.2 to 309.2 feet	Vertical Change	-.45	5 ft	5	REF		
6916	312.8 to 324.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	54	SF	\$40	\$2,160
48791	326.5 to 327.5 feet	Vertical Change	-.37	5 ft	5	REF		
6918	328.2 to 402.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	335	SF	\$120	\$40,230
50396	353.8 to 354.8 feet	Vertical Change	-.32	5 ft	5	REF		
47310	378.5 to 379.5 feet	Vertical Change	-.42	5 ft	5	REF		
6930	402.7 to 420.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	79	SF	\$120	\$9,450
6932	420.2 to 428.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	39	SF	\$120	\$4,644
58145	423.4 to 448.8 feet	Driveway				REF		
6934	431.6 to 446.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	68	SF	\$40	\$2,718
40257	445.8 to 446.8 feet	Running Slope	5.0-6.0%	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
W	1908221057	AUTUMN WAY	CANAL DR	HOWELL RD	TBD				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
56922	447.8 to 448.8 feet	Vertical Change	.52	5 ft	5	REF			
6936	450.3 to 461.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,264	
52112	456.8 to 457.8 feet	Vertical Change	-.29	5 ft	5	REF			
58146	458.2 to 483.3 feet	Driveway				REF			
52113	463.4 to 464.4 feet	Vertical Change	-.29	5 ft	5	REF			
6937	465.3 to 480.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	70	SF	\$40	\$2,808	
51683	482.6 to 483.6 feet	Vertical Change	-.3	5 ft	5	REF			
6939	485.0 to 497.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,966	
6940	500.2 to 532.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	146	SF	\$120	\$17,496	
46617	511.4 to 512.4 feet	Vertical Change	-.45	5 ft	5	REF			
58147	526.8 to 562.4 feet	Driveway				REF			
52565	532.2 to 533.2 feet	Vertical Change	-.28	5 ft	5	REF			
6941	536.1 to 560.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	109	SF	\$40	\$4,356	
42132	550.0 to 551.0 feet	Vertical Change	-.74	5 ft	5	REF			
48501	562.8 to 563.8 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$338	
6944	567.7 to 570.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,404	
6945	574.6 to 576.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$864	
47079	583.2 to 584.2 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$338	
49371	602.6 to 603.6 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$338	
6946	604.9 to 634.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	132	SF	\$120	\$15,876	
47311	622.8 to 623.8 feet	Vertical Change	-.42	5 ft	5	REF			
6948	638.2 to 657.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,368	
41984	643.2 to 644.2 feet	Vertical Change	-.78	5 ft	5	REF			
58148	652.0 to 681.4 feet	Driveway				REF			
6953	661.0 to 667.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	27	SF	\$40	\$1,080	
6955	667.0 to 671.9 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	22	SF	\$40	\$882	
6957	671.9 to 677.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	27	SF	\$40	\$1,080	
40258	677.6 to 679.1 feet	Running Slope	5.0-6.0%	5 ft	7	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221057	AUTUMN WAY	CANAL DR	HOWELL RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
6959	680.9 to 697.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	72	SF	\$40	\$2,898
47964	681.9 to 682.9 feet	Vertical Change	-.4	5 ft	5	REF		
58149	692.2 to 716.7 feet	Driveway				REF		
52566	698.2 to 699.2 feet	Vertical Change	-.28	5 ft	5	REF		
6963	699.6 to 715.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	69	SF	\$40	\$2,772
40259	714.3 to 715.4 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
48217	716.7 to 717.7 feet	Vertical Change	-.39	5 ft	5	REF		
6966	724.4 to 737.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,128
6968	737.6 to 745.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	36	SF	\$120	\$4,374
45247	741.8 to 742.8 feet	Vertical Change	-.51	5 ft	5	REF		
6970	745.7 to 750.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,484
TOTAL COST FOR: W side of AUTUMN WAY Starting at: CANAL DR							\$273,348.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908221103	AUTUMN WAY	HOWELL RD	HOLIDAY WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
6971	0.0 to 1.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$972	
6972	1.8 to 4.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,566	
6973	9.8 to 14.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,376	
42133	12.1 to 13.1 feet	Vertical Change	-.74	5 ft	5	REF			
6975	14.2 to 52.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	171	SF	\$120	\$20,574	
42476	27.8 to 28.8 feet	Vertical Change	-.69	5 ft	5	REF			
44238	47.4 to 48.4 feet	Vertical Change	-.56	5 ft	5	REF			
6981	52.3 to 59.2 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	31	SF	\$120	\$3,726	
58150	57.9 to 80.8 feet	Driveway				REF			
6982	59.2 to 62.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	16	SF	\$40	\$648	
6983	63.6 to 64.7 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	5	SF	\$40	\$198	
6984	65.4 to 76.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	50	SF	\$40	\$1,998	
6986	76.5 to 78.6 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	9	SF	\$40	\$378	
6987	81.3 to 88.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	32	SF	\$40	\$1,260	
58151	87.4 to 115.6 feet	Driveway				REF			
54004	92.1 to 93.1 feet	Vertical Change	-.25	5 ft	5	REF			
6990	95.3 to 113.1 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	80	SF	\$40	\$3,204	
6994	116.0 to 117.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$234	
49699	116.2 to 117.2 feet	Vertical Change	-.34	5 ft	5	REF			
50778	125.1 to 126.1 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$338	
51684	137.1 to 138.1 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$338	
6995	141.5 to 171.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	135	SF	\$120	\$16,254	
49080	157.0 to 158.0 feet	Vertical Change	-.36	5 ft	5	REF			
58152	166.4 to 208.1 feet	Driveway				REF			
6998	173.0 to 174.0 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$180	
6999	174.8 to 207.6 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	148	SF	\$40	\$5,904	
7006	207.6 to 213.1 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	25	SF	\$40	\$990	
49081	207.8 to 208.8 feet	Vertical Change	-.36	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221103	AUTUMN WAY	HOWELL RD	HOLIDAY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7008	213.1 to 236.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	107	SF	\$120	\$12,852
47080	218.1 to 219.1 feet	Vertical Change	-.43	5 ft	5	REF		
41938	235.9 to 236.9 feet	Vertical Change	-.79	5 ft	5	REF		
7011	236.9 to 243.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,510
58153	239.3 to 264.0 feet	Driveway				REF		
45041	244.6 to 245.6 feet	Vertical Change	-.52	5 ft	5	REF		
7012	247.1 to 261.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	66	SF	\$40	\$2,628
7014	265.0 to 292.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	125	SF	\$120	\$15,012
43877	275.1 to 276.1 feet	Vertical Change	-.58	5 ft	5	REF		
7016	292.8 to 296.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,214
7017	300.5 to 305.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,646
44668	301.4 to 302.4 feet	Vertical Change	-.54	5 ft	5	REF		
45743	306.5 to 307.5 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$338
7018	308.3 to 310.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
51685	311.7 to 312.7 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$338
42293	316.8 to 317.8 feet	Vertical Change	-.71	5 ft	5	SF	\$75	\$338
58154	319.0 to 344.0 feet	Driveway				REF		
42564	321.3 to 322.3 feet	Vertical Change	-.68	5 ft	5	REF		
7019	323.3 to 324.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$180
47965	325.4 to 326.4 feet	Vertical Change	-.4	5 ft	5	REF		
7020	327.8 to 337.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	42	SF	\$40	\$1,692
7022	337.2 to 341.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	18	SF	\$40	\$702
52567	343.3 to 344.3 feet	Vertical Change	-.28	5 ft	5	REF		
7024	344.0 to 360.9 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	76	SF	\$40	\$3,042
7028	360.9 to 387.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	119	SF	\$120	\$14,256
49082	367.7 to 368.7 feet	Vertical Change	-.36	5 ft	5	REF		
47560	387.1 to 388.1 feet	Vertical Change	-.41	5 ft	5	REF		
7031	387.3 to 396.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,806

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221103	AUTUMN WAY	HOWELL RD	HOLIDAY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58155	389.8 to 418.2 feet	Driveway				REF		
53074	395.9 to 396.9 feet	Vertical Change	-27	5 ft	5	REF		
7033	399.4 to 407.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	34	SF	\$40	\$1,368
7035	407.0 to 415.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	40	SF	\$40	\$1,584
46400	407.4 to 408.4 feet	Vertical Change	-46	5 ft	5	REF		
53614	412.9 to 413.9 feet	Vertical Change	-26	5 ft	5	REF		
51686	418.8 to 419.8 feet	Vertical Change	-3	5 ft	5	REF		
7036	419.1 to 425.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	28	SF	\$120	\$3,348
7039	425.3 to 467.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	192	SF	\$120	\$23,004
45951	439.1 to 440.1 feet	Vertical Change	-48	5 ft	5	REF		
50779	462.4 to 463.4 feet	Vertical Change	-31	5 ft	5	REF		
58156	463.8 to 487.6 feet	Driveway				REF		
7043	467.9 to 469.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$198
51687	468.0 to 469.0 feet	Vertical Change	-3	5 ft	5	REF		
7044	470.3 to 473.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	14	SF	\$40	\$540
7046	473.3 to 485.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	53	SF	\$40	\$2,106
54005	487.3 to 490.9 feet	Vertical Change	-25	5 ft	16	REF		
7049	488.8 to 511.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	101	SF	\$120	\$12,096
50780	502.1 to 503.1 feet	Vertical Change	-31	5 ft	5	REF		
48218	510.1 to 511.1 feet	Vertical Change	-39	5 ft	5	REF		
7051	511.2 to 526.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	69	SF	\$120	\$8,262
7053	526.5 to 538.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,318
51688	529.7 to 530.7 feet	Vertical Change	-3	5 ft	5	REF		
49700	537.4 to 538.4 feet	Vertical Change	-34	5 ft	5	REF		
58157	539.2 to 563.0 feet	Driveway				REF		
7054	543.1 to 544.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$180
50397	543.6 to 544.6 feet	Vertical Change	-32	5 ft	5	REF		
7055	546.9 to 553.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	31	SF	\$40	\$1,242

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1908221103	AUTUMN WAY	HOWELL RD	HOLIDAY WAY	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
7057	553.8 to 559.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	26	SF	\$40	\$1,026	
50398	561.9 to 562.9 feet	Vertical Change	-.32	5 ft	5	REF			
7060	562.3 to 621.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	267	SF	\$40	\$10,674	
52568	570.9 to 571.9 feet	Vertical Change	-.28	5 ft	5	REF			
45744	579.1 to 580.1 feet	Vertical Change	-.49	5 ft	5	REF			
46851	598.7 to 599.7 feet	Vertical Change	-.44	5 ft	5	REF			
49372	612.2 to 613.2 feet	Vertical Change	-.35	5 ft	5	REF			
58158	615.0 to 643.2 feet	Driveway				REF			
7069	625.3 to 642.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	76	SF	\$40	\$3,024	
40260	640.4 to 641.5 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
50781	643.8 to 644.8 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$338	
7071	645.6 to 801.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	701	SF	\$120	\$84,078	
45952	655.5 to 656.5 feet	Vertical Change	-.48	5 ft	5	REF			
42011	687.8 to 688.8 feet	Vertical Change	-.77	5 ft	5	REF			
47312	687.8 to 688.8 feet	Vertical Change	-.42	5 ft	5	REF			
49701	702.4 to 703.4 feet	Vertical Change	-.34	5 ft	5	REF			
44441	719.8 to 720.8 feet	Vertical Change	-.55	5 ft	5	REF			
45745	736.7 to 740.6 feet	Vertical Change	-.49	5 ft	18	REF			
42566	754.8 to 755.8 feet	Vertical Change	-.68	5 ft	5	REF			
43400	772.7 to 773.7 feet	Vertical Change	-.61	5 ft	5	REF			
41985	789.9 to 790.9 feet	Vertical Change	-.78	5 ft	5	REF			
7084	801.3 to 813.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	54	SF	\$120	\$6,426	
41939	807.6 to 808.6 feet	Vertical Change	-.79	5 ft	5	REF			
7086	813.2 to 817.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	18	SF	\$120	\$2,160	
58159	814.3 to 856.8 feet	Driveway				REF			
47966	817.4 to 818.4 feet	Vertical Change	-.4	5 ft	5	REF			
7087	820.7 to 833.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	56	SF	\$40	\$2,232	
7089	833.1 to 847.7 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	66	SF	\$40	\$2,628	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221103	AUTUMN WAY	HOWELL RD	HOLIDAY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7091	847.7 to 852.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	23	SF	\$40	\$900
50782	853.2 to 854.2 feet	Vertical Change	-.31	5 ft	5	REF		
7093	855.7 to 856.7 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$180
7094	856.7 to 864.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	33	SF	\$40	\$1,314
53615	868.0 to 869.0 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$338
7095	886.8 to 922.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	159	SF	\$120	\$19,062
43583	916.4 to 917.4 feet	Vertical Change	-.6	5 ft	5	REF		
7098	930.2 to 941.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$5,994
7100	941.3 to 958.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	77	SF	\$120	\$9,234
7102	959.4 to 966.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,942
48792	964.1 to 965.1 feet	Vertical Change	-.37	5 ft	5	REF		
TOTAL COST FOR: E side of AUTUMN WAY Starting at: HOWELL RD							\$340,564.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
W	1908221107	HOLIDAY WAY	CANAL DR	HOWELL RD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
7104	0.0 to 50.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	227	SF	\$120	\$27,216	
44865	2.4 to 3.4 feet	Vertical Change	-.53	5 ft	5	REF			
45042	15.5 to 16.5 feet	Vertical Change	-.52	5 ft	5	REF			
58160	47.2 to 71.9 feet	Driveway				REF			
47967	51.9 to 52.9 feet	Vertical Change	-.4	5 ft	5	REF			
7108	54.1 to 68.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	64	SF	\$40	\$2,556	
47968	69.7 to 70.7 feet	Vertical Change	-.4	5 ft	5	REF			
7110	71.8 to 84.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	56	SF	\$40	\$2,232	
48793	81.0 to 82.0 feet	Vertical Change	-.37	5 ft	5	REF			
7113	84.2 to 92.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,374	
7115	92.3 to 122.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	135	SF	\$120	\$16,146	
48502	98.0 to 99.0 feet	Vertical Change	-.38	5 ft	5	REF			
58161	117.3 to 145.2 feet	Driveway				REF			
7118	125.3 to 142.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	79	SF	\$40	\$3,150	
49373	145.6 to 146.6 feet	Vertical Change	-.35	5 ft	5	REF			
7123	146.3 to 147.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$864	
7124	147.9 to 192.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	200	SF	\$120	\$23,976	
45953	155.5 to 156.5 feet	Vertical Change	-.48	5 ft	5	REF			
58162	186.5 to 209.6 feet	Driveway				REF			
49374	192.2 to 193.2 feet	Vertical Change	-.35	5 ft	5	REF			
56640	192.2 to 193.2 feet	Vertical Change	.48	5 ft	5	REF			
7131	195.5 to 207.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	53	SF	\$40	\$2,124	
45954	210.4 to 211.5 feet	Vertical Change	-.48	5 ft	5	REF			
7135	211.6 to 234.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	105	SF	\$120	\$12,582	
47969	230.8 to 231.8 feet	Vertical Change	-.4	5 ft	5	REF			
7139	234.9 to 240.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	24	SF	\$120	\$2,916	
7141	240.3 to 245.1 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	22	SF	\$120	\$2,592	
58163	240.3 to 264.9 feet	Driveway				REF			
7142	248.7 to 259.2 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	47	SF	\$40	\$1,890	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
W	1908221107	HOLIDAY WAY	CANAL DR	HOWELL RD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
7144	259.2 to 262.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	16	SF	\$40	\$630	
47081	264.9 to 265.9 feet	Vertical Change	-.43	5 ft	5	REF			
7146	265.6 to 274.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	39	SF	\$120	\$4,698	
7148	274.3 to 300.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	117	SF	\$120	\$14,040	
43254	275.5 to 276.5 feet	Vertical Change	-.62	5 ft	5	REF			
41338	294.3 to 295.3 feet	Vertical Change	-1.42	5 ft	5	REF			
57450	294.4 to 295.4 feet	Vertical Change	1.38	5 ft	5	REF			
7150	300.3 to 342.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	190	SF	\$120	\$22,788	
42393	314.4 to 315.4 feet	Vertical Change	-.7	5 ft	5	REF			
44866	333.8 to 334.8 feet	Vertical Change	-.53	5 ft	5	REF			
7157	342.5 to 349.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,618	
49375	343.2 to 344.2 feet	Vertical Change	-.35	5 ft	5	REF			
58164	345.0 to 373.8 feet	Driveway				REF			
50783	348.6 to 349.6 feet	Vertical Change	-.31	5 ft	5	REF			
7159	352.5 to 358.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	28	SF	\$40	\$1,134	
7161	358.8 to 370.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	54	SF	\$40	\$2,142	
50029	373.9 to 374.9 feet	Vertical Change	-.33	5 ft	5	REF			
7163	373.9 to 374.9 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$180	
7164	374.9 to 396.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	99	SF	\$120	\$11,826	
58165	393.0 to 416.8 feet	Driveway				REF			
7167	400.8 to 414.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	63	SF	\$40	\$2,502	
52569	416.6 to 417.6 feet	Vertical Change	-.28	5 ft	5	REF			
7169	418.0 to 434.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	75	SF	\$120	\$9,018	
52570	420.2 to 421.2 feet	Vertical Change	-.28	5 ft	5	REF			
7171	434.7 to 471.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	165	SF	\$120	\$19,818	
47561	460.6 to 461.6 feet	Vertical Change	-.41	5 ft	5	REF			
7177	471.4 to 494.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	103	SF	\$120	\$12,366	
42677	473.5 to 474.5 feet	Vertical Change	-.67	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221107	HOLIDAY WAY	CANAL DR	HOWELL RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58166	486.5 to 510.8 feet	Driveway				REF		
45248	492.1 to 493.1 feet	Vertical Change	-51	5 ft	5	REF		
7181	495.0 to 507.8 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	58	SF	\$40	\$2,304
7185	509.2 to 520.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	50	SF	\$40	\$1,998
50784	510.2 to 511.2 feet	Vertical Change	-.31	5 ft	5	REF		
50785	515.6 to 516.6 feet	Vertical Change	-.31	5 ft	5	REF		
7189	520.3 to 562.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	191	SF	\$120	\$22,950
49084	530.6 to 531.6 feet	Vertical Change	-.36	5 ft	5	REF		
46853	541.6 to 542.6 feet	Vertical Change	-.44	5 ft	5	REF		
7192	562.8 to 574.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	53	SF	\$120	\$6,318
48503	563.1 to 564.1 feet	Vertical Change	-.38	5 ft	5	REF		
58167	568.8 to 594.4 feet	Driveway				REF		
7194	577.7 to 585.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	36	SF	\$40	\$1,458
7196	585.8 to 592.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	30	SF	\$40	\$1,206
7197	595.5 to 605.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	43	SF	\$120	\$5,184
48219	596.1 to 597.1 feet	Vertical Change	-.39	5 ft	5	REF		
7199	605.1 to 606.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$864
58168	616.5 to 639.3 feet	Driveway				REF		
46164	621.1 to 622.1 feet	Vertical Change	-.47	5 ft	5	REF		
7200	623.6 to 637.2 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	61	SF	\$40	\$2,448
46165	638.9 to 639.9 feet	Vertical Change	-.47	5 ft	5	REF		
7202	654.7 to 662.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,050
53616	655.9 to 656.9 feet	Vertical Change	-.26	5 ft	5	REF		
7203	668.3 to 682.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,614
58169	677.8 to 714.9 feet	Driveway				REF		
44669	680.3 to 683.1 feet	Vertical Change	-.54	5 ft	13	REF		
7205	686.4 to 711.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	114	SF	\$40	\$4,572
49085	695.6 to 696.6 feet	Vertical Change	-.36	5 ft	5	REF		
52571	714.4 to 715.4 feet	Vertical Change	-.28	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221107	HOLIDAY WAY	CANAL DR	HOWELL RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7208	715.3 to 756.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	184	SF	\$40	\$7,362
42047	725.4 to 726.4 feet	Vertical Change	-.76	5 ft	5	REF		
47313	745.7 to 746.7 feet	Vertical Change	-.42	5 ft	5	REF		
58170	752.8 to 792.0 feet	Driveway				REF		
43000	756.4 to 757.4 feet	Vertical Change	-.64	5 ft	5	REF		
7210	759.7 to 774.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	68	SF	\$40	\$2,736
7212	774.9 to 788.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	62	SF	\$40	\$2,466
52115	775.4 to 776.4 feet	Vertical Change	-.29	5 ft	5	REF		
49702	790.6 to 791.6 feet	Vertical Change	-.34	5 ft	5	REF		
55963	790.7 to 791.7 feet	Vertical Change	.35	5 ft	5	REF		
7215	792.2 to 812.9 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	93	SF	\$40	\$3,726
50786	808.0 to 809.0 feet	Vertical Change	-.31	5 ft	5	REF		
7218	812.9 to 841.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	130	SF	\$120	\$15,606
47970	828.5 to 829.5 feet	Vertical Change	-.4	5 ft	5	REF		
TOTAL COST FOR: W side of HOLIDAY WAY Starting at: CANAL DR							\$300,240.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1908221113	HOLIDAY WAY	HOWELL RD	CANAL DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
7222	0.0 to 24.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	112	SF	\$120	\$13,392	
47971	10.7 to 11.7 feet	Vertical Change	-.4	5 ft	5	REF			
56981	10.8 to 11.8 feet	Vertical Change	.58	5 ft	5	REF			
50399	22.7 to 23.7 feet	Vertical Change	-.32	5 ft	5	REF			
7226	24.8 to 38.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,182	
47314	32.6 to 33.6 feet	Vertical Change	-.42	5 ft	5	REF			
7229	44.8 to 48.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,052	
58171	46.3 to 71.3 feet	Driveway				REF			
46618	48.6 to 49.6 feet	Vertical Change	-.45	5 ft	5	REF			
7231	52.6 to 68.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	72	SF	\$40	\$2,880	
44867	71.1 to 72.1 feet	Vertical Change	-.53	5 ft	5	REF			
7234	72.8 to 95.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	101	SF	\$120	\$12,150	
58172	90.3 to 115.1 feet	Driveway				REF			
42678	95.5 to 96.5 feet	Vertical Change	-.67	5 ft	5	REF			
7237	98.8 to 105.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	28	SF	\$40	\$1,116	
7239	105.0 to 110.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	26	SF	\$40	\$1,026	
7241	110.7 to 113.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	11	SF	\$40	\$450	
42048	115.2 to 116.2 feet	Vertical Change	-.76	5 ft	5	REF			
7242	116.0 to 121.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	24	SF	\$120	\$2,862	
7244	121.3 to 136.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	69	SF	\$120	\$8,316	
42294	135.1 to 136.1 feet	Vertical Change	-.71	5 ft	5	REF			
7246	136.7 to 167.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	137	SF	\$120	\$16,416	
41510	155.5 to 156.5 feet	Vertical Change	-1.08	5 ft	5	REF			
7250	167.1 to 169.3 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	10	SF	\$120	\$1,188	
7251	169.3 to 187.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	83	SF	\$120	\$9,990	
44050	176.3 to 177.3 feet	Vertical Change	-.57	5 ft	5	REF			
49703	186.0 to 187.0 feet	Vertical Change	-.34	5 ft	5	REF			
7253	187.8 to 215.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	122	SF	\$120	\$14,688	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908221113	HOLIDAY WAY	HOWELL RD	CANAL DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
41800	196.1 to 197.1 feet	Vertical Change	-.84	5 ft	5	REF			
58173	211.4 to 235.4 feet	Driveway				REF			
50787	215.5 to 216.5 feet	Vertical Change	-.31	5 ft	5	REF			
7256	218.5 to 232.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	64	SF	\$40	\$2,556	
47562	235.4 to 236.4 feet	Vertical Change	-.41	5 ft	5	REF			
7257	235.5 to 260.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	111	SF	\$120	\$13,338	
49704	251.4 to 252.4 feet	Vertical Change	-.34	5 ft	5	REF			
7261	260.2 to 294.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	155	SF	\$120	\$18,576	
53075	271.4 to 272.4 feet	Vertical Change	-.27	5 ft	5	REF			
53617	294.0 to 295.0 feet	Vertical Change	-.26	5 ft	5	REF			
7266	294.6 to 301.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,888	
58174	301.3 to 327.4 feet	Driveway				REF			
7268	301.8 to 304.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	12	SF	\$40	\$486	
48794	306.1 to 307.1 feet	Vertical Change	-.37	5 ft	5	REF			
7269	308.7 to 323.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	66	SF	\$40	\$2,646	
46854	325.0 to 326.0 feet	Vertical Change	-.44	5 ft	5	REF			
7272	327.4 to 386.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	264	SF	\$40	\$10,548	
45746	331.3 to 332.3 feet	Vertical Change	-.49	5 ft	5	REF			
43720	359.8 to 360.8 feet	Vertical Change	-.59	5 ft	5	REF			
58175	381.8 to 404.8 feet	Driveway				REF			
7280	389.6 to 402.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	57	SF	\$40	\$2,286	
47082	404.4 to 405.4 feet	Vertical Change	-.43	5 ft	5	REF			
7282	405.2 to 425.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	91	SF	\$40	\$3,654	
58176	421.4 to 448.9 feet	Driveway				REF			
7284	428.8 to 446.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	81	SF	\$40	\$3,258	
54006	448.8 to 449.8 feet	Vertical Change	-.25	5 ft	5	REF			
7286	449.7 to 461.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	54	SF	\$120	\$6,534	
7288	461.8 to 463.3 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	7	SF	\$120	\$810	
7289	463.3 to 471.5 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	37	SF	\$120	\$4,428	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908221113	HOLIDAY WAY	HOWELL RD	CANAL DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
43001	470.1 to 471.1 feet	Vertical Change	-.64	5 ft	5	REF			
7291	471.5 to 482.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	47	SF	\$120	\$5,670	
7292	482.0 to 505.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	104	SF	\$120	\$12,420	
58177	500.0 to 528.8 feet	Driveway				REF			
7295	509.4 to 526.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	76	SF	\$40	\$3,042	
52116	527.9 to 528.9 feet	Vertical Change	-.29	5 ft	5	REF			
7298	529.2 to 581.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	237	SF	\$40	\$9,468	
53076	539.6 to 540.6 feet	Vertical Change	-.27	5 ft	5	REF			
50031	558.1 to 559.1 feet	Vertical Change	-.33	5 ft	5	REF			
48220	571.5 to 572.5 feet	Vertical Change	-.39	5 ft	5	REF			
58178	576.0 to 605.7 feet	Driveway				REF			
53077	581.4 to 582.4 feet	Vertical Change	-.27	5 ft	5	REF			
7307	584.5 to 603.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	83	SF	\$40	\$3,330	
52117	605.4 to 606.4 feet	Vertical Change	-.29	5 ft	5	REF			
7310	606.3 to 615.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	43	SF	\$40	\$1,710	
47563	614.9 to 615.9 feet	Vertical Change	-.41	5 ft	5	REF			
7314	615.8 to 656.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	184	SF	\$120	\$22,032	
49376	654.0 to 655.1 feet	Vertical Change	-.35	5 ft	5	REF			
7318	656.6 to 671.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,208	
7320	671.8 to 696.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	110	SF	\$120	\$13,176	
46855	674.1 to 675.1 feet	Vertical Change	-.44	5 ft	5	REF			
58179	691.5 to 715.6 feet	Driveway				REF			
7323	699.7 to 713.6 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	63	SF	\$40	\$2,502	
48795	706.3 to 707.3 feet	Vertical Change	-.37	5 ft	5	REF			
53618	716.4 to 717.4 feet	Vertical Change	-.26	5 ft	5	REF			
7326	717.0 to 735.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	84	SF	\$120	\$10,098	
58180	729.8 to 757.4 feet	Driveway				REF			
7330	739.2 to 755.0 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	71	SF	\$40	\$2,844	
51689	757.1 to 758.1 feet	Vertical Change	-.3	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221113	HOLIDAY WAY	HOWELL RD	CANAL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55942	757.2 to 758.2 feet	Vertical Change	.3	5 ft	5	REF		
7333	758.2 to 821.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	284	SF	\$120	\$34,020
43255	772.0 to 773.0 feet	Vertical Change	-.62	5 ft	5	REF		
44670	791.0 to 792.0 feet	Vertical Change	-.54	5 ft	5	REF		
48221	810.3 to 811.3 feet	Vertical Change	-.39	5 ft	5	REF		
58181	813.9 to 840.5 feet	Driveway				REF		
48504	819.9 to 820.9 feet	Vertical Change	-.38	5 ft	5	REF		
7339	824.2 to 837.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	59	SF	\$40	\$2,376
7343	839.4 to 843.1 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	17	SF	\$40	\$666
7345	843.1 to 844.1 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	5	SF	\$120	\$540
7346	845.2 to 879.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	153	SF	\$120	\$18,414
52572	847.8 to 848.8 feet	Vertical Change	-.28	5 ft	5	REF		
7352	879.3 to 881.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$918
TOTAL COST FOR: E side of HOLIDAY WAY Starting at: HOWELL RD							\$318,150.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority	
S	1908221114	CANAL DR	HOLIDAY WAY	144 GILL WAY				TBD	
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
7353	0.1 to 34.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	153	SF	\$120	\$18,414	
41765	4.1 to 5.1 feet	Vertical Change	-.86	5 ft	5	REF			
45527	22.4 to 23.4 feet	Vertical Change	-.5	5 ft	5	REF			
7355	34.2 to 44.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	45	SF	\$120	\$5,454	
7357	44.3 to 58.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	64	SF	\$120	\$7,668	
47972	46.8 to 47.8 feet	Vertical Change	-.4	5 ft	5	REF			
58182	54.5 to 73.3 feet	Driveway				REF			
7359	61.6 to 69.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	36	SF	\$40	\$1,422	
40261	68.8 to 70.1 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
7360	73.3 to 84.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	50	SF	\$40	\$1,980	
7361	88.7 to 95.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,726	
7363	95.6 to 103.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	34	SF	\$120	\$4,050	
TOTAL COST FOR: S							<i>side of</i> CANAL DR	<i>Starting at:</i> HOLIDAY WAY	\$42,714.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221116	CANAL DR	144 GILL WAY	GILL WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7364	0.0 to 31.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	109	SF	\$120	\$13,104
50032	38.6 to 39.6 feet	Vertical Change	-.33	4 ft	4	LF	\$75	\$263
TOTAL COST FOR: S side of CANAL DR Starting at: 144 GILL WAY							\$13,366.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908221121	GILL WAY	CANAL DR	HOWELL RD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
51690	8.2 to 9.2 feet	Vertical Change	-.3	4 ft	4	LF	\$75	\$300	
7365	11.4 to 18.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	30	SF	\$120	\$3,552	
50033	19.1 to 20.1 feet	Vertical Change	-.33	4 ft	4	LF	\$75	\$300	
50400	29.5 to 30.5 feet	Vertical Change	-.32	4 ft	4	LF	\$75	\$300	
44442	96.9 to 97.9 feet	Vertical Change	-.55	4 ft	4	SF	\$75	\$300	
42775	111.6 to 112.6 feet	Vertical Change	-.66	4 ft	4	SF	\$75	\$300	
42679	126.3 to 127.3 feet	Vertical Change	-.67	4 ft	4	SF	\$75	\$300	
58183	136.6 to 161.2 feet	Driveway				REF			
46401	141.4 to 142.4 feet	Vertical Change	-.46	4 ft	4	REF			
7366	149.6 to 155.9 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	25	SF	\$40	\$1,008	
42477	167.6 to 168.6 feet	Vertical Change	-.69	4 ft	4	REF			
7367	168.2 to 170.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	8	SF	\$120	\$1,008	
46619	179.2 to 180.2 feet	Vertical Change	-.45	4 ft	4	LF	\$75	\$300	
44239	191.4 to 192.4 feet	Vertical Change	-.56	4 ft	4	SF	\$75	\$300	
42680	206.5 to 207.5 feet	Vertical Change	-.67	4 ft	4	SF	\$75	\$300	
58184	215.6 to 240.9 feet	Driveway				REF			
44240	234.1 to 235.1 feet	Vertical Change	-.56	4 ft	4	REF			
42478	272.9 to 273.9 feet	Vertical Change	-.69	4 ft	4	SF	\$75	\$300	
42567	286.0 to 287.0 feet	Vertical Change	-.68	4 ft	4	SF	\$75	\$300	
58185	296.8 to 345.9 feet	Driveway				REF			
43878	313.6 to 314.6 feet	Vertical Change	-.58	4 ft	4	REF			
44671	326.5 to 327.5 feet	Vertical Change	-.54	4 ft	4	REF			
43721	332.2 to 333.2 feet	Vertical Change	-.59	4 ft	4	REF			
44672	342.2 to 343.2 feet	Vertical Change	-.54	4 ft	4	REF			
48796	351.6 to 352.6 feet	Vertical Change	-.37	4 ft	4	LF	\$75	\$300	
42568	364.2 to 365.2 feet	Vertical Change	-.68	4 ft	4	SF	\$75	\$300	
45528	376.4 to 377.4 feet	Vertical Change	-.5	4 ft	4	SF	\$75	\$300	
42569	388.6 to 389.6 feet	Vertical Change	-.68	4 ft	4	SF	\$75	\$300	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221121	GILL WAY	CANAL DR	HOWELL RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46402	403.7 to 404.7 feet	Vertical Change	-.46	4 ft	4	LF	\$75	\$300
42776	419.0 to 420.0 feet	Vertical Change	-.66	4 ft	4	SF	\$75	\$300
42570	434.0 to 435.0 feet	Vertical Change	-.68	4 ft	4	SF	\$75	\$300
47973	449.1 to 450.1 feet	Vertical Change	-.4	4 ft	4	LF	\$75	\$300
58186	459.1 to 480.6 feet	Driveway				REF		
45955	464.0 to 465.0 feet	Vertical Change	-.48	4 ft	4	REF		
44241	475.3 to 476.3 feet	Vertical Change	-.56	4 ft	4	REF		
43401	486.3 to 487.3 feet	Vertical Change	-.61	4 ft	4	SF	\$75	\$300
58187	490.8 to 512.7 feet	Driveway				REF		
42571	506.1 to 507.1 feet	Vertical Change	-.68	4 ft	4	REF		
7368	509.2 to 520.3 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	44	SF	\$40	\$1,776
42894	515.8 to 516.8 feet	Vertical Change	-.65	4 ft	4	REF		
46856	529.9 to 530.9 feet	Vertical Change	-.44	4 ft	4	LF	\$75	\$300
44673	544.2 to 545.2 feet	Vertical Change	-.54	4 ft	4	SF	\$75	\$300
50401	559.2 to 560.2 feet	Vertical Change	-.32	4 ft	4	LF	\$75	\$300
7369	571.4 to 575.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	15	SF	\$120	\$1,824
53619	574.4 to 575.4 feet	Vertical Change	-.26	4 ft	4	REF		
7370	601.4 to 605.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,920
53620	603.8 to 604.8 feet	Vertical Change	-.26	4 ft	4	REF		
58188	616.1 to 677.3 feet	Driveway				REF		
43879	628.3 to 629.3 feet	Vertical Change	-.58	4 ft	4	REF		
7371	628.3 to 633.7 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	22	SF	\$40	\$864
7372	641.7 to 647.0 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	21	SF	\$40	\$848
49705	664.0 to 665.0 feet	Vertical Change	-.34	4 ft	4	REF		
7373	671.7 to 688.4 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	67	SF	\$40	\$2,672
48505	696.2 to 697.2 feet	Vertical Change	-.38	4 ft	4	LF	\$75	\$300
50788	711.2 to 712.2 feet	Vertical Change	-.31	4 ft	4	LF	\$75	\$300
7376	716.1 to 720.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	19	SF	\$120	\$2,304
58189	721.4 to 737.2 feet	Driveway				REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908221121	GILL WAY	CANAL DR	HOWELL RD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
45956	726.2 to 727.2 feet	Vertical Change	-.48	4 ft	4	REF			
7377	733.2 to 744.2 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	44	SF	\$40	\$1,760	
45957	733.7 to 734.7 feet	Vertical Change	-.48	4 ft	4	REF			
42681	741.7 to 742.7 feet	Vertical Change	-.67	4 ft	4	REF			
52573	755.9 to 756.9 feet	Vertical Change	-.28	4 ft	4	LF	\$75	\$300	
7378	763.3 to 765.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	9	SF	\$120	\$1,056	
50402	770.6 to 771.6 feet	Vertical Change	-.32	4 ft	4	LF	\$75	\$300	
49377	785.2 to 786.2 feet	Vertical Change	-.35	4 ft	4	LF	\$75	\$300	
49378	800.2 to 801.2 feet	Vertical Change	-.35	4 ft	4	LF	\$75	\$300	
45747	804.9 to 805.9 feet	Vertical Change	-.49	4 ft	4	LF	\$75	\$300	
56641	804.9 to 805.9 feet	Vertical Change	.48	4 ft	4	LF	\$75	\$300	
53621	815.3 to 816.3 feet	Vertical Change	-.26	4 ft	4	LF	\$75	\$300	
7379	819.3 to 829.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	40	SF	\$120	\$4,752	
7380	841.7 to 843.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	6	SF	\$120	\$768	
48506	845.4 to 846.4 feet	Vertical Change	-.38	4 ft	4	LF	\$75	\$300	
58190	855.1 to 876.3 feet	Driveway				REF			
47974	860.3 to 861.3 feet	Vertical Change	-.4	4 ft	4	REF			
46166	871.6 to 872.6 feet	Vertical Change	-.47	4 ft	4	REF			
7381	878.0 to 881.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	15	SF	\$120	\$1,776	
7383	881.7 to 892.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	44	SF	\$120	\$5,280	
7386	892.7 to 895.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	10	SF	\$120	\$1,152	
49706	912.1 to 913.1 feet	Vertical Change	-.34	4 ft	4	LF	\$75	\$300	
7387	914.4 to 915.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	6	SF	\$120	\$672	
7388	936.3 to 970.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	137	SF	\$120	\$16,464	
58191	939.6 to 963.3 feet	Driveway				REF			
49379	954.4 to 955.4 feet	Vertical Change	-.35	4 ft	4	REF			
47315	966.9 to 967.9 feet	Vertical Change	-.42	4 ft	4	REF			
43584	971.4 to 972.4 feet	Vertical Change	-.6	4 ft	4	SF	\$75	\$300	
TOTAL COST FOR: W side of GILL WAY Starting at: CANAL DR								\$61,956.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221126	GILL WAY	HOWELL RD	CHARLENE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7393	0.0 to 3.9 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	16	SF	\$120	\$1,872
7394	3.9 to 6.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	11	SF	\$120	\$1,296
45529	13.3 to 14.3 feet	Vertical Change	-5	4 ft	4	SF	\$75	\$300
44674	19.2 to 20.2 feet	Vertical Change	-.54	4 ft	4	SF	\$75	\$300
7395	35.3 to 38.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	13	SF	\$120	\$1,584
7396	40.8 to 54.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	56	SF	\$120	\$6,720
46857	46.1 to 47.1 feet	Vertical Change	-.44	4 ft	4	REF		
48797	66.3 to 67.3 feet	Vertical Change	-.37	4 ft	4	REF		
7397	66.7 to 76.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	39	SF	\$120	\$4,704
58192	88.5 to 116.2 feet	Driveway				REF		
7398	88.7 to 96.0 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	29	SF	\$40	\$1,168
7400	96.0 to 126.1 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	120	SF	\$40	\$4,816
44443	105.4 to 106.4 feet	Vertical Change	-.55	4 ft	4	REF		
7404	126.1 to 135.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	39	SF	\$120	\$4,656
50034	135.1 to 136.1 feet	Vertical Change	-.33	4 ft	4	REF		
7405	141.8 to 148.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	28	SF	\$120	\$3,408
46858	148.0 to 149.0 feet	Vertical Change	-.44	4 ft	4	REF		
7407	148.9 to 161.9 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	52	SF	\$120	\$6,240
7409	161.9 to 184.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	91	SF	\$120	\$10,896
44051	164.0 to 165.0 feet	Vertical Change	-.57	4 ft	4	REF		

TOTAL COST FOR:	E	<i>side of</i>	GILL WAY	<i>Starting at:</i>	HOWELL RD	\$47,960.00
------------------------	----------	----------------	-----------------	---------------------	------------------	--------------------

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221129	CHARLENE DR	GILL WAY	DOROTHY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7411	0.0 to 26.3 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	171	SF	\$120	\$20,514
50789	5.5 to 6.5 feet	Vertical Change	-.31	7 ft	7	REF		
7413	26.3 to 50.8 feet	Cross Slope (PAR)	4.0-5.0%	7 ft	159	SF	\$120	\$19,110
50035	31.7 to 32.7 feet	Vertical Change	-.33	7 ft	7	REF		
47316	46.7 to 47.7 feet	Vertical Change	-.42	7 ft	7	REF		
7416	50.8 to 54.0 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	21	SF	\$120	\$2,496
58193	56.7 to 73.2 feet	Driveway				REF		
41648	60.1 to 61.1 feet	Vertical Change	-.93	7 ft	7	REF		
45748	66.7 to 67.7 feet	Vertical Change	-.49	7 ft	7	REF		
7417	67.1 to 76.0 feet	Cross Slope (Driveway)	2.0-3.0%	7 ft	58	SF	\$40	\$2,314
7418	78.5 to 79.8 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	8	SF	\$120	\$1,014
7419	87.2 to 96.4 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	60	SF	\$120	\$7,176
7420	106.7 to 115.5 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	57	SF	\$120	\$6,864
58194	118.9 to 145.9 feet	Driveway				REF		
52118	119.8 to 120.8 feet	Vertical Change	-.29	7 ft	7	REF		
7421	124.8 to 133.7 feet	Cross Slope (Driveway)	2.0-3.0%	7 ft	58	SF	\$40	\$2,314
7422	139.6 to 146.9 feet	Cross Slope (Driveway)	2.0-3.0%	7 ft	47	SF	\$40	\$1,898
7424	146.9 to 152.7 feet	Cross Slope (PAR)	4.0-5.0%	7 ft	38	SF	\$120	\$4,524
7426	152.7 to 154.6 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	12	SF	\$120	\$1,482
52119	155.2 to 156.2 feet	Vertical Change	-.29	7 ft	7	LF	\$75	\$488
50403	160.0 to 161.0 feet	Vertical Change	-.32	7 ft	7	LF	\$75	\$488
53078	190.2 to 191.2 feet	Vertical Change	-.27	7 ft	7	LF	\$75	\$488
7427	207.3 to 210.9 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	23	SF	\$120	\$2,808
58195	242.6 to 281.2 feet	Driveway				REF		
43125	300.4 to 301.4 feet	Vertical Change	-.63	7 ft	7	SF	\$75	\$488
44444	320.3 to 321.3 feet	Vertical Change	-.55	7 ft	7	SF	\$75	\$488
43402	335.3 to 336.3 feet	Vertical Change	-.61	7 ft	7	SF	\$75	\$488
58196	340.1 to 360.7 feet	Driveway				REF		
44052	343.2 to 344.2 feet	Vertical Change	-.57	7 ft	7	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221129	CHARLENE DR	GILL WAY	DOROTHY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
43403	356.2 to 357.2 feet	Vertical Change	-.61	7 ft	7	REF		
58197	363.1 to 375.1 feet	Driveway				REF		
45749	364.8 to 365.8 feet	Vertical Change	-.49	7 ft	7	REF		
52574	372.1 to 373.1 feet	Vertical Change	-.28	7 ft	7	REF		
41502	381.2 to 382.2 feet	Vertical Change	-1.09	7 ft	7	SF	\$75	\$488
7428	387.7 to 393.0 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	34	SF	\$120	\$4,134
42777	390.3 to 391.3 feet	Vertical Change	-.66	7 ft	7	REF		
47317	401.2 to 402.2 feet	Vertical Change	-.42	7 ft	7	LF	\$75	\$488
42572	416.0 to 417.0 feet	Vertical Change	-.68	7 ft	7	SF	\$75	\$488
TOTAL COST FOR: S side of CHARLENE DR Starting at: GILL WAY							\$81,035.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221131	CHARLENE DR	DOROTHY WAY	DEBORAH WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7429	3.1 to 7.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340
44445	6.5 to 7.5 feet	Vertical Change	-.55	5 ft	5	REF		
7431	16.4 to 21.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,240
45958	17.5 to 18.5 feet	Vertical Change	-.48	5 ft	5	REF		
47565	28.3 to 29.3 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375
7432	37.6 to 40.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,920
45959	42.5 to 43.5 feet	Vertical Change	-.48	5 ft	5	LF	\$75	\$375
7433	44.5 to 54.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,060
58198	65.2 to 80.9 feet	Driveway				REF		
53079	71.5 to 72.5 feet	Vertical Change	-.27	5 ft	5	REF		
7434	72.2 to 74.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	13	SF	\$40	\$520
45249	85.9 to 86.9 feet	Vertical Change	-.51	5 ft	5	SF	\$75	\$375
7435	87.3 to 88.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
58199	108.8 to 128.6 feet	Driveway				REF		
45530	113.3 to 114.3 feet	Vertical Change	-.5	5 ft	5	REF		
7436	113.7 to 119.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	31	SF	\$40	\$1,240
7437	129.5 to 131.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440
47083	144.4 to 145.4 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375
7438	177.2 to 194.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	89	SF	\$120	\$10,620
TOTAL COST FOR: N side of CHARLENE DR Starting at: DOROTHY WAY							\$29,480.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
N	1908221133	CHARLENE DR	DEBORAH WAY	GILL WAY				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7440	0.0 to 32.8 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	213	SF	\$120	\$25,584
58200	23.5 to 84.4 feet	Driveway				REF		
7444	32.8 to 54.6 feet	Cross Slope (Driveway)	4.0-5.0%	7 ft	142	SF	\$40	\$5,668
7446	54.6 to 101.7 feet	Cross Slope (Driveway)	2.0-3.0%	7 ft	306	SF	\$40	\$12,246
46620	55.5 to 56.5 feet	Vertical Change	-.45	7 ft	7	REF		
53080	70.5 to 71.5 feet	Vertical Change	-.27	7 ft	7	REF		
53622	78.5 to 79.5 feet	Vertical Change	-.26	7 ft	7	REF		
47566	90.4 to 91.4 feet	Vertical Change	-.41	7 ft	7	REF		
43256	100.1 to 101.1 feet	Vertical Change	-.62	7 ft	7	REF		
7450	101.7 to 149.7 feet	Cross Slope (PAR)	4.0-5.0%	7 ft	312	SF	\$120	\$37,440
42778	110.9 to 111.9 feet	Vertical Change	-.66	7 ft	7	REF		
42779	125.5 to 126.5 feet	Vertical Change	-.66	7 ft	7	REF		
46403	142.7 to 143.7 feet	Vertical Change	-.46	7 ft	7	REF		
7457	149.7 to 152.1 feet	Cross Slope (PAR)	2.0-3.0%	7 ft	16	SF	\$120	\$1,872
46404	154.7 to 155.7 feet	Vertical Change	-.46	7 ft	7	LF	\$75	\$488
44242	169.3 to 170.3 feet	Vertical Change	-.56	7 ft	7	SF	\$75	\$488
52120	183.6 to 184.6 feet	Vertical Change	-.29	7 ft	7	LF	\$75	\$488
TOTAL COST FOR: N							side of CHARLENE DR Starting at: DEBORAH WAY	\$84,272.50

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221139	GILL WAY	CHARLENE DR	CANAL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58201	24.0 to 70.9 feet	Driveway				REF		
42479	25.6 to 26.6 feet	Vertical Change	-69	4 ft	4	REF		
7458	32.2 to 35.9 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	15	SF	\$40	\$592
7460	35.9 to 37.5 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	6	SF	\$40	\$256
7461	38.4 to 53.2 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	59	SF	\$40	\$2,368
48798	39.0 to 40.0 feet	Vertical Change	-37	4 ft	4	REF		
7463	53.2 to 67.1 feet	Cross Slope (Driveway)	8.0-9.0%	4 ft	56	SF	\$40	\$2,224
43257	55.2 to 56.2 feet	Vertical Change	-62	4 ft	4	REF		
7467	67.1 to 72.8 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	23	SF	\$40	\$912
7468	72.8 to 74.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	6	SF	\$120	\$720
7469	76.1 to 77.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$576
42573	86.8 to 87.8 feet	Vertical Change	-68	4 ft	4	SF	\$75	\$300
42480	101.5 to 102.5 feet	Vertical Change	-69	4 ft	4	SF	\$75	\$300
42574	116.3 to 117.3 feet	Vertical Change	-68	4 ft	4	SF	\$75	\$300
7470	122.9 to 127.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	18	SF	\$120	\$2,112
58202	126.4 to 142.7 feet	Driveway				REF		
7472	127.3 to 128.3 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	4	SF	\$40	\$160
7473	129.2 to 152.4 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	93	SF	\$40	\$3,712
49086	146.1 to 147.1 feet	Vertical Change	-36	4 ft	4	REF		
58203	150.8 to 171.5 feet	Driveway				REF		
7477	152.4 to 155.3 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	12	SF	\$40	\$464
49707	153.4 to 154.4 feet	Vertical Change	-34	4 ft	4	REF		
7478	155.3 to 168.1 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	51	SF	\$40	\$2,048
47567	165.1 to 166.1 feet	Vertical Change	-41	4 ft	4	REF		
7481	168.1 to 171.4 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	13	SF	\$40	\$528
7482	171.4 to 180.3 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	36	SF	\$40	\$1,424
7485	180.3 to 183.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	12	SF	\$120	\$1,440
7487	183.3 to 186.8 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	14	SF	\$120	\$1,680

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221139	GILL WAY	CHARLENE DR	CANAL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7488	187.7 to 192.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	18	SF	\$120	\$2,208
47084	196.1 to 197.1 feet	Vertical Change	-43	4 ft	4	LF	\$75	\$300
7489	197.7 to 198.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$576
43258	200.5 to 201.5 feet	Vertical Change	-62	4 ft	4	SF	\$75	\$300
45531	210.4 to 211.4 feet	Vertical Change	-5	4 ft	4	SF	\$75	\$300
45043	225.2 to 226.2 feet	Vertical Change	-52	4 ft	4	SF	\$75	\$300
46621	240.1 to 241.1 feet	Vertical Change	-45	4 ft	4	LF	\$75	\$300
43722	257.2 to 261.1 feet	Vertical Change	-59	4 ft	16	SF	\$75	\$1,170
7490	264.7 to 268.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,920
45751	269.6 to 270.6 feet	Vertical Change	-49	4 ft	4	LF	\$75	\$300
7491	277.3 to 281.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,872
58204	280.5 to 301.3 feet	Driveway				REF		
7493	281.2 to 283.7 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	10	SF	\$40	\$400
7495	283.7 to 298.5 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	59	SF	\$40	\$2,368
45044	284.2 to 285.2 feet	Vertical Change	-52	4 ft	4	REF		
44675	295.2 to 296.2 feet	Vertical Change	-54	4 ft	4	REF		
7497	298.5 to 307.2 feet	Cross Slope (Driveway)	8.0-9.0%	4 ft	35	SF	\$40	\$1,392
44053	306.1 to 307.1 feet	Vertical Change	-57	4 ft	4	REF		
7499	307.2 to 309.4 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	9	SF	\$120	\$1,056
7500	309.4 to 310.4 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	4	SF	\$120	\$480
58205	309.6 to 333.9 feet	Driveway				REF		
7501	310.4 to 340.7 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	121	SF	\$40	\$4,848
42295	314.5 to 315.5 feet	Vertical Change	-71	4 ft	4	REF		
43585	326.7 to 327.7 feet	Vertical Change	-6	4 ft	4	REF		
42780	338.4 to 339.4 feet	Vertical Change	-66	4 ft	4	REF		
7506	340.7 to 344.2 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	14	SF	\$120	\$1,680
7508	344.2 to 345.6 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	6	SF	\$120	\$672
7509	345.6 to 347.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	6	SF	\$120	\$768

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221139	GILL WAY	CHARLENE DR	CANAL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
43002	350.8 to 351.8 feet	Vertical Change	-.64	4 ft	4	SF	\$75	\$300
46405	365.0 to 366.0 feet	Vertical Change	-.46	4 ft	4	LF	\$75	\$300
7510	379.5 to 380.6 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	4	SF	\$120	\$528
46167	380.1 to 381.1 feet	Vertical Change	-.47	4 ft	4	REF		
7511	380.6 to 383.3 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	11	SF	\$120	\$1,296
35	383.0 to 384.0 feet	Continuous Width		4 ft	4	SF	\$120	\$480
7513	385.7 to 387.0 feet	Cross Slope (PAR)	11.0-12.0%	4 ft	5	SF	\$120	\$624
7514	390.3 to 391.8 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	6	SF	\$120	\$720
7515	391.8 to 395.7 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	16	SF	\$120	\$1,872
53081	394.8 to 395.8 feet	Vertical Change	-.27	4 ft	4	REF		
7517	395.7 to 397.9 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	9	SF	\$120	\$1,056
7518	397.9 to 401.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	13	SF	\$120	\$1,536
46168	409.7 to 410.7 feet	Vertical Change	-.47	4 ft	4	LF	\$75	\$300
48222	424.6 to 425.6 feet	Vertical Change	-.39	4 ft	4	LF	\$75	\$300
7519	428.1 to 433.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	21	SF	\$120	\$2,496
7521	433.3 to 434.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	6	SF	\$120	\$672
36	435.3 to 436.3 feet	Continuous Width		4 ft	4	SF	\$120	\$480
58206	435.8 to 456.9 feet	Driveway				REF		
7522	436.5 to 438.7 feet	Cross Slope (Driveway)	7.0-8.0%	4 ft	9	SF	\$40	\$352
7524	438.7 to 454.4 feet	Cross Slope (Driveway)	9.0-10.0%	4 ft	63	SF	\$40	\$2,512
43404	451.2 to 452.2 feet	Vertical Change	-.61	4 ft	4	REF		
7526	454.4 to 458.0 feet	Cross Slope (Driveway)	7.0-8.0%	4 ft	14	SF	\$40	\$576
7528	458.0 to 459.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	5	SF	\$120	\$624
7529	459.3 to 464.8 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	22	SF	\$120	\$2,640
47975	461.2 to 462.2 feet	Vertical Change	-.4	4 ft	4	REF		
7530	464.8 to 468.1 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	13	SF	\$120	\$1,584
7532	468.1 to 470.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	9	SF	\$120	\$1,056
7533	470.3 to 480.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	42	SF	\$120	\$5,040

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221139	GILL WAY	CHARLENE DR	CANAL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7534	488.8 to 490.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	6	SF	\$120	\$672
44054	493.5 to 494.5 feet	Vertical Change	-.57	4 ft	4	REF		
7535	493.5 to 495.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	8	SF	\$120	\$960
7536	500.0 to 506.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	24	SF	\$120	\$2,928
58207	503.0 to 532.3 feet	Driveway				REF		
7538	506.1 to 509.6 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	14	SF	\$40	\$560
43880	507.9 to 508.9 feet	Vertical Change	-.58	4 ft	4	REF		
7540	509.6 to 528.9 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	77	SF	\$40	\$3,088
7542	528.9 to 538.6 feet	Cross Slope (Driveway)	8.0-9.0%	4 ft	39	SF	\$40	\$1,552
7544	538.6 to 540.1 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	6	SF	\$120	\$720
7545	540.1 to 543.7 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	14	SF	\$120	\$1,728
7547	543.7 to 545.2 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	6	SF	\$120	\$720
7548	545.2 to 547.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	10	SF	\$120	\$1,248
47976	551.5 to 552.5 feet	Vertical Change	-.4	4 ft	4	LF	\$75	\$300
7549	552.7 to 561.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	37	SF	\$120	\$4,416
7550	567.0 to 570.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	13	SF	\$120	\$1,536
7551	580.7 to 584.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	15	SF	\$120	\$1,824
7553	584.5 to 589.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	19	SF	\$120	\$2,304
58208	588.8 to 610.2 feet	Driveway				REF		
7555	589.3 to 614.0 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	99	SF	\$40	\$3,952
46622	604.2 to 605.2 feet	Vertical Change	-.45	4 ft	4	REF		
7559	614.0 to 619.7 feet	Cross Slope (PAR)	8.0-9.0%	4 ft	23	SF	\$120	\$2,736
43723	616.0 to 617.0 feet	Vertical Change	-.59	4 ft	4	REF		
7561	619.7 to 621.5 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	7	SF	\$120	\$864
7562	621.5 to 626.7 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	21	SF	\$120	\$2,496
7564	626.7 to 629.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	10	SF	\$120	\$1,248
47085	628.3 to 629.3 feet	Vertical Change	-.43	4 ft	4	REF		
7565	629.3 to 631.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	10	SF	\$120	\$1,200

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221139	GILL WAY	CHARLENE DR	CANAL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7566	647.3 to 661.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	57	SF	\$120	\$6,816
45532	656.2 to 657.2 feet	Vertical Change	-5	4 ft	4	REF		
7568	661.5 to 674.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	53	SF	\$120	\$6,336
58209	666.6 to 690.1 feet	Driveway				REF		
7570	674.7 to 676.1 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	6	SF	\$40	\$224
7571	676.1 to 704.1 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	112	SF	\$40	\$4,480
43881	681.5 to 682.5 feet	Vertical Change	-58	4 ft	4	REF		
37	688.1 to 689.1 feet	Continuous Width		4 ft	4	SF	\$120	\$480
7574	704.1 to 708.2 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	16	SF	\$120	\$1,968
7575	708.2 to 712.0 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	15	SF	\$120	\$1,824
47318	708.3 to 709.3 feet	Vertical Change	-42	4 ft	4	REF		
7576	712.0 to 714.0 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	8	SF	\$120	\$960
7577	714.0 to 716.8 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	11	SF	\$120	\$1,344
7578	716.8 to 732.1 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	61	SF	\$120	\$7,344
58210	718.6 to 734.2 feet	Driveway				REF		
7579	732.1 to 735.2 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	12	SF	\$40	\$496
43126	732.7 to 733.7 feet	Vertical Change	-63	4 ft	4	REF		
7580	735.2 to 740.3 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	20	SF	\$120	\$2,448
7581	740.3 to 743.5 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	13	SF	\$120	\$1,536
7583	743.5 to 745.2 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	7	SF	\$120	\$816
49380	743.7 to 744.7 feet	Vertical Change	-35	4 ft	4	REF		
7584	745.2 to 747.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	11	SF	\$120	\$1,296
TOTAL COST FOR: E side of GILL WAY Starting at: CHARLENE DR							\$148,090.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221141	CANAL DR	GILL WAY	DEBORAH WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7585	4.3 to 28.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	84	SF	\$120	\$10,122
7586	30.9 to 126.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	335	SF	\$120	\$40,236
49087	42.3 to 43.3 feet	Vertical Change	-36	4 ft	4	REF		
44676	62.3 to 63.3 feet	Vertical Change	-.54	4 ft	4	REF		
48799	105.0 to 106.0 feet	Vertical Change	-.37	4 ft	4	REF		
52121	131.5 to 132.5 feet	Vertical Change	-.29	4 ft	4	LF	\$75	\$263
48507	168.5 to 169.5 feet	Vertical Change	-.38	4 ft	4	LF	\$75	\$263
7595	169.7 to 187.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	61	SF	\$120	\$7,266
53623	178.3 to 179.3 feet	Vertical Change	-.26	4 ft	4	REF		
48508	181.6 to 182.6 feet	Vertical Change	-.38	4 ft	4	REF		
48223	185.4 to 186.4 feet	Vertical Change	-.39	4 ft	4	REF		
47319	197.2 to 198.2 feet	Vertical Change	-.42	4 ft	4	LF	\$75	\$263
TOTAL COST FOR: S side of CANAL DR Starting at: GILL WAY							\$58,411.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908221144	DEBORAH WAY	CANAL DR	CHARLENE DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
7596	0.0 to 8.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	36	SF	\$120	\$4,272	
44677	9.8 to 10.8 feet	Vertical Change	-.54	4 ft	4	SF	\$75	\$300	
43882	23.2 to 24.2 feet	Vertical Change	-.58	4 ft	4	SF	\$75	\$300	
44055	38.2 to 39.2 feet	Vertical Change	-.57	4 ft	4	SF	\$75	\$300	
7597	45.7 to 51.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	22	SF	\$120	\$2,640	
42481	53.0 to 54.0 feet	Vertical Change	-.69	4 ft	4	SF	\$75	\$300	
44678	67.7 to 68.7 feet	Vertical Change	-.54	4 ft	4	SF	\$75	\$300	
58211	78.3 to 98.2 feet	Driveway				REF			
7598	84.7 to 86.2 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	6	SF	\$40	\$240	
43405	92.2 to 93.2 feet	Vertical Change	-.61	4 ft	4	REF			
7599	98.3 to 113.2 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	60	SF	\$40	\$2,384	
41486	101.2 to 102.2 feet	Vertical Change	-1.11	4 ft	4	REF			
43259	111.5 to 112.5 feet	Vertical Change	-.62	4 ft	4	REF			
7600	117.3 to 122.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	20	SF	\$120	\$2,448	
44868	122.1 to 123.1 feet	Vertical Change	-.53	4 ft	4	REF			
7601	126.0 to 128.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	9	SF	\$120	\$1,104	
43260	135.0 to 136.0 feet	Vertical Change	-.62	4 ft	4	SF	\$75	\$300	
7602	139.8 to 179.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	157	SF	\$120	\$18,816	
58212	144.8 to 168.0 feet	Driveway				REF			
55943	150.8 to 151.8 feet	Vertical Change	.3	4 ft	4	REF			
50790	150.9 to 151.9 feet	Vertical Change	-.31	4 ft	4	REF			
47086	175.8 to 176.8 feet	Vertical Change	-.43	4 ft	4	REF			
7608	190.8 to 192.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$576	
48800	192.1 to 193.1 feet	Vertical Change	-.37	4 ft	4	LF	\$75	\$300	
7609	196.6 to 204.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	30	SF	\$120	\$3,600	
58213	200.1 to 211.0 feet	Driveway				REF			
7611	204.1 to 242.5 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	154	SF	\$40	\$6,144	
49088	207.6 to 208.6 feet	Vertical Change	-.36	4 ft	4	REF			
58214	217.4 to 233.9 feet	Driveway				REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221144	DEBORAH WAY	CANAL DR	CHARLENE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47977	230.9 to 231.9 feet	Vertical Change	-4	4 ft	4	REF		
7621	242.5 to 251.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	35	SF	\$120	\$4,224
53624	249.2 to 250.2 feet	Vertical Change	-26	4 ft	4	REF		
7622	256.2 to 312.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	224	SF	\$120	\$26,928
52575	261.9 to 262.9 feet	Vertical Change	-28	4 ft	4	REF		
43406	291.1 to 292.1 feet	Vertical Change	-.61	4 ft	4	REF		
44446	306.0 to 307.0 feet	Vertical Change	-.55	4 ft	4	REF		
7627	316.8 to 317.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	4	SF	\$120	\$480
44243	320.9 to 321.9 feet	Vertical Change	-.56	4 ft	4	SF	\$75	\$300
7628	323.4 to 334.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	46	SF	\$120	\$5,472
58215	331.0 to 350.9 feet	Driveway				REF		
44679	335.8 to 336.8 feet	Vertical Change	-.54	4 ft	4	REF		
44447	344.2 to 345.2 feet	Vertical Change	-.55	4 ft	4	REF		
44056	354.8 to 355.8 feet	Vertical Change	-.57	4 ft	4	SF	\$75	\$300
44448	364.6 to 365.6 feet	Vertical Change	-.55	4 ft	4	SF	\$75	\$300
45533	376.1 to 377.1 feet	Vertical Change	-.5	4 ft	4	SF	\$75	\$300
45045	388.1 to 389.1 feet	Vertical Change	-.52	4 ft	4	SF	\$75	\$300
58216	397.8 to 415.8 feet	Driveway				REF		
45960	402.4 to 403.4 feet	Vertical Change	-.48	4 ft	4	REF		
44244	411.2 to 412.2 feet	Vertical Change	-.56	4 ft	4	REF		
44245	420.2 to 421.2 feet	Vertical Change	-.56	4 ft	4	SF	\$75	\$300
7629	421.8 to 425.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	14	SF	\$120	\$1,680
44680	431.5 to 432.5 feet	Vertical Change	-.54	4 ft	4	SF	\$75	\$300
45046	441.9 to 442.9 feet	Vertical Change	-.52	4 ft	4	SF	\$75	\$300
7630	455.8 to 457.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$576
53625	457.1 to 458.1 feet	Vertical Change	-.26	4 ft	4	LF	\$75	\$300
7631	462.7 to 464.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	6	SF	\$120	\$720
49089	472.1 to 473.1 feet	Vertical Change	-.36	4 ft	4	LF	\$75	\$300

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221144	DEBORAH WAY	CANAL DR	CHARLENE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58217	482.6 to 498.3 feet	Driveway				REF		
48509	494.9 to 495.9 feet	Vertical Change	-0.38	4 ft	4	REF		
46859	512.3 to 513.3 feet	Vertical Change	-0.44	4 ft	4	LF	\$75	\$300
58218	516.5 to 533.6 feet	Driveway				REF		
48801	520.9 to 521.9 feet	Vertical Change	-0.37	4 ft	4	REF		
43407	529.6 to 530.6 feet	Vertical Change	-0.61	4 ft	4	REF		
7632	535.2 to 541.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	26	SF	\$120	\$3,168
48510	537.5 to 538.5 feet	Vertical Change	-0.38	4 ft	4	REF		
44449	549.5 to 550.5 feet	Vertical Change	-0.55	4 ft	4	SF	\$75	\$300
7633	551.7 to 552.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$576
45250	561.6 to 562.6 feet	Vertical Change	-0.51	4 ft	4	SF	\$75	\$300
42895	576.4 to 577.4 feet	Vertical Change	-0.65	4 ft	4	SF	\$75	\$300
7634	578.0 to 586.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	33	SF	\$120	\$3,984
58219	586.5 to 607.1 feet	Driveway				REF		
52576	602.0 to 603.0 feet	Vertical Change	-0.28	4 ft	4	REF		
7635	628.3 to 639.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	43	SF	\$120	\$5,136
50791	677.6 to 678.6 feet	Vertical Change	-0.31	4 ft	4	LF	\$75	\$300
47978	692.4 to 693.4 feet	Vertical Change	-0.4	4 ft	4	LF	\$75	\$300
58220	702.3 to 724.1 feet	Driveway				REF		
7638	710.1 to 727.1 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	68	SF	\$40	\$2,720
7639	738.4 to 745.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	27	SF	\$120	\$3,216
44246	738.8 to 739.8 feet	Vertical Change	-0.56	4 ft	4	REF		
7640	749.2 to 757.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	34	SF	\$120	\$4,080
7641	764.4 to 799.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	140	SF	\$120	\$16,752
45752	777.0 to 778.0 feet	Vertical Change	-0.49	4 ft	4	REF		
51691	791.4 to 792.4 feet	Vertical Change	-0.3	4 ft	4	REF		
TOTAL COST FOR: W side of DEBORAH WAY Starting at: CANAL DR							\$128,836.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908221147	DEBORAH WAY	CHARLENE DR	CANAL DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
7644	0.0 to 2.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	9	SF	\$120	\$1,104	
50036	11.9 to 12.9 feet	Vertical Change	-.33	4 ft	4	LF	\$75	\$300	
52122	77.4 to 78.4 feet	Vertical Change	-.29	4 ft	4	LF	\$75	\$300	
58221	89.3 to 106.1 feet	Driveway				REF			
58222	178.8 to 210.0 feet	Driveway				REF			
7645	181.8 to 184.6 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	11	SF	\$40	\$448	
43586	184.6 to 185.6 feet	Vertical Change	-.6	4 ft	4	REF			
47087	216.7 to 217.7 feet	Vertical Change	-.43	4 ft	4	LF	\$75	\$300	
42482	227.8 to 228.8 feet	Vertical Change	-.69	4 ft	4	SF	\$75	\$300	
42483	239.0 to 240.0 feet	Vertical Change	-.69	4 ft	4	SF	\$75	\$300	
45753	253.7 to 254.7 feet	Vertical Change	-.49	4 ft	4	LF	\$75	\$300	
58223	262.5 to 279.6 feet	Driveway				REF			
51692	300.3 to 301.3 feet	Vertical Change	-.3	4 ft	4	LF	\$75	\$300	
45047	314.7 to 315.7 feet	Vertical Change	-.52	4 ft	4	SF	\$75	\$300	
49090	329.2 to 330.2 feet	Vertical Change	-.36	4 ft	4	LF	\$75	\$300	
58224	336.4 to 354.6 feet	Driveway				REF			
46623	343.2 to 344.2 feet	Vertical Change	-.45	4 ft	4	REF			
49708	359.1 to 360.1 feet	Vertical Change	-.34	4 ft	4	LF	\$75	\$300	
58225	361.3 to 387.0 feet	Driveway				REF			
47088	365.2 to 366.2 feet	Vertical Change	-.43	4 ft	4	REF			
45251	378.0 to 379.0 feet	Vertical Change	-.51	4 ft	4	REF			
42049	391.9 to 392.9 feet	Vertical Change	-.76	4 ft	4	SF	\$75	\$300	
44450	405.1 to 406.1 feet	Vertical Change	-.55	4 ft	4	SF	\$75	\$300	
42484	415.9 to 416.9 feet	Vertical Change	-.69	4 ft	4	SF	\$75	\$300	
7646	423.1 to 426.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	12	SF	\$120	\$1,392	
7647	436.7 to 438.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	6	SF	\$120	\$768	
58226	440.7 to 457.7 feet	Driveway				REF			
53626	444.9 to 445.9 feet	Vertical Change	-.26	4 ft	4	REF			
50404	453.8 to 454.8 feet	Vertical Change	-.32	4 ft	4	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221147	DEBORAH WAY	CHARLENE DR	CANAL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7648	460.6 to 465.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	19	SF	\$120	\$2,304
52577	462.8 to 463.8 feet	Vertical Change	-.28	4 ft	4	REF		
52123	474.2 to 475.2 feet	Vertical Change	-.29	4 ft	4	LF	\$75	\$300
45048	484.9 to 485.9 feet	Vertical Change	-.52	4 ft	4	SF	\$75	\$300
46860	497.1 to 498.1 feet	Vertical Change	-.44	4 ft	4	LF	\$75	\$300
7649	509.2 to 515.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	26	SF	\$120	\$3,072
45754	511.4 to 512.4 feet	Vertical Change	-.49	4 ft	4	REF		
48802	521.7 to 522.7 feet	Vertical Change	-.37	4 ft	4	LF	\$75	\$300
49709	533.3 to 534.3 feet	Vertical Change	-.34	4 ft	4	LF	\$75	\$300
7650	547.0 to 562.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	62	SF	\$120	\$7,440
57128	547.6 to 548.6 feet	Vertical Change	.61	4 ft	4	REF		
58227	557.0 to 577.4 feet	Driveway				REF		
46861	562.2 to 563.2 feet	Vertical Change	-.44	4 ft	4	REF		
43724	572.4 to 573.4 feet	Vertical Change	-.59	4 ft	4	REF		
7653	581.7 to 584.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	10	SF	\$120	\$1,248
58228	583.9 to 618.0 feet	Driveway				REF		
7654	588.3 to 629.1 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	163	SF	\$40	\$6,528
42896	592.6 to 593.6 feet	Vertical Change	-.65	4 ft	4	REF		
47089	603.1 to 604.1 feet	Vertical Change	-.43	4 ft	4	REF		
51693	607.4 to 608.4 feet	Vertical Change	-.3	4 ft	4	REF		
53627	611.5 to 612.5 feet	Vertical Change	-.26	4 ft	4	REF		
44451	619.7 to 620.7 feet	Vertical Change	-.55	4 ft	4	REF		
53082	631.6 to 632.6 feet	Vertical Change	-.27	4 ft	4	LF	\$75	\$300
53628	643.6 to 644.6 feet	Vertical Change	-.26	4 ft	4	LF	\$75	\$300
7660	650.8 to 651.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	4	SF	\$120	\$480
50405	655.4 to 656.4 feet	Vertical Change	-.32	4 ft	4	LF	\$75	\$300
7661	664.8 to 673.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	33	SF	\$120	\$3,984
58229	665.5 to 681.5 feet	Driveway				REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221147	DEBORAH WAY	CHARLENE DR	CANAL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
53629	669.7 to 670.7 feet	Vertical Change	-.26	4 ft	4	REF		
7664	677.1 to 680.6 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	14	SF	\$40	\$560
49091	677.7 to 678.7 feet	Vertical Change	-.36	4 ft	4	REF		
7665	683.5 to 708.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	101	SF	\$120	\$12,144
42682	686.1 to 687.1 feet	Vertical Change	-.67	4 ft	4	REF		
46862	697.3 to 698.3 feet	Vertical Change	-.44	4 ft	4	REF		
49381	708.3 to 709.3 feet	Vertical Change	-.35	4 ft	4	REF		
7670	731.5 to 740.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	35	SF	\$120	\$4,176
52578	738.6 to 739.6 feet	Vertical Change	-.28	4 ft	4	REF		
7671	744.2 to 752.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	31	SF	\$120	\$3,744
58230	748.8 to 770.1 feet	Driveway				REF		
7673	752.0 to 781.8 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	119	SF	\$40	\$4,768
7679	781.8 to 787.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	24	SF	\$120	\$2,880
TOTAL COST FOR: E side of DEBORAH WAY Starting at: CHARLENE DR							\$63,340.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221149	CANAL DR	DEBORAH WAY	DOROTHY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7680	0.0 to 7.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	26	SF	\$120	\$3,108
7681	9.8 to 20.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	39	SF	\$120	\$4,662
7682	23.8 to 85.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	216	SF	\$120	\$25,914
47320	134.2 to 135.2 feet	Vertical Change	-.42	4 ft	4	LF	\$75	\$263
7688	150.0 to 151.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	6	SF	\$120	\$672
7689	175.3 to 176.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	4	SF	\$120	\$420
52579	183.8 to 184.8 feet	Vertical Change	-.28	4 ft	4	LF	\$75	\$263
TOTAL COST FOR: S side of CANAL DR Starting at: DEBORAH WAY							\$35,301.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
W	1908221152	DOROTHY WAY	CANAL DR	CHARLENE DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
47321	19.6 to 20.6 feet	Vertical Change	-.42	4 ft	4	LF	\$75	\$300	
7690	20.9 to 27.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	27	SF	\$120	\$3,216	
7692	27.6 to 66.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	157	SF	\$120	\$18,816	
58231	31.0 to 52.6 feet	Driveway				REF			
7696	66.8 to 74.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	32	SF	\$120	\$3,888	
58232	71.4 to 94.5 feet	Driveway				REF			
7698	74.9 to 127.1 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	209	SF	\$40	\$8,352	
52124	87.1 to 88.1 feet	Vertical Change	-.29	4 ft	4	REF			
7705	127.1 to 133.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	24	SF	\$120	\$2,880	
7707	133.1 to 168.0 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	140	SF	\$120	\$16,752	
50792	135.0 to 136.0 feet	Vertical Change	-.31	4 ft	4	REF			
42191	144.9 to 145.9 feet	Vertical Change	-.73	4 ft	4	REF			
42485	159.9 to 160.9 feet	Vertical Change	-.69	4 ft	4	REF			
7715	168.0 to 184.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	66	SF	\$120	\$7,968	
43408	174.8 to 175.8 feet	Vertical Change	-.61	4 ft	4	REF			
58233	182.7 to 210.4 feet	Driveway				REF			
7717	184.6 to 210.3 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	103	SF	\$40	\$4,112	
42192	188.8 to 189.8 feet	Vertical Change	-.73	4 ft	4	REF			
7720	210.3 to 214.1 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	15	SF	\$40	\$608	
7721	214.1 to 225.1 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	44	SF	\$120	\$5,280	
44452	215.9 to 216.9 feet	Vertical Change	-.55	4 ft	4	REF			
7722	225.1 to 228.6 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	14	SF	\$120	\$1,680	
7723	228.6 to 229.8 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	5	SF	\$120	\$576	
7724	229.8 to 233.7 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	16	SF	\$120	\$1,872	
43883	230.8 to 231.8 feet	Vertical Change	-.58	4 ft	4	REF			
7725	233.7 to 258.5 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	99	SF	\$120	\$11,904	
43261	244.3 to 245.3 feet	Vertical Change	-.62	4 ft	4	REF			
58234	253.9 to 280.1 feet	Driveway				REF			
45049	258.5 to 259.5 feet	Vertical Change	-.52	4 ft	4	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
W	1908221152	DOROTHY WAY	CANAL DR	CHARLENE DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
7727	258.5 to 304.3 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	183	SF	\$40	\$7,328	
44057	273.6 to 274.6 feet	Vertical Change	-.57	4 ft	4	REF			
49382	285.8 to 286.8 feet	Vertical Change	-.35	4 ft	4	REF			
50793	300.4 to 301.4 feet	Vertical Change	-.31	4 ft	4	REF			
7735	304.3 to 341.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	148	SF	\$120	\$17,760	
58235	318.8 to 331.1 feet	Driveway				REF			
53083	325.2 to 326.2 feet	Vertical Change	-.27	4 ft	4	REF			
45252	337.1 to 338.1 feet	Vertical Change	-.51	4 ft	4	REF			
7741	341.3 to 343.6 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	9	SF	\$120	\$1,104	
7742	343.6 to 364.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	84	SF	\$120	\$10,080	
44247	356.5 to 357.5 feet	Vertical Change	-.56	4 ft	4	REF			
7746	364.6 to 375.6 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	44	SF	\$120	\$5,280	
58236	365.9 to 385.4 feet	Driveway				REF			
7748	375.6 to 389.0 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	54	SF	\$40	\$2,144	
53084	380.4 to 381.4 feet	Vertical Change	-.27	4 ft	4	REF			
7751	389.0 to 390.2 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	5	SF	\$120	\$576	
7752	390.2 to 392.4 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	9	SF	\$120	\$1,056	
7753	392.4 to 395.4 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	12	SF	\$120	\$1,440	
7755	395.4 to 397.2 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	7	SF	\$120	\$864	
7756	397.2 to 400.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	12	SF	\$120	\$1,488	
7757	406.5 to 413.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	27	SF	\$120	\$3,216	
7758	420.1 to 421.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	6	SF	\$120	\$768	
50406	421.6 to 422.6 feet	Vertical Change	-.32	4 ft	4	REF			
7759	433.5 to 434.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$624	
45534	435.8 to 436.8 feet	Vertical Change	-.5	4 ft	4	SF	\$75	\$300	
48803	450.2 to 451.2 feet	Vertical Change	-.37	4 ft	4	LF	\$75	\$300	
43262	464.6 to 465.6 feet	Vertical Change	-.62	4 ft	4	SF	\$75	\$300	
58237	472.4 to 492.4 feet	Driveway				REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221152	DOROTHY WAY	CANAL DR	CHARLENE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7760	475.4 to 481.3 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	24	SF	\$40	\$944
7762	481.3 to 498.2 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	68	SF	\$40	\$2,704
49710	496.4 to 497.4 feet	Vertical Change	-.34	4 ft	4	REF		
7764	498.2 to 499.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	6	SF	\$120	\$768
47322	505.4 to 506.4 feet	Vertical Change	-.42	4 ft	4	LF	\$75	\$300
7765	513.0 to 523.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	40	SF	\$120	\$4,848
53085	533.8 to 534.8 feet	Vertical Change	-.27	4 ft	4	LF	\$75	\$300
58238	557.8 to 569.6 feet	Driveway				REF		
7766	558.1 to 574.2 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	64	SF	\$40	\$2,576
43725	590.2 to 591.2 feet	Vertical Change	-.59	4 ft	4	SF	\$75	\$300
47979	618.4 to 619.4 feet	Vertical Change	-.4	4 ft	4	LF	\$75	\$300
58239	622.3 to 637.8 feet	Driveway				REF		
53086	627.9 to 628.9 feet	Vertical Change	-.27	4 ft	4	REF		
44058	662.4 to 663.4 feet	Vertical Change	-.57	4 ft	4	SF	\$75	\$300
43409	676.7 to 677.7 feet	Vertical Change	-.61	4 ft	4	SF	\$75	\$300
42897	691.2 to 692.2 feet	Vertical Change	-.65	4 ft	4	SF	\$75	\$300
58240	693.2 to 724.6 feet	Driveway				REF		
44681	705.4 to 706.4 feet	Vertical Change	-.54	4 ft	4	REF		
44248	720.0 to 721.0 feet	Vertical Change	-.56	4 ft	4	REF		
47980	734.2 to 735.2 feet	Vertical Change	-.4	4 ft	4	LF	\$75	\$300
50037	748.9 to 749.9 feet	Vertical Change	-.33	4 ft	4	LF	\$75	\$300
52580	763.3 to 764.3 feet	Vertical Change	-.28	4 ft	4	LF	\$75	\$300
52125	777.8 to 778.8 feet	Vertical Change	-.29	4 ft	4	REF		
7767	778.4 to 782.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,968
7768	789.4 to 794.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	22	SF	\$120	\$2,592
50038	791.7 to 792.7 feet	Vertical Change	-.33	4 ft	4	REF		

TOTAL COST FOR: W side of DOROTHY WAY Starting at: CANAL DR \$162,232.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221154	DOROTHY WAY	CHARLENE DR	HOWELL RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44249	10.8 to 11.8 feet	Vertical Change	-.56	4 ft	4	SF	\$75	\$300
43884	25.4 to 26.4 feet	Vertical Change	-.58	4 ft	4	SF	\$75	\$300
44059	39.4 to 40.4 feet	Vertical Change	-.57	4 ft	4	SF	\$75	\$300
7769	52.8 to 56.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,920
44250	54.3 to 55.3 feet	Vertical Change	-.56	4 ft	4	REF		
58241	67.9 to 90.7 feet	Driveway				REF		
46406	71.5 to 72.5 feet	Vertical Change	-.46	4 ft	4	REF		
7770	71.6 to 90.2 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	74	SF	\$40	\$2,976
43726	82.8 to 83.8 feet	Vertical Change	-.59	4 ft	4	REF		
44060	95.7 to 96.7 feet	Vertical Change	-.57	4 ft	4	SF	\$75	\$300
58242	99.3 to 130.5 feet	Driveway				REF		
49383	146.3 to 147.3 feet	Vertical Change	-.35	4 ft	4	LF	\$75	\$300
53630	156.7 to 157.7 feet	Vertical Change	-.26	4 ft	4	LF	\$75	\$300
7772	176.3 to 184.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	33	SF	\$120	\$3,984
53087	186.6 to 187.6 feet	Vertical Change	-.27	4 ft	4	LF	\$75	\$300
TOTAL COST FOR: W side of DOROTHY WAY Starting at: CHARLENE DR							\$10,980.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908221157	HOWELL RD	DOROTHY WAY	GILL WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
7773	0.0 to 4.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	17	SF	\$120	\$2,016	
44682	0.6 to 1.6 feet	Vertical Change	-.54	4 ft	4	REF			
45535	11.9 to 12.9 feet	Vertical Change	-.5	4 ft	4	SF	\$75	\$263	
53631	21.6 to 22.6 feet	Vertical Change	-.26	4 ft	4	LF	\$75	\$263	
7774	43.7 to 92.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	171	SF	\$120	\$20,496	
58243	46.6 to 57.9 feet	Driveway				REF			
48224	88.5 to 89.5 feet	Vertical Change	-.39	4 ft	4	REF			
7782	97.6 to 117.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	70	SF	\$120	\$8,400	
52126	102.5 to 103.5 feet	Vertical Change	-.29	4 ft	4	REF			
58244	111.7 to 125.5 feet	Driveway				REF			
7783	127.8 to 131.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	13	SF	\$120	\$1,512	
52581	128.7 to 129.7 feet	Vertical Change	-.28	4 ft	4	REF			
7785	132.4 to 143.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	38	SF	\$120	\$4,578	
7788	143.3 to 162.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	67	SF	\$120	\$8,022	
7792	173.8 to 185.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	40	SF	\$120	\$4,830	
58245	178.8 to 198.8 feet	Driveway				REF			
7795	185.3 to 207.3 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	77	SF	\$40	\$3,080	
58246	204.0 to 226.0 feet	Driveway				REF			
7799	207.3 to 208.9 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	6	SF	\$40	\$224	
7800	214.7 to 233.7 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	67	SF	\$40	\$2,660	
7802	233.7 to 274.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	144	SF	\$120	\$17,220	
7809	274.7 to 310.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	126	SF	\$120	\$15,162	
58247	281.2 to 299.3 feet	Driveway				REF			
7814	326.5 to 334.6 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	28	SF	\$120	\$3,402	
7816	334.6 to 337.7 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	11	SF	\$120	\$1,302	
7817	350.2 to 368.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	64	SF	\$120	\$7,728	
7819	372.8 to 381.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	29	SF	\$120	\$3,486	
7822	381.1 to 389.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	30	SF	\$120	\$3,612	
7824	389.7 to 406.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	58	SF	\$120	\$7,014	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221157	HOWELL RD	DOROTHY WAY	GILL WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58248	396.7 to 413.7 feet	Driveway				REF		
46407	417.0 to 418.0 feet	Vertical Change	-46	4 ft	4	LF	\$75	\$263
7825	422.7 to 427.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	17	SF	\$120	\$2,016
47090	423.2 to 424.2 feet	Vertical Change	-43	4 ft	4	REF		
TOTAL COST FOR: N side of HOWELL RD Starting at: DOROTHY WAY							\$117,547.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221159	HOWELL RD	GILL WAY	HOLIDAY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44453	7.4 to 8.4 feet	Vertical Change	-.55	4 ft	4	SF	\$75	\$263
7826	11.2 to 50.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	137	SF	\$120	\$16,422
7831	53.8 to 122.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	240	SF	\$120	\$28,854
48511	92.4 to 93.4 feet	Vertical Change	-.38	4 ft	4	REF		
52582	102.5 to 103.5 feet	Vertical Change	-.28	4 ft	4	REF		
44061	111.8 to 112.8 feet	Vertical Change	-.57	4 ft	4	REF		
44869	121.6 to 122.6 feet	Vertical Change	-.53	4 ft	4	REF		
48512	131.4 to 132.4 feet	Vertical Change	-.38	4 ft	4	LF	\$75	\$263
7837	136.1 to 154.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	65	SF	\$120	\$7,812
49384	141.7 to 142.7 feet	Vertical Change	-.35	4 ft	4	REF		
7839	154.7 to 185.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	109	SF	\$120	\$13,020
46624	172.3 to 173.3 feet	Vertical Change	-.45	4 ft	4	REF		

TOTAL COST FOR:	N	<i>side of</i>	HOWELL RD	<i>Starting at:</i>	GILL WAY	\$66,633.00
------------------------	----------	----------------	------------------	---------------------	-----------------	--------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
N	1908221201	HOWELL RD	HOLIDAY WAY	AUTUMN WAY	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
7843	0.0 to 8.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,428			
7845	8.2 to 51.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	194	SF	\$120	\$23,274			
56963	9.9 to 10.9 feet	Vertical Change	.56	5 ft	5	REF					
50407	22.0 to 23.0 feet	Vertical Change	-.32	5 ft	5	REF					
56629	41.7 to 42.7 feet	Vertical Change	.45	5 ft	5	REF					
7851	51.3 to 65.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,830			
52583	61.8 to 62.8 feet	Vertical Change	-.28	5 ft	5	REF					
7854	72.3 to 181.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	491	SF	\$120	\$58,914			
53088	131.1 to 132.1 feet	Vertical Change	-.27	5 ft	5	REF					
50408	150.3 to 151.3 feet	Vertical Change	-.32	5 ft	5	REF					
TOTAL COST FOR: N							<i>side of</i>	HOWELL RD	<i>Starting at:</i>	HOLIDAY WAY	\$94,446.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221202	HOWELL RD	AUTUMN WAY	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7864	0.0 to 32.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	144	SF	\$120	\$17,280
49711	8.4 to 9.4 feet	Vertical Change	-.34	5 ft	5	REF		
7868	32.0 to 65.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	152	SF	\$120	\$18,198
48804	58.6 to 59.6 feet	Vertical Change	-.37	5 ft	5	REF		
TOTAL COST FOR: N side of HOWELL RD Starting at: AUTUMN WAY							\$35,478.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
S	1908221212	HOWELL RD	OLEANDER DR	GILL WAY	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
52584	9.5 to 13.0 feet	Vertical Change	-.28	5 ft	18	LF	\$75	\$1,313	
7871	14.9 to 66.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	258	SF	\$120	\$30,960	
51694	17.0 to 18.0 feet	Vertical Change	-.3	5 ft	5	REF			
41177	19.7 to 20.7 feet	Vertical Change	-3.16	5 ft	5	REF			
50039	22.5 to 23.5 feet	Vertical Change	-.33	5 ft	5	REF			
41179	25.3 to 26.3 feet	Vertical Change	-3.08	5 ft	5	REF			
53633	30.5 to 33.9 feet	Vertical Change	-.26	5 ft	17	REF			
51695	43.0 to 49.0 feet	Vertical Change	-.3	5 ft	30	REF			
52585	60.0 to 61.0 feet	Vertical Change	-.28	5 ft	5	REF			
52586	64.6 to 65.6 feet	Vertical Change	-.28	5 ft	5	REF			
51696	74.3 to 75.3 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
38	85.2 to 86.2 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
53089	99.7 to 103.1 feet	Vertical Change	-.27	5 ft	17	LF	\$75	\$1,275	
39	105.8 to 106.8 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
52587	107.1 to 110.5 feet	Vertical Change	-.28	5 ft	17	REF			
7877	107.1 to 109.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320	
7879	109.3 to 123.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	70	SF	\$120	\$8,400	
53634	115.9 to 116.9 feet	Vertical Change	-.26	5 ft	5	REF			
58249	117.8 to 155.5 feet	Driveway				REF			
43885	122.0 to 123.0 feet	Vertical Change	-.58	5 ft	5	REF			
7882	123.3 to 149.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	130	SF	\$40	\$5,200	
49385	136.6 to 137.6 feet	Vertical Change	-.35	5 ft	5	REF			
40262	147.2 to 148.2 feet	Running Slope	6.0-7.0%	5 ft	5	REF			
7885	149.3 to 151.4 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	10	SF	\$40	\$420	
41766	150.2 to 151.2 feet	Vertical Change	-.86	5 ft	5	REF			
57152	150.3 to 151.3 feet	Vertical Change	.66	5 ft	5	REF			
7887	151.4 to 172.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	104	SF	\$40	\$4,160	
41722	164.1 to 165.1 feet	Vertical Change	-.88	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221212	HOWELL RD	OLEANDER DR	GILL WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7888	172.2 to 212.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	203	SF	\$120	\$24,360
42394	180.5 to 181.5 feet	Vertical Change	-7	5 ft	5	REF		
52588	196.6 to 197.6 feet	Vertical Change	-28	5 ft	5	REF		
43127	212.2 to 213.2 feet	Vertical Change	-63	5 ft	5	REF		
7895	212.8 to 219.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	33	SF	\$120	\$3,900
46625	218.3 to 219.3 feet	Vertical Change	-45	5 ft	5	REF		
7899	219.3 to 227.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$4,980
46408	224.0 to 228.6 feet	Vertical Change	-46	5 ft	23	REF		
7901	227.6 to 276.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	246	SF	\$120	\$29,520
46169	243.5 to 244.5 feet	Vertical Change	-47	5 ft	5	REF		
44454	260.5 to 261.5 feet	Vertical Change	-55	5 ft	5	REF		
47568	275.5 to 276.5 feet	Vertical Change	-41	5 ft	5	REF		
7907	276.8 to 304.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	139	SF	\$120	\$16,680
47091	291.1 to 292.1 feet	Vertical Change	-43	5 ft	5	REF		
40	303.4 to 304.4 feet	Continuous Width		5 ft	5	SF	\$120	\$600
58250	306.3 to 339.2 feet	Driveway				REF		
46863	310.1 to 311.1 feet	Vertical Change	-44	5 ft	5	REF		
7912	312.8 to 337.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	124	SF	\$40	\$4,960
41744	324.3 to 325.3 feet	Vertical Change	-87	5 ft	5	REF		
40263	335.1 to 336.7 feet	Running Slope	7.0-8.0%	5 ft	8	REF		
7917	337.6 to 338.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$220
45536	338.3 to 339.3 feet	Vertical Change	-5	5 ft	5	REF		
7918	339.4 to 341.7 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	12	SF	\$40	\$460
7919	341.7 to 383.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	211	SF	\$120	\$25,260
50794	369.6 to 370.6 feet	Vertical Change	-31	5 ft	5	REF		
7922	386.0 to 410.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	122	SF	\$120	\$14,640
41	386.4 to 387.4 feet	Continuous Width		5 ft	5	SF	\$120	\$600
7923	413.7 to 417.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221212	HOWELL RD	OLEANDER DR	GILL WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7924	420.0 to 485.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	329	SF	\$120	\$39,420
7932	492.8 to 508.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	80	SF	\$120	\$9,540
50410	515.8 to 516.8 feet	Vertical Change	-32	5 ft	5	LF	\$75	\$375
7933	517.8 to 537.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	100	SF	\$120	\$12,000
49712	531.5 to 532.5 feet	Vertical Change	-34	5 ft	5	REF		
49386	562.7 to 563.7 feet	Vertical Change	-35	5 ft	5	LF	\$75	\$375
42	599.1 to 600.1 feet	Continuous Width		5 ft	5	SF	\$120	\$600
54010	601.2 to 602.2 feet	Vertical Change	-25	5 ft	5	LF	\$75	\$375
7934	607.9 to 657.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	248	SF	\$120	\$29,700
49387	626.7 to 627.7 feet	Vertical Change	-35	5 ft	5	REF		
58251	652.4 to 682.4 feet	Driveway				REF		
7937	661.6 to 680.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	92	SF	\$40	\$3,680
7940	683.1 to 684.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$660
7941	684.2 to 687.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740
7942	690.7 to 699.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$4,980
TOTAL COST FOR: S side of HOWELL RD Starting at: OLEANDER DR							\$286,467.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
S	1908221216	HOWELL RD	GILL WAY	VENTURA AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
7943	30.5 to 37.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020	
58252	32.9 to 55.9 feet	Driveway				REF			
7945	40.1 to 53.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	69	SF	\$40	\$2,740	
40264	52.3 to 54.1 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
7947	57.4 to 85.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	140	SF	\$120	\$16,740	
58253	99.2 to 121.8 feet	Driveway				REF			
7950	106.9 to 120.6 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	69	SF	\$40	\$2,740	
7955	141.6 to 151.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$6,060	
58254	172.5 to 195.4 feet	Driveway				REF			
7956	181.3 to 193.4 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	61	SF	\$40	\$2,420	
7958	207.8 to 210.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380	
7959	214.0 to 215.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960	
58255	236.8 to 260.6 feet	Driveway				REF			
7960	245.6 to 258.6 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	65	SF	\$40	\$2,600	
7964	262.1 to 263.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720	
58256	271.6 to 300.3 feet	Driveway				REF			
52589	277.4 to 278.4 feet	Vertical Change	-28	5 ft	5	REF			
7965	281.1 to 296.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	78	SF	\$40	\$3,100	
44062	298.9 to 299.9 feet	Vertical Change	-.57	5 ft	5	REF			
43263	315.3 to 316.3 feet	Vertical Change	-.62	5 ft	5	SF	\$75	\$375	
7968	326.3 to 332.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,420	
49388	331.5 to 332.5 feet	Vertical Change	-.35	5 ft	5	REF			
51697	342.3 to 343.3 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
53635	356.9 to 357.9 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
43587	372.9 to 373.9 feet	Vertical Change	-.6	5 ft	5	SF	\$75	\$375	
47323	387.8 to 388.8 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375	
7969	393.3 to 401.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$5,040	
53636	401.9 to 402.9 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
7970	409.6 to 419.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,700	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221216	HOWELL RD	GILL WAY	VENTURA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
7972	419.1 to 454.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	176	SF	\$120	\$21,060
53637	428.1 to 429.1 feet	Vertical Change	-26	5 ft	5	REF		
43	440.1 to 441.1 feet	Continuous Width		5 ft	5	SF	\$120	\$600
58257	450.6 to 478.6 feet	Driveway				REF		
7976	458.7 to 476.9 feet	Cross Slope (Driveway)	>15%	5 ft	91	SF	\$40	\$3,640
40265	475.6 to 476.7 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
7979	480.5 to 496.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	80	SF	\$120	\$9,540
46626	489.4 to 490.4 feet	Vertical Change	-45	5 ft	5	REF		
40266	493.8 to 495.9 feet	Running Slope	6.0-7.0%	5 ft	11	REF		
7981	496.4 to 515.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	93	SF	\$120	\$11,160
52590	502.3 to 503.3 feet	Vertical Change	-28	5 ft	5	REF		
7984	515.0 to 522.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	39	SF	\$120	\$4,680
47982	516.7 to 517.7 feet	Vertical Change	-4	5 ft	5	REF		
7986	522.8 to 552.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	147	SF	\$120	\$17,640
41986	533.3 to 534.3 feet	Vertical Change	-78	5 ft	5	REF		
48513	549.6 to 550.6 feet	Vertical Change	-38	5 ft	5	REF		

TOTAL COST FOR: S side of HOWELL RD Starting at: GILL WAY \$128,210.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908221332	WASHINGTON RD	ROBERTSON BLVD	1520 ROBERTSON RD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
7990	0.0 to 23.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	115	SF	\$120	\$13,800	
50411	0.2 to 1.2 feet	Vertical Change	-32	5 ft	5	REF			
49092	5.2 to 6.2 feet	Vertical Change	-36	5 ft	5	REF			
50041	10.8 to 11.8 feet	Vertical Change	-33	5 ft	5	REF			
50795	16.0 to 17.0 feet	Vertical Change	-31	5 ft	5	REF			
7993	23.0 to 26.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,100	
51698	26.0 to 27.0 feet	Vertical Change	-3	5 ft	5	REF			
44683	49.5 to 50.5 feet	Vertical Change	-54	5 ft	5	SF	\$75	\$375	
44	58.4 to 59.4 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
7994	58.9 to 62.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860	
7996	62.0 to 74.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	62	SF	\$120	\$7,380	
45050	65.7 to 66.7 feet	Vertical Change	-52	5 ft	5	REF			
8001	74.3 to 75.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660	
51699	75.5 to 76.5 feet	Vertical Change	-3	5 ft	5	LF	\$75	\$375	
45	83.7 to 84.7 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
53090	85.1 to 86.1 feet	Vertical Change	-27	5 ft	5	LF	\$75	\$375	
8002	92.0 to 103.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,600	
8005	125.3 to 137.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	61	SF	\$120	\$7,260	
43410	125.5 to 126.5 feet	Vertical Change	-61	5 ft	5	REF			
58258	132.2 to 158.6 feet	Driveway				REF			
42486	137.4 to 138.4 feet	Vertical Change	-69	5 ft	5	REF			
8007	140.7 to 150.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	47	SF	\$40	\$1,860	
49713	147.8 to 148.8 feet	Vertical Change	-34	5 ft	5	REF			
8010	150.0 to 155.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	29	SF	\$40	\$1,160	
50412	152.0 to 153.0 feet	Vertical Change	-32	5 ft	5	REF			
8013	158.0 to 159.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	7	SF	\$40	\$260	
53091	158.4 to 159.4 feet	Vertical Change	-27	5 ft	5	REF			
46	160.1 to 161.1 feet	Continuous Width		5 ft	5	SF	\$120	\$600	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221332	WASHINGTON RD	ROBERTSON BLVD	1520 ROBERTSON RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
TOTAL COST FOR:								\$45,865.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908221337	WASHINGTON RD	1520 ROBERTSON BLVD	DEFENDER ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
8014	0.0 to 15.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	77	SF	\$120	\$9,180	
58259	11.8 to 30.6 feet	Driveway				REF			
47	13.4 to 14.4 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
8016	18.3 to 27.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	47	SF	\$40	\$1,880	
43003	29.9 to 30.9 feet	Vertical Change	-.64	5 ft	5	REF			
8020	30.8 to 31.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200	
8021	31.8 to 57.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	129	SF	\$120	\$15,420	
49093	38.3 to 39.3 feet	Vertical Change	-.36	5 ft	5	REF			
47569	46.7 to 47.7 feet	Vertical Change	-.41	5 ft	5	REF			
48805	54.9 to 55.9 feet	Vertical Change	-.37	5 ft	5	REF			
8025	57.5 to 59.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	8	SF	\$120	\$960	
48	57.6 to 58.6 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
8026	59.7 to 62.7 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	15	SF	\$120	\$1,800	
45051	63.2 to 64.2 feet	Vertical Change	-.52	5 ft	5	SF	\$75	\$375	
8028	65.0 to 66.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$780	
8029	66.3 to 72.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,600	
49	70.0 to 71.0 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
8030	74.5 to 96.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	111	SF	\$120	\$13,320	
58260	91.3 to 121.8 feet	Driveway				REF			
8031	100.3 to 119.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	98	SF	\$40	\$3,920	
8033	122.6 to 123.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$720	
8034	123.8 to 208.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	424	SF	\$120	\$50,880	
53092	128.2 to 129.2 feet	Vertical Change	-.27	5 ft	5	REF			
52591	191.6 to 192.6 feet	Vertical Change	-.28	5 ft	5	REF			
51700	206.1 to 207.1 feet	Vertical Change	-.3	5 ft	5	REF			
48227	209.7 to 210.7 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375	
47324	219.1 to 220.1 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375	
47092	231.0 to 232.0 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221337	WASHINGTON RD	1520 ROBERTSON BLVD	DEFENDER ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
8037	237.8 to 241.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,100
8038	251.5 to 259.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$5,040
51701	256.3 to 257.3 feet	Vertical Change	-3	5 ft	5	REF		
TOTAL COST FOR: N side of WASHINGTON RD Starting at: 1520 ROBERTSON BLVD							\$113,100.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221339	WASHINGTON RD	DEFENDER ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
50413	2.9 to 3.9 feet	Vertical Change	-.32	5 ft	5	REF		
8040	3.3 to 10.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,500
48228	12.7 to 13.7 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375
45755	22.7 to 23.7 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$375
46627	33.1 to 34.1 feet	Vertical Change	-.45	5 ft	5	LF	\$75	\$375
53093	53.7 to 54.7 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
8041	63.2 to 80.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	85	SF	\$120	\$10,200
48229	64.3 to 65.3 feet	Vertical Change	-.39	5 ft	5	REF		
46864	74.3 to 75.3 feet	Vertical Change	-.44	5 ft	5	REF		
52592	84.6 to 85.6 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375
8042	88.3 to 102.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	70	SF	\$120	\$8,340
52128	89.9 to 93.0 feet	Vertical Change	-.29	5 ft	16	REF		
51702	95.1 to 96.1 feet	Vertical Change	-.3	5 ft	5	REF		
8044	115.3 to 120.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,180
48806	115.6 to 119.0 feet	Vertical Change	-.37	5 ft	17	REF		
TOTAL COST FOR: N side of WASHINGTON RD Starting at: DEFENDER ST							\$28,095.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908221340	WASHINGTON RD	SIDEWALK BEGINS	MAPLE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
8045	5.8 to 11.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,360	
48807	6.4 to 7.4 feet	Vertical Change	-37	5 ft	5	REF			
50796	11.1 to 12.1 feet	Vertical Change	-31	5 ft	5	REF			
50414	16.2 to 17.2 feet	Vertical Change	-32	5 ft	5	LF	\$75	\$375	
8046	18.4 to 34.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	79	SF	\$120	\$9,540	
8048	37.8 to 66.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	144	SF	\$120	\$17,220	
41545	42.6 to 43.6 feet	Vertical Change	-1.03	5 ft	5	REF			
47093	64.0 to 65.0 feet	Vertical Change	-43	5 ft	5	REF			
8049	74.1 to 75.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660	
45756	74.7 to 75.7 feet	Vertical Change	-49	5 ft	5	REF			
8050	79.4 to 88.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,580	
50797	85.1 to 86.1 feet	Vertical Change	-31	5 ft	5	REF			
8051	91.2 to 99.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,160	
8052	103.4 to 108.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,180	
50042	106.7 to 107.7 feet	Vertical Change	-33	5 ft	5	REF			
52594	117.4 to 118.4 feet	Vertical Change	-28	5 ft	5	LF	\$75	\$375	
49391	128.4 to 129.4 feet	Vertical Change	-35	5 ft	5	REF			
8053	128.9 to 134.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,420	
8054	137.6 to 152.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	75	SF	\$120	\$9,060	
48230	139.3 to 145.3 feet	Vertical Change	-39	5 ft	30	REF			
53095	162.7 to 163.7 feet	Vertical Change	-27	5 ft	5	LF	\$75	\$375	
8056	165.3 to 176.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,540	
50043	173.3 to 174.3 feet	Vertical Change	-33	5 ft	5	REF			
51703	194.5 to 195.5 feet	Vertical Change	-3	5 ft	5	LF	\$75	\$375	
49392	205.0 to 206.0 feet	Vertical Change	-35	5 ft	5	LF	\$75	\$375	
52595	246.1 to 247.1 feet	Vertical Change	-28	5 ft	5	LF	\$75	\$375	
50044	256.4 to 257.4 feet	Vertical Change	-33	5 ft	5	LF	\$75	\$375	
8058	265.4 to 276.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,720	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221340	WASHINGTON RD	SIDEWALK BEGINS	MAPLE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47094	275.3 to 276.3 feet	Vertical Change	-.43	5 ft	5	REF		
47983	279.5 to 280.5 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375
45253	284.0 to 285.0 feet	Vertical Change	-.51	5 ft	5	SF	\$75	\$375
52596	287.5 to 288.5 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375
54162	289.2 to 290.2 feet	Vertical Change	.29	5 ft	5	LF	\$75	\$375
8059	293.8 to 313.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	98	SF	\$120	\$11,700
53638	296.1 to 297.1 feet	Vertical Change	-.26	5 ft	5	REF		
53639	305.3 to 306.3 feet	Vertical Change	-.26	5 ft	5	REF		
51704	310.6 to 311.6 feet	Vertical Change	-.3	5 ft	5	REF		

TOTAL COST FOR: N side of WASHINGTON RD Starting at: SIDEWALK BEGINS \$86,265.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221343	MAPLE ST	WASHINGTON RD	OAK CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
8061	0.0 to 22.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	112	SF	\$120	\$13,380
41649	3.7 to 4.7 feet	Vertical Change	-.93	5 ft	5	REF		
44251	10.9 to 11.9 feet	Vertical Change	-.56	5 ft	5	REF		
49393	14.9 to 15.9 feet	Vertical Change	-.35	5 ft	5	REF		
50415	19.4 to 20.4 feet	Vertical Change	-.32	5 ft	5	REF		
8066	22.3 to 233.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	1055	SF	\$120	\$126,600
50416	24.1 to 25.1 feet	Vertical Change	-.32	5 ft	5	REF		
48514	29.0 to 30.0 feet	Vertical Change	-.38	5 ft	5	REF		
50045	33.9 to 34.9 feet	Vertical Change	-.33	5 ft	5	REF		
50798	38.8 to 39.8 feet	Vertical Change	-.31	5 ft	5	REF		
51705	43.7 to 44.7 feet	Vertical Change	-.3	5 ft	5	REF		
48231	48.6 to 49.6 feet	Vertical Change	-.39	5 ft	5	REF		
51706	53.5 to 54.5 feet	Vertical Change	-.3	5 ft	5	REF		
49094	58.4 to 59.4 feet	Vertical Change	-.36	5 ft	5	REF		
53096	63.3 to 64.3 feet	Vertical Change	-.27	5 ft	5	REF		
53097	68.2 to 69.2 feet	Vertical Change	-.27	5 ft	5	REF		
50417	73.1 to 74.1 feet	Vertical Change	-.32	5 ft	5	REF		
50046	77.8 to 78.8 feet	Vertical Change	-.33	5 ft	5	REF		
49715	82.7 to 83.7 feet	Vertical Change	-.34	5 ft	5	REF		
49394	87.5 to 88.5 feet	Vertical Change	-.35	5 ft	5	REF		
52129	92.5 to 93.5 feet	Vertical Change	-.29	5 ft	5	REF		
50418	97.3 to 98.3 feet	Vertical Change	-.32	5 ft	5	REF		
53098	102.2 to 103.2 feet	Vertical Change	-.27	5 ft	5	REF		
49395	112.1 to 113.1 feet	Vertical Change	-.35	5 ft	5	REF		
50419	116.8 to 117.8 feet	Vertical Change	-.32	5 ft	5	REF		
50047	121.6 to 122.6 feet	Vertical Change	-.33	5 ft	5	REF		
47984	126.5 to 127.5 feet	Vertical Change	-.4	5 ft	5	REF		
50799	131.3 to 132.3 feet	Vertical Change	-.31	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221343	MAPLE ST	WASHINGTON RD	OAK CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46628	136.0 to 137.0 feet	Vertical Change	-.45	5 ft	5	REF		
53099	141.1 to 142.1 feet	Vertical Change	-.27	5 ft	5	REF		
48232	145.9 to 146.9 feet	Vertical Change	-.39	5 ft	5	REF		
50420	150.8 to 151.8 feet	Vertical Change	-.32	5 ft	5	REF		
48808	155.6 to 156.6 feet	Vertical Change	-.37	5 ft	5	REF		
52597	160.5 to 161.5 feet	Vertical Change	-.28	5 ft	5	REF		
50421	170.2 to 171.2 feet	Vertical Change	-.32	5 ft	5	REF		
51707	175.3 to 176.3 feet	Vertical Change	-.3	5 ft	5	REF		
56991	184.6 to 185.6 feet	Vertical Change	.59	5 ft	5	REF		
50048	189.4 to 190.4 feet	Vertical Change	-.33	5 ft	5	REF		
53640	199.0 to 200.0 feet	Vertical Change	-.26	5 ft	5	REF		
50422	218.5 to 219.5 feet	Vertical Change	-.32	5 ft	5	REF		
54011	228.2 to 229.2 feet	Vertical Change	-.25	5 ft	5	REF		
53100	233.0 to 234.0 feet	Vertical Change	-.27	5 ft	5	REF		
8080	233.3 to 247.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	71	SF	\$120	\$8,520
50800	237.8 to 238.8 feet	Vertical Change	-.31	5 ft	5	REF		
49716	242.6 to 243.6 feet	Vertical Change	-.34	5 ft	5	REF		
49717	247.3 to 248.3 feet	Vertical Change	-.34	5 ft	5	REF		
8082	247.5 to 319.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	358	SF	\$120	\$42,960
51708	267.0 to 268.0 feet	Vertical Change	-.3	5 ft	5	REF		
53101	282.8 to 283.8 feet	Vertical Change	-.27	5 ft	5	REF		
49718	300.9 to 301.9 feet	Vertical Change	-.34	5 ft	5	REF		
41608	301.2 to 303.9 feet	Vertical Change	-.97	5 ft	13	REF		
51709	308.3 to 309.3 feet	Vertical Change	-.3	5 ft	5	REF		
50801	325.8 to 326.8 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375
52598	332.4 to 333.4 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375
49396	347.1 to 348.1 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$375
49719	354.6 to 355.6 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221343	MAPLE ST	WASHINGTON RD	OAK CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
8091	365.1 to 418.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	265	SF	\$120	\$31,800
53102	369.2 to 370.2 feet	Vertical Change	-27	5 ft	5	REF		
52599	379.4 to 380.4 feet	Vertical Change	-28	5 ft	5	REF		
47570	384.7 to 385.7 feet	Vertical Change	-41	5 ft	5	REF		
51710	389.9 to 390.9 feet	Vertical Change	-3	5 ft	5	REF		
47985	395.1 to 396.1 feet	Vertical Change	-4	5 ft	5	REF		
49720	400.1 to 401.1 feet	Vertical Change	-34	5 ft	5	REF		
52130	405.1 to 406.1 feet	Vertical Change	-29	5 ft	5	REF		
50423	410.4 to 411.4 feet	Vertical Change	-32	5 ft	5	REF		

TOTAL COST FOR: E side of MAPLE ST Starting at: WASHINGTON RD \$224,760.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908221346	OAK CT	ELM AVE	ELM AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
8098	0.0 to 5.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,480	
52131	1.9 to 2.9 feet	Vertical Change	-.29	5 ft	5	REF			
8100	5.8 to 31.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	127	SF	\$120	\$15,180	
49397	6.4 to 7.4 feet	Vertical Change	-.35	5 ft	5	REF			
49721	11.0 to 12.0 feet	Vertical Change	-.34	5 ft	5	REF			
58261	27.3 to 53.0 feet	Driveway				REF			
8102	35.5 to 50.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	74	SF	\$40	\$2,960	
50424	41.9 to 42.9 feet	Vertical Change	-.32	5 ft	5	REF			
40267	49.5 to 51.5 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
8103	54.3 to 61.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	34	SF	\$120	\$4,080	
58262	57.4 to 92.0 feet	Driveway				REF			
47986	61.3 to 62.3 feet	Vertical Change	-.4	5 ft	5	REF			
8105	64.7 to 88.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	119	SF	\$40	\$4,740	
47095	71.6 to 72.6 feet	Vertical Change	-.43	5 ft	5	REF			
52132	79.8 to 80.8 feet	Vertical Change	-.29	5 ft	5	REF			
8109	88.4 to 90.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	9	SF	\$40	\$340	
49095	92.3 to 93.3 feet	Vertical Change	-.36	5 ft	5	REF			
8110	93.1 to 143.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	254	SF	\$120	\$30,420	
49398	97.0 to 98.0 feet	Vertical Change	-.35	5 ft	5	REF			
48809	101.9 to 102.9 feet	Vertical Change	-.37	5 ft	5	REF			
48810	106.8 to 107.8 feet	Vertical Change	-.37	5 ft	5	REF			
49722	111.9 to 112.9 feet	Vertical Change	-.34	5 ft	5	REF			
52133	116.9 to 117.9 feet	Vertical Change	-.29	5 ft	5	REF			
51711	121.8 to 122.8 feet	Vertical Change	-.3	5 ft	5	REF			
49723	126.8 to 127.8 feet	Vertical Change	-.34	5 ft	5	REF			
48811	131.9 to 132.9 feet	Vertical Change	-.37	5 ft	5	REF			
58263	136.7 to 172.9 feet	Driveway				REF			
51712	141.7 to 142.7 feet	Vertical Change	-.3	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221346	OAK CT	ELM AVE	ELM AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
8114	146.8 to 171.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	122	SF	\$40	\$4,900
50425	156.9 to 157.9 feet	Vertical Change	-32	5 ft	5	REF		
52600	163.8 to 164.8 feet	Vertical Change	-28	5 ft	5	REF		
40268	170.8 to 172.6 feet	Running Slope	5.0-6.0%	5 ft	9	REF		
8119	174.5 to 175.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$660
50049	175.1 to 176.1 feet	Vertical Change	-33	5 ft	5	REF		
8120	175.6 to 182.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320
58264	177.8 to 201.6 feet	Driveway				REF		
8122	182.8 to 183.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$200
46409	182.9 to 183.9 feet	Vertical Change	-46	5 ft	5	REF		
8123	187.0 to 200.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	67	SF	\$40	\$2,660
46629	193.3 to 194.3 feet	Vertical Change	-45	5 ft	5	REF		
49096	204.1 to 205.1 feet	Vertical Change	-36	5 ft	5	REF		
8126	204.5 to 215.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	57	SF	\$120	\$6,780
48812	208.7 to 209.7 feet	Vertical Change	-37	5 ft	5	REF		
46170	213.4 to 214.4 feet	Vertical Change	-47	5 ft	5	REF		
8127	215.8 to 260.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	222	SF	\$120	\$26,580
48813	218.9 to 219.9 feet	Vertical Change	-37	5 ft	5	REF		
44684	225.0 to 226.0 feet	Vertical Change	-54	5 ft	5	REF		
49399	230.9 to 231.9 feet	Vertical Change	-35	5 ft	5	REF		
49400	236.9 to 237.9 feet	Vertical Change	-35	5 ft	5	REF		
48814	242.9 to 243.9 feet	Vertical Change	-37	5 ft	5	REF		
46171	248.8 to 249.8 feet	Vertical Change	-47	5 ft	5	REF		
49724	254.5 to 255.5 feet	Vertical Change	-34	5 ft	5	REF		
58265	255.0 to 283.5 feet	Driveway				REF		
48815	260.2 to 261.2 feet	Vertical Change	-37	5 ft	5	REF		
8130	263.6 to 271.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	40	SF	\$40	\$1,620
8132	271.7 to 281.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	49	SF	\$40	\$1,960

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221346	OAK CT	ELM AVE	ELM AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44063	272.5 to 273.5 feet	Vertical Change	-.57	5 ft	5	REF		
8134	281.5 to 282.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200
40269	281.5 to 283.1 feet	Running Slope	5.0-6.0%	5 ft	8	REF		
49725	285.2 to 286.2 feet	Vertical Change	-.34	5 ft	5	REF		
8135	285.2 to 286.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$780
8136	286.5 to 294.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,620
58266	287.1 to 315.7 feet	Driveway				REF		
46865	293.1 to 294.1 feet	Vertical Change	-.44	5 ft	5	REF		
8138	297.3 to 313.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	82	SF	\$40	\$3,260
49726	303.9 to 304.9 feet	Vertical Change	-.34	5 ft	5	REF		
40270	312.3 to 314.0 feet	Running Slope	6.0-7.0%	5 ft	9	REF		
49727	316.4 to 317.4 feet	Vertical Change	-.34	5 ft	5	REF		
8141	316.9 to 322.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	27	SF	\$120	\$3,180
8142	322.2 to 331.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,280
45757	323.2 to 324.2 feet	Vertical Change	-.49	5 ft	5	REF		
58267	326.6 to 353.5 feet	Driveway				REF		
49097	330.3 to 331.3 feet	Vertical Change	-.36	5 ft	5	REF		
8144	334.0 to 349.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	78	SF	\$40	\$3,100
48233	341.9 to 342.9 feet	Vertical Change	-.39	5 ft	5	REF		
8148	349.5 to 351.7 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	11	SF	\$40	\$440
40271	349.9 to 351.4 feet	Running Slope	6.0-7.0%	5 ft	8	REF		
8150	353.8 to 356.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	13	SF	\$40	\$520
48816	353.9 to 356.6 feet	Vertical Change	-.37	5 ft	14	REF		
58268	353.9 to 377.9 feet	Driveway				REF		
8151	359.9 to 365.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	26	SF	\$40	\$1,020
8153	365.0 to 376.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	57	SF	\$40	\$2,260
40272	375.3 to 377.5 feet	Running Slope	6.0-7.0%	5 ft	11	REF		
48818	379.4 to 380.4 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221346	OAK CT	ELM AVE	ELM AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51713	383.3 to 384.3 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375
8155	385.5 to 436.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	254	SF	\$120	\$30,420
49098	387.3 to 388.3 feet	Vertical Change	-.36	5 ft	5	REF		
49728	390.6 to 391.6 feet	Vertical Change	-.34	5 ft	5	REF		
46630	393.7 to 394.7 feet	Vertical Change	-.45	5 ft	5	REF		
48515	399.1 to 400.1 feet	Vertical Change	-.38	5 ft	5	REF		
50802	405.5 to 406.5 feet	Vertical Change	-.31	5 ft	5	REF		
48516	411.0 to 412.0 feet	Vertical Change	-.38	5 ft	5	REF		
48819	416.5 to 417.5 feet	Vertical Change	-.37	5 ft	5	REF		
48820	421.4 to 422.4 feet	Vertical Change	-.37	5 ft	5	REF		
48234	426.4 to 427.4 feet	Vertical Change	-.39	5 ft	5	REF		
58269	430.3 to 454.8 feet	Driveway				REF		
48821	431.1 to 432.1 feet	Vertical Change	-.37	5 ft	5	REF		
46631	435.6 to 436.6 feet	Vertical Change	-.45	5 ft	5	REF		
8163	439.1 to 453.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	70	SF	\$40	\$2,800
49401	445.5 to 446.5 feet	Vertical Change	-.35	5 ft	5	REF		
47987	456.8 to 457.8 feet	Vertical Change	-.4	5 ft	5	REF		
8165	457.2 to 464.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,560
58270	459.4 to 496.8 feet	Driveway				REF		
8167	464.8 to 465.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$200
48517	465.1 to 466.1 feet	Vertical Change	-.38	5 ft	5	REF		
8168	468.7 to 494.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	130	SF	\$40	\$5,180
49729	477.2 to 478.2 feet	Vertical Change	-.34	5 ft	5	REF		
47988	497.0 to 498.0 feet	Vertical Change	-.4	5 ft	5	REF		
8172	497.6 to 516.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	94	SF	\$120	\$11,280
49099	501.8 to 502.8 feet	Vertical Change	-.36	5 ft	5	REF		
49402	506.3 to 507.3 feet	Vertical Change	-.35	5 ft	5	REF		
49100	511.5 to 512.5 feet	Vertical Change	-.36	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221346	OAK CT	ELM AVE	ELM AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
8173	516.4 to 539.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	116	SF	\$120	\$13,860
53641	516.7 to 517.7 feet	Vertical Change	-26	5 ft	5	REF		
8175	539.5 to 548.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	44	SF	\$120	\$5,220
58271	541.7 to 577.2 feet	Driveway				REF		
8177	549.8 to 553.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	20	SF	\$40	\$800
8179	553.8 to 575.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	109	SF	\$40	\$4,340
52134	578.8 to 579.8 feet	Vertical Change	-29	5 ft	5	REF		
8182	579.0 to 580.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$660
8183	580.1 to 588.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$4,980
58272	583.7 to 607.8 feet	Driveway				REF		
8185	592.1 to 605.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	69	SF	\$40	\$2,760
53103	597.7 to 598.7 feet	Vertical Change	-27	5 ft	5	REF		
40273	604.7 to 606.6 feet	Running Slope	6.0-7.0%	5 ft	9	REF		
46410	608.9 to 609.9 feet	Vertical Change	-46	5 ft	5	REF		
8188	609.7 to 638.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	145	SF	\$120	\$17,460
48518	617.6 to 618.6 feet	Vertical Change	-38	5 ft	5	REF		
48235	622.4 to 623.4 feet	Vertical Change	-39	5 ft	5	REF		
45758	627.5 to 628.5 feet	Vertical Change	-49	5 ft	5	REF		
48236	632.4 to 633.4 feet	Vertical Change	-39	5 ft	5	REF		
47325	637.3 to 638.3 feet	Vertical Change	-42	5 ft	5	REF		

TOTAL COST FOR: N side of OAK CT Starting at: ELM AVE \$240,810.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
N	1908221347	ELM AVE	OAK CT	CEDAR CT				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
8189	0.0 to 60.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	301	SF	\$120	\$36,060
48519	2.8 to 3.8 feet	Vertical Change	-38	5 ft	5	REF		
50803	7.7 to 8.7 feet	Vertical Change	-31	5 ft	5	REF		
50426	12.6 to 13.6 feet	Vertical Change	-32	5 ft	5	REF		
54012	17.6 to 18.6 feet	Vertical Change	-25	5 ft	5	REF		
50427	27.6 to 28.6 feet	Vertical Change	-32	5 ft	5	REF		
53642	37.4 to 38.4 feet	Vertical Change	-26	5 ft	5	REF		
52135	42.3 to 43.3 feet	Vertical Change	-29	5 ft	5	REF		
52136	53.1 to 54.1 feet	Vertical Change	-29	5 ft	5	REF		
51714	58.2 to 59.2 feet	Vertical Change	-3	5 ft	5	REF		
8194	60.1 to 86.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	133	SF	\$120	\$15,960
51715	63.1 to 64.1 feet	Vertical Change	-3	5 ft	5	REF		
52137	68.1 to 69.1 feet	Vertical Change	-29	5 ft	5	REF		
52601	73.1 to 74.1 feet	Vertical Change	-28	5 ft	5	REF		
52138	78.2 to 79.2 feet	Vertical Change	-29	5 ft	5	REF		
52139	83.2 to 84.2 feet	Vertical Change	-29	5 ft	5	REF		
8197	90.1 to 183.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	468	SF	\$120	\$56,160
50804	92.7 to 93.7 feet	Vertical Change	-31	5 ft	5	REF		
53104	97.8 to 98.8 feet	Vertical Change	-27	5 ft	5	REF		
53105	162.9 to 163.9 feet	Vertical Change	-27	5 ft	5	REF		
49403	167.8 to 168.8 feet	Vertical Change	-35	5 ft	5	REF		
48520	172.7 to 173.7 feet	Vertical Change	-38	5 ft	5	REF		
49101	177.8 to 178.8 feet	Vertical Change	-36	5 ft	5	REF		

TOTAL COST FOR: N side of ELM AVE Starting at: OAK CT \$108,180.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908221351	CEDAR CT	ELM AVE	ELM AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
8210	0.8 to 31.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	152	SF	\$120	\$18,240	
47989	2.1 to 3.1 feet	Vertical Change	-.4	5 ft	5	REF			
57150	6.4 to 7.4 feet	Vertical Change	.65	5 ft	5	REF			
48822	15.6 to 16.6 feet	Vertical Change	-.37	5 ft	5	REF			
53643	25.5 to 26.5 feet	Vertical Change	-.26	5 ft	5	REF			
58273	26.0 to 52.0 feet	Driveway				REF			
8213	34.6 to 47.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	64	SF	\$40	\$2,560	
8215	47.4 to 50.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	15	SF	\$40	\$600	
40274	49.6 to 51.5 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
52140	53.2 to 54.2 feet	Vertical Change	-.29	5 ft	5	REF			
8217	53.3 to 61.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	40	SF	\$120	\$4,740	
58274	55.7 to 93.2 feet	Driveway				REF			
49404	60.6 to 61.6 feet	Vertical Change	-.35	5 ft	5	REF			
8220	64.4 to 87.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	117	SF	\$40	\$4,700	
50805	68.7 to 69.7 feet	Vertical Change	-.31	5 ft	5	REF			
53106	71.8 to 72.8 feet	Vertical Change	-.27	5 ft	5	REF			
48237	79.1 to 80.1 feet	Vertical Change	-.39	5 ft	5	REF			
8226	87.9 to 90.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	14	SF	\$40	\$560	
49102	92.1 to 93.1 feet	Vertical Change	-.36	5 ft	5	REF			
8228	92.3 to 150.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	292	SF	\$40	\$11,680	
46632	101.5 to 102.5 feet	Vertical Change	-.45	5 ft	5	REF			
48521	106.5 to 107.5 feet	Vertical Change	-.38	5 ft	5	REF			
50050	111.6 to 112.6 feet	Vertical Change	-.33	5 ft	5	REF			
50051	117.0 to 118.0 feet	Vertical Change	-.33	5 ft	5	REF			
51716	122.3 to 123.3 feet	Vertical Change	-.3	5 ft	5	REF			
50428	137.8 to 138.8 feet	Vertical Change	-.32	5 ft	5	REF			
58275	148.4 to 174.2 feet	Driveway				REF			
8232	150.7 to 153.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	16	SF	\$40	\$620	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908221351	CEDAR CT	ELM AVE	ELM AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
8234	157.8 to 171.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	69	SF	\$40	\$2,780	
40275	171.1 to 173.5 feet	Running Slope	5.0-6.0%	5 ft	12	REF			
8236	175.2 to 183.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	42	SF	\$120	\$4,980	
58276	178.8 to 219.2 feet	Driveway				REF			
48522	182.6 to 183.6 feet	Vertical Change	-.38	5 ft	5	REF			
8238	186.7 to 215.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	142	SF	\$40	\$5,680	
46633	211.0 to 212.0 feet	Vertical Change	-.45	5 ft	5	REF			
8246	218.2 to 257.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	197	SF	\$40	\$7,860	
52602	220.1 to 221.1 feet	Vertical Change	-.28	5 ft	5	REF			
50052	225.9 to 226.9 feet	Vertical Change	-.33	5 ft	5	REF			
46411	231.8 to 232.8 feet	Vertical Change	-.46	5 ft	5	REF			
47990	237.7 to 238.7 feet	Vertical Change	-.4	5 ft	5	REF			
45537	243.5 to 244.5 feet	Vertical Change	-.5	5 ft	5	REF			
53107	249.5 to 250.5 feet	Vertical Change	-.27	5 ft	5	REF			
58277	250.8 to 277.3 feet	Driveway				REF			
42487	255.6 to 256.6 feet	Vertical Change	-.69	5 ft	5	REF			
8250	261.0 to 268.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	36	SF	\$40	\$1,440	
45254	266.5 to 267.5 feet	Vertical Change	-.51	5 ft	5	REF			
8252	268.2 to 275.6 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	37	SF	\$40	\$1,480	
49730	279.2 to 280.2 feet	Vertical Change	-.34	5 ft	5	REF			
8254	279.6 to 289.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	48	SF	\$120	\$5,760	
58278	282.3 to 311.6 feet	Driveway				REF			
47096	288.0 to 289.0 feet	Vertical Change	-.43	5 ft	5	REF			
8257	292.6 to 308.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	81	SF	\$40	\$3,240	
8261	311.4 to 316.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	24	SF	\$40	\$940	
49405	311.5 to 312.5 feet	Vertical Change	-.35	5 ft	5	REF			
8263	316.1 to 325.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,700	
58279	319.0 to 347.6 feet	Driveway				REF			
8267	329.7 to 336.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	32	SF	\$40	\$1,260	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908221351	CEDAR CT	ELM AVE	ELM AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
8269	336.0 to 345.4 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	47	SF	\$40	\$1,880	
8271	348.7 to 351.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	16	SF	\$120	\$1,860	
58280	348.8 to 372.7 feet	Driveway				REF			
8272	354.8 to 370.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	80	SF	\$40	\$3,200	
8277	374.4 to 375.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$900	
8278	375.9 to 426.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	252	SF	\$120	\$30,240	
52141	378.8 to 379.8 feet	Vertical Change	-29	5 ft	5	REF			
50429	389.3 to 390.3 feet	Vertical Change	-32	5 ft	5	REF			
49103	411.4 to 412.4 feet	Vertical Change	-36	5 ft	5	REF			
58281	420.7 to 446.1 feet	Driveway				REF			
8282	429.9 to 443.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	68	SF	\$40	\$2,700	
52603	436.2 to 437.2 feet	Vertical Change	-28	5 ft	5	REF			
42012	446.9 to 447.9 feet	Vertical Change	-77	5 ft	5	REF			
8287	447.5 to 453.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	28	SF	\$120	\$3,360	
58282	451.8 to 477.1 feet	Driveway				REF			
8288	453.1 to 455.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	14	SF	\$40	\$540	
46866	455.0 to 456.0 feet	Vertical Change	-44	5 ft	5	REF			
8290	460.3 to 474.0 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	69	SF	\$40	\$2,740	
49104	467.9 to 468.9 feet	Vertical Change	-36	5 ft	5	REF			
50053	476.9 to 477.9 feet	Vertical Change	-33	5 ft	5	REF			
8292	477.2 to 540.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	317	SF	\$40	\$12,660	
47991	483.5 to 484.5 feet	Vertical Change	-4	5 ft	5	REF			
47097	490.1 to 491.1 feet	Vertical Change	-43	5 ft	5	REF			
47326	495.1 to 496.1 feet	Vertical Change	-42	5 ft	5	REF			
45961	500.1 to 501.1 feet	Vertical Change	-48	5 ft	5	REF			
47098	504.6 to 505.6 feet	Vertical Change	-43	5 ft	5	REF			
47992	509.5 to 510.5 feet	Vertical Change	-4	5 ft	5	REF			
52142	523.5 to 524.5 feet	Vertical Change	-29	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221351	CEDAR CT	ELM AVE	ELM AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
52143	533.0 to 534.0 feet	Vertical Change	-.29	5 ft	5	REF		
58283	534.7 to 568.8 feet	Driveway				REF		
48523	537.7 to 538.7 feet	Vertical Change	-.38	5 ft	5	REF		
8297	544.1 to 566.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	113	SF	\$40	\$4,540
51717	550.8 to 551.8 feet	Vertical Change	-.3	5 ft	5	REF		
8299	569.5 to 577.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	41	SF	\$120	\$4,860
50054	569.7 to 570.7 feet	Vertical Change	-.33	5 ft	5	REF		
58284	572.8 to 598.3 feet	Driveway				REF		
47993	576.8 to 577.8 feet	Vertical Change	-.4	5 ft	5	REF		
8301	581.3 to 596.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	74	SF	\$40	\$2,940
48524	588.5 to 589.5 feet	Vertical Change	-.38	5 ft	5	REF		
49406	599.5 to 600.5 feet	Vertical Change	-.35	5 ft	5	REF		
8303	599.7 to 617.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	88	SF	\$120	\$10,500
49105	604.0 to 605.0 feet	Vertical Change	-.36	5 ft	5	REF		
48823	613.5 to 614.5 feet	Vertical Change	-.37	5 ft	5	REF		
8305	617.2 to 627.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,120
48525	623.2 to 624.2 feet	Vertical Change	-.38	5 ft	5	REF		
8307	627.4 to 630.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	17	SF	\$120	\$2,040
TOTAL COST FOR: N side of CEDAR CT Starting at: ELM AVE							\$175,900.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908221353	ELM AVE	CEDAR CT	BIRCH CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
8308	0.0 to 51.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	257	SF	\$120	\$30,780	
48238	2.9 to 3.9 feet	Vertical Change	-39	5 ft	5	REF			
53644	11.6 to 12.6 feet	Vertical Change	-26	5 ft	5	REF			
52144	15.2 to 16.2 feet	Vertical Change	-29	5 ft	5	REF			
50806	38.8 to 39.8 feet	Vertical Change	-31	5 ft	5	REF			
8314	51.3 to 70.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	96	SF	\$120	\$11,520	
50807	64.2 to 65.2 feet	Vertical Change	-31	5 ft	5	REF			
53108	69.3 to 70.3 feet	Vertical Change	-27	5 ft	5	REF			
8316	70.5 to 113.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	216	SF	\$120	\$25,920	
50430	74.1 to 75.1 feet	Vertical Change	-32	5 ft	5	REF			
49407	79.0 to 80.0 feet	Vertical Change	-35	5 ft	5	REF			
52604	88.4 to 89.4 feet	Vertical Change	-28	5 ft	5	REF			
51718	93.4 to 94.4 feet	Vertical Change	-3	5 ft	5	REF			
46172	98.2 to 99.2 feet	Vertical Change	-47	5 ft	5	REF			
46412	103.4 to 104.4 feet	Vertical Change	-46	5 ft	5	REF			
52145	108.8 to 109.8 feet	Vertical Change	-29	5 ft	5	REF			
46173	112.1 to 113.1 feet	Vertical Change	-47	5 ft	5	REF			
8320	113.7 to 130.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	84	SF	\$120	\$10,080	
44870	117.0 to 118.0 feet	Vertical Change	-53	5 ft	5	REF			
47099	122.0 to 123.0 feet	Vertical Change	-43	5 ft	5	REF			
44455	127.0 to 128.0 feet	Vertical Change	-55	5 ft	5	REF			
8322	130.5 to 160.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	151	SF	\$120	\$18,120	
45538	131.9 to 132.9 feet	Vertical Change	-5	5 ft	5	REF			
45962	136.8 to 137.8 feet	Vertical Change	-48	5 ft	5	REF			
41675	141.8 to 142.8 feet	Vertical Change	-91	5 ft	5	REF			
45759	146.9 to 147.9 feet	Vertical Change	-49	5 ft	5	REF			
45052	151.9 to 152.9 feet	Vertical Change	-52	5 ft	5	REF			
45963	156.9 to 157.9 feet	Vertical Change	-48	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221353	ELM AVE	CEDAR CT	BIRCH CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
8324	160.7 to 174.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	67	SF	\$120	\$8,040
41602	161.8 to 162.8 feet	Vertical Change	-.98	5 ft	5	REF		
57147	161.9 to 162.9 feet	Vertical Change	.64	5 ft	5	REF		
46413	166.9 to 167.9 feet	Vertical Change	-.46	5 ft	5	REF		
45053	171.8 to 172.8 feet	Vertical Change	-.52	5 ft	5	REF		
8329	174.1 to 189.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	77	SF	\$120	\$9,180
45539	176.7 to 177.7 feet	Vertical Change	-.5	5 ft	5	REF		
50431	182.7 to 183.7 feet	Vertical Change	-.32	5 ft	5	REF		
44456	187.6 to 188.6 feet	Vertical Change	-.55	5 ft	5	REF		
TOTAL COST FOR: N side of ELM AVE Starting at: CEDAR CT							\$113,640.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908221356	BIRCH CT	ELM AVE	ELM AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
8332	3.4 to 31.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	141	SF	\$120	\$16,920	
47327	15.2 to 16.2 feet	Vertical Change	-.42	5 ft	5	REF			
53109	21.2 to 22.2 feet	Vertical Change	-.27	5 ft	5	REF			
58285	25.9 to 53.4 feet	Driveway				REF			
43886	26.2 to 27.2 feet	Vertical Change	-.58	5 ft	5	REF			
49106	31.2 to 32.2 feet	Vertical Change	-.36	5 ft	5	REF			
8334	34.5 to 49.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	76	SF	\$40	\$3,020	
47571	41.8 to 42.8 feet	Vertical Change	-.41	5 ft	5	REF			
8339	53.6 to 55.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$960	
8340	55.2 to 61.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,540	
58286	56.4 to 82.3 feet	Driveway				REF			
45054	56.9 to 57.9 feet	Vertical Change	-.52	5 ft	5	REF			
8341	66.4 to 80.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	68	SF	\$40	\$2,720	
40276	78.3 to 80.4 feet	Running Slope	6.0-7.0%	5 ft	11	REF			
46174	82.5 to 83.5 feet	Vertical Change	-.47	5 ft	5	REF			
8343	83.7 to 96.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	66	SF	\$120	\$7,920	
47994	87.8 to 88.8 feet	Vertical Change	-.4	5 ft	5	REF			
43411	92.7 to 93.7 feet	Vertical Change	-.61	5 ft	5	REF			
58287	92.7 to 112.2 feet	Driveway				REF			
8345	96.9 to 98.1 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$240	
41178	97.7 to 98.7 feet	Vertical Change	-3.13	5 ft	5	REF			
8346	101.5 to 109.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	41	SF	\$40	\$1,640	
47572	105.3 to 106.3 feet	Vertical Change	-.41	5 ft	5	REF			
8348	113.3 to 116.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	18	SF	\$120	\$2,100	
8349	117.9 to 125.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,380	
58288	119.4 to 146.7 feet	Driveway				REF			
8351	128.8 to 143.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	71	SF	\$40	\$2,840	
48526	135.8 to 136.8 feet	Vertical Change	-.38	5 ft	5	REF			
42781	146.9 to 147.9 feet	Vertical Change	-.66	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908221356	BIRCH CT	ELM AVE	ELM AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
8355	147.4 to 154.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	35	SF	\$40	\$1,380	
49107	151.7 to 152.7 feet	Vertical Change	-.36	5 ft	5	REF			
8357	154.3 to 174.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	100	SF	\$120	\$12,000	
53645	156.7 to 157.7 feet	Vertical Change	-.26	5 ft	5	REF			
48527	162.1 to 163.1 feet	Vertical Change	-.38	5 ft	5	REF			
45540	167.4 to 168.4 feet	Vertical Change	-.5	5 ft	5	REF			
8359	174.3 to 181.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320	
52605	177.5 to 178.5 feet	Vertical Change	-.28	5 ft	5	REF			
58289	177.7 to 204.5 feet	Driveway				REF			
53110	181.9 to 182.9 feet	Vertical Change	-.27	5 ft	5	REF			
8360	185.3 to 193.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	43	SF	\$40	\$1,700	
46414	193.0 to 194.0 feet	Vertical Change	-.46	5 ft	5	REF			
8362	193.8 to 201.3 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	38	SF	\$40	\$1,500	
41299	203.9 to 204.9 feet	Vertical Change	-1.57	5 ft	5	REF			
8364	204.7 to 222.4 feet	Cross Slope (PAR)	7.0-8.0%	5 ft	89	SF	\$120	\$10,620	
47573	211.2 to 212.2 feet	Vertical Change	-.41	5 ft	5	REF			
58290	221.8 to 244.5 feet	Driveway				REF			
8368	222.4 to 224.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	9	SF	\$40	\$360	
42013	222.9 to 223.9 feet	Vertical Change	-.77	5 ft	5	REF			
8369	224.2 to 225.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	5	SF	\$40	\$200	
8370	226.3 to 241.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	78	SF	\$40	\$3,120	
8374	245.3 to 246.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$600	
8375	246.3 to 249.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740	
49408	249.1 to 250.1 feet	Vertical Change	-.35	5 ft	5	REF			
58291	249.3 to 274.8 feet	Driveway				REF			
47995	253.7 to 254.7 feet	Vertical Change	-.4	5 ft	5	REF			
8376	257.5 to 259.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	11	SF	\$40	\$440	
8378	259.7 to 273.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	68	SF	\$40	\$2,720	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908221356	BIRCH CT	ELM AVE	ELM AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
40277	270.6 to 272.4 feet	Running Slope	8.0-9.0%	5 ft	9	REF			
44871	275.0 to 276.0 feet	Vertical Change	-.53	5 ft	5	REF			
8381	275.6 to 276.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600	
46175	281.9 to 282.9 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375	
58292	287.3 to 315.1 feet	Driveway				REF			
44872	288.2 to 289.2 feet	Vertical Change	-.53	5 ft	5	REF			
8382	290.9 to 293.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	12	SF	\$40	\$480	
50432	293.6 to 294.6 feet	Vertical Change	-.32	5 ft	5	REF			
56915	293.7 to 294.7 feet	Vertical Change	.51	5 ft	5	REF			
8383	297.4 to 312.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	77	SF	\$40	\$3,080	
46415	304.3 to 305.3 feet	Vertical Change	-.46	5 ft	5	REF			
8385	316.2 to 319.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	15	SF	\$120	\$1,800	
8387	319.2 to 324.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,420	
8390	324.9 to 329.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	22	SF	\$120	\$2,580	
8392	329.2 to 344.2 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	75	SF	\$120	\$9,000	
48239	340.1 to 341.1 feet	Vertical Change	-.39	5 ft	5	REF			
8395	345.1 to 347.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	11	SF	\$120	\$1,260	
48824	345.5 to 346.5 feet	Vertical Change	-.37	5 ft	5	REF			
8397	347.2 to 353.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,900	
58293	349.8 to 376.1 feet	Driveway				REF			
49731	352.0 to 353.0 feet	Vertical Change	-.34	5 ft	5	REF			
8399	356.8 to 372.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	80	SF	\$40	\$3,180	
40278	370.7 to 373.2 feet	Running Slope	5.0-6.0%	5 ft	13	REF			
8403	376.3 to 378.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	13	SF	\$40	\$500	
53111	379.0 to 380.0 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
8404	381.5 to 387.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,780	
45964	384.5 to 385.5 feet	Vertical Change	-.48	5 ft	5	REF			
45541	389.4 to 390.4 feet	Vertical Change	-.5	5 ft	5	SF	\$75	\$375	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221356	BIRCH CT	ELM AVE	ELM AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
8405	393.2 to 414.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	107	SF	\$120	\$12,780
48528	399.5 to 400.5 feet	Vertical Change	-.38	5 ft	5	REF		
46867	404.5 to 405.5 feet	Vertical Change	-.44	5 ft	5	REF		
43887	409.4 to 410.4 feet	Vertical Change	-.58	5 ft	5	REF		
58294	410.6 to 434.2 feet	Driveway				REF		
8408	417.7 to 431.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	71	SF	\$40	\$2,840
40280	431.1 to 432.4 feet	Running Slope	6.0-7.0%	5 ft	7	REF		
46176	435.2 to 436.2 feet	Vertical Change	-.47	5 ft	5	REF		
8412	435.5 to 436.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$660
8413	436.6 to 444.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800
58295	439.5 to 464.4 feet	Driveway				REF		
45965	439.6 to 440.6 feet	Vertical Change	-.48	5 ft	5	REF		
8415	448.7 to 461.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	66	SF	\$40	\$2,640
40281	461.3 to 463.3 feet	Running Slope	5.0-6.0%	5 ft	10	REF		
8417	466.1 to 492.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	132	SF	\$120	\$15,780
44457	470.2 to 471.2 feet	Vertical Change	-.55	5 ft	5	REF		
46634	475.1 to 476.1 feet	Vertical Change	-.45	5 ft	5	REF		
53112	480.1 to 481.1 feet	Vertical Change	-.27	5 ft	5	REF		
8420	492.4 to 493.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720
TOTAL COST FOR: N side of BIRCH CT Starting at: ELM AVE								\$161,905.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221357	ELM AVE	BIRCH CT	KITES WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
8421	1.8 to 14.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,800
49108	9.5 to 10.5 feet	Vertical Change	-.36	5 ft	5	REF		
47574	14.5 to 15.5 feet	Vertical Change	-.41	5 ft	5	REF		
8423	14.8 to 100.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	429	SF	\$120	\$51,480
53113	19.5 to 20.5 feet	Vertical Change	-.27	5 ft	5	REF		
52606	24.4 to 25.4 feet	Vertical Change	-.28	5 ft	5	REF		
52607	39.4 to 40.4 feet	Vertical Change	-.28	5 ft	5	REF		
54013	44.2 to 45.2 feet	Vertical Change	-.25	5 ft	5	REF		
52608	59.2 to 60.2 feet	Vertical Change	-.28	5 ft	5	REF		
57165	64.1 to 65.1 feet	Vertical Change	.69	5 ft	5	REF		
54014	74.2 to 75.2 feet	Vertical Change	-.25	5 ft	5	REF		
45760	79.2 to 80.2 feet	Vertical Change	-.49	5 ft	5	REF		
53114	84.3 to 85.3 feet	Vertical Change	-.27	5 ft	5	REF		
8436	100.6 to 135.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	176	SF	\$120	\$21,120
49732	107.8 to 108.8 feet	Vertical Change	-.34	5 ft	5	REF		
50808	115.8 to 116.8 feet	Vertical Change	-.31	5 ft	5	REF		
54015	123.9 to 124.9 feet	Vertical Change	-.25	5 ft	5	REF		
51719	129.8 to 130.8 feet	Vertical Change	-.3	5 ft	5	REF		
8440	135.8 to 181.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	230	SF	\$120	\$27,600
49409	139.8 to 140.8 feet	Vertical Change	-.35	5 ft	5	REF		
48825	155.9 to 156.9 feet	Vertical Change	-.37	5 ft	5	REF		
51720	163.8 to 164.8 feet	Vertical Change	-.3	5 ft	5	REF		
43727	171.6 to 172.6 feet	Vertical Change	-.59	5 ft	5	REF		
53646	179.3 to 180.3 feet	Vertical Change	-.26	5 ft	5	REF		
8447	181.8 to 186.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000
50809	184.1 to 185.1 feet	Vertical Change	-.31	5 ft	5	REF		
TOTAL COST FOR: N side of ELM AVE Starting at: BIRCH CT							\$111,000.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908221400	KITES WAY	ELM AVE	PISTACHIO CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
8448	0.0 to 6.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,720	
43888	0.8 to 1.8 feet	Vertical Change	-.58	5 ft	5	REF			
47328	6.2 to 7.2 feet	Vertical Change	-.42	5 ft	5	REF			
56974	6.3 to 7.3 feet	Vertical Change	.57	5 ft	5	SF	\$75	\$375	
52146	17.0 to 18.0 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
41406	20.0 to 21.0 feet	Vertical Change	-1.25	5 ft	5	SF	\$75	\$375	
48529	25.2 to 26.2 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375	
58296	27.2 to 52.2 feet	Driveway				REF			
8449	30.5 to 32.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$300	
41387	31.7 to 32.7 feet	Vertical Change	-1.31	5 ft	5	REF			
8450	35.4 to 50.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	73	SF	\$40	\$2,920	
46868	42.1 to 43.1 feet	Vertical Change	-.44	5 ft	5	REF			
40282	49.3 to 50.3 feet	Running Slope	6.0-7.0%	5 ft	5	REF			
41539	52.3 to 53.3 feet	Vertical Change	-1.04	5 ft	5	REF			
8453	53.5 to 54.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780	
58297	56.8 to 83.8 feet	Driveway				REF			
47329	61.8 to 62.8 feet	Vertical Change	-.42	5 ft	5	REF			
8454	65.3 to 79.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	73	SF	\$40	\$2,900	
51721	72.2 to 73.2 feet	Vertical Change	-.3	5 ft	5	REF			
40283	78.3 to 79.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
49733	82.4 to 83.4 feet	Vertical Change	-.34	5 ft	5	REF			
41662	82.5 to 83.5 feet	Vertical Change	-.92	5 ft	5	REF			
8457	83.8 to 87.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	19	SF	\$40	\$760	
47100	91.2 to 92.2 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375	
47575	99.9 to 100.9 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375	
48826	108.0 to 109.0 feet	Vertical Change	-.37	5 ft	5	REF			
8458	108.0 to 130.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	112	SF	\$120	\$13,440	
51722	116.0 to 117.0 feet	Vertical Change	-.3	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221400	KITES WAY	ELM AVE	PISTACHIO CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
8460	131.3 to 132.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	5	SF	\$120	\$600
52147	131.9 to 132.9 feet	Vertical Change	-.29	5 ft	5	REF		
8461	133.3 to 143.2 feet	Cross Slope (PAR)	7.0-8.0%	5 ft	49	SF	\$120	\$5,940
54016	140.2 to 141.2 feet	Vertical Change	-.25	5 ft	5	REF		
42782	144.1 to 145.1 feet	Vertical Change	-.66	5 ft	5	SF	\$75	\$375
53647	144.1 to 145.1 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
8463	146.4 to 155.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,580
50810	148.0 to 149.0 feet	Vertical Change	-.31	5 ft	5	REF		
58298	150.8 to 176.1 feet	Driveway				REF		
48240	155.8 to 156.8 feet	Vertical Change	-.39	5 ft	5	REF		
8465	159.0 to 173.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	74	SF	\$40	\$2,960
48241	166.3 to 167.3 feet	Vertical Change	-.39	5 ft	5	REF		
40284	172.8 to 174.4 feet	Running Slope	6.0-7.0%	5 ft	8	REF		
49410	176.1 to 177.1 feet	Vertical Change	-.35	5 ft	5	REF		
8468	177.6 to 185.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,620
58299	181.3 to 206.5 feet	Driveway				REF		
52609	185.8 to 186.8 feet	Vertical Change	-.28	5 ft	5	REF		
8469	189.8 to 204.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	72	SF	\$40	\$2,880
40285	203.3 to 204.9 feet	Running Slope	6.0-7.0%	5 ft	8	REF		
8471	208.2 to 247.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	196	SF	\$120	\$23,460
50433	215.7 to 216.7 feet	Vertical Change	-.32	5 ft	5	REF		
46635	223.9 to 224.9 feet	Vertical Change	-.45	5 ft	5	REF		
49411	231.9 to 232.9 feet	Vertical Change	-.35	5 ft	5	REF		
47996	240.0 to 241.0 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375
58300	243.8 to 267.5 feet	Driveway				REF		
43412	247.9 to 248.9 feet	Vertical Change	-.61	5 ft	5	REF		
56964	248.0 to 249.0 feet	Vertical Change	.56	5 ft	5	REF		
8477	251.8 to 265.5 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	69	SF	\$40	\$2,740

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
E	1908221400	KITES WAY	ELM AVE	PISTACHIO CT				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44685	258.3 to 259.3 feet	Vertical Change	-.54	5 ft	5	REF		
40286	264.5 to 266.7 feet	Running Slope	5.0-6.0%	5 ft	11	REF		
45255	268.0 to 269.0 feet	Vertical Change	-.51	5 ft	5	REF		
8479	268.8 to 307.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	193	SF	\$120	\$23,160
48827	285.9 to 286.9 feet	Vertical Change	-.37	5 ft	5	REF		
47330	294.0 to 295.0 feet	Vertical Change	-.42	5 ft	5	REF		
48828	302.1 to 303.1 feet	Vertical Change	-.37	5 ft	5	REF		
8482	307.4 to 325.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	93	SF	\$120	\$11,100
52148	310.0 to 311.0 feet	Vertical Change	-.29	5 ft	5	REF		
50055	318.0 to 319.0 feet	Vertical Change	-.33	5 ft	5	REF		
8485	325.9 to 340.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	73	SF	\$120	\$8,700
49734	326.0 to 327.0 feet	Vertical Change	-.34	5 ft	5	REF		
49109	333.9 to 334.9 feet	Vertical Change	-.36	5 ft	5	REF		
57245	338.0 to 339.0 feet	Vertical Change	.79	5 ft	5	REF		
8487	340.4 to 393.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	268	SF	\$120	\$32,100
49412	342.1 to 343.1 feet	Vertical Change	-.35	5 ft	5	REF		
42395	350.0 to 351.0 feet	Vertical Change	-.7	5 ft	5	REF		
50056	358.0 to 359.0 feet	Vertical Change	-.33	5 ft	5	REF		
46869	366.0 to 367.0 feet	Vertical Change	-.44	5 ft	5	REF		
43728	373.9 to 374.9 feet	Vertical Change	-.59	5 ft	5	REF		
44873	381.9 to 382.9 feet	Vertical Change	-.53	5 ft	5	REF		
44874	389.9 to 390.9 feet	Vertical Change	-.53	5 ft	5	REF		
43413	395.5 to 396.5 feet	Vertical Change	-.61	5 ft	5	SF	\$75	\$375

TOTAL COST FOR: E side of KITES WAY Starting at: ELM AVE \$152,410.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
E	1908221404	PISTACHIO CT	KITES WAY	KITES WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
48829	2.0 to 3.0 feet	Vertical Change	-.37	4 ft	4	REF			
8497	2.0 to 19.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	71	SF	\$120	\$8,544	
52610	7.5 to 8.5 feet	Vertical Change	-.28	4 ft	4	REF			
52611	15.5 to 18.5 feet	Vertical Change	-.28	4 ft	12	REF			
53648	21.4 to 22.4 feet	Vertical Change	-.26	4 ft	4	REF			
58301	22.0 to 48.7 feet	Driveway				REF			
8500	22.3 to 27.0 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	19	SF	\$40	\$752	
45542	27.4 to 28.4 feet	Vertical Change	-.5	4 ft	4	REF			
8502	31.0 to 45.2 feet	Cross Slope (Driveway)	13.014	4 ft	57	SF	\$40	\$2,272	
40287	44.8 to 46.0 feet	Running Slope	6.0-7.0%	4 ft	5	REF			
8504	49.4 to 56.8 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	30	SF	\$40	\$1,184	
58302	52.8 to 77.2 feet	Driveway				REF			
8505	61.8 to 75.2 feet	Cross Slope (Driveway)	13.014	4 ft	54	SF	\$40	\$2,144	
40288	74.3 to 76.6 feet	Running Slope	6.0-7.0%	4 ft	9	REF			
8512	79.1 to 90.2 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	44	SF	\$120	\$5,328	
49413	84.4 to 85.4 feet	Vertical Change	-.35	4 ft	4	REF			
8513	91.8 to 98.3 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	26	SF	\$120	\$3,120	
44686	99.3 to 100.3 feet	Vertical Change	-.54	4 ft	4	SF	\$75	\$300	
57372	99.4 to 100.4 feet	Vertical Change	1.02	4 ft	4	SF	\$75	\$300	
8515	100.9 to 125.8 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	100	SF	\$120	\$11,952	
51723	107.3 to 108.3 feet	Vertical Change	-.3	4 ft	4	REF			
51724	115.4 to 116.4 feet	Vertical Change	-.3	4 ft	4	REF			
51725	123.4 to 124.4 feet	Vertical Change	-.3	4 ft	4	REF			
8517	125.8 to 131.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	21	SF	\$120	\$2,544	
8519	131.1 to 146.0 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	60	SF	\$120	\$7,152	
58303	141.8 to 167.1 feet	Driveway				REF			
53649	145.2 to 146.2 feet	Vertical Change	-.26	4 ft	4	REF			
8521	150.5 to 165.2 feet	Cross Slope (Driveway)	12.0-13.0%	4 ft	59	SF	\$40	\$2,352	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221404	PISTACHIO CT	KITES WAY	KITES WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40289	164.3 to 166.2 feet	Running Slope	6.0-7.0%	4 ft	8	REF		
8524	168.8 to 177.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	34	SF	\$120	\$4,032
54017	170.2 to 171.2 feet	Vertical Change	-25	4 ft	4	REF		
58304	172.5 to 198.6 feet	Driveway				REF		
53115	177.3 to 178.3 feet	Vertical Change	-27	4 ft	4	REF		
8525	180.8 to 190.0 feet	Cross Slope (Driveway)	12.0-13.0%	4 ft	37	SF	\$40	\$1,472
8527	190.0 to 194.5 feet	Cross Slope (Driveway)	14.0-15.0%	4 ft	18	SF	\$40	\$720
40290	194.4 to 196.4 feet	Running Slope	7.0-8.0%	4 ft	8	REF		
57331	197.8 to 198.8 feet	Vertical Change	.9	4 ft	4	REF		
8529	198.7 to 201.7 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	12	SF	\$40	\$480
8531	201.7 to 219.1 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	70	SF	\$120	\$8,352
53650	207.9 to 208.9 feet	Vertical Change	-26	4 ft	4	REF		
47997	211.7 to 212.7 feet	Vertical Change	-4	4 ft	4	REF		
42050	219.7 to 220.7 feet	Vertical Change	-76	4 ft	4	REF		
8535	220.0 to 222.4 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	10	SF	\$120	\$1,152
8537	222.4 to 236.8 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	58	SF	\$120	\$6,912
54018	223.8 to 228.8 feet	Vertical Change	-25	4 ft	20	REF		
8541	236.8 to 242.8 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	24	SF	\$120	\$2,880
53116	237.7 to 240.7 feet	Vertical Change	-27	4 ft	12	REF		
44458	243.7 to 244.7 feet	Vertical Change	-55	4 ft	4	SF	\$75	\$300
8542	245.0 to 267.0 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	88	SF	\$120	\$10,560
53117	245.6 to 246.6 feet	Vertical Change	-27	4 ft	4	REF		
52613	249.5 to 258.4 feet	Vertical Change	-28	4 ft	36	REF		
44459	259.4 to 260.4 feet	Vertical Change	-55	4 ft	4	REF		
52149	261.1 to 264.0 feet	Vertical Change	-29	4 ft	12	REF		
58305	261.6 to 287.2 feet	Driveway				REF		
41745	267.0 to 268.0 feet	Vertical Change	-87	4 ft	4	REF		
8545	270.3 to 279.3 feet	Cross Slope (Driveway)	14.0-15.0%	4 ft	36	SF	\$40	\$1,440

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221404	PISTACHIO CT	KITES WAY	KITES WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
43264	276.8 to 277.8 feet	Vertical Change	-.62	4 ft	4	REF		
8548	279.3 to 283.6 feet	Cross Slope (Driveway)	12.0-13.0%	4 ft	17	SF	\$40	\$688
40291	283.2 to 285.3 feet	Running Slope	6.0-7.0%	4 ft	8	REF		
43414	286.8 to 287.8 feet	Vertical Change	-.61	4 ft	4	REF		
8549	287.5 to 293.0 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	22	SF	\$120	\$2,640
53653	290.8 to 291.8 feet	Vertical Change	-.26	4 ft	4	REF		
8550	293.0 to 307.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	57	SF	\$120	\$6,816
50811	295.2 to 305.4 feet	Vertical Change	-.31	4 ft	41	REF		
8552	307.2 to 313.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	26	SF	\$120	\$3,168
52152	308.9 to 309.9 feet	Vertical Change	-.29	4 ft	4	REF		
51726	313.4 to 314.4 feet	Vertical Change	-.3	4 ft	4	REF		
57232	313.4 to 314.4 feet	Vertical Change	.71	4 ft	4	REF		
8554	313.8 to 315.8 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	8	SF	\$120	\$960
48242	315.6 to 318.8 feet	Vertical Change	-.39	4 ft	13	REF		
8556	315.8 to 321.8 feet	Cross Slope (PAR)	8.0-9.0%	4 ft	24	SF	\$120	\$2,880
42575	322.4 to 323.5 feet	Vertical Change	-.68	4 ft	4	SF	\$75	\$330
8558	325.0 to 340.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	63	SF	\$120	\$7,536
51727	327.1 to 330.3 feet	Vertical Change	-.3	4 ft	13	REF		
58306	335.5 to 362.8 feet	Driveway				REF		
50436	336.0 to 341.7 feet	Vertical Change	-.32	4 ft	23	REF		
8560	344.6 to 358.8 feet	Cross Slope (Driveway)	14.0-15.0%	4 ft	57	SF	\$40	\$2,272
44460	351.1 to 352.1 feet	Vertical Change	-.55	4 ft	4	REF		
40292	358.0 to 359.8 feet	Running Slope	7.0-8.0%	4 ft	7	REF		
47331	361.7 to 367.9 feet	Vertical Change	-.42	4 ft	25	REF		
8562	363.7 to 381.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	72	SF	\$120	\$8,640
53656	372.0 to 380.8 feet	Vertical Change	-.26	4 ft	35	REF		
58307	378.1 to 404.0 feet	Driveway				REF		
8564	385.7 to 401.6 feet	Cross Slope (Driveway)	13.014	4 ft	64	SF	\$40	\$2,544

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221404	PISTACHIO CT	KITES WAY	KITES WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40293	400.6 to 401.8 feet	Running Slope	7.0-8.0%	4 ft	5	REF		
8568	405.7 to 424.6 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	76	SF	\$120	\$9,072
53120	419.1 to 420.1 feet	Vertical Change	-27	4 ft	4	REF		
58308	420.2 to 445.0 feet	Driveway				REF		
8569	429.1 to 442.8 feet	Cross Slope (Driveway)	13.014	4 ft	55	SF	\$40	\$2,192
50057	434.7 to 435.7 feet	Vertical Change	-33	4 ft	4	REF		
40294	442.0 to 443.3 feet	Running Slope	7.0-8.0%	4 ft	5	REF		
43265	445.5 to 446.5 feet	Vertical Change	-62	4 ft	4	REF		
8572	446.5 to 468.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	89	SF	\$120	\$10,656
53121	453.1 to 458.5 feet	Vertical Change	-27	4 ft	22	REF		
8576	468.7 to 493.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	100	SF	\$120	\$11,952
47101	472.2 to 475.6 feet	Vertical Change	-43	4 ft	14	REF		
46637	481.4 to 484.6 feet	Vertical Change	-45	4 ft	13	REF		
43729	490.0 to 491.0 feet	Vertical Change	-59	4 ft	4	REF		
53123	491.9 to 496.7 feet	Vertical Change	-27	4 ft	19	REF		
58309	492.8 to 517.5 feet	Driveway				REF		
8582	493.6 to 497.3 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	15	SF	\$40	\$592
41705	497.6 to 498.6 feet	Vertical Change	-89	4 ft	4	REF		
8583	501.1 to 507.0 feet	Cross Slope (Driveway)	>15%	4 ft	24	SF	\$40	\$944
8585	507.0 to 513.4 feet	Cross Slope (Driveway)	13.014	4 ft	26	SF	\$40	\$1,024
42783	507.6 to 508.6 feet	Vertical Change	-66	4 ft	4	REF		
8587	513.4 to 514.7 feet	Cross Slope (Driveway)	11.0-12.0%	4 ft	5	SF	\$40	\$208
40295	513.4 to 515.9 feet	Running Slope	5.0-6.0%	4 ft	10	REF		
41676	517.3 to 518.3 feet	Vertical Change	-91	4 ft	4	REF		
8588	518.3 to 562.0 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	175	SF	\$40	\$6,992
54022	522.7 to 527.5 feet	Vertical Change	-25	4 ft	19	REF		
43415	530.3 to 531.3 feet	Vertical Change	-61	4 ft	4	REF		
53126	534.4 to 535.4 feet	Vertical Change	-27	4 ft	4	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221404	PISTACHIO CT	KITES WAY	KITES WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47332	538.4 to 539.4 feet	Vertical Change	-42	4 ft	4	REF		
53127	542.5 to 547.4 feet	Vertical Change	-27	4 ft	20	REF		
48530	554.2 to 555.2 feet	Vertical Change	-38	4 ft	4	REF		
51729	558.4 to 563.4 feet	Vertical Change	-3	4 ft	20	REF		
8595	562.0 to 585.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	96	SF	\$120	\$11,472
52620	566.3 to 569.3 feet	Vertical Change	-28	4 ft	12	REF		
52154	572.3 to 585.2 feet	Vertical Change	-29	4 ft	52	REF		
58310	580.9 to 606.8 feet	Driveway				REF		
41401	586.1 to 587.1 feet	Vertical Change	-1.27	4 ft	4	REF		
8597	589.6 to 601.7 feet	Cross Slope (Driveway)	>15%	4 ft	48	SF	\$40	\$1,936
42898	596.7 to 597.7 feet	Vertical Change	-65	4 ft	4	REF		
8599	601.7 to 604.2 feet	Cross Slope (Driveway)	13.014	4 ft	10	SF	\$40	\$400
40296	603.3 to 604.5 feet	Running Slope	7.0-8.0%	4 ft	5	REF		
41677	606.8 to 607.8 feet	Vertical Change	-91	4 ft	4	REF		
8600	608.5 to 615.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	26	SF	\$120	\$3,168
50812	609.2 to 617.0 feet	Vertical Change	-31	4 ft	31	REF		
58311	611.8 to 636.3 feet	Driveway				REF		
8601	621.4 to 633.3 feet	Cross Slope (Driveway)	13.014	4 ft	48	SF	\$40	\$1,904
40297	632.5 to 634.3 feet	Running Slope	7.0-8.0%	4 ft	7	REF		
8602	637.4 to 650.0 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	50	SF	\$120	\$6,048
8604	650.0 to 651.2 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	5	SF	\$120	\$576
8605	651.2 to 666.3 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	60	SF	\$120	\$7,248
8610	666.3 to 689.8 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	94	SF	\$120	\$11,280
45762	666.6 to 695.5 feet	Vertical Change	-49	4 ft	116	REF		
8613	689.8 to 701.6 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	47	SF	\$120	\$5,664
53130	698.5 to 699.5 feet	Vertical Change	-27	4 ft	4	REF		
58312	699.8 to 726.8 feet	Driveway				REF		
8617	701.6 to 704.0 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	10	SF	\$40	\$384

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221404	PISTACHIO CT	KITES WAY	KITES WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51735	702.4 to 707.4 feet	Vertical Change	-.3	4 ft	20	REF		
8619	704.0 to 705.2 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	5	SF	\$40	\$192
8620	705.2 to 706.5 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	5	SF	\$40	\$208
8621	710.2 to 724.2 feet	Cross Slope (Driveway)	14.0-15.0%	4 ft	56	SF	\$40	\$2,240
48243	716.6 to 717.6 feet	Vertical Change	-.39	4 ft	4	REF		
8624	727.7 to 735.6 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	32	SF	\$120	\$3,792
53131	729.0 to 730.0 feet	Vertical Change	-.27	4 ft	4	REF		
58313	730.9 to 756.7 feet	Driveway				REF		
52160	733.6 to 734.6 feet	Vertical Change	-.29	4 ft	4	REF		
8625	739.2 to 754.3 feet	Cross Slope (Driveway)	14.0-15.0%	4 ft	60	SF	\$40	\$2,416
54024	746.4 to 747.4 feet	Vertical Change	-.25	4 ft	4	REF		
40298	754.6 to 755.7 feet	Running Slope	6.0-7.0%	4 ft	4	REF		
53659	756.8 to 757.8 feet	Vertical Change	-.26	4 ft	4	REF		
8626	758.8 to 762.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,920
51736	760.9 to 763.8 feet	Vertical Change	-.3	4 ft	12	REF		
8628	762.8 to 766.6 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	15	SF	\$120	\$1,824
8630	766.6 to 769.8 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	13	SF	\$120	\$1,536
8631	769.8 to 778.0 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	33	SF	\$120	\$3,936
45967	770.8 to 771.8 feet	Vertical Change	-.48	4 ft	4	REF		
8633	778.0 to 781.1 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	12	SF	\$120	\$1,488
50818	778.6 to 779.6 feet	Vertical Change	-.31	4 ft	4	REF		
8634	781.1 to 785.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,872
50058	783.6 to 784.6 feet	Vertical Change	-.33	4 ft	4	REF		
TOTAL COST FOR: E side of PISTACHIO CT Starting at: KITES WAY							\$239,854.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908221407	KITES WAY	PISTACHIO CT	ACACIA CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
52161	2.6 to 3.6 feet	Vertical Change	-29	5 ft	5	LF	\$75	\$375	
8635	4.9 to 11.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,720	
46638	12.7 to 13.7 feet	Vertical Change	-45	5 ft	5	LF	\$75	\$375	
8636	33.5 to 45.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,440	
45544	44.6 to 45.6 feet	Vertical Change	-5	5 ft	5	REF			
50819	52.6 to 53.6 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
53132	56.5 to 57.5 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
53133	60.5 to 61.5 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
51737	64.4 to 65.4 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
8637	67.6 to 75.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,920	
52162	76.5 to 77.5 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
8638	79.5 to 95.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	79	SF	\$120	\$9,480	
51738	84.4 to 87.4 feet	Vertical Change	-.3	5 ft	15	REF			
53660	90.4 to 91.4 feet	Vertical Change	-.26	5 ft	5	REF			
8641	100.6 to 124.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	119	SF	\$120	\$14,220	
53134	112.9 to 113.9 feet	Vertical Change	-.27	5 ft	5	REF			
47102	123.0 to 124.0 feet	Vertical Change	-.43	5 ft	5	REF			
8644	128.0 to 139.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,960	
8645	142.3 to 149.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,380	
51739	143.5 to 144.5 feet	Vertical Change	-.3	5 ft	5	REF			
8646	151.9 to 159.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,440	
50059	153.3 to 154.3 feet	Vertical Change	-.33	5 ft	5	REF			
8647	172.3 to 235.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	315	SF	\$120	\$37,800	
48830	193.4 to 194.4 feet	Vertical Change	-.37	5 ft	5	REF			
46871	223.4 to 224.4 feet	Vertical Change	-.44	5 ft	5	REF			
43889	233.5 to 234.5 feet	Vertical Change	-.58	5 ft	5	REF			
8648	237.8 to 239.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260	
8649	242.8 to 275.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	165	SF	\$120	\$19,800	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221407	KITES WAY	PISTACHIO CT	ACACIA CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51740	273.4 to 274.4 feet	Vertical Change	-.3	5 ft	5	REF		
8650	278.5 to 279.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
8651	282.1 to 285.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,220
45968	283.3 to 284.3 feet	Vertical Change	-.48	5 ft	5	REF		
8652	288.2 to 291.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,980
8653	296.7 to 304.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,920
46639	303.4 to 304.4 feet	Vertical Change	-.45	5 ft	5	REF		
8654	312.3 to 317.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,180
47103	313.5 to 314.5 feet	Vertical Change	-.43	5 ft	5	REF		
8655	322.3 to 339.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,260
45763	323.7 to 324.7 feet	Vertical Change	-.49	5 ft	5	REF		
46872	333.5 to 334.5 feet	Vertical Change	-.44	5 ft	5	REF		
47576	343.6 to 344.6 feet	Vertical Change	-.41	5 ft	5	REF		
8656	344.3 to 348.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,580
8657	352.5 to 399.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	233	SF	\$120	\$27,900
48244	353.6 to 354.6 feet	Vertical Change	-.39	5 ft	5	REF		
43266	363.4 to 364.4 feet	Vertical Change	-.62	5 ft	5	REF		
45545	373.7 to 374.7 feet	Vertical Change	-.5	5 ft	5	REF		
46178	383.9 to 384.9 feet	Vertical Change	-.47	5 ft	5	REF		
48245	393.9 to 394.9 feet	Vertical Change	-.39	5 ft	5	REF		
46179	403.6 to 404.6 feet	Vertical Change	-.47	5 ft	5	REF		
8658	404.1 to 443.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	198	SF	\$120	\$23,700
45056	413.6 to 414.6 feet	Vertical Change	-.52	5 ft	5	REF		
48531	423.7 to 424.7 feet	Vertical Change	-.38	5 ft	5	REF		
50820	433.5 to 434.5 feet	Vertical Change	-.31	5 ft	5	REF		
54025	443.5 to 444.5 feet	Vertical Change	-.25	5 ft	5	REF		
8664	443.6 to 459.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	78	SF	\$120	\$9,300
46873	454.1 to 455.1 feet	Vertical Change	-.44	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221407	KITES WAY	PISTACHIO CT	ACACIA CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
TOTAL COST FOR:								\$203,925.00

E *side of* **KITES WAY** *Starting at:* **PISTACHIO CT**

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908221411	ACACIA CT	KITES WAY	AUTUMN WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
8666	0.0 to 80.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	404	SF	\$120	\$48,420	
46640	6.6 to 7.6 feet	Vertical Change	-.45	5 ft	5	REF			
44252	16.0 to 17.0 feet	Vertical Change	-.56	5 ft	5	REF			
56623	75.1 to 76.1 feet	Vertical Change	.43	5 ft	5	REF			
44461	90.1 to 91.1 feet	Vertical Change	-.55	5 ft	5	REF			
8672	90.3 to 155.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	327	SF	\$120	\$39,180	
43416	119.8 to 120.8 feet	Vertical Change	-.61	5 ft	5	REF			
49414	149.6 to 150.6 feet	Vertical Change	-.35	5 ft	5	REF			
8676	155.6 to 208.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	262	SF	\$120	\$31,440	
46874	204.4 to 205.4 feet	Vertical Change	-.44	5 ft	5	REF			
8685	208.0 to 254.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	235	SF	\$120	\$28,140	
47104	221.4 to 222.4 feet	Vertical Change	-.43	5 ft	5	REF			
42488	238.4 to 239.4 feet	Vertical Change	-.69	5 ft	5	REF			
51741	254.5 to 255.5 feet	Vertical Change	-.3	5 ft	5	REF			
8692	263.1 to 266.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800	
41487	272.3 to 273.3 feet	Vertical Change	-1.11	5 ft	5	SF	\$75	\$375	
8693	273.4 to 305.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	159	SF	\$120	\$19,080	
55982	283.4 to 284.4 feet	Vertical Change	.38	5 ft	5	REF			
41650	290.1 to 291.1 feet	Vertical Change	-.93	5 ft	5	REF			
58314	298.3 to 326.7 feet	Driveway				REF			
8695	305.2 to 306.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	8	SF	\$40	\$300	
41706	306.4 to 307.4 feet	Vertical Change	-.89	5 ft	5	REF			
8696	310.6 to 325.1 feet	Cross Slope (Driveway)	13.014	5 ft	73	SF	\$40	\$2,900	
41603	317.3 to 318.3 feet	Vertical Change	-.98	5 ft	5	REF			
58315	327.9 to 350.3 feet	Driveway				REF			
46641	328.4 to 329.4 feet	Vertical Change	-.45	5 ft	5	REF			
41619	331.0 to 332.0 feet	Vertical Change	-.96	5 ft	5	REF			
8700	334.7 to 350.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	78	SF	\$40	\$3,100	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908221411	ACACIA CT	KITES WAY	AUTUMN WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
41651	341.5 to 342.5 feet	Vertical Change	-.93	5 ft	5	REF			
40299	348.6 to 350.7 feet	Running Slope	5.0-6.0%	5 ft	11	REF			
43128	352.1 to 353.1 feet	Vertical Change	-.63	5 ft	5	REF			
8704	352.9 to 354.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$720	
8705	354.1 to 371.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	88	SF	\$120	\$10,500	
58316	364.4 to 391.3 feet	Driveway				REF			
40300	370.2 to 371.6 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
46180	371.0 to 372.0 feet	Vertical Change	-.47	5 ft	5	REF			
8707	375.7 to 383.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	41	SF	\$40	\$1,620	
42784	380.9 to 381.9 feet	Vertical Change	-.66	5 ft	5	REF			
8709	383.8 to 389.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	26	SF	\$40	\$1,040	
40301	388.1 to 389.7 feet	Running Slope	6.0-7.0%	5 ft	8	REF			
53135	391.4 to 392.4 feet	Vertical Change	-.27	5 ft	5	REF			
8711	392.6 to 404.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	61	SF	\$120	\$7,260	
8713	404.7 to 441.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	185	SF	\$120	\$22,200	
42296	405.8 to 406.8 feet	Vertical Change	-.71	5 ft	5	REF			
44253	418.8 to 419.8 feet	Vertical Change	-.56	5 ft	5	REF			
48831	428.1 to 429.1 feet	Vertical Change	-.37	5 ft	5	REF			
53661	438.9 to 439.9 feet	Vertical Change	-.26	5 ft	5	REF			
8719	441.7 to 445.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220	
8720	452.1 to 459.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,560	
45764	453.1 to 454.1 feet	Vertical Change	-.49	5 ft	5	REF			
48246	467.8 to 468.8 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375	
47105	482.7 to 483.7 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375	
58317	492.2 to 516.6 feet	Driveway				REF			
48247	497.3 to 498.3 feet	Vertical Change	-.39	5 ft	5	REF			
8721	500.4 to 514.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	72	SF	\$40	\$2,880	
50821	507.1 to 508.1 feet	Vertical Change	-.31	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221411	ACACIA CT	KITES WAY	AUTUMN WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
43129	516.9 to 517.9 feet	Vertical Change	-.63	5 ft	5	REF		
56642	517.0 to 518.0 feet	Vertical Change	.48	5 ft	5	REF		
8723	518.0 to 519.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$780
42578	531.4 to 532.4 feet	Vertical Change	-.68	5 ft	5	REF		
8724	532.3 to 548.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	82	SF	\$120	\$9,780
41821	546.2 to 547.2 feet	Vertical Change	-.83	5 ft	5	REF		
58318	555.1 to 579.8 feet	Driveway				REF		
8726	557.8 to 560.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	14	SF	\$40	\$540
41559	560.9 to 561.9 feet	Vertical Change	-1.01	5 ft	5	REF		
8727	564.7 to 578.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	67	SF	\$40	\$2,680
41560	570.8 to 571.8 feet	Vertical Change	-1.01	5 ft	5	REF		
40302	576.9 to 579.3 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
42785	580.2 to 581.2 feet	Vertical Change	-.66	5 ft	5	REF		
8729	581.5 to 589.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	39	SF	\$120	\$4,680
45969	588.6 to 589.6 feet	Vertical Change	-.48	5 ft	5	REF		
8731	589.3 to 593.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,580
TOTAL COST FOR: E side of ACACIA CT Starting at: KITES WAY							\$249,525.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221412	AUTUMN WAY	ACACIA CT	PARKRIDGE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
8732	0.0 to 17.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	89	SF	\$120	\$10,680
42683	7.4 to 8.4 feet	Vertical Change	-.67	5 ft	5	REF		
43417	20.0 to 21.0 feet	Vertical Change	-.61	5 ft	5	REF		
8733	20.2 to 107.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	435	SF	\$120	\$52,200
49110	35.1 to 36.1 feet	Vertical Change	-.36	5 ft	5	REF		
50438	50.2 to 51.2 feet	Vertical Change	-.32	5 ft	5	REF		
41723	65.1 to 66.1 feet	Vertical Change	-.88	5 ft	5	REF		
54137	65.2 to 66.2 feet	Vertical Change	.25	5 ft	5	REF		
46642	79.5 to 80.5 feet	Vertical Change	-.45	5 ft	5	REF		
44462	86.6 to 87.6 feet	Vertical Change	-.55	5 ft	5	REF		
46416	93.7 to 94.7 feet	Vertical Change	-.46	5 ft	5	REF		
8739	115.7 to 122.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,260
8742	122.8 to 188.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	326	SF	\$120	\$39,120
43588	138.0 to 139.0 feet	Vertical Change	-.6	5 ft	5	REF		
47335	153.1 to 154.1 feet	Vertical Change	-.42	5 ft	5	REF		
49111	167.7 to 168.7 feet	Vertical Change	-.36	5 ft	5	REF		
44463	182.3 to 183.3 feet	Vertical Change	-.55	5 ft	5	REF		
53136	187.1 to 188.1 feet	Vertical Change	-.27	5 ft	5	REF		
TOTAL COST FOR: E side of AUTUMN WAY Starting at: ACACIA CT							\$106,260.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908221415	AUTUMN WAY	PARKRIDGE DR	ROSE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
42094	1.0 to 2.0 feet	Vertical Change	-.75	5 ft	5	SF	\$75	\$375	
56953	6.4 to 7.4 feet	Vertical Change	.55	5 ft	5	REF			
8751	6.6 to 19.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	66	SF	\$120	\$7,920	
43589	15.4 to 16.4 feet	Vertical Change	-.6	5 ft	5	REF			
58319	18.7 to 55.8 feet	Driveway				REF			
43890	20.3 to 21.3 feet	Vertical Change	-.58	5 ft	5	REF			
41348	24.2 to 25.2 feet	Vertical Change	-1.4	5 ft	5	REF			
8752	27.3 to 53.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	129	SF	\$40	\$5,140	
42297	39.5 to 40.5 feet	Vertical Change	-.71	5 ft	5	REF			
40303	52.0 to 53.8 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
44064	55.1 to 56.1 feet	Vertical Change	-.57	5 ft	5	REF			
8760	55.8 to 62.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	31	SF	\$40	\$1,240	
46181	58.3 to 59.3 feet	Vertical Change	-.47	5 ft	5	REF			
46182	62.8 to 63.8 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375	
58320	66.8 to 104.5 feet	Driveway				REF			
45546	68.4 to 69.4 feet	Vertical Change	-.5	5 ft	5	REF			
8761	68.7 to 72.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	18	SF	\$40	\$720	
45057	72.4 to 73.4 feet	Vertical Change	-.52	5 ft	5	REF			
8762	75.7 to 101.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	127	SF	\$40	\$5,080	
43891	87.8 to 88.8 feet	Vertical Change	-.58	5 ft	5	REF			
8766	101.1 to 102.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200	
40304	101.8 to 102.9 feet	Running Slope	7.0-8.0%	5 ft	6	REF			
47106	104.6 to 105.6 feet	Vertical Change	-.43	5 ft	5	REF			
8767	104.9 to 129.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	122	SF	\$120	\$14,640	
43418	108.5 to 109.5 feet	Vertical Change	-.61	5 ft	5	REF			
43130	114.5 to 115.5 feet	Vertical Change	-.63	5 ft	5	REF			
46183	124.5 to 125.5 feet	Vertical Change	-.47	5 ft	5	REF			
49112	134.2 to 135.2 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221415	AUTUMN WAY	PARKRIDGE DR	ROSE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
8769	139.3 to 163.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	119	SF	\$120	\$14,280
45547	144.0 to 145.0 feet	Vertical Change	-.5	5 ft	5	REF		
53662	154.0 to 155.0 feet	Vertical Change	-.26	5 ft	5	REF		
58321	157.3 to 184.6 feet	Driveway				REF		
47577	159.7 to 160.7 feet	Vertical Change	-.41	5 ft	5	REF		
44875	163.6 to 164.6 feet	Vertical Change	-.53	5 ft	5	REF		
8774	166.3 to 172.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	30	SF	\$40	\$1,200
48532	169.2 to 170.2 feet	Vertical Change	-.38	5 ft	5	REF		
8776	172.3 to 179.1 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	34	SF	\$40	\$1,360
53663	173.5 to 174.5 feet	Vertical Change	-.26	5 ft	5	REF		
43590	178.5 to 179.5 feet	Vertical Change	-.6	5 ft	5	REF		
8778	179.1 to 182.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	18	SF	\$40	\$700
52163	183.4 to 184.4 feet	Vertical Change	-.29	5 ft	5	REF		
8780	185.0 to 186.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200
8781	186.0 to 200.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	72	SF	\$120	\$8,640
58322	193.9 to 219.0 feet	Driveway				REF		
50822	196.9 to 197.9 feet	Vertical Change	-.31	5 ft	5	REF		
8784	200.4 to 216.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	80	SF	\$40	\$3,180
47107	205.6 to 206.6 feet	Vertical Change	-.43	5 ft	5	REF		
47108	210.8 to 211.8 feet	Vertical Change	-.43	5 ft	5	REF		
8789	216.3 to 219.4 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	16	SF	\$40	\$620
41746	221.1 to 222.1 feet	Vertical Change	-.87	5 ft	5	REF		
8790	222.0 to 252.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	152	SF	\$120	\$18,180
42899	225.3 to 226.3 feet	Vertical Change	-.65	5 ft	5	REF		
43131	231.1 to 232.1 feet	Vertical Change	-.63	5 ft	5	REF		
54026	240.7 to 241.7 feet	Vertical Change	-.25	5 ft	5	REF		
44254	255.1 to 256.1 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375

TOTAL COST FOR: W side of AUTUMN WAY Starting at: PARKRIDGE DR \$84,800.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908221419	KITES WAY	ROSE AVE	ELM AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
41290	4.9 to 5.9 feet	Vertical Change	-1.61	5 ft	5	SF	\$75	\$375	
8792	6.0 to 23.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	87	SF	\$120	\$10,380	
43591	9.8 to 10.8 feet	Vertical Change	-6	5 ft	5	REF			
42134	15.3 to 16.3 feet	Vertical Change	-74	5 ft	5	REF			
58323	17.6 to 57.3 feet	Driveway				REF			
43132	19.3 to 20.3 feet	Vertical Change	-63	5 ft	5	REF			
41370	23.1 to 24.1 feet	Vertical Change	-1.36	5 ft	5	REF			
8796	26.3 to 53.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	138	SF	\$40	\$5,520	
41296	35.8 to 36.8 feet	Vertical Change	-1.59	5 ft	5	REF			
42051	45.3 to 46.3 feet	Vertical Change	-76	5 ft	5	REF			
41414	57.5 to 58.5 feet	Vertical Change	-1.24	5 ft	5	REF			
8800	57.6 to 71.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	70	SF	\$120	\$8,340	
41941	61.7 to 62.7 feet	Vertical Change	-79	5 ft	5	REF			
58324	66.5 to 93.0 feet	Driveway				REF			
41652	66.7 to 67.7 feet	Vertical Change	-93	5 ft	5	REF			
41942	71.4 to 72.4 feet	Vertical Change	-79	5 ft	5	REF			
8802	75.6 to 90.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	77	SF	\$40	\$3,060	
41581	82.6 to 83.6 feet	Vertical Change	-1	5 ft	5	REF			
47999	93.2 to 94.2 feet	Vertical Change	-4	5 ft	5	REF			
8807	93.9 to 95.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$840	
8808	96.4 to 136.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	201	SF	\$120	\$24,120	
44255	96.5 to 97.5 feet	Vertical Change	-56	5 ft	5	REF			
41767	99.9 to 100.9 feet	Vertical Change	-86	5 ft	5	REF			
42396	104.1 to 105.1 feet	Vertical Change	-7	5 ft	5	REF			
41678	108.0 to 109.0 feet	Vertical Change	-91	5 ft	5	REF			
43267	112.8 to 113.8 feet	Vertical Change	-62	5 ft	5	REF			
42014	117.6 to 118.6 feet	Vertical Change	-77	5 ft	5	REF			
43730	122.7 to 123.7 feet	Vertical Change	-59	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221419	KITES WAY	ROSE AVE	ELM AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41724	127.6 to 128.6 feet	Vertical Change	-.88	5 ft	5	REF		
58325	132.4 to 161.8 feet	Driveway				REF		
43133	132.7 to 133.7 feet	Vertical Change	-.63	5 ft	5	REF		
8812	136.6 to 138.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	8	SF	\$40	\$320
41207	137.5 to 138.5 feet	Vertical Change	-2.37	5 ft	5	REF		
8813	141.2 to 156.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	75	SF	\$40	\$3,000
41679	148.9 to 149.9 feet	Vertical Change	-.91	5 ft	5	REF		
41282	160.0 to 161.0 feet	Vertical Change	-1.65	5 ft	5	REF		
8818	160.2 to 197.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	185	SF	\$40	\$7,400
43592	164.5 to 165.5 feet	Vertical Change	-.6	5 ft	5	REF		
42489	169.4 to 170.4 feet	Vertical Change	-.69	5 ft	5	REF		
44464	174.1 to 175.1 feet	Vertical Change	-.55	5 ft	5	REF		
41747	179.1 to 180.1 feet	Vertical Change	-.87	5 ft	5	REF		
41943	183.7 to 184.7 feet	Vertical Change	-.79	5 ft	5	REF		
47336	188.9 to 189.9 feet	Vertical Change	-.42	5 ft	5	REF		
57156	193.2 to 194.2 feet	Vertical Change	.67	5 ft	5	REF		
8822	197.2 to 210.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	66	SF	\$120	\$7,920
45765	198.5 to 199.5 feet	Vertical Change	-.49	5 ft	5	REF		
41838	203.5 to 204.5 feet	Vertical Change	-.82	5 ft	5	REF		
58326	203.9 to 227.3 feet	Driveway				REF		
41561	208.6 to 209.6 feet	Vertical Change	-1.01	5 ft	5	REF		
8825	212.3 to 219.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	38	SF	\$40	\$1,500
41627	218.1 to 219.1 feet	Vertical Change	-.95	5 ft	5	REF		
8827	219.8 to 226.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	32	SF	\$40	\$1,260
45970	228.8 to 229.8 feet	Vertical Change	-.48	5 ft	5	REF		
8828	229.5 to 230.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$600
8829	230.5 to 234.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,100
45766	232.4 to 233.4 feet	Vertical Change	-.49	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908221419	KITES WAY	ROSE AVE	ELM AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
45256	235.9 to 236.9 feet	Vertical Change	-.51	5 ft	5	SF	\$75	\$375	
8830	239.3 to 245.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,660	
42135	240.3 to 241.3 feet	Vertical Change	-.74	5 ft	5	REF			
46184	244.9 to 245.9 feet	Vertical Change	-.47	5 ft	5	REF			
45548	249.9 to 250.9 feet	Vertical Change	-.5	5 ft	5	SF	\$75	\$375	
50439	254.6 to 255.6 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375	
58327	259.4 to 284.4 feet	Driveway				REF			
48533	259.8 to 260.8 feet	Vertical Change	-.38	5 ft	5	REF			
52625	264.9 to 266.0 feet	Vertical Change	-.28	5 ft	6	REF			
8831	269.2 to 277.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	43	SF	\$40	\$1,740	
43731	275.2 to 276.2 feet	Vertical Change	-.59	5 ft	5	REF			
8833	277.9 to 282.6 feet	Cross Slope (Driveway)	13.014	5 ft	24	SF	\$40	\$940	
43892	286.8 to 287.8 feet	Vertical Change	-.58	5 ft	5	REF			
8835	287.3 to 303.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	81	SF	\$120	\$9,720	
49113	290.4 to 291.4 feet	Vertical Change	-.36	5 ft	5	REF			
51742	294.0 to 295.0 feet	Vertical Change	-.3	5 ft	5	REF			
50440	298.0 to 299.0 feet	Vertical Change	-.32	5 ft	5	REF			
49415	301.4 to 302.4 feet	Vertical Change	-.35	5 ft	5	REF			
8837	303.5 to 323.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	99	SF	\$120	\$11,880	
50823	306.6 to 307.6 feet	Vertical Change	-.31	5 ft	5	REF			
41582	311.7 to 312.7 feet	Vertical Change	-1	5 ft	5	REF			
41653	317.1 to 318.1 feet	Vertical Change	-.93	5 ft	5	REF			
8844	323.3 to 341.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	93	SF	\$120	\$11,100	
45257	326.1 to 327.1 feet	Vertical Change	-.51	5 ft	5	REF			
44687	331.3 to 332.3 feet	Vertical Change	-.54	5 ft	5	REF			
43732	336.2 to 337.2 feet	Vertical Change	-.59	5 ft	5	REF			
58328	336.9 to 362.1 feet	Driveway				REF			
8846	345.1 to 359.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	74	SF	\$40	\$2,940	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221419	KITES WAY	ROSE AVE	ELM AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41707	351.0 to 352.0 feet	Vertical Change	-.89	5 ft	5	REF		
40305	358.7 to 360.4 feet	Running Slope	5.0-6.0%	5 ft	9	REF		
50824	362.8 to 363.8 feet	Vertical Change	-.31	5 ft	5	REF		
8850	363.2 to 371.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,220
43419	368.4 to 369.4 feet	Vertical Change	-.61	5 ft	5	REF		
43593	375.2 to 376.2 feet	Vertical Change	-.6	5 ft	5	SF	\$75	\$375
8851	379.4 to 380.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
44876	380.4 to 381.4 feet	Vertical Change	-.53	5 ft	5	REF		
53664	385.3 to 386.3 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
46643	390.3 to 391.3 feet	Vertical Change	-.45	5 ft	5	LF	\$75	\$375
8852	391.6 to 406.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,760
41897	395.0 to 396.0 feet	Vertical Change	-.8	5 ft	5	REF		
58329	400.8 to 424.1 feet	Driveway				REF		
41340	405.4 to 406.4 feet	Vertical Change	-1.41	5 ft	5	REF		
8854	409.8 to 422.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	66	SF	\$40	\$2,620
47338	415.2 to 416.2 feet	Vertical Change	-.42	5 ft	5	REF		
40306	421.8 to 423.4 feet	Running Slope	5.0-6.0%	5 ft	8	REF		
41402	425.8 to 426.8 feet	Vertical Change	-1.27	5 ft	5	REF		
8857	426.8 to 474.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	237	SF	\$120	\$28,440
45767	429.5 to 430.5 feet	Vertical Change	-.49	5 ft	5	REF		
48248	433.7 to 434.7 feet	Vertical Change	-.39	5 ft	5	REF		
46875	438.4 to 439.4 feet	Vertical Change	-.44	5 ft	5	REF		
41822	447.9 to 448.9 feet	Vertical Change	-.83	5 ft	5	REF		
45549	452.9 to 453.9 feet	Vertical Change	-.5	5 ft	5	REF		
49736	458.3 to 459.3 feet	Vertical Change	-.34	5 ft	5	REF		
46644	463.0 to 464.0 feet	Vertical Change	-.45	5 ft	5	REF		
58330	467.5 to 493.6 feet	Driveway				REF		
49737	468.7 to 469.7 feet	Vertical Change	-.34	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221419	KITES WAY	ROSE AVE	ELM AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
53665	473.4 to 474.4 feet	Vertical Change	-.26	5 ft	5	REF		
8865	477.7 to 491.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	71	SF	\$40	\$2,820
46876	484.6 to 485.6 feet	Vertical Change	-.44	5 ft	5	REF		
40307	490.8 to 491.8 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
41801	494.6 to 495.6 feet	Vertical Change	-.84	5 ft	5	REF		
8867	495.2 to 496.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
8868	500.6 to 540.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	198	SF	\$120	\$23,820
47578	501.4 to 502.4 feet	Vertical Change	-.41	5 ft	5	REF		
44465	508.8 to 509.8 feet	Vertical Change	-.55	5 ft	5	REF		
45550	513.6 to 514.6 feet	Vertical Change	-.5	5 ft	5	REF		
46417	519.3 to 520.3 feet	Vertical Change	-.46	5 ft	5	REF		
46418	529.2 to 530.2 feet	Vertical Change	-.46	5 ft	5	REF		
58331	533.7 to 560.1 feet	Driveway				REF		
49114	534.7 to 535.7 feet	Vertical Change	-.36	5 ft	5	REF		
41407	539.4 to 540.4 feet	Vertical Change	-1.25	5 ft	5	REF		
8874	543.2 to 558.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	78	SF	\$40	\$3,120
44065	550.0 to 551.0 feet	Vertical Change	-.57	5 ft	5	REF		
40308	558.2 to 559.2 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
8879	561.7 to 576.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	75	SF	\$120	\$9,000
44688	573.5 to 574.5 feet	Vertical Change	-.54	5 ft	5	REF		
8880	576.7 to 603.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	135	SF	\$120	\$16,260
51743	578.3 to 579.3 feet	Vertical Change	-.3	5 ft	5	REF		
48249	583.4 to 584.4 feet	Vertical Change	-.39	5 ft	5	REF		
48250	587.8 to 588.8 feet	Vertical Change	-.39	5 ft	5	REF		
51744	598.1 to 599.1 feet	Vertical Change	-.3	5 ft	5	REF		
58332	598.3 to 623.0 feet	Driveway				REF		
41364	603.3 to 604.3 feet	Vertical Change	-1.37	5 ft	5	REF		
8884	606.3 to 609.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	15	SF	\$40	\$600

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
W	1908221419	KITES WAY	ROSE AVE	ELM AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
8886	609.3 to 620.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	58	SF	\$40	\$2,300	
43420	614.8 to 615.8 feet	Vertical Change	-.61	5 ft	5	REF			
40309	619.5 to 621.3 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
8890	624.3 to 631.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	35	SF	\$120	\$4,200	
50825	628.7 to 629.7 feet	Vertical Change	-.31	5 ft	5	REF			
8891	631.3 to 679.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	242	SF	\$120	\$28,980	
50060	634.5 to 635.5 feet	Vertical Change	-.33	5 ft	5	REF			
48000	649.9 to 650.9 feet	Vertical Change	-.4	5 ft	5	REF			
49416	653.7 to 654.7 feet	Vertical Change	-.35	5 ft	5	REF			
48832	657.6 to 658.6 feet	Vertical Change	-.37	5 ft	5	REF			
58333	674.3 to 712.4 feet	Driveway				REF			
44689	678.9 to 679.9 feet	Vertical Change	-.54	5 ft	5	REF			
8896	683.0 to 687.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	21	SF	\$40	\$840	
8898	687.2 to 694.7 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	38	SF	\$40	\$1,500	
52626	691.0 to 692.0 feet	Vertical Change	-.28	5 ft	5	REF			
8900	694.7 to 710.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	79	SF	\$40	\$3,140	
46645	701.1 to 702.1 feet	Vertical Change	-.45	5 ft	5	REF			
40310	709.8 to 711.9 feet	Running Slope	5.0-6.0%	5 ft	11	REF			
43421	713.7 to 714.7 feet	Vertical Change	-.61	5 ft	5	REF			
8903	714.3 to 715.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$660	
8904	715.4 to 718.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860	
58334	720.7 to 751.2 feet	Driveway				REF			
47579	725.8 to 726.8 feet	Vertical Change	-.41	5 ft	5	REF			
8905	729.7 to 748.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	93	SF	\$40	\$3,700	
47339	751.8 to 752.8 feet	Vertical Change	-.42	5 ft	5	REF			
8909	752.4 to 754.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,080	
8910	754.2 to 802.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	241	SF	\$120	\$28,920	
50441	771.6 to 772.6 feet	Vertical Change	-.32	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908221419	KITES WAY	ROSE AVE	ELM AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
52627	781.7 to 782.7 feet	Vertical Change	-.28	5 ft	5	REF			
46877	791.5 to 792.5 feet	Vertical Change	-.44	5 ft	5	REF			
58335	796.7 to 822.3 feet	Driveway				REF			
41435	801.7 to 802.7 feet	Vertical Change	-1.2	5 ft	5	REF			
8913	806.1 to 815.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	48	SF	\$40	\$1,920	
42052	812.3 to 813.3 feet	Vertical Change	-.76	5 ft	5	REF			
8916	815.7 to 819.7 feet	Cross Slope (Driveway)	13.014	5 ft	20	SF	\$40	\$800	
40311	819.5 to 821.5 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
41839	823.1 to 824.1 feet	Vertical Change	-.82	5 ft	5	REF			
8918	823.6 to 824.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$660	
8919	824.7 to 833.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,460	
8921	833.8 to 860.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	133	SF	\$120	\$15,900	
41604	834.5 to 835.5 feet	Vertical Change	-.98	5 ft	5	REF			
45551	842.6 to 843.6 feet	Vertical Change	-.5	5 ft	5	REF			
53137	846.7 to 847.7 feet	Vertical Change	-.27	5 ft	5	REF			
52628	855.4 to 856.4 feet	Vertical Change	-.28	5 ft	5	REF			

TOTAL COST FOR:	W	<i>side of</i>	KITES WAY	<i>Starting at:</i>	ROSE AVE	\$324,985.00
------------------------	----------	----------------	------------------	---------------------	-----------------	---------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221420	ELM AVE	KITES WAY	PHILLIP WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
8924	3.9 to 36.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	162	SF	\$120	\$19,440
8926	36.3 to 82.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	229	SF	\$120	\$27,480
8930	82.1 to 97.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	79	SF	\$120	\$9,420
53138	84.8 to 85.8 feet	Vertical Change	-27	5 ft	5	REF		
49738	94.8 to 95.8 feet	Vertical Change	-.34	5 ft	5	REF		
8932	97.8 to 105.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	36	SF	\$120	\$4,320
50442	104.7 to 105.7 feet	Vertical Change	-.32	5 ft	5	REF		
8934	105.0 to 206.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	508	SF	\$120	\$60,900
53666	124.6 to 125.6 feet	Vertical Change	-.26	5 ft	5	REF		
50443	141.7 to 142.7 feet	Vertical Change	-.32	5 ft	5	REF		
47109	165.0 to 166.0 feet	Vertical Change	-.43	5 ft	5	REF		
TOTAL COST FOR: N side of ELM AVE Starting at: KITES WAY							\$121,560.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908221424	PHILLIP WAY	ELM AVE	ROSE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
8942	0.0 to 6.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	34	SF	\$120	\$4,020	
58336	5.3 to 29.8 feet	Driveway				REF			
8943	6.7 to 9.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	16	SF	\$40	\$620	
8944	13.8 to 27.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	70	SF	\$40	\$2,800	
47340	20.0 to 21.0 feet	Vertical Change	-.42	5 ft	5	REF			
8946	31.0 to 42.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,140	
53139	34.5 to 35.5 feet	Vertical Change	-.27	5 ft	5	REF			
58337	36.8 to 58.8 feet	Driveway				REF			
49417	39.7 to 40.7 feet	Vertical Change	-.35	5 ft	5	REF			
8949	46.6 to 62.5 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	80	SF	\$40	\$3,180	
8951	65.6 to 106.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	203	SF	\$120	\$24,300	
52629	65.9 to 66.9 feet	Vertical Change	-.28	5 ft	5	REF			
43422	68.7 to 69.7 feet	Vertical Change	-.61	5 ft	5	REF			
45258	71.8 to 72.8 feet	Vertical Change	-.51	5 ft	5	REF			
42095	82.5 to 83.5 feet	Vertical Change	-.75	5 ft	5	REF			
47580	92.8 to 93.8 feet	Vertical Change	-.41	5 ft	5	REF			
44877	96.5 to 97.5 feet	Vertical Change	-.53	5 ft	5	REF			
58338	98.2 to 125.4 feet	Driveway				REF			
50061	102.0 to 103.0 feet	Vertical Change	-.33	5 ft	5	REF			
41944	103.4 to 107.3 feet	Vertical Change	-.79	5 ft	20	REF			
8955	106.1 to 108.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	12	SF	\$40	\$480	
8957	109.4 to 110.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$240	
8958	110.6 to 117.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	32	SF	\$40	\$1,280	
8959	117.0 to 126.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	49	SF	\$40	\$1,960	
44066	117.8 to 118.8 feet	Vertical Change	-.57	5 ft	5	REF			
8961	126.8 to 128.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$900	
8962	128.3 to 172.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	220	SF	\$120	\$26,400	
42579	129.1 to 130.1 feet	Vertical Change	-.68	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221424	PHILLIP WAY	ELM AVE	ROSE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46878	133.7 to 134.7 feet	Vertical Change	-.44	5 ft	5	REF		
48251	147.5 to 148.5 feet	Vertical Change	-.39	5 ft	5	REF		
50826	156.6 to 157.6 feet	Vertical Change	-.31	5 ft	5	REF		
45552	159.9 to 160.9 feet	Vertical Change	-.5	5 ft	5	REF		
58339	161.3 to 189.8 feet	Driveway				REF		
54027	167.3 to 168.3 feet	Vertical Change	-.25	5 ft	5	REF		
8964	172.3 to 184.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	61	SF	\$40	\$2,440
42136	181.9 to 182.9 feet	Vertical Change	-.74	5 ft	5	REF		
8966	184.5 to 191.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	37	SF	\$40	\$1,460
8967	191.8 to 192.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	5	SF	\$120	\$600
8968	193.5 to 194.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$780
45971	194.2 to 198.2 feet	Vertical Change	-.48	5 ft	20	REF		
8969	194.8 to 199.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700
8971	199.3 to 250.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	254	SF	\$120	\$30,420
42298	201.0 to 202.0 feet	Vertical Change	-.71	5 ft	5	REF		
42900	211.1 to 212.1 feet	Vertical Change	-.65	5 ft	5	REF		
46419	220.3 to 221.3 feet	Vertical Change	-.46	5 ft	5	REF		
48252	228.3 to 229.3 feet	Vertical Change	-.39	5 ft	5	REF		
47581	238.4 to 239.4 feet	Vertical Change	-.41	5 ft	5	REF		
44256	248.4 to 249.4 feet	Vertical Change	-.56	5 ft	5	REF		
8978	250.0 to 261.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,960
58340	256.1 to 282.8 feet	Driveway				REF		
44878	258.9 to 259.9 feet	Vertical Change	-.53	5 ft	5	REF		
8980	261.6 to 262.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$200
8981	265.6 to 277.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	58	SF	\$40	\$2,320
46879	273.1 to 274.1 feet	Vertical Change	-.44	5 ft	5	REF		
8983	277.2 to 281.0 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	19	SF	\$40	\$760
52164	284.0 to 285.0 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221424	PHILLIP WAY	ELM AVE	ROSE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
8985	285.2 to 299.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	69	SF	\$120	\$8,280
43423	287.0 to 290.8 feet	Vertical Change	-.61	5 ft	19	REF		
58341	290.2 to 331.2 feet	Driveway				REF		
52165	298.3 to 299.3 feet	Vertical Change	-.29	5 ft	5	REF		
8987	302.5 to 307.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	27	SF	\$40	\$1,060
45259	306.2 to 307.2 feet	Vertical Change	-.51	5 ft	5	REF		
8989	307.8 to 328.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	103	SF	\$40	\$4,100
41787	309.7 to 310.7 feet	Vertical Change	-.85	5 ft	5	REF		
41898	319.6 to 320.6 feet	Vertical Change	-.8	5 ft	5	REF		
47341	323.7 to 324.7 feet	Vertical Change	-.42	5 ft	5	REF		
8995	331.3 to 351.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	101	SF	\$40	\$4,020
47110	332.0 to 333.0 feet	Vertical Change	-.43	5 ft	5	REF		
43004	338.9 to 339.9 feet	Vertical Change	-.64	5 ft	5	REF		
42786	349.0 to 350.0 feet	Vertical Change	-.66	5 ft	5	REF		
8996	351.4 to 389.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	190	SF	\$120	\$22,740
45769	353.9 to 354.9 feet	Vertical Change	-.49	5 ft	5	REF		
45260	359.4 to 360.4 feet	Vertical Change	-.51	5 ft	5	REF		
42580	369.6 to 370.6 feet	Vertical Change	-.68	5 ft	5	REF		
58342	379.5 to 407.8 feet	Driveway				REF		
48534	380.2 to 381.2 feet	Vertical Change	-.38	5 ft	5	REF		
46647	384.3 to 385.3 feet	Vertical Change	-.45	5 ft	5	REF		
9004	389.3 to 390.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	6	SF	\$40	\$220
9005	391.3 to 405.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	70	SF	\$40	\$2,780
48253	398.7 to 399.7 feet	Vertical Change	-.39	5 ft	5	REF		
9007	405.2 to 407.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	10	SF	\$40	\$380
9008	409.6 to 441.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	161	SF	\$120	\$19,260
50062	413.0 to 414.0 feet	Vertical Change	-.33	5 ft	5	REF		
58343	418.0 to 447.6 feet	Driveway				REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221424	PHILLIP WAY	ELM AVE	ROSE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
50063	421.4 to 422.4 feet	Vertical Change	-.33	5 ft	5	REF		
42299	424.0 to 425.0 feet	Vertical Change	-.71	5 ft	5	REF		
52166	427.0 to 428.0 feet	Vertical Change	-.29	5 ft	5	REF		
43733	438.4 to 439.4 feet	Vertical Change	-.59	5 ft	5	REF		
9013	441.7 to 446.7 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	25	SF	\$40	\$1,000
9015	449.2 to 494.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	225	SF	\$120	\$26,940
41899	452.9 to 453.9 feet	Vertical Change	-.8	5 ft	5	REF		
48001	463.6 to 464.6 feet	Vertical Change	-.4	5 ft	5	REF		
47582	476.1 to 477.1 feet	Vertical Change	-.41	5 ft	5	REF		
48833	485.9 to 486.9 feet	Vertical Change	-.37	5 ft	5	REF		
58344	486.9 to 512.9 feet	Driveway				REF		
45553	489.4 to 490.4 feet	Vertical Change	-.5	5 ft	5	REF		
9021	496.5 to 511.7 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	76	SF	\$40	\$3,040
45058	504.1 to 505.1 feet	Vertical Change	-.52	5 ft	5	REF		
51745	509.4 to 510.4 feet	Vertical Change	-.3	5 ft	5	REF		
9025	514.4 to 538.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	122	SF	\$120	\$14,580
43005	517.5 to 518.5 feet	Vertical Change	-.64	5 ft	5	REF		
42581	527.9 to 528.9 feet	Vertical Change	-.68	5 ft	5	REF		
9030	538.7 to 549.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,660
57157	548.6 to 549.6 feet	Vertical Change	.67	5 ft	5	REF		
58345	551.7 to 578.8 feet	Driveway				REF		
9031	552.3 to 558.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	30	SF	\$40	\$1,180
45972	554.0 to 555.0 feet	Vertical Change	-.48	5 ft	5	REF		
52167	557.1 to 558.1 feet	Vertical Change	-.29	5 ft	5	REF		
9033	561.4 to 575.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	73	SF	\$40	\$2,900
45554	568.4 to 569.4 feet	Vertical Change	-.5	5 ft	5	REF		
9038	578.8 to 621.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	216	SF	\$40	\$8,620
52630	579.8 to 580.8 feet	Vertical Change	-.28	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908221424	PHILLIP WAY	ELM AVE	ROSE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
42137	582.9 to 583.9 feet	Vertical Change	-.74	5 ft	5	REF			
47342	600.2 to 603.1 feet	Vertical Change	-.42	5 ft	14	REF			
44879	610.4 to 611.4 feet	Vertical Change	-.53	5 ft	5	REF			
58346	615.0 to 641.8 feet	Driveway				REF			
46880	617.5 to 618.5 feet	Vertical Change	-.44	5 ft	5	REF			
9043	625.5 to 631.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	29	SF	\$40	\$1,160	
9045	631.3 to 638.9 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	38	SF	\$40	\$1,520	
45555	631.9 to 632.9 feet	Vertical Change	-.5	5 ft	5	REF			
47583	643.5 to 647.3 feet	Vertical Change	-.41	5 ft	19	REF			
9046	643.8 to 681.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	190	SF	\$120	\$22,740	
45556	651.5 to 652.5 feet	Vertical Change	-.5	5 ft	5	REF			
53140	661.3 to 662.3 feet	Vertical Change	-.27	5 ft	5	REF			
49418	670.8 to 671.8 feet	Vertical Change	-.35	5 ft	5	REF			
58347	677.1 to 705.4 feet	Driveway				REF			
45059	677.8 to 678.8 feet	Vertical Change	-.52	5 ft	5	REF			
9052	684.6 to 688.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	17	SF	\$40	\$680	
9054	688.0 to 689.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	9	SF	\$40	\$360	
9055	689.8 to 698.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	42	SF	\$40	\$1,680	
49115	692.2 to 693.2 feet	Vertical Change	-.36	5 ft	5	REF			
9056	698.2 to 700.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	13	SF	\$40	\$520	
9057	704.9 to 745.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	201	SF	\$40	\$8,040	
42787	706.8 to 707.8 feet	Vertical Change	-.66	5 ft	5	REF			
48254	720.2 to 721.2 feet	Vertical Change	-.39	5 ft	5	REF			
46185	730.3 to 731.3 feet	Vertical Change	-.47	5 ft	5	REF			
58348	735.8 to 763.7 feet	Driveway				REF			
46648	737.9 to 741.6 feet	Vertical Change	-.45	5 ft	19	REF			
9063	745.1 to 755.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	53	SF	\$40	\$2,120	
43594	753.2 to 754.2 feet	Vertical Change	-.6	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221424	PHILLIP WAY	ELM AVE	ROSE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9067	755.7 to 796.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	203	SF	\$40	\$8,100
48002	765.4 to 766.4 feet	Vertical Change	-.4	5 ft	5	REF		
48003	768.7 to 769.7 feet	Vertical Change	-.4	5 ft	5	REF		
43734	772.4 to 773.4 feet	Vertical Change	-.59	5 ft	5	REF		
46186	782.1 to 783.1 feet	Vertical Change	-.47	5 ft	5	REF		
49116	791.9 to 792.9 feet	Vertical Change	-.36	5 ft	5	REF		
TOTAL COST FOR: E side of PHILLIP WAY Starting at: ELM AVE							\$297,015.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
S	1908221425	ROSE AVE	PHILLIP WAY	KITES WAY				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9070	0.0 to 66.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	331	SF	\$120	\$39,720
41987	5.7 to 6.7 feet	Vertical Change	-.78	5 ft	5	REF		
46420	16.5 to 17.5 feet	Vertical Change	-.46	5 ft	5	REF		
47343	46.9 to 47.9 feet	Vertical Change	-.42	5 ft	5	REF		
49419	67.3 to 68.3 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$375
9074	75.8 to 78.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
9075	80.7 to 148.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	341	SF	\$120	\$40,860
42300	108.8 to 109.8 feet	Vertical Change	-.71	5 ft	5	REF		
48255	113.9 to 114.9 feet	Vertical Change	-.39	5 ft	5	REF		
51746	124.0 to 125.0 feet	Vertical Change	-.3	5 ft	5	REF		
49739	139.0 to 140.0 feet	Vertical Change	-.34	5 ft	5	REF		
9080	148.8 to 162.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	70	SF	\$120	\$8,400
49420	149.2 to 150.2 feet	Vertical Change	-.35	5 ft	5	REF		
49740	159.4 to 160.4 feet	Vertical Change	-.34	5 ft	5	REF		
9082	162.8 to 191.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	145	SF	\$120	\$17,400
47584	165.8 to 166.8 feet	Vertical Change	-.41	5 ft	5	REF		
49741	170.6 to 171.6 feet	Vertical Change	-.34	5 ft	5	REF		
48256	175.2 to 176.2 feet	Vertical Change	-.39	5 ft	5	REF		
44467	184.7 to 188.2 feet	Vertical Change	-.55	5 ft	18	REF		

TOTAL COST FOR: S side of ROSE AVE Starting at: PHILLIP WAY \$108,255.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908221428	ROSE AVE	AUTUMN WAY	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
44257	0.6 to 1.6 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375	
9085	2.1 to 6.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760	
41395	5.4 to 6.4 feet	Vertical Change	-1.28	5 ft	5	REF			
49117	10.8 to 11.8 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375	
9086	12.5 to 27.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,880	
48535	20.6 to 21.6 feet	Vertical Change	-.38	5 ft	5	REF			
53668	30.3 to 31.3 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
49421	39.9 to 40.9 feet	Vertical Change	-.35	5 ft	5	REF			
9087	40.9 to 48.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320	
44880	49.8 to 50.8 feet	Vertical Change	-.53	5 ft	5	SF	\$75	\$375	
9088	52.8 to 55.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620	
9089	58.5 to 110.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	262	SF	\$120	\$31,440	
46421	59.7 to 60.7 feet	Vertical Change	-.46	5 ft	5	REF			
48536	69.4 to 70.4 feet	Vertical Change	-.38	5 ft	5	REF			
52631	79.2 to 80.2 feet	Vertical Change	-.28	5 ft	5	REF			
46187	88.9 to 91.5 feet	Vertical Change	-.47	5 ft	13	REF			
46422	98.6 to 99.6 feet	Vertical Change	-.46	5 ft	5	REF			
46649	105.2 to 112.8 feet	Vertical Change	-.45	5 ft	38	REF			
58349	106.4 to 142.3 feet	Driveway				REF			
9091	110.9 to 159.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	242	SF	\$40	\$9,680	
45261	116.3 to 117.3 feet	Vertical Change	-.51	5 ft	5	REF			
43893	121.0 to 122.0 feet	Vertical Change	-.58	5 ft	5	REF			
49742	127.6 to 128.6 feet	Vertical Change	-.34	5 ft	5	REF			
44690	132.4 to 133.4 feet	Vertical Change	-.54	5 ft	5	REF			
48834	137.1 to 138.1 feet	Vertical Change	-.37	5 ft	5	REF			
45557	141.4 to 142.4 feet	Vertical Change	-.5	5 ft	5	REF			
45060	145.4 to 147.0 feet	Vertical Change	-.52	5 ft	8	REF			
45061	149.1 to 151.2 feet	Vertical Change	-.52	5 ft	10	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221428	ROSE AVE	AUTUMN WAY	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58350	154.7 to 180.1 feet	Driveway				REF		
50828	156.5 to 163.0 feet	Vertical Change	-31	5 ft	33	REF		
9097	161.1 to 167.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	34	SF	\$40	\$1,340
9100	167.8 to 185.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	88	SF	\$40	\$3,500
53141	170.6 to 171.6 feet	Vertical Change	-27	5 ft	5	REF		
47344	181.0 to 182.0 feet	Vertical Change	-42	5 ft	5	REF		
42490	184.5 to 185.5 feet	Vertical Change	-69	5 ft	5	REF		
9105	185.3 to 237.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	263	SF	\$120	\$31,500
49743	185.5 to 186.5 feet	Vertical Change	-34	5 ft	5	REF		
44692	188.7 to 192.2 feet	Vertical Change	-54	5 ft	18	REF		
44067	196.4 to 199.9 feet	Vertical Change	-57	5 ft	18	REF		
50829	201.3 to 202.3 feet	Vertical Change	-31	5 ft	5	REF		
46651	206.2 to 209.7 feet	Vertical Change	-45	5 ft	18	REF		
48257	225.0 to 226.0 feet	Vertical Change	-39	5 ft	5	REF		
58351	229.8 to 268.3 feet	Driveway				REF		
47111	231.4 to 232.4 feet	Vertical Change	-43	5 ft	5	REF		
50065	235.0 to 238.9 feet	Vertical Change	-33	5 ft	20	REF		
9111	237.8 to 239.1 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	7	SF	\$40	\$260
9112	239.1 to 242.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	16	SF	\$40	\$620
9113	242.2 to 273.0 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	154	SF	\$40	\$6,160
48537	246.2 to 247.2 feet	Vertical Change	-38	5 ft	5	REF		
41174	247.7 to 248.7 feet	Vertical Change	-3.24	5 ft	5	REF		
46881	259.9 to 260.9 feet	Vertical Change	-44	5 ft	5	REF		
44068	265.7 to 266.7 feet	Vertical Change	-57	5 ft	5	REF		
44881	271.4 to 272.4 feet	Vertical Change	-53	5 ft	5	REF		
9117	273.0 to 283.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	54	SF	\$120	\$6,540
48005	274.5 to 275.5 feet	Vertical Change	-4	5 ft	5	REF		
58352	279.4 to 318.5 feet	Driveway				REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221428	ROSE AVE	AUTUMN WAY	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44468	285.0 to 288.0 feet	Vertical Change	-.55	5 ft	15	REF		
9119	286.6 to 289.2 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	13	SF	\$40	\$520
9121	290.8 to 293.1 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	12	SF	\$40	\$460
44882	292.9 to 293.9 feet	Vertical Change	-.53	5 ft	5	REF		
9123	293.1 to 308.6 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	78	SF	\$40	\$3,100
44883	301.1 to 302.1 feet	Vertical Change	-.53	5 ft	5	REF		
9125	308.6 to 313.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	23	SF	\$40	\$940
44469	308.9 to 309.9 feet	Vertical Change	-.55	5 ft	5	REF		
9126	313.3 to 316.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	16	SF	\$40	\$640
44693	314.2 to 315.2 feet	Vertical Change	-.54	5 ft	5	REF		
9127	316.5 to 319.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	14	SF	\$40	\$560
41620	317.2 to 318.2 feet	Vertical Change	-.96	5 ft	5	REF		
9129	319.3 to 327.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	42	SF	\$120	\$5,040
42237	324.3 to 325.3 feet	Vertical Change	-.72	5 ft	5	REF		
9132	327.7 to 363.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	177	SF	\$120	\$21,240
43895	331.8 to 332.8 feet	Vertical Change	-.58	5 ft	5	REF		
44884	341.7 to 342.7 feet	Vertical Change	-.53	5 ft	5	REF		
43269	351.4 to 352.4 feet	Vertical Change	-.62	5 ft	5	REF		
58353	356.3 to 399.8 feet	Driveway				REF		
46652	357.9 to 358.9 feet	Vertical Change	-.45	5 ft	5	REF		
9138	363.1 to 365.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	13	SF	\$40	\$500
46423	364.1 to 366.7 feet	Vertical Change	-.46	5 ft	13	REF		
9140	365.6 to 369.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	17	SF	\$40	\$680
9141	369.0 to 378.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	48	SF	\$40	\$1,920
48006	370.6 to 371.6 feet	Vertical Change	-.4	5 ft	5	REF		
44694	377.1 to 378.1 feet	Vertical Change	-.54	5 ft	5	REF		
9143	378.6 to 392.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	68	SF	\$40	\$2,700
42684	381.6 to 382.6 feet	Vertical Change	-.67	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221428	ROSE AVE	AUTUMN WAY	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41768	386.1 to 387.1 feet	Vertical Change	-.86	5 ft	5	REF		
9145	392.1 to 393.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$220
45973	392.2 to 393.2 feet	Vertical Change	-.48	5 ft	5	REF		
9146	393.2 to 397.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	21	SF	\$40	\$820
49745	398.6 to 399.6 feet	Vertical Change	-.34	5 ft	5	REF		
9149	400.0 to 411.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	56	SF	\$40	\$2,220
43595	402.3 to 403.3 feet	Vertical Change	-.6	5 ft	5	REF		
58354	407.3 to 432.3 feet	Driveway				REF		
50444	409.6 to 412.8 feet	Vertical Change	-.32	5 ft	16	REF		
9150	414.5 to 424.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	51	SF	\$40	\$2,040
44470	421.8 to 422.8 feet	Vertical Change	-.55	5 ft	5	REF		
9152	424.7 to 429.4 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	24	SF	\$40	\$940
40312	428.2 to 430.5 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
46653	431.8 to 432.8 feet	Vertical Change	-.45	5 ft	5	REF		
9153	434.0 to 470.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	180	SF	\$120	\$21,600
46189	442.8 to 443.8 feet	Vertical Change	-.47	5 ft	5	REF		
49422	452.6 to 453.6 feet	Vertical Change	-.35	5 ft	5	REF		
46424	462.2 to 463.2 feet	Vertical Change	-.46	5 ft	5	REF		
9159	475.5 to 491.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	80	SF	\$120	\$9,540
58355	482.6 to 523.6 feet	Driveway				REF		
48258	487.0 to 488.0 feet	Vertical Change	-.39	5 ft	5	REF		
41725	491.0 to 492.0 feet	Vertical Change	-.88	5 ft	5	REF		
9163	491.4 to 510.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	97	SF	\$40	\$3,860
43134	496.5 to 497.5 feet	Vertical Change	-.63	5 ft	5	REF		
45062	502.1 to 503.1 feet	Vertical Change	-.52	5 ft	5	REF		
53142	507.2 to 508.2 feet	Vertical Change	-.27	5 ft	5	REF		
9167	510.7 to 518.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	38	SF	\$40	\$1,500
46190	512.6 to 513.6 feet	Vertical Change	-.47	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221428	ROSE AVE	AUTUMN WAY	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46191	517.7 to 518.7 feet	Vertical Change	-.47	5 ft	5	REF		
9169	518.2 to 553.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	178	SF	\$40	\$7,120
48836	522.2 to 523.2 feet	Vertical Change	-.37	5 ft	5	REF		
42902	523.4 to 524.4 feet	Vertical Change	-.65	5 ft	5	REF		
45559	527.6 to 528.6 feet	Vertical Change	-.5	5 ft	5	REF		
45262	531.4 to 532.4 feet	Vertical Change	-.51	5 ft	5	REF		
58356	534.8 to 574.1 feet	Driveway				REF		
52632	536.7 to 537.7 feet	Vertical Change	-.28	5 ft	5	REF		
41374	540.6 to 541.6 feet	Vertical Change	-1.35	5 ft	5	REF		
47112	541.0 to 542.0 feet	Vertical Change	-.43	5 ft	5	REF		
46425	546.2 to 547.2 feet	Vertical Change	-.46	5 ft	5	REF		
43135	550.9 to 551.9 feet	Vertical Change	-.63	5 ft	5	REF		
9177	553.8 to 569.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	79	SF	\$40	\$3,140
42788	556.7 to 557.7 feet	Vertical Change	-.66	5 ft	5	REF		
48259	561.9 to 562.9 feet	Vertical Change	-.39	5 ft	5	REF		
46882	567.1 to 568.1 feet	Vertical Change	-.44	5 ft	5	REF		
9179	569.5 to 575.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	28	SF	\$40	\$1,100
41306	572.5 to 573.5 feet	Vertical Change	-1.55	5 ft	5	REF		
9181	575.0 to 586.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,960
43424	576.8 to 577.8 feet	Vertical Change	-.61	5 ft	5	REF		
45063	579.9 to 580.9 feet	Vertical Change	-.52	5 ft	5	REF		
51747	587.3 to 588.3 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375
47585	591.9 to 592.9 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: N side of ROSE AVE Starting at: AUTUMN WAY							\$210,230.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
S	1908221430	ROSE AVE	SANTA CRUZ BLVD	PHILLIP WAY	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
9182	0.0 to 18.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	92	SF	\$120	\$10,980	
52169	0.2 to 1.2 feet	Vertical Change	-29	5 ft	5	REF			
52170	6.1 to 7.1 feet	Vertical Change	-29	5 ft	5	REF			
58357	11.9 to 52.7 feet	Driveway				REF			
42096	14.3 to 15.3 feet	Vertical Change	-.75	5 ft	5	REF			
9184	18.3 to 20.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	13	SF	\$40	\$500	
9186	20.8 to 23.1 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	12	SF	\$40	\$460	
9187	23.1 to 37.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	71	SF	\$40	\$2,840	
45064	31.9 to 32.9 feet	Vertical Change	-.52	5 ft	5	REF			
9190	37.3 to 49.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	63	SF	\$40	\$2,500	
44471	42.0 to 43.0 feet	Vertical Change	-.55	5 ft	5	REF			
9191	49.8 to 54.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	25	SF	\$40	\$1,000	
48837	51.5 to 52.5 feet	Vertical Change	-.37	5 ft	5	REF			
9193	54.8 to 65.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	52	SF	\$120	\$6,240	
58358	60.9 to 88.7 feet	Driveway				REF			
44258	62.4 to 63.4 feet	Vertical Change	-.56	5 ft	5	REF			
9196	65.2 to 70.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	29	SF	\$40	\$1,140	
45065	66.2 to 67.2 feet	Vertical Change	-.52	5 ft	5	REF			
56954	66.3 to 67.3 feet	Vertical Change	.55	5 ft	5	REF			
47345	66.4 to 67.4 feet	Vertical Change	-.42	5 ft	5	REF			
9198	70.9 to 91.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	102	SF	\$40	\$4,080	
42138	77.7 to 78.7 feet	Vertical Change	-.74	5 ft	5	REF			
54028	90.0 to 91.0 feet	Vertical Change	-.25	5 ft	5	REF			
9200	91.3 to 118.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	137	SF	\$120	\$16,380	
43270	102.7 to 103.7 feet	Vertical Change	-.62	5 ft	5	REF			
44695	114.3 to 115.3 feet	Vertical Change	-.54	5 ft	5	REF			
9204	118.6 to 144.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	127	SF	\$120	\$15,240	
49118	125.0 to 126.0 feet	Vertical Change	-.36	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221430	ROSE AVE	SANTA CRUZ BLVD	PHILLIP WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
43271	136.3 to 137.3 feet	Vertical Change	-.62	5 ft	5	REF		
9206	144.0 to 162.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	90	SF	\$120	\$10,800
47346	144.4 to 145.4 feet	Vertical Change	-.42	5 ft	5	REF		
42903	147.6 to 148.6 feet	Vertical Change	-.65	5 ft	5	REF		
58359	150.8 to 182.8 feet	Driveway				REF		
44885	155.6 to 156.6 feet	Vertical Change	-.53	5 ft	5	REF		
9209	162.0 to 164.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	13	SF	\$40	\$500
9211	164.5 to 166.1 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	8	SF	\$40	\$320
9212	166.1 to 182.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	81	SF	\$40	\$3,220
46654	172.5 to 173.5 feet	Vertical Change	-.45	5 ft	5	REF		
9216	182.2 to 203.7 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	108	SF	\$40	\$4,300
46192	183.3 to 184.3 feet	Vertical Change	-.47	5 ft	5	REF		
44472	186.9 to 187.9 feet	Vertical Change	-.55	5 ft	5	REF		
58360	196.4 to 224.0 feet	Driveway				REF		
45771	198.8 to 199.8 feet	Vertical Change	-.49	5 ft	5	REF		
53672	202.7 to 203.7 feet	Vertical Change	-.26	5 ft	5	REF		
9217	204.6 to 205.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200
9218	205.6 to 210.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	24	SF	\$40	\$940
9221	210.3 to 220.1 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	49	SF	\$40	\$1,960
47347	213.7 to 214.7 feet	Vertical Change	-.42	5 ft	5	REF		
9225	220.1 to 224.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	20	SF	\$40	\$780
56923	223.8 to 224.8 feet	Vertical Change	.52	5 ft	5	REF		
9227	224.8 to 231.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	33	SF	\$120	\$3,900
9229	231.3 to 245.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	70	SF	\$120	\$8,400
43425	238.6 to 239.6 feet	Vertical Change	-.61	5 ft	5	REF		
53673	250.4 to 251.4 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
9230	259.5 to 268.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,400
58361	259.8 to 289.9 feet	Driveway				REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221430	ROSE AVE	SANTA CRUZ BLVD	PHILLIP WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51748	260.7 to 264.5 feet	Vertical Change	-.3	5 ft	19	REF		
9234	268.5 to 307.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	195	SF	\$40	\$7,800
47586	277.8 to 278.8 feet	Vertical Change	-.41	5 ft	5	REF		
53143	289.6 to 295.7 feet	Vertical Change	-.27	5 ft	30	REF		
44696	305.1 to 306.1 feet	Vertical Change	-.54	5 ft	5	REF		
9245	307.5 to 318.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,360
44259	314.8 to 315.8 feet	Vertical Change	-.56	5 ft	5	REF		
9247	318.1 to 321.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	16	SF	\$120	\$1,920
TOTAL COST FOR: S side of ROSE AVE Starting at: SANTA CRUZ BLVD							\$118,535.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221431	PHILLIP WAY	ROSE AVE	MOLLY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9248	0.0 to 5.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120
53674	2.2 to 3.2 feet	Vertical Change	-.26	5 ft	5	REF		
9250	5.2 to 23.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	93	SF	\$120	\$11,160
46427	6.2 to 7.2 feet	Vertical Change	-.46	5 ft	5	REF		
46193	18.9 to 19.9 feet	Vertical Change	-.47	5 ft	5	REF		
9252	23.8 to 72.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	246	SF	\$120	\$29,460
50830	29.5 to 30.5 feet	Vertical Change	-.31	5 ft	5	REF		
48838	40.5 to 41.5 feet	Vertical Change	-.37	5 ft	5	REF		
45066	51.0 to 52.0 feet	Vertical Change	-.52	5 ft	5	REF		
52171	70.1 to 71.1 feet	Vertical Change	-.29	5 ft	5	REF		
9255	72.9 to 97.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	121	SF	\$120	\$14,580
50831	82.2 to 83.2 feet	Vertical Change	-.31	5 ft	5	REF		
9259	97.2 to 187.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	449	SF	\$120	\$53,880
50445	103.0 to 104.0 feet	Vertical Change	-.32	5 ft	5	REF		
49120	124.1 to 125.1 feet	Vertical Change	-.36	5 ft	5	REF		
50832	144.5 to 145.5 feet	Vertical Change	-.31	5 ft	5	REF		
49746	175.5 to 176.5 feet	Vertical Change	-.34	5 ft	5	REF		
42789	185.9 to 186.9 feet	Vertical Change	-.66	5 ft	5	REF		
9263	187.0 to 191.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	21	SF	\$120	\$2,520
TOTAL COST FOR: W side of PHILLIP WAY Starting at: ROSE AVE							\$114,720.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221434	MOLLY AVE	PHILLIP WAY	342 MOLLY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9264	0.0 to 13.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	68	SF	\$120	\$8,160
44069	5.9 to 6.9 feet	Vertical Change	-.57	5 ft	5	REF		
9266	13.6 to 14.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	5	SF	\$120	\$600
9267	14.6 to 16.7 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	11	SF	\$120	\$1,260
45067	15.2 to 16.2 feet	Vertical Change	-.52	5 ft	5	REF		
56643	15.3 to 16.3 feet	Vertical Change	.48	5 ft	5	REF		
9269	16.7 to 23.9 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	36	SF	\$120	\$4,320
42582	25.0 to 26.0 feet	Vertical Change	-.68	5 ft	5	SF	\$75	\$375
9270	27.1 to 36.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	48	SF	\$120	\$5,700
58362	28.6 to 67.0 feet	Driveway				REF		
43596	30.3 to 31.3 feet	Vertical Change	-.6	5 ft	5	REF		
45263	35.7 to 36.7 feet	Vertical Change	-.51	5 ft	5	REF		
9274	36.6 to 40.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	21	SF	\$40	\$840
9276	40.8 to 50.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	47	SF	\$40	\$1,880
49121	46.0 to 47.0 feet	Vertical Change	-.36	5 ft	5	REF		
9277	50.2 to 54.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	20	SF	\$40	\$780
44473	55.1 to 56.1 feet	Vertical Change	-.55	5 ft	5	REF		
9278	63.0 to 95.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	162	SF	\$40	\$6,460
45264	78.8 to 79.8 feet	Vertical Change	-.51	5 ft	5	REF		
58363	86.4 to 123.6 feet	Driveway				REF		
45265	90.3 to 94.2 feet	Vertical Change	-.51	5 ft	20	REF		
9284	95.3 to 104.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	45	SF	\$40	\$1,780
9288	104.2 to 138.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	171	SF	\$40	\$6,820
51749	107.4 to 108.4 feet	Vertical Change	-.3	5 ft	5	REF		
44697	117.5 to 118.5 feet	Vertical Change	-.54	5 ft	5	REF		
48839	126.8 to 127.8 feet	Vertical Change	-.37	5 ft	5	REF		
48538	130.1 to 131.1 feet	Vertical Change	-.38	5 ft	5	REF		
45975	135.7 to 139.1 feet	Vertical Change	-.48	5 ft	17	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221434	MOLLY AVE	PHILLIP WAY	342 MOLLY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58364	136.8 to 161.0 feet	Driveway				REF		
41726	140.9 to 141.9 feet	Vertical Change	-0.88	5 ft	5	REF		
9295	141.4 to 149.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	40	SF	\$40	\$1,580
43272	142.7 to 143.7 feet	Vertical Change	-0.62	5 ft	5	REF		
43007	151.4 to 152.4 feet	Vertical Change	-0.64	5 ft	5	REF		
9298	156.7 to 196.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	201	SF	\$40	\$8,040
43597	160.8 to 161.8 feet	Vertical Change	-0.6	5 ft	5	REF		
46428	165.6 to 166.6 feet	Vertical Change	-0.46	5 ft	5	REF		
45772	187.6 to 188.6 feet	Vertical Change	-0.49	5 ft	5	REF		
9304	196.9 to 206.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	49	SF	\$120	\$5,880
52172	200.6 to 201.6 feet	Vertical Change	-0.29	5 ft	5	REF		
58365	202.6 to 227.8 feet	Driveway				REF		
9306	209.7 to 212.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	12	SF	\$40	\$480
9308	212.1 to 214.5 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	12	SF	\$40	\$480
9310	214.5 to 218.0 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	18	SF	\$40	\$700
48260	217.2 to 218.2 feet	Vertical Change	-0.39	5 ft	5	REF		
9312	218.0 to 223.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	29	SF	\$40	\$1,160
9314	223.8 to 226.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	14	SF	\$40	\$560
41390	229.6 to 230.6 feet	Vertical Change	-1.29	5 ft	5	SF	\$75	\$375
9316	241.1 to 242.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780
48840	248.1 to 249.1 feet	Vertical Change	-0.37	5 ft	5	LF	\$75	\$375
41196	252.7 to 253.7 feet	Vertical Change	-2.48	5 ft	5	REF		
41769	252.7 to 253.7 feet	Vertical Change	-0.86	5 ft	5	REF		
9317	252.8 to 285.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	165	SF	\$120	\$19,740
58366	272.7 to 303.3 feet	Driveway				REF		
47349	276.4 to 277.4 feet	Vertical Change	-0.42	5 ft	5	REF		
41303	279.4 to 280.4 feet	Vertical Change	-1.56	5 ft	5	REF		
43273	291.8 to 292.8 feet	Vertical Change	-0.62	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221434	MOLLY AVE	PHILLIP WAY	342 MOLLY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41213	304.7 to 305.7 feet	Vertical Change	-2.22	5 ft	5	SF	\$75	\$375
44260	307.9 to 308.9 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375
47350	314.2 to 315.2 feet	Vertical Change	-.42	5 ft	5	REF		
9320	314.2 to 317.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160
48008	319.3 to 320.3 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375
9321	322.3 to 336.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	69	SF	\$120	\$8,280
45560	331.5 to 332.5 feet	Vertical Change	-.5	5 ft	5	REF		
50	342.0 to 343.0 feet	Continuous Width		5 ft	5	SF	\$120	\$600
TOTAL COST FOR: N side of MOLLY AVE Starting at: PHILLIP WAY							\$91,290.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221437	MOLLY AVE	342 MOLLY AVE	ELM AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9323	0.0 to 5.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,240
58367	0.1 to 26.2 feet	Driveway				REF		
43274	2.7 to 8.6 feet	Vertical Change	-.62	5 ft	30	REF		
56965	7.8 to 8.8 feet	Vertical Change	.56	5 ft	5	REF		
9324	7.8 to 27.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	98	SF	\$40	\$3,900
46883	17.0 to 18.0 feet	Vertical Change	-.44	5 ft	5	REF		
45068	26.6 to 27.6 feet	Vertical Change	-.52	5 ft	5	REF		
56992	26.7 to 27.7 feet	Vertical Change	.59	5 ft	5	REF		
41229	28.2 to 29.2 feet	Vertical Change	-2.03	5 ft	5	SF	\$75	\$375
46884	31.4 to 39.4 feet	Vertical Change	-.44	5 ft	40	LF	\$75	\$3,000
58368	34.2 to 59.1 feet	Driveway				REF		
9331	35.3 to 39.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	23	SF	\$40	\$900
9332	41.4 to 42.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$220
57136	42.4 to 43.4 feet	Vertical Change	.62	5 ft	5	REF		
9333	42.5 to 43.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	7	SF	\$40	\$260
9334	43.8 to 47.9 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	21	SF	\$40	\$820
9336	47.9 to 52.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	21	SF	\$40	\$820
42583	49.8 to 50.8 feet	Vertical Change	-.68	5 ft	5	REF		
9337	52.0 to 57.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	29	SF	\$40	\$1,140
9339	57.7 to 60.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	14	SF	\$40	\$560
44071	58.4 to 59.4 feet	Vertical Change	-.57	5 ft	5	REF		
9341	60.5 to 91.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	153	SF	\$120	\$18,300
46429	62.0 to 66.0 feet	Vertical Change	-.46	5 ft	20	REF		
46430	75.3 to 76.3 feet	Vertical Change	-.46	5 ft	5	REF		
43896	88.8 to 89.8 feet	Vertical Change	-.58	5 ft	5	REF		
9344	91.0 to 104.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	67	SF	\$120	\$8,040
43275	102.4 to 103.4 feet	Vertical Change	-.62	5 ft	5	REF		
52173	104.4 to 111.1 feet	Vertical Change	-.29	5 ft	34	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221437	MOLLY AVE	342 MOLLY AVE	ELM AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9348	104.4 to 108.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,580
9349	112.8 to 116.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,980
53144	113.9 to 114.9 feet	Vertical Change	-27	5 ft	5	REF		
43598	115.9 to 116.9 feet	Vertical Change	-6	5 ft	5	REF		
51750	118.1 to 119.1 feet	Vertical Change	-3	5 ft	5	LF	\$75	\$375
50446	122.2 to 125.3 feet	Vertical Change	-32	5 ft	16	LF	\$75	\$1,163
42584	128.5 to 129.5 feet	Vertical Change	-68	5 ft	5	SF	\$75	\$375
58369	134.7 to 160.1 feet	Driveway				REF		
51751	134.9 to 138.0 feet	Vertical Change	-3	5 ft	16	REF		
9350	138.5 to 148.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	51	SF	\$40	\$2,020
41945	139.1 to 142.2 feet	Vertical Change	-79	5 ft	15	REF		
45976	144.1 to 145.1 feet	Vertical Change	-48	5 ft	5	REF		
42904	153.2 to 154.2 feet	Vertical Change	-65	5 ft	5	REF		
44072	163.1 to 164.1 feet	Vertical Change	-57	5 ft	5	SF	\$75	\$375
48261	167.5 to 170.2 feet	Vertical Change	-39	5 ft	14	LF	\$75	\$1,013
58370	170.2 to 194.7 feet	Driveway				REF		
44073	173.5 to 174.5 feet	Vertical Change	-57	5 ft	5	REF		
42015	184.2 to 185.2 feet	Vertical Change	-77	5 ft	5	REF		
9352	188.8 to 192.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	19	SF	\$40	\$760
9354	192.6 to 197.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	24	SF	\$40	\$960
42905	193.4 to 194.4 feet	Vertical Change	-65	5 ft	5	REF		
9356	197.4 to 199.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380
41802	197.8 to 198.8 feet	Vertical Change	-84	5 ft	5	REF		
41803	207.9 to 208.9 feet	Vertical Change	-84	5 ft	5	SF	\$75	\$375
41727	219.6 to 220.6 feet	Vertical Change	-88	5 ft	5	SF	\$75	\$375
9357	230.1 to 233.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040
9359	233.5 to 252.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	93	SF	\$120	\$11,100
46431	233.9 to 234.9 feet	Vertical Change	-46	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221437	MOLLY AVE	342 MOLLY AVE	ELM AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
42301	247.9 to 248.9 feet	Vertical Change	-.71	5 ft	5	REF		
9363	252.0 to 287.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	175	SF	\$120	\$21,000
44261	261.7 to 262.7 feet	Vertical Change	-.56	5 ft	5	REF		
58371	268.0 to 296.0 feet	Driveway				REF		
43426	271.5 to 272.5 feet	Vertical Change	-.61	5 ft	5	REF		
41289	274.3 to 275.3 feet	Vertical Change	-1.62	5 ft	5	REF		
56966	276.7 to 277.7 feet	Vertical Change	.56	5 ft	5	REF		
43136	285.7 to 286.7 feet	Vertical Change	-.63	5 ft	5	REF		
9368	291.4 to 323.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	159	SF	\$40	\$6,360
42906	298.3 to 299.3 feet	Vertical Change	-.65	5 ft	5	REF		
58372	299.8 to 326.0 feet	Driveway				REF		
43599	302.8 to 303.8 feet	Vertical Change	-.6	5 ft	5	REF		
41770	304.4 to 305.4 feet	Vertical Change	-.86	5 ft	5	REF		
42139	315.7 to 316.7 feet	Vertical Change	-.74	5 ft	5	REF		
9375	323.2 to 341.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	94	SF	\$40	\$3,740
42302	330.3 to 331.3 feet	Vertical Change	-.71	5 ft	5	REF		
44698	340.7 to 341.7 feet	Vertical Change	-.54	5 ft	5	REF		
9377	341.9 to 378.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	184	SF	\$120	\$22,080
45070	354.1 to 355.1 feet	Vertical Change	-.52	5 ft	5	REF		
9381	378.7 to 406.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	138	SF	\$120	\$16,560
43737	382.2 to 383.2 feet	Vertical Change	-.59	5 ft	5	REF		
58373	387.0 to 418.1 feet	Driveway				REF		
43276	392.6 to 393.6 feet	Vertical Change	-.62	5 ft	5	REF		
9384	406.3 to 416.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	49	SF	\$40	\$1,960
46655	407.4 to 408.4 feet	Vertical Change	-.45	5 ft	5	REF		
9386	416.1 to 419.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	16	SF	\$40	\$620
49748	418.8 to 419.8 feet	Vertical Change	-.34	5 ft	5	REF		
9388	419.2 to 432.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,740

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221437	MOLLY AVE	342 MOLLY AVE	ELM AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54029	422.0 to 430.4 feet	Vertical Change	-.25	5 ft	42	REF		
58374	424.3 to 452.6 feet	Driveway				REF		
9393	432.1 to 438.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	33	SF	\$40	\$1,300
9395	438.6 to 461.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	116	SF	\$40	\$4,620
41628	442.0 to 443.0 feet	Vertical Change	-.95	5 ft	5	REF		
45773	457.7 to 458.7 feet	Vertical Change	-.49	5 ft	5	REF		
9397	461.7 to 496.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	176	SF	\$120	\$21,120
41728	465.1 to 466.1 feet	Vertical Change	-.88	5 ft	5	REF		
48262	478.4 to 479.4 feet	Vertical Change	-.39	5 ft	5	REF		
46886	486.4 to 487.4 feet	Vertical Change	-.44	5 ft	5	REF		
58375	490.4 to 519.5 feet	Driveway				REF		
45977	491.6 to 492.6 feet	Vertical Change	-.48	5 ft	5	REF		
45071	495.2 to 499.0 feet	Vertical Change	-.52	5 ft	19	REF		
9401	496.9 to 542.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	229	SF	\$40	\$9,160
45266	509.6 to 510.6 feet	Vertical Change	-.51	5 ft	5	REF		
48263	520.9 to 521.9 feet	Vertical Change	-.39	5 ft	5	REF		
45267	524.9 to 527.7 feet	Vertical Change	-.51	5 ft	14	REF		
53676	540.0 to 541.0 feet	Vertical Change	-.26	5 ft	5	REF		
43600	546.5 to 547.5 feet	Vertical Change	-.6	5 ft	5	SF	\$75	\$375
TOTAL COST FOR: W side of MOLLY AVE Starting at: 342 MOLLY AVE								\$185,080.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E/S	1908221440	MOLLY AVE	ELM AVE	PHILLIP WAY	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
9407	0.3 to 69.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	345	SF	\$120	\$41,400	
43897	21.6 to 22.6 feet	Vertical Change	-.58	5 ft	5	REF			
58376	36.2 to 64.4 feet	Driveway				REF			
45268	40.1 to 43.8 feet	Vertical Change	-.51	5 ft	19	REF			
45269	54.4 to 55.4 feet	Vertical Change	-.51	5 ft	5	REF			
45774	65.3 to 67.4 feet	Vertical Change	-.49	5 ft	11	REF			
9418	69.3 to 99.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	149	SF	\$120	\$17,880	
41988	69.5 to 70.5 feet	Vertical Change	-.78	5 ft	5	REF			
48009	81.1 to 82.1 feet	Vertical Change	-.4	5 ft	5	REF			
42907	93.7 to 94.7 feet	Vertical Change	-.65	5 ft	5	REF			
58377	94.0 to 130.6 feet	Driveway				REF			
49123	97.8 to 98.8 feet	Vertical Change	-.36	5 ft	5	REF			
9420	99.1 to 130.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	158	SF	\$40	\$6,320	
42140	113.5 to 114.5 feet	Vertical Change	-.74	5 ft	5	REF			
45775	123.7 to 124.7 feet	Vertical Change	-.49	5 ft	5	REF			
51752	135.4 to 136.4 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
9426	136.5 to 151.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,700	
45776	138.7 to 139.7 feet	Vertical Change	-.49	5 ft	5	REF			
48841	142.8 to 143.8 feet	Vertical Change	-.37	5 ft	5	REF			
58378	146.9 to 174.4 feet	Driveway				REF			
46887	147.9 to 148.9 feet	Vertical Change	-.44	5 ft	5	REF			
41900	152.7 to 155.5 feet	Vertical Change	-.8	5 ft	14	REF			
57241	154.6 to 155.6 feet	Vertical Change	.77	5 ft	5	REF			
41748	167.2 to 168.2 feet	Vertical Change	-.87	5 ft	5	REF			
42016	176.1 to 177.1 feet	Vertical Change	-.77	5 ft	5	SF	\$75	\$375	
57233	179.8 to 180.8 feet	Vertical Change	.71	5 ft	5	SF	\$75	\$375	
41863	181.0 to 182.0 feet	Vertical Change	-.81	5 ft	5	SF	\$75	\$375	
9430	189.8 to 190.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
E/S	1908221440	MOLLY AVE	ELM AVE	PHILLIP WAY				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41901	195.3 to 196.3 feet	Vertical Change	-.8	5 ft	5	SF	\$75	\$375
9431	201.3 to 202.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660
42053	208.5 to 209.5 feet	Vertical Change	-.76	5 ft	5	SF	\$75	\$375
9432	215.3 to 220.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,240
44074	220.1 to 221.1 feet	Vertical Change	-.57	5 ft	5	REF		
9433	223.9 to 226.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260
43008	235.0 to 236.0 feet	Vertical Change	-.64	5 ft	5	SF	\$75	\$375
45072	248.1 to 249.1 feet	Vertical Change	-.52	5 ft	5	SF	\$75	\$375
58379	256.2 to 283.3 feet	Driveway				REF		
9434	257.2 to 267.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	53	SF	\$40	\$2,100
48264	258.2 to 259.2 feet	Vertical Change	-.39	5 ft	5	REF		
47588	263.6 to 264.6 feet	Vertical Change	-.41	5 ft	5	REF		
44699	271.3 to 272.3 feet	Vertical Change	-.54	5 ft	5	REF		
9435	275.2 to 276.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$220
54030	278.1 to 279.1 feet	Vertical Change	-.25	5 ft	5	REF		
9436	278.1 to 281.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	15	SF	\$40	\$620
48265	284.3 to 285.3 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375
58380	288.1 to 316.8 feet	Driveway				REF		
9438	295.0 to 311.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	84	SF	\$40	\$3,360
9442	311.8 to 314.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	12	SF	\$40	\$460
54031	313.3 to 314.3 feet	Vertical Change	-.25	5 ft	5	REF		
9444	314.1 to 315.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	8	SF	\$40	\$340
9445	315.8 to 316.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200
9446	318.5 to 323.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,880
9447	353.8 to 361.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800
58381	376.3 to 404.0 feet	Driveway				REF		
50067	381.0 to 382.0 feet	Vertical Change	-.33	5 ft	5	REF		
9450	384.6 to 390.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	29	SF	\$40	\$1,140

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E/S	1908221440	MOLLY AVE	ELM AVE	PHILLIP WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
52635	394.6 to 395.6 feet	Vertical Change	-28	5 ft	5	REF			
9453	400.0 to 415.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	79	SF	\$40	\$3,140	
49424	405.4 to 406.4 feet	Vertical Change	-35	5 ft	5	REF			
53146	410.3 to 416.3 feet	Vertical Change	-27	5 ft	30	REF			
58383	412.0 to 440.5 feet	Driveway				REF			
9457	416.6 to 423.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	33	SF	\$40	\$1,320	
9461	423.2 to 429.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	29	SF	\$40	\$1,160	
9463	429.0 to 432.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	18	SF	\$40	\$720	
48010	430.9 to 431.9 feet	Vertical Change	-.4	5 ft	5	REF			
9465	432.6 to 437.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	22	SF	\$40	\$880	
9467	437.0 to 438.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	8	SF	\$40	\$300	
9468	444.2 to 475.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	159	SF	\$120	\$19,020	
47352	445.1 to 446.1 feet	Vertical Change	-.42	5 ft	5	REF			
49749	449.6 to 450.6 feet	Vertical Change	-.34	5 ft	5	REF			
45978	461.3 to 462.3 feet	Vertical Change	-.48	5 ft	5	REF			
58384	469.3 to 496.3 feet	Driveway				REF			
42141	471.5 to 472.5 feet	Vertical Change	-.74	5 ft	5	REF			
9472	479.2 to 485.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	30	SF	\$40	\$1,200	
9474	485.2 to 492.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	36	SF	\$40	\$1,420	
42397	486.4 to 487.4 feet	Vertical Change	-.7	5 ft	5	REF			
9476	492.3 to 494.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	12	SF	\$40	\$460	
44887	497.3 to 498.3 feet	Vertical Change	-.53	5 ft	5	REF			
9477	498.2 to 513.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	78	SF	\$120	\$9,300	
42193	501.6 to 502.6 feet	Vertical Change	-.73	5 ft	5	REF			
42142	509.1 to 510.1 feet	Vertical Change	-.74	5 ft	5	REF			
9478	513.7 to 537.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	120	SF	\$120	\$14,400	
52175	518.7 to 522.4 feet	Vertical Change	-.29	5 ft	18	REF			
58385	528.2 to 553.2 feet	Driveway				REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E/S	1908221440	MOLLY AVE	ELM AVE	PHILLIP WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
42303	531.2 to 532.2 feet	Vertical Change	-.71	5 ft	5	REF			
42398	534.6 to 535.6 feet	Vertical Change	-.7	5 ft	5	REF			
9483	537.7 to 544.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	34	SF	\$40	\$1,360	
9485	544.5 to 552.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	40	SF	\$40	\$1,600	
42304	545.7 to 546.7 feet	Vertical Change	-.71	5 ft	5	REF			
9488	552.5 to 556.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	21	SF	\$40	\$860	
9490	556.8 to 573.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	84	SF	\$120	\$10,020	
41377	557.7 to 558.7 feet	Vertical Change	-1.34	5 ft	5	REF			
46432	560.2 to 561.2 feet	Vertical Change	-.46	5 ft	5	REF			
48842	563.5 to 565.3 feet	Vertical Change	-.37	5 ft	9	REF			
42305	568.3 to 569.3 feet	Vertical Change	-.71	5 ft	5	REF			
52176	574.0 to 575.0 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
9493	579.4 to 590.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,540	
53677	580.4 to 581.4 feet	Vertical Change	-.26	5 ft	5	REF			
47353	587.3 to 588.3 feet	Vertical Change	-.42	5 ft	5	REF			
9495	590.3 to 606.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	79	SF	\$120	\$9,420	
43277	605.5 to 606.5 feet	Vertical Change	-.62	5 ft	5	REF			
9497	606.0 to 677.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	359	SF	\$120	\$43,020	
43137	617.2 to 618.2 feet	Vertical Change	-.63	5 ft	5	REF			
48011	630.5 to 631.5 feet	Vertical Change	-.4	5 ft	5	REF			
46433	657.0 to 658.0 feet	Vertical Change	-.46	5 ft	5	REF			
47354	684.1 to 685.1 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375	
58386	695.3 to 725.5 feet	Driveway				REF			
45777	703.7 to 708.8 feet	Vertical Change	-.49	5 ft	26	REF			
9508	710.0 to 736.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	131	SF	\$40	\$5,220	
49426	718.3 to 719.3 feet	Vertical Change	-.35	5 ft	5	REF			
48540	729.8 to 730.8 feet	Vertical Change	-.38	5 ft	5	REF			
47589	733.0 to 734.0 feet	Vertical Change	-.41	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E/S	1908221440	MOLLY AVE	ELM AVE	PHILLIP WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9515	736.1 to 769.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	168	SF	\$120	\$20,100
43601	740.9 to 741.9 feet	Vertical Change	-6	5 ft	5	REF		
48012	750.6 to 751.6 feet	Vertical Change	-4	5 ft	5	REF		
44076	761.2 to 762.2 feet	Vertical Change	-57	5 ft	5	REF		
TOTAL COST FOR: E/S side of MOLLY AVE Starting at: ELM AVE							\$251,825.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221442	PHILLIP WAY	MOLLY AVE	PHILLIP CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9525	0.0 to 12.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	61	SF	\$120	\$7,260
52636	2.1 to 3.1 feet	Vertical Change	-.28	5 ft	5	REF		
41286	4.5 to 5.5 feet	Vertical Change	-1.63	5 ft	5	REF		
9528	12.1 to 67.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	275	SF	\$120	\$32,940
45778	14.5 to 15.5 feet	Vertical Change	-.49	5 ft	5	REF		
48843	34.5 to 35.5 feet	Vertical Change	-.37	5 ft	5	REF		
9533	67.0 to 75.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	40	SF	\$120	\$4,800
9535	75.0 to 80.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,180
53148	76.1 to 77.1 feet	Vertical Change	-.27	5 ft	5	REF		
9536	104.8 to 117.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,500
45979	117.0 to 118.0 feet	Vertical Change	-.48	5 ft	5	REF		
9538	117.3 to 163.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	231	SF	\$120	\$27,660
52177	137.9 to 138.9 feet	Vertical Change	-.29	5 ft	5	REF		
56916	152.8 to 153.8 feet	Vertical Change	.51	5 ft	5	REF		
49124	157.0 to 158.0 feet	Vertical Change	-.36	5 ft	5	REF		
50836	160.1 to 161.1 feet	Vertical Change	-.31	5 ft	5	REF		
9540	163.4 to 189.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	130	SF	\$120	\$15,540
46434	168.9 to 169.9 feet	Vertical Change	-.46	5 ft	5	REF		
51753	179.7 to 180.7 feet	Vertical Change	-.3	5 ft	5	REF		
9546	189.3 to 197.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	39	SF	\$120	\$4,620
50837	189.6 to 190.6 feet	Vertical Change	-.31	5 ft	5	REF		
TOTAL COST FOR: W side of PHILLIP WAY Starting at: MOLLY AVE							\$103,500.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908221443	PHILLIP CT	PHILLIP WAY	104 PHILLIP CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
9550	0.0 to 33.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	169	SF	\$120	\$20,280	
42143	5.3 to 6.3 feet	Vertical Change	-.74	5 ft	5	REF			
44888	14.1 to 15.1 feet	Vertical Change	-.53	5 ft	5	REF			
42908	23.1 to 24.1 feet	Vertical Change	-.65	5 ft	5	REF			
58387	23.3 to 50.0 feet	Driveway				REF			
44700	26.7 to 27.7 feet	Vertical Change	-.54	5 ft	5	REF			
44077	30.9 to 31.9 feet	Vertical Change	-.57	5 ft	5	REF			
9554	33.8 to 46.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	62	SF	\$40	\$2,460	
43278	41.7 to 42.7 feet	Vertical Change	-.62	5 ft	5	REF			
9556	46.1 to 53.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	39	SF	\$40	\$1,540	
44078	51.8 to 52.8 feet	Vertical Change	-.57	5 ft	5	REF			
56975	51.9 to 52.9 feet	Vertical Change	.57	5 ft	5	REF			
45562	53.4 to 54.4 feet	Vertical Change	-.5	5 ft	5	REF			
9558	53.8 to 91.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	186	SF	\$120	\$22,320	
42585	56.6 to 57.6 feet	Vertical Change	-.68	5 ft	5	REF			
42491	66.7 to 67.7 feet	Vertical Change	-.69	5 ft	5	REF			
42586	76.9 to 77.9 feet	Vertical Change	-.68	5 ft	5	REF			
58388	86.3 to 113.5 feet	Driveway				REF			
48013	87.3 to 88.3 feet	Vertical Change	-.4	5 ft	5	REF			
41864	90.6 to 91.6 feet	Vertical Change	-.81	5 ft	5	REF			
9560	91.0 to 92.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	6	SF	\$40	\$240	
48844	93.4 to 94.4 feet	Vertical Change	-.37	5 ft	5	REF			
9561	93.9 to 102.6 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	44	SF	\$40	\$1,740	
45563	101.9 to 102.9 feet	Vertical Change	-.5	5 ft	5	REF			
9563	102.6 to 105.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	15	SF	\$40	\$580	
9565	105.5 to 110.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	27	SF	\$40	\$1,060	
43009	114.8 to 117.5 feet	Vertical Change	-.64	5 ft	14	REF			
9567	115.2 to 116.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$960	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221443	PHILLIP CT	PHILLIP WAY	104 PHILLIP CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9568	116.8 to 140.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	116	SF	\$120	\$13,920
42587	128.6 to 129.6 feet	Vertical Change	-.68	5 ft	5	REF		
51	140.0 to 141.0 feet	Continuous Width		5 ft	5	SF	\$120	\$600
TOTAL COST FOR: N side of PHILLIP CT Starting at: PHILLIP WAY							\$65,700.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221445	PHILLIP CT	104 PHILLIP CT	PHILLIP WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9574	0.0 to 8.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	41	SF	\$120	\$4,860
50838	0.7 to 1.7 feet	Vertical Change	-.31	5 ft	5	REF		
58389	2.7 to 43.9 feet	Driveway				REF		
53678	7.8 to 8.8 feet	Vertical Change	-.26	5 ft	5	REF		
56982	7.8 to 8.8 feet	Vertical Change	.58	5 ft	5	REF		
9578	8.1 to 9.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240
9579	12.1 to 19.4 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	36	SF	\$40	\$1,460
9583	19.4 to 35.0 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	78	SF	\$40	\$3,120
43279	23.2 to 24.2 feet	Vertical Change	-.62	5 ft	5	REF		
53149	33.2 to 34.2 feet	Vertical Change	-.27	5 ft	5	REF		
9584	35.0 to 41.9 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	35	SF	\$40	\$1,380
9586	44.3 to 45.5 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$240
53679	45.1 to 46.1 feet	Vertical Change	-.26	5 ft	5	REF		
9587	45.5 to 69.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	122	SF	\$120	\$14,580
47355	48.6 to 49.6 feet	Vertical Change	-.42	5 ft	5	REF		
43602	53.1 to 54.1 feet	Vertical Change	-.6	5 ft	5	REF		
58390	64.0 to 96.3 feet	Driveway				REF		
9592	73.1 to 80.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	36	SF	\$40	\$1,440
9595	80.3 to 89.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	45	SF	\$40	\$1,800
51754	81.0 to 82.0 feet	Vertical Change	-.3	5 ft	5	REF		
9597	89.3 to 92.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	18	SF	\$40	\$720
9598	95.9 to 106.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	51	SF	\$40	\$2,040
54032	105.4 to 106.4 feet	Vertical Change	-.25	5 ft	5	REF		
9600	106.1 to 116.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,180
50839	114.1 to 115.1 feet	Vertical Change	-.31	5 ft	5	REF		
9601	126.2 to 141.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	75	SF	\$120	\$9,000
46656	128.4 to 129.4 feet	Vertical Change	-.45	5 ft	5	REF		
58391	133.9 to 161.8 feet	Driveway				REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221445	PHILLIP CT	104 PHILLIP CT	PHILLIP WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
43603	136.4 to 137.4 feet	Vertical Change	-.6	5 ft	5	REF		
53680	140.8 to 141.8 feet	Vertical Change	-.26	5 ft	5	REF		
9603	142.8 to 151.1 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	41	SF	\$40	\$1,660
43738	150.3 to 151.3 feet	Vertical Change	-.59	5 ft	5	REF		
9606	151.1 to 163.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	60	SF	\$40	\$2,420
49427	160.0 to 161.0 feet	Vertical Change	-.35	5 ft	5	REF		
9608	163.2 to 170.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	39	SF	\$120	\$4,620
43739	166.8 to 167.8 feet	Vertical Change	-.59	5 ft	5	REF		
9609	170.9 to 173.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560
9611	173.5 to 196.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	115	SF	\$120	\$13,800
46888	181.5 to 182.5 feet	Vertical Change	-.44	5 ft	5	REF		
41680	191.1 to 192.1 feet	Vertical Change	-.91	5 ft	5	REF		
9616	196.5 to 202.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,660
TOTAL COST FOR: S side of PHILLIP CT Starting at: 104 PHILLIP CT							\$74,780.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221448	PHILLIP WAY	PHILLIP CT	ELM AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9617	0.2 to 233.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	1168	SF	\$120	\$140,160
46889	13.7 to 14.7 feet	Vertical Change	-.44	5 ft	5	REF		
46435	22.8 to 23.8 feet	Vertical Change	-.46	5 ft	5	REF		
42492	43.3 to 44.3 feet	Vertical Change	-.69	5 ft	5	REF		
44701	64.1 to 65.1 feet	Vertical Change	-.54	5 ft	5	REF		
44079	84.5 to 85.5 feet	Vertical Change	-.57	5 ft	5	REF		
47590	104.7 to 105.7 feet	Vertical Change	-.41	5 ft	5	REF		
43740	125.3 to 126.3 feet	Vertical Change	-.59	5 ft	5	REF		
44080	135.7 to 136.7 feet	Vertical Change	-.57	5 ft	5	REF		
50447	158.7 to 159.7 feet	Vertical Change	-.32	5 ft	5	REF		
43604	188.9 to 189.9 feet	Vertical Change	-.6	5 ft	5	REF		
48014	198.4 to 199.4 feet	Vertical Change	-.4	5 ft	5	REF		
49750	208.0 to 209.0 feet	Vertical Change	-.34	5 ft	5	REF		
52	208.4 to 209.4 feet	Continuous Width		5 ft	5	SF	\$120	\$600
43138	220.0 to 221.0 feet	Vertical Change	-.63	5 ft	5	REF		
45779	228.7 to 229.7 feet	Vertical Change	-.49	5 ft	5	REF		

TOTAL COST FOR: W side of PHILLIP WAY Starting at: PHILLIP CT \$140,760.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908221450	ELM AVE	PHILLIP WAY	MOLLY AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
9633	0.0 to 23.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	117	SF	\$120	\$13,980	
52637	5.2 to 6.2 feet	Vertical Change	-.28	5 ft	5	REF			
44081	20.0 to 21.0 feet	Vertical Change	-.57	5 ft	5	REF			
58392	20.7 to 49.3 feet	Driveway				REF			
47356	24.2 to 25.2 feet	Vertical Change	-.42	5 ft	5	REF			
9636	28.8 to 43.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	74	SF	\$40	\$2,940	
44474	28.9 to 29.9 feet	Vertical Change	-.55	5 ft	5	REF			
56644	29.0 to 30.0 feet	Vertical Change	.48	5 ft	5	REF			
53150	38.6 to 39.6 feet	Vertical Change	-.27	5 ft	5	REF			
9638	43.5 to 75.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	160	SF	\$40	\$6,380	
46657	48.3 to 49.3 feet	Vertical Change	-.45	5 ft	5	REF			
43428	53.5 to 54.5 feet	Vertical Change	-.61	5 ft	5	REF			
51755	60.2 to 61.2 feet	Vertical Change	-.3	5 ft	5	REF			
44262	63.1 to 64.1 feet	Vertical Change	-.56	5 ft	5	REF			
58393	74.9 to 109.7 feet	Driveway				REF			
9640	75.4 to 79.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	22	SF	\$40	\$880	
47591	79.8 to 80.8 feet	Vertical Change	-.41	5 ft	5	REF			
9642	79.8 to 86.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	31	SF	\$40	\$1,240	
9644	86.0 to 91.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	28	SF	\$40	\$1,120	
42588	89.2 to 90.2 feet	Vertical Change	-.68	5 ft	5	REF			
9646	91.6 to 95.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	21	SF	\$40	\$840	
9648	95.8 to 99.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	19	SF	\$40	\$760	
42144	99.0 to 100.0 feet	Vertical Change	-.74	5 ft	5	REF			
9649	99.6 to 104.0 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	22	SF	\$40	\$880	
9650	104.0 to 107.7 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	19	SF	\$40	\$740	
43741	106.6 to 107.6 feet	Vertical Change	-.59	5 ft	5	REF			
57153	106.7 to 107.7 feet	Vertical Change	.66	5 ft	5	REF			
9652	110.4 to 152.7 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	211	SF	\$40	\$8,460	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
N	1908221450	ELM AVE	PHILLIP WAY	MOLLY AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
42589	113.5 to 114.5 feet	Vertical Change	-.68	5 ft	5	REF			
53151	117.4 to 118.4 feet	Vertical Change	-.27	5 ft	5	REF			
53681	128.3 to 129.3 feet	Vertical Change	-.26	5 ft	5	REF			
58394	145.2 to 173.8 feet	Driveway				REF			
50448	149.2 to 150.2 feet	Vertical Change	-.32	5 ft	5	REF			
9655	157.0 to 163.2 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	31	SF	\$40	\$1,240	
42909	163.2 to 164.2 feet	Vertical Change	-.65	5 ft	5	REF			
9657	163.2 to 169.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	33	SF	\$40	\$1,320	
40313	168.8 to 170.8 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
9659	174.1 to 179.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	27	SF	\$40	\$1,060	
45073	177.2 to 178.2 feet	Vertical Change	-.52	5 ft	5	REF			
9660	179.4 to 219.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	199	SF	\$120	\$23,820	
58395	193.0 to 221.6 feet	Driveway				REF			
48541	197.1 to 198.1 feet	Vertical Change	-.38	5 ft	5	REF			
45271	211.6 to 212.6 feet	Vertical Change	-.51	5 ft	5	REF			
9665	219.1 to 223.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	23	SF	\$40	\$900	
48015	222.2 to 223.2 feet	Vertical Change	-.4	5 ft	5	REF			
9667	223.6 to 234.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,420	
49751	226.4 to 227.4 feet	Vertical Change	-.34	5 ft	5	REF			
53682	233.2 to 234.2 feet	Vertical Change	-.26	5 ft	5	REF			
9669	234.3 to 260.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	133	SF	\$120	\$15,960	
49428	253.4 to 254.4 feet	Vertical Change	-.35	5 ft	5	REF			
9671	260.9 to 264.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,280	
9673	264.7 to 277.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	62	SF	\$120	\$7,380	
48267	276.1 to 277.1 feet	Vertical Change	-.39	5 ft	5	REF			
9675	277.0 to 283.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020	
9676	285.8 to 346.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	302	SF	\$120	\$36,240	
47114	298.1 to 299.1 feet	Vertical Change	-.43	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221450	ELM AVE	PHILLIP WAY	MOLLY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
45272	312.0 to 313.0 feet	Vertical Change	-.51	5 ft	5	REF		
9681	348.8 to 373.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	122	SF	\$120	\$14,580
48542	366.5 to 367.5 feet	Vertical Change	-.38	5 ft	5	REF		
TOTAL COST FOR: N side of ELM AVE Starting at: PHILLIP WAY							\$153,440.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221452	ELM AVE	MOLLY AVE	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9683	0.0 to 91.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	458	SF	\$120	\$54,960
48845	1.7 to 2.7 feet	Vertical Change	-.37	5 ft	5	REF		
53	4.8 to 5.8 feet	Continuous Width		5 ft	5	SF	\$120	\$600
44889	21.1 to 22.1 feet	Vertical Change	-.53	5 ft	5	REF		
45074	33.2 to 34.2 feet	Vertical Change	-.52	5 ft	5	REF		
52178	45.9 to 46.9 feet	Vertical Change	-.29	5 ft	5	REF		
45980	59.2 to 60.2 feet	Vertical Change	-.48	5 ft	5	REF		
45981	72.8 to 73.8 feet	Vertical Change	-.48	5 ft	5	REF		
50449	86.1 to 89.4 feet	Vertical Change	-.32	5 ft	17	REF		
44082	93.5 to 94.5 feet	Vertical Change	-.57	5 ft	5	SF	\$75	\$375
TOTAL COST FOR: N side of ELM AVE Starting at: MOLLY AVE								\$55,935.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908221455	SANTA CRUZ BLVD	ELM AVE	ROSE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
9692	3.9 to 6.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380	
49125	14.4 to 15.4 feet	Vertical Change	-36	5 ft	5	LF	\$75	\$375	
9693	16.9 to 81.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	321	SF	\$120	\$38,460	
46658	35.1 to 36.1 feet	Vertical Change	-45	5 ft	5	REF			
45273	55.8 to 56.8 feet	Vertical Change	-51	5 ft	5	REF			
45780	66.2 to 67.2 feet	Vertical Change	-49	5 ft	5	REF			
48846	86.8 to 87.8 feet	Vertical Change	-37	5 ft	5	REF			
9695	87.8 to 91.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,920	
47115	97.3 to 98.3 feet	Vertical Change	-43	5 ft	5	LF	\$75	\$375	
47116	107.5 to 108.5 feet	Vertical Change	-43	5 ft	5	LF	\$75	\$375	
48543	117.9 to 118.9 feet	Vertical Change	-38	5 ft	5	LF	\$75	\$375	
53683	128.4 to 129.4 feet	Vertical Change	-26	5 ft	5	LF	\$75	\$375	
9696	132.2 to 146.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,760	
48268	149.0 to 150.0 feet	Vertical Change	-39	5 ft	5	LF	\$75	\$375	
50840	169.2 to 170.2 feet	Vertical Change	-31	5 ft	5	LF	\$75	\$375	
9697	178.9 to 196.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	90	SF	\$120	\$10,800	
50450	179.4 to 180.4 feet	Vertical Change	-32	5 ft	5	REF			
50069	189.7 to 190.7 feet	Vertical Change	-33	5 ft	5	REF			
47117	210.3 to 211.3 feet	Vertical Change	-43	5 ft	5	LF	\$75	\$375	
51756	220.7 to 221.7 feet	Vertical Change	-3	5 ft	5	LF	\$75	\$375	
9698	233.8 to 245.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,720	
41371	241.6 to 242.6 feet	Vertical Change	-1.36	5 ft	5	SF	\$75	\$375	
48269	262.4 to 263.4 feet	Vertical Change	-39	5 ft	5	LF	\$75	\$375	
51757	272.8 to 273.8 feet	Vertical Change	-3	5 ft	5	LF	\$75	\$375	
57121	283.1 to 284.1 feet	Vertical Change	.6	5 ft	5	SF	\$75	\$375	
9701	285.2 to 290.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,240	
53152	289.5 to 290.5 feet	Vertical Change	-27	5 ft	5	REF			
9702	293.5 to 295.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1908221455	SANTA CRUZ BLVD	ELM AVE	ROSE AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
9703	300.8 to 305.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000	
9705	314.4 to 325.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,540	
53153	334.8 to 335.8 feet	Vertical Change	-27	5 ft	5	LF	\$75	\$375	
50841	345.4 to 346.4 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
52179	374.3 to 375.3 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
48016	384.6 to 385.6 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375	
45982	395.1 to 396.1 feet	Vertical Change	-.48	5 ft	5	LF	\$75	\$375	
9706	398.2 to 423.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	125	SF	\$120	\$15,000	
49753	400.2 to 401.2 feet	Vertical Change	-.34	5 ft	5	REF			
53684	405.7 to 406.7 feet	Vertical Change	-.26	5 ft	5	REF			
53154	416.4 to 417.4 feet	Vertical Change	-.27	5 ft	5	REF			
9708	434.7 to 435.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600	
9709	438.6 to 442.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220	
9710	445.1 to 448.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740	
53155	459.1 to 460.1 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
51758	501.6 to 502.6 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
9711	513.8 to 516.7 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	15	SF	\$120	\$1,740	
9712	516.7 to 522.7 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	30	SF	\$120	\$3,600	
41511	522.8 to 523.8 feet	Vertical Change	-1.08	5 ft	5	SF	\$75	\$375	
9714	538.3 to 542.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340	
45075	543.5 to 544.5 feet	Vertical Change	-.52	5 ft	5	SF	\$75	\$375	
9716	553.8 to 565.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,960	
43898	564.5 to 565.5 feet	Vertical Change	-.58	5 ft	5	REF			
52638	596.4 to 597.4 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
47118	607.0 to 608.0 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375	
46195	617.7 to 618.7 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375	
9719	628.0 to 641.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,100	
56955	628.6 to 629.6 feet	Vertical Change	.55	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221455	SANTA CRUZ BLVD	ELM AVE	ROSE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54033	638.9 to 639.9 feet	Vertical Change	-.25	5 ft	5	REF		
48544	649.6 to 650.6 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375
9722	651.8 to 654.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440
9723	660.5 to 678.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	88	SF	\$120	\$10,560
9725	678.1 to 682.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	22	SF	\$120	\$2,580
43429	681.2 to 682.2 feet	Vertical Change	-.61	5 ft	5	REF		
9727	682.4 to 732.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	249	SF	\$120	\$29,820
49429	692.0 to 693.0 feet	Vertical Change	-.35	5 ft	5	REF		
52180	702.7 to 703.7 feet	Vertical Change	-.29	5 ft	5	REF		
50842	713.4 to 714.4 feet	Vertical Change	-.31	5 ft	5	REF		
41185	728.6 to 729.6 feet	Vertical Change	-2.85	5 ft	5	REF		
9734	737.2 to 741.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,640
49754	745.3 to 746.3 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375
9735	750.2 to 752.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260
9736	770.7 to 778.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,560
49755	791.7 to 792.7 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375
9737	794.9 to 802.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,440
42791	803.0 to 804.0 feet	Vertical Change	-.66	5 ft	5	SF	\$75	\$375
45781	814.8 to 815.8 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$375
57139	819.0 to 820.0 feet	Vertical Change	.63	5 ft	5	SF	\$75	\$375
9739	824.8 to 830.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,240
48847	827.8 to 828.8 feet	Vertical Change	-.37	5 ft	5	REF		
54034	831.9 to 832.9 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375

TOTAL COST FOR: E side of SANTA CRUZ BLVD Starting at: ELM AVE \$196,860.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221456	SANTA CRUZ BLVD	ROSE AVE	PARKRIDGE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
48017	1.8 to 2.8 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375
44475	6.9 to 7.9 feet	Vertical Change	-.55	5 ft	5	REF		
9740	7.6 to 26.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	95	SF	\$120	\$11,340
53685	10.7 to 11.7 feet	Vertical Change	-.26	5 ft	5	REF		
46436	19.2 to 20.2 feet	Vertical Change	-.46	5 ft	5	REF		
47592	26.9 to 27.9 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375
52181	34.3 to 35.3 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375
44476	44.2 to 45.2 feet	Vertical Change	-.55	5 ft	5	SF	\$75	\$375
43899	63.6 to 64.6 feet	Vertical Change	-.58	5 ft	5	SF	\$75	\$375
9743	68.9 to 71.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440
9744	74.0 to 106.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	161	SF	\$120	\$19,260
44890	83.6 to 84.6 feet	Vertical Change	-.53	5 ft	5	REF		
57129	83.7 to 84.7 feet	Vertical Change	.61	5 ft	5	REF		
49126	103.3 to 104.3 feet	Vertical Change	-.36	5 ft	5	REF		
51759	113.2 to 114.2 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375
50451	123.0 to 124.0 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375
54155	123.0 to 124.0 feet	Vertical Change	.27	5 ft	5	LF	\$75	\$375
54035	125.4 to 126.4 feet	Vertical Change	-.25	5 ft	5	REF		
9747	125.8 to 145.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	97	SF	\$120	\$11,640
45782	142.8 to 143.8 feet	Vertical Change	-.49	5 ft	5	REF		
50452	152.4 to 153.4 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375
9750	154.0 to 156.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200
47593	162.4 to 163.4 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375
52182	182.3 to 183.3 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375
9751	199.9 to 202.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680
45274	202.7 to 203.7 feet	Vertical Change	-.51	5 ft	5	REF		
9752	210.6 to 218.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,500
TOTAL COST FOR: E side of SANTA CRUZ BLVD Starting at: ROSE AVE							\$55,185.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908221458	SANTA CRUZ BLVD	PARKRIDGE DR	ROSE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
9755	7.5 to 36.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	146	SF	\$120	\$17,460	
46659	15.7 to 16.7 feet	Vertical Change	-.45	5 ft	5	REF			
50070	34.5 to 35.5 feet	Vertical Change	-.33	5 ft	5	REF			
45076	53.9 to 54.9 feet	Vertical Change	-.52	5 ft	5	SF	\$75	\$375	
42685	63.8 to 64.8 feet	Vertical Change	-.67	5 ft	5	SF	\$75	\$375	
44263	73.7 to 74.7 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375	
9760	82.7 to 103.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	106	SF	\$120	\$12,660	
50843	102.8 to 103.8 feet	Vertical Change	-.31	5 ft	5	REF			
9764	106.3 to 108.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
9765	112.1 to 133.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	108	SF	\$120	\$12,960	
48270	132.7 to 133.7 feet	Vertical Change	-.39	5 ft	5	REF			
55956	132.8 to 133.8 feet	Vertical Change	.33	5 ft	5	REF			
9770	142.3 to 159.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	84	SF	\$120	\$10,140	
49127	152.2 to 153.2 feet	Vertical Change	-.36	5 ft	5	REF			
48545	162.2 to 163.2 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375	
9771	177.0 to 216.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	199	SF	\$120	\$23,880	
TOTAL COST FOR:		W	<i>side of</i> SANTA CRUZ BLVD	<i>Starting at:</i> PARKRIDGE DR				\$79,680.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908221500	SANTA CRUZ BLVD	ROSE AVE	ELM AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
48271	1.9 to 2.9 feet	Vertical Change	-39	5 ft	5	LF	\$75	\$375	
45564	7.7 to 8.7 feet	Vertical Change	-5	5 ft	5	SF	\$75	\$375	
48848	11.4 to 12.4 feet	Vertical Change	-37	5 ft	5	LF	\$75	\$375	
51760	16.4 to 17.4 feet	Vertical Change	-3	5 ft	5	LF	\$75	\$375	
9774	19.1 to 22.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,920	
52183	20.0 to 21.0 feet	Vertical Change	-29	5 ft	5	REF			
9775	41.8 to 72.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	153	SF	\$120	\$18,300	
43742	42.1 to 43.1 feet	Vertical Change	-59	5 ft	5	REF			
53686	53.8 to 54.8 feet	Vertical Change	-26	5 ft	5	REF			
52639	65.1 to 66.1 feet	Vertical Change	-28	5 ft	5	REF			
51761	98.9 to 99.9 feet	Vertical Change	-3	5 ft	5	LF	\$75	\$375	
50071	110.2 to 111.2 feet	Vertical Change	-33	5 ft	5	REF			
9778	110.3 to 152.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	210	SF	\$120	\$25,200	
50072	133.2 to 134.2 feet	Vertical Change	-33	5 ft	5	REF			
50453	144.8 to 145.8 feet	Vertical Change	-32	5 ft	5	REF			
48849	155.8 to 156.8 feet	Vertical Change	-37	5 ft	5	LF	\$75	\$375	
9780	162.2 to 167.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,880	
44702	167.6 to 168.6 feet	Vertical Change	-54	5 ft	5	SF	\$75	\$375	
9781	176.3 to 187.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,900	
41902	182.2 to 183.2 feet	Vertical Change	-8	5 ft	5	REF			
9782	190.8 to 259.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	345	SF	\$120	\$41,340	
50454	202.1 to 203.1 feet	Vertical Change	-32	5 ft	5	REF			
48272	213.3 to 214.3 feet	Vertical Change	-39	5 ft	5	REF			
46660	257.8 to 258.8 feet	Vertical Change	-45	5 ft	5	REF			
9785	264.8 to 348.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	419	SF	\$120	\$50,220	
50455	312.9 to 313.9 feet	Vertical Change	-32	5 ft	5	REF			
9792	348.5 to 360.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	62	SF	\$120	\$7,380	
41546	357.7 to 358.7 feet	Vertical Change	-1.03	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221500	SANTA CRUZ BLVD	ROSE AVE	ELM AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9795	360.8 to 382.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	108	SF	\$120	\$12,960
48546	380.4 to 381.4 feet	Vertical Change	-.38	5 ft	5	REF		
9798	385.5 to 388.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680
9799	390.8 to 415.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	124	SF	\$120	\$14,880
44891	391.8 to 392.8 feet	Vertical Change	-.53	5 ft	5	REF		
47594	402.7 to 403.7 feet	Vertical Change	-.41	5 ft	5	REF		
9802	415.6 to 424.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	45	SF	\$120	\$5,340
52184	423.4 to 424.4 feet	Vertical Change	-.29	5 ft	5	REF		
9804	424.5 to 428.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220
9805	432.4 to 447.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	77	SF	\$120	\$9,180
9806	465.8 to 467.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900
52640	478.6 to 479.6 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375
9807	485.7 to 503.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	87	SF	\$120	\$10,380
48273	489.2 to 490.2 feet	Vertical Change	-.39	5 ft	5	REF		
9810	506.4 to 509.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680
9811	511.7 to 521.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,700
9812	524.5 to 527.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860
50456	529.2 to 530.2 feet	Vertical Change	-.32	5 ft	5	REF		
9813	530.2 to 541.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,600
52641	540.0 to 541.0 feet	Vertical Change	-.28	5 ft	5	REF		
9815	541.2 to 555.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	69	SF	\$120	\$8,280
45983	550.7 to 551.7 feet	Vertical Change	-.48	5 ft	5	REF		
9819	555.0 to 564.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,700
48547	561.8 to 562.8 feet	Vertical Change	-.38	5 ft	5	REF		
46661	583.4 to 584.4 feet	Vertical Change	-.45	5 ft	5	LF	\$75	\$375
9822	589.3 to 591.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440
49430	594.4 to 595.4 feet	Vertical Change	-.35	5 ft	5	REF		
9823	594.9 to 596.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,140

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221500	SANTA CRUZ BLVD	ROSE AVE	ELM AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9824	600.2 to 602.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,380
9825	607.3 to 608.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
52642	616.2 to 617.2 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375
9826	621.8 to 661.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	200	SF	\$120	\$24,000
53687	626.9 to 627.9 feet	Vertical Change	-.26	5 ft	5	REF		
49431	637.8 to 638.8 feet	Vertical Change	-.35	5 ft	5	REF		
50844	648.5 to 649.5 feet	Vertical Change	-.31	5 ft	5	REF		
9832	664.2 to 829.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	824	SF	\$120	\$98,880
44703	680.8 to 681.8 feet	Vertical Change	-.54	5 ft	5	REF		
49432	691.4 to 692.4 feet	Vertical Change	-.35	5 ft	5	REF		
52185	712.4 to 713.4 feet	Vertical Change	-.29	5 ft	5	REF		
51762	722.9 to 723.9 feet	Vertical Change	-.3	5 ft	5	REF		
49433	733.3 to 734.3 feet	Vertical Change	-.35	5 ft	5	REF		
49128	754.1 to 755.1 feet	Vertical Change	-.36	5 ft	5	REF		
44083	774.3 to 775.3 feet	Vertical Change	-.57	5 ft	5	REF		
42306	796.7 to 797.7 feet	Vertical Change	-.71	5 ft	5	REF		
56967	807.9 to 808.9 feet	Vertical Change	.56	5 ft	5	REF		
9847	829.0 to 836.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	39	SF	\$120	\$4,680
52186	830.9 to 831.9 feet	Vertical Change	-.29	5 ft	5	REF		

TOTAL COST FOR:	W	<i>side of</i>	SANTA CRUZ BLVD	<i>Starting at:</i>	ROSE AVE	\$377,370.00
------------------------	----------	----------------	------------------------	---------------------	-----------------	---------------------

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908221502	ELM AVE	SANTA CRUZ BLVD	PINE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
9850	0.0 to 2.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440	
47357	5.2 to 9.9 feet	Vertical Change	-.42	5 ft	24	LF	\$75	\$1,763	
49129	14.6 to 17.6 feet	Vertical Change	-.36	5 ft	15	LF	\$75	\$1,125	
53157	23.5 to 31.3 feet	Vertical Change	-.27	5 ft	39	LF	\$75	\$2,925	
58396	34.4 to 63.9 feet	Driveway				REF			
50457	34.6 to 43.8 feet	Vertical Change	-.32	5 ft	46	REF			
9851	41.7 to 50.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	43	SF	\$40	\$1,700	
53158	49.5 to 50.5 feet	Vertical Change	-.27	5 ft	5	REF			
44084	53.6 to 54.6 feet	Vertical Change	-.57	5 ft	5	REF			
9852	55.6 to 73.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	90	SF	\$40	\$3,580	
46196	62.0 to 68.6 feet	Vertical Change	-.47	5 ft	33	REF			
58397	67.8 to 95.8 feet	Driveway				REF			
46662	71.6 to 74.5 feet	Vertical Change	-.45	5 ft	15	REF			
9855	73.5 to 76.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	16	SF	\$40	\$640	
9857	76.7 to 78.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	7	SF	\$40	\$260	
9858	78.0 to 81.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	18	SF	\$40	\$720	
45567	80.9 to 81.9 feet	Vertical Change	-.5	5 ft	5	REF			
9860	81.6 to 84.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	14	SF	\$40	\$540	
9861	84.3 to 128.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	220	SF	\$40	\$8,800	
42017	85.0 to 86.0 feet	Vertical Change	-.77	5 ft	5	REF			
46437	89.4 to 90.4 feet	Vertical Change	-.46	5 ft	5	REF			
42307	93.7 to 99.7 feet	Vertical Change	-.71	5 ft	30	REF			
49756	102.2 to 108.2 feet	Vertical Change	-.34	5 ft	30	REF			
49757	110.9 to 130.6 feet	Vertical Change	-.34	5 ft	99	REF			
58398	130.3 to 161.5 feet	Driveway				REF			
43139	131.7 to 136.9 feet	Vertical Change	-.63	5 ft	26	REF			
9866	132.2 to 138.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	33	SF	\$40	\$1,320	
9868	138.8 to 144.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	28	SF	\$40	\$1,120	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221502	ELM AVE	SANTA CRUZ BLVD	PINE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
48018	143.9 to 144.9 feet	Vertical Change	-.4	5 ft	5	REF		
9870	144.4 to 192.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	241	SF	\$40	\$9,640
50461	159.3 to 162.4 feet	Vertical Change	-.32	5 ft	15	REF		
43605	163.3 to 164.3 feet	Vertical Change	-.6	5 ft	5	REF		
54036	165.5 to 168.7 feet	Vertical Change	-.25	5 ft	16	REF		
44892	172.4 to 173.4 feet	Vertical Change	-.53	5 ft	5	REF		
53160	174.5 to 175.5 feet	Vertical Change	-.27	5 ft	5	REF		
53688	183.2 to 184.2 feet	Vertical Change	-.26	5 ft	5	REF		
TOTAL COST FOR: N side of ELM AVE Starting at: SANTA CRUZ BLVD							\$35,572.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908221503	PINE ST	ELM AVE	PINE CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
9873	7.1 to 132.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	627	SF	\$120	\$75,180	
42054	8.1 to 9.1 feet	Vertical Change	-0.76	5 ft	5	REF			
52644	12.5 to 15.8 feet	Vertical Change	-0.28	5 ft	17	REF			
52189	19.4 to 26.6 feet	Vertical Change	-0.29	5 ft	36	REF			
54037	37.5 to 40.4 feet	Vertical Change	-0.25	5 ft	15	REF			
41323	82.7 to 83.7 feet	Vertical Change	-1.48	5 ft	5	REF			
57467	82.7 to 83.7 feet	Vertical Change	1.49	5 ft	5	REF			
53161	101.3 to 104.3 feet	Vertical Change	-0.27	5 ft	15	REF			
51766	107.4 to 112.5 feet	Vertical Change	-0.3	5 ft	26	REF			
49434	118.3 to 119.3 feet	Vertical Change	-0.35	5 ft	5	REF			
43431	120.7 to 121.7 feet	Vertical Change	-0.61	5 ft	5	REF			
51767	123.1 to 128.7 feet	Vertical Change	-0.3	5 ft	28	REF			
50462	131.9 to 136.8 feet	Vertical Change	-0.32	5 ft	25	REF			
9881	132.4 to 204.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	359	SF	\$120	\$43,080	
43140	137.8 to 138.8 feet	Vertical Change	-0.63	5 ft	5	REF			
53691	139.8 to 144.6 feet	Vertical Change	-0.26	5 ft	24	REF			
44477	145.5 to 146.5 feet	Vertical Change	-0.55	5 ft	5	REF			
50463	149.4 to 150.4 feet	Vertical Change	-0.32	5 ft	5	REF			
43743	153.4 to 154.4 feet	Vertical Change	-0.59	5 ft	5	REF			
52648	155.3 to 158.2 feet	Vertical Change	-0.28	5 ft	14	REF			
45568	161.3 to 168.1 feet	Vertical Change	-0.5	5 ft	34	REF			
54038	172.7 to 175.5 feet	Vertical Change	-0.25	5 ft	14	REF			
44478	176.4 to 177.4 feet	Vertical Change	-0.55	5 ft	5	REF			
54039	178.4 to 179.4 feet	Vertical Change	-0.25	5 ft	5	REF			
43900	184.1 to 185.1 feet	Vertical Change	-0.58	5 ft	5	REF			
50466	186.1 to 194.3 feet	Vertical Change	-0.32	5 ft	41	REF			
53163	199.7 to 200.7 feet	Vertical Change	-0.27	5 ft	5	REF			
41441	203.5 to 204.5 feet	Vertical Change	-1.19	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221503	PINE ST	ELM AVE	PINE CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9891	204.2 to 205.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960
TOTAL COST FOR: E side of PINE ST Starting at: ELM AVE							\$119,220.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908221505	PINE CT	PINE ST	309 PINE CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
41230	6.9 to 7.9 feet	Vertical Change	-2.01	5 ft	5	REF			
9892	7.3 to 45.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	190	SF	\$120	\$22,800	
50853	9.1 to 14.4 feet	Vertical Change	-31	5 ft	27	REF			
50079	20.2 to 35.5 feet	Vertical Change	-33	5 ft	77	REF			
41238	36.4 to 37.4 feet	Vertical Change	-1.94	5 ft	5	REF			
58399	37.5 to 65.8 feet	Driveway				REF			
43744	38.4 to 39.4 feet	Vertical Change	-59	5 ft	5	REF			
50854	40.4 to 41.4 feet	Vertical Change	-31	5 ft	5	REF			
45784	46.5 to 47.5 feet	Vertical Change	-49	5 ft	5	REF			
45276	52.5 to 53.5 feet	Vertical Change	-51	5 ft	5	REF			
47358	58.2 to 59.2 feet	Vertical Change	-42	5 ft	5	REF			
9896	60.5 to 72.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	58	SF	\$40	\$2,320	
44086	64.4 to 73.4 feet	Vertical Change	-57	5 ft	45	REF			
42018	76.3 to 77.3 feet	Vertical Change	-77	5 ft	5	SF	\$75	\$375	
41804	80.4 to 81.4 feet	Vertical Change	-84	5 ft	5	SF	\$75	\$375	
41663	84.4 to 85.4 feet	Vertical Change	-92	5 ft	5	SF	\$75	\$375	
9899	88.2 to 128.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	200	SF	\$120	\$23,940	
43432	88.5 to 89.5 feet	Vertical Change	-61	5 ft	5	REF			
41903	92.6 to 93.6 feet	Vertical Change	-8	5 ft	5	REF			
52649	94.6 to 95.6 feet	Vertical Change	-28	5 ft	5	REF			
43745	96.6 to 99.5 feet	Vertical Change	-59	5 ft	15	REF			
58400	98.0 to 127.1 feet	Driveway				REF			
50080	100.7 to 101.7 feet	Vertical Change	-33	5 ft	5	REF			
54040	104.1 to 105.1 feet	Vertical Change	-25	5 ft	5	REF			
45277	109.0 to 110.0 feet	Vertical Change	-51	5 ft	5	REF			
49131	115.3 to 116.3 feet	Vertical Change	-36	5 ft	5	REF			
47359	121.1 to 122.1 feet	Vertical Change	-42	5 ft	5	REF			
49761	131.2 to 136.2 feet	Vertical Change	-34	5 ft	25	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221505	PINE CT	PINE ST	309 PINE CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9903	131.7 to 139.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,440
41231	137.2 to 138.2 feet	Vertical Change	-2.01	5 ft	5	REF		
TOTAL COST FOR: S							<i>side of PINE CT Starting at: PINE ST</i>	\$54,625.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908221507	PINE CT	309 PINE CT	PINE ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
9905	0.0 to 84.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	424	SF	\$120	\$50,820	
41593	0.2 to 1.2 feet	Vertical Change	-.99	5 ft	5	REF			
49436	2.1 to 10.3 feet	Vertical Change	-.35	5 ft	41	REF			
41946	11.4 to 12.4 feet	Vertical Change	-.79	5 ft	5	REF			
50083	13.4 to 16.5 feet	Vertical Change	-.33	5 ft	16	REF			
45985	24.4 to 27.4 feet	Vertical Change	-.48	5 ft	15	REF			
45078	33.1 to 40.6 feet	Vertical Change	-.52	5 ft	38	REF			
41904	41.8 to 42.8 feet	Vertical Change	-.8	5 ft	5	REF			
52651	44.0 to 47.2 feet	Vertical Change	-.28	5 ft	16	REF			
41729	50.5 to 51.5 feet	Vertical Change	-.88	5 ft	5	REF			
50856	52.8 to 58.2 feet	Vertical Change	-.31	5 ft	27	REF			
41708	59.4 to 60.4 feet	Vertical Change	-.89	5 ft	5	REF			
51770	61.5 to 75.8 feet	Vertical Change	-.3	5 ft	72	REF			
50470	79.1 to 82.1 feet	Vertical Change	-.32	5 ft	15	REF			
9912	90.6 to 126.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	179	SF	\$120	\$21,420	
45569	92.4 to 93.4 feet	Vertical Change	-.5	5 ft	5	REF			
53166	96.6 to 97.6 feet	Vertical Change	-.27	5 ft	5	REF			
44893	98.6 to 99.6 feet	Vertical Change	-.53	5 ft	5	REF			
52652	102.8 to 116.7 feet	Vertical Change	-.28	5 ft	70	REF			
58401	118.0 to 151.3 feet	Driveway				REF			
51772	120.4 to 126.2 feet	Vertical Change	-.3	5 ft	29	REF			
9916	129.8 to 138.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	43	SF	\$40	\$1,720	
46666	137.7 to 138.7 feet	Vertical Change	-.45	5 ft	5	REF			
9918	138.4 to 143.2 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	24	SF	\$40	\$960	
9920	143.2 to 147.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	23	SF	\$40	\$920	
41865	150.6 to 151.6 feet	Vertical Change	-.81	5 ft	5	REF			
9922	151.1 to 152.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200	
9923	152.1 to 160.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,860	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908221507	PINE CT	309 PINE CT	PINE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
41594	157.4 to 158.4 feet	Vertical Change	-99	5 ft	5	REF			
42590	161.8 to 162.8 feet	Vertical Change	-68	5 ft	5	SF	\$75	\$375	
54043	164.0 to 165.0 feet	Vertical Change	-25	5 ft	5	LF	\$75	\$375	
41681	166.1 to 167.1 feet	Vertical Change	-91	5 ft	5	SF	\$75	\$375	
53694	168.4 to 169.4 feet	Vertical Change	-26	5 ft	5	LF	\$75	\$375	
41905	170.6 to 171.6 feet	Vertical Change	-8	5 ft	5	SF	\$75	\$375	
48019	175.1 to 178.3 feet	Vertical Change	-4	5 ft	16	LF	\$75	\$1,200	
41749	179.4 to 180.4 feet	Vertical Change	-87	5 ft	5	REF			
9924	179.7 to 194.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	76	SF	\$120	\$9,120	
49765	181.4 to 182.4 feet	Vertical Change	-34	5 ft	5	REF			
41664	183.1 to 184.1 feet	Vertical Change	-92	5 ft	5	REF			
49438	185.1 to 192.2 feet	Vertical Change	-35	5 ft	36	REF			
9926	194.9 to 216.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	107	SF	\$120	\$12,780	
41730	195.4 to 196.4 feet	Vertical Change	-88	5 ft	5	REF			
46438	199.5 to 210.4 feet	Vertical Change	-46	5 ft	55	REF			
58402	209.3 to 240.5 feet	Driveway				REF			
52654	213.1 to 214.1 feet	Vertical Change	-28	5 ft	5	REF			
41540	214.5 to 215.5 feet	Vertical Change	-1.04	5 ft	5	REF			
9930	216.2 to 228.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	62	SF	\$40	\$2,480	
43606	216.3 to 221.0 feet	Vertical Change	-6	5 ft	24	REF			
46439	224.2 to 225.2 feet	Vertical Change	-46	5 ft	5	REF			
45786	228.8 to 229.8 feet	Vertical Change	-49	5 ft	5	REF			
46667	232.9 to 233.9 feet	Vertical Change	-45	5 ft	5	REF			
9933	233.1 to 235.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	14	SF	\$40	\$540	
9935	235.8 to 256.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	103	SF	\$40	\$4,100	
41697	240.1 to 244.9 feet	Vertical Change	-9	5 ft	24	REF			
49767	246.1 to 275.1 feet	Vertical Change	-34	5 ft	145	REF			
9937	256.3 to 262.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,840	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221507	PINE CT	309 PINE CT	PINE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9939	262.7 to 280.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	88	SF	\$120	\$10,560
58403	274.6 to 300.7 feet	Driveway				REF		
42910	275.6 to 276.6 feet	Vertical Change	-65	5 ft	5	REF		
9942	283.7 to 298.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	73	SF	\$40	\$2,940
43607	290.9 to 291.9 feet	Vertical Change	-.6	5 ft	5	REF		
40314	297.7 to 299.2 feet	Running Slope	5.0-6.0%	5 ft	8	REF		
44266	301.9 to 304.9 feet	Vertical Change	-.56	5 ft	15	REF		
9945	302.2 to 307.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	26	SF	\$120	\$3,060
58404	304.3 to 331.8 feet	Driveway				REF		
9946	307.3 to 308.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$280
43142	307.7 to 310.7 feet	Vertical Change	-.63	5 ft	15	REF		
9947	312.8 to 315.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	14	SF	\$40	\$540
9949	315.5 to 329.0 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	68	SF	\$40	\$2,700
43747	320.7 to 321.7 feet	Vertical Change	-.59	5 ft	5	REF		
43433	332.0 to 337.0 feet	Vertical Change	-.61	5 ft	25	REF		
9953	333.2 to 340.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	38	SF	\$120	\$4,500
50862	338.3 to 339.3 feet	Vertical Change	-.31	5 ft	5	REF		
9955	340.7 to 365.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	124	SF	\$120	\$14,820
50086	342.8 to 354.7 feet	Vertical Change	-.33	5 ft	60	REF		
41750	357.6 to 358.6 feet	Vertical Change	-.87	5 ft	5	REF		
51775	358.6 to 359.6 feet	Vertical Change	-.3	5 ft	5	REF		
43903	358.8 to 360.3 feet	Vertical Change	-.58	5 ft	8	REF		
52656	359.6 to 360.6 feet	Vertical Change	-.28	5 ft	5	REF		
41665	359.9 to 360.9 feet	Vertical Change	-.92	5 ft	5	REF		
TOTAL COST FOR: N side of PINE CT Starting at: 309 PINE CT							\$156,235.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908221508	PINE ST	PINE CT	LARK AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
9958	0.0 to 10.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,060	
41260	7.6 to 8.6 feet	Vertical Change	-1.77	5 ft	5	REF			
49440	9.8 to 15.1 feet	Vertical Change	-.35	5 ft	26	REF			
9960	10.1 to 17.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	39	SF	\$120	\$4,680	
9962	17.9 to 46.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	142	SF	\$120	\$17,040	
46197	18.5 to 21.4 feet	Vertical Change	-.47	5 ft	15	REF			
44479	24.1 to 25.1 feet	Vertical Change	-.55	5 ft	5	REF			
51776	27.8 to 28.8 feet	Vertical Change	-.3	5 ft	5	REF			
43608	29.7 to 30.7 feet	Vertical Change	-.6	5 ft	5	REF			
50863	31.5 to 36.2 feet	Vertical Change	-.31	5 ft	24	REF			
53696	38.6 to 45.1 feet	Vertical Change	-.26	5 ft	33	REF			
9965	46.3 to 131.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	428	SF	\$120	\$51,300	
54138	46.8 to 47.8 feet	Vertical Change	.25	5 ft	5	REF			
48021	51.5 to 52.5 feet	Vertical Change	-.4	5 ft	5	REF			
51778	55.4 to 58.3 feet	Vertical Change	-.3	5 ft	15	REF			
43904	59.1 to 60.1 feet	Vertical Change	-.58	5 ft	5	REF			
53169	63.0 to 65.9 feet	Vertical Change	-.27	5 ft	15	REF			
44705	66.7 to 67.7 feet	Vertical Change	-.54	5 ft	5	REF			
44480	74.4 to 75.4 feet	Vertical Change	-.55	5 ft	5	REF			
52658	78.3 to 85.1 feet	Vertical Change	-.28	5 ft	34	REF			
52199	88.0 to 89.0 feet	Vertical Change	-.29	5 ft	5	REF			
44267	89.8 to 90.8 feet	Vertical Change	-.56	5 ft	5	REF			
52200	91.9 to 99.1 feet	Vertical Change	-.29	5 ft	36	REF			
52201	102.4 to 103.4 feet	Vertical Change	-.29	5 ft	5	REF			
53701	108.3 to 113.1 feet	Vertical Change	-.26	5 ft	24	REF			
52659	116.2 to 117.2 feet	Vertical Change	-.28	5 ft	5	REF			
50866	120.1 to 129.0 feet	Vertical Change	-.31	5 ft	45	REF			
43905	130.1 to 131.1 feet	Vertical Change	-.58	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221508	PINE ST	PINE CT	LARK AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9969	131.8 to 205.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	369	SF	\$120	\$44,340
52660	134.2 to 137.2 feet	Vertical Change	-.28	5 ft	15	REF		
43609	138.3 to 139.3 feet	Vertical Change	-.6	5 ft	5	REF		
52203	140.2 to 152.8 feet	Vertical Change	-.29	5 ft	63	REF		
50870	157.6 to 183.9 feet	Vertical Change	-.31	5 ft	132	REF		
43610	184.9 to 185.9 feet	Vertical Change	-.6	5 ft	5	REF		
52206	186.9 to 197.5 feet	Vertical Change	-.29	5 ft	53	REF		
45987	200.6 to 211.6 feet	Vertical Change	-.48	5 ft	55	REF		
9975	205.7 to 211.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	30	SF	\$120	\$3,600
9977	211.7 to 217.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,300
42055	212.3 to 213.3 feet	Vertical Change	-.76	5 ft	5	REF		
TOTAL COST FOR: E side of PINE ST Starting at: PINE CT							\$130,320.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S/E	1908221511	LARK AVE	PINE ST	ROSE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
9978	5.0 to 32.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	139	SF	\$120	\$16,620
41349	7.1 to 8.1 feet	Vertical Change	-1.4	5 ft	5	REF		
53174	10.6 to 19.9 feet	Vertical Change	-.27	5 ft	46	REF		
44268	20.8 to 21.8 feet	Vertical Change	-.56	5 ft	5	REF		
52666	22.8 to 27.9 feet	Vertical Change	-.28	5 ft	26	REF		
58405	26.9 to 53.4 feet	Driveway				REF		
41350	28.9 to 29.9 feet	Vertical Change	-1.4	5 ft	5	REF		
45790	30.9 to 34.0 feet	Vertical Change	-.49	5 ft	16	REF		
9979	36.9 to 51.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	72	SF	\$40	\$2,880
44895	43.9 to 44.9 feet	Vertical Change	-.53	5 ft	5	REF		
45080	54.4 to 57.3 feet	Vertical Change	-.52	5 ft	15	REF		
9982	55.0 to 61.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,900
58406	56.9 to 84.8 feet	Driveway				REF		
41226	58.3 to 59.3 feet	Vertical Change	-2.09	5 ft	5	REF		
42239	60.3 to 63.5 feet	Vertical Change	-.72	5 ft	16	REF		
50480	62.9 to 66.6 feet	Vertical Change	-.32	5 ft	18	REF		
9984	68.1 to 127.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	297	SF	\$40	\$11,860
44269	70.2 to 71.2 feet	Vertical Change	-.56	5 ft	5	REF		
44270	74.3 to 75.3 feet	Vertical Change	-.56	5 ft	5	REF		
44707	78.5 to 79.5 feet	Vertical Change	-.54	5 ft	5	REF		
46200	82.6 to 83.6 feet	Vertical Change	-.47	5 ft	5	REF		
48023	85.7 to 89.0 feet	Vertical Change	-.4	5 ft	17	REF		
41512	90.1 to 91.1 feet	Vertical Change	-1.08	5 ft	5	REF		
52668	94.9 to 98.1 feet	Vertical Change	-.28	5 ft	16	REF		
43145	99.2 to 100.2 feet	Vertical Change	-.63	5 ft	5	REF		
52669	101.0 to 105.6 feet	Vertical Change	-.28	5 ft	23	REF		
44089	106.6 to 109.5 feet	Vertical Change	-.57	5 ft	15	REF		
51784	110.2 to 113.1 feet	Vertical Change	-.3	5 ft	15	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S/E	1908221511	LARK AVE	PINE ST	ROSE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
43435	113.8 to 114.8 feet	Vertical Change	-.61	5 ft	5	REF			
50876	115.7 to 118.5 feet	Vertical Change	-.31	5 ft	14	REF			
46894	121.3 to 129.5 feet	Vertical Change	-.44	5 ft	41	REF			
9987	132.3 to 137.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,880	
51785	135.9 to 136.9 feet	Vertical Change	-.3	5 ft	5	REF			
48551	148.7 to 149.7 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375	
58407	151.6 to 178.3 feet	Driveway				REF			
41989	153.6 to 158.4 feet	Vertical Change	-.78	5 ft	24	REF			
51786	158.0 to 159.0 feet	Vertical Change	-.3	5 ft	5	REF			
43611	159.9 to 160.9 feet	Vertical Change	-.6	5 ft	5	REF			
9988	162.8 to 165.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	15	SF	\$40	\$620	
46202	164.5 to 165.5 feet	Vertical Change	-.47	5 ft	5	REF			
44709	168.9 to 169.9 feet	Vertical Change	-.54	5 ft	5	REF			
45279	172.9 to 173.9 feet	Vertical Change	-.51	5 ft	5	REF			
45081	176.9 to 177.9 feet	Vertical Change	-.52	5 ft	5	REF			
9989	178.2 to 188.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	52	SF	\$40	\$2,080	
48851	180.4 to 184.1 feet	Vertical Change	-.37	5 ft	19	REF			
58408	182.7 to 207.0 feet	Driveway				REF			
41365	184.8 to 185.8 feet	Vertical Change	-1.37	5 ft	5	REF			
43146	186.4 to 187.4 feet	Vertical Change	-.63	5 ft	5	REF			
53705	188.4 to 189.6 feet	Vertical Change	-.26	5 ft	6	REF			
42400	191.6 to 192.6 feet	Vertical Change	-.7	5 ft	5	REF			
9990	192.3 to 207.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	75	SF	\$40	\$2,980	
42145	196.1 to 197.1 feet	Vertical Change	-.74	5 ft	5	REF			
41513	200.3 to 201.3 feet	Vertical Change	-1.08	5 ft	5	REF			
41605	204.5 to 205.5 feet	Vertical Change	-.98	5 ft	5	REF			
41595	208.7 to 209.7 feet	Vertical Change	-.99	5 ft	5	REF			
9993	209.7 to 258.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	246	SF	\$120	\$29,460	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S/E	1908221511	LARK AVE	PINE ST	ROSE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
45280	211.3 to 214.5 feet	Vertical Change	-.51	5 ft	16	REF		
41551	215.3 to 216.3 feet	Vertical Change	-1.02	5 ft	5	REF		
53176	218.5 to 221.1 feet	Vertical Change	-.27	5 ft	13	REF		
42792	224.6 to 225.6 feet	Vertical Change	-.66	5 ft	5	REF		
53177	226.3 to 234.3 feet	Vertical Change	-.27	5 ft	40	REF		
50877	237.0 to 238.0 feet	Vertical Change	-.31	5 ft	5	REF		
42591	238.8 to 239.8 feet	Vertical Change	-.68	5 ft	5	REF		
52212	240.8 to 246.1 feet	Vertical Change	-.29	5 ft	27	REF		
43906	247.1 to 248.1 feet	Vertical Change	-.58	5 ft	5	REF		
58409	248.9 to 281.7 feet	Driveway				REF		
53707	249.3 to 250.3 feet	Vertical Change	-.26	5 ft	5	REF		
41448	251.4 to 252.4 feet	Vertical Change	-1.16	5 ft	5	REF		
57406	251.5 to 252.5 feet	Vertical Change	1.18	5 ft	5	REF		
43280	253.7 to 257.1 feet	Vertical Change	-.62	5 ft	17	REF		
50878	257.8 to 258.8 feet	Vertical Change	-.31	5 ft	5	REF		
10001	258.8 to 263.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	25	SF	\$40	\$980
43748	259.3 to 260.3 feet	Vertical Change	-.59	5 ft	5	REF		
44896	262.8 to 263.8 feet	Vertical Change	-.53	5 ft	5	REF		
10003	263.7 to 277.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	67	SF	\$40	\$2,680
44271	267.2 to 268.2 feet	Vertical Change	-.56	5 ft	5	REF		
45083	271.7 to 272.7 feet	Vertical Change	-.52	5 ft	5	REF		
44710	276.1 to 277.1 feet	Vertical Change	-.54	5 ft	5	REF		
10005	277.1 to 283.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	30	SF	\$40	\$1,220
53179	279.1 to 280.1 feet	Vertical Change	-.27	5 ft	5	REF		
47360	282.9 to 287.8 feet	Vertical Change	-.42	5 ft	25	REF		
10009	283.2 to 288.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,420
58410	283.4 to 312.3 feet	Driveway				REF		
10011	291.6 to 310.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	92	SF	\$40	\$3,680

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S/E	1908221511	LARK AVE	PINE ST	ROSE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40315	307.8 to 309.5 feet	Running Slope	5.0-6.0%	5 ft	9	REF		
10015	313.3 to 315.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
49770	313.4 to 316.6 feet	Vertical Change	-.34	5 ft	16	REF		
42308	317.6 to 318.6 feet	Vertical Change	-.71	5 ft	5	SF	\$75	\$375
51788	319.7 to 343.0 feet	Vertical Change	-.3	5 ft	117	LF	\$75	\$8,738
10016	327.4 to 378.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	258	SF	\$120	\$30,900
48024	347.0 to 348.0 feet	Vertical Change	-.4	5 ft	5	REF		
58411	354.3 to 383.7 feet	Driveway				REF		
43436	356.7 to 361.8 feet	Vertical Change	-.61	5 ft	26	REF		
45571	367.4 to 368.4 feet	Vertical Change	-.5	5 ft	5	REF		
46440	371.6 to 372.6 feet	Vertical Change	-.46	5 ft	5	REF		
45988	375.8 to 376.8 feet	Vertical Change	-.48	5 ft	5	REF		
46441	380.1 to 381.1 feet	Vertical Change	-.46	5 ft	5	REF		
52216	383.8 to 384.8 feet	Vertical Change	-.29	5 ft	5	REF		
10020	385.9 to 408.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	111	SF	\$120	\$13,260
44482	386.1 to 391.8 feet	Vertical Change	-.55	5 ft	29	REF		
58412	386.8 to 412.1 feet	Driveway				REF		
46442	394.0 to 395.0 feet	Vertical Change	-.46	5 ft	5	REF		
47600	398.3 to 399.3 feet	Vertical Change	-.41	5 ft	5	REF		
49134	402.6 to 403.6 feet	Vertical Change	-.36	5 ft	5	REF		
47601	406.8 to 407.8 feet	Vertical Change	-.41	5 ft	5	REF		
50482	411.1 to 419.4 feet	Vertical Change	-.32	5 ft	42	REF		
10021	411.9 to 513.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	509	SF	\$40	\$20,360
45572	424.3 to 425.3 feet	Vertical Change	-.5	5 ft	5	REF		
48552	431.1 to 432.1 feet	Vertical Change	-.38	5 ft	5	REF		
47120	438.0 to 443.7 feet	Vertical Change	-.43	5 ft	29	REF		
44092	447.2 to 450.6 feet	Vertical Change	-.57	5 ft	17	REF		
47602	455.9 to 456.9 feet	Vertical Change	-.41	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S/E	1908221511	LARK AVE	PINE ST	ROSE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44272	462.0 to 463.0 feet	Vertical Change	-.56	5 ft	5	REF		
52673	464.1 to 465.1 feet	Vertical Change	-.28	5 ft	5	REF		
45990	468.0 to 480.7 feet	Vertical Change	-.48	5 ft	64	REF		
58413	472.7 to 502.6 feet	Driveway				REF		
49138	483.5 to 484.5 feet	Vertical Change	-.36	5 ft	5	REF		
45992	487.8 to 488.8 feet	Vertical Change	-.48	5 ft	5	REF		
44712	492.0 to 493.0 feet	Vertical Change	-.54	5 ft	5	REF		
45283	496.1 to 497.1 feet	Vertical Change	-.51	5 ft	5	REF		
46443	500.5 to 501.5 feet	Vertical Change	-.46	5 ft	5	REF		
47121	503.9 to 513.1 feet	Vertical Change	-.43	5 ft	46	REF		
58414	507.7 to 534.0 feet	Driveway				REF		
10030	513.7 to 521.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	38	SF	\$40	\$1,500
10033	521.2 to 563.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	213	SF	\$40	\$8,520
48852	523.2 to 524.2 feet	Vertical Change	-.37	5 ft	5	REF		
51793	530.5 to 533.0 feet	Vertical Change	-.3	5 ft	13	REF		
41666	534.9 to 535.9 feet	Vertical Change	-.92	5 ft	5	REF		
44093	537.1 to 540.1 feet	Vertical Change	-.57	5 ft	15	REF		
53708	541.2 to 542.2 feet	Vertical Change	-.26	5 ft	5	REF		
42146	547.1 to 548.1 feet	Vertical Change	-.74	5 ft	5	REF		
47363	554.1 to 555.1 feet	Vertical Change	-.42	5 ft	5	REF		
43281	565.0 to 566.0 feet	Vertical Change	-.62	5 ft	5	SF	\$75	\$375
TOTAL COST FOR: S/E side of LARK AVE Starting at: PINE ST								\$171,162.50

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W/N	1908221515	LARK AVE	ROSE AVE	PINE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
10037	0.0 to 2.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	11	SF	\$120	\$1,320	
10038	2.2 to 9.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,440	
41990	8.7 to 9.7 feet	Vertical Change	-.78	5 ft	5	REF			
10039	11.8 to 33.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	107	SF	\$120	\$12,780	
42056	14.4 to 15.4 feet	Vertical Change	-.76	5 ft	5	REF			
46444	15.2 to 16.2 feet	Vertical Change	-.46	5 ft	5	REF			
53709	19.7 to 20.7 feet	Vertical Change	-.26	5 ft	5	REF			
52675	23.6 to 24.6 feet	Vertical Change	-.28	5 ft	5	REF			
54049	27.3 to 28.3 feet	Vertical Change	-.25	5 ft	5	REF			
45791	30.8 to 31.8 feet	Vertical Change	-.49	5 ft	5	REF			
45284	38.1 to 39.1 feet	Vertical Change	-.51	5 ft	5	SF	\$75	\$375	
10042	43.9 to 75.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	157	SF	\$120	\$18,840	
47122	45.4 to 46.4 feet	Vertical Change	-.43	5 ft	5	REF			
47364	52.8 to 53.8 feet	Vertical Change	-.42	5 ft	5	REF			
46896	60.0 to 61.0 feet	Vertical Change	-.44	5 ft	5	REF			
49771	67.3 to 68.3 feet	Vertical Change	-.34	5 ft	5	REF			
53181	72.6 to 73.6 feet	Vertical Change	-.27	5 ft	5	REF			
44899	74.5 to 75.5 feet	Vertical Change	-.53	5 ft	5	REF			
10045	80.4 to 82.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$1,020	
49446	82.1 to 83.1 feet	Vertical Change	-.35	5 ft	5	REF			
10046	86.2 to 91.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060	
49139	89.5 to 90.5 feet	Vertical Change	-.36	5 ft	5	REF			
48853	96.9 to 97.9 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375	
48275	103.8 to 104.8 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375	
53710	109.1 to 110.1 feet	Vertical Change	-.26	5 ft	5	REF			
10047	109.7 to 215.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	527	SF	\$120	\$63,180	
52217	118.5 to 119.5 feet	Vertical Change	-.29	5 ft	5	REF			
44484	132.9 to 133.9 feet	Vertical Change	-.55	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W/N	1908221515	LARK AVE	ROSE AVE	PINE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46672	139.9 to 140.9 feet	Vertical Change	-.45	5 ft	5	REF		
43908	147.1 to 148.1 feet	Vertical Change	-.58	5 ft	5	REF		
53711	149.0 to 150.0 feet	Vertical Change	-.26	5 ft	5	REF		
53182	152.5 to 153.5 feet	Vertical Change	-.27	5 ft	5	REF		
48554	161.6 to 162.6 feet	Vertical Change	-.38	5 ft	5	REF		
48555	175.8 to 176.8 feet	Vertical Change	-.38	5 ft	5	REF		
49140	190.3 to 193.2 feet	Vertical Change	-.36	5 ft	15	REF		
48276	197.6 to 198.6 feet	Vertical Change	-.39	5 ft	5	REF		
49772	203.7 to 208.5 feet	Vertical Change	-.34	5 ft	24	REF		
56942	207.7 to 208.7 feet	Vertical Change	.54	5 ft	5	REF		
42401	209.7 to 210.7 feet	Vertical Change	-.7	5 ft	5	REF		
43749	218.9 to 219.9 feet	Vertical Change	-.59	5 ft	5	SF	\$75	\$375
46206	224.4 to 225.4 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375
48556	233.1 to 241.1 feet	Vertical Change	-.38	5 ft	40	REF		
10064	233.8 to 263.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	150	SF	\$120	\$17,940
58415	244.5 to 273.8 feet	Driveway				REF		
41621	247.3 to 248.3 feet	Vertical Change	-.96	5 ft	5	REF		
46445	249.2 to 252.4 feet	Vertical Change	-.46	5 ft	16	REF		
51795	254.5 to 255.5 feet	Vertical Change	-.3	5 ft	5	REF		
48557	258.9 to 259.9 feet	Vertical Change	-.38	5 ft	5	REF		
44485	263.1 to 264.1 feet	Vertical Change	-.55	5 ft	5	REF		
10068	266.8 to 378.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	559	SF	\$40	\$22,360
45286	267.3 to 268.3 feet	Vertical Change	-.51	5 ft	5	REF		
48558	271.5 to 272.5 feet	Vertical Change	-.38	5 ft	5	REF		
45287	275.3 to 278.5 feet	Vertical Change	-.51	5 ft	16	REF		
58416	277.9 to 305.4 feet	Driveway				REF		
41771	279.2 to 283.6 feet	Vertical Change	-.86	5 ft	22	REF		
50091	286.3 to 287.3 feet	Vertical Change	-.33	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W/N	1908221515	LARK AVE	ROSE AVE	PINE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
45085	290.5 to 291.5 feet	Vertical Change	-.52	5 ft	5	REF		
48559	294.8 to 295.8 feet	Vertical Change	-.38	5 ft	5	REF		
46207	299.0 to 300.0 feet	Vertical Change	-.47	5 ft	5	REF		
49141	303.3 to 309.4 feet	Vertical Change	-.36	5 ft	30	REF		
41805	310.4 to 313.5 feet	Vertical Change	-.84	5 ft	16	REF		
42240	319.1 to 320.1 feet	Vertical Change	-.72	5 ft	5	REF		
49142	326.3 to 327.3 feet	Vertical Change	-.36	5 ft	5	REF		
53184	331.4 to 332.4 feet	Vertical Change	-.27	5 ft	5	REF		
43909	333.8 to 334.8 feet	Vertical Change	-.58	5 ft	5	REF		
43910	341.4 to 342.4 feet	Vertical Change	-.58	5 ft	5	REF		
52677	343.9 to 347.4 feet	Vertical Change	-.28	5 ft	18	REF		
44273	348.9 to 349.9 feet	Vertical Change	-.56	5 ft	5	REF		
53185	353.9 to 354.9 feet	Vertical Change	-.27	5 ft	5	REF		
43011	356.3 to 357.3 feet	Vertical Change	-.64	5 ft	5	REF		
42194	363.8 to 364.8 feet	Vertical Change	-.73	5 ft	5	REF		
52218	369.1 to 370.1 feet	Vertical Change	-.29	5 ft	5	REF		
43150	371.8 to 375.6 feet	Vertical Change	-.63	5 ft	19	REF		
58417	372.5 to 398.6 feet	Driveway				REF		
57148	374.7 to 375.7 feet	Vertical Change	.64	5 ft	5	REF		
44274	376.7 to 379.6 feet	Vertical Change	-.56	5 ft	15	REF		
10075	382.5 to 396.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	68	SF	\$40	\$2,720
42687	389.3 to 390.3 feet	Vertical Change	-.67	5 ft	5	REF		
40316	395.5 to 397.7 feet	Running Slope	6.0-7.0%	5 ft	11	REF		
10077	396.1 to 397.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	6	SF	\$40	\$240
43151	400.1 to 403.4 feet	Vertical Change	-.63	5 ft	17	REF		
10078	400.1 to 401.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$660
10079	401.2 to 421.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	100	SF	\$120	\$11,940
41396	404.6 to 405.6 feet	Vertical Change	-1.28	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W/N	1908221515	LARK AVE	ROSE AVE	PINE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57402	404.6 to 405.6 feet	Vertical Change	1.15	5 ft	5	REF		
58418	405.0 to 431.5 feet	Driveway				REF		
42147	406.8 to 407.8 feet	Vertical Change	-.74	5 ft	5	REF		
47603	409.4 to 412.9 feet	Vertical Change	-.41	5 ft	18	REF		
47124	416.1 to 417.1 feet	Vertical Change	-.43	5 ft	5	REF		
44900	420.1 to 421.1 feet	Vertical Change	-.53	5 ft	5	REF		
46446	424.6 to 425.6 feet	Vertical Change	-.46	5 ft	5	REF		
43751	429.1 to 430.1 feet	Vertical Change	-.59	5 ft	5	REF		
51796	430.2 to 432.9 feet	Vertical Change	-.3	5 ft	14	REF		
10082	433.8 to 460.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	134	SF	\$120	\$16,020
44094	433.9 to 434.9 feet	Vertical Change	-.57	5 ft	5	REF		
41456	435.9 to 436.9 feet	Vertical Change	-1.14	5 ft	5	REF		
52219	438.0 to 439.0 feet	Vertical Change	-.29	5 ft	5	REF		
44486	442.3 to 443.3 feet	Vertical Change	-.55	5 ft	5	REF		
53186	444.9 to 451.2 feet	Vertical Change	-.27	5 ft	32	REF		
41525	452.9 to 453.9 feet	Vertical Change	-1.06	5 ft	5	REF		
51797	459.3 to 460.3 feet	Vertical Change	-.3	5 ft	5	REF		
42913	459.5 to 460.5 feet	Vertical Change	-.65	5 ft	5	REF		
TOTAL COST FOR: W/N side of LARK AVE Starting at: ROSE AVE							\$178,395.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221517	PINE ST	LARK AVE	ROSE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
10087	0.0 to 117.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	587	SF	\$120	\$70,380
41731	9.3 to 10.3 feet	Vertical Change	-88	5 ft	5	REF		
43912	16.6 to 17.6 feet	Vertical Change	-58	5 ft	5	REF		
53188	22.3 to 23.3 feet	Vertical Change	-27	5 ft	5	REF		
41948	24.1 to 25.1 feet	Vertical Change	-79	5 ft	5	REF		
54051	29.9 to 30.9 feet	Vertical Change	-25	5 ft	5	REF		
43012	31.8 to 32.8 feet	Vertical Change	-64	5 ft	5	REF		
54052	33.8 to 34.8 feet	Vertical Change	-25	5 ft	5	REF		
41772	39.6 to 40.6 feet	Vertical Change	-86	5 ft	5	REF		
53714	43.6 to 44.6 feet	Vertical Change	-26	5 ft	5	REF		
43013	47.6 to 48.6 feet	Vertical Change	-64	5 ft	5	REF		
44487	55.6 to 56.6 feet	Vertical Change	-55	5 ft	5	REF		
46897	63.6 to 64.6 feet	Vertical Change	-44	5 ft	5	REF		
46673	71.7 to 72.7 feet	Vertical Change	-45	5 ft	5	REF		
45575	79.6 to 80.6 feet	Vertical Change	-5	5 ft	5	REF		
46447	87.3 to 90.3 feet	Vertical Change	-46	5 ft	15	REF		
53715	101.0 to 102.0 feet	Vertical Change	-26	5 ft	5	REF		
46448	104.5 to 105.5 feet	Vertical Change	-46	5 ft	5	REF		
10097	123.5 to 195.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	362	SF	\$120	\$43,380
54053	127.8 to 128.8 feet	Vertical Change	-25	5 ft	5	REF		
50092	143.8 to 144.8 feet	Vertical Change	-33	5 ft	5	REF		
48278	151.8 to 152.8 feet	Vertical Change	-39	5 ft	5	REF		
53716	160.0 to 163.0 feet	Vertical Change	-26	5 ft	15	REF		
48855	167.8 to 168.8 feet	Vertical Change	-37	5 ft	5	REF		
48560	175.9 to 176.9 feet	Vertical Change	-38	5 ft	5	REF		
46898	184.0 to 185.0 feet	Vertical Change	-44	5 ft	5	REF		
52679	191.7 to 192.7 feet	Vertical Change	-28	5 ft	5	REF		
10106	195.8 to 200.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	21	SF	\$120	\$2,520

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221517	PINE ST	LARK AVE	ROSE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
43152	199.2 to 200.2 feet	Vertical Change	-.63	5 ft	5	REF		
10108	200.0 to 203.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860
TOTAL COST FOR: E side of PINE ST Starting at: LARK AVE							\$118,140.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
S	1908221519	ROSE AVE	PINE ST	LARK AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
10109	0.0 to 35.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	180	SF	\$120	\$21,540	
41421	4.0 to 5.0 feet	Vertical Change	-1.22	5 ft	5	REF			
50093	10.1 to 11.1 feet	Vertical Change	-.33	5 ft	5	REF			
42241	12.3 to 13.3 feet	Vertical Change	-.72	5 ft	5	REF			
42494	19.8 to 20.8 feet	Vertical Change	-.69	5 ft	5	REF			
48856	27.3 to 28.3 feet	Vertical Change	-.37	5 ft	5	REF			
43752	34.3 to 41.4 feet	Vertical Change	-.59	5 ft	36	REF			
10113	41.1 to 48.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,560	
44095	44.9 to 45.9 feet	Vertical Change	-.57	5 ft	5	REF			
49144	49.2 to 50.2 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375	
50882	53.4 to 54.4 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
10114	55.7 to 57.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900	
45289	57.6 to 70.6 feet	Vertical Change	-.51	5 ft	65	SF	\$75	\$4,875	
10115	62.9 to 68.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,240	
58420	66.2 to 90.0 feet	Driveway				REF			
46208	72.7 to 73.7 feet	Vertical Change	-.47	5 ft	5	REF			
44488	77.0 to 78.0 feet	Vertical Change	-.55	5 ft	5	REF			
47365	81.2 to 82.2 feet	Vertical Change	-.42	5 ft	5	REF			
48562	85.5 to 86.5 feet	Vertical Change	-.38	5 ft	5	REF			
10116	88.9 to 118.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	147	SF	\$40	\$5,880	
44902	89.8 to 97.7 feet	Vertical Change	-.53	5 ft	40	REF			
45087	103.8 to 104.8 feet	Vertical Change	-.52	5 ft	5	REF			
54054	107.5 to 110.4 feet	Vertical Change	-.25	5 ft	15	REF			
50883	114.9 to 115.9 feet	Vertical Change	-.31	5 ft	5	REF			
46209	122.0 to 123.0 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375	
10124	123.8 to 175.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	258	SF	\$120	\$30,960	
50884	136.5 to 137.5 feet	Vertical Change	-.31	5 ft	5	REF			
54055	140.2 to 143.1 feet	Vertical Change	-.25	5 ft	15	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221519	ROSE AVE	PINE ST	LARK AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44489	144.1 to 145.1 feet	Vertical Change	-.55	5 ft	5	REF		
42793	151.7 to 152.7 feet	Vertical Change	-.66	5 ft	5	REF		
53718	157.5 to 158.5 feet	Vertical Change	-.26	5 ft	5	REF		
44490	159.4 to 160.4 feet	Vertical Change	-.55	5 ft	5	REF		
53719	163.2 to 166.1 feet	Vertical Change	-.26	5 ft	15	REF		
58421	168.0 to 196.1 feet	Driveway				REF		
41257	170.7 to 171.7 feet	Vertical Change	-1.78	5 ft	5	REF		
45995	172.7 to 175.8 feet	Vertical Change	-.48	5 ft	16	REF		
10131	179.4 to 192.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	68	SF	\$40	\$2,700
45088	185.8 to 186.8 feet	Vertical Change	-.52	5 ft	5	REF		
40317	194.2 to 195.2 feet	Running Slope	6.0-7.0%	5 ft	5	REF		
10133	196.5 to 197.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$260
48564	196.6 to 197.6 feet	Vertical Change	-.38	5 ft	5	REF		
58422	199.6 to 226.2 feet	Driveway				REF		
10134	200.3 to 204.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	19	SF	\$40	\$740
43753	200.7 to 201.7 feet	Vertical Change	-.59	5 ft	5	REF		
52221	202.8 to 205.7 feet	Vertical Change	-.29	5 ft	15	REF		
10135	208.2 to 213.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	24	SF	\$40	\$960
10137	213.0 to 224.1 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	56	SF	\$40	\$2,220
43440	216.0 to 217.0 feet	Vertical Change	-.61	5 ft	5	REF		
10139	224.1 to 226.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	12	SF	\$40	\$480
10141	226.5 to 228.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	8	SF	\$40	\$300
10142	228.0 to 265.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	189	SF	\$120	\$22,620
50885	229.3 to 230.3 feet	Vertical Change	-.31	5 ft	5	REF		
42057	231.2 to 232.2 feet	Vertical Change	-.76	5 ft	5	REF		
48565	238.4 to 239.4 feet	Vertical Change	-.38	5 ft	5	REF		
48279	246.6 to 247.6 feet	Vertical Change	-.39	5 ft	5	REF		
49773	254.3 to 257.3 feet	Vertical Change	-.34	5 ft	15	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221519	ROSE AVE	PINE ST	LARK AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41866	261.8 to 262.8 feet	Vertical Change	-.81	5 ft	5	REF		
TOTAL COST FOR: S side of ROSE AVE Starting at: PINE ST							\$103,360.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority	
S	1908221520	ROSE AVE	LARK AVE	SANTA CRUZ BLVD				TBD	
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
43754	2.6 to 3.6 feet	Vertical Change	-.59	5 ft	5	SF	\$75	\$375	
10148	4.8 to 16.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,260	
45795	14.1 to 15.1 feet	Vertical Change	-.49	5 ft	5	REF			
48280	20.2 to 21.2 feet	Vertical Change	-.39	5 ft	5	REF			
10149	21.2 to 91.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	352	SF	\$120	\$42,240	
45576	25.9 to 26.9 feet	Vertical Change	-.5	5 ft	5	REF			
43913	31.4 to 32.4 feet	Vertical Change	-.58	5 ft	5	REF			
44275	37.8 to 38.8 feet	Vertical Change	-.56	5 ft	5	REF			
52680	47.7 to 48.7 feet	Vertical Change	-.28	5 ft	5	REF			
46449	51.5 to 52.5 feet	Vertical Change	-.46	5 ft	5	REF			
42794	58.8 to 59.8 feet	Vertical Change	-.66	5 ft	5	REF			
52681	64.5 to 65.5 feet	Vertical Change	-.28	5 ft	5	REF			
43441	66.6 to 67.6 feet	Vertical Change	-.61	5 ft	5	REF			
43755	74.1 to 75.1 feet	Vertical Change	-.59	5 ft	5	REF			
43153	81.3 to 82.3 feet	Vertical Change	-.63	5 ft	5	REF			
54057	86.2 to 88.8 feet	Vertical Change	-.25	5 ft	13	REF			
42914	93.6 to 94.6 feet	Vertical Change	-.65	5 ft	5	SF	\$75	\$375	
TOTAL COST FOR:							S	<i>side of ROSE AVE Starting at: LARK AVE</i>	\$50,250.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908221522	ROSE AVE	SANTA CRUZ BLVD	PINE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
47125	1.4 to 2.4 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375	
10156	6.1 to 33.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	137	SF	\$120	\$16,380	
42495	12.5 to 13.5 feet	Vertical Change	-.69	5 ft	5	REF			
42795	18.8 to 19.8 feet	Vertical Change	-.66	5 ft	5	REF			
58423	21.6 to 51.0 feet	Driveway				REF			
46674	24.9 to 27.7 feet	Vertical Change	-.45	5 ft	14	REF			
42309	28.8 to 29.8 feet	Vertical Change	-.71	5 ft	5	REF			
44491	32.1 to 33.1 feet	Vertical Change	-.55	5 ft	5	REF			
47126	36.1 to 37.1 feet	Vertical Change	-.43	5 ft	5	REF			
44097	39.4 to 40.4 feet	Vertical Change	-.57	5 ft	5	REF			
44098	42.9 to 43.9 feet	Vertical Change	-.57	5 ft	5	REF			
43914	46.8 to 47.8 feet	Vertical Change	-.58	5 ft	5	REF			
10159	47.1 to 52.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	26	SF	\$40	\$1,020	
44276	50.0 to 55.3 feet	Vertical Change	-.56	5 ft	27	REF			
10162	55.1 to 102.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	236	SF	\$120	\$28,260	
43915	57.6 to 58.6 feet	Vertical Change	-.58	5 ft	5	REF			
46210	65.7 to 66.7 feet	Vertical Change	-.47	5 ft	5	REF			
46450	81.2 to 82.2 feet	Vertical Change	-.46	5 ft	5	REF			
42242	85.0 to 86.0 feet	Vertical Change	-.72	5 ft	5	REF			
58424	87.2 to 116.3 feet	Driveway				REF			
43756	90.7 to 95.7 feet	Vertical Change	-.59	5 ft	25	REF			
54159	96.4 to 97.4 feet	Vertical Change	.28	5 ft	5	REF			
43916	98.0 to 99.0 feet	Vertical Change	-.58	5 ft	5	REF			
43154	101.7 to 102.7 feet	Vertical Change	-.63	5 ft	5	REF			
43442	105.1 to 106.1 feet	Vertical Change	-.61	5 ft	5	REF			
10168	105.4 to 108.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	17	SF	\$40	\$660	
43014	108.5 to 109.5 feet	Vertical Change	-.64	5 ft	5	REF			
10169	111.3 to 145.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	169	SF	\$40	\$6,760	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221522	ROSE AVE	SANTA CRUZ BLVD	PINE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
42688	112.1 to 113.1 feet	Vertical Change	-.67	5 ft	5	REF		
56924	115.8 to 116.8 feet	Vertical Change	.52	5 ft	5	REF		
53191	117.9 to 118.9 feet	Vertical Change	-.27	5 ft	5	REF		
44713	119.9 to 120.9 feet	Vertical Change	-.54	5 ft	5	REF		
44278	123.0 to 124.0 feet	Vertical Change	-.56	5 ft	5	REF		
47366	130.2 to 131.2 feet	Vertical Change	-.42	5 ft	5	REF		
58425	131.8 to 172.1 feet	Driveway				REF		
48566	139.5 to 140.5 feet	Vertical Change	-.38	5 ft	5	REF		
48567	143.3 to 144.3 feet	Vertical Change	-.38	5 ft	5	REF		
50485	147.4 to 148.4 feet	Vertical Change	-.32	5 ft	5	REF		
48281	151.4 to 152.4 feet	Vertical Change	-.39	5 ft	5	REF		
44714	158.8 to 159.8 feet	Vertical Change	-.54	5 ft	5	REF		
47605	163.0 to 164.0 feet	Vertical Change	-.41	5 ft	5	REF		
44279	167.7 to 171.4 feet	Vertical Change	-.56	5 ft	19	REF		
10172	168.8 to 174.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	28	SF	\$40	\$1,100
56943	170.5 to 171.5 feet	Vertical Change	.54	5 ft	5	REF		
42915	171.6 to 174.8 feet	Vertical Change	-.65	5 ft	16	REF		
10175	174.3 to 191.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	85	SF	\$120	\$10,140
44280	182.4 to 183.4 feet	Vertical Change	-.56	5 ft	5	REF		
50886	192.2 to 193.2 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375
10176	200.8 to 221.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	103	SF	\$120	\$12,300
52222	211.4 to 212.4 feet	Vertical Change	-.29	5 ft	5	REF		
58426	211.9 to 242.9 feet	Driveway				REF		
46900	217.1 to 220.1 feet	Vertical Change	-.44	5 ft	15	REF		
10183	221.3 to 246.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	125	SF	\$40	\$5,000
52223	224.9 to 225.9 feet	Vertical Change	-.29	5 ft	5	REF		
45996	228.3 to 229.3 feet	Vertical Change	-.48	5 ft	5	REF		
48568	231.8 to 232.8 feet	Vertical Change	-.38	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221522	ROSE AVE	SANTA CRUZ BLVD	PINE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47127	235.2 to 236.2 feet	Vertical Change	-.43	5 ft	5	REF		
45997	238.6 to 239.6 feet	Vertical Change	-.48	5 ft	5	REF		
43918	242.8 to 243.8 feet	Vertical Change	-.58	5 ft	5	REF		
10188	246.3 to 264.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	93	SF	\$120	\$11,100
58427	256.1 to 287.1 feet	Driveway				REF		
42098	260.8 to 265.9 feet	Vertical Change	-.75	5 ft	25	REF		
10190	264.8 to 290.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	130	SF	\$40	\$5,180
48282	266.4 to 269.7 feet	Vertical Change	-.39	5 ft	17	REF		
43282	272.1 to 273.1 feet	Vertical Change	-.62	5 ft	5	REF		
43444	275.7 to 276.7 feet	Vertical Change	-.61	5 ft	5	REF		
42796	278.9 to 279.9 feet	Vertical Change	-.66	5 ft	5	REF		
42797	282.2 to 283.2 feet	Vertical Change	-.66	5 ft	5	REF		
44715	285.6 to 286.6 feet	Vertical Change	-.54	5 ft	5	REF		
56983	285.7 to 286.7 feet	Vertical Change	.58	5 ft	5	REF		
42798	286.0 to 291.7 feet	Vertical Change	-.66	5 ft	29	REF		
10197	290.7 to 321.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	156	SF	\$120	\$18,720
44281	294.7 to 295.7 feet	Vertical Change	-.56	5 ft	5	REF		
48569	304.5 to 305.5 feet	Vertical Change	-.38	5 ft	5	REF		
57341	320.3 to 321.3 feet	Vertical Change	.98	5 ft	5	REF		
10201	321.9 to 342.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	101	SF	\$120	\$12,060
45796	324.3 to 325.3 feet	Vertical Change	-.49	5 ft	5	REF		
58428	328.6 to 368.0 feet	Driveway				REF		
44101	331.8 to 337.1 feet	Vertical Change	-.57	5 ft	27	REF		
43613	340.3 to 341.3 feet	Vertical Change	-.6	5 ft	5	REF		
10205	342.0 to 344.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	11	SF	\$40	\$420
44282	344.2 to 345.2 feet	Vertical Change	-.56	5 ft	5	REF		
45090	348.0 to 349.0 feet	Vertical Change	-.52	5 ft	5	REF		
10206	349.2 to 355.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	30	SF	\$40	\$1,200

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221522	ROSE AVE	SANTA CRUZ BLVD	PINE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44283	351.6 to 352.6 feet	Vertical Change	-.56	5 ft	5	REF		
48283	355.4 to 356.4 feet	Vertical Change	-.39	5 ft	5	REF		
10207	359.4 to 392.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	165	SF	\$40	\$6,580
47128	363.2 to 364.2 feet	Vertical Change	-.43	5 ft	5	REF		
46451	367.6 to 370.7 feet	Vertical Change	-.46	5 ft	16	REF		
43445	379.4 to 380.4 feet	Vertical Change	-.61	5 ft	5	REF		
58429	382.4 to 412.5 feet	Driveway				REF		
41682	387.3 to 388.3 feet	Vertical Change	-.91	5 ft	5	REF		
43284	389.2 to 392.2 feet	Vertical Change	-.62	5 ft	15	REF		
10212	392.3 to 398.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	32	SF	\$40	\$1,260
43015	394.7 to 395.7 feet	Vertical Change	-.64	5 ft	5	REF		
42592	398.2 to 399.2 feet	Vertical Change	-.68	5 ft	5	REF		
10216	398.6 to 402.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	19	SF	\$40	\$760
42148	401.5 to 402.5 feet	Vertical Change	-.74	5 ft	5	REF		
42800	405.0 to 406.0 feet	Vertical Change	-.66	5 ft	5	REF		
10217	407.0 to 440.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	169	SF	\$40	\$6,740
42496	408.2 to 409.2 feet	Vertical Change	-.69	5 ft	5	REF		
45578	411.6 to 415.3 feet	Vertical Change	-.5	5 ft	19	REF		
41773	416.2 to 417.2 feet	Vertical Change	-.86	5 ft	5	REF		
46901	423.9 to 424.9 feet	Vertical Change	-.44	5 ft	5	REF		
41949	436.2 to 437.2 feet	Vertical Change	-.79	5 ft	5	REF		
TOTAL COST FOR: N side of ROSE AVE Starting at: SANTA CRUZ BLVD							\$146,390.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221525	PINE ST	ROSE AVE	PARKRIDGE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
10221	0.1 to 154.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	773	SF	\$120	\$92,760
41552	5.1 to 6.1 feet	Vertical Change	-1.02	5 ft	5	REF		
53192	5.1 to 6.1 feet	Vertical Change	-.27	5 ft	5	REF		
42801	11.6 to 12.6 feet	Vertical Change	-.66	5 ft	5	REF		
42916	18.9 to 19.9 feet	Vertical Change	-.65	5 ft	5	REF		
43016	28.5 to 29.5 feet	Vertical Change	-.64	5 ft	5	REF		
51798	38.1 to 39.1 feet	Vertical Change	-.3	5 ft	5	REF		
46211	47.8 to 48.8 feet	Vertical Change	-.47	5 ft	5	REF		
54058	52.9 to 53.9 feet	Vertical Change	-.25	5 ft	5	REF		
46452	66.6 to 67.6 feet	Vertical Change	-.46	5 ft	5	REF		
45290	76.5 to 77.5 feet	Vertical Change	-.51	5 ft	5	REF		
48027	86.0 to 87.0 feet	Vertical Change	-.4	5 ft	5	REF		
45797	105.6 to 106.6 feet	Vertical Change	-.49	5 ft	5	REF		
47129	125.0 to 126.0 feet	Vertical Change	-.43	5 ft	5	REF		
54059	134.5 to 135.5 feet	Vertical Change	-.25	5 ft	5	REF		
54060	144.1 to 145.1 feet	Vertical Change	-.25	5 ft	5	REF		
42594	153.9 to 154.9 feet	Vertical Change	-.68	5 ft	5	REF		
10237	154.7 to 201.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	232	SF	\$120	\$27,840
43017	163.8 to 164.8 feet	Vertical Change	-.64	5 ft	5	REF		
45291	173.7 to 174.7 feet	Vertical Change	-.51	5 ft	5	REF		
42497	183.4 to 184.4 feet	Vertical Change	-.69	5 ft	5	REF		
43155	193.1 to 194.1 feet	Vertical Change	-.63	5 ft	5	REF		
40318	201.0 to 203.8 feet	Running Slope	5.0-6.0%	5 ft	14	REF		
47367	202.6 to 203.6 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375
57426	202.7 to 203.7 feet	Vertical Change	1.21	5 ft	5	SF	\$75	\$375
10239	205.2 to 208.8 feet	Cross Slope (PAR)	10.0-11.0%	5 ft	18	SF	\$120	\$2,160
41519	206.9 to 207.9 feet	Vertical Change	-1.07	5 ft	5	REF		
10241	208.8 to 212.1 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	17	SF	\$120	\$1,980

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221525	PINE ST	ROSE AVE	PARKRIDGE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56984	211.4 to 212.4 feet	Vertical Change	.58	5 ft	5	REF		
44716	212.7 to 213.7 feet	Vertical Change	-.54	5 ft	5	SF	\$75	\$375
10242	215.7 to 219.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160
44904	217.6 to 218.6 feet	Vertical Change	-.53	5 ft	5	REF		
TOTAL COST FOR: E side of PINE ST Starting at: ROSE AVE							\$128,025.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908221527	PINE ST	PARKRIDGE DR	133 PINE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
43446	1.8 to 2.8 feet	Vertical Change	-.61	5 ft	5	SF	\$75	\$375	
10243	6.8 to 34.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	137	SF	\$120	\$16,440	
41418	7.5 to 8.5 feet	Vertical Change	-1.23	5 ft	5	REF			
58430	26.8 to 67.8 feet	Driveway				REF			
42690	28.1 to 29.1 feet	Vertical Change	-.67	5 ft	5	REF			
41426	34.0 to 35.0 feet	Vertical Change	-1.21	5 ft	5	REF			
50887	34.0 to 35.0 feet	Vertical Change	-.31	5 ft	5	REF			
10245	37.0 to 49.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	63	SF	\$40	\$2,500	
10247	49.5 to 55.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	28	SF	\$40	\$1,100	
44284	54.5 to 55.5 feet	Vertical Change	-.56	5 ft	5	REF			
10248	55.0 to 58.0 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	15	SF	\$40	\$600	
45798	57.8 to 58.8 feet	Vertical Change	-.49	5 ft	5	REF			
10249	58.0 to 64.4 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	32	SF	\$40	\$1,280	
10251	64.4 to 67.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	13	SF	\$40	\$540	
43285	68.1 to 71.0 feet	Vertical Change	-.62	5 ft	15	REF			
10252	69.2 to 73.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	23	SF	\$120	\$2,700	
41457	71.9 to 72.9 feet	Vertical Change	-1.14	5 ft	5	REF			
10254	73.7 to 92.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	93	SF	\$120	\$11,160	
44492	80.7 to 81.7 feet	Vertical Change	-.55	5 ft	5	REF			
58431	83.2 to 112.2 feet	Driveway				REF			
53193	86.3 to 91.5 feet	Vertical Change	-.27	5 ft	26	REF			
10258	92.3 to 95.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	18	SF	\$40	\$700	
47368	94.1 to 95.1 feet	Vertical Change	-.42	5 ft	5	REF			
10260	95.8 to 97.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	10	SF	\$40	\$400	
49145	97.6 to 98.6 feet	Vertical Change	-.36	5 ft	5	REF			
10261	104.6 to 108.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	21	SF	\$40	\$840	
53720	108.3 to 109.3 feet	Vertical Change	-.26	5 ft	5	REF			
10263	108.8 to 167.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	293	SF	\$40	\$11,720	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221527	PINE ST	PARKRIDGE DR	133 PINE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
49448	111.6 to 112.6 feet	Vertical Change	-.35	5 ft	5	REF		
52682	140.7 to 141.7 feet	Vertical Change	-.28	5 ft	5	REF		
44493	150.8 to 151.8 feet	Vertical Change	-.55	5 ft	5	REF		
58432	151.1 to 185.2 feet	Driveway				REF		
41840	156.4 to 161.8 feet	Vertical Change	-.82	5 ft	27	REF		
43449	164.4 to 165.4 feet	Vertical Change	-.61	5 ft	5	REF		
10271	167.4 to 175.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	42	SF	\$40	\$1,680
43758	167.7 to 168.7 feet	Vertical Change	-.59	5 ft	5	REF		
43759	171.0 to 172.0 feet	Vertical Change	-.59	5 ft	5	REF		
43450	174.7 to 175.7 feet	Vertical Change	-.61	5 ft	5	REF		
10273	175.8 to 193.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	88	SF	\$40	\$3,520
43287	178.3 to 179.3 feet	Vertical Change	-.62	5 ft	5	REF		
56944	182.1 to 183.1 feet	Vertical Change	.54	5 ft	5	REF		
45799	182.2 to 187.4 feet	Vertical Change	-.49	5 ft	26	REF		
43018	189.9 to 190.9 feet	Vertical Change	-.64	5 ft	5	REF		
58433	191.3 to 219.2 feet	Driveway				REF		
10277	194.8 to 203.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	45	SF	\$40	\$1,780
43452	197.4 to 200.5 feet	Vertical Change	-.61	5 ft	16	REF		
43920	203.0 to 204.0 feet	Vertical Change	-.58	5 ft	5	REF		
43288	206.8 to 207.8 feet	Vertical Change	-.62	5 ft	5	REF		
43289	210.6 to 211.6 feet	Vertical Change	-.62	5 ft	5	REF		
45292	214.0 to 215.0 feet	Vertical Change	-.51	5 ft	5	REF		
10278	216.4 to 217.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$260
42311	218.1 to 221.6 feet	Vertical Change	-.71	5 ft	18	REF		
10279	218.5 to 247.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	146	SF	\$40	\$5,820
56945	220.7 to 221.7 feet	Vertical Change	.54	5 ft	5	REF		
42691	220.9 to 224.1 feet	Vertical Change	-.67	5 ft	16	REF		
50888	225.0 to 226.0 feet	Vertical Change	-.31	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221527	PINE ST	PARKRIDGE DR	133 PINE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
50094	228.5 to 229.5 feet	Vertical Change	-.33	5 ft	5	REF		
52683	235.2 to 236.2 feet	Vertical Change	-.28	5 ft	5	REF		
10284	247.6 to 296.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	245	SF	\$120	\$29,400
50095	255.8 to 256.8 feet	Vertical Change	-.33	5 ft	5	REF		
52684	263.1 to 264.1 feet	Vertical Change	-.28	5 ft	5	REF		
54061	269.8 to 272.6 feet	Vertical Change	-.25	5 ft	14	REF		
58434	274.3 to 306.5 feet	Driveway				REF		
41867	284.3 to 285.3 feet	Vertical Change	-.81	5 ft	5	REF		
57246	284.3 to 285.3 feet	Vertical Change	.79	5 ft	5	REF		
49449	292.0 to 293.0 feet	Vertical Change	-.35	5 ft	5	REF		
44718	296.1 to 297.1 feet	Vertical Change	-.54	5 ft	5	REF		
46000	300.1 to 301.1 feet	Vertical Change	-.48	5 ft	5	REF		
10293	301.9 to 315.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	66	SF	\$40	\$2,640
46453	304.4 to 305.4 feet	Vertical Change	-.46	5 ft	5	REF		
45581	307.5 to 310.5 feet	Vertical Change	-.5	5 ft	15	REF		
58435	310.0 to 338.3 feet	Driveway				REF		
48284	313.5 to 316.4 feet	Vertical Change	-.39	5 ft	14	REF		
10297	315.1 to 324.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	46	SF	\$40	\$1,840
45091	322.7 to 323.7 feet	Vertical Change	-.52	5 ft	5	REF		
10301	324.3 to 357.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	165	SF	\$40	\$6,580
43921	326.7 to 327.7 feet	Vertical Change	-.58	5 ft	5	REF		
46454	331.0 to 332.0 feet	Vertical Change	-.46	5 ft	5	REF		
46213	335.5 to 343.6 feet	Vertical Change	-.47	5 ft	41	REF		
47130	346.2 to 347.2 feet	Vertical Change	-.43	5 ft	5	REF		
46675	349.8 to 366.2 feet	Vertical Change	-.45	5 ft	82	REF		
10302	364.6 to 434.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	351	SF	\$120	\$42,060
53723	370.5 to 371.5 feet	Vertical Change	-.26	5 ft	5	REF		
44906	372.3 to 373.3 feet	Vertical Change	-.53	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221527	PINE ST	PARKRIDGE DR	133 PINE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44102	379.3 to 380.3 feet	Vertical Change	-.57	5 ft	5	REF		
44285	386.5 to 387.5 feet	Vertical Change	-.56	5 ft	5	REF		
52224	388.4 to 394.6 feet	Vertical Change	-.29	5 ft	31	REF		
46457	400.7 to 410.1 feet	Vertical Change	-.46	5 ft	47	REF		
58436	407.3 to 434.3 feet	Driveway				REF		
41609	410.8 to 411.8 feet	Vertical Change	-.97	5 ft	5	REF		
45800	412.7 to 417.4 feet	Vertical Change	-.49	5 ft	24	REF		
44494	421.3 to 422.3 feet	Vertical Change	-.55	5 ft	5	REF		
44495	426.0 to 427.0 feet	Vertical Change	-.55	5 ft	5	REF		
45093	429.6 to 430.6 feet	Vertical Change	-.52	5 ft	5	REF		
45294	433.2 to 434.2 feet	Vertical Change	-.51	5 ft	5	REF		
45582	437.4 to 440.9 feet	Vertical Change	-.5	5 ft	18	SF	\$75	\$1,313
10309	440.2 to 445.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060
42019	442.3 to 443.3 feet	Vertical Change	-.77	5 ft	5	REF		
58437	444.0 to 468.3 feet	Driveway				REF		
46214	444.6 to 447.6 feet	Vertical Change	-.47	5 ft	15	REF		
10310	450.7 to 456.6 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	30	SF	\$40	\$1,180
48287	451.2 to 452.2 feet	Vertical Change	-.39	5 ft	5	REF		
46676	457.2 to 458.2 feet	Vertical Change	-.45	5 ft	5	REF		
10313	458.8 to 464.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	28	SF	\$40	\$1,120
40319	464.0 to 465.6 feet	Running Slope	7.0-8.0%	5 ft	8	REF		
46677	468.2 to 475.4 feet	Vertical Change	-.45	5 ft	36	REF		
10316	468.5 to 559.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	456	SF	\$40	\$18,240
51800	478.6 to 481.7 feet	Vertical Change	-.3	5 ft	16	REF		
44496	484.9 to 485.9 feet	Vertical Change	-.55	5 ft	5	REF		
53727	487.4 to 505.5 feet	Vertical Change	-.26	5 ft	91	REF		
53728	509.3 to 510.3 feet	Vertical Change	-.26	5 ft	5	REF		
43454	513.9 to 514.9 feet	Vertical Change	-.61	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908221527	PINE ST	PARKRIDGE DR	133 PINE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
50098	515.7 to 522.2 feet	Vertical Change	-.33	5 ft	33	REF		
52690	524.6 to 525.6 feet	Vertical Change	-.28	5 ft	5	REF		
46902	528.3 to 546.5 feet	Vertical Change	-.44	5 ft	91	REF		
58438	534.0 to 566.1 feet	Driveway				REF		
44907	549.8 to 550.8 feet	Vertical Change	-.53	5 ft	5	REF		
44103	554.0 to 555.0 feet	Vertical Change	-.57	5 ft	5	REF		
45094	558.3 to 559.3 feet	Vertical Change	-.52	5 ft	5	REF		
10327	559.7 to 566.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	32	SF	\$40	\$1,280
43922	565.4 to 566.4 feet	Vertical Change	-.58	5 ft	5	REF		
TOTAL COST FOR: W side of PINE ST Starting at: PARKRIDGE DR							\$172,127.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W/S	1908221531	PINE ST	133 PINE ST	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
10330	0.0 to 1.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720	
58439	0.0 to 15.4 feet	Driveway				REF			
50100	2.4 to 3.4 feet	Vertical Change	-33	5 ft	5	REF			
50491	6.2 to 7.2 feet	Vertical Change	-32	5 ft	5	REF			
51802	10.2 to 11.2 feet	Vertical Change	-3	5 ft	5	REF			
46903	14.3 to 15.3 feet	Vertical Change	-44	5 ft	5	REF			
10331	18.3 to 96.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	393	SF	\$120	\$47,100	
53729	18.7 to 29.1 feet	Vertical Change	-26	5 ft	52	REF			
46679	32.8 to 36.1 feet	Vertical Change	-45	5 ft	17	REF			
50101	39.7 to 40.7 feet	Vertical Change	-33	5 ft	5	REF			
49451	46.8 to 47.8 feet	Vertical Change	-35	5 ft	5	REF			
47607	53.7 to 54.7 feet	Vertical Change	-41	5 ft	5	REF			
47370	60.5 to 64.0 feet	Vertical Change	-42	5 ft	18	REF			
46215	74.5 to 75.5 feet	Vertical Change	-47	5 ft	5	REF			
52691	79.2 to 85.1 feet	Vertical Change	-28	5 ft	30	REF			
58440	88.6 to 117.3 feet	Driveway				REF			
50492	89.6 to 93.1 feet	Vertical Change	-32	5 ft	18	REF			
43923	94.2 to 97.2 feet	Vertical Change	-58	5 ft	15	REF			
10336	100.9 to 114.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	67	SF	\$40	\$2,660	
52226	106.8 to 107.8 feet	Vertical Change	-29	5 ft	5	REF			
10338	114.2 to 115.2 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200	
42802	117.5 to 118.5 feet	Vertical Change	-66	5 ft	5	SF	\$75	\$375	
10339	118.8 to 121.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740	
48028	119.6 to 120.6 feet	Vertical Change	-4	5 ft	5	REF			
58441	121.3 to 147.5 feet	Driveway				REF			
41356	121.7 to 122.7 feet	Vertical Change	-1.38	5 ft	5	REF			
44104	123.9 to 126.9 feet	Vertical Change	-57	5 ft	15	REF			
10340	129.1 to 144.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	77	SF	\$40	\$3,080	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W/S	1908221531	PINE ST	133 PINE ST	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
42498	136.8 to 137.8 feet	Vertical Change	-.69	5 ft	5	REF			
44286	147.8 to 150.8 feet	Vertical Change	-.56	5 ft	15	REF			
10343	148.8 to 193.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	225	SF	\$120	\$27,000	
41284	151.8 to 152.8 feet	Vertical Change	-1.64	5 ft	5	REF			
44908	159.2 to 160.2 feet	Vertical Change	-.53	5 ft	5	REF			
43761	166.5 to 167.5 feet	Vertical Change	-.59	5 ft	5	REF			
42312	173.7 to 174.7 feet	Vertical Change	-.71	5 ft	5	REF			
54063	178.4 to 181.9 feet	Vertical Change	-.25	5 ft	18	REF			
43455	188.0 to 189.0 feet	Vertical Change	-.61	5 ft	5	REF			
53732	190.2 to 195.9 feet	Vertical Change	-.26	5 ft	29	REF			
10346	196.8 to 211.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	72	SF	\$120	\$8,640	
47608	202.2 to 203.2 feet	Vertical Change	-.41	5 ft	5	REF			
53734	206.9 to 210.3 feet	Vertical Change	-.26	5 ft	17	REF			
10347	213.3 to 224.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,660	
50890	213.5 to 218.9 feet	Vertical Change	-.31	5 ft	27	REF			
58442	216.2 to 245.6 feet	Driveway				REF			
42313	220.1 to 221.1 feet	Vertical Change	-.71	5 ft	5	REF			
46904	222.1 to 225.1 feet	Vertical Change	-.44	5 ft	15	REF			
10348	228.8 to 242.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	70	SF	\$40	\$2,780	
42499	235.1 to 236.1 feet	Vertical Change	-.69	5 ft	5	REF			
43762	246.1 to 247.1 feet	Vertical Change	-.59	5 ft	5	REF			
10349	246.9 to 259.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,800	
49452	249.9 to 250.9 feet	Vertical Change	-.35	5 ft	5	REF			
58443	252.2 to 283.7 feet	Driveway				REF			
54064	254.4 to 259.9 feet	Vertical Change	-.25	5 ft	27	REF			
10351	259.9 to 262.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	13	SF	\$40	\$520	
10353	262.5 to 264.1 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	8	SF	\$40	\$320	
10354	264.1 to 267.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	18	SF	\$40	\$720	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W/S	1908221531	PINE ST	133 PINE ST	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
45802	267.0 to 268.0 feet	Vertical Change	-49	5 ft	5	REF			
10356	267.7 to 277.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	47	SF	\$40	\$1,860	
46217	271.1 to 272.1 feet	Vertical Change	-47	5 ft	5	REF			
45095	275.3 to 276.3 feet	Vertical Change	-52	5 ft	5	REF			
10358	277.0 to 281.1 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	21	SF	\$40	\$820	
10360	281.1 to 282.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200	
10361	282.1 to 283.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$280	
52227	283.0 to 286.0 feet	Vertical Change	-29	5 ft	15	REF			
46905	292.3 to 293.3 feet	Vertical Change	-44	5 ft	5	LF	\$75	\$375	
46218	297.7 to 298.7 feet	Vertical Change	-47	5 ft	5	LF	\$75	\$375	
47610	303.2 to 304.2 feet	Vertical Change	-41	5 ft	5	LF	\$75	\$375	
54065	308.7 to 311.6 feet	Vertical Change	-25	5 ft	15	LF	\$75	\$1,088	
50102	319.2 to 320.2 feet	Vertical Change	-33	5 ft	5	REF			
10362	319.8 to 322.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680	
48859	326.3 to 327.3 feet	Vertical Change	-37	5 ft	5	LF	\$75	\$375	
43158	331.7 to 332.7 feet	Vertical Change	-63	5 ft	5	SF	\$75	\$375	
46219	337.1 to 338.1 feet	Vertical Change	-47	5 ft	5	LF	\$75	\$375	
58444	340.5 to 368.9 feet	Driveway				REF			
10363	342.2 to 350.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	39	SF	\$40	\$1,560	
47371	342.6 to 349.6 feet	Vertical Change	-42	5 ft	35	REF			
10365	350.0 to 352.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	12	SF	\$40	\$460	
10367	352.3 to 361.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	44	SF	\$40	\$1,740	
43456	359.0 to 360.0 feet	Vertical Change	-61	5 ft	5	REF			
10369	361.0 to 367.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	33	SF	\$40	\$1,320	
10372	370.3 to 373.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	14	SF	\$120	\$1,620	
48289	370.6 to 371.6 feet	Vertical Change	-39	5 ft	5	REF			
42595	372.9 to 373.9 feet	Vertical Change	-68	5 ft	5	REF			
10373	373.0 to 388.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	77	SF	\$120	\$9,240	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W/S	1908221531	PINE ST	133 PINE ST	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
52228	377.8 to 386.1 feet	Vertical Change	-29	5 ft	42	REF			
58445	381.6 to 410.1 feet	Driveway				REF			
43019	387.5 to 388.5 feet	Vertical Change	-.64	5 ft	5	REF			
10376	392.1 to 407.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	78	SF	\$40	\$3,120	
48290	399.7 to 400.7 feet	Vertical Change	-.39	5 ft	5	REF			
10380	411.2 to 429.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	92	SF	\$120	\$11,040	
42149	413.4 to 414.4 feet	Vertical Change	-.74	5 ft	5	REF			
50494	421.5 to 422.5 feet	Vertical Change	-.32	5 ft	5	REF			
48570	429.4 to 430.4 feet	Vertical Change	-.38	5 ft	5	REF			
51805	433.5 to 434.5 feet	Vertical Change	-.3	5 ft	5	REF			
10383	434.2 to 435.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600	
51806	437.5 to 438.5 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
10384	440.0 to 451.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,720	
47611	441.4 to 448.2 feet	Vertical Change	-.41	5 ft	34	REF			
42058	451.2 to 452.2 feet	Vertical Change	-.76	5 ft	5	REF			
43020	455.2 to 456.2 feet	Vertical Change	-.64	5 ft	5	SF	\$75	\$375	
41751	459.2 to 460.2 feet	Vertical Change	-.87	5 ft	5	SF	\$75	\$375	
48291	463.2 to 472.2 feet	Vertical Change	-.39	5 ft	45	LF	\$75	\$3,375	
10385	467.4 to 479.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,200	
41391	473.2 to 474.2 feet	Vertical Change	-1.29	5 ft	5	REF			
53739	473.2 to 476.8 feet	Vertical Change	-.26	5 ft	18	REF			
58446	474.5 to 497.7 feet	Driveway				REF			
44499	479.6 to 480.6 feet	Vertical Change	-.55	5 ft	5	REF			
10389	482.5 to 491.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	44	SF	\$40	\$1,740	
42020	489.5 to 490.5 feet	Vertical Change	-.77	5 ft	5	REF			
10391	491.2 to 497.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	31	SF	\$40	\$1,220	
10393	497.3 to 499.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	10	SF	\$40	\$400	
41774	499.0 to 500.0 feet	Vertical Change	-.86	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W/S	1908221531	PINE ST	133 PINE ST	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
10395	499.3 to 516.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	84	SF	\$120	\$10,080
48292	501.8 to 502.8 feet	Vertical Change	-.39	5 ft	5	REF		
43457	507.0 to 508.0 feet	Vertical Change	-.61	5 ft	5	REF		
58447	507.9 to 539.0 feet	Driveway				REF		
50495	514.4 to 517.5 feet	Vertical Change	-.32	5 ft	16	REF		
10398	516.1 to 518.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	13	SF	\$40	\$520
10400	520.1 to 523.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	16	SF	\$40	\$640
10401	523.3 to 533.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	52	SF	\$40	\$2,080
47372	528.8 to 529.8 feet	Vertical Change	-.42	5 ft	5	REF		
10404	533.7 to 538.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	25	SF	\$40	\$1,020
10407	541.0 to 555.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	72	SF	\$120	\$8,640
45096	541.6 to 544.7 feet	Vertical Change	-.52	5 ft	16	REF		
43614	548.8 to 549.8 feet	Vertical Change	-.6	5 ft	5	REF		
50496	551.6 to 552.6 feet	Vertical Change	-.32	5 ft	5	REF		
53740	554.7 to 555.7 feet	Vertical Change	-.26	5 ft	5	REF		
10410	555.4 to 574.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	95	SF	\$120	\$11,400
41841	557.8 to 558.8 feet	Vertical Change	-.82	5 ft	5	REF		
54068	561.0 to 562.0 feet	Vertical Change	-.25	5 ft	5	REF		
42404	566.9 to 567.9 feet	Vertical Change	-.7	5 ft	5	REF		
58448	569.4 to 596.8 feet	Driveway				REF		
43764	572.2 to 575.5 feet	Vertical Change	-.59	5 ft	16	REF		
10411	579.3 to 588.3 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	45	SF	\$40	\$1,800
42099	587.1 to 588.1 feet	Vertical Change	-.75	5 ft	5	REF		
10413	588.3 to 593.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	28	SF	\$40	\$1,100
40320	593.6 to 595.8 feet	Running Slope	6.0-7.0%	5 ft	11	REF		
10415	593.8 to 594.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	6	SF	\$40	\$220
10416	598.1 to 637.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	196	SF	\$120	\$23,520
48571	598.5 to 601.7 feet	Vertical Change	-.38	5 ft	16	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W/S	1908221531	PINE ST	133 PINE ST	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
42803	602.7 to 606.3 feet	Vertical Change	-.66	5 ft	18	REF			
51807	610.6 to 611.6 feet	Vertical Change	-.3	5 ft	5	REF			
44105	613.2 to 614.2 feet	Vertical Change	-.57	5 ft	5	REF			
50891	618.1 to 626.3 feet	Vertical Change	-.31	5 ft	41	REF			
58449	625.0 to 651.5 feet	Driveway				REF			
41906	627.7 to 628.7 feet	Vertical Change	-.8	5 ft	5	REF			
45803	629.8 to 630.8 feet	Vertical Change	-.49	5 ft	5	REF			
48861	641.5 to 642.5 feet	Vertical Change	-.37	5 ft	5	REF			
53741	645.7 to 646.7 feet	Vertical Change	-.26	5 ft	5	REF			
10419	647.5 to 662.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	74	SF	\$40	\$2,940	
46906	652.7 to 655.8 feet	Vertical Change	-.44	5 ft	15	REF			
58450	657.3 to 680.3 feet	Driveway				REF			
10424	665.5 to 679.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	68	SF	\$40	\$2,700	
40321	678.0 to 679.0 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
52695	685.0 to 686.0 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
10426	686.7 to 688.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
52229	695.6 to 696.6 feet	Vertical Change	-.29	5 ft	5	REF			
10427	695.7 to 727.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	157	SF	\$120	\$18,840	
49147	701.4 to 702.4 feet	Vertical Change	-.36	5 ft	5	REF			
54069	715.1 to 716.1 feet	Vertical Change	-.25	5 ft	5	REF			
52230	722.7 to 723.7 feet	Vertical Change	-.29	5 ft	5	REF			
50892	731.0 to 732.0 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
10431	733.6 to 748.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,760	
54070	737.2 to 742.3 feet	Vertical Change	-.25	5 ft	26	REF			
50497	745.3 to 746.3 feet	Vertical Change	-.32	5 ft	5	REF			
58451	749.2 to 775.7 feet	Driveway				REF			
10432	752.5 to 754.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	12	SF	\$40	\$480	
49774	753.4 to 756.4 feet	Vertical Change	-.34	5 ft	15	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W/S	1908221531	PINE ST	133 PINE ST	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40322	755.6 to 756.8 feet	Running Slope	7.0-8.0%	5 ft	6	REF		
10433	759.1 to 773.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	71	SF	\$40	\$2,840
52231	776.7 to 779.8 feet	Vertical Change	-29	5 ft	16	REF		
10434	777.0 to 778.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,020
10435	778.7 to 784.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,720
58452	778.7 to 806.2 feet	Driveway				REF		
47373	782.9 to 786.1 feet	Vertical Change	-42	5 ft	16	REF		
10436	789.8 to 803.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	70	SF	\$40	\$2,800
46223	796.2 to 797.2 feet	Vertical Change	-47	5 ft	5	REF		
47374	807.1 to 810.2 feet	Vertical Change	-42	5 ft	16	REF		
10438	807.2 to 808.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$720
10439	808.4 to 836.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	143	SF	\$120	\$17,100
49776	813.1 to 814.1 feet	Vertical Change	-34	5 ft	5	REF		
48293	839.5 to 840.5 feet	Vertical Change	-39	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: W/S side of PINE ST Starting at: 133 PINE ST							\$296,117.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority			
W	1908221532	SANTA CRUZ BLVD	PINE ST	ENGLEWOOD AVE				TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
10441	0.0 to 12.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	64	SF	\$120	\$7,620			
50498	5.9 to 6.9 feet	Vertical Change	-.32	5 ft	5	REF					
10443	12.7 to 90.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	387	SF	\$120	\$46,380			
47613	43.6 to 44.6 feet	Vertical Change	-.41	5 ft	5	REF					
50104	77.1 to 78.1 feet	Vertical Change	-.33	5 ft	5	REF					
50893	88.4 to 89.4 feet	Vertical Change	-.31	5 ft	5	REF					
10446	94.1 to 110.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	82	SF	\$120	\$9,840			
10449	125.8 to 142.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	84	SF	\$120	\$10,140			
45804	131.7 to 132.7 feet	Vertical Change	-.49	5 ft	5	REF					
48862	154.1 to 155.1 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375			
50894	164.8 to 165.8 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375			
10451	172.4 to 179.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,200			
48863	175.3 to 176.3 feet	Vertical Change	-.37	5 ft	5	REF					
10452	184.1 to 191.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,200			
TOTAL COST FOR: W							<i>side of</i>	SANTA CRUZ BLVD	<i>Starting at:</i>	PINE ST	\$83,130.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908221535	ENGLEWOOD AVE	SANTA CRUZ BLVD	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
10454	1.3 to 6.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000	
10455	9.5 to 38.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	146	SF	\$120	\$17,520	
50105	10.4 to 11.4 feet	Vertical Change	-.33	5 ft	5	REF			
46680	14.6 to 32.3 feet	Vertical Change	-.45	5 ft	88	REF			
58453	24.9 to 52.8 feet	Driveway				REF			
43021	36.8 to 37.8 feet	Vertical Change	-.64	5 ft	5	REF			
42917	42.5 to 43.5 feet	Vertical Change	-.65	5 ft	5	REF			
44909	47.9 to 48.9 feet	Vertical Change	-.53	5 ft	5	REF			
10460	49.9 to 54.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	21	SF	\$40	\$840	
46004	53.4 to 54.4 feet	Vertical Change	-.48	5 ft	5	REF			
58454	56.6 to 81.5 feet	Driveway				REF			
51809	57.7 to 58.7 feet	Vertical Change	-.3	5 ft	5	REF			
46005	61.8 to 62.8 feet	Vertical Change	-.48	5 ft	5	REF			
10461	65.9 to 67.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240	
46908	67.4 to 68.4 feet	Vertical Change	-.44	5 ft	5	REF			
46681	72.8 to 73.8 feet	Vertical Change	-.45	5 ft	5	REF			
45805	78.5 to 79.5 feet	Vertical Change	-.49	5 ft	5	REF			
41775	84.4 to 85.4 feet	Vertical Change	-.86	5 ft	5	REF			
10462	84.7 to 164.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	400	SF	\$120	\$48,000	
46006	86.7 to 87.7 feet	Vertical Change	-.48	5 ft	5	REF			
50500	91.0 to 98.6 feet	Vertical Change	-.32	5 ft	38	REF			
54073	102.1 to 107.4 feet	Vertical Change	-.25	5 ft	27	REF			
52697	110.5 to 111.5 feet	Vertical Change	-.28	5 ft	5	REF			
45806	114.6 to 134.6 feet	Vertical Change	-.49	5 ft	100	REF			
50896	137.8 to 141.0 feet	Vertical Change	-.31	5 ft	16	REF			
52698	144.1 to 149.0 feet	Vertical Change	-.28	5 ft	25	REF			
47615	151.9 to 152.9 feet	Vertical Change	-.41	5 ft	5	REF			
58455	153.1 to 178.7 feet	Driveway				REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908221535	ENGLEWOOD AVE	SANTA CRUZ BLVD	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
46225	156.2 to 157.2 feet	Vertical Change	-.47	5 ft	5	REF			
46007	159.5 to 160.5 feet	Vertical Change	-.48	5 ft	5	REF			
46682	163.6 to 164.6 feet	Vertical Change	-.45	5 ft	5	REF			
46008	167.7 to 168.7 feet	Vertical Change	-.48	5 ft	5	REF			
10472	169.0 to 181.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	62	SF	\$40	\$2,460	
49780	171.8 to 172.8 feet	Vertical Change	-.34	5 ft	5	REF			
45585	176.2 to 177.2 feet	Vertical Change	-.5	5 ft	5	REF			
43458	181.9 to 188.4 feet	Vertical Change	-.61	5 ft	33	SF	\$75	\$2,438	
58456	182.9 to 211.0 feet	Driveway				REF			
10475	184.8 to 195.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	54	SF	\$40	\$2,140	
43459	190.9 to 191.9 feet	Vertical Change	-.61	5 ft	5	REF			
45097	194.8 to 195.8 feet	Vertical Change	-.52	5 ft	5	REF			
10479	198.4 to 200.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	10	SF	\$40	\$380	
46909	198.6 to 199.6 feet	Vertical Change	-.44	5 ft	5	REF			
44910	203.1 to 204.1 feet	Vertical Change	-.53	5 ft	5	REF			
45586	207.8 to 208.8 feet	Vertical Change	-.5	5 ft	5	REF			
46460	212.8 to 215.7 feet	Vertical Change	-.46	5 ft	15	LF	\$75	\$1,088	
10480	218.0 to 237.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	96	SF	\$120	\$11,460	
44287	221.4 to 222.4 feet	Vertical Change	-.56	5 ft	5	REF			
53199	228.1 to 233.6 feet	Vertical Change	-.27	5 ft	28	REF			
46683	238.8 to 246.0 feet	Vertical Change	-.45	5 ft	36	LF	\$75	\$2,700	
10483	248.8 to 275.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	135	SF	\$120	\$16,140	
51810	255.3 to 256.3 feet	Vertical Change	-.3	5 ft	5	REF			
44106	257.2 to 258.2 feet	Vertical Change	-.57	5 ft	5	REF			
51811	259.4 to 286.1 feet	Vertical Change	-.3	5 ft	134	REF			
58457	275.8 to 305.8 feet	Driveway				REF			
10486	287.0 to 303.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	83	SF	\$40	\$3,320	
44502	289.6 to 290.6 feet	Vertical Change	-.55	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908221535	ENGLEWOOD AVE	SANTA CRUZ BLVD	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44107	294.1 to 295.1 feet	Vertical Change	-.57	5 ft	5	REF		
43766	298.0 to 299.0 feet	Vertical Change	-.59	5 ft	5	REF		
45298	302.0 to 309.2 feet	Vertical Change	-.51	5 ft	36	REF		
58458	308.6 to 337.7 feet	Driveway				REF		
41278	310.1 to 311.1 feet	Vertical Change	-1.66	5 ft	5	REF		
46462	311.8 to 314.5 feet	Vertical Change	-.46	5 ft	14	REF		
10487	312.4 to 315.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	13	SF	\$40	\$520
10489	315.0 to 332.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	87	SF	\$40	\$3,460
44504	317.4 to 318.4 feet	Vertical Change	-.55	5 ft	5	REF		
44911	321.5 to 322.5 feet	Vertical Change	-.53	5 ft	5	REF		
43616	325.4 to 326.4 feet	Vertical Change	-.6	5 ft	5	REF		
46463	330.0 to 331.0 feet	Vertical Change	-.46	5 ft	5	REF		
10491	332.3 to 369.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	187	SF	\$40	\$7,480
45299	334.6 to 335.6 feet	Vertical Change	-.51	5 ft	5	REF		
44108	339.0 to 340.0 feet	Vertical Change	-.57	5 ft	5	REF		
41265	341.3 to 342.3 feet	Vertical Change	-1.74	5 ft	5	REF		
52234	343.3 to 346.3 feet	Vertical Change	-.29	5 ft	15	REF		
52235	351.0 to 356.0 feet	Vertical Change	-.29	5 ft	25	REF		
43617	357.3 to 358.3 feet	Vertical Change	-.6	5 ft	5	REF		
49782	359.4 to 366.3 feet	Vertical Change	-.34	5 ft	35	REF		
49784	369.3 to 370.3 feet	Vertical Change	-.34	5 ft	5	REF		
TOTAL COST FOR: N side of ENGLEWOOD AVE Starting at: SANTA CRUZ BLVD							\$123,185.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221537	ENGLEWOOD AVE	SIDEWALK BEGINS	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58459	0.0 to 22.4 feet	Driveway				REF		
50110	0.3 to 1.3 feet	Vertical Change	-0.33	5 ft	5	REF		
10493	3.4 to 5.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	10	SF	\$40	\$400
10495	5.4 to 19.4 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	70	SF	\$40	\$2,800
42196	11.2 to 12.2 feet	Vertical Change	-0.73	5 ft	5	REF		
42315	35.1 to 36.1 feet	Vertical Change	-0.71	5 ft	5	SF	\$75	\$375
58460	41.8 to 68.6 feet	Driveway				REF		
42316	47.9 to 48.9 feet	Vertical Change	-0.71	5 ft	5	REF		
10496	51.8 to 66.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	74	SF	\$40	\$2,960
44505	58.9 to 59.9 feet	Vertical Change	-0.55	5 ft	5	REF		
40323	65.3 to 67.6 feet	Running Slope	5.0-6.0%	5 ft	11	REF		
42694	69.9 to 70.9 feet	Vertical Change	-0.67	5 ft	5	SF	\$75	\$375
42918	82.4 to 83.4 feet	Vertical Change	-0.65	5 ft	5	SF	\$75	\$375
58461	86.3 to 117.9 feet	Driveway				REF		
10500	88.2 to 92.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	23	SF	\$40	\$920
43767	94.8 to 95.8 feet	Vertical Change	-0.59	5 ft	5	REF		
10501	97.0 to 113.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	80	SF	\$40	\$3,200
43768	106.2 to 107.2 feet	Vertical Change	-0.59	5 ft	5	REF		
10505	113.0 to 117.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	22	SF	\$40	\$880
10508	117.4 to 163.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	232	SF	\$40	\$9,280
46226	117.8 to 118.8 feet	Vertical Change	-0.47	5 ft	5	REF		
52236	121.7 to 130.7 feet	Vertical Change	-0.29	5 ft	45	REF		
43927	133.8 to 134.8 feet	Vertical Change	-0.58	5 ft	5	REF		
52238	135.6 to 145.5 feet	Vertical Change	-0.29	5 ft	50	REF		
50903	149.0 to 150.0 feet	Vertical Change	-0.31	5 ft	5	REF		
58462	150.1 to 179.8 feet	Driveway				REF		
41752	153.6 to 154.6 feet	Vertical Change	-0.87	5 ft	5	REF		
44506	153.6 to 154.6 feet	Vertical Change	-0.55	5 ft	5	REF		
56933	153.7 to 154.7 feet	Vertical Change	0.53	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908221537	ENGLEWOOD AVE	SIDEWALK BEGINS	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
44507	155.6 to 158.6 feet	Vertical Change	-.55	5 ft	15	REF			
10513	176.6 to 187.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	53	SF	\$40	\$2,120	
44914	180.3 to 183.5 feet	Vertical Change	-.53	5 ft	16	REF			
58463	182.8 to 207.0 feet	Driveway				REF			
41654	184.5 to 185.5 feet	Vertical Change	-.93	5 ft	5	REF			
44915	186.2 to 192.5 feet	Vertical Change	-.53	5 ft	32	REF			
10515	187.2 to 191.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	20	SF	\$40	\$800	
10517	191.2 to 192.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$280	
45588	195.9 to 196.9 feet	Vertical Change	-.5	5 ft	5	REF			
41789	200.0 to 201.0 feet	Vertical Change	-.85	5 ft	5	REF			
45589	204.2 to 205.2 feet	Vertical Change	-.5	5 ft	5	REF			
42150	208.5 to 209.5 feet	Vertical Change	-.74	5 ft	5	SF	\$75	\$375	
10518	210.9 to 239.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	141	SF	\$120	\$16,860	
45300	211.7 to 215.1 feet	Vertical Change	-.51	5 ft	17	REF			
44110	218.6 to 244.9 feet	Vertical Change	-.57	5 ft	132	REF			
10522	241.5 to 243.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900	
10523	245.9 to 257.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,080	
45811	247.5 to 248.5 feet	Vertical Change	-.49	5 ft	5	REF			
49789	253.0 to 275.3 feet	Vertical Change	-.34	5 ft	112	REF			
10525	265.6 to 267.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960	
10526	270.6 to 288.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	88	SF	\$120	\$10,560	
58464	275.2 to 306.6 feet	Driveway				REF			
43292	279.4 to 284.6 feet	Vertical Change	-.62	5 ft	26	REF			
56917	283.9 to 284.9 feet	Vertical Change	.51	5 ft	5	REF			
43928	289.5 to 290.5 feet	Vertical Change	-.58	5 ft	5	REF			
43160	295.2 to 296.2 feet	Vertical Change	-.63	5 ft	5	REF			
44111	300.8 to 301.8 feet	Vertical Change	-.57	5 ft	5	REF			
10527	302.3 to 324.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	110	SF	\$40	\$4,400	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221537	ENGLEWOOD AVE	SIDEWALK BEGINS	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44289	306.6 to 309.6 feet	Vertical Change	-.56	5 ft	15	REF		
58465	309.0 to 336.5 feet	Driveway				REF		
43929	312.6 to 316.8 feet	Vertical Change	-.58	5 ft	21	REF		
44725	320.4 to 321.4 feet	Vertical Change	-.54	5 ft	5	REF		
42500	325.8 to 326.8 feet	Vertical Change	-.69	5 ft	5	REF		
43930	331.8 to 332.8 feet	Vertical Change	-.58	5 ft	5	REF		
10532	332.7 to 366.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	170	SF	\$40	\$6,800
52700	336.8 to 337.8 feet	Vertical Change	-.28	5 ft	5	REF		
43770	337.3 to 340.5 feet	Vertical Change	-.59	5 ft	16	REF		
54074	341.6 to 348.9 feet	Vertical Change	-.25	5 ft	37	REF		
44726	349.9 to 357.6 feet	Vertical Change	-.54	5 ft	39	REF		
52701	358.8 to 361.9 feet	Vertical Change	-.28	5 ft	16	REF		
TOTAL COST FOR:		S	<i>side of</i> ENGLEWOOD AVE	Starting at: SIDEWALK BEGINS				\$72,700.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority	
W	1908221538	SANTA CRUZ BLVD	ENGLEWOOD AVE	WASHINGTON RD				TBD	
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
10538	0.0 to 30.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	150	SF	\$120	\$18,000	
49795	6.0 to 9.7 feet	Vertical Change	-.34	5 ft	18	REF			
48032	13.6 to 14.6 feet	Vertical Change	-.4	5 ft	5	REF			
52702	17.6 to 18.6 feet	Vertical Change	-.28	5 ft	5	REF			
50508	26.4 to 27.4 feet	Vertical Change	-.32	5 ft	5	REF			
41823	26.5 to 27.5 feet	Vertical Change	-.83	5 ft	5	REF			
54075	28.0 to 29.2 feet	Vertical Change	-.25	5 ft	6	REF			
47377	36.8 to 37.8 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375	
10545	47.3 to 74.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	136	SF	\$120	\$16,320	
45590	51.7 to 52.7 feet	Vertical Change	-.5	5 ft	5	REF			
45591	63.4 to 64.4 feet	Vertical Change	-.5	5 ft	5	REF			
49797	74.9 to 75.9 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375	
10546	77.1 to 88.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,720	
50113	79.6 to 80.6 feet	Vertical Change	-.33	5 ft	5	REF			
49466	84.4 to 85.4 feet	Vertical Change	-.35	5 ft	5	REF			
TOTAL COST FOR: W							<i>side of</i> SANTA CRUZ BLVD	<i>Starting at:</i> ENGLEWOOD AVE	\$41,790.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908221540	SANTA CRUZ BLVD	WASHINGTON RD	ELM AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
10547	0.0 to 11.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,780	
49151	6.7 to 7.7 feet	Vertical Change	-.36	5 ft	5	REF			
46227	27.7 to 28.7 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375	
45812	41.7 to 42.7 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$375	
10548	58.3 to 86.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	142	SF	\$120	\$16,980	
49798	61.2 to 62.2 feet	Vertical Change	-.34	5 ft	5	REF			
41274	61.4 to 62.4 feet	Vertical Change	-1.69	5 ft	5	REF			
50509	76.1 to 77.1 feet	Vertical Change	-.32	5 ft	5	REF			
44290	86.3 to 87.3 feet	Vertical Change	-.56	5 ft	5	REF			
10553	86.6 to 90.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	20	SF	\$120	\$2,340	
10555	90.5 to 108.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	92	SF	\$120	\$10,980	
48033	98.1 to 99.1 feet	Vertical Change	-.4	5 ft	5	REF			
58466	98.2 to 128.8 feet	Driveway				REF			
49799	101.7 to 102.7 feet	Vertical Change	-.34	5 ft	5	REF			
52703	106.0 to 107.0 feet	Vertical Change	-.28	5 ft	5	REF			
10558	108.8 to 141.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	165	SF	\$40	\$6,600	
52241	118.2 to 119.2 feet	Vertical Change	-.29	5 ft	5	REF			
45301	135.0 to 137.6 feet	Vertical Change	-.51	5 ft	13	REF			
10564	141.8 to 161.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	100	SF	\$120	\$12,000	
53745	144.8 to 148.2 feet	Vertical Change	-.26	5 ft	17	REF			
55977	153.6 to 154.6 feet	Vertical Change	.37	5 ft	5	REF			
50905	163.6 to 164.6 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
10567	175.5 to 177.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
49152	177.4 to 178.4 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375	
47378	191.1 to 192.1 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375	
10568	204.2 to 207.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800	
52242	204.9 to 205.9 feet	Vertical Change	-.29	5 ft	5	REF			
10569	211.3 to 212.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908221540	SANTA CRUZ BLVD	WASHINGTON RD	ELM AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
48034	218.4 to 219.4 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375
51813	232.1 to 233.1 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375
44291	245.4 to 246.4 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375
52243	256.2 to 257.2 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375
44916	286.6 to 287.6 feet	Vertical Change	-.53	5 ft	5	SF	\$75	\$375
10570	299.2 to 304.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,180
50906	315.0 to 316.0 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375
52244	329.4 to 330.4 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375
49153	343.7 to 344.7 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375
10571	355.0 to 362.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,260
50114	363.0 to 364.0 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: E side of SANTA CRUZ BLVD Starting at: WASHINGTON RD							\$72,030.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
S	1908221546	ELM AVE	SANTA CRUZ BLVD	MAPLE ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
10572	0.0 to 77.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	387	SF	\$120	\$46,440	
41776	17.2 to 18.2 feet	Vertical Change	-86	5 ft	5	REF			
42317	27.2 to 28.2 feet	Vertical Change	-71	5 ft	5	REF			
45302	37.2 to 38.2 feet	Vertical Change	-51	5 ft	5	REF			
44727	57.3 to 58.3 feet	Vertical Change	-54	5 ft	5	REF			
50907	97.2 to 100.6 feet	Vertical Change	-.31	5 ft	17	LF	\$75	\$1,275	
10573	103.2 to 129.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	131	SF	\$120	\$15,720	
45100	107.2 to 108.2 feet	Vertical Change	-.52	5 ft	5	REF			
48573	117.1 to 118.1 feet	Vertical Change	-.38	5 ft	5	REF			
10575	132.5 to 145.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	66	SF	\$120	\$7,860	
45813	137.1 to 138.1 feet	Vertical Change	-.49	5 ft	5	REF			
10576	149.3 to 156.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,200	
52704	154.8 to 155.8 feet	Vertical Change	-.28	5 ft	5	REF			
10577	159.5 to 162.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500	
10578	187.8 to 190.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500	
10579	192.4 to 210.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	93	SF	\$120	\$11,100	
10580	213.8 to 260.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	235	SF	\$120	\$28,140	
44112	252.0 to 253.0 feet	Vertical Change	-.57	5 ft	5	REF			
10583	263.2 to 521.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	1293	SF	\$120	\$155,100	
50115	321.9 to 322.9 feet	Vertical Change	-.33	5 ft	5	REF			
51814	332.0 to 333.0 feet	Vertical Change	-.3	5 ft	5	REF			
10604	533.6 to 546.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	66	SF	\$120	\$7,860	
10605	550.6 to 555.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120	
10606	560.3 to 561.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900	
10607	577.5 to 578.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840	
10608	587.2 to 602.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	75	SF	\$120	\$9,000	
51816	607.3 to 608.3 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
10609	617.8 to 622.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,580	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221546	ELM AVE	SANTA CRUZ BLVD	MAPLE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
10610	624.3 to 642.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	89	SF	\$120	\$10,680
10611	654.7 to 662.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,500
10612	669.7 to 674.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000
47618	680.1 to 681.1 feet	Vertical Change	-41	5 ft	5	LF	\$75	\$375
10613	735.6 to 743.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,740
10615	747.9 to 751.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040
10616	758.2 to 760.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260
10617	770.5 to 787.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,320
43294	784.0 to 785.0 feet	Vertical Change	-62	5 ft	5	REF		
10619	792.6 to 801.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,520
10621	805.5 to 812.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,080
10622	814.5 to 869.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	277	SF	\$120	\$33,240
49468	865.8 to 866.8 feet	Vertical Change	-35	5 ft	5	REF		
10624	875.1 to 892.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	89	SF	\$120	\$10,620
50908	883.4 to 884.4 feet	Vertical Change	-31	5 ft	5	REF		
50116	891.8 to 892.8 feet	Vertical Change	-33	5 ft	5	REF		
10626	892.8 to 897.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	24	SF	\$120	\$2,880
10628	897.6 to 933.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	181	SF	\$120	\$21,720
48294	897.8 to 898.8 feet	Vertical Change	-39	5 ft	5	REF		
57236	900.9 to 901.9 feet	Vertical Change	.73	5 ft	5	REF		
44728	908.9 to 909.9 feet	Vertical Change	-54	5 ft	5	REF		
45101	916.3 to 917.3 feet	Vertical Change	-52	5 ft	5	REF		
46464	920.0 to 921.0 feet	Vertical Change	-46	5 ft	5	REF		
47379	927.9 to 928.9 feet	Vertical Change	-42	5 ft	5	REF		
58469	938.2 to 964.1 feet	Driveway				REF		
47619	943.9 to 944.9 feet	Vertical Change	-41	5 ft	5	REF		
10631	947.4 to 961.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	73	SF	\$40	\$2,900
44729	954.3 to 955.3 feet	Vertical Change	-54	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908221546	ELM AVE	SANTA CRUZ BLVD	MAPLE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
40327	960.7 to 962.6 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
45814	964.3 to 965.3 feet	Vertical Change	-.49	5 ft	5	REF			
10635	965.2 to 966.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960	
58470	968.7 to 994.6 feet	Driveway				REF			
10636	972.9 to 974.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$220	
46228	973.9 to 974.9 feet	Vertical Change	-.47	5 ft	5	REF			
57166	974.0 to 975.0 feet	Vertical Change	.69	5 ft	5	REF			
10637	977.0 to 992.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	78	SF	\$40	\$3,120	
53202	984.3 to 985.3 feet	Vertical Change	-.27	5 ft	5	REF			
40328	991.5 to 993.2 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
42919	994.9 to 995.9 feet	Vertical Change	-.65	5 ft	5	REF			
10639	995.6 to 999.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	17	SF	\$120	\$2,040	
10640	999.0 to 1012.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	69	SF	\$120	\$8,280	
47620	1005.2 to 1006.2 feet	Vertical Change	-.41	5 ft	5	REF			
10642	1012.8 to 1029.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	86	SF	\$120	\$10,260	
41709	1013.3 to 1014.3 feet	Vertical Change	-.89	5 ft	5	REF			
48868	1021.5 to 1022.5 feet	Vertical Change	-.37	5 ft	5	REF			
41357	1029.1 to 1030.1 feet	Vertical Change	-1.38	5 ft	5	REF			
10645	1030.8 to 1031.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600	
51817	1033.6 to 1034.6 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
10646	1039.3 to 1050.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,540	
52245	1043.5 to 1044.5 feet	Vertical Change	-.29	5 ft	5	REF			
10648	1050.2 to 1063.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	68	SF	\$120	\$8,160	
49469	1053.6 to 1054.6 feet	Vertical Change	-.35	5 ft	5	REF			
58471	1056.8 to 1085.0 feet	Driveway				REF			
52246	1058.6 to 1059.6 feet	Vertical Change	-.29	5 ft	5	REF			
10650	1067.3 to 1080.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	66	SF	\$40	\$2,660	
10652	1080.6 to 1082.3 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	9	SF	\$40	\$340	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221546	ELM AVE	SANTA CRUZ BLVD	MAPLE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40329	1081.6 to 1082.8 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
10653	1086.7 to 1093.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320
58472	1088.3 to 1114.6 feet	Driveway				REF		
10655	1097.9 to 1111.6 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	68	SF	\$40	\$2,740
48869	1104.4 to 1105.4 feet	Vertical Change	-.37	5 ft	5	REF		
40330	1110.9 to 1113.9 feet	Running Slope	5.0-6.0%	5 ft	15	REF		
10657	1116.3 to 1120.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	20	SF	\$120	\$2,340
53747	1119.0 to 1120.0 feet	Vertical Change	-.26	5 ft	5	REF		
10659	1120.2 to 1125.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	27	SF	\$120	\$3,240
47621	1123.9 to 1124.9 feet	Vertical Change	-.41	5 ft	5	REF		
10660	1125.6 to 1130.6 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	25	SF	\$120	\$3,000
51818	1128.9 to 1129.9 feet	Vertical Change	-.3	5 ft	5	REF		
10661	1130.6 to 1144.9 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	72	SF	\$120	\$8,580
53203	1133.9 to 1134.9 feet	Vertical Change	-.27	5 ft	5	REF		
41481	1143.9 to 1144.9 feet	Vertical Change	-1.12	5 ft	5	REF		
57291	1144.0 to 1145.0 feet	Vertical Change	.83	5 ft	5	REF		
10663	1144.9 to 1146.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,080
10664	1146.7 to 1166.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	99	SF	\$120	\$11,880
46010	1148.9 to 1149.9 feet	Vertical Change	-.48	5 ft	5	REF		
50117	1159.0 to 1160.0 feet	Vertical Change	-.33	5 ft	5	REF		
56918	1164.1 to 1165.1 feet	Vertical Change	.51	5 ft	5	REF		
10666	1166.5 to 1184.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	89	SF	\$120	\$10,620
44292	1169.0 to 1170.0 feet	Vertical Change	-.56	5 ft	5	REF		
53748	1174.1 to 1175.1 feet	Vertical Change	-.26	5 ft	5	REF		
58473	1178.6 to 1202.1 feet	Driveway				REF		
52705	1179.0 to 1180.0 feet	Vertical Change	-.28	5 ft	5	REF		
10668	1187.7 to 1202.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	73	SF	\$40	\$2,900
50118	1194.4 to 1195.4 feet	Vertical Change	-.33	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221546	ELM AVE	SANTA CRUZ BLVD	MAPLE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
10671	1206.3 to 1214.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,620
45815	1209.5 to 1210.5 feet	Vertical Change	-49	5 ft	5	REF		
58474	1209.7 to 1235.6 feet	Driveway				REF		
50510	1214.0 to 1215.0 feet	Vertical Change	-.32	5 ft	5	REF		
10672	1217.7 to 1230.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	63	SF	\$40	\$2,500
51819	1224.7 to 1225.7 feet	Vertical Change	-.3	5 ft	5	REF		
10676	1230.2 to 1232.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	9	SF	\$40	\$380
40331	1231.3 to 1232.6 feet	Running Slope	9.0-10.0%	5 ft	6	REF		
10677	1235.4 to 1254.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	98	SF	\$40	\$3,900
44293	1249.3 to 1250.3 feet	Vertical Change	-.56	5 ft	5	REF		
44113	1254.4 to 1255.4 feet	Vertical Change	-.57	5 ft	5	REF		
10679	1254.9 to 1294.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	198	SF	\$120	\$23,760
42405	1259.3 to 1260.3 feet	Vertical Change	-.7	5 ft	5	REF		
47622	1269.3 to 1270.3 feet	Vertical Change	-.41	5 ft	5	REF		
46229	1274.4 to 1275.4 feet	Vertical Change	-.47	5 ft	5	REF		
53204	1279.3 to 1280.3 feet	Vertical Change	-.27	5 ft	5	REF		
48870	1285.7 to 1286.7 feet	Vertical Change	-.37	5 ft	5	REF		
53205	1292.2 to 1293.2 feet	Vertical Change	-.27	5 ft	5	REF		
10683	1294.5 to 1304.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,820
48295	1298.1 to 1299.1 feet	Vertical Change	-.39	5 ft	5	REF		
58475	1299.2 to 1323.8 feet	Driveway				REF		
48296	1304.2 to 1305.2 feet	Vertical Change	-.39	5 ft	5	REF		
10685	1304.2 to 1305.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$200
10686	1308.2 to 1322.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	72	SF	\$40	\$2,860
48871	1314.9 to 1315.9 feet	Vertical Change	-.37	5 ft	5	REF		
40332	1322.3 to 1324.3 feet	Running Slope	6.0-7.0%	5 ft	10	REF		
10688	1326.5 to 1334.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	38	SF	\$120	\$4,500
49470	1326.6 to 1327.6 feet	Vertical Change	-.35	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221546	ELM AVE	SANTA CRUZ BLVD	MAPLE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58476	1328.1 to 1364.5 feet	Driveway				REF		
48297	1333.6 to 1334.6 feet	Vertical Change	-0.39	5 ft	5	REF		
10689	1338.0 to 1356.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	93	SF	\$40	\$3,720
50119	1351.9 to 1352.9 feet	Vertical Change	-0.33	5 ft	5	REF		
10691	1356.6 to 1363.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	32	SF	\$40	\$1,280
44509	1358.8 to 1359.8 feet	Vertical Change	-0.55	5 ft	5	REF		
45592	1365.6 to 1366.6 feet	Vertical Change	-0.5	5 ft	5	REF		
10692	1366.0 to 1390.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	123	SF	\$120	\$14,760
53206	1369.0 to 1370.0 feet	Vertical Change	-0.27	5 ft	5	REF		
49800	1376.4 to 1377.4 feet	Vertical Change	-0.34	5 ft	5	REF		
51820	1388.8 to 1389.8 feet	Vertical Change	-0.3	5 ft	5	REF		
10693	1390.6 to 1414.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	118	SF	\$120	\$14,160
52706	1398.7 to 1399.7 feet	Vertical Change	-0.28	5 ft	5	REF		
50909	1403.6 to 1404.6 feet	Vertical Change	-0.31	5 ft	5	REF		
58477	1409.0 to 1444.9 feet	Driveway				REF		
10696	1417.7 to 1430.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	63	SF	\$40	\$2,520
10699	1430.3 to 1442.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	62	SF	\$40	\$2,480
10701	1446.3 to 1455.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	47	SF	\$120	\$5,580
58478	1448.9 to 1475.3 feet	Driveway				REF		
10704	1458.3 to 1472.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	71	SF	\$40	\$2,820
10707	1475.9 to 1477.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$840
10708	1477.3 to 1545.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	342	SF	\$120	\$41,040
53207	1504.9 to 1505.9 feet	Vertical Change	-0.27	5 ft	5	REF		
53208	1519.6 to 1520.6 feet	Vertical Change	-0.27	5 ft	5	REF		
52707	1524.6 to 1525.6 feet	Vertical Change	-0.28	5 ft	5	REF		
50120	1529.6 to 1530.6 feet	Vertical Change	-0.33	5 ft	5	REF		
53749	1534.6 to 1535.6 feet	Vertical Change	-0.26	5 ft	5	REF		
58479	1537.0 to 1564.6 feet	Driveway				REF		
51821	1539.5 to 1540.5 feet	Vertical Change	-0.3	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221546	ELM AVE	SANTA CRUZ BLVD	MAPLE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
50910	1544.3 to 1545.3 feet	Vertical Change	-.31	5 ft	5	REF		
10717	1548.9 to 1564.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	76	SF	\$40	\$3,020
48574	1555.2 to 1556.2 feet	Vertical Change	-.38	5 ft	5	REF		
48298	1566.5 to 1567.5 feet	Vertical Change	-.39	5 ft	5	REF		
10720	1566.6 to 1574.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	40	SF	\$120	\$4,800
58480	1569.1 to 1604.9 feet	Driveway				REF		
49801	1574.3 to 1575.3 feet	Vertical Change	-.34	5 ft	5	REF		
10723	1578.2 to 1601.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	118	SF	\$40	\$4,720
49802	1585.2 to 1586.2 feet	Vertical Change	-.34	5 ft	5	REF		
49471	1592.1 to 1593.1 feet	Vertical Change	-.35	5 ft	5	REF		
48575	1605.2 to 1606.2 feet	Vertical Change	-.38	5 ft	5	REF		
10725	1605.7 to 1635.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	150	SF	\$120	\$18,000
49472	1614.2 to 1615.2 feet	Vertical Change	-.35	5 ft	5	REF		
52247	1619.1 to 1620.1 feet	Vertical Change	-.29	5 ft	5	REF		
49473	1624.1 to 1625.1 feet	Vertical Change	-.35	5 ft	5	REF		
48299	1629.0 to 1630.0 feet	Vertical Change	-.39	5 ft	5	REF		
48300	1634.1 to 1635.1 feet	Vertical Change	-.39	5 ft	5	REF		
10729	1635.7 to 1654.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	94	SF	\$120	\$11,220
52248	1639.0 to 1640.0 feet	Vertical Change	-.29	5 ft	5	REF		
52708	1644.1 to 1645.1 feet	Vertical Change	-.28	5 ft	5	REF		
58481	1647.5 to 1683.9 feet	Driveway				REF		
50911	1651.9 to 1652.9 feet	Vertical Change	-.31	5 ft	5	REF		
10731	1654.4 to 1655.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$200
10732	1658.1 to 1671.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	67	SF	\$40	\$2,680
45102	1661.3 to 1662.3 feet	Vertical Change	-.52	5 ft	5	REF		
10736	1671.5 to 1683.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	58	SF	\$40	\$2,320
52249	1675.2 to 1676.2 feet	Vertical Change	-.29	5 ft	5	REF		
40333	1682.0 to 1684.0 feet	Running Slope	5.0-6.0%	5 ft	10	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908221546	ELM AVE	SANTA CRUZ BLVD	MAPLE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
48301	1686.3 to 1687.3 feet	Vertical Change	-.39	5 ft	5	REF		
10738	1687.2 to 1693.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	33	SF	\$120	\$3,960
58482	1689.3 to 1715.6 feet	Driveway				REF		
10739	1697.2 to 1713.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	82	SF	\$40	\$3,260
49154	1705.2 to 1706.2 feet	Vertical Change	-.36	5 ft	5	REF		
40334	1713.0 to 1714.1 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
49155	1716.4 to 1717.4 feet	Vertical Change	-.36	5 ft	5	REF		
10741	1717.0 to 1723.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	33	SF	\$120	\$3,900
10743	1723.5 to 1746.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	114	SF	\$120	\$13,680
48302	1726.3 to 1727.3 feet	Vertical Change	-.39	5 ft	5	REF		
50511	1730.9 to 1731.9 feet	Vertical Change	-.32	5 ft	5	REF		
48303	1740.1 to 1741.1 feet	Vertical Change	-.39	5 ft	5	REF		
47135	1745.0 to 1746.0 feet	Vertical Change	-.43	5 ft	5	REF		
TOTAL COST FOR: S							<i>side of ELM AVE Starting at: SANTA CRUZ BLVD</i>	\$719,140.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
W	1908221548	MAPLE ST	ELM AVE	WASHINGTON RD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
10748	0.8 to 27.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	134	SF	\$120	\$16,020	
52250	9.4 to 10.4 feet	Vertical Change	-.29	5 ft	5	REF			
47136	16.7 to 17.7 feet	Vertical Change	-.43	5 ft	5	REF			
48872	21.7 to 22.7 feet	Vertical Change	-.37	5 ft	5	REF			
48576	26.6 to 27.6 feet	Vertical Change	-.38	5 ft	5	REF			
10751	27.5 to 55.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	141	SF	\$120	\$16,860	
51822	31.6 to 32.6 feet	Vertical Change	-.3	5 ft	5	REF			
48873	41.3 to 42.3 feet	Vertical Change	-.37	5 ft	5	REF			
48577	46.2 to 47.2 feet	Vertical Change	-.38	5 ft	5	REF			
52709	51.0 to 52.0 feet	Vertical Change	-.28	5 ft	5	REF			
10755	55.6 to 92.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	183	SF	\$120	\$21,900	
50512	56.1 to 57.1 feet	Vertical Change	-.32	5 ft	5	REF			
50513	61.1 to 62.1 feet	Vertical Change	-.32	5 ft	5	REF			
53209	80.3 to 81.3 feet	Vertical Change	-.27	5 ft	5	REF			
53210	85.2 to 86.2 feet	Vertical Change	-.27	5 ft	5	REF			
10759	92.1 to 155.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	316	SF	\$120	\$37,920	
49156	99.9 to 100.9 feet	Vertical Change	-.36	5 ft	5	REF			
48304	104.8 to 105.8 feet	Vertical Change	-.39	5 ft	5	REF			
49474	109.7 to 110.7 feet	Vertical Change	-.35	5 ft	5	REF			
49157	119.5 to 120.5 feet	Vertical Change	-.36	5 ft	5	REF			
48305	124.4 to 125.4 feet	Vertical Change	-.39	5 ft	5	REF			
52251	129.2 to 130.2 feet	Vertical Change	-.29	5 ft	5	REF			
52710	134.1 to 135.1 feet	Vertical Change	-.28	5 ft	5	REF			
49475	143.9 to 144.9 feet	Vertical Change	-.35	5 ft	5	REF			
58483	148.0 to 191.3 feet	Driveway				REF			
49158	148.7 to 149.7 feet	Vertical Change	-.36	5 ft	5	REF			
48035	157.7 to 159.4 feet	Vertical Change	-.4	5 ft	9	REF			
10764	161.2 to 187.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	129	SF	\$40	\$5,160	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908221548	MAPLE ST	ELM AVE	WASHINGTON RD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
43295	170.0 to 171.0 feet	Vertical Change	-.62	5 ft	5	REF			
41868	181.5 to 182.5 feet	Vertical Change	-.81	5 ft	5	REF			
10768	187.0 to 196.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	49	SF	\$40	\$1,960	
45303	193.5 to 197.0 feet	Vertical Change	-.51	5 ft	18	REF			
10772	196.8 to 238.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	211	SF	\$120	\$25,260	
43931	200.5 to 201.5 feet	Vertical Change	-.58	5 ft	5	REF			
52252	208.1 to 209.1 feet	Vertical Change	-.29	5 ft	5	REF			
49476	218.0 to 219.0 feet	Vertical Change	-.35	5 ft	5	REF			
47623	222.8 to 223.8 feet	Vertical Change	-.41	5 ft	5	REF			
48578	227.8 to 228.8 feet	Vertical Change	-.38	5 ft	5	REF			
46684	232.6 to 233.6 feet	Vertical Change	-.45	5 ft	5	REF			
49159	237.5 to 238.5 feet	Vertical Change	-.36	5 ft	5	REF			
49803	242.4 to 243.4 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375	
48579	247.3 to 248.3 feet	Vertical Change	-.38	5 ft	5	REF			
10776	247.4 to 267.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	99	SF	\$120	\$11,880	
45103	252.3 to 253.3 feet	Vertical Change	-.52	5 ft	5	REF			
50912	257.2 to 258.2 feet	Vertical Change	-.31	5 ft	5	REF			
46685	262.0 to 263.0 feet	Vertical Change	-.45	5 ft	5	REF			
46011	266.9 to 267.9 feet	Vertical Change	-.48	5 ft	5	REF			
10778	267.2 to 278.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	56	SF	\$120	\$6,720	
52253	271.8 to 272.8 feet	Vertical Change	-.29	5 ft	5	REF			
10780	278.4 to 281.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680	
46912	278.8 to 279.8 feet	Vertical Change	-.44	5 ft	5	REF			

TOTAL COST FOR: W side of MAPLE ST Starting at: ELM AVE \$145,735.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908230804	WASHINGTON RD	MAPLE ST	SHASTA CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
47624	7.3 to 8.3 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375	
10781	8.5 to 29.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	105	SF	\$120	\$12,600	
47380	12.3 to 14.4 feet	Vertical Change	-.42	5 ft	11	REF			
55983	16.8 to 17.8 feet	Vertical Change	.38	5 ft	5	REF			
54076	17.3 to 18.3 feet	Vertical Change	-.25	5 ft	5	REF			
49160	21.2 to 22.2 feet	Vertical Change	-.36	5 ft	5	REF			
46012	24.7 to 25.7 feet	Vertical Change	-.48	5 ft	5	REF			
46465	29.8 to 30.8 feet	Vertical Change	-.46	5 ft	5	LF	\$75	\$375	
10784	33.1 to 38.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120	
45304	38.6 to 39.6 feet	Vertical Change	-.51	5 ft	5	SF	\$75	\$375	
48874	43.6 to 44.6 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375	
47381	47.8 to 48.8 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375	
48580	52.7 to 53.7 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375	
10785	57.6 to 68.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,420	
50914	61.6 to 62.6 feet	Vertical Change	-.31	5 ft	5	REF			
10787	71.9 to 98.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	132	SF	\$120	\$15,840	
53211	72.2 to 73.2 feet	Vertical Change	-.27	5 ft	5	REF			
49161	77.4 to 78.4 feet	Vertical Change	-.36	5 ft	5	REF			
51824	82.4 to 83.4 feet	Vertical Change	-.3	5 ft	5	REF			
48875	92.4 to 93.4 feet	Vertical Change	-.37	5 ft	5	REF			
48876	97.4 to 98.4 feet	Vertical Change	-.37	5 ft	5	REF			
53750	112.7 to 113.7 feet	Vertical Change	-.26	5 ft	5	REF			
10792	112.8 to 115.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500	
48306	117.6 to 118.6 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375	
10793	122.3 to 127.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060	
53212	122.9 to 123.9 feet	Vertical Change	-.27	5 ft	5	REF			
53751	127.9 to 128.9 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
48307	132.8 to 133.8 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908230804	WASHINGTON RD	MAPLE ST	SHASTA CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
48877	137.9 to 138.9 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375	
10794	142.6 to 160.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	90	SF	\$120	\$10,800	
47382	142.8 to 143.8 feet	Vertical Change	-.42	5 ft	5	REF			
51825	147.8 to 148.8 feet	Vertical Change	-.3	5 ft	5	REF			
49477	157.8 to 158.8 feet	Vertical Change	-.35	5 ft	5	REF			
49162	163.1 to 164.1 feet	Vertical Change	-.36	5 ft	5	REF			
10795	163.3 to 166.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800	
52254	168.0 to 169.0 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
10796	170.2 to 179.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,760	
50514	173.0 to 174.0 feet	Vertical Change	-.32	5 ft	5	REF			
50121	177.8 to 178.8 feet	Vertical Change	-.33	5 ft	5	REF			
52255	183.1 to 184.1 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
10797	186.3 to 209.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	117	SF	\$120	\$13,980	
48308	188.1 to 189.1 feet	Vertical Change	-.39	5 ft	5	REF			
48878	198.0 to 199.0 feet	Vertical Change	-.37	5 ft	5	REF			
52712	207.1 to 208.1 feet	Vertical Change	-.28	5 ft	5	REF			
56968	213.7 to 214.7 feet	Vertical Change	.56	5 ft	5	REF			
10800	214.7 to 251.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	185	SF	\$120	\$22,140	
45816	220.3 to 221.3 feet	Vertical Change	-.49	5 ft	5	REF			
49163	225.2 to 226.2 feet	Vertical Change	-.36	5 ft	5	REF			
48309	230.4 to 231.4 feet	Vertical Change	-.39	5 ft	5	REF			
47625	235.4 to 236.4 feet	Vertical Change	-.41	5 ft	5	REF			
53752	240.3 to 241.3 feet	Vertical Change	-.26	5 ft	5	REF			
48310	245.2 to 246.2 feet	Vertical Change	-.39	5 ft	5	REF			
10803	258.9 to 266.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,380	
50515	265.5 to 266.5 feet	Vertical Change	-.32	5 ft	5	REF			
10804	270.0 to 271.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
52713	270.5 to 271.5 feet	Vertical Change	-.28	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230804	WASHINGTON RD	MAPLE ST	SHASTA CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
10805	274.2 to 364.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	449	SF	\$120	\$53,880
47383	275.3 to 276.3 feet	Vertical Change	-42	5 ft	5	REF		
51826	285.5 to 286.5 feet	Vertical Change	-3	5 ft	5	REF		
53213	290.5 to 291.5 feet	Vertical Change	-27	5 ft	5	REF		
52256	300.7 to 301.7 feet	Vertical Change	-29	5 ft	5	REF		
49164	305.7 to 306.7 feet	Vertical Change	-36	5 ft	5	REF		
50516	310.9 to 311.9 feet	Vertical Change	-32	5 ft	5	REF		
48581	315.9 to 316.9 feet	Vertical Change	-38	5 ft	5	REF		
41324	323.6 to 324.6 feet	Vertical Change	-1.48	5 ft	5	REF		
57466	323.6 to 324.6 feet	Vertical Change	1.47	5 ft	5	REF		
54077	326.1 to 327.1 feet	Vertical Change	-25	5 ft	5	REF		
49165	345.9 to 346.9 feet	Vertical Change	-36	5 ft	5	REF		
50122	356.1 to 357.1 feet	Vertical Change	-33	5 ft	5	REF		
49166	366.1 to 367.1 feet	Vertical Change	-36	5 ft	5	REF		
10816	366.1 to 383.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	88	SF	\$120	\$10,500
49478	371.5 to 372.5 feet	Vertical Change	-35	5 ft	5	REF		
47137	376.4 to 377.4 feet	Vertical Change	-43	5 ft	5	REF		
46013	381.6 to 382.6 feet	Vertical Change	-48	5 ft	5	REF		
10818	385.9 to 471.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	430	SF	\$120	\$51,540
44917	386.6 to 387.6 feet	Vertical Change	-53	5 ft	5	REF		
46230	392.2 to 393.2 feet	Vertical Change	-47	5 ft	5	REF		
45305	397.0 to 398.0 feet	Vertical Change	-51	5 ft	5	REF		
49167	407.5 to 408.5 feet	Vertical Change	-36	5 ft	5	REF		
48311	412.8 to 413.8 feet	Vertical Change	-39	5 ft	5	REF		
49805	417.7 to 418.7 feet	Vertical Change	-34	5 ft	5	REF		
48312	423.0 to 424.0 feet	Vertical Change	-39	5 ft	5	REF		
52714	427.9 to 428.9 feet	Vertical Change	-28	5 ft	5	REF		
48582	433.8 to 434.8 feet	Vertical Change	-38	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908230804	WASHINGTON RD	MAPLE ST	SHASTA CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
50123	438.7 to 439.7 feet	Vertical Change	-.33	5 ft	5	REF			
51827	444.1 to 445.1 feet	Vertical Change	-.3	5 ft	5	REF			
49806	449.1 to 450.1 feet	Vertical Change	-.34	5 ft	5	REF			
49168	454.3 to 455.3 feet	Vertical Change	-.36	5 ft	5	REF			
52715	464.6 to 465.6 feet	Vertical Change	-.28	5 ft	5	REF			
53753	469.5 to 470.5 feet	Vertical Change	-.26	5 ft	5	REF			
10828	476.6 to 479.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,920	
54078	479.8 to 480.8 feet	Vertical Change	-.25	5 ft	5	REF			
49807	501.1 to 502.1 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375	
53214	506.4 to 507.4 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
49808	511.4 to 512.4 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375	
50915	516.7 to 517.7 feet	Vertical Change	-.31	5 ft	5	REF			
10829	517.5 to 522.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,880	
51828	521.5 to 522.5 feet	Vertical Change	-.3	5 ft	5	REF			
10830	525.7 to 575.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	248	SF	\$120	\$29,820	
52716	532.1 to 533.1 feet	Vertical Change	-.28	5 ft	5	REF			
49809	537.2 to 538.2 feet	Vertical Change	-.34	5 ft	5	REF			
49810	547.3 to 548.3 feet	Vertical Change	-.34	5 ft	5	REF			
48036	552.3 to 553.3 feet	Vertical Change	-.4	5 ft	5	REF			
43771	557.6 to 558.6 feet	Vertical Change	-.59	5 ft	5	REF			
49479	562.6 to 563.6 feet	Vertical Change	-.35	5 ft	5	REF			
47384	573.0 to 574.0 feet	Vertical Change	-.42	5 ft	5	REF			
46913	578.2 to 579.2 feet	Vertical Change	-.44	5 ft	5	LF	\$75	\$375	
45817	583.1 to 584.1 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$375	
48313	588.2 to 589.2 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375	
46686	593.2 to 594.2 feet	Vertical Change	-.45	5 ft	5	LF	\$75	\$375	
49480	603.1 to 604.1 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$375	
50517	613.2 to 614.2 feet	Vertical Change	-.32	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908230804	WASHINGTON RD	MAPLE ST	SHASTA CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
10834	614.1 to 623.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,580	
46466	618.6 to 619.6 feet	Vertical Change	-46	5 ft	5	REF			
46914	623.6 to 624.6 feet	Vertical Change	-44	5 ft	5	LF	\$75	\$375	
48583	628.8 to 629.8 feet	Vertical Change	-38	5 ft	5	LF	\$75	\$375	
49169	633.9 to 634.9 feet	Vertical Change	-36	5 ft	5	LF	\$75	\$375	
50518	638.9 to 639.9 feet	Vertical Change	-32	5 ft	5	LF	\$75	\$375	
49170	643.9 to 644.9 feet	Vertical Change	-36	5 ft	5	LF	\$75	\$375	
10835	645.6 to 650.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,940	
50519	648.9 to 649.9 feet	Vertical Change	-32	5 ft	5	REF			
48037	654.2 to 655.2 feet	Vertical Change	-4	5 ft	5	LF	\$75	\$375	
52717	659.9 to 660.9 feet	Vertical Change	-28	5 ft	5	LF	\$75	\$375	
47626	664.8 to 665.8 feet	Vertical Change	-41	5 ft	5	LF	\$75	\$375	
10836	669.7 to 723.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	270	SF	\$120	\$32,340	
49811	669.9 to 670.9 feet	Vertical Change	-34	5 ft	5	REF			
48314	674.8 to 675.8 feet	Vertical Change	-39	5 ft	5	REF			
52718	680.2 to 681.2 feet	Vertical Change	-28	5 ft	5	REF			
48584	684.9 to 685.9 feet	Vertical Change	-38	5 ft	5	REF			
47138	693.8 to 694.8 feet	Vertical Change	-43	5 ft	5	REF			
53754	706.5 to 707.5 feet	Vertical Change	-26	5 ft	5	REF			
47627	710.4 to 711.4 feet	Vertical Change	-41	5 ft	5	REF			
54079	715.4 to 716.4 feet	Vertical Change	-25	5 ft	5	REF			
50520	720.8 to 721.8 feet	Vertical Change	-32	5 ft	5	REF			
50124	725.8 to 726.8 feet	Vertical Change	-33	5 ft	5	LF	\$75	\$375	
54147	733.2 to 734.2 feet	Vertical Change	.26	5 ft	5	LF	\$75	\$375	
10840	735.3 to 739.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220	
45818	737.3 to 738.3 feet	Vertical Change	-49	5 ft	5	REF			
47628	741.3 to 742.3 feet	Vertical Change	-41	5 ft	5	LF	\$75	\$375	
50521	749.5 to 750.5 feet	Vertical Change	-32	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230804	WASHINGTON RD	MAPLE ST	SHASTA CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
48315	753.1 to 754.1 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375
53215	758.2 to 759.2 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
10841	759.8 to 811.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	260	SF	\$120	\$31,140
49481	777.6 to 778.6 feet	Vertical Change	-.35	5 ft	5	REF		
46915	782.4 to 783.4 feet	Vertical Change	-.44	5 ft	5	REF		
48316	787.6 to 788.6 feet	Vertical Change	-.39	5 ft	5	REF		
48038	792.5 to 793.5 feet	Vertical Change	-.4	5 ft	5	REF		
47385	797.5 to 798.5 feet	Vertical Change	-.42	5 ft	5	REF		
47139	800.7 to 801.7 feet	Vertical Change	-.43	5 ft	5	REF		
48317	804.5 to 806.7 feet	Vertical Change	-.39	5 ft	11	REF		
49812	810.5 to 811.5 feet	Vertical Change	-.34	5 ft	5	REF		
TOTAL COST FOR: N side of WASHINGTON RD Starting at: MAPLE ST							\$339,990.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230807	SHASTA CT	WASHINGTON RD	WASHINGTON RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
10847	0.0 to 9.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,880
45593	2.2 to 3.2 feet	Vertical Change	-5	5 ft	5	REF		
10849	9.8 to 29.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	99	SF	\$120	\$11,940
54080	10.1 to 11.1 feet	Vertical Change	-25	5 ft	5	REF		
47386	14.2 to 15.2 feet	Vertical Change	-42	5 ft	5	REF		
48879	17.6 to 18.6 feet	Vertical Change	-37	5 ft	5	REF		
50522	22.6 to 23.6 feet	Vertical Change	-32	5 ft	5	REF		
47629	27.5 to 28.5 feet	Vertical Change	-41	5 ft	5	REF		
10851	29.7 to 36.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,840
47387	32.5 to 33.5 feet	Vertical Change	-42	5 ft	5	REF		
47630	35.9 to 36.9 feet	Vertical Change	-41	5 ft	5	REF		
48880	44.2 to 45.2 feet	Vertical Change	-37	5 ft	5	LF	\$75	\$375
49171	49.4 to 50.4 feet	Vertical Change	-36	5 ft	5	LF	\$75	\$375
52720	54.4 to 55.4 feet	Vertical Change	-28	5 ft	5	LF	\$75	\$375
52257	59.6 to 60.6 feet	Vertical Change	-29	5 ft	5	LF	\$75	\$375
48881	64.5 to 65.5 feet	Vertical Change	-37	5 ft	5	LF	\$75	\$375
48882	69.7 to 70.7 feet	Vertical Change	-37	5 ft	5	LF	\$75	\$375
52721	73.1 to 74.1 feet	Vertical Change	-28	5 ft	5	LF	\$75	\$375
43932	76.7 to 77.7 feet	Vertical Change	-58	5 ft	5	SF	\$75	\$375
49813	79.9 to 80.9 feet	Vertical Change	-34	5 ft	5	LF	\$75	\$375
58484	80.6 to 125.1 feet	Driveway				REF		
51829	87.8 to 91.0 feet	Vertical Change	-3	5 ft	16	REF		
10852	91.7 to 98.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	32	SF	\$40	\$1,280
10854	98.1 to 108.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	53	SF	\$40	\$2,100
49482	101.6 to 102.6 feet	Vertical Change	-35	5 ft	5	REF		
10856	108.6 to 113.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	23	SF	\$40	\$920
50523	113.0 to 114.0 feet	Vertical Change	-32	5 ft	5	REF		
10857	113.2 to 119.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	31	SF	\$40	\$1,220

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230807	SHASTA CT	WASHINGTON RD	WASHINGTON RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
10859	119.3 to 122.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	18	SF	\$40	\$700
10861	122.8 to 131.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	44	SF	\$40	\$1,780
46687	124.3 to 126.0 feet	Vertical Change	-.45	5 ft	9	REF		
56969	125.1 to 126.1 feet	Vertical Change	.56	5 ft	5	REF		
10863	132.8 to 154.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	106	SF	\$120	\$12,780
54081	133.2 to 134.2 feet	Vertical Change	-.25	5 ft	5	REF		
51830	137.3 to 138.3 feet	Vertical Change	-.3	5 ft	5	REF		
48883	140.7 to 141.7 feet	Vertical Change	-.37	5 ft	5	REF		
50916	145.0 to 146.0 feet	Vertical Change	-.31	5 ft	5	REF		
42100	150.4 to 151.4 feet	Vertical Change	-.75	5 ft	5	REF		
10865	154.1 to 222.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	342	SF	\$120	\$40,980
48884	156.5 to 157.5 feet	Vertical Change	-.37	5 ft	5	REF		
48885	162.0 to 163.0 feet	Vertical Change	-.37	5 ft	5	REF		
43296	168.6 to 169.6 feet	Vertical Change	-.62	5 ft	5	REF		
49814	180.1 to 181.1 feet	Vertical Change	-.34	5 ft	5	REF		
46916	191.7 to 192.7 feet	Vertical Change	-.44	5 ft	5	REF		
50917	202.9 to 203.9 feet	Vertical Change	-.31	5 ft	5	REF		
53755	206.5 to 208.7 feet	Vertical Change	-.26	5 ft	11	REF		
44730	208.6 to 209.6 feet	Vertical Change	-.54	5 ft	5	REF		
45594	214.3 to 215.3 feet	Vertical Change	-.5	5 ft	5	REF		
41732	220.2 to 221.2 feet	Vertical Change	-.88	5 ft	5	REF		
10872	225.3 to 231.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,900
58485	227.0 to 301.8 feet	Driveway				REF		
50125	232.6 to 233.6 feet	Vertical Change	-.33	5 ft	5	REF		
10873	234.9 to 239.5 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	23	SF	\$40	\$920
10875	239.5 to 259.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	100	SF	\$40	\$4,000
46231	251.0 to 252.0 feet	Vertical Change	-.47	5 ft	5	REF		
10876	259.5 to 265.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	29	SF	\$40	\$1,140

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230807	SHASTA CT	WASHINGTON RD	WASHINGTON RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
10877	265.2 to 275.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	50	SF	\$40	\$2,000
10879	275.2 to 285.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	52	SF	\$40	\$2,080
49483	283.8 to 284.8 feet	Vertical Change	-.35	5 ft	5	REF		
10880	285.6 to 293.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	40	SF	\$40	\$1,620
10882	293.7 to 295.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	8	SF	\$40	\$340
54082	296.1 to 299.1 feet	Vertical Change	-.25	5 ft	15	REF		
40335	296.9 to 298.7 feet	Running Slope	7.0-8.0%	5 ft	9	REF		
10883	297.9 to 299.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	7	SF	\$40	\$280
10884	302.1 to 303.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$220
52722	303.6 to 304.6 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375
10885	309.3 to 331.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	113	SF	\$120	\$13,560
10887	331.9 to 369.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	190	SF	\$120	\$22,800
10893	369.9 to 399.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	147	SF	\$120	\$17,640
50919	391.4 to 392.4 feet	Vertical Change	-.31	5 ft	5	REF		
10898	399.3 to 422.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	114	SF	\$120	\$13,680
46232	410.3 to 411.3 feet	Vertical Change	-.47	5 ft	5	REF		
10900	422.1 to 428.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,600
52723	427.0 to 428.0 feet	Vertical Change	-.28	5 ft	5	REF		
50920	432.9 to 435.4 feet	Vertical Change	-.31	5 ft	13	LF	\$75	\$938
TOTAL COST FOR: N side of SHASTA CT Starting at: WASHINGTON RD							\$175,887.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908230810	WASHINGTON RD	SHASTA CT	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
10901	0.0 to 20.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	104	SF	\$120	\$12,420	
47140	1.0 to 2.0 feet	Vertical Change	-43	5 ft	5	REF			
41698	21.7 to 22.7 feet	Vertical Change	-9	5 ft	5	SF	\$75	\$375	
10902	28.6 to 32.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520	
10903	36.9 to 124.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	437	SF	\$120	\$52,440	
52724	49.7 to 50.7 feet	Vertical Change	-28	5 ft	5	REF			
53756	62.1 to 63.1 feet	Vertical Change	-26	5 ft	5	REF			
51831	69.5 to 70.5 feet	Vertical Change	-3	5 ft	5	REF			
52725	78.3 to 79.3 feet	Vertical Change	-28	5 ft	5	REF			
52726	105.2 to 106.2 feet	Vertical Change	-28	5 ft	5	REF			
10908	127.9 to 214.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	433	SF	\$120	\$51,900	
53757	133.0 to 134.0 feet	Vertical Change	-26	5 ft	5	REF			
48039	142.0 to 143.0 feet	Vertical Change	-4	5 ft	5	REF			
54083	160.2 to 161.2 feet	Vertical Change	-25	5 ft	5	REF			
49484	169.2 to 170.2 feet	Vertical Change	-35	5 ft	5	REF			
48318	178.1 to 179.1 feet	Vertical Change	-39	5 ft	5	REF			
50526	187.2 to 188.2 feet	Vertical Change	-32	5 ft	5	REF			
48585	196.4 to 197.4 feet	Vertical Change	-38	5 ft	5	REF			
44731	214.7 to 215.7 feet	Vertical Change	-54	5 ft	5	SF	\$75	\$375	
47631	223.7 to 224.7 feet	Vertical Change	-41	5 ft	5	LF	\$75	\$375	
10915	227.4 to 336.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	544	SF	\$120	\$65,220	
46688	232.8 to 233.8 feet	Vertical Change	-45	5 ft	5	REF			
50126	251.2 to 252.2 feet	Vertical Change	-33	5 ft	5	REF			
50127	260.3 to 261.3 feet	Vertical Change	-33	5 ft	5	REF			
45104	269.4 to 270.4 feet	Vertical Change	-52	5 ft	5	REF			
46233	287.7 to 288.7 feet	Vertical Change	-47	5 ft	5	REF			
47632	296.6 to 297.6 feet	Vertical Change	-41	5 ft	5	REF			
46689	306.5 to 307.5 feet	Vertical Change	-45	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
N	1908230810	WASHINGTON RD	SHASTA CT	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
49172	324.9 to 325.9 feet	Vertical Change	-.36	5 ft	5	REF			
43620	333.9 to 334.9 feet	Vertical Change	-.6	5 ft	5	REF			
10921	336.1 to 363.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	137	SF	\$120	\$16,380	
46014	342.1 to 343.1 feet	Vertical Change	-.48	5 ft	5	REF			
44114	360.2 to 361.2 feet	Vertical Change	-.57	5 ft	5	REF			
10923	363.4 to 477.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	572	SF	\$120	\$68,640	
50128	369.3 to 370.3 feet	Vertical Change	-.33	5 ft	5	REF			
44115	378.4 to 379.4 feet	Vertical Change	-.57	5 ft	5	REF			
51832	396.4 to 397.4 feet	Vertical Change	-.3	5 ft	5	REF			
50921	405.7 to 406.7 feet	Vertical Change	-.31	5 ft	5	REF			
46690	414.8 to 415.8 feet	Vertical Change	-.45	5 ft	5	REF			
48040	433.1 to 434.1 feet	Vertical Change	-.4	5 ft	5	REF			
44919	441.7 to 442.7 feet	Vertical Change	-.53	5 ft	5	REF			
43621	450.6 to 451.6 feet	Vertical Change	-.6	5 ft	5	REF			
49173	468.9 to 469.9 feet	Vertical Change	-.36	5 ft	5	REF			
50129	477.6 to 478.6 feet	Vertical Change	-.33	5 ft	5	REF			
10928	486.7 to 530.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	220	SF	\$120	\$26,400	
44920	487.0 to 488.0 feet	Vertical Change	-.53	5 ft	5	REF			
45105	504.9 to 505.9 feet	Vertical Change	-.52	5 ft	5	REF			
48041	514.0 to 515.0 feet	Vertical Change	-.4	5 ft	5	REF			
48886	522.9 to 523.9 feet	Vertical Change	-.37	5 ft	5	REF			
53758	541.2 to 542.2 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
54148	541.2 to 542.2 feet	Vertical Change	.26	5 ft	5	LF	\$75	\$375	
45106	550.5 to 551.5 feet	Vertical Change	-.52	5 ft	5	SF	\$75	\$375	
51833	559.2 to 560.2 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
49174	577.3 to 578.3 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375	
48042	586.4 to 587.4 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375	
47388	595.5 to 596.5 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908230810	WASHINGTON RD	SHASTA CT	SANTA CRUZ BLVD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
10931	622.0 to 629.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,380	
51834	622.2 to 623.2 feet	Vertical Change	-3	5 ft	5	REF			
53216	627.9 to 631.9 feet	Vertical Change	-27	5 ft	20	REF			
48319	648.3 to 649.3 feet	Vertical Change	-39	5 ft	5	LF	\$75	\$375	
51835	657.2 to 658.2 feet	Vertical Change	-3	5 ft	5	LF	\$75	\$375	
10932	664.3 to 667.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740	
46691	730.3 to 731.3 feet	Vertical Change	-45	5 ft	5	LF	\$75	\$375	
49486	758.0 to 759.0 feet	Vertical Change	-35	5 ft	5	LF	\$75	\$375	
10933	760.0 to 819.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	295	SF	\$120	\$35,400	
50527	766.9 to 767.9 feet	Vertical Change	-32	5 ft	5	REF			
46692	775.9 to 776.9 feet	Vertical Change	-45	5 ft	5	REF			
44294	793.9 to 794.9 feet	Vertical Change	-56	5 ft	5	REF			
44921	802.9 to 803.9 feet	Vertical Change	-53	5 ft	5	REF			
43297	812.2 to 813.2 feet	Vertical Change	-62	5 ft	5	REF			
48887	820.4 to 821.4 feet	Vertical Change	-37	5 ft	5	LF	\$75	\$375	
48043	826.8 to 827.8 feet	Vertical Change	-4	5 ft	5	LF	\$75	\$375	
TOTAL COST FOR: N							<i>side of</i> WASHINGTON RD	<i>Starting at:</i> SHASTA CT	\$343,440.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908230812	WASHINGTON RD	SANTA CRUZ BLVD	WASHINGTON RD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
10935	9.9 to 13.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,980	
10937	13.2 to 22.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	46	SF	\$120	\$5,460	
10939	22.3 to 24.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200	
48044	23.5 to 24.5 feet	Vertical Change	-4	5 ft	5	REF			
50130	41.1 to 42.1 feet	Vertical Change	-33	5 ft	5	LF	\$75	\$375	
46693	49.9 to 50.9 feet	Vertical Change	-45	5 ft	5	LF	\$75	\$375	
46234	59.2 to 60.2 feet	Vertical Change	-47	5 ft	5	LF	\$75	\$375	
50922	76.8 to 77.8 feet	Vertical Change	-31	5 ft	5	LF	\$75	\$375	
50923	85.7 to 86.7 feet	Vertical Change	-31	5 ft	5	LF	\$75	\$375	
48320	95.2 to 96.2 feet	Vertical Change	-39	5 ft	5	LF	\$75	\$375	
47633	113.9 to 114.9 feet	Vertical Change	-41	5 ft	5	LF	\$75	\$375	
44732	123.7 to 124.7 feet	Vertical Change	-54	5 ft	5	SF	\$75	\$375	
46235	134.1 to 135.1 feet	Vertical Change	-47	5 ft	5	LF	\$75	\$375	
46236	146.1 to 147.1 feet	Vertical Change	-47	5 ft	5	LF	\$75	\$375	
44510	152.5 to 153.5 feet	Vertical Change	-55	5 ft	5	SF	\$75	\$375	
45595	163.5 to 164.5 feet	Vertical Change	-5	5 ft	5	SF	\$75	\$375	
46694	173.2 to 174.2 feet	Vertical Change	-45	5 ft	5	LF	\$75	\$375	
10940	182.2 to 201.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	97	SF	\$120	\$11,640	
43622	182.6 to 183.6 feet	Vertical Change	-6	5 ft	5	REF			
44295	192.6 to 193.6 feet	Vertical Change	-56	5 ft	5	REF			
44922	202.0 to 203.0 feet	Vertical Change	-53	5 ft	5	SF	\$75	\$375	
44511	211.3 to 212.3 feet	Vertical Change	-55	5 ft	5	SF	\$75	\$375	
52727	220.9 to 221.9 feet	Vertical Change	-28	5 ft	5	LF	\$75	\$375	
43023	230.3 to 231.3 feet	Vertical Change	-64	5 ft	5	REF			
44923	239.7 to 240.7 feet	Vertical Change	-53	5 ft	5	REF			
42318	249.1 to 250.1 feet	Vertical Change	-71	5 ft	5	REF			
10946	261.2 to 266.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	28	SF	\$40	\$1,140	
46695	267.8 to 268.8 feet	Vertical Change	-45	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908230812	WASHINGTON RD	SANTA CRUZ BLVD	WASHINGTON RD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
46917	286.7 to 287.7 feet	Vertical Change	-.44	5 ft	5	REF			
58486	292.3 to 317.4 feet	Driveway				REF			
48321	296.2 to 297.2 feet	Vertical Change	-.39	5 ft	5	REF			
10947	301.8 to 313.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	60	SF	\$40	\$2,420	
49175	307.5 to 308.5 feet	Vertical Change	-.36	5 ft	5	REF			
40336	313.0 to 314.9 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
48045	324.8 to 325.8 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375	
50131	334.0 to 335.0 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375	
50924	343.2 to 344.2 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
49487	352.3 to 353.3 feet	Vertical Change	-.35	5 ft	5	REF			
10950	352.6 to 366.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,160	
52258	361.1 to 362.1 feet	Vertical Change	-.29	5 ft	5	REF			
TOTAL COST FOR:		N	<i>side of</i> WASHINGTON RD	<i>Starting at:</i> SANTA CRUZ BLVD				\$39,125.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908230822	WASHINGTON RD	KITES WAY	DEFENDER ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
41806	7.8 to 8.8 feet	Vertical Change	-.84	5 ft	5	SF	\$75	\$375	
53217	10.3 to 13.7 feet	Vertical Change	-.27	5 ft	17	LF	\$75	\$1,275	
52260	22.7 to 23.7 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
46918	30.2 to 33.8 feet	Vertical Change	-.44	5 ft	18	LF	\$75	\$1,350	
50132	40.2 to 41.2 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375	
46015	47.8 to 56.3 feet	Vertical Change	-.48	5 ft	43	LF	\$75	\$3,188	
10952	49.3 to 51.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020	
51836	60.3 to 63.8 feet	Vertical Change	-.3	5 ft	18	LF	\$75	\$1,313	
10953	61.5 to 290.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	1147	SF	\$120	\$137,640	
50133	72.8 to 105.6 feet	Vertical Change	-.33	5 ft	164	REF			
48888	109.5 to 115.5 feet	Vertical Change	-.37	5 ft	30	REF			
50531	119.5 to 125.6 feet	Vertical Change	-.32	5 ft	31	REF			
51839	129.6 to 133.1 feet	Vertical Change	-.3	5 ft	18	REF			
50532	137.1 to 140.6 feet	Vertical Change	-.32	5 ft	18	REF			
53759	144.6 to 145.6 feet	Vertical Change	-.26	5 ft	5	REF			
49816	149.6 to 150.6 feet	Vertical Change	-.34	5 ft	5	REF			
54085	159.5 to 160.5 feet	Vertical Change	-.25	5 ft	5	REF			
51840	169.6 to 170.6 feet	Vertical Change	-.3	5 ft	5	REF			
47636	174.6 to 178.1 feet	Vertical Change	-.41	5 ft	18	REF			
45596	182.1 to 185.6 feet	Vertical Change	-.5	5 ft	18	REF			
51841	192.1 to 195.6 feet	Vertical Change	-.3	5 ft	18	REF			
47637	201.1 to 207.4 feet	Vertical Change	-.41	5 ft	32	REF			
53760	210.7 to 211.7 feet	Vertical Change	-.26	5 ft	5	REF			
46016	215.6 to 221.7 feet	Vertical Change	-.48	5 ft	31	REF			
50925	228.2 to 231.7 feet	Vertical Change	-.31	5 ft	18	REF			
52261	238.2 to 244.2 feet	Vertical Change	-.29	5 ft	30	REF			
50533	248.2 to 254.2 feet	Vertical Change	-.32	5 ft	30	REF			
44924	258.3 to 261.8 feet	Vertical Change	-.53	5 ft	18	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908230822	WASHINGTON RD	KITES WAY	DEFENDER ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
45107	265.8 to 271.8 feet	Vertical Change	-.52	5 ft	30	REF			
51842	275.8 to 281.8 feet	Vertical Change	-.3	5 ft	30	REF			
47142	288.3 to 309.3 feet	Vertical Change	-.43	5 ft	105	REF			
10973	290.9 to 305.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	73	SF	\$120	\$8,700	
10975	305.4 to 382.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	385	SF	\$120	\$46,200	
47639	313.3 to 316.8 feet	Vertical Change	-.41	5 ft	18	REF			
49177	323.3 to 326.9 feet	Vertical Change	-.36	5 ft	18	REF			
52262	330.8 to 331.8 feet	Vertical Change	-.29	5 ft	5	REF			
53221	335.8 to 339.4 feet	Vertical Change	-.27	5 ft	18	REF			
49819	345.3 to 346.3 feet	Vertical Change	-.34	5 ft	5	REF			
45597	350.3 to 351.3 feet	Vertical Change	-.5	5 ft	5	REF			
48892	355.4 to 361.4 feet	Vertical Change	-.37	5 ft	30	REF			
51844	365.4 to 366.4 feet	Vertical Change	-.3	5 ft	5	REF			
47391	372.8 to 386.3 feet	Vertical Change	-.42	5 ft	68	REF			
10979	382.4 to 405.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	116	SF	\$120	\$13,860	
53223	392.8 to 393.8 feet	Vertical Change	-.27	5 ft	5	REF			
52731	397.8 to 398.8 feet	Vertical Change	-.28	5 ft	5	REF			
50138	402.8 to 408.7 feet	Vertical Change	-.33	5 ft	30	REF			
10981	405.5 to 450.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	224	SF	\$120	\$26,880	
51846	415.3 to 418.7 feet	Vertical Change	-.3	5 ft	17	REF			
42596	420.2 to 421.2 feet	Vertical Change	-.68	5 ft	5	REF			
47392	425.3 to 428.8 feet	Vertical Change	-.42	5 ft	18	REF			
53225	435.7 to 436.7 feet	Vertical Change	-.27	5 ft	5	REF			
50140	440.2 to 443.8 feet	Vertical Change	-.33	5 ft	18	REF			
46470	447.8 to 453.7 feet	Vertical Change	-.46	5 ft	30	REF			
10987	455.7 to 495.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	199	SF	\$120	\$23,880	
51847	457.7 to 471.3 feet	Vertical Change	-.3	5 ft	68	REF			
53765	475.3 to 476.3 feet	Vertical Change	-.26	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230822	WASHINGTON RD	KITES WAY	DEFENDER ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
50141	480.3 to 481.3 feet	Vertical Change	-.33	5 ft	5	REF		
52732	485.2 to 502.4 feet	Vertical Change	-.28	5 ft	86	REF		
58487	493.7 to 541.3 feet	Driveway				REF		
10992	495.5 to 500.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	24	SF	\$40	\$960
10993	504.2 to 522.1 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	90	SF	\$40	\$3,580
47144	521.3 to 522.3 feet	Vertical Change	-.43	5 ft	5	REF		
10999	522.1 to 538.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	82	SF	\$40	\$3,260
53227	532.1 to 533.1 feet	Vertical Change	-.27	5 ft	5	REF		
40337	537.9 to 539.7 feet	Running Slope	6.0-7.0%	5 ft	9	REF		
48590	548.9 to 549.9 feet	Vertical Change	-.38	5 ft	5	REF		
11001	549.9 to 564.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,940
50536	564.0 to 565.0 feet	Vertical Change	-.32	5 ft	5	REF		
52733	569.1 to 570.1 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375
50930	576.5 to 585.0 feet	Vertical Change	-.31	5 ft	43	LF	\$75	\$3,188
11002	589.9 to 593.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,340
49822	591.6 to 599.9 feet	Vertical Change	-.34	5 ft	42	REF		
50538	603.9 to 609.9 feet	Vertical Change	-.32	5 ft	30	LF	\$75	\$2,250
11003	605.0 to 607.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,380
52734	614.0 to 625.0 feet	Vertical Change	-.28	5 ft	55	LF	\$75	\$4,125
11004	623.3 to 669.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	232	SF	\$120	\$27,780
51850	629.0 to 632.5 feet	Vertical Change	-.3	5 ft	18	REF		
52266	639.0 to 640.0 feet	Vertical Change	-.29	5 ft	5	REF		
50932	644.1 to 655.0 feet	Vertical Change	-.31	5 ft	55	REF		
49492	659.1 to 675.0 feet	Vertical Change	-.35	5 ft	80	REF		
11007	673.1 to 692.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	99	SF	\$120	\$11,820
50541	679.0 to 682.5 feet	Vertical Change	-.32	5 ft	18	REF		
54088	686.5 to 699.9 feet	Vertical Change	-.25	5 ft	67	REF		
11010	692.8 to 705.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	65	SF	\$120	\$7,740

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908230822	WASHINGTON RD	KITES WAY	DEFENDER ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
48325	703.9 to 714.9 feet	Vertical Change	-.39	5 ft	55	REF			
11012	705.7 to 741.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	179	SF	\$120	\$21,420	
47393	718.8 to 719.8 feet	Vertical Change	-.42	5 ft	5	REF			
50936	724.1 to 725.1 feet	Vertical Change	-.31	5 ft	5	REF			
47394	729.3 to 730.3 feet	Vertical Change	-.42	5 ft	5	REF			
48592	734.0 to 735.0 feet	Vertical Change	-.38	5 ft	5	REF			
52269	740.1 to 741.1 feet	Vertical Change	-.29	5 ft	5	REF			
11018	741.4 to 753.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	59	SF	\$120	\$7,080	
45108	745.8 to 746.8 feet	Vertical Change	-.52	5 ft	5	REF			
50146	751.8 to 752.8 feet	Vertical Change	-.33	5 ft	5	REF			
11020	753.2 to 825.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	362	SF	\$120	\$43,440	
52737	757.9 to 758.9 feet	Vertical Change	-.28	5 ft	5	REF			
49823	763.9 to 764.9 feet	Vertical Change	-.34	5 ft	5	REF			
55989	770.0 to 771.0 feet	Vertical Change	.39	5 ft	5	REF			
47640	776.0 to 777.0 feet	Vertical Change	-.41	5 ft	5	REF			
49495	782.0 to 783.0 feet	Vertical Change	-.35	5 ft	5	REF			
45307	788.0 to 789.0 feet	Vertical Change	-.51	5 ft	5	REF			
44926	793.9 to 794.9 feet	Vertical Change	-.53	5 ft	5	REF			
47145	800.0 to 801.0 feet	Vertical Change	-.43	5 ft	5	REF			
48048	805.9 to 806.9 feet	Vertical Change	-.4	5 ft	5	REF			
46017	811.8 to 812.8 feet	Vertical Change	-.48	5 ft	5	REF			
50147	817.8 to 818.8 feet	Vertical Change	-.33	5 ft	5	REF			
11033	846.6 to 852.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	30	SF	\$120	\$3,540	
48593	846.9 to 847.9 feet	Vertical Change	-.38	5 ft	5	REF			
48326	850.9 to 851.9 feet	Vertical Change	-.39	5 ft	5	REF			
11034	852.5 to 865.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,560	
48327	855.3 to 856.3 feet	Vertical Change	-.39	5 ft	5	REF			
58489	857.9 to 907.0 feet	Driveway				REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908230822	WASHINGTON RD	KITES WAY	DEFENDER ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
48328	858.8 to 862.4 feet	Vertical Change	-.39	5 ft	18	REF			
41553	863.5 to 864.5 feet	Vertical Change	-1.02	5 ft	5	REF			
11037	869.0 to 872.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	17	SF	\$40	\$660	
11039	872.3 to 878.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	30	SF	\$40	\$1,200	
45308	876.0 to 877.0 feet	Vertical Change	-.51	5 ft	5	REF			
11041	878.3 to 893.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	75	SF	\$40	\$3,000	
52738	881.1 to 882.1 feet	Vertical Change	-.28	5 ft	5	REF			
41193	886.2 to 887.2 feet	Vertical Change	-2.52	5 ft	5	REF			
46237	891.3 to 892.3 feet	Vertical Change	-.47	5 ft	5	REF			
46471	896.4 to 897.4 feet	Vertical Change	-.46	5 ft	5	REF			
11043	899.2 to 934.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	176	SF	\$40	\$7,040	
48895	901.9 to 902.9 feet	Vertical Change	-.37	5 ft	5	REF			
49824	910.3 to 911.3 feet	Vertical Change	-.34	5 ft	5	REF			
43463	915.1 to 916.1 feet	Vertical Change	-.61	5 ft	5	REF			
46698	919.5 to 920.5 feet	Vertical Change	-.45	5 ft	5	REF			
50542	925.9 to 926.9 feet	Vertical Change	-.32	5 ft	5	REF			
48594	933.1 to 934.1 feet	Vertical Change	-.38	5 ft	5	REF			
48896	937.9 to 938.9 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375	
49496	943.2 to 944.2 feet	Vertical Change	-.35	5 ft	5	REF			
11048	943.6 to 1010.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	333	SF	\$120	\$39,960	
50937	949.1 to 950.1 feet	Vertical Change	-.31	5 ft	5	REF			
52270	954.9 to 955.9 feet	Vertical Change	-.29	5 ft	5	REF			
50543	960.9 to 961.9 feet	Vertical Change	-.32	5 ft	5	REF			
53231	966.6 to 967.6 feet	Vertical Change	-.27	5 ft	5	REF			
51852	982.3 to 983.3 feet	Vertical Change	-.3	5 ft	5	REF			
53232	1007.3 to 1008.3 feet	Vertical Change	-.27	5 ft	5	REF			
11051	1014.9 to 1106.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	456	SF	\$120	\$54,660	
50148	1024.8 to 1025.8 feet	Vertical Change	-.33	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230822	WASHINGTON RD	KITES WAY	DEFENDER ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47641	1030.6 to 1031.6 feet	Vertical Change	-.41	5 ft	5	REF		
50149	1036.2 to 1037.2 feet	Vertical Change	-.33	5 ft	5	REF		
44296	1042.1 to 1043.1 feet	Vertical Change	-.56	5 ft	5	REF		
51853	1053.7 to 1054.7 feet	Vertical Change	-.3	5 ft	5	REF		
43298	1059.5 to 1060.5 feet	Vertical Change	-.62	5 ft	5	REF		
47395	1065.3 to 1066.3 feet	Vertical Change	-.42	5 ft	5	REF		
46472	1071.0 to 1072.0 feet	Vertical Change	-.46	5 ft	5	REF		
49181	1076.6 to 1077.6 feet	Vertical Change	-.36	5 ft	5	REF		
47642	1082.8 to 1083.8 feet	Vertical Change	-.41	5 ft	5	REF		
44927	1088.5 to 1089.5 feet	Vertical Change	-.53	5 ft	5	REF		
52739	1098.2 to 1099.2 feet	Vertical Change	-.28	5 ft	5	REF		
43024	1103.0 to 1104.0 feet	Vertical Change	-.64	5 ft	5	REF		
11062	1115.5 to 1116.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
43934	1116.0 to 1117.0 feet	Vertical Change	-.58	5 ft	5	REF		
11063	1125.4 to 1145.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	100	SF	\$120	\$12,000
49497	1126.1 to 1127.1 feet	Vertical Change	-.35	5 ft	5	REF		
50150	1135.7 to 1136.7 feet	Vertical Change	-.33	5 ft	5	REF		
42920	1146.0 to 1147.0 feet	Vertical Change	-.65	5 ft	5	SF	\$75	\$375
11065	1149.6 to 1152.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440
11066	1155.5 to 1179.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	120	SF	\$120	\$14,460
45309	1156.7 to 1157.7 feet	Vertical Change	-.51	5 ft	5	REF		
43161	1166.9 to 1167.9 feet	Vertical Change	-.63	5 ft	5	REF		
53233	1177.4 to 1178.4 feet	Vertical Change	-.27	5 ft	5	REF		
43299	1187.8 to 1188.8 feet	Vertical Change	-.62	5 ft	5	SF	\$75	\$375
41950	1197.9 to 1198.9 feet	Vertical Change	-.79	5 ft	5	SF	\$75	\$375
42319	1208.0 to 1209.0 feet	Vertical Change	-.71	5 ft	5	SF	\$75	\$375
53768	1248.7 to 1249.7 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
58490	1252.8 to 1289.8 feet	Driveway				REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230822	WASHINGTON RD	KITES WAY	DEFENDER ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
11067	1261.9 to 1263.2 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	6	SF	\$40	\$260
11068	1266.3 to 1283.6 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	86	SF	\$40	\$3,460
42406	1274.0 to 1275.0 feet	Vertical Change	-.7	5 ft	5	REF		
40339	1284.5 to 1285.6 feet	Running Slope	6.0-7.0%	5 ft	5	REF		
11069	1285.1 to 1286.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	8	SF	\$40	\$320
53234	1290.3 to 1291.3 feet	Vertical Change	-.27	5 ft	5	REF		
49825	1346.0 to 1347.0 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375
11070	1373.8 to 1379.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120
11071	1381.1 to 1383.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140
11072	1391.2 to 1404.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,160
49826	1395.8 to 1396.8 feet	Vertical Change	-.34	5 ft	5	REF		
41790	1445.7 to 1446.7 feet	Vertical Change	-.85	5 ft	5	SF	\$75	\$375
TOTAL COST FOR: S side of WASHINGTON RD Starting at: KITES WAY							\$581,927.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908230831	PARKRIDGE DR	SANTA CRUZ BLVD	AUTUMN WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
11073	1.4 to 10.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,640	
43162	6.1 to 7.1 feet	Vertical Change	-.63	5 ft	5	REF			
52271	11.9 to 12.9 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
42597	12.2 to 13.2 feet	Vertical Change	-.68	5 ft	5	SF	\$75	\$375	
11074	15.3 to 30.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	76	SF	\$120	\$9,060	
42059	16.1 to 17.1 feet	Vertical Change	-.76	5 ft	5	REF			
41667	19.6 to 20.6 feet	Vertical Change	-.92	5 ft	5	REF			
58491	25.8 to 51.9 feet	Driveway				REF			
43935	26.7 to 27.7 feet	Vertical Change	-.58	5 ft	5	REF			
11076	30.4 to 67.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	187	SF	\$40	\$7,480	
42598	30.6 to 32.7 feet	Vertical Change	-.68	5 ft	11	REF			
56985	31.8 to 32.8 feet	Vertical Change	.58	5 ft	5	REF			
48329	35.7 to 36.7 feet	Vertical Change	-.39	5 ft	5	REF			
43464	41.2 to 42.2 feet	Vertical Change	-.61	5 ft	5	REF			
42921	46.3 to 47.3 feet	Vertical Change	-.65	5 ft	5	REF			
43025	51.9 to 52.9 feet	Vertical Change	-.64	5 ft	5	REF			
45310	56.1 to 57.1 feet	Vertical Change	-.51	5 ft	5	REF			
43772	61.1 to 62.1 feet	Vertical Change	-.59	5 ft	5	REF			
58492	64.0 to 102.4 feet	Driveway				REF			
44297	66.8 to 67.8 feet	Vertical Change	-.56	5 ft	5	REF			
11085	67.8 to 72.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	24	SF	\$40	\$940	
45109	70.8 to 72.2 feet	Vertical Change	-.52	5 ft	7	REF			
11087	72.5 to 79.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	34	SF	\$40	\$1,360	
45110	75.1 to 76.1 feet	Vertical Change	-.52	5 ft	5	REF			
47146	79.2 to 80.2 feet	Vertical Change	-.43	5 ft	5	REF			
11089	79.3 to 99.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	99	SF	\$40	\$3,940	
49827	83.3 to 84.3 feet	Vertical Change	-.34	5 ft	5	REF			
55964	83.3 to 84.3 feet	Vertical Change	.35	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908230831	PARKRIDGE DR	SANTA CRUZ BLVD	AUTUMN WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
44116	86.9 to 87.9 feet	Vertical Change	-.57	5 ft	5	REF			
46473	90.7 to 91.7 feet	Vertical Change	-.46	5 ft	5	REF			
50151	94.2 to 95.2 feet	Vertical Change	-.33	5 ft	5	REF			
47147	98.3 to 99.3 feet	Vertical Change	-.43	5 ft	5	REF			
11093	99.0 to 151.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	261	SF	\$40	\$10,440	
47396	102.1 to 103.1 feet	Vertical Change	-.42	5 ft	5	REF			
41683	102.8 to 103.8 feet	Vertical Change	-.91	5 ft	5	REF			
52272	107.1 to 108.1 feet	Vertical Change	-.29	5 ft	5	REF			
42695	111.0 to 112.0 feet	Vertical Change	-.67	5 ft	5	REF			
49182	120.8 to 121.8 feet	Vertical Change	-.36	5 ft	5	REF			
47148	130.7 to 131.7 feet	Vertical Change	-.43	5 ft	5	REF			
45600	140.6 to 141.6 feet	Vertical Change	-.5	5 ft	5	REF			
58493	143.6 to 182.7 feet	Driveway				REF			
43163	146.7 to 147.7 feet	Vertical Change	-.63	5 ft	5	REF			
42151	150.6 to 151.6 feet	Vertical Change	-.74	5 ft	5	REF			
11105	151.2 to 162.9 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	59	SF	\$40	\$2,340	
45311	154.4 to 155.4 feet	Vertical Change	-.51	5 ft	5	REF			
43773	158.7 to 159.7 feet	Vertical Change	-.59	5 ft	5	REF			
44735	162.7 to 163.7 feet	Vertical Change	-.54	5 ft	5	REF			
11108	162.9 to 167.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	25	SF	\$40	\$980	
44736	166.7 to 167.7 feet	Vertical Change	-.54	5 ft	5	REF			
11109	167.8 to 175.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	38	SF	\$40	\$1,500	
43936	170.8 to 171.8 feet	Vertical Change	-.58	5 ft	5	REF			
11111	175.3 to 177.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	13	SF	\$40	\$500	
11113	177.8 to 180.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	15	SF	\$40	\$600	
44512	182.2 to 183.2 feet	Vertical Change	-.55	5 ft	5	REF			
11115	184.1 to 195.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	57	SF	\$120	\$6,780	
46699	186.3 to 187.3 feet	Vertical Change	-.45	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230831	PARKRIDGE DR	SANTA CRUZ BLVD	AUTUMN WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58494	189.8 to 215.5 feet	Driveway				REF		
47149	191.3 to 192.3 feet	Vertical Change	-43	5 ft	5	REF		
46474	195.3 to 196.3 feet	Vertical Change	-46	5 ft	5	REF		
11117	198.3 to 212.7 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	72	SF	\$40	\$2,880
46922	205.3 to 206.3 feet	Vertical Change	-44	5 ft	5	REF		
40340	212.3 to 213.8 feet	Running Slope	7.0-8.0%	5 ft	8	REF		
41526	215.4 to 216.4 feet	Vertical Change	-1.06	5 ft	5	REF		
11119	216.3 to 222.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	33	SF	\$40	\$1,300
42922	219.4 to 220.4 feet	Vertical Change	-.65	5 ft	5	REF		
11121	222.8 to 242.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	101	SF	\$120	\$12,060
44117	223.0 to 224.0 feet	Vertical Change	-.57	5 ft	5	REF		
43624	233.0 to 234.0 feet	Vertical Change	-.6	5 ft	5	REF		
41315	242.9 to 243.9 feet	Vertical Change	-1.51	5 ft	5	REF		
11124	242.9 to 274.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	156	SF	\$120	\$18,720
44928	252.7 to 253.7 feet	Vertical Change	-.53	5 ft	5	REF		
58495	263.5 to 306.6 feet	Driveway				REF		
47150	268.0 to 269.0 feet	Vertical Change	-43	5 ft	5	REF		
11128	274.1 to 300.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	131	SF	\$40	\$5,240
43937	276.6 to 277.6 feet	Vertical Change	-.58	5 ft	5	REF		
44737	280.9 to 281.9 feet	Vertical Change	-.54	5 ft	5	REF		
43300	284.9 to 285.9 feet	Vertical Change	-.62	5 ft	5	REF		
43465	288.9 to 289.9 feet	Vertical Change	-.61	5 ft	5	REF		
49498	292.9 to 293.9 feet	Vertical Change	-.35	5 ft	5	REF		
11132	300.3 to 302.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	12	SF	\$40	\$460
43026	301.1 to 306.4 feet	Vertical Change	-.64	5 ft	26	REF		
11134	302.6 to 305.2 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	13	SF	\$40	\$520
11135	307.8 to 308.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$660
11136	308.9 to 318.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,880

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230831	PARKRIDGE DR	SANTA CRUZ BLVD	AUTUMN WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
52273	309.5 to 310.5 feet	Vertical Change	-29	5 ft	5	REF		
58496	312.3 to 340.3 feet	Driveway				REF		
50152	312.6 to 313.6 feet	Vertical Change	-.33	5 ft	5	REF		
45111	319.3 to 320.3 feet	Vertical Change	-.52	5 ft	5	REF		
11137	322.9 to 337.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	73	SF	\$40	\$2,900
40341	337.4 to 339.3 feet	Running Slope	5.0-6.0%	5 ft	10	REF		
11139	341.8 to 343.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	10	SF	\$120	\$1,140
11140	343.7 to 406.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	315	SF	\$120	\$37,740
52740	347.8 to 348.8 feet	Vertical Change	-.28	5 ft	5	REF		
46923	355.3 to 356.3 feet	Vertical Change	-.44	5 ft	5	REF		
49499	365.8 to 366.8 feet	Vertical Change	-.35	5 ft	5	REF		
46238	376.1 to 377.1 feet	Vertical Change	-.47	5 ft	5	REF		
51854	386.3 to 387.3 feet	Vertical Change	-.3	5 ft	5	REF		
45601	396.4 to 397.4 feet	Vertical Change	-.5	5 ft	5	REF		
46475	406.2 to 412.5 feet	Vertical Change	-.46	5 ft	32	REF		
11142	406.6 to 411.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	27	SF	\$120	\$3,180
58497	407.3 to 437.5 feet	Driveway				REF		
11144	411.9 to 417.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	28	SF	\$40	\$1,100
44298	416.0 to 417.0 feet	Vertical Change	-.56	5 ft	5	REF		
11146	417.4 to 425.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	39	SF	\$40	\$1,560
11148	425.2 to 464.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	196	SF	\$40	\$7,820
42599	426.3 to 427.3 feet	Vertical Change	-.68	5 ft	5	REF		
45602	431.2 to 432.2 feet	Vertical Change	-.5	5 ft	5	REF		
48050	441.4 to 442.4 feet	Vertical Change	-.4	5 ft	5	REF		
50544	445.6 to 446.6 feet	Vertical Change	-.32	5 ft	5	REF		
48595	455.1 to 456.1 feet	Vertical Change	-.38	5 ft	5	REF		
58498	457.3 to 496.6 feet	Driveway				REF		
44739	459.7 to 460.7 feet	Vertical Change	-.54	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230831	PARKRIDGE DR	SANTA CRUZ BLVD	AUTUMN WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
48897	464.2 to 469.2 feet	Vertical Change	-.37	5 ft	25	REF		
11152	464.3 to 502.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	191	SF	\$40	\$7,640
47643	472.3 to 473.3 feet	Vertical Change	-.41	5 ft	5	REF		
46239	476.5 to 477.5 feet	Vertical Change	-.47	5 ft	5	REF		
47151	480.7 to 481.7 feet	Vertical Change	-.43	5 ft	5	REF		
47397	484.9 to 485.9 feet	Vertical Change	-.42	5 ft	5	REF		
48597	489.9 to 490.9 feet	Vertical Change	-.38	5 ft	5	REF		
44299	495.8 to 496.8 feet	Vertical Change	-.56	5 ft	5	REF		
11161	502.5 to 509.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,080
43466	505.1 to 506.1 feet	Vertical Change	-.61	5 ft	5	REF		
11163	509.3 to 539.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	151	SF	\$120	\$18,060
11168	539.4 to 551.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,200
51855	544.8 to 545.8 feet	Vertical Change	-.3	5 ft	5	REF		
11170	551.4 to 589.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	192	SF	\$120	\$23,040
50545	554.8 to 555.8 feet	Vertical Change	-.32	5 ft	5	REF		
47398	564.6 to 565.6 feet	Vertical Change	-.42	5 ft	5	REF		
50153	574.3 to 575.3 feet	Vertical Change	-.33	5 ft	5	REF		
11174	589.8 to 592.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620
44740	590.4 to 591.4 feet	Vertical Change	-.54	5 ft	5	REF		
43774	595.4 to 596.4 feet	Vertical Change	-.59	5 ft	5	SF	\$75	\$375
TOTAL COST FOR: S side of PARKRIDGE DR Starting at: SANTA CRUZ BLVD							\$217,485.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230833	PARKRIDGE DR	AUTUMN WAY	THOMAS CHIDLAW DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
11175	0.0 to 8.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	42	SF	\$120	\$4,980
41636	3.8 to 4.8 feet	Vertical Change	-.94	5 ft	5	REF		
56970	7.8 to 8.8 feet	Vertical Change	.56	5 ft	5	REF		
11178	8.3 to 13.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,820
46476	10.3 to 11.9 feet	Vertical Change	-.46	5 ft	8	REF		
11180	13.0 to 17.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	23	SF	\$120	\$2,760
11182	17.6 to 30.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,500
58499	25.6 to 49.7 feet	Driveway				REF		
47399	30.6 to 31.6 feet	Vertical Change	-.42	5 ft	5	REF		
11183	33.9 to 48.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	72	SF	\$40	\$2,880
47400	41.1 to 42.1 feet	Vertical Change	-.42	5 ft	5	REF		
40342	47.3 to 48.6 feet	Running Slope	6.0-7.0%	5 ft	7	REF		
46019	50.6 to 51.6 feet	Vertical Change	-.48	5 ft	5	LF	\$75	\$375
11187	51.9 to 69.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,260
51856	59.2 to 60.2 feet	Vertical Change	-.3	5 ft	5	REF		
11189	69.0 to 80.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	59	SF	\$120	\$7,080
58500	74.3 to 102.4 feet	Driveway				REF		
11190	83.8 to 99.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	77	SF	\$40	\$3,080
40343	97.8 to 100.2 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
11194	102.6 to 136.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	170	SF	\$120	\$20,460
45603	109.8 to 110.8 feet	Vertical Change	-.5	5 ft	5	REF		
42152	119.0 to 120.0 feet	Vertical Change	-.74	5 ft	5	REF		
52741	127.7 to 128.7 feet	Vertical Change	-.28	5 ft	5	REF		
58501	130.7 to 156.8 feet	Driveway				REF		
11200	140.4 to 154.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	72	SF	\$40	\$2,880
40344	153.4 to 155.7 feet	Running Slope	5.0-6.0%	5 ft	11	REF		
46240	157.3 to 158.3 feet	Vertical Change	-.47	5 ft	5	REF		
11203	158.5 to 174.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	78	SF	\$120	\$9,300

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230833	PARKRIDGE DR	AUTUMN WAY	THOMAS CHIDLAW DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47401	169.4 to 170.4 feet	Vertical Change	-.42	5 ft	5	REF		
11204	175.4 to 185.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$5,940
54089	180.1 to 181.1 feet	Vertical Change	-.25	5 ft	5	REF		
11206	185.3 to 210.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	128	SF	\$120	\$15,360
50938	188.0 to 189.0 feet	Vertical Change	-.31	5 ft	5	REF		
46020	195.8 to 196.8 feet	Vertical Change	-.48	5 ft	5	REF		
58502	205.7 to 231.8 feet	Driveway				REF		
52742	210.9 to 211.9 feet	Vertical Change	-.28	5 ft	5	REF		
11209	213.5 to 226.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	64	SF	\$40	\$2,560
46021	221.6 to 222.6 feet	Vertical Change	-.48	5 ft	5	REF		
11214	226.3 to 229.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	17	SF	\$40	\$660
40345	228.9 to 230.7 feet	Running Slope	5.0-6.0%	5 ft	9	REF		
41562	232.5 to 233.5 feet	Vertical Change	-1.01	5 ft	5	REF		
11215	233.8 to 245.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	57	SF	\$120	\$6,840
TOTAL COST FOR: S							side of PARKRIDGE DR Starting at: AUTUMN WAY	\$105,735.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908230835	THOMAS CHIDLAW DR	PARKRIDGE DR	CYPRESS LN					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
11216	0.0 to 6.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	31	SF	\$120	\$3,660	
58503	0.8 to 26.9 feet	Driveway				REF			
43027	5.9 to 6.9 feet	Vertical Change	-.64	5 ft	5	REF			
57294	6.0 to 7.0 feet	Vertical Change	.85	5 ft	5	REF			
11217	9.2 to 21.4 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	61	SF	\$40	\$2,440	
45604	16.3 to 17.3 feet	Vertical Change	-.5	5 ft	5	REF			
11219	21.4 to 24.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	16	SF	\$40	\$620	
40346	23.1 to 24.8 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
11220	27.8 to 29.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$900	
11221	29.3 to 59.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	151	SF	\$120	\$18,120	
58504	52.9 to 78.6 feet	Driveway				REF			
11226	63.3 to 76.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	65	SF	\$40	\$2,600	
40347	75.5 to 77.8 feet	Running Slope	5.0-6.0%	5 ft	12	REF			
52743	78.7 to 79.7 feet	Vertical Change	-.28	5 ft	5	REF			
11230	79.9 to 81.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$1,020	
11231	81.6 to 105.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	119	SF	\$120	\$14,280	
11233	105.4 to 120.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	78	SF	\$120	\$9,300	
58505	115.0 to 139.7 feet	Driveway				REF			
49828	120.8 to 121.8 feet	Vertical Change	-.34	5 ft	5	REF			
11235	124.5 to 132.3 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	39	SF	\$40	\$1,560	
11237	132.3 to 137.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	28	SF	\$40	\$1,100	
11238	140.8 to 197.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	282	SF	\$120	\$33,900	
51857	183.0 to 184.0 feet	Vertical Change	-.3	5 ft	5	REF			
58506	189.9 to 215.1 feet	Driveway				REF			
11247	200.6 to 208.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	39	SF	\$40	\$1,560	
44929	207.1 to 208.1 feet	Vertical Change	-.53	5 ft	5	REF			
11249	208.4 to 214.0 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	28	SF	\$40	\$1,120	
11251	218.1 to 265.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	236	SF	\$120	\$28,260	
53235	227.2 to 228.2 feet	Vertical Change	-.27	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908230835	THOMAS CHIDLAW DR	PARKRIDGE DR	CYPRESS LN					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
52275	237.9 to 238.9 feet	Vertical Change	-29	5 ft	5	REF			
48330	252.4 to 253.4 feet	Vertical Change	-39	5 ft	5	REF			
11259	265.2 to 281.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	83	SF	\$120	\$9,900	
50939	267.1 to 268.1 feet	Vertical Change	-31	5 ft	5	REF			
58507	276.3 to 301.7 feet	Driveway				REF			
47644	281.9 to 282.9 feet	Vertical Change	-41	5 ft	5	REF			
11261	285.2 to 299.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	71	SF	\$40	\$2,820	
48598	291.7 to 292.7 feet	Vertical Change	-38	5 ft	5	REF			
40348	298.8 to 300.3 feet	Running Slope	6.0-7.0%	5 ft	8	REF			
11263	303.1 to 314.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	56	SF	\$120	\$6,780	
11264	314.4 to 321.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320	
11266	321.6 to 338.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	82	SF	\$120	\$9,840	
58508	331.1 to 357.6 feet	Driveway				REF			
11268	341.4 to 355.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	70	SF	\$40	\$2,800	
48331	349.2 to 350.2 feet	Vertical Change	-39	5 ft	5	REF			
40349	354.4 to 356.6 feet	Running Slope	5.0-6.0%	5 ft	11	REF			
49184	357.5 to 358.5 feet	Vertical Change	-36	5 ft	5	REF			
11270	359.0 to 396.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	187	SF	\$120	\$22,440	
53769	382.0 to 383.0 feet	Vertical Change	-26	5 ft	5	REF			
58509	390.4 to 417.8 feet	Driveway				REF			
48332	397.1 to 398.1 feet	Vertical Change	-39	5 ft	5	REF			
11273	400.1 to 416.5 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	82	SF	\$40	\$3,280	
52276	407.3 to 408.3 feet	Vertical Change	-29	5 ft	5	REF			
40350	415.0 to 417.1 feet	Running Slope	5.0-6.0%	5 ft	11	REF			
49185	418.9 to 419.9 feet	Vertical Change	-36	5 ft	5	REF			
11275	419.8 to 479.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	297	SF	\$120	\$35,580	
52744	433.8 to 434.8 feet	Vertical Change	-28	5 ft	5	REF			
50940	464.2 to 465.2 feet	Vertical Change	-31	5 ft	5	REF			
58510	471.5 to 502.0 feet	Driveway				REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230835	THOMAS CHIDLAW DR	PARKRIDGE DR	CYPRESS LN	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47645	479.0 to 480.0 feet	Vertical Change	-.41	5 ft	5	REF		
11279	483.4 to 497.3 feet	Cross Slope (Driveway)	13.014	5 ft	70	SF	\$40	\$2,780
48599	490.1 to 491.1 feet	Vertical Change	-.38	5 ft	5	REF		
40351	496.7 to 499.2 feet	Running Slope	5.0-6.0%	5 ft	13	REF		
11280	502.0 to 508.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	33	SF	\$40	\$1,300
11282	508.5 to 516.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	38	SF	\$120	\$4,560
52745	515.2 to 516.2 feet	Vertical Change	-.28	5 ft	5	REF		
11283	516.1 to 518.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680
TOTAL COST FOR: E							<i>side of THOMAS CHIDLAW DR Starting at: PARKRIDGE DR</i>	\$228,520.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
S	1908230838	CYPRESS LN	THOMAS CHIDLAW DR	GILL WAY	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
11284	5.3 to 42.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	188	SF	\$120	\$22,500	
46924	7.4 to 8.4 feet	Vertical Change	-.44	5 ft	5	REF			
57287	60.4 to 61.4 feet	Vertical Change	.8	5 ft	5	SF	\$75	\$375	
11287	145.6 to 151.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,720	
58511	146.5 to 172.4 feet	Driveway				REF			
50546	151.9 to 152.9 feet	Vertical Change	-.32	5 ft	5	REF			
11288	155.3 to 166.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	56	SF	\$40	\$2,260	
11290	166.6 to 168.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	11	SF	\$40	\$420	
44930	170.7 to 171.7 feet	Vertical Change	-.53	5 ft	5	REF			
46477	187.1 to 188.1 feet	Vertical Change	-.46	5 ft	5	LF	\$75	\$375	
58512	187.3 to 213.4 feet	Driveway				REF			
11291	193.8 to 194.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200	
11292	194.8 to 210.9 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	81	SF	\$40	\$3,220	
11295	210.9 to 211.9 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200	
54090	212.7 to 213.7 feet	Vertical Change	-.25	5 ft	5	REF			
11296	213.7 to 232.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	94	SF	\$120	\$11,280	
58513	227.0 to 251.3 feet	Driveway				REF			
56911	232.6 to 233.6 feet	Vertical Change	.5	5 ft	5	REF			
11298	236.3 to 248.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	63	SF	\$40	\$2,500	
40352	248.6 to 249.8 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
11301	252.7 to 261.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$5,040	
58514	256.6 to 279.9 feet	Driveway				REF			
56946	261.3 to 262.3 feet	Vertical Change	.54	5 ft	5	REF			
11302	264.3 to 278.4 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	70	SF	\$40	\$2,820	
52277	280.4 to 281.4 feet	Vertical Change	-.29	5 ft	5	REF			
11306	302.7 to 317.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,760	
47402	303.8 to 304.8 feet	Vertical Change	-.42	5 ft	5	REF			
11307	320.2 to 324.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760	
52746	321.6 to 322.6 feet	Vertical Change	-.28	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
S	1908230838	CYPRESS LN	THOMAS CHIDLAW DR	GILL WAY	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
52747	326.3 to 327.3 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375			
11308	327.9 to 331.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860			
TOTAL COST FOR: S							<i>side of</i>	CYPRESS LN	<i>Starting at:</i>	THOMAS CHIDLAW DR	\$68,665.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908230839	GILL WAY	CYPRESS LN	VENTURA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
11309	0.0 to 3.0 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	15	SF	\$120	\$1,800
11310	3.0 to 17.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	74	SF	\$120	\$8,880
56912	4.2 to 5.2 feet	Vertical Change	.5	5 ft	5	REF		
50547	15.8 to 16.8 feet	Vertical Change	-.32	5 ft	5	REF		
11314	17.8 to 22.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	24	SF	\$120	\$2,820
53236	22.5 to 23.5 feet	Vertical Change	-.27	5 ft	5	REF		
11315	22.5 to 31.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,580
42153	55.4 to 56.4 feet	Vertical Change	-.74	5 ft	5	SF	\$75	\$375
11316	82.4 to 87.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060
57376	85.6 to 86.6 feet	Vertical Change	1.07	5 ft	5	REF		
11318	88.3 to 103.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	75	SF	\$120	\$9,000
TOTAL COST FOR: W side of GILL WAY Starting at: CYPRESS LN							\$31,515.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230843	GILL WAY	VENTURA AVE	HOWELL RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
11319	0.0 to 16.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	82	SF	\$120	\$9,780
50155	6.8 to 7.8 feet	Vertical Change	-.33	5 ft	5	REF		
48600	16.8 to 17.8 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375
46241	27.1 to 28.1 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375
11322	44.3 to 50.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,420
11323	52.3 to 64.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,200
49500	58.5 to 62.3 feet	Vertical Change	-.35	5 ft	19	REF		
11325	64.3 to 109.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	224	SF	\$120	\$26,820
49829	75.0 to 76.0 feet	Vertical Change	-.34	5 ft	5	REF		
46700	85.0 to 86.0 feet	Vertical Change	-.45	5 ft	5	REF		
52748	89.4 to 90.4 feet	Vertical Change	-.28	5 ft	5	REF		
48898	98.9 to 99.9 feet	Vertical Change	-.37	5 ft	5	REF		
11335	109.0 to 120.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,660
47646	111.9 to 112.9 feet	Vertical Change	-.41	5 ft	5	REF		
11338	139.7 to 153.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,160
43301	145.5 to 146.5 feet	Vertical Change	-.62	5 ft	5	REF		
11339	159.3 to 169.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,820
46925	162.1 to 163.1 feet	Vertical Change	-.44	5 ft	5	REF		
47152	167.1 to 168.1 feet	Vertical Change	-.43	5 ft	5	REF		
11341	169.0 to 210.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	209	SF	\$120	\$25,080
48333	177.8 to 178.8 feet	Vertical Change	-.39	5 ft	5	REF		
45112	193.7 to 194.7 feet	Vertical Change	-.52	5 ft	5	REF		
11343	210.8 to 217.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,780
58515	211.0 to 238.7 feet	Driveway				REF		
42600	211.2 to 212.2 feet	Vertical Change	-.68	5 ft	5	REF		
11345	220.2 to 235.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	76	SF	\$40	\$3,040
47153	228.7 to 229.7 feet	Vertical Change	-.43	5 ft	5	REF		
11351	239.6 to 240.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$720

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230843	GILL WAY	VENTURA AVE	HOWELL RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
11352	240.8 to 264.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	117	SF	\$120	\$14,040
46022	242.3 to 243.3 feet	Vertical Change	-.48	5 ft	5	REF		
50549	259.0 to 260.0 feet	Vertical Change	-.32	5 ft	5	REF		
11354	264.2 to 304.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	202	SF	\$120	\$24,180
52749	274.9 to 275.9 feet	Vertical Change	-.28	5 ft	5	REF		
46478	284.7 to 285.7 feet	Vertical Change	-.46	5 ft	5	REF		
46701	291.2 to 292.2 feet	Vertical Change	-.45	5 ft	5	REF		
58516	299.1 to 323.0 feet	Driveway				REF		
11360	307.9 to 314.7 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	34	SF	\$40	\$1,360
11362	314.7 to 320.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	28	SF	\$40	\$1,140
43467	322.9 to 323.9 feet	Vertical Change	-.61	5 ft	5	REF		
11363	323.7 to 362.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	195	SF	\$120	\$23,400
58517	356.7 to 383.0 feet	Driveway				REF		
11368	365.5 to 376.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	54	SF	\$40	\$2,160
11370	376.3 to 380.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	21	SF	\$40	\$820
40353	379.2 to 381.6 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
11371	383.3 to 386.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	15	SF	\$40	\$600
57332	387.7 to 388.7 feet	Vertical Change	.9	5 ft	5	SF	\$75	\$375
11372	390.3 to 403.6 feet	Cross Slope (PAR)	12.0-13.0%	5 ft	67	SF	\$120	\$7,980
41488	404.4 to 405.4 feet	Vertical Change	-1.11	5 ft	5	SF	\$75	\$375
41777	404.5 to 405.5 feet	Vertical Change	-.86	5 ft	5	SF	\$75	\$375
11375	406.7 to 424.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	88	SF	\$120	\$10,500
58518	418.2 to 443.4 feet	Driveway				REF		
43938	420.0 to 421.0 feet	Vertical Change	-.58	5 ft	5	REF		
53238	420.0 to 421.0 feet	Vertical Change	-.27	5 ft	5	REF		
53770	424.4 to 425.4 feet	Vertical Change	-.26	5 ft	5	REF		
11377	428.7 to 441.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	62	SF	\$40	\$2,480
51858	443.5 to 444.5 feet	Vertical Change	-.3	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1908230843	GILL WAY	VENTURA AVE	HOWELL RD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
11378	444.2 to 537.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	465	SF	\$120	\$55,860	
11384	537.3 to 541.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760	
TOTAL COST FOR: E							<i>side of</i> GILL WAY	<i>Starting at:</i> VENTURA AVE	\$249,635.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
W	1908230846	GILL WAY	HOWELL RD	CYPRESS LN	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
11385	0.0 to 1.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$702	
11386	1.3 to 22.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	96	SF	\$120	\$11,502	
11391	26.2 to 31.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,862	
11392	65.8 to 86.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	92	SF	\$120	\$11,070	
54	78.9 to 79.9 feet	Continuous Width		5 ft	5	SF	\$120	\$540	
58519	84.0 to 106.4 feet	Driveway				REF			
11395	90.3 to 102.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	53	SF	\$40	\$2,124	
11397	102.1 to 105.4 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	15	SF	\$40	\$594	
40354	103.4 to 104.4 feet	Running Slope	7.0-8.0%	5 ft	5	REF			
11399	105.4 to 106.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	5	SF	\$40	\$216	
57462	105.7 to 106.7 feet	Vertical Change	1.41	5 ft	5	REF			
11400	106.6 to 118.7 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	54	SF	\$120	\$6,534	
53239	118.6 to 119.6 feet	Vertical Change	-.27	5 ft	5	REF			
11403	118.7 to 119.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$594	
11404	119.8 to 120.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$594	
11405	124.6 to 135.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,832	
49501	134.7 to 135.7 feet	Vertical Change	-.35	5 ft	5	REF			
11406	151.2 to 174.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	105	SF	\$120	\$12,636	
44513	166.0 to 167.0 feet	Vertical Change	-.55	5 ft	5	REF			
58520	177.1 to 202.2 feet	Driveway				REF			
11407	184.6 to 199.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	67	SF	\$40	\$2,682	
52750	202.5 to 203.5 feet	Vertical Change	-.28	5 ft	5	REF			
58521	209.0 to 233.0 feet	Driveway				REF			
56925	213.8 to 214.8 feet	Vertical Change	.52	5 ft	5	REF			
11410	216.5 to 229.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	60	SF	\$40	\$2,394	
11414	229.8 to 230.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$180	
51859	270.9 to 271.9 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$338	
45605	304.6 to 305.6 feet	Vertical Change	-.5	5 ft	5	SF	\$75	\$338	
58522	310.3 to 336.2 feet	Driveway				REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908230846	GILL WAY	HOWELL RD	CYPRESS LN	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
53771	317.0 to 318.0 feet	Vertical Change	-.26	5 ft	5	REF		
11415	320.6 to 333.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	58	SF	\$40	\$2,340
48601	336.1 to 337.1 feet	Vertical Change	-.38	5 ft	5	REF		
58523	341.4 to 367.3 feet	Driveway				REF		
11417	346.0 to 347.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$216
11418	350.7 to 363.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	55	SF	\$40	\$2,214
11420	363.0 to 364.2 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	5	SF	\$40	\$216
46023	366.4 to 367.4 feet	Vertical Change	-.48	5 ft	5	REF		
49502	376.8 to 377.8 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$338
48334	383.5 to 384.5 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$338
48602	393.2 to 394.2 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$338
41907	399.6 to 400.6 feet	Vertical Change	-.8	5 ft	5	SF	\$75	\$338
TOTAL COST FOR: W side of GILL WAY Starting at: HOWELL RD							\$68,067.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority	
N	1908230848	CYPRESS LN	GILL WAY	HOLIDAY WAY					TBD	
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total		
43939	11.2 to 12.2 feet	Vertical Change	-.58	5 ft	5	SF	\$75	\$338		
11421	13.6 to 60.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	209	SF	\$120	\$25,110		
11425	60.1 to 75.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	70	SF	\$120	\$8,370		
53240	66.4 to 67.4 feet	Vertical Change	-.27	5 ft	5	REF				
11429	75.6 to 83.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,374		
58524	78.8 to 101.3 feet	Driveway				REF				
11431	83.7 to 84.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$198		
11432	86.7 to 99.4 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	57	SF	\$40	\$2,286		
50156	92.3 to 93.3 feet	Vertical Change	-.33	5 ft	5	REF				
11434	101.2 to 102.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$198		
11435	102.3 to 146.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	198	SF	\$120	\$23,706		
46479	104.9 to 105.9 feet	Vertical Change	-.46	5 ft	5	REF				
50551	121.0 to 122.0 feet	Vertical Change	-.32	5 ft	5	REF				
52751	137.1 to 138.1 feet	Vertical Change	-.28	5 ft	5	REF				
11440	159.0 to 179.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	91	SF	\$120	\$10,962		
11443	179.3 to 185.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	29	SF	\$120	\$3,510		
56993	185.3 to 186.3 feet	Vertical Change	.59	5 ft	5	REF				
11445	185.8 to 200.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	68	SF	\$120	\$8,100		
11448	200.8 to 203.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	11	SF	\$120	\$1,296		
TOTAL COST FOR:							N	<i>side of</i> CYPRESS LN	<i>Starting at:</i> GILL WAY	\$88,447.50

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230851	HOLIDAY WAY	CYPRESS LN	860 HOLIDAY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
11449	0.0 to 26.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	121	SF	\$120	\$14,526
41458	13.2 to 14.2 feet	Vertical Change	-1.14	5 ft	5	REF		
43302	13.2 to 14.2 feet	Vertical Change	-.62	5 ft	5	REF		
11453	26.9 to 43.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	77	SF	\$120	\$9,180
47647	27.1 to 28.1 feet	Vertical Change	-.41	5 ft	5	REF		
58525	38.3 to 60.3 feet	Driveway				REF		
40355	41.1 to 42.2 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
43028	41.8 to 42.8 feet	Vertical Change	-.64	5 ft	5	REF		
11457	45.1 to 57.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	57	SF	\$40	\$2,286
11460	61.0 to 70.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,184
58526	66.5 to 90.4 feet	Driveway				REF		
11461	75.4 to 88.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	60	SF	\$40	\$2,394
11465	92.2 to 112.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	91	SF	\$120	\$10,908
47154	112.1 to 113.1 feet	Vertical Change	-.43	5 ft	5	REF		
52279	144.0 to 145.0 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$338
11468	146.3 to 153.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,104
49503	159.6 to 160.6 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$338
11469	170.7 to 176.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,970
58527	171.8 to 195.0 feet	Driveway				REF		
52280	176.1 to 177.1 feet	Vertical Change	-.29	5 ft	5	REF		
11470	179.4 to 192.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	58	SF	\$40	\$2,322
40356	192.4 to 195.1 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
58528	201.4 to 225.5 feet	Driveway				REF		
11471	209.7 to 223.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	61	SF	\$40	\$2,430
40357	221.4 to 223.7 feet	Running Slope	5.0-6.0%	5 ft	10	REF		
48335	225.4 to 226.4 feet	Vertical Change	-.39	5 ft	5	REF		
55965	225.4 to 226.4 feet	Vertical Change	.35	5 ft	5	REF		
11473	226.9 to 272.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	206	SF	\$120	\$24,732
41991	240.3 to 241.3 feet	Vertical Change	-.78	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230851	HOLIDAY WAY	CYPRESS LN	860 HOLIDAY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44300	257.3 to 258.3 feet	Vertical Change	-.56	5 ft	5	REF		
58529	269.3 to 291.9 feet	Driveway				REF		
11475	276.2 to 290.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	63	SF	\$40	\$2,538
41668	292.3 to 293.3 feet	Vertical Change	-.92	5 ft	5	REF		
51860	303.9 to 304.9 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$338
57235	304.2 to 305.2 feet	Vertical Change	.72	5 ft	5	SF	\$75	\$338
46242	304.4 to 305.4 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$338
11478	313.1 to 320.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,158
50552	313.4 to 314.4 feet	Vertical Change	-.32	5 ft	5	REF		
48603	335.3 to 336.3 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$338
58530	348.4 to 372.9 feet	Driveway				REF		
11479	356.0 to 370.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	65	SF	\$40	\$2,610
43029	373.3 to 374.3 feet	Vertical Change	-.64	5 ft	5	REF		
53241	374.6 to 375.6 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$338
57373	378.8 to 379.8 feet	Vertical Change	1.03	5 ft	5	SF	\$75	\$338
TOTAL COST FOR: E side of HOLIDAY WAY Starting at: CYPRESS LN							\$93,042.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230853	HOLIDAY WAY	860 HOLIDAY WAY	813 HOLIDAY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
11482	0.4 to 34.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	153	SF	\$120	\$18,414
53772	2.1 to 3.1 feet	Vertical Change	-26	5 ft	5	REF		
47648	11.6 to 12.6 feet	Vertical Change	-41	5 ft	5	REF		
52281	28.6 to 29.6 feet	Vertical Change	-29	5 ft	5	REF		
53242	33.2 to 34.2 feet	Vertical Change	-27	5 ft	5	REF		
11485	34.5 to 47.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	58	SF	\$120	\$6,912
11487	47.3 to 50.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,890
11488	60.6 to 66.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,078
44301	65.1 to 66.1 feet	Vertical Change	-56	5 ft	5	REF		
TOTAL COST FOR: N side of HOLIDAY WAY Starting at: 860 HOLIDAY WAY							\$30,294.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908230855	HOLIDAY WAY	813 HOLIDAY WAY	CYPRESS LN					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
58531	0.0 to 25.6 feet	Driveway				REF			
11489	7.5 to 20.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	57	SF	\$40	\$2,286	
11491	20.2 to 22.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	11	SF	\$40	\$432	
40358	21.8 to 23.4 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
47155	25.1 to 26.1 feet	Vertical Change	-.43	5 ft	5	REF			
11492	29.5 to 31.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,296	
50553	41.8 to 42.8 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$338	
48604	51.7 to 52.7 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$338	
47403	56.5 to 57.5 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$338	
44741	70.0 to 71.0 feet	Vertical Change	-.54	5 ft	5	SF	\$75	\$338	
11493	71.9 to 78.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,780	
58532	74.9 to 103.6 feet	Driveway				REF			
47649	79.4 to 80.4 feet	Vertical Change	-.41	5 ft	5	REF			
11494	83.3 to 100.5 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	77	SF	\$40	\$3,096	
45312	86.8 to 87.8 feet	Vertical Change	-.51	5 ft	5	REF			
40359	99.8 to 101.9 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
42060	103.0 to 104.0 feet	Vertical Change	-.76	5 ft	5	REF			
11496	104.2 to 107.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	14	SF	\$40	\$540	
11497	117.1 to 130.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,128	
43030	118.6 to 119.6 feet	Vertical Change	-.64	5 ft	5	REF			
46702	129.0 to 130.0 feet	Vertical Change	-.45	5 ft	5	REF			
46024	134.3 to 135.3 feet	Vertical Change	-.48	5 ft	5	REF			
11500	135.2 to 145.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,508	
58533	142.5 to 168.7 feet	Driveway				REF			
41392	149.3 to 150.3 feet	Vertical Change	-1.29	5 ft	5	REF			
11501	152.7 to 166.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	62	SF	\$40	\$2,466	
45313	163.8 to 164.8 feet	Vertical Change	-.51	5 ft	4	REF			
40360	165.6 to 166.9 feet	Running Slope	5.0-6.0%	5 ft	6	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908230855	HOLIDAY WAY	813 HOLIDAY WAY	CYPRESS LN	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47404	168.2 to 169.2 feet	Vertical Change	-.42	5 ft	5	REF		
11504	169.4 to 170.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$180
11505	170.4 to 172.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,188
44742	171.7 to 172.7 feet	Vertical Change	-.54	5 ft	5	REF		
58534	174.5 to 198.0 feet	Driveway				REF		
11506	177.5 to 178.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$216
45606	178.8 to 179.8 feet	Vertical Change	-.5	5 ft	5	REF		
11507	182.0 to 194.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	57	SF	\$40	\$2,286
11509	198.9 to 200.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$702
58535	223.0 to 237.2 feet	Driveway				REF		
11510	231.8 to 235.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	17	SF	\$40	\$684
11511	238.9 to 243.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,592
11512	248.8 to 256.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,158
46243	249.5 to 250.5 feet	Vertical Change	-.47	5 ft	5	REF		
11513	259.3 to 267.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,428
11514	272.1 to 280.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,644
58536	276.8 to 299.3 feet	Driveway				REF		
11515	284.2 to 297.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	60	SF	\$40	\$2,412
11517	300.4 to 310.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	45	SF	\$120	\$5,454
58537	304.3 to 329.3 feet	Driveway				REF		
43164	310.5 to 311.5 feet	Vertical Change	-.63	5 ft	5	REF		
11518	313.9 to 321.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	32	SF	\$40	\$1,278
11520	321.0 to 327.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	27	SF	\$40	\$1,080
43468	329.8 to 330.8 feet	Vertical Change	-.61	5 ft	5	SF	\$75	\$338
50941	329.8 to 330.8 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$338
11521	361.5 to 367.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,294
TOTAL COST FOR: W side of HOLIDAY WAY Starting at: 813 HOLIDAY WAY							\$63,153.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908230859	CYPRESS LN	HOLIDAY WAY	OLEANDER DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
11523	0.0 to 21.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	95	SF	\$120	\$11,394	
56926	2.0 to 3.0 feet	Vertical Change	.52	5 ft	5	REF			
49830	9.6 to 10.6 feet	Vertical Change	-.34	5 ft	5	REF			
11526	21.1 to 67.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	207	SF	\$120	\$24,840	
54092	38.7 to 39.7 feet	Vertical Change	-.25	5 ft	5	REF			
58538	59.2 to 93.7 feet	Driveway				REF			
42243	64.2 to 65.2 feet	Vertical Change	-.72	5 ft	5	REF			
11534	70.1 to 73.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	15	SF	\$40	\$594	
11536	73.4 to 83.3 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	45	SF	\$40	\$1,782	
11540	83.3 to 89.9 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	30	SF	\$40	\$1,188	
44302	97.2 to 98.2 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$338	
11543	101.3 to 145.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	200	SF	\$120	\$23,976	
46025	112.2 to 113.2 feet	Vertical Change	-.48	5 ft	5	REF			
45113	138.9 to 139.9 feet	Vertical Change	-.52	5 ft	5	REF			
11549	145.7 to 220.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	334	SF	\$120	\$40,122	
45607	154.0 to 155.0 feet	Vertical Change	-.5	5 ft	5	REF			
43469	169.1 to 170.1 feet	Vertical Change	-.61	5 ft	5	REF			
43303	181.2 to 182.2 feet	Vertical Change	-.62	5 ft	5	REF			
47650	196.2 to 197.2 feet	Vertical Change	-.41	5 ft	5	REF			
43775	210.6 to 211.6 feet	Vertical Change	-.59	5 ft	5	REF			
11558	220.0 to 241.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	95	SF	\$120	\$11,394	
46026	225.1 to 226.1 feet	Vertical Change	-.48	5 ft	5	REF			
41951	242.1 to 243.1 feet	Vertical Change	-.79	5 ft	5	SF	\$75	\$338	
11559	249.5 to 252.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,836	
11560	264.2 to 275.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,886	
11561	279.9 to 288.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,752	
41842	286.0 to 287.0 feet	Vertical Change	-.82	5 ft	5	REF			
48336	295.0 to 296.0 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$338	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230859	CYPRESS LN	HOLIDAY WAY	OLEANDER DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
11562	297.3 to 299.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,188
11563	304.1 to 351.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	211	SF	\$120	\$25,326
46244	310.4 to 311.4 feet	Vertical Change	-47	5 ft	5	REF		
11565	351.0 to 360.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	44	SF	\$120	\$5,292
11567	360.8 to 380.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	89	SF	\$120	\$10,638
46480	364.9 to 365.9 feet	Vertical Change	-46	5 ft	5	REF		
48899	370.3 to 374.1 feet	Vertical Change	-37	5 ft	17	REF		
41583	379.7 to 380.7 feet	Vertical Change	-1	5 ft	5	REF		
50942	382.1 to 385.5 feet	Vertical Change	-31	5 ft	15	LF	\$75	\$1,148
11570	389.1 to 392.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,836
53243	399.0 to 400.0 feet	Vertical Change	-27	5 ft	5	LF	\$75	\$338
11571	461.8 to 469.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,266
49831	469.2 to 470.2 feet	Vertical Change	-34	5 ft	5	REF		
TOTAL COST FOR: N side of CYPRESS LN Starting at: HOLIDAY WAY							\$178,807.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908230901	CYPRESS LN	OLEANDER DR	THOMAS CHIDLAW DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
46245	0.3 to 1.3 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375	
11572	1.9 to 22.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	102	SF	\$120	\$12,240	
47405	26.9 to 27.9 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375	
11575	31.3 to 43.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	61	SF	\$120	\$7,260	
48900	36.5 to 37.5 feet	Vertical Change	-.37	5 ft	5	REF			
11577	45.7 to 53.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,560	
53244	45.9 to 46.9 feet	Vertical Change	-.27	5 ft	5	REF			
11578	55.5 to 58.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,980	
49832	74.5 to 75.5 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375	
58539	82.0 to 103.1 feet	Driveway				REF			
52752	83.9 to 84.9 feet	Vertical Change	-.28	5 ft	5	REF			
52282	88.9 to 89.9 feet	Vertical Change	-.29	5 ft	5	REF			
11579	92.5 to 101.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	47	SF	\$40	\$1,860	
48605	104.5 to 108.2 feet	Vertical Change	-.38	5 ft	19	LF	\$75	\$1,388	
11581	105.7 to 120.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	73	SF	\$120	\$8,760	
48901	111.1 to 112.6 feet	Vertical Change	-.37	5 ft	8	REF			
58540	113.6 to 139.5 feet	Driveway				REF			
48337	120.0 to 121.0 feet	Vertical Change	-.39	5 ft	5	REF			
11583	123.9 to 138.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	71	SF	\$40	\$2,840	
44514	130.3 to 131.3 feet	Vertical Change	-.55	5 ft	5	REF			
41753	140.2 to 141.2 feet	Vertical Change	-.87	5 ft	5	REF			
11585	141.4 to 144.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	16	SF	\$120	\$1,980	
11586	144.7 to 192.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	237	SF	\$120	\$28,380	
53245	151.9 to 152.9 feet	Vertical Change	-.27	5 ft	5	REF			
41952	165.6 to 166.6 feet	Vertical Change	-.79	5 ft	5	REF			
41953	180.1 to 181.1 feet	Vertical Change	-.79	5 ft	5	REF			
46926	192.1 to 193.1 feet	Vertical Change	-.44	5 ft	5	LF	\$75	\$375	
58541	194.9 to 221.3 feet	Driveway				REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230901	CYPRESS LN	OLEANDER DR	THOMAS CHIDLAW DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47651	200.9 to 201.9 feet	Vertical Change	-.41	5 ft	5	REF		
11590	204.7 to 219.9 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	76	SF	\$40	\$3,040
43940	210.1 to 211.1 feet	Vertical Change	-.58	5 ft	5	REF		
40361	218.1 to 219.2 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
48051	221.3 to 222.3 feet	Vertical Change	-.4	5 ft	5	REF		
11592	221.3 to 222.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$220
11593	223.0 to 271.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	241	SF	\$120	\$28,920
46481	230.7 to 231.7 feet	Vertical Change	-.46	5 ft	5	REF		
42407	243.3 to 244.3 feet	Vertical Change	-.7	5 ft	5	REF		
58542	264.6 to 290.0 feet	Driveway				REF		
11601	274.6 to 288.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	69	SF	\$40	\$2,780
53774	281.2 to 282.2 feet	Vertical Change	-.26	5 ft	5	REF		
40362	287.4 to 289.6 feet	Running Slope	5.0-6.0%	5 ft	11	REF		
11604	293.6 to 312.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	95	SF	\$120	\$11,460
46028	301.1 to 302.1 feet	Vertical Change	-.48	5 ft	5	REF		
46482	310.9 to 311.9 feet	Vertical Change	-.46	5 ft	5	REF		
11606	312.7 to 326.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	71	SF	\$120	\$8,460
TOTAL COST FOR: S							side of CYPRESS LN Starting at: OLEANDER DR	\$127,627.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908230902	THOMAS CHIDLAW DR	CYPRESS LN	MAGNOLIA CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
11608	0.0 to 27.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	137	SF	\$120	\$16,440	
42501	21.3 to 22.3 feet	Vertical Change	-.69	5 ft	5	REF			
11611	31.8 to 36.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,940	
46483	33.8 to 34.8 feet	Vertical Change	-.46	5 ft	5	REF			
11612	39.9 to 80.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	201	SF	\$120	\$24,120	
52753	48.3 to 49.3 feet	Vertical Change	-.28	5 ft	5	REF			
51861	62.4 to 63.4 feet	Vertical Change	-.3	5 ft	5	REF			
11614	80.1 to 93.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	66	SF	\$120	\$7,920	
11618	93.3 to 175.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	413	SF	\$120	\$49,560	
50555	108.4 to 109.4 feet	Vertical Change	-.32	5 ft	5	REF			
53775	138.5 to 139.5 feet	Vertical Change	-.26	5 ft	5	REF			
50157	167.4 to 168.4 feet	Vertical Change	-.33	5 ft	5	REF			
11632	175.9 to 184.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	43	SF	\$120	\$5,160	
11634	184.5 to 187.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560	
TOTAL COST FOR: W							<i>side of THOMAS CHIDLAW DR Starting at: CYPRESS LN</i>	\$107,700.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N / W	1908230904	MAGNOLIA CT	THOMAS CHIDLAW DR	1606 MAGNOLIA CT	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
11635	1.0 to 19.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	92	SF	\$120	\$11,040	
52754	5.9 to 6.9 feet	Vertical Change	-.28	5 ft	5	REF			
58543	13.8 to 40.3 feet	Driveway				REF			
52755	19.0 to 20.0 feet	Vertical Change	-.28	5 ft	5	REF			
11639	22.4 to 37.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	74	SF	\$40	\$2,980	
50943	28.7 to 29.7 feet	Vertical Change	-.31	5 ft	5	REF			
40363	36.7 to 38.8 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
11642	40.9 to 51.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	52	SF	\$120	\$6,180	
11643	51.2 to 72.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	106	SF	\$120	\$12,660	
11647	72.3 to 96.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	119	SF	\$120	\$14,280	
53246	75.0 to 76.0 feet	Vertical Change	-.27	5 ft	5	REF			
44931	86.2 to 87.2 feet	Vertical Change	-.53	5 ft	5	REF			
11649	96.1 to 103.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,200	
58544	98.2 to 125.1 feet	Driveway				REF			
45608	103.3 to 104.3 feet	Vertical Change	-.5	5 ft	5	REF			
11650	107.2 to 122.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	79	SF	\$40	\$3,140	
42601	113.9 to 114.9 feet	Vertical Change	-.68	5 ft	5	REF			
40364	121.7 to 124.0 feet	Running Slope	5.0-6.0%	5 ft	12	REF			
43626	125.0 to 126.0 feet	Vertical Change	-.6	5 ft	5	REF			
11654	126.6 to 145.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	92	SF	\$120	\$11,040	
44743	135.5 to 136.5 feet	Vertical Change	-.54	5 ft	5	REF			
58545	140.3 to 164.8 feet	Driveway				REF			
42804	145.3 to 146.3 feet	Vertical Change	-.66	5 ft	5	REF			
11657	149.9 to 164.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	75	SF	\$40	\$2,980	
43304	156.3 to 157.3 feet	Vertical Change	-.62	5 ft	5	REF			
TOTAL COST FOR: N / W side of MAGNOLIA CT Starting at: THOMAS CHIDLAW DR							\$68,500.00		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W / S	1908230906	MAGNOLIA CT	1607 MAGNOLIA CT	THOMAS CHIDLAW DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
11662	0.0 to 14.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	73	SF	\$120	\$8,760	
42154	2.3 to 3.3 feet	Vertical Change	-.74	5 ft	5	REF			
58546	9.2 to 35.0 feet	Driveway				REF			
41710	14.1 to 15.1 feet	Vertical Change	-.89	5 ft	5	REF			
11665	17.4 to 21.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	21	SF	\$40	\$820	
11667	21.5 to 33.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	59	SF	\$40	\$2,360	
41807	24.9 to 25.9 feet	Vertical Change	-.84	5 ft	5	REF			
41629	35.7 to 36.7 feet	Vertical Change	-.95	5 ft	5	SF	\$75	\$375	
11669	36.9 to 68.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	160	SF	\$120	\$19,140	
42155	46.9 to 47.9 feet	Vertical Change	-.74	5 ft	5	REF			
42696	59.0 to 60.0 feet	Vertical Change	-.67	5 ft	5	REF			
58547	62.3 to 89.8 feet	Driveway				REF			
41596	69.2 to 70.2 feet	Vertical Change	-.99	5 ft	5	REF			
11673	72.8 to 87.1 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	72	SF	\$40	\$2,860	
44744	79.3 to 80.3 feet	Vertical Change	-.54	5 ft	5	REF			
11677	91.4 to 112.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	104	SF	\$120	\$12,480	
52756	102.0 to 103.0 feet	Vertical Change	-.28	5 ft	5	REF			
11680	112.2 to 137.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	125	SF	\$120	\$15,000	
42697	113.3 to 114.3 feet	Vertical Change	-.67	5 ft	5	REF			
58548	131.2 to 155.9 feet	Driveway				REF			
42805	137.4 to 138.4 feet	Vertical Change	-.66	5 ft	5	REF			
11682	141.1 to 154.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	66	SF	\$40	\$2,640	
42244	147.2 to 148.2 feet	Vertical Change	-.72	5 ft	5	REF			
40365	153.8 to 155.4 feet	Running Slope	6.0-7.0%	5 ft	8	REF			
41454	157.1 to 158.1 feet	Vertical Change	-1.15	5 ft	5	REF			
11685	158.0 to 175.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	87	SF	\$120	\$10,380	
50556	169.6 to 170.6 feet	Vertical Change	-.32	5 ft	5	REF			
TOTAL COST FOR: W / S side of MAGNOLIA CT Starting at: 1607 MAGNOLIA CT								\$74,815.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908230907	THOMAS CHIDLAW DR	MAGNOLIA CT	PARKRIDGE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
11687	0.0 to 71.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	357	SF	\$120	\$42,780
49504	8.0 to 9.0 feet	Vertical Change	-35	5 ft	5	REF		
46703	19.7 to 20.7 feet	Vertical Change	-45	5 ft	5	REF		
49505	30.7 to 31.7 feet	Vertical Change	-35	5 ft	5	REF		
49833	44.3 to 45.3 feet	Vertical Change	-34	5 ft	5	REF		
44304	57.6 to 58.6 feet	Vertical Change	-56	5 ft	5	REF		
58549	64.5 to 96.6 feet	Driveway				REF		
49186	71.2 to 72.2 feet	Vertical Change	-36	5 ft	5	REF		
11696	74.6 to 91.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	84	SF	\$40	\$3,340
50158	80.3 to 81.3 feet	Vertical Change	-33	5 ft	5	REF		
49506	89.4 to 90.4 feet	Vertical Change	-35	5 ft	5	REF		
11699	91.3 to 94.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	15	SF	\$40	\$600
40366	93.8 to 95.1 feet	Running Slope	5.0-6.0%	5 ft	7	REF		
11701	97.8 to 129.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	160	SF	\$120	\$19,200
48902	98.1 to 99.1 feet	Vertical Change	-37	5 ft	5	REF		
53776	111.8 to 112.8 feet	Vertical Change	-26	5 ft	5	REF		
11703	129.8 to 178.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	242	SF	\$120	\$29,100
46029	167.1 to 168.1 feet	Vertical Change	-48	5 ft	5	REF		
11706	178.3 to 181.3 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	15	SF	\$120	\$1,800
11707	181.3 to 184.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	18	SF	\$120	\$2,100
11709	184.8 to 186.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	10	SF	\$120	\$1,200
TOTAL COST FOR: W side of THOMAS CHIDLAW DR Starting at: MAGNOLIA CT							\$100,120.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908230909	PARKRIDGE DR	THOMAS CHIDLAW DR	OLEANDER DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
11710	0.0 to 6.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,960	
11712	6.6 to 34.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	137	SF	\$120	\$16,440	
53247	17.6 to 18.6 feet	Vertical Change	-27	5 ft	5	REF			
11714	34.0 to 39.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,420	
58550	34.5 to 57.9 feet	Driveway				REF			
11715	43.4 to 56.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	66	SF	\$40	\$2,620	
43470	48.8 to 49.8 feet	Vertical Change	-61	5 ft	5	REF			
41554	59.1 to 60.1 feet	Vertical Change	-1.02	5 ft	5	SF	\$75	\$375	
11716	60.4 to 124.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	319	SF	\$120	\$38,220	
43305	74.9 to 75.9 feet	Vertical Change	-62	5 ft	5	REF			
41992	89.9 to 90.9 feet	Vertical Change	-78	5 ft	5	REF			
45609	105.0 to 106.0 feet	Vertical Change	-5	5 ft	5	REF			
42408	114.7 to 115.7 feet	Vertical Change	-7	5 ft	5	REF			
58551	117.9 to 143.9 feet	Driveway				REF			
53248	119.7 to 120.7 feet	Vertical Change	-27	5 ft	5	REF			
11720	124.1 to 125.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	6	SF	\$40	\$220	
46030	124.8 to 126.9 feet	Vertical Change	-48	5 ft	11	REF			
11721	127.8 to 142.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	75	SF	\$40	\$3,000	
43776	134.7 to 135.7 feet	Vertical Change	-59	5 ft	5	REF			
44932	143.7 to 145.7 feet	Vertical Change	-53	5 ft	10	REF			
11725	145.8 to 150.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	25	SF	\$120	\$3,000	
11726	150.8 to 180.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	146	SF	\$120	\$17,580	
48903	151.3 to 152.3 feet	Vertical Change	-37	5 ft	5	REF			
58552	173.2 to 199.3 feet	Driveway				REF			
52757	180.1 to 181.1 feet	Vertical Change	-28	5 ft	5	REF			
11729	184.0 to 197.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	70	SF	\$40	\$2,780	
11732	200.8 to 202.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,020	
11733	202.5 to 217.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,820	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230909	PARKRIDGE DR	THOMAS CHIDLAW DR	OLEANDER DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
48904	214.4 to 217.2 feet	Vertical Change	-.37	5 ft	14	REF		
58553	218.7 to 237.7 feet	Driveway				REF		
46704	223.2 to 224.2 feet	Vertical Change	-.45	5 ft	5	REF		
11734	225.4 to 236.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	54	SF	\$40	\$2,140
40367	233.3 to 235.6 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
11738	236.1 to 237.1 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	5	SF	\$40	\$200
11739	238.0 to 239.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	9	SF	\$40	\$340
11752	266.2 to 304.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	192	SF	\$120	\$23,040
53250	272.2 to 273.2 feet	Vertical Change	-.27	5 ft	5	REF		
47652	282.1 to 283.1 feet	Vertical Change	-.41	5 ft	5	REF		
41954	292.1 to 293.1 feet	Vertical Change	-.79	5 ft	5	REF		
47406	302.0 to 303.0 feet	Vertical Change	-.42	5 ft	5	REF		
11754	304.6 to 326.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	108	SF	\$120	\$12,900
43941	312.1 to 313.1 feet	Vertical Change	-.58	5 ft	5	REF		
41541	321.7 to 322.7 feet	Vertical Change	-1.04	5 ft	5	REF		
TOTAL COST FOR: N side of PARKRIDGE DR Starting at: THOMAS CHIDLAW DR							\$140,075.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1908230912	OLEANDER DR	PARKRIDGE DR	CYPRESS LN	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
11757	0.0 to 32.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	160	SF	\$120	\$19,200	
41459	6.4 to 7.4 feet	Vertical Change	-1.14	5 ft	5	REF			
47407	13.9 to 14.9 feet	Vertical Change	-.42	5 ft	5	REF			
43471	21.6 to 22.6 feet	Vertical Change	-.61	5 ft	5	REF			
58555	24.7 to 53.0 feet	Driveway				REF			
50160	27.4 to 28.4 feet	Vertical Change	-.33	5 ft	5	REF			
41520	31.3 to 32.3 feet	Vertical Change	-1.07	5 ft	5	REF			
11759	32.9 to 34.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	7	SF	\$40	\$280	
11760	34.3 to 36.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	11	SF	\$40	\$440	
11761	36.5 to 47.9 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	57	SF	\$40	\$2,280	
46246	37.5 to 38.5 feet	Vertical Change	-.47	5 ft	5	REF			
47156	47.1 to 48.1 feet	Vertical Change	-.43	5 ft	5	REF			
11764	47.9 to 53.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	28	SF	\$40	\$1,120	
44515	52.2 to 53.2 feet	Vertical Change	-.55	5 ft	5	REF			
11767	54.4 to 61.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	33	SF	\$120	\$3,960	
43942	56.2 to 57.2 feet	Vertical Change	-.58	5 ft	5	REF			
11769	61.0 to 70.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,880	
54093	62.2 to 63.2 feet	Vertical Change	-.25	5 ft	5	REF			
58556	64.2 to 103.1 feet	Driveway				REF			
44305	67.6 to 68.6 feet	Vertical Change	-.56	5 ft	5	REF			
44306	71.7 to 72.7 feet	Vertical Change	-.56	5 ft	5	REF			
11771	72.4 to 77.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	26	SF	\$40	\$1,060	
46705	76.6 to 77.6 feet	Vertical Change	-.45	5 ft	5	REF			
56630	76.7 to 77.7 feet	Vertical Change	.45	5 ft	5	REF			
11774	77.7 to 80.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	14	SF	\$40	\$540	
44516	80.4 to 81.4 feet	Vertical Change	-.55	5 ft	5	REF			
11775	80.4 to 87.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	33	SF	\$40	\$1,340	
43943	83.5 to 84.5 feet	Vertical Change	-.58	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230912	OLEANDER DR	PARKRIDGE DR	CYPRESS LN	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
11777	87.1 to 90.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	18	SF	\$40	\$700
44517	87.8 to 88.8 feet	Vertical Change	-.55	5 ft	5	REF		
11779	90.6 to 100.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	48	SF	\$40	\$1,900
43944	91.6 to 92.6 feet	Vertical Change	-.58	5 ft	5	REF		
43945	95.1 to 96.1 feet	Vertical Change	-.58	5 ft	5	REF		
43946	99.6 to 100.6 feet	Vertical Change	-.58	5 ft	5	REF		
11781	100.1 to 105.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	26	SF	\$40	\$1,020
45610	103.9 to 104.9 feet	Vertical Change	-.5	5 ft	5	REF		
11785	106.1 to 119.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,160
47408	112.2 to 113.2 feet	Vertical Change	-.42	5 ft	5	REF		
50161	122.1 to 123.1 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375
48052	132.1 to 133.1 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375
53251	142.1 to 143.1 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
58557	145.6 to 181.8 feet	Driveway				REF		
11786	150.5 to 151.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$280
47157	151.9 to 152.9 feet	Vertical Change	-.43	5 ft	5	REF		
11787	155.7 to 169.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	67	SF	\$40	\$2,660
45114	160.0 to 161.0 feet	Vertical Change	-.52	5 ft	5	REF		
44118	167.4 to 168.4 feet	Vertical Change	-.57	5 ft	5	REF		
11789	169.0 to 181.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	62	SF	\$40	\$2,460
43307	175.3 to 176.3 feet	Vertical Change	-.62	5 ft	5	REF		
43947	183.1 to 184.1 feet	Vertical Change	-.58	5 ft	5	SF	\$75	\$375
11792	184.4 to 206.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	108	SF	\$120	\$12,960
44745	189.6 to 190.6 feet	Vertical Change	-.54	5 ft	5	REF		
52283	196.3 to 197.3 feet	Vertical Change	-.29	5 ft	5	REF		
58558	196.8 to 226.5 feet	Driveway				REF		
43165	200.9 to 201.9 feet	Vertical Change	-.63	5 ft	5	REF		
45115	205.9 to 206.9 feet	Vertical Change	-.52	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230912	OLEANDER DR	PARKRIDGE DR	CYPRESS LN	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
11794	206.0 to 208.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	10	SF	\$40	\$400
11796	208.0 to 211.7 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	19	SF	\$40	\$740
44746	211.1 to 212.1 feet	Vertical Change	-.54	5 ft	5	REF		
11797	211.7 to 222.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	54	SF	\$40	\$2,160
43948	216.1 to 217.1 feet	Vertical Change	-.58	5 ft	5	REF		
44933	220.9 to 221.9 feet	Vertical Change	-.53	5 ft	5	REF		
11798	222.5 to 224.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	12	SF	\$40	\$460
11799	224.8 to 228.1 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	17	SF	\$40	\$660
41754	226.1 to 227.1 feet	Vertical Change	-.87	5 ft	5	REF		
11801	228.1 to 231.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	17	SF	\$120	\$1,980
11802	231.4 to 250.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	94	SF	\$120	\$11,220
46031	232.0 to 233.0 feet	Vertical Change	-.48	5 ft	5	REF		
48607	238.9 to 239.9 feet	Vertical Change	-.38	5 ft	5	REF		
43949	248.5 to 249.5 feet	Vertical Change	-.58	5 ft	5	REF		
11805	254.8 to 296.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	208	SF	\$120	\$24,900
42101	258.2 to 259.2 feet	Vertical Change	-.75	5 ft	5	REF		
43031	268.1 to 269.1 feet	Vertical Change	-.64	5 ft	5	REF		
42602	277.7 to 278.7 feet	Vertical Change	-.68	5 ft	5	REF		
43308	287.4 to 288.4 feet	Vertical Change	-.62	5 ft	5	REF		
58559	289.1 to 316.8 feet	Driveway				REF		
41325	296.8 to 297.8 feet	Vertical Change	-1.48	5 ft	5	REF		
11808	299.7 to 315.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	77	SF	\$40	\$3,080
44119	306.8 to 307.8 feet	Vertical Change	-.57	5 ft	5	REF		
44518	316.9 to 317.9 feet	Vertical Change	-.55	5 ft	5	REF		
11810	318.4 to 320.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,080
11811	320.2 to 341.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	104	SF	\$120	\$12,480
44934	329.1 to 330.1 feet	Vertical Change	-.53	5 ft	5	REF		
58560	330.6 to 374.1 feet	Driveway				REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908230912	OLEANDER DR	PARKRIDGE DR	CYPRESS LN					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
44519	340.7 to 341.7 feet	Vertical Change	-.55	5 ft	5	REF			
11813	341.0 to 370.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	147	SF	\$40	\$5,880	
48053	344.9 to 345.9 feet	Vertical Change	-.4	5 ft	5	REF			
45116	348.9 to 349.9 feet	Vertical Change	-.52	5 ft	5	REF			
47158	352.9 to 353.9 feet	Vertical Change	-.43	5 ft	5	REF			
47653	356.8 to 357.8 feet	Vertical Change	-.41	5 ft	5	REF			
46927	360.7 to 361.7 feet	Vertical Change	-.44	5 ft	5	REF			
48338	364.7 to 365.7 feet	Vertical Change	-.39	5 ft	5	REF			
11817	370.4 to 373.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	14	SF	\$40	\$560	
54094	370.8 to 371.8 feet	Vertical Change	-.25	5 ft	5	REF			
11818	373.2 to 374.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200	
11819	375.0 to 378.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	19	SF	\$120	\$2,280	
11820	378.8 to 382.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,920	
49507	380.2 to 381.2 feet	Vertical Change	-.35	5 ft	5	REF			
53252	386.5 to 387.5 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
52758	396.0 to 397.0 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
11821	400.3 to 407.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,500	
58561	400.6 to 426.6 feet	Driveway				REF			
50162	401.1 to 402.1 feet	Vertical Change	-.33	5 ft	5	REF			
11823	407.8 to 423.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	78	SF	\$40	\$3,120	
45819	410.9 to 411.9 feet	Vertical Change	-.49	5 ft	5	REF			
43166	415.8 to 416.8 feet	Vertical Change	-.63	5 ft	5	REF			
44120	421.1 to 425.1 feet	Vertical Change	-.57	5 ft	20	REF			
11827	423.4 to 425.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	11	SF	\$40	\$440	
11828	425.6 to 426.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200	
11829	427.4 to 449.7 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	112	SF	\$40	\$4,460	
50944	430.7 to 433.8 feet	Vertical Change	-.31	5 ft	16	REF			
49834	442.2 to 443.2 feet	Vertical Change	-.34	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1908230912	OLEANDER DR	PARKRIDGE DR	CYPRESS LN	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
11830	449.7 to 456.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,900	
48905	451.6 to 452.6 feet	Vertical Change	-.37	5 ft	5	REF			
46247	456.0 to 457.0 feet	Vertical Change	-.47	5 ft	5	REF			
TOTAL COST FOR: E							<i>side of</i> OLEANDER DR	<i>Starting at:</i> PARKRIDGE DR	\$155,110.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908230914	OLEANDER DR	CYPRESS LN	HOWELL RD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
53253	6.0 to 7.0 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375	
48608	14.1 to 15.1 feet	Vertical Change	-.38	5 ft	5	LF	\$75	\$375	
58562	14.7 to 54.8 feet	Driveway				REF			
52759	17.5 to 18.5 feet	Vertical Change	-.28	5 ft	5	REF			
11831	22.1 to 27.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	29	SF	\$40	\$1,160	
53777	26.4 to 27.4 feet	Vertical Change	-.26	5 ft	5	REF			
52760	34.4 to 35.4 feet	Vertical Change	-.28	5 ft	5	REF			
49508	42.3 to 43.3 feet	Vertical Change	-.35	5 ft	5	REF			
11833	47.8 to 55.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	38	SF	\$40	\$1,520	
47654	50.2 to 51.2 feet	Vertical Change	-.41	5 ft	5	REF			
52761	54.5 to 55.5 feet	Vertical Change	-.28	5 ft	5	REF			
11836	58.6 to 66.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,560	
43627	66.1 to 67.1 feet	Vertical Change	-.6	5 ft	5	REF			
58563	67.8 to 98.2 feet	Driveway				REF			
47409	71.0 to 72.0 feet	Vertical Change	-.42	5 ft	5	REF			
11837	73.7 to 76.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	15	SF	\$40	\$600	
45820	75.4 to 76.4 feet	Vertical Change	-.49	5 ft	5	REF			
11839	76.7 to 95.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	94	SF	\$40	\$3,740	
41869	80.9 to 81.9 feet	Vertical Change	-.81	5 ft	5	REF			
41482	86.0 to 87.0 feet	Vertical Change	-1.12	5 ft	5	REF			
43472	90.9 to 91.9 feet	Vertical Change	-.61	5 ft	5	REF			
11841	95.4 to 104.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	46	SF	\$40	\$1,840	
41300	95.9 to 96.9 feet	Vertical Change	-1.57	5 ft	5	REF			
42923	96.9 to 97.9 feet	Vertical Change	-.65	5 ft	5	REF			
42061	103.5 to 104.5 feet	Vertical Change	-.76	5 ft	5	REF			
43309	110.4 to 111.4 feet	Vertical Change	-.62	5 ft	5	SF	\$75	\$375	
42102	119.9 to 120.9 feet	Vertical Change	-.75	5 ft	5	SF	\$75	\$375	
47410	129.5 to 130.5 feet	Vertical Change	-.42	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230914	OLEANDER DR	CYPRESS LN	HOWELL RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
11842	129.6 to 163.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	168	SF	\$120	\$20,100
42409	139.3 to 140.3 feet	Vertical Change	-.7	5 ft	5	REF		
44935	148.8 to 149.8 feet	Vertical Change	-.53	5 ft	5	REF		
43167	158.5 to 159.5 feet	Vertical Change	-.63	5 ft	5	REF		
44307	163.1 to 164.1 feet	Vertical Change	-.56	5 ft	5	REF		
58564	163.9 to 186.3 feet	Driveway				REF		
41449	167.6 to 168.6 feet	Vertical Change	-1.16	5 ft	5	REF		
11843	171.2 to 179.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	43	SF	\$40	\$1,720
42245	176.7 to 177.7 feet	Vertical Change	-.72	5 ft	5	REF		
11845	179.8 to 184.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	22	SF	\$40	\$860
40368	183.7 to 185.0 feet	Running Slope	6.0-7.0%	5 ft	7	REF		
44520	186.1 to 187.1 feet	Vertical Change	-.55	5 ft	5	REF		
43629	205.9 to 206.9 feet	Vertical Change	-.6	5 ft	5	SF	\$75	\$375
58566	206.7 to 244.3 feet	Driveway				REF		
43310	210.8 to 214.1 feet	Vertical Change	-.62	5 ft	17	REF		
56994	213.2 to 214.2 feet	Vertical Change	.59	5 ft	5	REF		
11851	213.3 to 216.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	14	SF	\$40	\$560
43778	215.4 to 216.4 feet	Vertical Change	-.59	5 ft	5	REF		
44521	219.7 to 220.7 feet	Vertical Change	-.55	5 ft	5	REF		
43630	224.0 to 225.0 feet	Vertical Change	-.6	5 ft	5	REF		
11852	224.6 to 234.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	50	SF	\$40	\$2,000
43032	228.1 to 229.1 feet	Vertical Change	-.64	5 ft	5	REF		
43033	232.1 to 233.1 feet	Vertical Change	-.64	5 ft	5	REF		
42924	235.8 to 236.8 feet	Vertical Change	-.65	5 ft	5	REF		
11853	238.8 to 250.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	59	SF	\$40	\$2,360
43631	240.2 to 241.2 feet	Vertical Change	-.6	5 ft	5	REF		
45315	243.8 to 244.8 feet	Vertical Change	-.51	5 ft	5	REF		
57130	243.9 to 244.9 feet	Vertical Change	.61	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230914	OLEANDER DR	CYPRESS LN	HOWELL RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41209	244.6 to 245.6 feet	Vertical Change	-2.32	5 ft	5	REF		
47411	249.1 to 250.1 feet	Vertical Change	-.42	5 ft	5	REF		
52284	253.4 to 254.4 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375
44522	262.6 to 263.6 feet	Vertical Change	-.55	5 ft	5	SF	\$75	\$375
45611	272.4 to 273.4 feet	Vertical Change	-.5	5 ft	5	SF	\$75	\$375
48054	282.1 to 283.1 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375
58567	282.7 to 324.4 feet	Driveway				REF		
54095	287.2 to 288.2 feet	Vertical Change	-.25	5 ft	5	REF		
11856	290.4 to 304.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	72	SF	\$40	\$2,880
41733	291.4 to 292.4 feet	Vertical Change	-.88	5 ft	5	REF		
46248	295.6 to 296.6 feet	Vertical Change	-.47	5 ft	5	REF		
45612	299.9 to 300.9 feet	Vertical Change	-.5	5 ft	5	REF		
45613	304.0 to 305.0 feet	Vertical Change	-.5	5 ft	5	REF		
44936	307.9 to 308.9 feet	Vertical Change	-.53	5 ft	5	REF		
11859	310.6 to 322.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	61	SF	\$40	\$2,440
44937	311.8 to 312.8 feet	Vertical Change	-.53	5 ft	5	REF		
44308	315.9 to 316.9 feet	Vertical Change	-.56	5 ft	5	REF		
44523	319.9 to 320.9 feet	Vertical Change	-.55	5 ft	5	REF		
50163	329.0 to 330.0 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375
49836	339.8 to 340.8 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375
58568	341.1 to 371.0 feet	Driveway				REF		
11862	350.8 to 359.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	45	SF	\$40	\$1,800
44747	354.3 to 355.3 feet	Vertical Change	-.54	5 ft	5	REF		
41955	359.5 to 360.5 feet	Vertical Change	-.79	5 ft	5	REF		
43632	364.5 to 365.5 feet	Vertical Change	-.6	5 ft	5	REF		
11863	366.0 to 369.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	16	SF	\$40	\$620
11865	369.1 to 372.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	18	SF	\$40	\$720
11867	372.7 to 386.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,160

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230914	OLEANDER DR	CYPRESS LN	HOWELL RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
43473	374.6 to 375.6 feet	Vertical Change	-.61	5 ft	5	REF		
42603	382.2 to 383.2 feet	Vertical Change	-.68	5 ft	5	REF		
11869	386.3 to 395.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	48	SF	\$120	\$5,700
42806	394.9 to 395.9 feet	Vertical Change	-.66	5 ft	5	REF		
11871	395.8 to 397.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200
TOTAL COST FOR: E side of OLEANDER DR Starting at: CYPRESS LN							\$68,665.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908230916	OLEANDER DR	HOWELL RD	PEACH DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
11872	4.0 to 7.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220
42320	7.5 to 8.5 feet	Vertical Change	-71	5 ft	5	REF		
51862	9.8 to 13.1 feet	Vertical Change	-3	5 ft	16	LF	\$75	\$1,238
49509	19.1 to 22.5 feet	Vertical Change	-35	5 ft	17	LF	\$75	\$1,275
50164	26.4 to 27.4 feet	Vertical Change	-33	5 ft	5	LF	\$75	\$375
45316	33.8 to 34.8 feet	Vertical Change	-51	5 ft	5	SF	\$75	\$375
53778	103.6 to 104.6 feet	Vertical Change	-26	5 ft	5	LF	\$75	\$375
52285	120.5 to 121.5 feet	Vertical Change	-29	5 ft	5	LF	\$75	\$375
53779	125.3 to 126.3 feet	Vertical Change	-26	5 ft	5	LF	\$75	\$375
11873	175.2 to 179.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700

TOTAL COST FOR:	W	<i>side of</i>	OLEANDER DR	<i>Starting at:</i>	HOWELL RD	\$9,307.50
------------------------	----------	----------------	--------------------	---------------------	------------------	-------------------

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908230919	OLEANDER DR	PEACH DR	PARKRIDGE DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
47159	0.4 to 1.4 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375	
11874	1.6 to 116.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	575	SF	\$120	\$68,940	
46033	5.2 to 6.2 feet	Vertical Change	-.48	5 ft	5	REF			
46706	12.5 to 13.5 feet	Vertical Change	-.45	5 ft	5	REF			
52286	41.1 to 42.1 feet	Vertical Change	-.29	5 ft	5	REF			
49187	69.9 to 70.9 feet	Vertical Change	-.36	5 ft	5	REF			
46929	95.0 to 96.0 feet	Vertical Change	-.44	5 ft	5	REF			
44938	105.0 to 106.0 feet	Vertical Change	-.53	5 ft	5	REF			
58569	106.0 to 147.8 feet	Driveway				REF			
50945	115.0 to 116.5 feet	Vertical Change	-.31	5 ft	8	REF			
11881	116.5 to 126.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	52	SF	\$40	\$2,060	
45821	119.1 to 120.1 feet	Vertical Change	-.49	5 ft	5	REF			
45614	123.3 to 124.3 feet	Vertical Change	-.5	5 ft	5	REF			
11883	126.8 to 138.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	59	SF	\$40	\$2,380	
45117	127.4 to 128.4 feet	Vertical Change	-.52	5 ft	5	REF			
45118	131.3 to 132.3 feet	Vertical Change	-.52	5 ft	5	REF			
46249	135.3 to 136.3 feet	Vertical Change	-.47	5 ft	5	REF			
45317	139.4 to 140.4 feet	Vertical Change	-.51	5 ft	5	REF			
44748	143.5 to 144.5 feet	Vertical Change	-.54	5 ft	5	REF			
11886	146.9 to 170.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	119	SF	\$40	\$4,740	
46484	148.1 to 149.1 feet	Vertical Change	-.46	5 ft	5	REF			
49188	153.1 to 154.1 feet	Vertical Change	-.36	5 ft	5	REF			
45615	160.4 to 161.4 feet	Vertical Change	-.5	5 ft	5	REF			
58570	163.8 to 202.8 feet	Driveway				REF			
44749	170.6 to 171.6 feet	Vertical Change	-.54	5 ft	5	REF			
11888	173.4 to 186.4 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	65	SF	\$40	\$2,600	
46707	178.5 to 179.5 feet	Vertical Change	-.45	5 ft	5	REF			
52762	182.2 to 183.2 feet	Vertical Change	-.28	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908230919	OLEANDER DR	PEACH DR	PARKRIDGE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
48340	186.3 to 187.3 feet	Vertical Change	-.39	5 ft	5	REF		
11890	186.4 to 192.7 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	32	SF	\$40	\$1,260
47655	190.2 to 191.2 feet	Vertical Change	-.41	5 ft	5	REF		
11892	192.7 to 198.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	30	SF	\$40	\$1,180
47412	194.2 to 195.2 feet	Vertical Change	-.42	5 ft	5	REF		
11894	198.6 to 199.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	7	SF	\$40	\$260
11895	203.7 to 257.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	268	SF	\$120	\$32,220
46708	206.6 to 207.6 feet	Vertical Change	-.45	5 ft	5	REF		
45119	220.3 to 221.3 feet	Vertical Change	-.52	5 ft	5	REF		
45822	230.2 to 231.2 feet	Vertical Change	-.49	5 ft	5	REF		
44939	240.3 to 241.3 feet	Vertical Change	-.53	5 ft	5	REF		
48055	250.2 to 251.2 feet	Vertical Change	-.4	5 ft	5	REF		
58571	253.0 to 281.3 feet	Driveway				REF		
11898	257.4 to 270.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	67	SF	\$40	\$2,660
51864	260.1 to 261.1 feet	Vertical Change	-.3	5 ft	5	REF		
44940	265.4 to 266.4 feet	Vertical Change	-.53	5 ft	5	REF		
11901	274.9 to 299.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	121	SF	\$40	\$4,820
49189	275.8 to 276.8 feet	Vertical Change	-.36	5 ft	5	REF		
49837	281.2 to 282.2 feet	Vertical Change	-.34	5 ft	5	REF		
58572	288.4 to 319.1 feet	Driveway				REF		
49510	292.9 to 293.9 feet	Vertical Change	-.35	5 ft	5	REF		
48906	297.3 to 298.3 feet	Vertical Change	-.37	5 ft	5	REF		
11904	299.0 to 331.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	165	SF	\$40	\$6,580
45318	302.6 to 303.6 feet	Vertical Change	-.51	5 ft	5	REF		
45319	307.7 to 308.7 feet	Vertical Change	-.51	5 ft	5	REF		
44941	313.0 to 314.0 feet	Vertical Change	-.53	5 ft	5	REF		
50165	317.9 to 319.5 feet	Vertical Change	-.33	5 ft	8	REF		
11911	331.9 to 375.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	220	SF	\$120	\$26,340

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908230919	OLEANDER DR	PEACH DR	PARKRIDGE DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
48056	335.8 to 336.8 feet	Vertical Change	-.4	5 ft	5	REF			
44309	345.8 to 346.8 feet	Vertical Change	-.56	5 ft	5	REF			
51865	355.6 to 356.6 feet	Vertical Change	-.3	5 ft	5	REF			
43633	365.4 to 366.4 feet	Vertical Change	-.6	5 ft	5	REF			
58573	366.9 to 406.5 feet	Driveway				REF			
51866	371.1 to 372.1 feet	Vertical Change	-.3	5 ft	5	REF			
50166	375.6 to 376.6 feet	Vertical Change	-.33	5 ft	5	REF			
11916	378.9 to 405.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	132	SF	\$40	\$5,280	
44121	399.3 to 400.3 feet	Vertical Change	-.57	5 ft	5	REF			
11920	408.5 to 409.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600	
49190	411.2 to 412.2 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375	
48057	415.1 to 416.1 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375	
11921	418.9 to 424.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120	
58574	419.0 to 444.8 feet	Driveway				REF			
49838	419.9 to 420.9 feet	Vertical Change	-.34	5 ft	5	REF			
45120	424.4 to 425.4 feet	Vertical Change	-.52	5 ft	5	REF			
11922	424.9 to 453.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	144	SF	\$40	\$5,760	
46485	439.7 to 440.7 feet	Vertical Change	-.46	5 ft	5	REF			
41547	445.1 to 446.1 feet	Vertical Change	-1.03	5 ft	5	REF			
45121	450.0 to 451.0 feet	Vertical Change	-.52	5 ft	5	REF			
11930	453.7 to 505.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	260	SF	\$120	\$31,140	
44750	456.1 to 457.1 feet	Vertical Change	-.54	5 ft	5	REF			
45616	466.1 to 467.1 feet	Vertical Change	-.5	5 ft	5	REF			
41483	476.2 to 477.2 feet	Vertical Change	-1.12	5 ft	5	REF			
43950	486.0 to 487.0 feet	Vertical Change	-.58	5 ft	5	REF			
45122	495.9 to 496.9 feet	Vertical Change	-.52	5 ft	5	REF			
58575	496.8 to 537.6 feet	Driveway				REF			
43634	501.1 to 502.1 feet	Vertical Change	-.6	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908230919	OLEANDER DR	PEACH DR	PARKRIDGE DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
41808	505.5 to 506.5 feet	Vertical Change	-.84	5 ft	5	REF			
11934	505.6 to 535.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	148	SF	\$40	\$5,900	
56956	507.1 to 508.1 feet	Vertical Change	.55	5 ft	5	REF			
44942	509.6 to 510.6 feet	Vertical Change	-.53	5 ft	5	REF			
43779	513.7 to 514.7 feet	Vertical Change	-.59	5 ft	5	REF			
45617	517.7 to 518.7 feet	Vertical Change	-.5	5 ft	5	REF			
43034	521.7 to 522.7 feet	Vertical Change	-.64	5 ft	5	REF			
44310	525.7 to 526.7 feet	Vertical Change	-.56	5 ft	5	REF			
45320	529.7 to 530.7 feet	Vertical Change	-.51	5 ft	5	REF			
44524	533.9 to 539.0 feet	Vertical Change	-.55	5 ft	26	REF			
11940	535.1 to 536.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	6	SF	\$40	\$240	
11941	536.3 to 538.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	12	SF	\$40	\$460	
11943	538.6 to 553.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	73	SF	\$120	\$8,760	
58576	544.2 to 585.3 feet	Driveway				REF			
45823	545.7 to 546.7 feet	Vertical Change	-.49	5 ft	5	REF			
50946	553.2 to 558.4 feet	Vertical Change	-.31	5 ft	26	REF			
11947	555.7 to 559.1 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	17	SF	\$40	\$680	
11949	559.1 to 562.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	17	SF	\$40	\$680	
44943	561.5 to 562.5 feet	Vertical Change	-.53	5 ft	5	REF			
11951	562.5 to 573.5 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	55	SF	\$40	\$2,200	
44312	565.5 to 566.5 feet	Vertical Change	-.56	5 ft	5	REF			
44313	569.5 to 570.5 feet	Vertical Change	-.56	5 ft	5	REF			
45321	573.5 to 574.5 feet	Vertical Change	-.51	5 ft	5	REF			
11953	573.5 to 578.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	26	SF	\$40	\$1,060	
44314	577.3 to 578.3 feet	Vertical Change	-.56	5 ft	5	REF			
11954	578.8 to 584.7 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	30	SF	\$40	\$1,180	
46709	581.3 to 582.3 feet	Vertical Change	-.45	5 ft	5	REF			
43780	585.3 to 586.3 feet	Vertical Change	-.59	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908230919	OLEANDER DR	PEACH DR	PARKRIDGE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
11956	585.6 to 595.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	48	SF	\$120	\$5,760
48907	592.2 to 593.2 feet	Vertical Change	-.37	5 ft	5	REF		
11958	595.2 to 619.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	120	SF	\$120	\$14,460
47656	599.8 to 600.8 feet	Vertical Change	-.41	5 ft	5	REF		
52763	609.8 to 610.8 feet	Vertical Change	-.28	5 ft	5	REF		
58577	610.6 to 652.4 feet	Driveway				REF		
44525	614.4 to 615.4 feet	Vertical Change	-.55	5 ft	5	REF		
50557	619.0 to 620.0 feet	Vertical Change	-.32	5 ft	5	REF		
11962	619.3 to 656.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	185	SF	\$40	\$7,400
43781	620.3 to 624.1 feet	Vertical Change	-.59	5 ft	19	REF		
44526	627.2 to 628.2 feet	Vertical Change	-.55	5 ft	5	REF		
44944	631.1 to 632.1 feet	Vertical Change	-.53	5 ft	5	REF		
43782	635.1 to 636.1 feet	Vertical Change	-.59	5 ft	5	REF		
44751	638.2 to 639.2 feet	Vertical Change	-.54	5 ft	5	REF		
44752	643.1 to 644.1 feet	Vertical Change	-.54	5 ft	5	REF		
44122	647.2 to 648.2 feet	Vertical Change	-.57	5 ft	5	REF		
46251	651.4 to 652.4 feet	Vertical Change	-.47	5 ft	5	REF		
11971	656.3 to 666.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,300
11973	666.8 to 671.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	25	SF	\$120	\$2,940
TOTAL COST FOR: W side of OLEANDER DR Starting at: PEACH DR							\$261,085.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908230921	PARKRIDGE DR	OLEANDER DR	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
50167	0.0 to 1.0 feet	Vertical Change	-.33	5 ft	5	REF			
11975	0.0 to 36.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	181	SF	\$120	\$21,780	
48341	12.4 to 13.4 feet	Vertical Change	-.39	5 ft	5	REF			
53780	21.0 to 22.0 feet	Vertical Change	-.26	5 ft	5	REF			
11979	36.3 to 89.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	267	SF	\$120	\$32,040	
11981	89.7 to 91.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140	
58578	111.0 to 150.6 feet	Driveway				REF			
11982	114.2 to 116.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	13	SF	\$40	\$500	
11983	118.8 to 127.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	42	SF	\$40	\$1,660	
11986	127.1 to 135.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	43	SF	\$40	\$1,720	
53781	134.2 to 135.2 feet	Vertical Change	-.26	5 ft	5	REF			
11988	135.7 to 144.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	45	SF	\$40	\$1,780	
11990	144.6 to 147.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	14	SF	\$40	\$540	
11992	147.3 to 149.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	10	SF	\$40	\$400	
11993	149.3 to 150.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200	
49839	150.2 to 151.2 feet	Vertical Change	-.34	5 ft	5	REF			
11994	151.8 to 163.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,780	
58579	156.8 to 185.3 feet	Driveway				REF			
43311	159.9 to 166.0 feet	Vertical Change	-.62	5 ft	31	REF			
11997	166.0 to 279.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	569	SF	\$40	\$22,780	
42321	172.9 to 173.9 feet	Vertical Change	-.71	5 ft	5	REF			
43951	179.1 to 180.1 feet	Vertical Change	-.58	5 ft	5	REF			
43035	185.4 to 186.9 feet	Vertical Change	-.64	5 ft	8	REF			
44315	190.2 to 191.2 feet	Vertical Change	-.56	5 ft	5	REF			
42807	194.5 to 195.5 feet	Vertical Change	-.66	5 ft	5	REF			
43475	204.3 to 205.3 feet	Vertical Change	-.61	5 ft	5	REF			
53254	214.3 to 215.3 feet	Vertical Change	-.27	5 ft	5	REF			
48609	224.0 to 225.0 feet	Vertical Change	-.38	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230921	PARKRIDGE DR	OLEANDER DR	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
50947	234.0 to 235.0 feet	Vertical Change	-.31	5 ft	5	REF		
45618	243.8 to 244.8 feet	Vertical Change	-.5	5 ft	5	REF		
58580	245.5 to 276.0 feet	Driveway				REF		
48610	259.4 to 260.4 feet	Vertical Change	-.38	5 ft	5	REF		
46036	269.8 to 270.8 feet	Vertical Change	-.48	5 ft	5	REF		
51867	275.3 to 276.3 feet	Vertical Change	-.3	5 ft	5	REF		
58581	281.2 to 316.9 feet	Driveway				REF		
48611	281.4 to 284.2 feet	Vertical Change	-.38	5 ft	14	REF		
46931	287.0 to 288.0 feet	Vertical Change	-.44	5 ft	5	REF		
12012	290.6 to 308.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	89	SF	\$40	\$3,580
48612	295.8 to 296.8 feet	Vertical Change	-.38	5 ft	5	REF		
45620	307.6 to 308.6 feet	Vertical Change	-.5	5 ft	5	REF		
12014	308.5 to 313.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	27	SF	\$40	\$1,060
40371	313.6 to 315.3 feet	Running Slope	8.0-9.0%	5 ft	8	REF		
49511	327.5 to 328.5 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$375
12015	336.4 to 363.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	136	SF	\$120	\$16,320
44945	337.2 to 338.2 feet	Vertical Change	-.53	5 ft	5	REF		
56934	342.1 to 343.1 feet	Vertical Change	.53	5 ft	5	REF		
48613	346.9 to 347.9 feet	Vertical Change	-.38	5 ft	5	REF		
58582	358.8 to 397.6 feet	Driveway				REF		
54096	362.0 to 363.0 feet	Vertical Change	-.25	5 ft	5	REF		
12018	367.0 to 373.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	31	SF	\$40	\$1,240
46037	371.7 to 372.7 feet	Vertical Change	-.48	5 ft	5	REF		
47657	376.9 to 377.9 feet	Vertical Change	-.41	5 ft	5	REF		
52287	386.5 to 387.5 feet	Vertical Change	-.29	5 ft	5	REF		
12019	387.2 to 393.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	31	SF	\$40	\$1,240
50168	391.7 to 392.7 feet	Vertical Change	-.33	5 ft	5	REF		
12021	393.4 to 408.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	76	SF	\$40	\$3,040
58583	403.6 to 434.3 feet	Driveway				REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230921	PARKRIDGE DR	OLEANDER DR	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
12025	408.6 to 411.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	16	SF	\$40	\$620
45621	411.3 to 412.3 feet	Vertical Change	-.5	5 ft	5	REF		
12027	411.7 to 421.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	47	SF	\$40	\$1,880
46486	416.7 to 417.7 feet	Vertical Change	-.46	5 ft	5	REF		
12031	421.1 to 424.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	18	SF	\$40	\$720
46711	427.0 to 428.0 feet	Vertical Change	-.45	5 ft	5	REF		
12032	429.8 to 430.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200
12033	431.7 to 455.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	120	SF	\$40	\$4,800
46252	432.3 to 433.3 feet	Vertical Change	-.47	5 ft	5	REF		
48614	441.7 to 442.7 feet	Vertical Change	-.38	5 ft	5	REF		
50948	445.5 to 446.5 feet	Vertical Change	-.31	5 ft	5	REF		
12039	455.7 to 456.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720
TOTAL COST FOR: N side of PARKRIDGE DR Starting at: OLEANDER DR							\$127,115.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230923	SANTA CRUZ BLVD	PARKRIDGE DR	CHERRY CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
12040	5.9 to 9.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,980
12041	11.3 to 39.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	140	SF	\$120	\$16,740
49191	18.1 to 19.1 feet	Vertical Change	-36	5 ft	5	REF		
48615	38.0 to 39.0 feet	Vertical Change	-38	5 ft	5	REF		
12046	47.3 to 51.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700
12047	58.0 to 68.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,180
51868	77.2 to 78.2 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375
50949	107.3 to 108.3 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375
50558	117.1 to 118.1 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375
12048	147.6 to 157.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,760
53782	156.6 to 157.6 feet	Vertical Change	-.26	5 ft	5	REF		
50169	166.2 to 167.2 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375
12049	170.8 to 182.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,840
51869	175.6 to 176.6 feet	Vertical Change	-.3	5 ft	5	REF		
TOTAL COST FOR:		E	<i>side of</i> SANTA CRUZ BLVD	<i>Starting at:</i> PARKRIDGE DR				\$41,700.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908230925	CHERRY CT	SANTA CRUZ BLVD	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
43476	2.1 to 3.1 feet	Vertical Change	-.61	5 ft	5	SF	\$75	\$375	
44946	8.8 to 9.8 feet	Vertical Change	-.53	5 ft	5	REF			
12050	9.3 to 18.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,580	
47161	13.6 to 14.6 feet	Vertical Change	-.43	5 ft	5	REF			
48058	18.6 to 19.6 feet	Vertical Change	-.4	5 ft	5	REF			
12052	18.6 to 57.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	196	SF	\$120	\$23,580	
41436	20.8 to 21.8 feet	Vertical Change	-1.2	5 ft	5	REF			
44753	26.7 to 27.7 feet	Vertical Change	-.54	5 ft	5	REF			
58584	26.8 to 65.8 feet	Driveway				REF			
48616	33.1 to 34.1 feet	Vertical Change	-.38	5 ft	5	REF			
44947	37.2 to 38.2 feet	Vertical Change	-.53	5 ft	5	REF			
43312	41.3 to 42.3 feet	Vertical Change	-.62	5 ft	5	REF			
43036	45.2 to 46.2 feet	Vertical Change	-.64	5 ft	5	REF			
43477	49.0 to 50.0 feet	Vertical Change	-.61	5 ft	5	REF			
45824	53.0 to 54.0 feet	Vertical Change	-.49	5 ft	5	REF			
43952	56.9 to 57.9 feet	Vertical Change	-.58	5 ft	5	REF			
12060	57.9 to 62.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	25	SF	\$40	\$980	
44316	61.1 to 62.1 feet	Vertical Change	-.56	5 ft	5	REF			
12062	62.8 to 67.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	25	SF	\$40	\$1,000	
46712	65.3 to 66.3 feet	Vertical Change	-.45	5 ft	5	REF			
12064	67.8 to 85.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	88	SF	\$120	\$10,500	
50559	75.0 to 76.0 feet	Vertical Change	-.32	5 ft	5	REF			
58585	77.6 to 117.8 feet	Driveway				REF			
45622	84.6 to 85.6 feet	Vertical Change	-.5	5 ft	5	REF			
12068	86.2 to 87.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$220	
12069	87.3 to 90.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	18	SF	\$40	\$700	
43783	90.5 to 91.5 feet	Vertical Change	-.59	5 ft	5	REF			
12070	90.8 to 95.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	24	SF	\$40	\$940	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908230925	CHERRY CT	SANTA CRUZ BLVD	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
12072	95.5 to 109.9 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	72	SF	\$40	\$2,880	
42410	95.6 to 96.6 feet	Vertical Change	-.7	5 ft	5	REF			
43635	100.5 to 101.5 feet	Vertical Change	-.6	5 ft	5	REF			
41908	105.1 to 106.1 feet	Vertical Change	-.8	5 ft	5	REF			
12074	109.9 to 111.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	9	SF	\$40	\$340	
45124	110.7 to 111.7 feet	Vertical Change	-.52	5 ft	5	REF			
12075	111.6 to 113.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	11	SF	\$40	\$440	
45623	113.8 to 114.8 feet	Vertical Change	-.5	5 ft	5	REF			
12077	113.8 to 116.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	12	SF	\$40	\$460	
42197	116.9 to 117.9 feet	Vertical Change	-.73	5 ft	5	REF			
12078	118.4 to 135.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	87	SF	\$40	\$3,480	
45125	135.5 to 136.5 feet	Vertical Change	-.52	5 ft	5	REF			
12080	135.8 to 173.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	189	SF	\$120	\$22,680	
43953	145.7 to 146.7 feet	Vertical Change	-.58	5 ft	5	REF			
49192	155.9 to 156.9 feet	Vertical Change	-.36	5 ft	5	REF			
45624	166.1 to 167.1 feet	Vertical Change	-.5	5 ft	5	REF			
58586	169.9 to 195.8 feet	Driveway				REF			
12085	173.6 to 175.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	11	SF	\$40	\$440	
41527	176.0 to 177.0 feet	Vertical Change	-1.06	5 ft	5	REF			
12086	178.5 to 192.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	68	SF	\$40	\$2,700	
42502	186.4 to 187.4 feet	Vertical Change	-.69	5 ft	5	REF			
12089	192.0 to 194.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	13	SF	\$40	\$520	
43636	196.8 to 197.8 feet	Vertical Change	-.6	5 ft	5	SF	\$75	\$375	
12090	198.1 to 216.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	93	SF	\$120	\$11,100	
46932	205.0 to 206.0 feet	Vertical Change	-.44	5 ft	5	REF			
58587	205.7 to 252.1 feet	Driveway				REF			
41909	209.5 to 210.5 feet	Vertical Change	-.8	5 ft	5	REF			
46253	213.5 to 214.7 feet	Vertical Change	-.47	5 ft	6	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230925	CHERRY CT	SANTA CRUZ BLVD	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
12092	216.6 to 218.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	10	SF	\$40	\$380
44754	217.9 to 218.9 feet	Vertical Change	-.54	5 ft	5	REF		
44317	222.2 to 223.2 feet	Vertical Change	-.56	5 ft	5	REF		
12093	225.3 to 231.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	31	SF	\$40	\$1,240
46713	226.4 to 227.4 feet	Vertical Change	-.45	5 ft	5	REF		
42156	232.0 to 233.0 feet	Vertical Change	-.74	5 ft	5	REF		
41809	237.8 to 238.8 feet	Vertical Change	-.84	5 ft	5	REF		
45126	242.6 to 243.6 feet	Vertical Change	-.52	5 ft	5	REF		
12094	244.9 to 275.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	151	SF	\$40	\$6,040
42698	247.6 to 248.6 feet	Vertical Change	-.67	5 ft	5	REF		
42198	252.2 to 253.2 feet	Vertical Change	-.73	5 ft	5	REF		
57227	252.3 to 253.3 feet	Vertical Change	.7	5 ft	5	REF		
43313	253.1 to 254.1 feet	Vertical Change	-.62	5 ft	5	REF		
42503	257.4 to 258.4 feet	Vertical Change	-.69	5 ft	5	REF		
54097	259.5 to 260.5 feet	Vertical Change	-.25	5 ft	5	REF		
42808	264.8 to 265.8 feet	Vertical Change	-.66	5 ft	5	REF		
46254	276.1 to 279.2 feet	Vertical Change	-.47	5 ft	15	LF	\$75	\$1,163
45625	282.9 to 283.9 feet	Vertical Change	-.5	5 ft	5	SF	\$75	\$375
58588	283.5 to 310.8 feet	Driveway				REF		
43168	287.4 to 290.5 feet	Vertical Change	-.63	5 ft	16	REF		
12097	293.0 to 304.4 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	57	SF	\$40	\$2,280
42411	300.9 to 301.9 feet	Vertical Change	-.7	5 ft	5	REF		
12099	304.4 to 310.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	32	SF	\$40	\$1,260
58589	312.0 to 350.1 feet	Driveway				REF		
46255	312.7 to 313.7 feet	Vertical Change	-.47	5 ft	5	REF		
12102	313.9 to 315.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	7	SF	\$40	\$260
12103	318.4 to 340.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	112	SF	\$40	\$4,460
43637	323.5 to 324.5 feet	Vertical Change	-.6	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230925	CHERRY CT	SANTA CRUZ BLVD	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44755	332.9 to 333.9 feet	Vertical Change	-.54	5 ft	5	REF		
12109	340.7 to 347.1 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	32	SF	\$40	\$1,280
42604	341.9 to 342.9 feet	Vertical Change	-.68	5 ft	5	REF		
12110	351.4 to 352.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660
47659	353.1 to 354.1 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375
58590	355.8 to 387.3 feet	Driveway				REF		
45127	360.4 to 361.4 feet	Vertical Change	-.52	5 ft	5	REF		
12111	362.5 to 363.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$260
12112	365.4 to 366.4 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200
12113	366.4 to 368.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	11	SF	\$40	\$440
12114	368.6 to 376.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	40	SF	\$40	\$1,580
47413	375.4 to 379.0 feet	Vertical Change	-.42	5 ft	18	REF		
12117	376.5 to 380.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	21	SF	\$40	\$820
12119	380.6 to 384.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	21	SF	\$40	\$840
43478	388.3 to 389.3 feet	Vertical Change	-.61	5 ft	5	SF	\$75	\$375
58591	397.1 to 424.8 feet	Driveway				REF		
12121	400.5 to 402.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$300
44123	401.2 to 402.2 feet	Vertical Change	-.57	5 ft	5	REF		
12122	405.3 to 409.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	19	SF	\$40	\$740
12124	409.0 to 413.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	24	SF	\$40	\$940
44124	412.2 to 413.2 feet	Vertical Change	-.57	5 ft	5	REF		
12126	413.7 to 417.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	17	SF	\$40	\$660
12128	417.0 to 422.2 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	26	SF	\$40	\$1,040
40372	419.6 to 421.7 feet	Running Slope	8.0-9.0%	5 ft	11	REF		
43314	424.7 to 425.7 feet	Vertical Change	-.62	5 ft	5	REF		
12130	426.1 to 434.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,740
45322	435.6 to 436.6 feet	Vertical Change	-.51	5 ft	5	SF	\$75	\$375
12131	437.8 to 444.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,260

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230925	CHERRY CT	SANTA CRUZ BLVD	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47162	445.2 to 446.2 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375
12132	448.2 to 482.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	171	SF	\$120	\$20,460
43479	455.3 to 456.3 feet	Vertical Change	-.61	5 ft	5	REF		
46038	464.1 to 465.1 feet	Vertical Change	-.48	5 ft	5	REF		
49512	473.3 to 474.3 feet	Vertical Change	-.35	5 ft	5	REF		
58592	476.2 to 514.1 feet	Driveway				REF		
12134	482.3 to 490.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	42	SF	\$40	\$1,680
44318	482.7 to 485.1 feet	Vertical Change	-.56	5 ft	12	REF		
48617	488.9 to 489.9 feet	Vertical Change	-.38	5 ft	5	REF		
12138	490.7 to 500.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	51	SF	\$40	\$2,040
44319	494.0 to 495.0 feet	Vertical Change	-.56	5 ft	5	REF		
44320	498.8 to 499.8 feet	Vertical Change	-.56	5 ft	5	REF		
42157	503.6 to 504.6 feet	Vertical Change	-.74	5 ft	5	REF		
12139	503.9 to 508.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	25	SF	\$40	\$1,000
42412	508.7 to 509.7 feet	Vertical Change	-.7	5 ft	5	REF		
12141	508.9 to 511.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	13	SF	\$40	\$520
12143	511.5 to 514.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	15	SF	\$40	\$600
12144	514.5 to 515.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$220
43785	514.6 to 515.6 feet	Vertical Change	-.59	5 ft	5	REF		
12145	516.3 to 518.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	13	SF	\$120	\$1,500
12146	518.8 to 524.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,180
58593	518.8 to 544.8 feet	Driveway				REF		
45323	520.5 to 521.5 feet	Vertical Change	-.51	5 ft	5	REF		
42413	523.7 to 524.7 feet	Vertical Change	-.7	5 ft	5	REF		
12148	524.1 to 546.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	114	SF	\$40	\$4,560
43037	529.2 to 530.2 feet	Vertical Change	-.64	5 ft	5	REF		
41711	534.4 to 535.4 feet	Vertical Change	-.89	5 ft	5	REF		
41734	539.6 to 540.6 feet	Vertical Change	-.88	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908230925	CHERRY CT	SANTA CRUZ BLVD	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
42809	543.9 to 544.9 feet	Vertical Change	-.66	5 ft	5	REF			
41460	545.0 to 546.0 feet	Vertical Change	-1.14	5 ft	5	REF			
12155	546.9 to 572.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	129	SF	\$120	\$15,480	
53783	547.2 to 550.1 feet	Vertical Change	-.26	5 ft	14	REF			
49513	552.9 to 553.9 feet	Vertical Change	-.35	5 ft	5	REF			
52764	557.9 to 558.9 feet	Vertical Change	-.28	5 ft	5	REF			
43169	562.8 to 563.8 feet	Vertical Change	-.63	5 ft	5	REF			
48618	572.7 to 573.7 feet	Vertical Change	-.38	5 ft	5	REF			
42062	582.7 to 583.7 feet	Vertical Change	-.76	5 ft	5	SF	\$75	\$375	
12156	587.0 to 602.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	76	SF	\$120	\$9,180	
46933	592.4 to 593.4 feet	Vertical Change	-.44	5 ft	5	REF			
58594	595.4 to 632.7 feet	Driveway				REF			
41563	602.2 to 603.2 feet	Vertical Change	-1.01	5 ft	5	REF			
12158	605.8 to 624.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	95	SF	\$40	\$3,800	
41910	607.1 to 608.1 feet	Vertical Change	-.8	5 ft	5	REF			
41911	612.3 to 613.3 feet	Vertical Change	-.8	5 ft	5	REF			
41912	617.4 to 618.4 feet	Vertical Change	-.8	5 ft	5	REF			
41669	622.4 to 623.4 feet	Vertical Change	-.92	5 ft	5	REF			
12160	624.8 to 630.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	28	SF	\$40	\$1,100	
41913	627.5 to 628.5 feet	Vertical Change	-.8	5 ft	5	REF			
40373	629.6 to 631.6 feet	Running Slope	6.0-7.0%	5 ft	10	REF			
42414	632.6 to 633.6 feet	Vertical Change	-.7	5 ft	5	REF			
12161	634.4 to 644.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,120	
58595	643.6 to 679.4 feet	Driveway				REF			
12163	644.6 to 649.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	26	SF	\$40	\$1,040	
12165	652.8 to 656.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	16	SF	\$40	\$640	
12167	656.0 to 657.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	7	SF	\$40	\$260	
12168	657.3 to 674.9 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	88	SF	\$40	\$3,520	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1908230925	CHERRY CT	SANTA CRUZ BLVD	SANTA CRUZ BLVD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
50560	666.3 to 667.3 feet	Vertical Change	-.32	5 ft	5	REF			
12171	674.9 to 678.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	17	SF	\$40	\$660	
TOTAL COST FOR: E							<i>side of</i> CHERRY CT	<i>Starting at:</i> SANTA CRUZ BLVD	\$204,942.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230926	SANTA CRUZ BLVD	CHERRY CT	PLUM CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
50561	55.8 to 56.8 feet	Vertical Change	-.32	5 ft	5	REF		
12173	56.4 to 67.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,420
53255	75.9 to 76.9 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
51871	95.2 to 96.2 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375
53784	114.6 to 115.6 feet	Vertical Change	-.26	5 ft	5	REF		
12174	115.0 to 129.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,820
50950	124.4 to 125.4 feet	Vertical Change	-.31	5 ft	5	REF		
54163	124.5 to 125.5 feet	Vertical Change	.29	5 ft	5	REF		
12177	144.0 to 148.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,460
12178	155.2 to 195.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	204	SF	\$120	\$24,420
50562	190.5 to 191.5 feet	Vertical Change	-.32	5 ft	5	REF		
TOTAL COST FOR: E side of SANTA CRUZ BLVD Starting at: CHERRY CT							\$42,870.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230929	PLUM CT	SANTA CRUZ BLVD	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58596	0.1 to 25.7 feet	Driveway				REF		
42699	3.9 to 4.9 feet	Vertical Change	-67	5 ft	5	REF		
12183	4.3 to 8.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	23	SF	\$40	\$900
12186	8.8 to 10.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$320
42415	10.7 to 11.7 feet	Vertical Change	-7	5 ft	5	REF		
42246	15.4 to 16.4 feet	Vertical Change	-72	5 ft	5	REF		
42605	20.5 to 21.5 feet	Vertical Change	-68	5 ft	5	REF		
44125	25.4 to 26.4 feet	Vertical Change	-57	5 ft	5	REF		
12187	29.9 to 32.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
43954	31.5 to 35.4 feet	Vertical Change	-58	5 ft	20	REF		
44321	43.2 to 44.2 feet	Vertical Change	-56	5 ft	5	SF	\$75	\$375
48059	53.2 to 54.2 feet	Vertical Change	-4	5 ft	5	REF		
12188	53.4 to 84.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	153	SF	\$120	\$18,360
44322	63.2 to 64.2 feet	Vertical Change	-56	5 ft	5	REF		
42700	73.2 to 74.2 feet	Vertical Change	-67	5 ft	5	REF		
58597	75.3 to 115.1 feet	Driveway				REF		
41319	82.7 to 83.7 feet	Vertical Change	-1.5	5 ft	5	REF		
12191	84.0 to 94.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	53	SF	\$40	\$2,120
45626	86.6 to 87.6 feet	Vertical Change	-5	5 ft	5	REF		
45825	90.6 to 91.6 feet	Vertical Change	-49	5 ft	5	REF		
45324	94.5 to 95.5 feet	Vertical Change	-51	5 ft	5	REF		
12196	94.6 to 107.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	65	SF	\$40	\$2,600
42701	98.3 to 99.3 feet	Vertical Change	-67	5 ft	5	REF		
45325	102.2 to 103.2 feet	Vertical Change	-51	5 ft	5	REF		
44528	106.3 to 107.3 feet	Vertical Change	-55	5 ft	5	REF		
12198	107.6 to 116.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	44	SF	\$40	\$1,760
45128	110.3 to 111.3 feet	Vertical Change	-52	5 ft	5	REF		
44948	114.6 to 115.6 feet	Vertical Change	-53	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230929	PLUM CT	SANTA CRUZ BLVD	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
12202	116.4 to 118.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260
58598	119.5 to 147.2 feet	Driveway				REF		
12203	124.1 to 125.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200
52288	125.2 to 126.2 feet	Vertical Change	-.29	5 ft	5	REF		
12204	127.3 to 130.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	14	SF	\$40	\$580
12205	130.2 to 133.4 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	16	SF	\$40	\$640
45826	130.6 to 131.6 feet	Vertical Change	-.49	5 ft	5	REF		
12207	133.4 to 142.9 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	48	SF	\$40	\$1,900
43315	135.8 to 136.8 feet	Vertical Change	-.62	5 ft	5	REF		
43786	141.3 to 142.3 feet	Vertical Change	-.59	5 ft	5	REF		
12209	142.9 to 147.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	25	SF	\$40	\$980
41555	146.4 to 147.4 feet	Vertical Change	-1.02	5 ft	5	REF		
12212	147.8 to 154.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	34	SF	\$120	\$4,140
12213	154.7 to 171.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,260
43316	156.2 to 157.2 feet	Vertical Change	-.62	5 ft	5	REF		
44126	166.2 to 167.2 feet	Vertical Change	-.57	5 ft	5	REF		
43955	176.4 to 177.4 feet	Vertical Change	-.58	5 ft	5	SF	\$75	\$375
12214	177.7 to 182.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,880
58599	179.2 to 207.9 feet	Driveway				REF		
43956	186.4 to 187.9 feet	Vertical Change	-.58	5 ft	8	REF		
12215	187.3 to 203.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	80	SF	\$40	\$3,180
43170	191.7 to 192.7 feet	Vertical Change	-.63	5 ft	5	REF		
42416	196.8 to 197.8 feet	Vertical Change	-.7	5 ft	5	REF		
43171	202.0 to 203.0 feet	Vertical Change	-.63	5 ft	5	REF		
12219	203.2 to 209.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	29	SF	\$40	\$1,160
47660	207.5 to 209.8 feet	Vertical Change	-.41	5 ft	12	REF		
56976	208.9 to 209.9 feet	Vertical Change	.57	5 ft	5	REF		
12221	209.0 to 211.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230929	PLUM CT	SANTA CRUZ BLVD	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
12222	215.5 to 230.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,820
43957	220.0 to 221.0 feet	Vertical Change	-.58	5 ft	5	REF		
45327	228.6 to 229.6 feet	Vertical Change	-.51	5 ft	5	REF		
45130	237.3 to 238.3 feet	Vertical Change	-.52	5 ft	5	SF	\$75	\$375
46039	246.2 to 247.2 feet	Vertical Change	-.48	5 ft	5	LF	\$75	\$375
58600	251.2 to 296.1 feet	Driveway				REF		
49840	252.5 to 253.5 feet	Vertical Change	-.34	5 ft	5	REF		
41250	257.6 to 258.6 feet	Vertical Change	-1.86	5 ft	5	REF		
12225	261.1 to 270.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	45	SF	\$40	\$1,800
42199	266.0 to 267.0 feet	Vertical Change	-.73	5 ft	5	REF		
45328	270.1 to 271.1 feet	Vertical Change	-.51	5 ft	5	REF		
12227	270.1 to 284.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	70	SF	\$40	\$2,820
44127	274.4 to 275.4 feet	Vertical Change	-.57	5 ft	5	REF		
44949	279.7 to 280.7 feet	Vertical Change	-.53	5 ft	5	REF		
12228	284.2 to 286.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	11	SF	\$40	\$420
42702	285.1 to 286.1 feet	Vertical Change	-.67	5 ft	5	REF		
12229	286.3 to 292.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	33	SF	\$40	\$1,300
12231	292.8 to 295.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	15	SF	\$40	\$600
45329	296.0 to 297.0 feet	Vertical Change	-.51	5 ft	5	REF		
12233	297.8 to 299.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$720
12234	299.0 to 315.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	83	SF	\$120	\$9,900
53785	307.6 to 308.6 feet	Vertical Change	-.26	5 ft	5	REF		
58601	310.6 to 344.7 feet	Driveway				REF		
47414	319.4 to 321.0 feet	Vertical Change	-.42	5 ft	8	REF		
44323	326.5 to 327.5 feet	Vertical Change	-.56	5 ft	5	REF		
12236	330.5 to 338.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	41	SF	\$40	\$1,640
44529	332.8 to 333.8 feet	Vertical Change	-.55	5 ft	5	REF		
44530	338.4 to 342.0 feet	Vertical Change	-.55	5 ft	18	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230929	PLUM CT	SANTA CRUZ BLVD	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
12238	342.0 to 343.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	8	SF	\$40	\$320
42703	345.6 to 346.6 feet	Vertical Change	-.67	5 ft	5	REF		
12239	346.3 to 351.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120
58602	347.0 to 383.3 feet	Driveway				REF		
44324	351.6 to 352.6 feet	Vertical Change	-.56	5 ft	5	REF		
12240	354.5 to 359.2 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	24	SF	\$40	\$940
12242	359.2 to 360.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	7	SF	\$40	\$280
53786	359.6 to 360.6 feet	Vertical Change	-.26	5 ft	5	REF		
12243	360.6 to 370.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	51	SF	\$40	\$2,020
45827	363.9 to 364.9 feet	Vertical Change	-.49	5 ft	5	REF		
44325	368.9 to 369.9 feet	Vertical Change	-.56	5 ft	5	REF		
12245	370.7 to 378.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	38	SF	\$40	\$1,500
43787	373.7 to 374.7 feet	Vertical Change	-.59	5 ft	5	REF		
12247	378.2 to 383.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	26	SF	\$40	\$1,020
46256	378.6 to 379.6 feet	Vertical Change	-.47	5 ft	5	REF		
12249	383.3 to 384.5 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$240
44128	383.6 to 384.6 feet	Vertical Change	-.57	5 ft	5	REF		
12250	384.5 to 393.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,280
58603	388.0 to 433.0 feet	Driveway				REF		
41791	388.7 to 389.7 feet	Vertical Change	-.85	5 ft	5	REF		
12252	393.3 to 394.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$200
46487	393.5 to 394.5 feet	Vertical Change	-.46	5 ft	5	REF		
12253	395.9 to 405.2 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	47	SF	\$40	\$1,860
43788	399.4 to 400.4 feet	Vertical Change	-.59	5 ft	5	REF		
41531	402.9 to 403.9 feet	Vertical Change	-1.05	5 ft	5	REF		
12257	405.2 to 424.4 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	96	SF	\$40	\$3,840
42810	407.8 to 408.8 feet	Vertical Change	-.66	5 ft	5	REF		
42417	412.7 to 413.7 feet	Vertical Change	-.7	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230929	PLUM CT	SANTA CRUZ BLVD	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
43789	417.8 to 418.8 feet	Vertical Change	-.59	5 ft	5	REF		
43790	422.9 to 423.9 feet	Vertical Change	-.59	5 ft	5	REF		
12262	424.4 to 428.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	19	SF	\$40	\$760
43172	428.1 to 429.9 feet	Vertical Change	-.63	5 ft	9	REF		
12264	428.2 to 431.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	17	SF	\$40	\$660
42811	433.3 to 434.3 feet	Vertical Change	-.66	5 ft	5	REF		
12266	434.7 to 435.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$600
12267	435.7 to 442.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,840
48342	438.4 to 439.4 feet	Vertical Change	-.39	5 ft	5	REF		
12268	446.0 to 453.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,620
58604	446.8 to 473.2 feet	Driveway				REF		
51872	448.5 to 449.5 feet	Vertical Change	-.3	5 ft	5	REF		
47661	453.1 to 454.1 feet	Vertical Change	-.41	5 ft	5	REF		
12269	457.2 to 461.5 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	22	SF	\$40	\$860
12271	461.5 to 469.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	42	SF	\$40	\$1,680
12273	473.7 to 486.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	63	SF	\$120	\$7,500
54099	477.2 to 478.2 feet	Vertical Change	-.25	5 ft	5	REF		
12274	486.2 to 508.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	113	SF	\$120	\$13,500
54100	494.8 to 495.8 feet	Vertical Change	-.25	5 ft	5	REF		
49514	504.9 to 505.9 feet	Vertical Change	-.35	5 ft	5	REF		
12275	512.6 to 536.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	120	SF	\$120	\$14,400
45629	515.3 to 516.3 feet	Vertical Change	-.5	5 ft	5	REF		
46714	525.3 to 526.3 feet	Vertical Change	-.45	5 ft	5	REF		
58605	527.3 to 562.9 feet	Driveway				REF		
47662	530.6 to 531.6 feet	Vertical Change	-.41	5 ft	5	REF		
52289	535.1 to 536.1 feet	Vertical Change	-.29	5 ft	5	REF		
12279	536.6 to 543.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	33	SF	\$40	\$1,300
52290	539.5 to 540.5 feet	Vertical Change	-.29	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230929	PLUM CT	SANTA CRUZ BLVD	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
12283	543.1 to 565.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	113	SF	\$40	\$4,500
44326	543.6 to 544.6 feet	Vertical Change	-.56	5 ft	5	REF		
46040	547.6 to 548.6 feet	Vertical Change	-.48	5 ft	5	REF		
45630	551.6 to 552.6 feet	Vertical Change	-.5	5 ft	5	REF		
46488	555.5 to 556.5 feet	Vertical Change	-.46	5 ft	5	REF		
44756	559.5 to 560.5 feet	Vertical Change	-.54	5 ft	5	REF		
45631	563.5 to 564.5 feet	Vertical Change	-.5	5 ft	5	REF		
12285	565.6 to 572.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	33	SF	\$120	\$3,960
46041	567.7 to 569.1 feet	Vertical Change	-.48	5 ft	7	REF		
56626	568.2 to 569.2 feet	Vertical Change	.44	5 ft	5	REF		
58606	571.3 to 596.5 feet	Driveway				REF		
12287	572.2 to 575.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	18	SF	\$40	\$720
45330	576.5 to 577.5 feet	Vertical Change	-.51	5 ft	5	REF		
12288	580.9 to 594.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	67	SF	\$40	\$2,680
46715	586.6 to 587.6 feet	Vertical Change	-.45	5 ft	5	REF		
47663	596.7 to 597.7 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375
12291	598.2 to 601.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040
44531	601.3 to 602.3 feet	Vertical Change	-.55	5 ft	5	REF		
43480	604.8 to 605.8 feet	Vertical Change	-.61	5 ft	5	SF	\$75	\$375
44532	613.2 to 614.2 feet	Vertical Change	-.55	5 ft	5	SF	\$75	\$375
12292	617.0 to 654.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	188	SF	\$120	\$22,560
44327	623.6 to 624.6 feet	Vertical Change	-.56	5 ft	5	REF		
43958	633.6 to 634.6 feet	Vertical Change	-.58	5 ft	5	REF		
51873	643.5 to 644.5 feet	Vertical Change	-.3	5 ft	5	REF		
58607	646.6 to 685.6 feet	Driveway				REF		
42418	649.0 to 650.0 feet	Vertical Change	-.7	5 ft	5	REF		
47163	653.7 to 654.7 feet	Vertical Change	-.43	5 ft	5	REF		
12297	654.6 to 662.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	41	SF	\$40	\$1,620

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230929	PLUM CT	SANTA CRUZ BLVD	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44129	661.9 to 662.9 feet	Vertical Change	-.57	5 ft	5	REF		
12299	662.7 to 681.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	95	SF	\$40	\$3,800
43959	669.7 to 670.7 feet	Vertical Change	-.58	5 ft	5	REF		
42925	677.4 to 678.4 feet	Vertical Change	-.65	5 ft	5	REF		
12301	681.7 to 688.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	33	SF	\$40	\$1,300
45331	685.7 to 686.7 feet	Vertical Change	-.51	5 ft	5	REF		
58608	686.8 to 722.4 feet	Driveway				REF		
12303	688.2 to 690.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	10	SF	\$40	\$400
44951	691.2 to 692.2 feet	Vertical Change	-.53	5 ft	5	REF		
12304	693.9 to 703.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	50	SF	\$40	\$1,980
50951	698.4 to 699.4 feet	Vertical Change	-.31	5 ft	5	REF		
12306	703.8 to 720.7 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	85	SF	\$40	\$3,380
45332	706.4 to 707.4 feet	Vertical Change	-.51	5 ft	5	REF		
44952	714.6 to 715.6 feet	Vertical Change	-.53	5 ft	5	REF		
43481	722.3 to 723.3 feet	Vertical Change	-.61	5 ft	5	REF		
12308	723.8 to 756.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	162	SF	\$120	\$19,380
51874	730.4 to 731.4 feet	Vertical Change	-.3	5 ft	5	REF		
45131	738.9 to 739.9 feet	Vertical Change	-.52	5 ft	5	REF		
58609	751.8 to 790.8 feet	Driveway				REF		
50563	758.9 to 759.9 feet	Vertical Change	-.32	5 ft	5	REF		
12311	760.5 to 791.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	153	SF	\$40	\$6,120
45132	763.0 to 764.0 feet	Vertical Change	-.52	5 ft	5	REF		
45133	766.9 to 767.9 feet	Vertical Change	-.52	5 ft	5	REF		
44533	770.7 to 771.7 feet	Vertical Change	-.55	5 ft	5	REF		
43791	774.7 to 775.7 feet	Vertical Change	-.59	5 ft	5	REF		
50172	778.8 to 779.8 feet	Vertical Change	-.33	5 ft	5	REF		
43317	782.7 to 783.7 feet	Vertical Change	-.62	5 ft	5	REF		
46716	786.7 to 787.7 feet	Vertical Change	-.45	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230929	PLUM CT	SANTA CRUZ BLVD	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
12317	791.1 to 793.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	10	SF	\$40	\$380
44130	796.2 to 797.2 feet	Vertical Change	-.57	5 ft	5	SF	\$75	\$375
12318	801.3 to 805.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400
50564	806.3 to 807.3 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: E side of PLUM CT Starting at: SANTA CRUZ BLVD							\$235,375.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230931	SANTA CRUZ BLVD	PLUM CT	PEACH DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47664	11.7 to 12.7 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375
12319	32.1 to 59.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	136	SF	\$120	\$16,320
46717	39.8 to 40.8 feet	Vertical Change	-.45	5 ft	5	REF		
43038	49.9 to 50.9 feet	Vertical Change	-.64	5 ft	5	REF		
47665	60.0 to 61.0 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375
47666	70.0 to 71.0 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375
50565	80.0 to 81.0 feet	Vertical Change	-.32	5 ft	5	LF	\$75	\$375
46489	89.9 to 90.9 feet	Vertical Change	-.46	5 ft	5	LF	\$75	\$375
56646	89.9 to 90.9 feet	Vertical Change	.49	5 ft	5	LF	\$75	\$375
50952	99.6 to 100.6 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375
51875	109.6 to 110.6 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375
50953	129.5 to 130.5 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375
45633	149.5 to 150.5 feet	Vertical Change	-.5	5 ft	5	SF	\$75	\$375
50954	154.5 to 155.5 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375
50955	159.5 to 160.5 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375
49841	166.0 to 167.0 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375
41173	166.1 to 167.1 feet	Vertical Change	-3.31	5 ft	5	SF	\$75	\$375
52765	168.9 to 172.8 feet	Vertical Change	-.28	5 ft	20	LF	\$75	\$1,463
TOTAL COST FOR: E side of SANTA CRUZ BLVD Starting at: PLUM CT							\$23,032.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908230934	PEACH DR	SANTA CRUZ BLVD	OLEANDER DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
12322	0.0 to 13.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	67	SF	\$120	\$8,040	
41914	7.0 to 8.0 feet	Vertical Change	-8	5 ft	5	REF			
41181	12.7 to 13.7 feet	Vertical Change	-3	5 ft	5	REF			
12324	13.4 to 23.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	52	SF	\$120	\$6,180	
58610	17.6 to 56.9 feet	Driveway				REF			
46257	19.5 to 26.3 feet	Vertical Change	-.47	5 ft	34	REF			
12325	25.1 to 55.6 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	153	SF	\$40	\$6,100	
41824	28.1 to 29.1 feet	Vertical Change	-.83	5 ft	5	REF			
42200	32.3 to 33.3 feet	Vertical Change	-.73	5 ft	5	REF			
41778	36.3 to 37.3 feet	Vertical Change	-.86	5 ft	5	REF			
41915	40.2 to 41.2 feet	Vertical Change	-.8	5 ft	5	REF			
41792	44.1 to 45.1 feet	Vertical Change	-.85	5 ft	5	REF			
46718	47.9 to 48.9 feet	Vertical Change	-.45	5 ft	5	REF			
12334	55.6 to 56.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200	
12335	58.2 to 61.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740	
49515	60.8 to 61.8 feet	Vertical Change	-.35	5 ft	5	REF			
44953	65.8 to 66.8 feet	Vertical Change	-.53	5 ft	5	SF	\$75	\$375	
58611	68.3 to 98.2 feet	Driveway				REF			
43960	71.2 to 74.4 feet	Vertical Change	-.58	5 ft	16	REF			
57131	75.3 to 76.3 feet	Vertical Change	.61	5 ft	5	REF			
41415	75.7 to 76.7 feet	Vertical Change	-1.24	5 ft	5	REF			
12336	78.2 to 95.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	87	SF	\$40	\$3,480	
41793	79.3 to 80.3 feet	Vertical Change	-.85	5 ft	5	REF			
43482	82.8 to 83.8 feet	Vertical Change	-.61	5 ft	5	REF			
41622	86.3 to 87.3 feet	Vertical Change	-.96	5 ft	5	REF			
42158	89.8 to 90.8 feet	Vertical Change	-.74	5 ft	5	REF			
42247	93.3 to 94.3 feet	Vertical Change	-.72	5 ft	5	REF			
12339	98.5 to 100.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	9	SF	\$40	\$360	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230934	PEACH DR	SANTA CRUZ BLVD	OLEANDER DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
53256	99.3 to 100.3 feet	Vertical Change	-27	5 ft	5	REF		
41916	101.5 to 102.5 feet	Vertical Change	-8	5 ft	5	SF	\$75	\$375
43173	109.9 to 110.9 feet	Vertical Change	-63	5 ft	5	SF	\$75	\$375
41755	119.5 to 120.5 feet	Vertical Change	-87	5 ft	5	SF	\$75	\$375
52291	122.1 to 123.1 feet	Vertical Change	-29	5 ft	5	LF	\$75	\$375
52767	129.6 to 130.6 feet	Vertical Change	-28	5 ft	5	LF	\$75	\$375
49842	139.8 to 140.8 feet	Vertical Change	-34	5 ft	5	LF	\$75	\$375
58612	144.8 to 187.5 feet	Driveway				REF		
44328	153.7 to 154.7 feet	Vertical Change	-56	5 ft	5	REF		
12340	153.9 to 155.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240
41655	154.4 to 155.4 feet	Vertical Change	-93	5 ft	5	REF		
12341	156.4 to 158.1 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	9	SF	\$40	\$340
12342	158.1 to 169.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	56	SF	\$40	\$2,240
42926	158.8 to 159.8 feet	Vertical Change	-65	5 ft	5	REF		
44131	162.6 to 163.6 feet	Vertical Change	-57	5 ft	5	REF		
43174	166.6 to 167.6 feet	Vertical Change	-63	5 ft	5	REF		
12344	169.3 to 185.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	80	SF	\$40	\$3,200
42322	170.5 to 171.5 feet	Vertical Change	-71	5 ft	5	REF		
43792	174.6 to 175.6 feet	Vertical Change	-59	5 ft	5	REF		
44758	178.3 to 179.3 feet	Vertical Change	-54	5 ft	5	REF		
44329	182.4 to 183.4 feet	Vertical Change	-56	5 ft	5	REF		
41779	186.4 to 187.4 feet	Vertical Change	-86	5 ft	5	REF		
12346	188.3 to 201.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	67	SF	\$40	\$2,680
53257	191.3 to 192.3 feet	Vertical Change	-27	5 ft	5	REF		
58613	194.0 to 226.3 feet	Driveway				REF		
44534	201.9 to 202.9 feet	Vertical Change	-55	5 ft	5	REF		
12348	202.6 to 204.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	11	SF	\$40	\$420
12350	204.7 to 222.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	87	SF	\$40	\$3,460

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908230934	PEACH DR	SANTA CRUZ BLVD	OLEANDER DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
45135	205.6 to 206.6 feet	Vertical Change	-.52	5 ft	5	REF			
48060	209.1 to 210.1 feet	Vertical Change	-.4	5 ft	5	REF			
44954	212.7 to 213.7 feet	Vertical Change	-.53	5 ft	5	REF			
44759	216.1 to 217.1 feet	Vertical Change	-.54	5 ft	5	REF			
47667	219.7 to 220.7 feet	Vertical Change	-.41	5 ft	5	REF			
42606	223.3 to 224.3 feet	Vertical Change	-.68	5 ft	5	REF			
49193	228.1 to 229.1 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375	
48908	234.2 to 247.4 feet	Vertical Change	-.37	5 ft	66	LF	\$75	\$4,950	
48911	250.5 to 281.6 feet	Vertical Change	-.37	5 ft	156	LF	\$75	\$11,663	
12352	272.5 to 284.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,020	
58614	274.3 to 316.3 feet	Driveway				REF			
41843	283.0 to 284.0 feet	Vertical Change	-.82	5 ft	5	REF			
12354	284.2 to 312.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	140	SF	\$40	\$5,580	
44955	287.2 to 288.2 feet	Vertical Change	-.53	5 ft	5	REF			
44330	291.3 to 292.3 feet	Vertical Change	-.56	5 ft	5	REF			
46258	295.3 to 296.3 feet	Vertical Change	-.47	5 ft	5	REF			
42927	299.2 to 300.2 feet	Vertical Change	-.65	5 ft	5	REF			
43793	303.2 to 304.2 feet	Vertical Change	-.59	5 ft	5	REF			
43483	307.2 to 308.2 feet	Vertical Change	-.61	5 ft	5	REF			
43794	311.2 to 312.2 feet	Vertical Change	-.59	5 ft	5	REF			
12358	312.1 to 313.4 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	6	SF	\$40	\$260	
12359	313.4 to 314.4 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200	
41298	315.2 to 316.2 feet	Vertical Change	-1.58	5 ft	5	REF			
48062	317.6 to 329.5 feet	Vertical Change	-.4	5 ft	59	LF	\$75	\$4,463	
58615	320.2 to 360.3 feet	Driveway				REF			
12360	321.3 to 323.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	10	SF	\$40	\$400	
12361	327.4 to 330.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	15	SF	\$40	\$600	
12363	330.4 to 346.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	79	SF	\$40	\$3,140	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230934	PEACH DR	SANTA CRUZ BLVD	OLEANDER DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
43175	332.8 to 333.8 feet	Vertical Change	-.63	5 ft	5	REF		
44331	337.0 to 338.0 feet	Vertical Change	-.56	5 ft	5	REF		
43318	341.1 to 342.1 feet	Vertical Change	-.62	5 ft	5	REF		
44535	345.1 to 346.1 feet	Vertical Change	-.55	5 ft	5	REF		
12367	346.1 to 358.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	60	SF	\$40	\$2,380
46719	349.1 to 350.1 feet	Vertical Change	-.45	5 ft	5	REF		
44332	353.0 to 354.0 feet	Vertical Change	-.56	5 ft	5	REF		
41408	360.6 to 361.6 feet	Vertical Change	-1.25	5 ft	5	REF		
12369	361.1 to 402.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	209	SF	\$120	\$25,020
48622	362.8 to 377.4 feet	Vertical Change	-.38	5 ft	73	REF		
48624	381.3 to 417.8 feet	Vertical Change	-.38	5 ft	183	REF		
12374	406.2 to 430.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	120	SF	\$120	\$14,400
58616	413.8 to 442.8 feet	Driveway				REF		
43961	421.4 to 422.4 feet	Vertical Change	-.58	5 ft	5	REF		
44333	426.7 to 427.7 feet	Vertical Change	-.56	5 ft	5	REF		
44133	432.1 to 433.1 feet	Vertical Change	-.57	5 ft	5	REF		
12375	432.4 to 437.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	26	SF	\$40	\$1,020
44536	437.2 to 438.2 feet	Vertical Change	-.55	5 ft	5	REF		
12377	437.5 to 443.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	29	SF	\$40	\$1,140
46042	442.5 to 443.5 feet	Vertical Change	-.48	5 ft	5	REF		
12380	443.2 to 461.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	91	SF	\$40	\$3,620
50175	447.2 to 448.2 feet	Vertical Change	-.33	5 ft	5	REF		
42928	450.6 to 451.6 feet	Vertical Change	-.65	5 ft	5	REF		
58617	453.0 to 482.5 feet	Driveway				REF		
46259	460.4 to 461.4 feet	Vertical Change	-.47	5 ft	5	REF		
12384	462.8 to 469.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	31	SF	\$40	\$1,240
46720	465.6 to 466.6 feet	Vertical Change	-.45	5 ft	5	REF		
12385	469.0 to 478.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	48	SF	\$40	\$1,900

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908230934	PEACH DR	SANTA CRUZ BLVD	OLEANDER DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
44537	470.8 to 471.8 feet	Vertical Change	-.55	5 ft	5	REF			
12386	478.5 to 480.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	11	SF	\$40	\$420	
12387	480.6 to 482.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	11	SF	\$40	\$440	
52768	481.7 to 482.7 feet	Vertical Change	-.28	5 ft	5	REF			
12389	482.8 to 483.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$600	
12390	483.8 to 592.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	546	SF	\$120	\$65,460	
47164	519.1 to 520.1 feet	Vertical Change	-.43	5 ft	5	REF			
58618	529.8 to 571.8 feet	Driveway				REF			
49524	534.1 to 535.1 feet	Vertical Change	-.35	5 ft	5	REF			
44760	543.0 to 544.0 feet	Vertical Change	-.54	5 ft	5	REF			
45136	547.1 to 548.1 feet	Vertical Change	-.52	5 ft	5	REF			
46043	551.0 to 552.0 feet	Vertical Change	-.48	5 ft	5	REF			
44334	555.0 to 556.0 feet	Vertical Change	-.56	5 ft	5	REF			
44134	558.9 to 559.9 feet	Vertical Change	-.57	5 ft	5	REF			
48627	567.0 to 568.0 feet	Vertical Change	-.38	5 ft	5	REF			
44538	576.1 to 577.1 feet	Vertical Change	-.55	5 ft	5	REF			
48914	581.8 to 582.8 feet	Vertical Change	-.37	5 ft	5	REF			
58619	583.6 to 612.9 feet	Driveway				REF			
45333	591.8 to 593.0 feet	Vertical Change	-.51	5 ft	6	REF			
12409	592.9 to 613.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	104	SF	\$40	\$4,180	
42812	597.0 to 598.0 feet	Vertical Change	-.66	5 ft	5	REF			
42813	602.2 to 603.2 feet	Vertical Change	-.66	5 ft	5	REF			
44539	607.2 to 608.2 feet	Vertical Change	-.55	5 ft	5	REF			
43795	610.8 to 613.5 feet	Vertical Change	-.59	5 ft	14	REF			
12413	613.8 to 641.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	140	SF	\$120	\$16,740	
42929	619.8 to 620.8 feet	Vertical Change	-.65	5 ft	5	REF			
43962	627.3 to 628.3 feet	Vertical Change	-.58	5 ft	5	REF			
48348	637.2 to 638.2 feet	Vertical Change	-.39	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230934	PEACH DR	SANTA CRUZ BLVD	OLEANDER DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
43963	641.3 to 642.3 feet	Vertical Change	-.58	5 ft	5	REF		
TOTAL COST FOR: S side of PEACH DR Starting at: SANTA CRUZ BLVD							\$218,515.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908230937	PEACH DR	OLEANDER DR	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
49202	1.9 to 2.9 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375	
12415	12.1 to 18.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020	
58620	13.0 to 51.5 feet	Driveway				REF			
53787	14.9 to 15.9 feet	Vertical Change	-.26	5 ft	5	REF			
12417	18.8 to 27.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	41	SF	\$40	\$1,640	
47415	23.7 to 24.7 feet	Vertical Change	-.42	5 ft	5	REF			
12421	27.0 to 59.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	161	SF	\$40	\$6,440	
52292	27.6 to 28.6 feet	Vertical Change	-.29	5 ft	5	REF			
49203	31.5 to 32.5 feet	Vertical Change	-.36	5 ft	5	REF			
46490	39.4 to 40.4 feet	Vertical Change	-.46	5 ft	5	REF			
49204	43.3 to 44.3 feet	Vertical Change	-.36	5 ft	5	REF			
12426	63.2 to 71.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,860	
58621	65.4 to 90.4 feet	Driveway				REF			
12428	71.3 to 78.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	38	SF	\$40	\$1,500	
47671	71.7 to 73.1 feet	Vertical Change	-.41	5 ft	7	REF			
47165	77.0 to 78.0 feet	Vertical Change	-.43	5 ft	5	REF			
12432	78.8 to 90.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	58	SF	\$40	\$2,300	
12435	90.3 to 131.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	206	SF	\$40	\$8,220	
52293	101.5 to 104.8 feet	Vertical Change	-.29	5 ft	17	REF			
50176	108.7 to 114.9 feet	Vertical Change	-.33	5 ft	31	REF			
48349	119.5 to 120.5 feet	Vertical Change	-.39	5 ft	5	REF			
47672	125.2 to 139.6 feet	Vertical Change	-.41	5 ft	72	REF			
12439	131.4 to 156.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	123	SF	\$120	\$14,760	
58622	143.8 to 186.4 feet	Driveway				REF			
48066	146.2 to 147.2 feet	Vertical Change	-.4	5 ft	5	REF			
44335	153.6 to 154.6 feet	Vertical Change	-.56	5 ft	5	REF			
12445	156.0 to 168.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	62	SF	\$40	\$2,480	
53258	157.7 to 158.7 feet	Vertical Change	-.27	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908230937	PEACH DR	OLEANDER DR	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
48915	161.7 to 162.7 feet	Vertical Change	-.37	5 ft	5	REF			
48350	165.7 to 166.7 feet	Vertical Change	-.39	5 ft	5	REF			
12447	168.4 to 183.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	73	SF	\$40	\$2,920	
47673	169.6 to 170.6 feet	Vertical Change	-.41	5 ft	5	REF			
43484	173.4 to 174.4 feet	Vertical Change	-.61	5 ft	5	REF			
46261	177.2 to 178.2 feet	Vertical Change	-.47	5 ft	5	REF			
44956	181.2 to 182.2 feet	Vertical Change	-.53	5 ft	5	REF			
12449	183.0 to 191.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	43	SF	\$40	\$1,700	
48067	185.2 to 188.6 feet	Vertical Change	-.4	5 ft	17	REF			
12451	191.5 to 208.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	83	SF	\$120	\$9,900	
50957	192.5 to 193.5 feet	Vertical Change	-.31	5 ft	5	REF			
58623	194.8 to 237.8 feet	Driveway				REF			
50567	197.4 to 198.4 feet	Vertical Change	-.32	5 ft	5	REF			
51877	202.2 to 203.2 feet	Vertical Change	-.3	5 ft	5	REF			
12455	208.0 to 215.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	39	SF	\$40	\$1,540	
53788	208.7 to 209.7 feet	Vertical Change	-.26	5 ft	5	REF			
52294	212.5 to 213.5 feet	Vertical Change	-.29	5 ft	5	REF			
12457	215.7 to 239.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	118	SF	\$40	\$4,720	
45634	216.3 to 217.3 feet	Vertical Change	-.5	5 ft	5	REF			
48916	220.1 to 221.1 feet	Vertical Change	-.37	5 ft	5	REF			
50958	224.1 to 225.1 feet	Vertical Change	-.31	5 ft	5	REF			
49205	227.9 to 228.9 feet	Vertical Change	-.36	5 ft	5	REF			
44336	231.9 to 232.9 feet	Vertical Change	-.56	5 ft	5	REF			
52770	242.9 to 243.9 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
53789	255.2 to 256.2 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
46722	259.5 to 268.0 feet	Vertical Change	-.45	5 ft	43	LF	\$75	\$3,188	
49526	271.8 to 284.7 feet	Vertical Change	-.35	5 ft	65	LF	\$75	\$4,838	
12461	276.0 to 281.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230937	PEACH DR	OLEANDER DR	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58624	276.5 to 316.1 feet	Driveway				REF		
12462	284.6 to 312.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	138	SF	\$40	\$5,500
46492	287.6 to 288.6 feet	Vertical Change	-.46	5 ft	5	REF		
46723	291.8 to 292.8 feet	Vertical Change	-.45	5 ft	5	REF		
47416	295.7 to 296.7 feet	Vertical Change	-.42	5 ft	5	REF		
44540	299.7 to 300.7 feet	Vertical Change	-.55	5 ft	5	REF		
53259	303.5 to 304.5 feet	Vertical Change	-.27	5 ft	5	REF		
44761	307.4 to 308.4 feet	Vertical Change	-.54	5 ft	5	REF		
44957	311.3 to 312.3 feet	Vertical Change	-.53	5 ft	5	REF		
12469	312.1 to 349.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	187	SF	\$40	\$7,500
46493	315.6 to 334.6 feet	Vertical Change	-.46	5 ft	95	REF		
58625	325.2 to 355.0 feet	Driveway				REF		
45635	338.9 to 339.9 feet	Vertical Change	-.5	5 ft	5	REF		
43319	344.1 to 345.1 feet	Vertical Change	-.62	5 ft	5	REF		
44762	349.4 to 350.4 feet	Vertical Change	-.54	5 ft	5	REF		
12475	349.6 to 353.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	17	SF	\$40	\$680
12476	353.0 to 355.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	14	SF	\$40	\$540
56919	353.5 to 354.5 feet	Vertical Change	.51	5 ft	5	REF		
42814	354.7 to 355.7 feet	Vertical Change	-.66	5 ft	5	REF		
12478	355.7 to 357.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$780
52295	356.9 to 368.3 feet	Vertical Change	-.29	5 ft	57	REF		
12479	357.0 to 410.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	269	SF	\$120	\$32,220
44338	369.5 to 394.9 feet	Vertical Change	-.56	5 ft	127	REF		
51878	396.3 to 409.5 feet	Vertical Change	-.3	5 ft	66	REF		
58626	401.9 to 444.8 feet	Driveway				REF		
12485	410.7 to 423.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	65	SF	\$40	\$2,600
46045	414.7 to 415.7 feet	Vertical Change	-.48	5 ft	5	REF		
48069	418.8 to 419.8 feet	Vertical Change	-.4	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908230937	PEACH DR	OLEANDER DR	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
52297	422.6 to 423.6 feet	Vertical Change	-0.29	5 ft	5	REF			
12489	423.7 to 462.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	196	SF	\$40	\$7,820	
49528	426.5 to 427.5 feet	Vertical Change	-0.35	5 ft	5	REF			
46937	430.5 to 431.5 feet	Vertical Change	-0.44	5 ft	5	REF			
45138	434.5 to 435.5 feet	Vertical Change	-0.52	5 ft	5	REF			
54102	438.7 to 439.7 feet	Vertical Change	-0.25	5 ft	5	REF			
46262	443.2 to 451.2 feet	Vertical Change	-0.47	5 ft	40	REF			
58627	452.6 to 493.1 feet	Driveway				REF			
50181	454.6 to 455.6 feet	Vertical Change	-0.33	5 ft	5	REF			
47167	461.7 to 462.7 feet	Vertical Change	-0.43	5 ft	5	REF			
12495	462.8 to 485.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	116	SF	\$40	\$4,620	
52771	465.9 to 466.9 feet	Vertical Change	-0.28	5 ft	5	REF			
47168	469.8 to 470.8 feet	Vertical Change	-0.43	5 ft	5	REF			
46725	473.8 to 474.8 feet	Vertical Change	-0.45	5 ft	5	REF			
48070	477.6 to 478.6 feet	Vertical Change	-0.4	5 ft	5	REF			
46938	481.4 to 482.4 feet	Vertical Change	-0.44	5 ft	5	REF			
46263	485.2 to 486.2 feet	Vertical Change	-0.47	5 ft	5	REF			
12498	485.9 to 495.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	50	SF	\$40	\$2,000	
52298	489.1 to 490.1 feet	Vertical Change	-0.29	5 ft	5	REF			
42063	493.2 to 494.2 feet	Vertical Change	-0.76	5 ft	5	REF			
49209	498.0 to 506.5 feet	Vertical Change	-0.36	5 ft	43	LF	\$75	\$3,188	
12502	508.1 to 553.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	228	SF	\$120	\$27,420	
52772	510.4 to 513.9 feet	Vertical Change	-0.28	5 ft	18	REF			
43638	515.3 to 521.2 feet	Vertical Change	-0.6	5 ft	30	REF			
50568	525.2 to 543.7 feet	Vertical Change	-0.32	5 ft	93	REF			
42420	545.1 to 548.4 feet	Vertical Change	-0.7	5 ft	17	REF			
58628	546.6 to 573.8 feet	Driveway				REF			
47678	549.5 to 555.5 feet	Vertical Change	-0.41	5 ft	30	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230937	PEACH DR	OLEANDER DR	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
12506	557.2 to 571.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	72	SF	\$40	\$2,880
43320	564.6 to 565.6 feet	Vertical Change	-.62	5 ft	5	REF		
44764	574.3 to 587.3 feet	Vertical Change	-.54	5 ft	65	REF		
12508	575.7 to 577.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,260
12509	584.8 to 592.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,500
58629	585.3 to 614.6 feet	Driveway				REF		
52773	588.8 to 594.4 feet	Vertical Change	-.28	5 ft	28	REF		
12511	592.3 to 594.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	10	SF	\$40	\$400
12513	594.3 to 598.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	23	SF	\$40	\$900
46265	598.6 to 599.6 feet	Vertical Change	-.47	5 ft	5	REF		
12514	598.8 to 614.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	79	SF	\$40	\$3,160
46727	603.6 to 604.6 feet	Vertical Change	-.45	5 ft	5	REF		
45833	608.7 to 609.7 feet	Vertical Change	-.49	5 ft	5	REF		
47417	613.8 to 626.8 feet	Vertical Change	-.42	5 ft	65	REF		
12516	614.6 to 616.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	11	SF	\$40	\$440
12517	616.8 to 632.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	81	SF	\$120	\$9,660
49211	630.8 to 631.8 feet	Vertical Change	-.36	5 ft	5	REF		
TOTAL COST FOR: N side of PEACH DR Starting at: OLEANDER DR							\$197,217.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908230938	SANTA CRUZ BLVD	PEACH DR	HOWELL RD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
12522	5.6 to 41.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	181	SF	\$120	\$21,720	
50183	27.6 to 28.6 feet	Vertical Change	-.33	5 ft	5	REF			
54149	37.8 to 38.8 feet	Vertical Change	.26	5 ft	5	REF			
12527	47.7 to 51.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,280	
12528	53.8 to 87.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	170	SF	\$120	\$20,400	
12537	114.5 to 119.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,880	
52299	117.6 to 118.6 feet	Vertical Change	-.29	5 ft	5	REF			
12538	123.5 to 128.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,940	
49529	127.2 to 128.2 feet	Vertical Change	-.35	5 ft	5	REF			
12539	135.9 to 145.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,700	
43485	146.8 to 147.8 feet	Vertical Change	-.61	5 ft	5	SF	\$75	\$375	
12541	150.9 to 152.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660	
52300	156.8 to 157.8 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375	
44542	166.6 to 167.6 feet	Vertical Change	-.55	5 ft	5	SF	\$75	\$375	
TOTAL COST FOR:		E	<i>side of</i> SANTA CRUZ BLVD	<i>Starting at:</i> PEACH DR				\$57,705.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908230939	SANTA CRUZ BLVD	HOWELL RD	PEACH DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51883	0.3 to 1.3 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375
12542	12.5 to 56.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	218	SF	\$120	\$26,160
12544	56.1 to 61.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	26	SF	\$120	\$3,120
12546	61.3 to 83.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	110	SF	\$120	\$13,200
54103	70.5 to 71.5 feet	Vertical Change	-.25	5 ft	5	REF		
12549	86.8 to 90.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400
12550	99.2 to 125.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	131	SF	\$120	\$15,720
49212	118.5 to 119.5 feet	Vertical Change	-.36	5 ft	5	REF		
52301	127.9 to 131.3 feet	Vertical Change	-.29	5 ft	17	REF		
12553	128.1 to 178.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	253	SF	\$120	\$30,360
46940	146.9 to 147.9 feet	Vertical Change	-.44	5 ft	5	REF		
43639	166.3 to 167.3 feet	Vertical Change	-.6	5 ft	5	REF		
48919	180.8 to 181.8 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: W side of SANTA CRUZ BLVD Starting at: HOWELL RD							\$91,710.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908230942	SANTA CRUZ BLVD	PEACH DR	PLUM CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
52774	2.0 to 3.0 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
12559	8.1 to 14.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,900	
44543	14.1 to 15.1 feet	Vertical Change	-.55	5 ft	5	REF			
12561	14.6 to 43.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	147	SF	\$120	\$17,580	
53262	21.8 to 22.8 feet	Vertical Change	-.27	5 ft	5	REF			
12563	43.9 to 90.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	233	SF	\$120	\$27,900	
47680	50.7 to 51.7 feet	Vertical Change	-.41	5 ft	5	REF			
56627	50.8 to 51.8 feet	Vertical Change	.44	5 ft	5	REF			
52775	60.2 to 61.2 feet	Vertical Change	-.28	5 ft	5	REF			
42421	70.0 to 71.0 feet	Vertical Change	-.7	5 ft	5	REF			
44339	79.6 to 80.6 feet	Vertical Change	-.56	5 ft	5	REF			
12570	107.4 to 121.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	69	SF	\$120	\$8,220	
48073	108.3 to 109.3 feet	Vertical Change	-.4	5 ft	5	REF			
49213	117.7 to 118.7 feet	Vertical Change	-.36	5 ft	5	REF			
12571	134.8 to 166.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	158	SF	\$120	\$18,960	
41216	137.7 to 138.7 feet	Vertical Change	-2.18	5 ft	5	REF			
57548	137.7 to 138.7 feet	Vertical Change	2.2	5 ft	5	REF			
12574	170.1 to 180.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,420	
50962	180.2 to 181.2 feet	Vertical Change	-.31	5 ft	5	REF			

TOTAL COST FOR:	W	<i>side of</i>	SANTA CRUZ BLVD	<i>Starting at:</i>	PEACH DR	\$83,355.00
------------------------	----------	----------------	------------------------	---------------------	-----------------	--------------------

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908230944	PLUM WAY	SANTA CRUZ BLVD	WALNUT WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
46268	1.6 to 2.6 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375	
12577	2.7 to 27.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	122	SF	\$120	\$14,580	
48356	7.5 to 13.2 feet	Vertical Change	-.39	5 ft	29	REF			
58630	15.9 to 54.8 feet	Driveway				REF			
50184	17.1 to 23.8 feet	Vertical Change	-.33	5 ft	33	REF			
46728	28.8 to 29.8 feet	Vertical Change	-.45	5 ft	5	REF			
43640	34.5 to 35.5 feet	Vertical Change	-.6	5 ft	5	REF			
46269	38.9 to 39.9 feet	Vertical Change	-.47	5 ft	5	REF			
56639	39.0 to 40.0 feet	Vertical Change	.47	5 ft	5	REF			
49530	43.5 to 44.5 feet	Vertical Change	-.35	5 ft	5	REF			
12578	48.8 to 52.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	17	SF	\$40	\$680	
45834	49.2 to 50.2 feet	Vertical Change	-.49	5 ft	5	REF			
12580	52.2 to 68.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	81	SF	\$40	\$3,220	
47681	55.0 to 73.4 feet	Vertical Change	-.41	5 ft	92	REF			
58631	64.2 to 91.8 feet	Driveway				REF			
12583	68.3 to 90.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	110	SF	\$40	\$4,400	
48074	77.9 to 78.9 feet	Vertical Change	-.4	5 ft	5	REF			
47682	83.2 to 84.2 feet	Vertical Change	-.41	5 ft	5	REF			
45835	88.3 to 89.3 feet	Vertical Change	-.49	5 ft	5	REF			
12587	90.3 to 130.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	201	SF	\$40	\$8,020	
56913	93.5 to 94.5 feet	Vertical Change	.5	5 ft	5	REF			
44544	93.8 to 98.8 feet	Vertical Change	-.55	5 ft	25	REF			
53793	99.2 to 103.6 feet	Vertical Change	-.26	5 ft	22	REF			
52302	106.6 to 107.6 feet	Vertical Change	-.29	5 ft	5	REF			
43964	108.6 to 115.6 feet	Vertical Change	-.58	5 ft	35	REF			
50965	116.7 to 121.7 feet	Vertical Change	-.31	5 ft	25	REF			
43641	122.8 to 123.8 feet	Vertical Change	-.6	5 ft	5	REF			
49853	124.8 to 127.7 feet	Vertical Change	-.34	5 ft	15	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230944	PLUM WAY	SANTA CRUZ BLVD	WALNUT WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
12591	130.4 to 144.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,160
49854	132.8 to 133.8 feet	Vertical Change	-.34	5 ft	5	REF		
58632	134.3 to 162.3 feet	Driveway				REF		
49855	136.7 to 137.7 feet	Vertical Change	-.34	5 ft	5	REF		
41393	138.6 to 139.6 feet	Vertical Change	-1.29	5 ft	5	REF		
43321	140.7 to 143.8 feet	Vertical Change	-.62	5 ft	16	REF		
12595	144.0 to 165.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	108	SF	\$40	\$4,320
44138	148.3 to 149.3 feet	Vertical Change	-.57	5 ft	5	REF		
41917	153.3 to 154.3 feet	Vertical Change	-.8	5 ft	5	REF		
43796	158.3 to 159.3 feet	Vertical Change	-.59	5 ft	5	REF		
44545	162.1 to 164.5 feet	Vertical Change	-.55	5 ft	12	REF		
41548	165.3 to 166.3 feet	Vertical Change	-1.03	5 ft	5	REF		
12602	165.6 to 175.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$5,940
50967	167.2 to 172.0 feet	Vertical Change	-.31	5 ft	24	REF		
58633	169.0 to 196.3 feet	Driveway				REF		
41918	172.4 to 173.4 feet	Vertical Change	-.8	5 ft	5	REF		
46498	173.8 to 176.3 feet	Vertical Change	-.46	5 ft	13	REF		
12604	176.4 to 181.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	25	SF	\$40	\$980
46942	178.6 to 179.6 feet	Vertical Change	-.44	5 ft	5	REF		
12606	181.3 to 183.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	9	SF	\$40	\$340
53264	182.1 to 183.1 feet	Vertical Change	-.27	5 ft	5	REF		
12607	183.0 to 192.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	49	SF	\$40	\$1,940
48075	185.5 to 186.5 feet	Vertical Change	-.4	5 ft	5	REF		
50572	189.1 to 190.1 feet	Vertical Change	-.32	5 ft	5	REF		
47419	192.6 to 193.6 feet	Vertical Change	-.42	5 ft	5	REF		
12609	192.7 to 216.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	121	SF	\$40	\$4,840
45336	196.3 to 197.3 feet	Vertical Change	-.51	5 ft	5	REF		
48076	216.3 to 221.3 feet	Vertical Change	-.4	5 ft	25	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908230944	PLUM WAY	SANTA CRUZ BLVD	WALNUT WAY	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
12615	216.9 to 218.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020	
12616	222.4 to 245.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	117	SF	\$120	\$14,040	
52777	224.3 to 239.9 feet	Vertical Change	-28	5 ft	78	REF			
58634	238.1 to 266.4 feet	Driveway				REF			
43486	241.3 to 245.0 feet	Vertical Change	-.61	5 ft	19	REF			
12621	245.8 to 253.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	37	SF	\$40	\$1,460	
51887	251.4 to 252.4 feet	Vertical Change	-.3	5 ft	5	REF			
12625	253.1 to 262.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	49	SF	\$40	\$1,940	
44546	255.7 to 256.7 feet	Vertical Change	-.55	5 ft	5	REF			
44765	260.2 to 261.2 feet	Vertical Change	-.54	5 ft	5	REF			
12627	262.8 to 268.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	28	SF	\$40	\$1,120	
45140	264.7 to 282.4 feet	Vertical Change	-.52	5 ft	88	REF			
12629	268.4 to 270.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320	
12630	278.1 to 280.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500	
58635	280.7 to 308.7 feet	Driveway				REF			
53796	282.8 to 283.8 feet	Vertical Change	-.26	5 ft	5	REF			
12631	284.9 to 286.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$260	
48921	286.0 to 287.0 feet	Vertical Change	-.37	5 ft	5	REF			
12632	287.1 to 306.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	94	SF	\$40	\$3,780	
43039	292.4 to 293.4 feet	Vertical Change	-.64	5 ft	5	REF			
46271	301.3 to 302.3 feet	Vertical Change	-.47	5 ft	5	REF			
12636	306.0 to 307.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	8	SF	\$40	\$320	
12637	307.6 to 308.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$220	
46050	309.3 to 310.3 feet	Vertical Change	-.48	5 ft	5	REF			
12638	310.3 to 315.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,940	
50576	316.2 to 321.5 feet	Vertical Change	-.32	5 ft	27	LF	\$75	\$1,988	
50973	324.8 to 325.8 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	

TOTAL COST FOR: N side of PLUM WAY Starting at: SANTA CRUZ BLVD \$90,077.50

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908230946	WALNUT WAY	PLUM WAY	CHERRY WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
58636	0.0 to 36.7 feet	Driveway				REF			
43797	0.8 to 3.7 feet	Vertical Change	-59	5 ft	15	REF			
12639	3.7 to 34.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	153	SF	\$40	\$6,120	
48633	18.1 to 19.1 feet	Vertical Change	-.38	5 ft	5	REF			
50577	32.1 to 33.1 feet	Vertical Change	-.32	5 ft	5	REF			
40374	32.2 to 35.1 feet	Running Slope	5.0-6.0%	5 ft	14	REF			
45836	36.0 to 37.0 feet	Vertical Change	-.49	5 ft	5	REF			
58637	38.8 to 64.8 feet	Driveway				REF			
12642	41.5 to 43.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	12	SF	\$40	\$460	
42815	44.2 to 47.0 feet	Vertical Change	-.66	5 ft	14	REF			
12643	47.5 to 62.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	75	SF	\$40	\$2,980	
47420	53.9 to 54.9 feet	Vertical Change	-.42	5 ft	5	REF			
40376	61.9 to 63.8 feet	Running Slope	8.0-9.0%	5 ft	10	REF			
42504	63.2 to 67.8 feet	Vertical Change	-.69	5 ft	23	REF			
49857	66.8 to 76.8 feet	Vertical Change	-.34	5 ft	50	REF			
12647	66.8 to 115.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	245	SF	\$120	\$29,400	
52780	89.9 to 90.9 feet	Vertical Change	-.28	5 ft	5	REF			
54104	100.1 to 101.1 feet	Vertical Change	-.25	5 ft	5	REF			
58638	106.8 to 135.5 feet	Driveway				REF			
43798	112.3 to 116.0 feet	Vertical Change	-.59	5 ft	19	REF			
12657	115.8 to 120.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	25	SF	\$40	\$980	
42323	118.1 to 119.1 feet	Vertical Change	-.71	5 ft	5	REF			
12659	120.7 to 121.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	6	SF	\$40	\$220	
42707	121.6 to 122.6 feet	Vertical Change	-.67	5 ft	5	REF			
12660	121.8 to 129.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	40	SF	\$40	\$1,600	
42505	125.2 to 129.1 feet	Vertical Change	-.69	5 ft	20	REF			
12661	129.8 to 133.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	20	SF	\$40	\$800	
46943	136.1 to 147.3 feet	Vertical Change	-.44	5 ft	56	REF			
58639	139.4 to 167.7 feet	Driveway				REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908230946	WALNUT WAY	PLUM WAY	CHERRY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
12663	141.6 to 146.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	23	SF	\$40	\$900
12665	148.1 to 152.7 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	23	SF	\$40	\$920
52781	149.9 to 150.9 feet	Vertical Change	-.28	5 ft	5	REF		
12667	152.7 to 156.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	18	SF	\$40	\$720
45337	153.4 to 154.4 feet	Vertical Change	-.51	5 ft	5	REF		
12668	156.3 to 157.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	6	SF	\$40	\$240
46051	156.7 to 157.7 feet	Vertical Change	-.48	5 ft	5	REF		
12669	157.5 to 159.4 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	10	SF	\$40	\$380
12670	159.4 to 166.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	33	SF	\$40	\$1,320
47421	160.2 to 161.2 feet	Vertical Change	-.42	5 ft	5	REF		
47683	163.6 to 164.6 feet	Vertical Change	-.41	5 ft	5	REF		
12671	166.0 to 167.1 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$220
43799	167.3 to 170.2 feet	Vertical Change	-.59	5 ft	15	REF		
12672	167.9 to 168.9 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200
12673	168.9 to 170.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780
41358	171.2 to 172.2 feet	Vertical Change	-1.38	5 ft	5	SF	\$75	\$375
12674	173.7 to 178.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760
41870	177.2 to 178.2 feet	Vertical Change	-.81	5 ft	5	REF		
42506	187.1 to 188.1 feet	Vertical Change	-.69	5 ft	5	SF	\$75	\$375
41735	196.7 to 197.7 feet	Vertical Change	-.88	5 ft	5	SF	\$75	\$375
12675	198.1 to 239.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	209	SF	\$120	\$25,080
44340	206.2 to 207.2 feet	Vertical Change	-.56	5 ft	5	REF		
58640	208.0 to 237.3 feet	Driveway				REF		
41190	211.9 to 212.9 feet	Vertical Change	-2.58	5 ft	5	REF		
43322	213.9 to 217.8 feet	Vertical Change	-.62	5 ft	20	REF		
56920	216.9 to 217.9 feet	Vertical Change	.51	5 ft	5	REF		
42608	219.6 to 220.6 feet	Vertical Change	-.68	5 ft	5	REF		
45142	222.9 to 223.9 feet	Vertical Change	-.52	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908230946	WALNUT WAY	PLUM WAY	CHERRY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
43488	226.4 to 227.4 feet	Vertical Change	-.61	5 ft	5	REF		
44959	229.8 to 230.8 feet	Vertical Change	-.53	5 ft	5	REF		
44547	233.0 to 234.0 feet	Vertical Change	-.55	5 ft	5	REF		
43643	236.2 to 239.7 feet	Vertical Change	-.6	5 ft	18	REF		
41521	240.9 to 241.9 feet	Vertical Change	-1.07	5 ft	5	SF	\$75	\$375
48635	247.9 to 248.9 feet	Vertical Change	-.38	5 ft	5	REF		
58641	248.3 to 276.3 feet	Driveway				REF		
12680	248.6 to 268.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	100	SF	\$40	\$4,000
41597	252.2 to 253.2 feet	Vertical Change	-.99	5 ft	5	REF		
44769	254.3 to 263.3 feet	Vertical Change	-.54	5 ft	45	REF		
41871	265.5 to 266.5 feet	Vertical Change	-.81	5 ft	5	REF		
44960	268.7 to 269.7 feet	Vertical Change	-.53	5 ft	5	REF		
45637	272.0 to 273.0 feet	Vertical Change	-.5	5 ft	5	REF		
12683	273.2 to 307.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	173	SF	\$40	\$6,920
46272	275.5 to 276.5 feet	Vertical Change	-.47	5 ft	5	REF		
41844	278.0 to 281.4 feet	Vertical Change	-.82	5 ft	17	REF		
54105	284.4 to 285.4 feet	Vertical Change	-.25	5 ft	5	REF		
42708	290.8 to 291.8 feet	Vertical Change	-.67	5 ft	5	REF		
58642	295.7 to 338.3 feet	Driveway				REF		
41598	298.7 to 299.7 feet	Vertical Change	-.99	5 ft	5	REF		
42931	300.7 to 303.5 feet	Vertical Change	-.65	5 ft	14	REF		
42610	306.6 to 307.6 feet	Vertical Change	-.68	5 ft	5	REF		
44548	310.6 to 311.6 feet	Vertical Change	-.55	5 ft	5	REF		
42709	314.6 to 315.6 feet	Vertical Change	-.67	5 ft	5	REF		
46945	318.3 to 319.3 feet	Vertical Change	-.44	5 ft	5	REF		
47169	321.6 to 322.6 feet	Vertical Change	-.43	5 ft	5	REF		
47422	325.3 to 326.3 feet	Vertical Change	-.42	5 ft	5	REF		
12689	327.6 to 330.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	13	SF	\$40	\$540

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908230946	WALNUT WAY	PLUM WAY	CHERRY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51889	328.8 to 329.8 feet	Vertical Change	-.3	5 ft	5	REF		
12691	330.3 to 332.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	11	SF	\$40	\$440
45638	332.5 to 334.5 feet	Vertical Change	-.5	5 ft	10	REF		
12693	332.5 to 334.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	10	SF	\$40	\$400
12695	334.5 to 336.4 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	10	SF	\$40	\$380
44140	337.7 to 338.7 feet	Vertical Change	-.57	5 ft	5	REF		
TOTAL COST FOR: W side of WALNUT WAY Starting at: PLUM WAY							\$90,260.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230948	CHERRY WAY	WALNUT WAY	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
12696	0.0 to 4.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400
58643	0.0 to 29.3 feet	Driveway				REF		
45837	3.7 to 4.7 feet	Vertical Change	-49	5 ft	5	REF		
12698	4.0 to 8.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	22	SF	\$40	\$880
12700	8.4 to 12.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	19	SF	\$40	\$740
44341	8.9 to 9.9 feet	Vertical Change	-56	5 ft	5	REF		
44771	12.8 to 13.8 feet	Vertical Change	-54	5 ft	5	REF		
42324	16.4 to 17.4 feet	Vertical Change	-71	5 ft	5	REF		
44141	20.4 to 21.4 feet	Vertical Change	-57	5 ft	5	REF		
12701	23.3 to 43.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	99	SF	\$40	\$3,960
42611	24.5 to 25.5 feet	Vertical Change	-68	5 ft	5	REF		
42325	28.8 to 32.3 feet	Vertical Change	-71	5 ft	17	REF		
41532	33.2 to 34.2 feet	Vertical Change	-1.05	5 ft	5	REF		
44342	42.9 to 43.9 feet	Vertical Change	-56	5 ft	5	REF		
12704	50.3 to 81.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	154	SF	\$120	\$18,420
43323	52.6 to 53.6 feet	Vertical Change	-62	5 ft	5	REF		
43176	61.4 to 62.4 feet	Vertical Change	-63	5 ft	5	REF		
44549	70.3 to 71.3 feet	Vertical Change	-55	5 ft	5	REF		
58644	71.3 to 99.6 feet	Driveway				REF		
41240	75.4 to 76.4 feet	Vertical Change	-1.92	5 ft	5	REF		
42932	77.4 to 79.5 feet	Vertical Change	-65	5 ft	10	REF		
57122	78.6 to 79.6 feet	Vertical Change	.6	5 ft	5	REF		
43965	79.4 to 80.4 feet	Vertical Change	-58	5 ft	5	REF		
43644	82.9 to 83.9 feet	Vertical Change	-6	5 ft	5	REF		
44961	86.3 to 87.3 feet	Vertical Change	-53	5 ft	5	REF		
45338	89.9 to 90.9 feet	Vertical Change	-51	5 ft	5	REF		
43645	93.3 to 94.3 feet	Vertical Change	-6	5 ft	5	REF		
43489	96.8 to 97.8 feet	Vertical Change	-61	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230948	CHERRY WAY	WALNUT WAY	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
12707	98.5 to 110.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	62	SF	\$40	\$2,460
44143	102.4 to 103.4 feet	Vertical Change	-.57	5 ft	5	REF		
41331	104.7 to 105.7 feet	Vertical Change	-1.45	5 ft	5	REF		
43177	106.7 to 107.7 feet	Vertical Change	-.63	5 ft	5	REF		
58645	107.9 to 138.4 feet	Driveway				REF		
41301	110.7 to 111.7 feet	Vertical Change	-1.57	5 ft	5	REF		
46946	114.0 to 117.1 feet	Vertical Change	-.44	5 ft	16	REF		
46273	119.5 to 120.5 feet	Vertical Change	-.47	5 ft	5	REF		
44343	122.8 to 123.8 feet	Vertical Change	-.56	5 ft	5	REF		
43178	126.4 to 127.4 feet	Vertical Change	-.63	5 ft	5	REF		
43324	129.6 to 130.6 feet	Vertical Change	-.62	5 ft	5	REF		
44550	133.2 to 134.2 feet	Vertical Change	-.55	5 ft	5	REF		
43800	137.0 to 138.0 feet	Vertical Change	-.59	5 ft	5	REF		
56977	137.5 to 138.5 feet	Vertical Change	.57	5 ft	5	REF		
46502	139.1 to 140.1 feet	Vertical Change	-.46	5 ft	5	LF	\$75	\$375
42161	141.2 to 142.2 feet	Vertical Change	-.74	5 ft	5	SF	\$75	\$375
49215	146.3 to 147.3 feet	Vertical Change	-.36	5 ft	5	REF		
12708	146.9 to 164.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,260
42507	165.5 to 166.5 feet	Vertical Change	-.69	5 ft	5	SF	\$75	\$375
58646	167.2 to 206.6 feet	Driveway				REF		
12710	167.3 to 175.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	40	SF	\$40	\$1,580
41500	174.5 to 175.5 feet	Vertical Change	-1.1	5 ft	5	REF		
12712	175.2 to 182.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	35	SF	\$40	\$1,380
44551	178.2 to 179.2 feet	Vertical Change	-.55	5 ft	5	REF		
57162	178.3 to 179.3 feet	Vertical Change	.68	5 ft	5	REF		
42817	180.5 to 181.5 feet	Vertical Change	-.66	5 ft	5	REF		
12717	182.1 to 189.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	36	SF	\$40	\$1,440
42508	183.6 to 184.6 feet	Vertical Change	-.69	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230948	CHERRY WAY	WALNUT WAY	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
42249	186.8 to 187.8 feet	Vertical Change	-.72	5 ft	5	REF		
42423	189.9 to 190.9 feet	Vertical Change	-.7	5 ft	5	REF		
42710	193.2 to 194.2 feet	Vertical Change	-.67	5 ft	5	REF		
42711	196.4 to 197.4 feet	Vertical Change	-.67	5 ft	5	REF		
43966	199.9 to 200.9 feet	Vertical Change	-.58	5 ft	5	REF		
12718	200.3 to 203.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	17	SF	\$40	\$680
42509	203.3 to 204.3 feet	Vertical Change	-.69	5 ft	5	REF		
12720	203.7 to 207.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	21	SF	\$40	\$820
43041	206.9 to 207.9 feet	Vertical Change	-.64	5 ft	5	REF		
12723	208.7 to 219.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,300
41610	209.1 to 210.1 feet	Vertical Change	-.97	5 ft	5	REF		
58647	213.3 to 238.3 feet	Driveway				REF		
41872	215.4 to 218.2 feet	Vertical Change	-.81	5 ft	14	REF		
45339	219.1 to 220.1 feet	Vertical Change	-.51	5 ft	5	REF		
12725	222.4 to 236.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	68	SF	\$40	\$2,720
42818	228.8 to 229.8 feet	Vertical Change	-.66	5 ft	5	REF		
12729	236.0 to 237.0 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	5	SF	\$40	\$200
44552	238.8 to 244.0 feet	Vertical Change	-.55	5 ft	26	SF	\$75	\$1,950
54106	246.9 to 247.9 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375
42819	248.9 to 249.9 feet	Vertical Change	-.66	5 ft	5	SF	\$75	\$375
42933	258.5 to 259.5 feet	Vertical Change	-.65	5 ft	5	SF	\$75	\$375
12730	266.0 to 268.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380
44344	268.3 to 269.3 feet	Vertical Change	-.56	5 ft	5	REF		
42820	277.8 to 278.8 feet	Vertical Change	-.66	5 ft	5	SF	\$75	\$375
58648	280.8 to 307.6 feet	Driveway				REF		
45838	285.0 to 288.4 feet	Vertical Change	-.49	5 ft	17	REF		
12731	287.3 to 301.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	72	SF	\$40	\$2,860
57154	289.4 to 290.4 feet	Vertical Change	.66	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
S	1908230948	CHERRY WAY	WALNUT WAY	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
42612	290.8 to 291.8 feet	Vertical Change	-.68	5 ft	5	REF			
43646	294.4 to 295.4 feet	Vertical Change	-.6	5 ft	5	REF			
42202	297.9 to 298.9 feet	Vertical Change	-.73	5 ft	5	REF			
42613	301.0 to 302.0 feet	Vertical Change	-.68	5 ft	5	REF			
12735	301.6 to 307.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	28	SF	\$40	\$1,100	
47686	304.2 to 305.2 feet	Vertical Change	-.41	5 ft	5	REF			
47423	307.8 to 311.1 feet	Vertical Change	-.42	5 ft	17	REF			
58649	311.8 to 340.1 feet	Driveway				REF			
48922	315.2 to 319.9 feet	Vertical Change	-.37	5 ft	23	REF			
12737	320.4 to 323.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	15	SF	\$40	\$600	
44146	322.6 to 323.6 feet	Vertical Change	-.57	5 ft	5	REF			
45144	325.9 to 326.9 feet	Vertical Change	-.52	5 ft	5	REF			
43490	329.0 to 330.0 feet	Vertical Change	-.61	5 ft	5	REF			
42614	332.6 to 333.6 feet	Vertical Change	-.68	5 ft	5	REF			
44553	336.0 to 337.0 feet	Vertical Change	-.55	5 ft	5	REF			
12738	336.3 to 340.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	23	SF	\$40	\$900	
42510	339.4 to 342.6 feet	Vertical Change	-.69	5 ft	16	REF			
46052	349.2 to 350.2 feet	Vertical Change	-.48	5 ft	5	LF	\$75	\$375	
53797	366.5 to 367.5 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375	
43801	368.3 to 369.3 feet	Vertical Change	-.59	5 ft	5	SF	\$75	\$375	
12739	370.6 to 372.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260	
58650	371.3 to 408.7 feet	Driveway				REF			
46947	373.8 to 378.9 feet	Vertical Change	-.44	5 ft	26	REF			
12740	380.8 to 401.4 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	103	SF	\$40	\$4,120	
43326	388.6 to 389.6 feet	Vertical Change	-.62	5 ft	5	REF			
44962	398.2 to 399.2 feet	Vertical Change	-.53	5 ft	5	REF			
12744	401.4 to 406.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	27	SF	\$40	\$1,080	
40377	406.0 to 408.1 feet	Running Slope	6.0-7.0%	5 ft	11	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230948	CHERRY WAY	WALNUT WAY	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
43327	409.2 to 414.2 feet	Vertical Change	-.62	5 ft	25	REF		
58651	417.4 to 443.6 feet	Driveway				REF		
52304	419.8 to 424.9 feet	Vertical Change	-.29	5 ft	26	REF		
12745	423.1 to 424.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$220
12746	426.7 to 432.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	27	SF	\$40	\$1,060
12748	432.0 to 442.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	53	SF	\$40	\$2,120
43328	433.8 to 434.8 feet	Vertical Change	-.62	5 ft	5	REF		
40378	441.4 to 443.7 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
43967	444.5 to 448.4 feet	Vertical Change	-.58	5 ft	20	REF		
12750	445.7 to 449.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	18	SF	\$120	\$2,100
12752	449.2 to 455.0 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	29	SF	\$120	\$3,480
48357	452.3 to 453.3 feet	Vertical Change	-.39	5 ft	5	REF		
12754	455.0 to 457.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	13	SF	\$120	\$1,560
43647	456.7 to 457.7 feet	Vertical Change	-.6	5 ft	5	REF		
12755	457.6 to 459.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380
TOTAL COST FOR: S side of CHERRY WAY Starting at: WALNUT WAY							\$85,160.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908230950	CHERRY WAY	SANTA CRUZ BLVD	WALNUT WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
12756	0.9 to 11.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,480	
47424	4.0 to 5.0 feet	Vertical Change	-.42	5 ft	5	REF			
47171	10.8 to 11.8 feet	Vertical Change	-.43	5 ft	5	REF			
12758	11.7 to 27.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	81	SF	\$120	\$9,660	
48078	15.6 to 16.6 feet	Vertical Change	-.4	5 ft	5	REF			
56647	15.7 to 16.7 feet	Vertical Change	.49	5 ft	5	REF			
53798	20.7 to 21.7 feet	Vertical Change	-.26	5 ft	5	REF			
43042	22.5 to 23.5 feet	Vertical Change	-.64	5 ft	5	REF			
12760	27.8 to 45.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,320	
54107	35.4 to 36.4 feet	Vertical Change	-.25	5 ft	5	REF			
52782	47.7 to 48.7 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375	
43968	51.6 to 52.6 feet	Vertical Change	-.58	5 ft	5	SF	\$75	\$375	
58652	54.0 to 82.2 feet	Driveway				REF			
48079	55.5 to 62.3 feet	Vertical Change	-.4	5 ft	34	REF			
12761	59.2 to 64.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	28	SF	\$40	\$1,120	
48923	65.2 to 66.2 feet	Vertical Change	-.37	5 ft	5	REF			
47172	68.9 to 69.9 feet	Vertical Change	-.43	5 ft	5	REF			
46729	72.2 to 73.2 feet	Vertical Change	-.45	5 ft	5	REF			
46274	75.5 to 76.5 feet	Vertical Change	-.47	5 ft	5	REF			
46053	78.7 to 79.7 feet	Vertical Change	-.48	5 ft	5	REF			
12762	81.0 to 104.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	119	SF	\$40	\$4,740	
45147	82.1 to 85.5 feet	Vertical Change	-.52	5 ft	17	REF			
41484	86.6 to 87.6 feet	Vertical Change	-1.12	5 ft	5	REF			
43802	89.6 to 90.6 feet	Vertical Change	-.59	5 ft	5	REF			
54108	93.2 to 94.2 feet	Vertical Change	-.25	5 ft	5	REF			
43329	96.7 to 100.4 feet	Vertical Change	-.62	5 ft	19	REF			
58653	99.3 to 126.6 feet	Driveway				REF			
41637	102.3 to 105.3 feet	Vertical Change	-.94	5 ft	15	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908230950	CHERRY WAY	SANTA CRUZ BLVD	WALNUT WAY	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
12764	104.7 to 113.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	43	SF	\$40	\$1,720	
44772	106.4 to 107.4 feet	Vertical Change	-.54	5 ft	5	REF			
43180	110.1 to 111.1 feet	Vertical Change	-.63	5 ft	5	REF			
12768	113.3 to 133.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	102	SF	\$40	\$4,060	
42934	113.5 to 114.5 feet	Vertical Change	-.65	5 ft	5	REF			
42935	116.8 to 117.8 feet	Vertical Change	-.65	5 ft	5	REF			
42712	120.1 to 121.1 feet	Vertical Change	-.67	5 ft	5	REF			
44963	123.3 to 124.3 feet	Vertical Change	-.53	5 ft	5	REF			
43648	127.3 to 128.5 feet	Vertical Change	-.6	5 ft	6	REF			
56935	127.7 to 128.7 feet	Vertical Change	.53	5 ft	5	REF			
45341	129.5 to 130.5 feet	Vertical Change	-.51	5 ft	5	REF			
41684	131.8 to 132.8 feet	Vertical Change	-.91	5 ft	5	REF			
47425	136.9 to 137.9 feet	Vertical Change	-.42	5 ft	5	LF	\$75	\$375	
49532	146.6 to 147.6 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$375	
12771	149.9 to 166.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	81	SF	\$120	\$9,660	
43044	156.4 to 157.4 feet	Vertical Change	-.64	5 ft	5	REF			
58654	159.3 to 199.0 feet	Driveway				REF			
41564	162.2 to 163.2 feet	Vertical Change	-1.01	5 ft	5	REF			
56921	163.7 to 164.7 feet	Vertical Change	.51	5 ft	5	REF			
44556	164.1 to 167.1 feet	Vertical Change	-.55	5 ft	15	REF			
12773	168.8 to 171.7 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	15	SF	\$40	\$580	
49533	169.7 to 170.7 feet	Vertical Change	-.35	5 ft	5	REF			
12775	171.7 to 175.4 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	19	SF	\$40	\$740	
44964	173.7 to 174.7 feet	Vertical Change	-.53	5 ft	5	REF			
12777	175.4 to 177.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	12	SF	\$40	\$480	
42615	177.4 to 178.4 feet	Vertical Change	-.68	5 ft	5	REF			
12778	177.8 to 194.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	83	SF	\$40	\$3,320	
43045	180.8 to 181.8 feet	Vertical Change	-.64	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230950	CHERRY WAY	SANTA CRUZ BLVD	WALNUT WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
49858	183.9 to 184.9 feet	Vertical Change	-.34	5 ft	5	REF		
43491	187.2 to 188.2 feet	Vertical Change	-.61	5 ft	5	REF		
45149	190.9 to 191.9 feet	Vertical Change	-.52	5 ft	5	REF		
12780	194.4 to 200.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	30	SF	\$40	\$1,180
43803	194.6 to 195.6 feet	Vertical Change	-.59	5 ft	5	REF		
45150	198.5 to 201.4 feet	Vertical Change	-.52	5 ft	15	REF		
12782	200.3 to 214.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	71	SF	\$120	\$8,460
41810	202.0 to 203.0 feet	Vertical Change	-.84	5 ft	5	REF		
46730	205.3 to 206.3 feet	Vertical Change	-.45	5 ft	5	REF		
47173	212.2 to 213.2 feet	Vertical Change	-.43	5 ft	5	REF		
58655	213.3 to 243.3 feet	Driveway				REF		
50578	218.0 to 219.0 feet	Vertical Change	-.32	5 ft	5	REF		
12784	218.8 to 227.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	43	SF	\$40	\$1,700
43181	220.0 to 223.0 feet	Vertical Change	-.63	5 ft	15	REF		
44557	225.5 to 226.5 feet	Vertical Change	-.55	5 ft	5	REF		
43970	228.8 to 229.8 feet	Vertical Change	-.58	5 ft	5	REF		
47687	232.2 to 233.2 feet	Vertical Change	-.41	5 ft	5	REF		
42823	235.6 to 236.6 feet	Vertical Change	-.66	5 ft	5	REF		
12787	236.4 to 246.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	50	SF	\$40	\$2,000
42616	239.0 to 240.0 feet	Vertical Change	-.68	5 ft	5	REF		
44965	242.1 to 247.7 feet	Vertical Change	-.53	5 ft	28	REF		
12788	251.4 to 252.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720
42512	252.9 to 253.9 feet	Vertical Change	-.69	5 ft	5	SF	\$75	\$375
44346	262.6 to 263.6 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375
12789	265.2 to 285.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	103	SF	\$120	\$12,360
44347	272.3 to 273.3 feet	Vertical Change	-.56	5 ft	5	REF		
42936	282.0 to 283.0 feet	Vertical Change	-.65	5 ft	5	REF		
58656	284.3 to 311.3 feet	Driveway				REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908230950	CHERRY WAY	SANTA CRUZ BLVD	WALNUT WAY	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
12791	285.8 to 289.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	20	SF	\$40	\$800	
41611	287.7 to 288.7 feet	Vertical Change	-.97	5 ft	5	REF			
44558	289.6 to 292.7 feet	Vertical Change	-.55	5 ft	15	REF			
12793	289.8 to 293.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	19	SF	\$40	\$760	
12795	293.6 to 298.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	25	SF	\$40	\$1,020	
43804	295.1 to 296.1 feet	Vertical Change	-.59	5 ft	5	REF			
47426	298.6 to 299.6 feet	Vertical Change	-.42	5 ft	5	REF			
12797	298.7 to 300.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$320	
43805	301.9 to 302.9 feet	Vertical Change	-.59	5 ft	5	REF			
42713	305.2 to 306.2 feet	Vertical Change	-.67	5 ft	5	REF			
45841	308.4 to 309.4 feet	Vertical Change	-.49	5 ft	5	REF			
48080	312.2 to 315.4 feet	Vertical Change	-.4	5 ft	16	LF	\$75	\$1,200	
12798	315.2 to 317.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260	
12799	321.5 to 327.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,840	
45640	324.2 to 325.2 feet	Vertical Change	-.5	5 ft	5	REF			
58657	326.8 to 354.1 feet	Driveway				REF			
12800	331.3 to 335.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	21	SF	\$40	\$820	
43649	331.7 to 334.9 feet	Vertical Change	-.6	5 ft	16	REF			
12802	335.4 to 343.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	42	SF	\$40	\$1,680	
43650	337.5 to 338.5 feet	Vertical Change	-.6	5 ft	5	REF			
44773	341.0 to 342.0 feet	Vertical Change	-.54	5 ft	5	REF			
12804	343.8 to 345.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$320	
44348	344.3 to 348.2 feet	Vertical Change	-.56	5 ft	20	REF			
12805	349.2 to 355.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	33	SF	\$40	\$1,320	
44774	350.3 to 351.3 feet	Vertical Change	-.54	5 ft	5	REF			
46275	353.7 to 357.1 feet	Vertical Change	-.47	5 ft	17	REF			
41811	358.0 to 359.0 feet	Vertical Change	-.84	5 ft	5	SF	\$75	\$375	
46276	361.1 to 362.1 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230950	CHERRY WAY	SANTA CRUZ BLVD	WALNUT WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
12808	366.6 to 378.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,020
43971	368.9 to 369.9 feet	Vertical Change	-.58	5 ft	5	REF		
53799	375.2 to 376.2 feet	Vertical Change	-.26	5 ft	5	REF		
12810	378.3 to 386.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	42	SF	\$120	\$5,040
41409	379.6 to 380.6 feet	Vertical Change	-1.25	5 ft	5	REF		
49534	386.3 to 387.3 feet	Vertical Change	-.35	5 ft	5	REF		
TOTAL COST FOR: N side of CHERRY WAY Starting at: SANTA CRUZ BLVD							\$107,700.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908230951	WALNUT WAY	PLUM WAY	CHERRY WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
12812	0.0 to 21.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	107	SF	\$120	\$12,780	
42937	4.5 to 5.5 feet	Vertical Change	-.65	5 ft	5	REF			
12813	22.0 to 23.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	6	SF	\$120	\$720	
41599	22.2 to 23.2 feet	Vertical Change	-.99	5 ft	5	REF			
12814	23.2 to 31.4 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	41	SF	\$120	\$4,920	
54109	23.9 to 24.9 feet	Vertical Change	-.25	5 ft	5	REF			
48924	31.8 to 32.8 feet	Vertical Change	-.37	5 ft	5	REF			
12817	32.2 to 33.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	5	SF	\$120	\$600	
12818	34.1 to 42.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$4,980	
40379	38.3 to 39.6 feet	Running Slope	6.0-7.0%	5 ft	7	REF			
57580	40.6 to 41.6 feet	Vertical Change	2.71	5 ft	5	REF			
45641	42.1 to 43.1 feet	Vertical Change	-.5	5 ft	5	REF			
12821	42.4 to 50.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	39	SF	\$120	\$4,620	
12823	50.1 to 51.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600	
45642	50.5 to 51.5 feet	Vertical Change	-.5	5 ft	5	REF			
47174	79.4 to 80.4 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375	
47175	89.4 to 90.4 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375	
12824	97.8 to 100.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800	
12826	100.8 to 124.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	119	SF	\$120	\$14,280	
49216	118.7 to 119.7 feet	Vertical Change	-.36	5 ft	5	REF			
12829	124.6 to 137.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	66	SF	\$120	\$7,920	
47176	128.1 to 129.1 feet	Vertical Change	-.43	5 ft	5	REF			
12831	137.8 to 165.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	137	SF	\$120	\$16,440	
53269	149.3 to 150.3 feet	Vertical Change	-.27	5 ft	5	REF			
43806	164.4 to 165.4 feet	Vertical Change	-.59	5 ft	5	REF			
12835	165.2 to 171.9 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	34	SF	\$120	\$4,020	
51890	168.5 to 169.5 feet	Vertical Change	-.3	5 ft	5	REF			
12836	171.9 to 174.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	12	SF	\$120	\$1,380	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908230951	WALNUT WAY	PLUM WAY	CHERRY WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46055	172.6 to 173.6 feet	Vertical Change	-.48	5 ft	5	REF		
12838	174.2 to 199.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	126	SF	\$120	\$15,060
54110	176.6 to 177.6 feet	Vertical Change	-.25	5 ft	5	REF		
53800	180.6 to 183.6 feet	Vertical Change	-.26	5 ft	15	REF		
53801	186.5 to 189.4 feet	Vertical Change	-.26	5 ft	15	REF		
43047	190.5 to 191.5 feet	Vertical Change	-.64	5 ft	5	REF		
50975	192.1 to 194.7 feet	Vertical Change	-.31	5 ft	13	REF		
53802	196.8 to 197.8 feet	Vertical Change	-.26	5 ft	5	REF		
42714	198.4 to 199.4 feet	Vertical Change	-.67	5 ft	5	REF		
TOTAL COST FOR: E side of WALNUT WAY Starting at: PLUM WAY							\$90,870.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908230953	PLUM WAY	WALNUT WAY	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
12841	0.0 to 1.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	10	SF	\$120	\$1,140	
12842	1.9 to 13.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,140	
49217	2.9 to 3.9 feet	Vertical Change	-36	5 ft	5	REF			
12844	13.8 to 47.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	170	SF	\$120	\$20,400	
45842	14.9 to 15.9 feet	Vertical Change	-49	5 ft	5	REF			
41712	25.3 to 26.3 feet	Vertical Change	-89	5 ft	5	REF			
41208	25.4 to 26.4 feet	Vertical Change	-2.37	5 ft	5	REF			
58658	26.1 to 49.8 feet	Driveway				REF			
44966	27.2 to 31.1 feet	Vertical Change	-53	5 ft	20	REF			
50191	34.4 to 35.4 feet	Vertical Change	-33	5 ft	5	REF			
50976	39.7 to 40.7 feet	Vertical Change	-31	5 ft	5	REF			
12852	47.8 to 49.7 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	10	SF	\$40	\$380	
52784	48.4 to 50.0 feet	Vertical Change	-28	5 ft	8	REF			
12853	49.7 to 52.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	13	SF	\$40	\$520	
44775	51.0 to 52.0 feet	Vertical Change	-54	5 ft	5	REF			
12855	52.3 to 60.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	40	SF	\$120	\$4,740	
12856	60.2 to 62.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560	
42715	62.8 to 63.8 feet	Vertical Change	-67	5 ft	5	REF			
12858	62.8 to 74.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	56	SF	\$120	\$6,720	
42513	72.7 to 73.7 feet	Vertical Change	-69	5 ft	5	REF			
12860	74.0 to 76.7 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	14	SF	\$120	\$1,620	
12861	76.7 to 82.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	28	SF	\$120	\$3,360	
58659	77.0 to 113.0 feet	Driveway				REF			
41191	78.3 to 79.3 feet	Vertical Change	-2.58	5 ft	5	REF			
44967	80.2 to 83.1 feet	Vertical Change	-53	5 ft	15	REF			
12864	83.9 to 89.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	27	SF	\$40	\$1,080	
47177	86.4 to 87.4 feet	Vertical Change	-43	5 ft	5	REF			
12866	89.3 to 95.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	32	SF	\$40	\$1,260	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908230953	PLUM WAY	WALNUT WAY	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
46950	89.8 to 90.8 feet	Vertical Change	-.44	5 ft	5	REF			
42939	94.4 to 95.4 feet	Vertical Change	-.65	5 ft	5	REF			
12868	95.6 to 106.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	54	SF	\$40	\$2,160	
43652	99.0 to 100.0 feet	Vertical Change	-.6	5 ft	5	REF			
41756	103.2 to 104.2 feet	Vertical Change	-.87	5 ft	5	REF			
12870	106.4 to 109.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	14	SF	\$40	\$560	
44350	107.0 to 108.0 feet	Vertical Change	-.56	5 ft	5	REF			
12871	109.2 to 112.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	18	SF	\$40	\$720	
45643	114.2 to 117.3 feet	Vertical Change	-.5	5 ft	16	REF			
12872	114.6 to 115.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$660	
12873	115.7 to 142.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	135	SF	\$120	\$16,140	
41606	118.4 to 119.4 feet	Vertical Change	-.98	5 ft	5	REF			
53803	126.2 to 127.2 feet	Vertical Change	-.26	5 ft	5	REF			
58660	129.3 to 158.2 feet	Driveway				REF			
45343	133.7 to 138.8 feet	Vertical Change	-.51	5 ft	26	REF			
44776	143.0 to 144.0 feet	Vertical Change	-.54	5 ft	5	REF			
42424	148.0 to 149.0 feet	Vertical Change	-.7	5 ft	5	REF			
44560	152.5 to 153.5 feet	Vertical Change	-.55	5 ft	5	REF			
12875	156.3 to 159.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	14	SF	\$40	\$560	
43182	157.9 to 161.1 feet	Vertical Change	-.63	5 ft	16	REF			
12876	159.1 to 226.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	339	SF	\$120	\$40,620	
41359	162.0 to 163.0 feet	Vertical Change	-1.38	5 ft	5	REF			
53804	164.0 to 167.0 feet	Vertical Change	-.26	5 ft	15	REF			
44147	173.0 to 174.0 feet	Vertical Change	-.57	5 ft	5	REF			
50977	181.0 to 182.0 feet	Vertical Change	-.31	5 ft	5	REF			
41780	183.0 to 184.0 feet	Vertical Change	-.86	5 ft	5	REF			
42162	192.5 to 193.5 feet	Vertical Change	-.74	5 ft	5	REF			
54111	198.4 to 201.3 feet	Vertical Change	-.25	5 ft	15	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230953	PLUM WAY	WALNUT WAY	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
42825	202.2 to 203.2 feet	Vertical Change	-.66	5 ft	5	REF		
53806	204.1 to 207.0 feet	Vertical Change	-.26	5 ft	15	REF		
53270	209.8 to 210.8 feet	Vertical Change	-.27	5 ft	5	REF		
42425	211.6 to 212.6 feet	Vertical Change	-.7	5 ft	5	REF		
58661	213.4 to 241.5 feet	Driveway				REF		
44777	217.2 to 222.3 feet	Vertical Change	-.54	5 ft	26	REF		
56947	222.9 to 223.9 feet	Vertical Change	.54	5 ft	5	REF		
42940	224.9 to 225.9 feet	Vertical Change	-.65	5 ft	5	REF		
43183	228.3 to 229.3 feet	Vertical Change	-.63	5 ft	5	REF		
43654	231.8 to 232.8 feet	Vertical Change	-.6	5 ft	5	REF		
46505	235.2 to 236.2 feet	Vertical Change	-.46	5 ft	5	REF		
44968	238.4 to 239.4 feet	Vertical Change	-.53	5 ft	5	REF		
12886	239.6 to 251.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	59	SF	\$40	\$2,360
42514	245.9 to 246.9 feet	Vertical Change	-.69	5 ft	5	REF		
57140	246.0 to 247.0 feet	Vertical Change	.63	5 ft	5	REF		
53807	251.4 to 252.4 feet	Vertical Change	-.26	5 ft	5	REF		
42515	256.2 to 257.2 feet	Vertical Change	-.69	5 ft	5	SF	\$75	\$375
54113	258.1 to 259.1 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375
12889	260.1 to 276.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	81	SF	\$120	\$9,720
58662	261.2 to 284.8 feet	Driveway				REF		
42716	263.7 to 266.6 feet	Vertical Change	-.67	5 ft	15	REF		
49218	272.8 to 273.8 feet	Vertical Change	-.36	5 ft	5	REF		
12892	277.2 to 278.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200
12893	278.2 to 281.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	15	SF	\$40	\$600
12895	281.2 to 284.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	15	SF	\$40	\$580
47427	285.9 to 290.1 feet	Vertical Change	-.42	5 ft	21	REF		
12896	286.9 to 295.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,400
41993	294.2 to 295.2 feet	Vertical Change	-.78	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908230953	PLUM WAY	WALNUT WAY	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
12898	295.9 to 304.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	42	SF	\$120	\$5,040
52785	299.1 to 300.1 feet	Vertical Change	-.28	5 ft	5	REF		
57237	299.2 to 300.2 feet	Vertical Change	.73	5 ft	5	REF		
42251	303.2 to 304.2 feet	Vertical Change	-.72	5 ft	5	REF		
54114	303.2 to 304.2 feet	Vertical Change	-.25	5 ft	5	REF		
12902	304.3 to 305.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780
TOTAL COST FOR: S side of PLUM WAY Starting at: WALNUT WAY							\$136,770.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority		
W	1908230954	SANTA CRUZ BLVD	PLUM WAY	CHERRY WAY					TBD		
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
41194	4.9 to 5.9 feet	Vertical Change	-2.5	5 ft	5	SF	\$75	\$375			
12903	10.6 to 48.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	188	SF	\$120	\$22,500			
43972	10.9 to 11.9 feet	Vertical Change	-.58	5 ft	5	REF					
48636	17.2 to 18.2 feet	Vertical Change	-.38	5 ft	5	REF					
52306	46.9 to 47.9 feet	Vertical Change	-.29	5 ft	5	REF					
54115	56.5 to 57.5 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375			
12908	60.8 to 63.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560			
53808	66.2 to 67.2 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375			
42941	76.1 to 77.1 feet	Vertical Change	-.65	5 ft	5	SF	\$75	\$375			
12909	88.2 to 98.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,300			
53271	95.9 to 96.9 feet	Vertical Change	-.27	5 ft	5	REF					
54150	96.0 to 97.0 feet	Vertical Change	.26	5 ft	5	REF					
12911	104.0 to 118.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,820			
44351	115.5 to 116.5 feet	Vertical Change	-.56	5 ft	5	REF					
54116	132.7 to 136.1 feet	Vertical Change	-.25	5 ft	17	LF	\$75	\$1,275			
12916	143.3 to 185.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	212	SF	\$120	\$25,500			
49219	154.5 to 155.5 feet	Vertical Change	-.36	5 ft	5	REF					
53809	189.9 to 190.9 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375			
TOTAL COST FOR: W							<i>side of</i>	SANTA CRUZ BLVD	<i>Starting at:</i>	PLUM WAY	\$67,830.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908230955	SANTA CRUZ BLVD	CHERRY WAY	PARKRIDGE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
12924	3.4 to 28.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	127	SF	\$120	\$15,240
46056	3.6 to 4.6 feet	Vertical Change	-.48	5 ft	5	REF		
50978	9.7 to 10.7 feet	Vertical Change	-.31	5 ft	5	REF		
12927	31.0 to 71.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	202	SF	\$120	\$24,180
48637	46.0 to 47.0 feet	Vertical Change	-.38	5 ft	5	REF		
53810	74.8 to 75.8 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
12929	80.7 to 97.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	82	SF	\$120	\$9,780
46731	84.6 to 85.6 feet	Vertical Change	-.45	5 ft	5	REF		
48925	94.2 to 95.2 feet	Vertical Change	-.37	5 ft	5	REF		
12930	100.3 to 125.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	125	SF	\$120	\$15,000
41845	113.9 to 114.9 feet	Vertical Change	-.82	5 ft	5	REF		
50192	133.6 to 134.6 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375
12935	136.1 to 144.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,160
12936	148.7 to 164.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	79	SF	\$120	\$9,420
42617	153.1 to 154.1 feet	Vertical Change	-.68	5 ft	5	REF		
53811	172.5 to 173.5 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375
12937	179.3 to 189.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,120
49859	187.4 to 188.4 feet	Vertical Change	-.34	5 ft	5	REF		
TOTAL COST FOR: W side of SANTA CRUZ BLVD Starting at: CHERRY WAY							\$86,025.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230959	PARKRIDGE DR	SANTA CRUZ BLVD	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
12940	0.6 to 2.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	11	SF	\$120	\$1,320
52307	1.3 to 2.3 feet	Vertical Change	-29	5 ft	5	REF		
12941	2.8 to 22.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	101	SF	\$120	\$12,060
48081	6.4 to 7.4 feet	Vertical Change	-.4	5 ft	5	REF		
45153	10.8 to 11.8 feet	Vertical Change	-.52	5 ft	5	REF		
58663	17.6 to 54.6 feet	Driveway				REF		
54117	17.7 to 20.2 feet	Vertical Change	-.25	5 ft	13	REF		
43655	21.0 to 24.0 feet	Vertical Change	-.6	5 ft	15	REF		
12945	23.7 to 32.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	46	SF	\$40	\$1,840
43048	27.0 to 28.0 feet	Vertical Change	-.64	5 ft	5	REF		
57158	27.0 to 28.0 feet	Vertical Change	.67	5 ft	5	REF		
42618	30.4 to 31.4 feet	Vertical Change	-.68	5 ft	5	REF		
12949	32.9 to 42.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	50	SF	\$40	\$1,980
50193	34.1 to 35.1 feet	Vertical Change	-.33	5 ft	5	REF		
43493	37.5 to 38.5 feet	Vertical Change	-.61	5 ft	5	REF		
43049	40.7 to 41.7 feet	Vertical Change	-.64	5 ft	5	REF		
43050	43.9 to 44.9 feet	Vertical Change	-.64	5 ft	5	REF		
45344	47.6 to 48.6 feet	Vertical Change	-.51	5 ft	5	REF		
47178	51.2 to 52.2 feet	Vertical Change	-.43	5 ft	5	REF		
12950	52.6 to 77.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	125	SF	\$40	\$4,980
49535	55.1 to 56.1 feet	Vertical Change	-.35	5 ft	5	REF		
43494	57.4 to 60.5 feet	Vertical Change	-.61	5 ft	16	REF		
43184	67.4 to 68.4 feet	Vertical Change	-.63	5 ft	5	REF		
58664	67.7 to 96.9 feet	Driveway				REF		
44148	72.6 to 77.9 feet	Vertical Change	-.57	5 ft	27	REF		
12951	78.3 to 95.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	88	SF	\$40	\$3,500
44778	80.2 to 81.2 feet	Vertical Change	-.54	5 ft	5	REF		
42619	83.6 to 84.6 feet	Vertical Change	-.68	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230959	PARKRIDGE DR	SANTA CRUZ BLVD	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
42942	87.1 to 88.1 feet	Vertical Change	-.65	5 ft	5	REF		
43052	90.2 to 91.2 feet	Vertical Change	-.64	5 ft	5	REF		
42516	97.0 to 102.2 feet	Vertical Change	-.69	5 ft	26	REF		
12957	97.6 to 98.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
44149	106.7 to 107.7 feet	Vertical Change	-.57	5 ft	5	SF	\$75	\$375
43973	116.2 to 117.2 feet	Vertical Change	-.58	5 ft	5	SF	\$75	\$375
12958	123.8 to 130.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020
49860	126.2 to 127.2 feet	Vertical Change	-.34	5 ft	5	REF		
50979	135.4 to 136.4 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375
12959	137.8 to 140.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,620
58665	139.6 to 166.2 feet	Driveway				REF		
12961	140.5 to 143.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	15	SF	\$40	\$600
12963	143.5 to 144.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$260
49220	145.5 to 146.5 feet	Vertical Change	-.36	5 ft	5	REF		
48358	149.1 to 150.1 feet	Vertical Change	-.39	5 ft	5	REF		
45645	152.4 to 153.4 feet	Vertical Change	-.5	5 ft	5	REF		
47688	159.2 to 160.2 feet	Vertical Change	-.41	5 ft	5	REF		
48638	162.5 to 163.5 feet	Vertical Change	-.38	5 ft	5	REF		
12964	163.3 to 184.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	106	SF	\$40	\$4,260
50194	166.5 to 172.1 feet	Vertical Change	-.33	5 ft	28	REF		
58666	174.0 to 204.2 feet	Driveway				REF		
50579	178.4 to 182.0 feet	Vertical Change	-.32	5 ft	18	REF		
12970	184.6 to 188.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	21	SF	\$40	\$840
46951	187.5 to 188.5 feet	Vertical Change	-.44	5 ft	5	REF		
12972	188.8 to 192.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	17	SF	\$40	\$680
45646	191.0 to 192.0 feet	Vertical Change	-.5	5 ft	5	REF		
49536	194.2 to 195.2 feet	Vertical Change	-.35	5 ft	5	REF		
50196	197.3 to 198.3 feet	Vertical Change	-.33	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230959	PARKRIDGE DR	SANTA CRUZ BLVD	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
48927	200.6 to 201.6 feet	Vertical Change	-.37	5 ft	5	REF		
12973	201.6 to 217.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	81	SF	\$40	\$3,240
53812	206.8 to 207.8 feet	Vertical Change	-.26	5 ft	5	REF		
48928	215.4 to 216.4 feet	Vertical Change	-.37	5 ft	5	REF		
51893	225.2 to 226.2 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375
46057	234.9 to 235.9 feet	Vertical Change	-.48	5 ft	5	LF	\$75	\$375
12975	244.3 to 252.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800
48359	244.8 to 245.8 feet	Vertical Change	-.39	5 ft	5	REF		
58667	247.8 to 275.9 feet	Driveway				REF		
50197	250.6 to 251.6 feet	Vertical Change	-.33	5 ft	5	REF		
50980	254.6 to 255.6 feet	Vertical Change	-.31	5 ft	5	REF		
12976	258.1 to 261.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	17	SF	\$40	\$680
12978	261.5 to 273.2 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	59	SF	\$40	\$2,340
50198	277.3 to 278.3 feet	Vertical Change	-.33	5 ft	5	LF	\$75	\$375
58668	283.1 to 322.7 feet	Driveway				REF		
47428	288.4 to 291.5 feet	Vertical Change	-.42	5 ft	16	REF		
12981	290.7 to 296.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	28	SF	\$40	\$1,100
42827	294.4 to 295.4 feet	Vertical Change	-.66	5 ft	5	REF		
44562	298.1 to 299.1 feet	Vertical Change	-.55	5 ft	5	REF		
12982	299.6 to 303.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	18	SF	\$40	\$740
42253	301.7 to 305.6 feet	Vertical Change	-.72	5 ft	20	REF		
42828	307.8 to 311.7 feet	Vertical Change	-.66	5 ft	20	REF		
47179	314.6 to 315.6 feet	Vertical Change	-.43	5 ft	5	REF		
43053	318.6 to 319.6 feet	Vertical Change	-.64	5 ft	5	REF		
12983	320.1 to 327.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	36	SF	\$40	\$1,440
42254	322.9 to 327.9 feet	Vertical Change	-.72	5 ft	25	REF		
44563	332.7 to 333.7 feet	Vertical Change	-.55	5 ft	5	SF	\$75	\$375
53813	334.7 to 335.7 feet	Vertical Change	-.26	5 ft	5	LF	\$75	\$375

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908230959	PARKRIDGE DR	SANTA CRUZ BLVD	COTTONWOOD DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
56927	336.9 to 337.9 feet	Vertical Change	.52	5 ft	5	SF	\$75	\$375	
45844	337.0 to 338.0 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$375	
45154	342.3 to 343.3 feet	Vertical Change	-.52	5 ft	5	SF	\$75	\$375	
49221	351.9 to 352.9 feet	Vertical Change	-.36	5 ft	5	LF	\$75	\$375	
58669	354.4 to 381.3 feet	Driveway				REF			
50981	357.3 to 360.3 feet	Vertical Change	-.31	5 ft	15	REF			
42620	361.4 to 362.4 feet	Vertical Change	-.68	5 ft	5	REF			
12984	364.9 to 378.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	70	SF	\$40	\$2,780	
42064	371.6 to 372.6 feet	Vertical Change	-.76	5 ft	5	REF			
42427	381.5 to 389.5 feet	Vertical Change	-.7	5 ft	40	REF			
12987	382.4 to 418.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	179	SF	\$120	\$21,420	
58670	391.6 to 419.3 feet	Driveway				REF			
49537	394.4 to 395.4 feet	Vertical Change	-.35	5 ft	5	REF			
42163	396.4 to 399.6 feet	Vertical Change	-.74	5 ft	16	REF			
42065	402.2 to 403.2 feet	Vertical Change	-.76	5 ft	5	REF			
52308	405.6 to 406.6 feet	Vertical Change	-.29	5 ft	5	REF			
45346	408.7 to 409.7 feet	Vertical Change	-.51	5 ft	5	REF			
43335	411.8 to 412.8 feet	Vertical Change	-.62	5 ft	5	REF			
42621	415.6 to 416.6 feet	Vertical Change	-.68	5 ft	5	REF			
12993	418.1 to 421.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	17	SF	\$40	\$660	
46058	419.0 to 424.6 feet	Vertical Change	-.48	5 ft	28	REF			
12995	421.4 to 453.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	159	SF	\$120	\$19,080	
47429	428.7 to 429.7 feet	Vertical Change	-.42	5 ft	5	REF			
46952	448.1 to 449.1 feet	Vertical Change	-.44	5 ft	5	REF			
12999	453.2 to 465.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	62	SF	\$120	\$7,440	
49538	457.8 to 458.8 feet	Vertical Change	-.35	5 ft	5	REF			
58671	459.7 to 488.7 feet	Driveway				REF			
53273	463.1 to 464.1 feet	Vertical Change	-.27	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908230959	PARKRIDGE DR	SANTA CRUZ BLVD	COTTONWOOD DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
55978	463.2 to 464.2 feet	Vertical Change	.37	5 ft	5	REF			
43807	465.2 to 468.2 feet	Vertical Change	-.59	5 ft	15	REF			
13003	465.6 to 488.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	112	SF	\$40	\$4,480	
44564	471.0 to 472.0 feet	Vertical Change	-.55	5 ft	5	REF			
43656	474.4 to 475.4 feet	Vertical Change	-.6	5 ft	5	REF			
44971	477.9 to 478.9 feet	Vertical Change	-.53	5 ft	5	REF			
43186	481.5 to 482.5 feet	Vertical Change	-.63	5 ft	5	REF			
44352	485.1 to 486.1 feet	Vertical Change	-.56	5 ft	5	REF			
13006	488.0 to 503.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	77	SF	\$40	\$3,060	
43054	488.9 to 494.3 feet	Vertical Change	-.64	5 ft	27	REF			
58672	500.3 to 527.7 feet	Driveway				REF			
13012	503.3 to 506.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	18	SF	\$40	\$700	
46059	503.4 to 506.7 feet	Vertical Change	-.48	5 ft	17	REF			
13014	507.8 to 508.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200	
13015	508.8 to 510.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	8	SF	\$40	\$300	
43187	509.6 to 510.6 feet	Vertical Change	-.63	5 ft	5	REF			
13016	510.3 to 529.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	97	SF	\$40	\$3,880	
43808	513.1 to 514.1 feet	Vertical Change	-.59	5 ft	5	REF			
50199	516.5 to 517.5 feet	Vertical Change	-.33	5 ft	5	REF			
43657	519.9 to 520.9 feet	Vertical Change	-.6	5 ft	5	REF			
43055	523.3 to 524.3 feet	Vertical Change	-.64	5 ft	5	REF			
56995	527.1 to 528.1 feet	Vertical Change	.59	5 ft	5	REF			
42944	527.4 to 530.7 feet	Vertical Change	-.65	5 ft	17	REF			
13021	529.7 to 531.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	11	SF	\$120	\$1,320	
41528	531.7 to 532.7 feet	Vertical Change	-1.06	5 ft	5	REF			
13022	531.9 to 561.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	147	SF	\$120	\$17,580	
43337	543.9 to 544.9 feet	Vertical Change	-.62	5 ft	5	REF			
13027	561.2 to 579.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	93	SF	\$120	\$11,220	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230959	PARKRIDGE DR	SANTA CRUZ BLVD	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58673	566.4 to 607.3 feet	Driveway				REF		
49222	572.1 to 575.7 feet	Vertical Change	-0.36	5 ft	18	REF		
43658	578.6 to 579.6 feet	Vertical Change	-0.6	5 ft	5	REF		
13032	579.9 to 585.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	30	SF	\$40	\$1,200
48082	582.4 to 583.4 feet	Vertical Change	-0.4	5 ft	5	REF		
43495	588.6 to 592.3 feet	Vertical Change	-0.61	5 ft	18	REF		
13033	595.4 to 602.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	37	SF	\$40	\$1,480
43810	595.5 to 596.5 feet	Vertical Change	-0.59	5 ft	5	REF		
44150	599.6 to 600.6 feet	Vertical Change	-0.57	5 ft	5	REF		
13035	602.8 to 603.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$200
43659	603.2 to 604.2 feet	Vertical Change	-0.6	5 ft	5	REF		
13036	604.6 to 607.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	15	SF	\$40	\$580
52786	609.7 to 610.7 feet	Vertical Change	-0.28	5 ft	5	REF		
13038	609.8 to 620.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,600
50200	620.3 to 621.3 feet	Vertical Change	-0.33	5 ft	5	REF		
13039	629.7 to 700.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	354	SF	\$120	\$42,540
49862	630.5 to 631.5 feet	Vertical Change	-0.34	5 ft	5	REF		
50983	640.2 to 641.2 feet	Vertical Change	-0.31	5 ft	5	REF		
43056	649.7 to 650.7 feet	Vertical Change	-0.64	5 ft	5	REF		
43811	659.0 to 660.0 feet	Vertical Change	-0.59	5 ft	5	REF		
50984	668.7 to 669.7 feet	Vertical Change	-0.31	5 ft	5	REF		
42429	677.9 to 678.9 feet	Vertical Change	-0.7	5 ft	5	REF		
48640	687.3 to 688.3 feet	Vertical Change	-0.38	5 ft	5	REF		
58674	690.8 to 726.6 feet	Driveway				REF		
43057	695.0 to 696.0 feet	Vertical Change	-0.64	5 ft	5	REF		
52787	698.1 to 699.1 feet	Vertical Change	-0.28	5 ft	5	REF		
13047	700.6 to 705.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	23	SF	\$40	\$900
44566	702.2 to 703.2 feet	Vertical Change	-0.55	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230959	PARKRIDGE DR	SANTA CRUZ BLVD	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13049	705.1 to 720.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	76	SF	\$40	\$3,020
47689	705.3 to 706.3 feet	Vertical Change	-.41	5 ft	5	REF		
47431	709.0 to 710.0 feet	Vertical Change	-.42	5 ft	5	REF		
45347	712.5 to 713.5 feet	Vertical Change	-.51	5 ft	5	REF		
48641	716.1 to 717.1 feet	Vertical Change	-.38	5 ft	5	REF		
45648	719.4 to 720.4 feet	Vertical Change	-.5	5 ft	5	REF		
13051	721.2 to 722.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200
13052	722.2 to 724.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	12	SF	\$40	\$480
13054	725.4 to 726.4 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200
42945	726.9 to 727.9 feet	Vertical Change	-.65	5 ft	5	REF		
13055	727.8 to 737.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,060
45348	738.7 to 739.7 feet	Vertical Change	-.51	5 ft	5	SF	\$75	\$375
13056	741.7 to 748.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,840
43812	749.5 to 750.5 feet	Vertical Change	-.59	5 ft	5	SF	\$75	\$375
13057	756.4 to 767.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,840
43496	758.8 to 764.1 feet	Vertical Change	-.61	5 ft	27	REF		
58675	761.0 to 789.0 feet	Driveway				REF		
42430	767.9 to 768.9 feet	Vertical Change	-.7	5 ft	5	REF		
13058	769.9 to 777.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	40	SF	\$40	\$1,600
42829	771.4 to 772.4 feet	Vertical Change	-.66	5 ft	5	REF		
42622	774.9 to 775.9 feet	Vertical Change	-.68	5 ft	5	REF		
43058	778.5 to 782.5 feet	Vertical Change	-.64	5 ft	20	REF		
13059	783.3 to 784.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$260
48642	785.0 to 786.0 feet	Vertical Change	-.38	5 ft	5	REF		
13060	786.1 to 789.4 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	17	SF	\$40	\$660
41352	789.6 to 790.6 feet	Vertical Change	-1.39	5 ft	5	REF		
13062	790.3 to 808.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	92	SF	\$120	\$11,040
46953	800.8 to 801.8 feet	Vertical Change	-.44	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230959	PARKRIDGE DR	SANTA CRUZ BLVD	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58676	803.3 to 842.7 feet	Driveway				REF		
41473	804.8 to 805.8 feet	Vertical Change	-1.13	5 ft	5	REF		
42830	806.8 to 811.9 feet	Vertical Change	-.66	5 ft	26	REF		
13065	810.9 to 813.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	12	SF	\$40	\$460
13067	814.1 to 828.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	73	SF	\$40	\$2,920
45649	817.8 to 818.8 feet	Vertical Change	-.5	5 ft	5	REF		
44353	821.4 to 822.4 feet	Vertical Change	-.56	5 ft	5	REF		
45350	824.6 to 825.6 feet	Vertical Change	-.51	5 ft	5	REF		
42831	827.8 to 828.8 feet	Vertical Change	-.66	5 ft	5	REF		
13069	828.7 to 832.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	21	SF	\$40	\$820
47432	831.1 to 832.1 feet	Vertical Change	-.42	5 ft	5	REF		
13070	832.8 to 837.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	25	SF	\$40	\$1,000
46506	834.4 to 835.4 feet	Vertical Change	-.46	5 ft	5	REF		
13072	837.8 to 843.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	28	SF	\$40	\$1,100
44567	838.0 to 839.0 feet	Vertical Change	-.55	5 ft	5	REF		
42832	841.9 to 845.3 feet	Vertical Change	-.66	5 ft	17	REF		
13075	843.3 to 853.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	52	SF	\$40	\$2,060
41427	846.8 to 847.8 feet	Vertical Change	-1.21	5 ft	5	REF		
13077	853.6 to 879.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	131	SF	\$120	\$15,660
43974	853.9 to 854.9 feet	Vertical Change	-.58	5 ft	5	REF		
48643	875.4 to 876.4 feet	Vertical Change	-.38	5 ft	5	REF		
13081	879.7 to 912.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	162	SF	\$120	\$19,440
50201	884.5 to 885.5 feet	Vertical Change	-.33	5 ft	5	REF		
50580	893.1 to 894.1 feet	Vertical Change	-.32	5 ft	5	REF		
50985	911.6 to 912.6 feet	Vertical Change	-.31	5 ft	5	REF		
13083	912.1 to 944.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	160	SF	\$120	\$19,140
49539	930.7 to 931.7 feet	Vertical Change	-.35	5 ft	5	REF		
49540	936.5 to 937.5 feet	Vertical Change	-.35	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908230959	PARKRIDGE DR	SANTA CRUZ BLVD	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
48929	941.5 to 942.5 feet	Vertical Change	-.37	5 ft	5	REF		
13085	944.0 to 948.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760
TOTAL COST FOR: N side of PARKRIDGE DR Starting at: SANTA CRUZ BLVD							\$305,330.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1908231000	COTTONWOOD DR	PARKRIDGE CT	JUNIPER CT	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
13086	4.1 to 26.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	110	SF	\$120	\$13,200	
46954	16.3 to 17.3 feet	Vertical Change	-.44	5 ft	5	REF			
58677	17.6 to 45.9 feet	Driveway				REF			
50581	21.2 to 25.9 feet	Vertical Change	-.32	5 ft	24	REF			
13088	26.1 to 32.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	31	SF	\$40	\$1,220	
45351	28.7 to 29.7 feet	Vertical Change	-.51	5 ft	5	REF			
44781	32.1 to 33.1 feet	Vertical Change	-.54	5 ft	5	REF			
13090	32.2 to 41.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	45	SF	\$40	\$1,800	
43059	35.6 to 36.6 feet	Vertical Change	-.64	5 ft	5	REF			
45845	39.1 to 40.1 feet	Vertical Change	-.49	5 ft	5	REF			
13092	41.2 to 51.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	53	SF	\$40	\$2,120	
44151	42.5 to 43.5 feet	Vertical Change	-.57	5 ft	5	REF			
45157	46.1 to 52.1 feet	Vertical Change	-.52	5 ft	30	REF			
13096	51.8 to 71.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	98	SF	\$120	\$11,700	
58678	61.1 to 89.7 feet	Driveway				REF			
42204	64.8 to 69.2 feet	Vertical Change	-.73	5 ft	22	REF			
44782	71.9 to 72.9 feet	Vertical Change	-.54	5 ft	5	REF			
44569	75.4 to 76.4 feet	Vertical Change	-.55	5 ft	5	REF			
43338	79.1 to 80.1 feet	Vertical Change	-.62	5 ft	5	REF			
45846	82.7 to 83.7 feet	Vertical Change	-.49	5 ft	5	REF			
13099	83.1 to 87.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	23	SF	\$40	\$920	
45158	86.3 to 87.3 feet	Vertical Change	-.52	5 ft	5	REF			
13101	87.7 to 138.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	255	SF	\$40	\$10,200	
44354	89.8 to 94.9 feet	Vertical Change	-.56	5 ft	26	REF			
45353	99.7 to 100.7 feet	Vertical Change	-.51	5 ft	5	REF			
43339	108.9 to 109.9 feet	Vertical Change	-.62	5 ft	5	REF			
44153	119.0 to 120.0 feet	Vertical Change	-.57	5 ft	5	REF			
43975	127.7 to 128.7 feet	Vertical Change	-.58	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908231000	COTTONWOOD DR	PARKRIDGE CT	JUNIPER CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58679	130.9 to 160.1 feet	Driveway				REF		
41220	133.7 to 134.7 feet	Vertical Change	-2.12	5 ft	5	REF		
50582	135.4 to 141.0 feet	Vertical Change	-.32	5 ft	28	REF		
13112	138.7 to 141.7 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	15	SF	\$40	\$600
13113	141.7 to 146.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	23	SF	\$40	\$920
46277	144.2 to 145.2 feet	Vertical Change	-.47	5 ft	5	REF		
13115	146.3 to 180.7 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	172	SF	\$40	\$6,880
44972	147.5 to 148.5 feet	Vertical Change	-.53	5 ft	5	REF		
45159	151.0 to 152.0 feet	Vertical Change	-.52	5 ft	5	REF		
46732	154.6 to 155.6 feet	Vertical Change	-.45	5 ft	5	REF		
46733	160.7 to 163.9 feet	Vertical Change	-.45	5 ft	16	REF		
58680	172.8 to 211.8 feet	Driveway				REF		
50202	177.5 to 180.6 feet	Vertical Change	-.33	5 ft	16	REF		
13120	180.7 to 181.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200
13121	181.7 to 184.7 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	15	SF	\$40	\$600
13122	184.7 to 203.4 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	94	SF	\$40	\$3,740
53274	186.4 to 187.4 feet	Vertical Change	-.27	5 ft	5	REF		
48361	192.7 to 193.7 feet	Vertical Change	-.39	5 ft	5	REF		
48930	196.4 to 197.4 feet	Vertical Change	-.37	5 ft	5	REF		
13127	203.4 to 207.7 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	22	SF	\$40	\$860
13129	207.7 to 209.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	8	SF	\$40	\$320
45160	211.6 to 214.3 feet	Vertical Change	-.52	5 ft	14	REF		
13130	212.3 to 219.5 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	36	SF	\$40	\$1,440
TOTAL COST FOR: E side of COTTONWOOD DR Starting at: PARKRIDGE CT							\$56,720.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E / S	1908231002	JUNIPER CT	COTTONWOOD DR	574 JUNIPER CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
13131	0.0 to 7.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320	
13133	7.2 to 18.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	56	SF	\$120	\$6,660	
53814	13.6 to 14.6 feet	Vertical Change	-.26	5 ft	5	REF			
13135	18.3 to 54.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	180	SF	\$120	\$21,540	
52788	32.7 to 33.7 feet	Vertical Change	-.28	5 ft	5	REF			
54118	69.4 to 70.4 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375	
13143	84.4 to 105.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	108	SF	\$120	\$12,900	
50583	88.1 to 89.1 feet	Vertical Change	-.32	5 ft	5	REF			
55945	96.3 to 97.3 feet	Vertical Change	.31	5 ft	5	REF			
44973	101.7 to 107.0 feet	Vertical Change	-.53	5 ft	27	REF			
55	103.5 to 104.5 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
58681	105.6 to 125.8 feet	Driveway				REF			
13147	108.7 to 117.7 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	45	SF	\$40	\$1,800	
44355	115.4 to 116.4 feet	Vertical Change	-.56	5 ft	5	REF			
13149	117.7 to 121.1 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	17	SF	\$40	\$680	
13150	121.1 to 122.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	8	SF	\$40	\$300	
13151	122.6 to 123.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$240	
43660	125.5 to 130.8 feet	Vertical Change	-.6	5 ft	27	REF			
13152	125.5 to 126.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200	
13153	129.1 to 151.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	113	SF	\$120	\$13,500	
41227	131.9 to 132.9 feet	Vertical Change	-2.07	5 ft	5	REF			
43340	134.7 to 135.7 feet	Vertical Change	-.62	5 ft	5	REF			
43189	145.4 to 146.4 feet	Vertical Change	-.63	5 ft	5	REF			
48362	157.3 to 158.3 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375	
13155	162.7 to 167.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,880	
47690	169.4 to 170.4 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375	
58682	173.5 to 204.3 feet	Driveway				REF			
41287	178.1 to 179.1 feet	Vertical Change	-1.63	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E / S	1908231002	JUNIPER CT	COTTONWOOD DR	574 JUNIPER CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13156	179.3 to 182.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	15	SF	\$40	\$580
44974	179.4 to 181.7 feet	Vertical Change	-.53	5 ft	12	REF		
13158	183.1 to 184.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$220
13159	184.2 to 186.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	13	SF	\$40	\$520
13160	186.8 to 198.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	59	SF	\$40	\$2,340
46507	189.0 to 190.0 feet	Vertical Change	-.46	5 ft	5	REF		
43661	193.1 to 194.1 feet	Vertical Change	-.6	5 ft	5	REF		
13163	198.5 to 204.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	29	SF	\$40	\$1,140
13166	206.6 to 209.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440
58683	207.1 to 234.9 feet	Driveway				REF		
13167	211.5 to 214.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	14	SF	\$40	\$540
13169	214.2 to 236.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	112	SF	\$40	\$4,480
47181	216.8 to 217.8 feet	Vertical Change	-.43	5 ft	5	REF		
50203	220.5 to 221.5 feet	Vertical Change	-.33	5 ft	5	REF		
47691	227.2 to 228.2 feet	Vertical Change	-.41	5 ft	5	REF		
45650	230.3 to 231.3 feet	Vertical Change	-.5	5 ft	5	REF		
50986	236.3 to 237.3 feet	Vertical Change	-.31	5 ft	5	REF		
13177	236.6 to 254.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	87	SF	\$120	\$10,440
TOTAL COST FOR: E / S side of JUNIPER CT Starting at: COTTONWOOD DR								\$88,445.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908231004	JUNIPER CT	576 JUNIPER CT	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58684	0.0 to 25.2 feet	Driveway				REF		
46508	0.5 to 1.5 feet	Vertical Change	-46	5 ft	5	REF		
13178	0.9 to 2.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	10	SF	\$40	\$400
13180	3.8 to 17.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	68	SF	\$40	\$2,700
13182	17.3 to 21.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	20	SF	\$40	\$800
13184	21.3 to 23.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	13	SF	\$40	\$500
45651	25.1 to 29.9 feet	Vertical Change	-5	5 ft	24	REF		
13186	26.0 to 27.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$600
13187	27.0 to 36.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,820
45848	38.9 to 39.9 feet	Vertical Change	-49	5 ft	5	LF	\$75	\$375
47433	51.4 to 52.4 feet	Vertical Change	-42	5 ft	5	LF	\$75	\$375
13188	54.3 to 60.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,900
52789	60.8 to 61.8 feet	Vertical Change	-28	5 ft	5	REF		
43341	69.7 to 70.7 feet	Vertical Change	-62	5 ft	5	SF	\$75	\$375
43663	79.9 to 80.9 feet	Vertical Change	-6	5 ft	5	SF	\$75	\$375
13189	84.8 to 88.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220
58685	85.0 to 111.3 feet	Driveway				REF		
41332	85.3 to 86.3 feet	Vertical Change	-1.45	5 ft	5	REF		
44356	87.2 to 90.2 feet	Vertical Change	-56	5 ft	15	REF		
13190	92.3 to 108.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	81	SF	\$40	\$3,220
43664	99.8 to 100.8 feet	Vertical Change	-6	5 ft	5	REF		
43062	110.3 to 116.0 feet	Vertical Change	-64	5 ft	29	REF		
13192	111.8 to 113.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,020
13193	113.5 to 145.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	160	SF	\$120	\$19,140
43665	122.7 to 123.7 feet	Vertical Change	-6	5 ft	5	REF		
58686	125.1 to 154.3 feet	Driveway				REF		
41360	129.2 to 130.2 feet	Vertical Change	-1.38	5 ft	5	REF		
44154	131.1 to 132.1 feet	Vertical Change	-57	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908231004	JUNIPER CT	576 JUNIPER CT	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44570	137.0 to 138.0 feet	Vertical Change	-.55	5 ft	5	REF		
45355	140.3 to 141.3 feet	Vertical Change	-.51	5 ft	5	REF		
41846	143.7 to 144.7 feet	Vertical Change	-.82	5 ft	5	REF		
44155	146.9 to 147.9 feet	Vertical Change	-.57	5 ft	5	REF		
13198	148.6 to 173.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	126	SF	\$40	\$5,040
45161	150.2 to 151.2 feet	Vertical Change	-.52	5 ft	5	REF		
44571	154.4 to 158.1 feet	Vertical Change	-.55	5 ft	19	REF		
41245	159.5 to 160.5 feet	Vertical Change	-1.9	5 ft	5	REF		
43977	166.5 to 167.5 feet	Vertical Change	-.58	5 ft	5	REF		
41211	174.9 to 175.9 feet	Vertical Change	-2.26	5 ft	5	SF	\$75	\$375
13201	177.2 to 179.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560
TOTAL COST FOR: N side of JUNIPER CT Starting at: 576 JUNIPER CT							\$48,795.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908231005	COTTONWOOD DR	JUNIPER CT	SPRUCE CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
13202	5.0 to 8.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040	
54119	7.9 to 8.9 feet	Vertical Change	-.25	5 ft	5	REF			
13204	8.4 to 16.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	38	SF	\$120	\$4,560	
42721	15.4 to 16.4 feet	Vertical Change	-.67	5 ft	5	REF			
13206	16.0 to 43.7 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	139	SF	\$120	\$16,620	
43190	24.6 to 25.6 feet	Vertical Change	-.63	5 ft	5	REF			
42624	33.5 to 34.5 feet	Vertical Change	-.68	5 ft	5	REF			
13209	43.7 to 54.7 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	55	SF	\$120	\$6,600	
41920	52.2 to 53.2 feet	Vertical Change	-.8	5 ft	5	REF			
13211	54.7 to 62.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	38	SF	\$120	\$4,500	
46279	61.4 to 62.4 feet	Vertical Change	-.47	5 ft	5	REF			
13213	62.2 to 63.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	7	SF	\$120	\$840	
13214	63.6 to 69.9 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	32	SF	\$120	\$3,780	
13215	69.9 to 80.0 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	50	SF	\$120	\$6,060	
49541	70.4 to 71.4 feet	Vertical Change	-.35	5 ft	5	REF			
13217	80.0 to 98.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	95	SF	\$120	\$11,340	
43815	88.9 to 89.9 feet	Vertical Change	-.59	5 ft	5	REF			
48363	98.1 to 99.1 feet	Vertical Change	-.39	5 ft	5	REF			
13218	98.9 to 105.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,780	
49542	107.4 to 108.4 feet	Vertical Change	-.35	5 ft	5	REF			
13220	107.7 to 146.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	194	SF	\$120	\$23,280	
46734	116.9 to 117.9 feet	Vertical Change	-.45	5 ft	5	REF			
52310	144.7 to 145.7 feet	Vertical Change	-.29	5 ft	5	REF			
13224	146.5 to 165.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	94	SF	\$120	\$11,280	
13226	165.3 to 183.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	89	SF	\$120	\$10,620	
46957	183.4 to 184.4 feet	Vertical Change	-.44	5 ft	5	LF	\$75	\$375	
13228	184.7 to 189.1 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	22	SF	\$120	\$2,640	
13230	189.1 to 191.8 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	14	SF	\$120	\$1,620	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908231005	COTTONWOOD DR	JUNIPER CT	SPRUCE CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13232	191.8 to 202.4 feet	Cross Slope (PAR)	10.0-11.0%	5 ft	53	SF	\$120	\$6,360
44783	195.0 to 196.0 feet	Vertical Change	-.54	5 ft	5	REF		
40380	196.0 to 197.2 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
41353	198.3 to 199.3 feet	Vertical Change	-1.39	5 ft	5	REF		
56620	199.1 to 200.1 feet	Vertical Change	.42	5 ft	5	REF		
51895	199.2 to 200.2 feet	Vertical Change	-.3	5 ft	5	REF		
13235	202.4 to 206.2 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	19	SF	\$120	\$2,280
57345	203.3 to 204.3 feet	Vertical Change	.99	5 ft	5	REF		
41873	206.7 to 207.7 feet	Vertical Change	-.81	5 ft	5	SF	\$75	\$375
TOTAL COST FOR: E side of COTTONWOOD DR Starting at: JUNIPER CT							\$118,950.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908231007	SPRUCE CT	COTTONWOOD DR	COTTONWOOD DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
13237	0.0 to 33.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	169	SF	\$120	\$20,280	
41204	7.0 to 8.0 feet	Vertical Change	-2.38	5 ft	5	REF			
44572	15.3 to 16.3 feet	Vertical Change	-.55	5 ft	5	REF			
58687	19.3 to 44.8 feet	Driveway				REF			
41176	19.5 to 20.5 feet	Vertical Change	-3.18	5 ft	5	REF			
43063	25.2 to 26.2 feet	Vertical Change	-.64	5 ft	5	REF			
44975	28.4 to 29.4 feet	Vertical Change	-.53	5 ft	5	REF			
45849	31.7 to 32.7 feet	Vertical Change	-.49	5 ft	5	REF			
46735	34.9 to 35.9 feet	Vertical Change	-.45	5 ft	5	REF			
45850	38.6 to 39.6 feet	Vertical Change	-.49	5 ft	5	REF			
13241	39.3 to 59.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	102	SF	\$40	\$4,060	
47182	42.1 to 43.1 feet	Vertical Change	-.43	5 ft	5	REF			
48931	46.0 to 47.0 feet	Vertical Change	-.37	5 ft	5	REF			
46958	53.1 to 54.1 feet	Vertical Change	-.44	5 ft	5	REF			
58688	53.5 to 84.3 feet	Driveway				REF			
46060	62.4 to 63.4 feet	Vertical Change	-.48	5 ft	5	REF			
13244	63.5 to 66.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	17	SF	\$40	\$660	
46280	66.1 to 67.1 feet	Vertical Change	-.47	5 ft	5	REF			
49863	69.7 to 70.7 feet	Vertical Change	-.34	5 ft	5	REF			
13245	75.8 to 82.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	35	SF	\$40	\$1,380	
47183	76.6 to 77.6 feet	Vertical Change	-.43	5 ft	5	REF			
48083	79.7 to 80.7 feet	Vertical Change	-.4	5 ft	5	REF			
49864	83.4 to 84.4 feet	Vertical Change	-.34	5 ft	5	REF			
13246	85.3 to 93.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,680	
50584	88.0 to 89.0 feet	Vertical Change	-.32	5 ft	5	REF			
47434	99.5 to 100.5 feet	Vertical Change	-.42	5 ft	5	REF			
13250	99.5 to 133.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	169	SF	\$120	\$20,280	
48645	126.3 to 127.3 feet	Vertical Change	-.38	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908231007	SPRUCE CT	COTTONWOOD DR	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58689	127.7 to 155.4 feet	Driveway				REF		
13253	135.6 to 138.9 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	17	SF	\$40	\$660
13255	138.9 to 145.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	32	SF	\$40	\$1,280
52311	142.0 to 143.0 feet	Vertical Change	-.29	5 ft	5	REF		
13257	145.3 to 151.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	28	SF	\$40	\$1,140
47435	146.3 to 147.3 feet	Vertical Change	-.42	5 ft	5	REF		
13259	151.0 to 156.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	28	SF	\$40	\$1,140
13261	156.7 to 164.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	37	SF	\$120	\$4,380
13262	164.0 to 178.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	72	SF	\$120	\$8,580
58690	164.1 to 208.2 feet	Driveway				REF		
56648	171.7 to 172.7 feet	Vertical Change	.49	5 ft	5	REF		
43978	176.2 to 177.2 feet	Vertical Change	-.58	5 ft	5	REF		
45851	181.8 to 182.8 feet	Vertical Change	-.49	5 ft	5	REF		
13266	185.5 to 188.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	16	SF	\$40	\$640
42833	186.4 to 187.4 feet	Vertical Change	-.66	5 ft	5	REF		
44156	190.1 to 191.1 feet	Vertical Change	-.57	5 ft	5	REF		
43191	194.0 to 195.0 feet	Vertical Change	-.63	5 ft	5	REF		
13267	194.9 to 200.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	30	SF	\$40	\$1,200
44357	197.8 to 198.8 feet	Vertical Change	-.56	5 ft	5	REF		
13269	200.9 to 203.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	14	SF	\$40	\$560
43192	201.5 to 202.5 feet	Vertical Change	-.63	5 ft	5	REF		
13271	204.6 to 208.2 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	18	SF	\$40	\$720
41251	209.8 to 210.8 feet	Vertical Change	-1.86	5 ft	5	SF	\$75	\$375
13273	211.0 to 227.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	82	SF	\$120	\$9,780
45356	217.9 to 218.9 feet	Vertical Change	-.51	5 ft	5	REF		
58691	220.3 to 250.9 feet	Driveway				REF		
41321	224.0 to 225.0 feet	Vertical Change	-1.49	5 ft	5	REF		
44358	226.9 to 227.9 feet	Vertical Change	-.56	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908231007	SPRUCE CT	COTTONWOOD DR	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13275	228.0 to 231.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	17	SF	\$40	\$660
13276	232.3 to 233.6 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	7	SF	\$40	\$260
44784	233.1 to 234.1 feet	Vertical Change	-.54	5 ft	5	REF		
13277	233.6 to 245.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	57	SF	\$40	\$2,280
46061	236.5 to 237.5 feet	Vertical Change	-.48	5 ft	5	REF		
45162	240.0 to 241.0 feet	Vertical Change	-.52	5 ft	5	REF		
47184	244.2 to 245.2 feet	Vertical Change	-.43	5 ft	5	REF		
13280	245.0 to 248.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	17	SF	\$40	\$680
13282	248.4 to 249.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	6	SF	\$40	\$220
13283	249.5 to 250.9 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	7	SF	\$40	\$280
44157	251.4 to 252.4 feet	Vertical Change	-.57	5 ft	5	REF		
13284	252.7 to 260.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800
58692	254.3 to 294.3 feet	Driveway				REF		
42066	260.6 to 261.6 feet	Vertical Change	-.76	5 ft	5	REF		
13286	262.9 to 267.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	23	SF	\$40	\$920
13287	267.5 to 275.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	39	SF	\$40	\$1,560
44785	269.7 to 270.7 feet	Vertical Change	-.54	5 ft	5	REF		
45652	272.8 to 273.8 feet	Vertical Change	-.5	5 ft	5	REF		
13289	275.3 to 288.7 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	67	SF	\$40	\$2,680
45653	276.1 to 277.1 feet	Vertical Change	-.5	5 ft	5	REF		
46281	279.5 to 280.5 feet	Vertical Change	-.47	5 ft	5	REF		
48646	282.9 to 283.9 feet	Vertical Change	-.38	5 ft	5	REF		
13291	288.7 to 291.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	13	SF	\$40	\$500
13292	291.2 to 294.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	17	SF	\$40	\$680
46736	296.5 to 297.5 feet	Vertical Change	-.45	5 ft	5	REF		
13293	296.9 to 298.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720
58693	299.8 to 329.8 feet	Driveway				REF		
48084	306.8 to 307.8 feet	Vertical Change	-.4	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908231007	SPRUCE CT	COTTONWOOD DR	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13294	306.8 to 307.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$220
13295	309.7 to 323.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	69	SF	\$40	\$2,760
48364	319.2 to 320.2 feet	Vertical Change	-.39	5 ft	5	REF		
13298	323.5 to 328.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	26	SF	\$40	\$1,020
13300	331.2 to 332.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
43500	331.9 to 332.9 feet	Vertical Change	-.61	5 ft	5	REF		
13301	342.0 to 389.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	237	SF	\$120	\$28,380
44786	347.0 to 348.0 feet	Vertical Change	-.54	5 ft	5	REF		
41419	355.2 to 356.2 feet	Vertical Change	-1.23	5 ft	5	REF		
58694	372.4 to 413.8 feet	Driveway				REF		
45654	372.7 to 373.7 feet	Vertical Change	-.5	5 ft	5	REF		
44573	376.9 to 377.9 feet	Vertical Change	-.55	5 ft	5	REF		
53815	380.9 to 381.9 feet	Vertical Change	-.26	5 ft	5	REF		
50204	385.2 to 386.2 feet	Vertical Change	-.33	5 ft	5	REF		
49223	389.8 to 390.8 feet	Vertical Change	-.36	5 ft	5	REF		
13308	396.9 to 409.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	65	SF	\$40	\$2,580
46737	397.9 to 398.9 feet	Vertical Change	-.45	5 ft	5	REF		
46959	405.4 to 406.4 feet	Vertical Change	-.44	5 ft	5	REF		
54120	408.9 to 412.7 feet	Vertical Change	-.25	5 ft	19	REF		
13310	409.8 to 415.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	30	SF	\$40	\$1,180
44976	413.0 to 418.6 feet	Vertical Change	-.53	5 ft	28	REF		
13312	415.7 to 442.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	135	SF	\$120	\$16,200
44359	425.6 to 426.6 feet	Vertical Change	-.56	5 ft	5	REF		
58695	425.8 to 457.1 feet	Driveway				REF		
42021	433.2 to 437.4 feet	Vertical Change	-.77	5 ft	21	REF		
43979	440.1 to 441.1 feet	Vertical Change	-.58	5 ft	5	REF		
44158	443.8 to 444.8 feet	Vertical Change	-.57	5 ft	5	REF		
43501	447.3 to 448.3 feet	Vertical Change	-.61	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
E	1908231007	SPRUCE CT	COTTONWOOD DR	COTTONWOOD DR	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
44159	450.4 to 451.4 feet	Vertical Change	-.57	5 ft	5	REF					
43980	453.8 to 454.8 feet	Vertical Change	-.58	5 ft	5	REF					
13317	454.4 to 480.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	132	SF	\$40	\$5,260			
44788	457.3 to 462.9 feet	Vertical Change	-.54	5 ft	28	REF					
44576	466.3 to 467.3 feet	Vertical Change	-.55	5 ft	5	REF					
41217	476.1 to 477.1 feet	Vertical Change	-2.17	5 ft	5	REF					
TOTAL COST FOR: E							<i>side of</i>	SPRUCE CT	<i>Starting at:</i>	COTTONWOOD DR	\$156,235.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1908231008	COTTONWOOD DR	SPRUCE CT	PEACH DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
13319	5.1 to 6.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720	
41366	6.9 to 7.9 feet	Vertical Change	-1.37	5 ft	5	SF	\$75	\$375	
13320	8.0 to 9.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	7	SF	\$120	\$840	
13321	9.4 to 16.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	37	SF	\$120	\$4,440	
50987	10.8 to 11.8 feet	Vertical Change	-.31	5 ft	5	REF			
40381	14.9 to 17.9 feet	Running Slope	5.0-6.0%	5 ft	15	REF			
53275	15.9 to 16.9 feet	Vertical Change	-.27	5 ft	5	REF			
57403	15.9 to 16.9 feet	Vertical Change	1.15	5 ft	5	REF			
13325	19.0 to 23.9 feet	Cross Slope (PAR)	9.0-10.0%	5 ft	25	SF	\$120	\$2,940	
41503	20.0 to 21.0 feet	Vertical Change	-1.09	5 ft	5	REF			
13327	23.9 to 37.3 feet	Cross Slope (PAR)	7.0-8.0%	5 ft	67	SF	\$120	\$8,040	
43343	27.6 to 28.6 feet	Vertical Change	-.62	5 ft	5	REF			
45163	36.5 to 37.5 feet	Vertical Change	-.52	5 ft	5	REF			
13329	37.3 to 51.5 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	71	SF	\$120	\$8,520	
49865	45.6 to 46.6 feet	Vertical Change	-.34	5 ft	5	REF			
13331	51.5 to 92.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	203	SF	\$120	\$24,360	
46510	54.9 to 55.9 feet	Vertical Change	-.46	5 ft	5	REF			
48647	65.6 to 66.6 feet	Vertical Change	-.38	5 ft	5	REF			
46960	75.7 to 76.7 feet	Vertical Change	-.44	5 ft	5	REF			
47185	85.3 to 86.3 feet	Vertical Change	-.43	5 ft	5	REF			
13335	92.1 to 106.0 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	70	SF	\$120	\$8,340	
48365	94.5 to 95.5 feet	Vertical Change	-.39	5 ft	5	REF			
46282	104.0 to 105.0 feet	Vertical Change	-.47	5 ft	5	REF			
13337	106.0 to 134.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	144	SF	\$120	\$17,280	
47692	114.1 to 115.1 feet	Vertical Change	-.41	5 ft	5	REF			
13342	134.8 to 144.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,700	
43344	143.7 to 144.7 feet	Vertical Change	-.62	5 ft	5	REF			
13344	144.3 to 210.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	331	SF	\$120	\$39,720	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908231008	COTTONWOOD DR	SPRUCE CT	PEACH DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
48932	152.3 to 153.3 feet	Vertical Change	-.37	5 ft	5	REF		
48366	161.8 to 162.8 feet	Vertical Change	-.39	5 ft	5	REF		
46961	172.6 to 173.6 feet	Vertical Change	-.44	5 ft	5	REF		
56936	172.7 to 173.7 feet	Vertical Change	.53	5 ft	5	REF		
49543	182.6 to 183.6 feet	Vertical Change	-.35	5 ft	5	REF		
49544	192.2 to 193.2 feet	Vertical Change	-.35	5 ft	5	REF		
53816	202.1 to 203.1 feet	Vertical Change	-.26	5 ft	5	REF		
13354	210.5 to 217.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,900
TOTAL COST FOR: E side of COTTONWOOD DR Starting at: SPRUCE CT							\$125,175.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908231011	PEACH DR	COTTONWOOD DR	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
13355	2.1 to 11.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,460	
58696	8.1 to 44.4 feet	Driveway				REF			
46738	10.3 to 12.5 feet	Vertical Change	-45	5 ft	11	REF			
13357	11.2 to 13.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	12	SF	\$40	\$460	
13359	13.5 to 15.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	9	SF	\$40	\$360	
13360	15.3 to 18.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	15	SF	\$40	\$580	
48933	15.6 to 16.6 feet	Vertical Change	-.37	5 ft	5	REF			
13362	18.2 to 25.6 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	37	SF	\$40	\$1,480	
43666	20.1 to 21.1 feet	Vertical Change	-.6	5 ft	5	REF			
46739	24.3 to 25.3 feet	Vertical Change	-.45	5 ft	5	REF			
13363	25.6 to 52.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	134	SF	\$40	\$5,340	
44362	27.4 to 28.4 feet	Vertical Change	-.56	5 ft	5	REF			
44977	30.7 to 31.7 feet	Vertical Change	-.53	5 ft	5	REF			
45852	36.7 to 37.7 feet	Vertical Change	-.49	5 ft	5	REF			
48934	40.0 to 41.0 feet	Vertical Change	-.37	5 ft	5	REF			
48648	44.2 to 49.0 feet	Vertical Change	-.38	5 ft	24	REF			
13369	52.3 to 62.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	50	SF	\$120	\$5,940	
46511	57.6 to 58.6 feet	Vertical Change	-.46	5 ft	5	REF			
58697	57.8 to 87.8 feet	Driveway				REF			
13371	62.2 to 66.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	22	SF	\$40	\$880	
48649	64.9 to 65.9 feet	Vertical Change	-.38	5 ft	5	REF			
13373	66.6 to 91.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	124	SF	\$40	\$4,960	
47186	70.2 to 71.2 feet	Vertical Change	-.43	5 ft	5	REF			
44577	73.8 to 74.8 feet	Vertical Change	-.55	5 ft	5	REF			
42625	77.6 to 78.6 feet	Vertical Change	-.68	5 ft	5	REF			
44789	81.3 to 82.3 feet	Vertical Change	-.54	5 ft	5	REF			
45357	84.6 to 85.6 feet	Vertical Change	-.51	5 ft	5	REF			
48650	88.1 to 89.1 feet	Vertical Change	-.38	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908231011	PEACH DR	COTTONWOOD DR	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13379	91.4 to 116.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	125	SF	\$120	\$15,000
51896	96.5 to 97.5 feet	Vertical Change	-3	5 ft	5	REF		
48651	134.0 to 135.0 feet	Vertical Change	-38	5 ft	5	LF	\$75	\$375
48085	138.9 to 145.5 feet	Vertical Change	-4	5 ft	33	LF	\$75	\$2,475
13382	141.3 to 146.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000
58698	146.0 to 165.3 feet	Driveway				REF		
13384	146.3 to 154.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	41	SF	\$40	\$1,660
47693	148.1 to 149.1 feet	Vertical Change	-41	5 ft	5	REF		
51897	151.5 to 152.5 feet	Vertical Change	-3	5 ft	5	REF		
13386	154.6 to 161.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	35	SF	\$40	\$1,400
49545	155.1 to 156.1 feet	Vertical Change	-35	5 ft	5	REF		
44579	158.5 to 159.5 feet	Vertical Change	-55	5 ft	5	REF		
13388	161.6 to 167.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	32	SF	\$40	\$1,260
48652	162.1 to 163.1 feet	Vertical Change	-38	5 ft	5	REF		
44790	166.0 to 170.6 feet	Vertical Change	-54	5 ft	23	REF		
13392	167.9 to 179.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,140
45164	180.1 to 181.1 feet	Vertical Change	-52	5 ft	5	SF	\$75	\$375
58699	180.5 to 212.3 feet	Driveway				REF		
45165	184.1 to 191.8 feet	Vertical Change	-52	5 ft	39	REF		
13393	185.7 to 192.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	34	SF	\$40	\$1,360
13395	192.5 to 217.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	124	SF	\$40	\$4,940
43667	193.9 to 194.9 feet	Vertical Change	-6	5 ft	5	REF		
45855	197.1 to 198.1 feet	Vertical Change	-49	5 ft	5	REF		
42947	200.7 to 201.7 feet	Vertical Change	-65	5 ft	5	REF		
45655	204.2 to 205.2 feet	Vertical Change	-5	5 ft	5	REF		
46283	208.0 to 209.0 feet	Vertical Change	-47	5 ft	5	REF		
44364	212.3 to 215.0 feet	Vertical Change	-56	5 ft	14	REF		
53276	215.6 to 216.6 feet	Vertical Change	-27	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908231011	PEACH DR	COTTONWOOD DR	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13403	217.2 to 240.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	116	SF	\$120	\$13,860
45166	225.6 to 226.6 feet	Vertical Change	-52	5 ft	5	REF		
48935	234.2 to 235.2 feet	Vertical Change	-37	5 ft	5	REF		
43193	243.3 to 244.3 feet	Vertical Change	-63	5 ft	5	REF		
13405	243.7 to 273.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	148	SF	\$120	\$17,760
44365	253.1 to 254.1 feet	Vertical Change	-56	5 ft	5	REF		
58700	254.8 to 296.1 feet	Driveway				REF		
42165	259.3 to 265.1 feet	Vertical Change	-74	5 ft	29	REF		
56948	264.2 to 265.2 feet	Vertical Change	.54	5 ft	5	REF		
43669	267.1 to 268.1 feet	Vertical Change	-.6	5 ft	5	REF		
42948	271.2 to 272.2 feet	Vertical Change	-.65	5 ft	5	REF		
43195	275.4 to 276.4 feet	Vertical Change	-.63	5 ft	5	REF		
13408	276.7 to 289.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	66	SF	\$40	\$2,620
42723	279.2 to 280.2 feet	Vertical Change	-.67	5 ft	5	REF		
43196	282.9 to 283.9 feet	Vertical Change	-.63	5 ft	5	REF		
42327	286.2 to 287.2 feet	Vertical Change	-.71	5 ft	5	REF		
13410	289.8 to 292.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	14	SF	\$40	\$540
46741	290.4 to 291.4 feet	Vertical Change	-.45	5 ft	5	REF		
13412	292.5 to 294.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	11	SF	\$40	\$420
13413	294.6 to 296.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	11	SF	\$40	\$440
41921	295.5 to 296.5 feet	Vertical Change	-.8	5 ft	5	REF		
13415	296.8 to 298.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$960
13416	298.4 to 316.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	89	SF	\$120	\$10,620
41638	307.2 to 308.2 feet	Vertical Change	-.94	5 ft	5	REF		
46284	315.4 to 316.4 feet	Vertical Change	-.47	5 ft	5	REF		
43502	323.9 to 324.9 feet	Vertical Change	-.61	5 ft	5	SF	\$75	\$375
58701	324.2 to 355.5 feet	Driveway				REF		
50989	328.5 to 329.5 feet	Vertical Change	-.31	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908231011	PEACH DR	COTTONWOOD DR	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13417	331.1 to 332.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$220
42205	332.6 to 333.6 feet	Vertical Change	-.73	5 ft	5	REF		
13418	333.2 to 354.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	105	SF	\$40	\$4,200
42949	336.1 to 337.1 feet	Vertical Change	-.65	5 ft	5	REF		
43197	339.5 to 340.5 feet	Vertical Change	-.63	5 ft	5	REF		
41994	342.9 to 343.9 feet	Vertical Change	-.78	5 ft	5	REF		
42328	346.4 to 347.4 feet	Vertical Change	-.71	5 ft	5	REF		
45358	349.8 to 350.8 feet	Vertical Change	-.51	5 ft	5	REF		
43064	353.2 to 354.2 feet	Vertical Change	-.64	5 ft	5	REF		
13425	355.0 to 356.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$220
47188	357.5 to 358.5 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375
58702	361.8 to 391.4 feet	Driveway				REF		
13426	364.3 to 366.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	9	SF	\$40	\$340
53277	366.2 to 367.2 feet	Vertical Change	-.27	5 ft	5	REF		
13427	369.8 to 372.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	14	SF	\$40	\$560
48086	370.2 to 371.2 feet	Vertical Change	-.4	5 ft	5	REF		
13429	372.6 to 379.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	35	SF	\$40	\$1,380
50205	373.7 to 374.7 feet	Vertical Change	-.33	5 ft	5	REF		
50585	377.1 to 378.1 feet	Vertical Change	-.32	5 ft	5	REF		
13431	379.5 to 390.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	53	SF	\$40	\$2,100
44978	380.5 to 381.5 feet	Vertical Change	-.53	5 ft	5	REF		
13433	390.0 to 393.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	17	SF	\$40	\$660
53817	391.1 to 392.1 feet	Vertical Change	-.26	5 ft	5	REF		
13435	393.3 to 429.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	181	SF	\$120	\$21,660
50206	395.3 to 396.3 feet	Vertical Change	-.33	5 ft	5	REF		
48087	400.4 to 401.4 feet	Vertical Change	-.4	5 ft	5	REF		
46512	409.9 to 410.9 feet	Vertical Change	-.46	5 ft	5	REF		
48088	419.3 to 420.3 feet	Vertical Change	-.4	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908231011	PEACH DR	COTTONWOOD DR	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58703	421.7 to 463.0 feet	Driveway				REF		
48367	424.6 to 425.6 feet	Vertical Change	-.39	5 ft	5	REF		
43817	428.5 to 429.5 feet	Vertical Change	-.59	5 ft	5	REF		
13441	429.4 to 442.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	66	SF	\$40	\$2,640
43818	433.2 to 434.2 feet	Vertical Change	-.59	5 ft	5	REF		
43198	436.8 to 437.8 feet	Vertical Change	-.63	5 ft	5	REF		
43503	441.2 to 442.2 feet	Vertical Change	-.61	5 ft	5	REF		
13445	442.6 to 458.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	77	SF	\$40	\$3,080
44160	444.6 to 445.6 feet	Vertical Change	-.57	5 ft	5	REF		
42432	448.3 to 449.3 feet	Vertical Change	-.7	5 ft	5	REF		
42022	452.4 to 453.4 feet	Vertical Change	-.77	5 ft	5	REF		
42950	456.6 to 457.6 feet	Vertical Change	-.65	5 ft	5	REF		
13447	458.0 to 463.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	26	SF	\$40	\$1,040
43819	460.2 to 461.2 feet	Vertical Change	-.59	5 ft	5	REF		
57123	460.3 to 461.3 feet	Vertical Change	.6	5 ft	5	REF		
42517	461.1 to 462.1 feet	Vertical Change	-.69	5 ft	5	REF		
13449	463.2 to 477.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	69	SF	\$40	\$2,760
41847	465.3 to 466.3 feet	Vertical Change	-.82	5 ft	5	REF		
58704	470.2 to 498.3 feet	Driveway				REF		
41957	473.4 to 474.4 feet	Vertical Change	-.79	5 ft	5	REF		
42256	477.2 to 478.2 feet	Vertical Change	-.72	5 ft	5	REF		
13451	477.9 to 479.0 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$220
56928	479.2 to 480.2 feet	Vertical Change	.52	5 ft	5	REF		
13452	479.8 to 483.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	18	SF	\$40	\$700
46062	482.6 to 483.6 feet	Vertical Change	-.48	5 ft	5	REF		
13454	483.3 to 493.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	53	SF	\$40	\$2,100
45167	487.4 to 488.4 feet	Vertical Change	-.52	5 ft	5	REF		
45168	492.7 to 493.7 feet	Vertical Change	-.52	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908231011	PEACH DR	COTTONWOOD DR	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13457	493.8 to 496.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	13	SF	\$40	\$500
52312	497.6 to 502.9 feet	Vertical Change	-29	5 ft	27	REF		
13458	498.9 to 499.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
13459	503.4 to 504.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660
49866	518.7 to 519.7 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375
58705	538.9 to 568.5 feet	Driveway				REF		
41450	543.0 to 544.0 feet	Vertical Change	-1.16	5 ft	5	REF		
43504	545.1 to 546.1 feet	Vertical Change	-.61	5 ft	5	REF		
53278	547.0 to 548.0 feet	Vertical Change	-.27	5 ft	5	REF		
13460	550.0 to 564.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	75	SF	\$40	\$2,980
49546	556.9 to 557.9 feet	Vertical Change	-.35	5 ft	5	REF		
46964	566.9 to 569.9 feet	Vertical Change	-.44	5 ft	15	REF		
13462	568.4 to 582.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	69	SF	\$40	\$2,780
41958	570.9 to 571.9 feet	Vertical Change	-.79	5 ft	5	REF		
48089	572.8 to 577.8 feet	Vertical Change	-.4	5 ft	25	REF		
58706	576.3 to 601.9 feet	Driveway				REF		
41959	578.8 to 579.8 feet	Vertical Change	-.79	5 ft	5	REF		
46513	580.7 to 583.7 feet	Vertical Change	-.46	5 ft	15	REF		
13464	585.8 to 600.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	75	SF	\$40	\$3,000
41922	592.9 to 593.9 feet	Vertical Change	-.8	5 ft	5	REF		
45656	602.9 to 605.8 feet	Vertical Change	-.5	5 ft	14	SF	\$75	\$1,088
41410	606.9 to 607.9 feet	Vertical Change	-1.25	5 ft	5	SF	\$75	\$375
48653	608.9 to 647.3 feet	Vertical Change	-.38	5 ft	192	LF	\$75	\$14,400
58707	644.1 to 672.9 feet	Driveway				REF		
41437	648.3 to 649.3 feet	Vertical Change	-1.2	5 ft	5	REF		
13465	649.1 to 652.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	16	SF	\$40	\$640
41874	650.2 to 653.2 feet	Vertical Change	-.81	5 ft	15	REF		
13467	652.3 to 654.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	13	SF	\$40	\$500

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908231011	PEACH DR	COTTONWOOD DR	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
44793	653.1 to 654.1 feet	Vertical Change	-.54	5 ft	5	REF			
56986	653.2 to 654.2 feet	Vertical Change	.58	5 ft	5	REF			
13469	654.8 to 656.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	10	SF	\$40	\$400	
42626	655.4 to 659.4 feet	Vertical Change	-.68	5 ft	20	REF			
13470	656.8 to 674.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	87	SF	\$40	\$3,480	
42628	661.5 to 662.5 feet	Vertical Change	-.68	5 ft	5	REF			
42724	665.4 to 666.4 feet	Vertical Change	-.67	5 ft	5	REF			
43065	669.1 to 670.1 feet	Vertical Change	-.64	5 ft	5	REF			
42629	672.8 to 677.9 feet	Vertical Change	-.68	5 ft	26	REF			
13475	674.2 to 675.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$960	
13476	675.8 to 687.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	61	SF	\$120	\$7,260	
47695	679.1 to 688.0 feet	Vertical Change	-.41	5 ft	45	REF			
58708	680.3 to 717.6 feet	Driveway				REF			
13478	687.9 to 713.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	126	SF	\$40	\$5,020	
44580	694.5 to 695.5 feet	Vertical Change	-.55	5 ft	5	REF			
42951	698.0 to 699.0 feet	Vertical Change	-.65	5 ft	5	REF			
43820	701.2 to 702.2 feet	Vertical Change	-.59	5 ft	5	REF			
43199	704.4 to 705.4 feet	Vertical Change	-.63	5 ft	5	REF			
42067	707.5 to 708.5 feet	Vertical Change	-.76	5 ft	5	REF			
42207	711.0 to 712.0 feet	Vertical Change	-.73	5 ft	5	REF			
13482	713.8 to 716.7 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	15	SF	\$40	\$580	
43066	714.2 to 715.2 feet	Vertical Change	-.64	5 ft	5	REF			
13483	716.7 to 722.1 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	27	SF	\$40	\$1,080	
43821	717.7 to 722.9 feet	Vertical Change	-.59	5 ft	26	REF			
13486	722.1 to 724.7 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	13	SF	\$120	\$1,560	
13487	724.7 to 727.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	15	SF	\$120	\$1,740	
47441	725.8 to 726.8 feet	Vertical Change	-.42	5 ft	5	REF			
13489	727.6 to 730.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	12	SF	\$120	\$1,440	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908231011	PEACH DR	COTTONWOOD DR	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13490	730.0 to 733.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220
TOTAL COST FOR: S side of PEACH DR Starting at: COTTONWOOD DR							\$209,932.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908231013	PEACH DR	SANTA CRUZ BLVD	COTTONWOOD DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
42433	1.3 to 2.3 feet	Vertical Change	-.7	5 ft	5	SF	\$75	\$375	
41781	6.8 to 11.2 feet	Vertical Change	-.86	5 ft	22	SF	\$75	\$1,650	
13491	8.8 to 18.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$6,000	
44582	12.6 to 21.9 feet	Vertical Change	-.55	5 ft	47	REF			
13492	22.5 to 28.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,480	
44794	24.6 to 25.6 feet	Vertical Change	-.54	5 ft	5	REF			
44981	27.8 to 28.8 feet	Vertical Change	-.53	5 ft	5	REF			
44161	31.2 to 32.2 feet	Vertical Change	-.57	5 ft	5	SF	\$75	\$375	
46514	34.4 to 35.4 feet	Vertical Change	-.46	5 ft	5	LF	\$75	\$375	
58710	37.0 to 42.8 feet	Driveway				REF			
45361	37.7 to 38.7 feet	Vertical Change	-.51	5 ft	5	REF			
13493	38.5 to 62.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	119	SF	\$40	\$4,760	
43823	41.4 to 45.1 feet	Vertical Change	-.59	5 ft	19	REF			
41378	46.6 to 47.6 feet	Vertical Change	-1.34	5 ft	5	REF			
48091	48.1 to 55.4 feet	Vertical Change	-.4	5 ft	37	REF			
58711	53.3 to 84.7 feet	Driveway				REF			
50990	60.6 to 61.6 feet	Vertical Change	-.31	5 ft	5	REF			
13495	62.3 to 66.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	21	SF	\$40	\$840	
49228	64.4 to 65.4 feet	Vertical Change	-.36	5 ft	5	REF			
13497	66.5 to 79.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	67	SF	\$40	\$2,660	
47697	67.9 to 68.9 feet	Vertical Change	-.41	5 ft	5	REF			
46742	74.6 to 75.6 feet	Vertical Change	-.45	5 ft	5	REF			
45856	78.1 to 79.1 feet	Vertical Change	-.49	5 ft	5	REF			
13499	79.8 to 90.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	53	SF	\$40	\$2,100	
48938	84.0 to 85.0 feet	Vertical Change	-.37	5 ft	5	REF			
49229	88.0 to 89.0 feet	Vertical Change	-.36	5 ft	5	REF			
47442	91.6 to 92.6 feet	Vertical Change	-.42	5 ft	5	REF			
13502	91.8 to 118.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	132	SF	\$120	\$15,840	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
N	1908231013	PEACH DR	SANTA CRUZ BLVD	COTTONWOOD DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
48939	97.3 to 119.1 feet	Vertical Change	-.37	5 ft	109	REF			
58712	114.6 to 153.7 feet	Driveway				REF			
42835	120.2 to 121.2 feet	Vertical Change	-.66	5 ft	5	REF			
13503	120.3 to 149.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	145	SF	\$40	\$5,800	
48655	124.2 to 125.2 feet	Vertical Change	-.38	5 ft	5	REF			
45657	128.0 to 129.0 feet	Vertical Change	-.5	5 ft	5	REF			
43824	132.2 to 133.2 feet	Vertical Change	-.59	5 ft	5	REF			
43825	136.8 to 137.8 feet	Vertical Change	-.59	5 ft	5	REF			
43672	140.8 to 141.8 feet	Vertical Change	-.6	5 ft	5	REF			
48369	144.7 to 145.7 feet	Vertical Change	-.39	5 ft	5	REF			
43201	148.8 to 170.7 feet	Vertical Change	-.63	5 ft	109	REF			
13508	149.3 to 154.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	23	SF	\$40	\$940	
13511	154.9 to 171.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	82	SF	\$120	\$9,840	
58713	163.1 to 191.1 feet	Driveway				REF			
13513	171.3 to 181.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	52	SF	\$40	\$2,080	
43826	173.5 to 174.5 feet	Vertical Change	-.59	5 ft	5	REF			
43068	177.1 to 178.1 feet	Vertical Change	-.64	5 ft	5	REF			
43069	180.3 to 181.3 feet	Vertical Change	-.64	5 ft	5	REF			
13517	181.7 to 186.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	23	SF	\$40	\$900	
44983	183.6 to 184.6 feet	Vertical Change	-.53	5 ft	5	REF			
13519	186.2 to 192.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	33	SF	\$40	\$1,320	
43983	186.9 to 187.9 feet	Vertical Change	-.58	5 ft	5	REF			
42630	190.8 to 194.1 feet	Vertical Change	-.68	5 ft	17	REF			
13523	192.8 to 239.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	232	SF	\$120	\$27,780	
41224	195.4 to 196.4 feet	Vertical Change	-2.1	5 ft	5	REF			
46966	197.5 to 208.3 feet	Vertical Change	-.44	5 ft	54	REF			
47699	214.9 to 219.9 feet	Vertical Change	-.41	5 ft	25	REF			
45659	224.4 to 240.8 feet	Vertical Change	-.5	5 ft	82	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908231013	PEACH DR	SANTA CRUZ BLVD	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58714	233.8 to 260.7 feet	Driveway				REF		
13532	239.1 to 242.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	15	SF	\$40	\$580
13534	242.0 to 243.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	7	SF	\$40	\$260
13535	243.3 to 246.0 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	14	SF	\$40	\$540
13537	246.0 to 247.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$240
43347	246.9 to 247.9 feet	Vertical Change	-62	5 ft	5	REF		
13538	247.2 to 249.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	9	SF	\$40	\$360
42953	250.2 to 251.2 feet	Vertical Change	-65	5 ft	5	REF		
13539	252.8 to 255.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	13	SF	\$40	\$500
42954	253.5 to 254.5 feet	Vertical Change	-65	5 ft	5	REF		
13541	257.1 to 260.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	16	SF	\$40	\$640
42726	260.5 to 264.6 feet	Vertical Change	-67	5 ft	21	REF		
13543	261.9 to 262.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$600
13544	262.9 to 275.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,740
47444	265.5 to 266.5 feet	Vertical Change	-42	5 ft	5	REF		
46967	269.4 to 274.3 feet	Vertical Change	-44	5 ft	25	REF		
58715	269.7 to 296.2 feet	Driveway				REF		
13546	275.8 to 278.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	14	SF	\$40	\$540
13548	278.5 to 282.1 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	18	SF	\$40	\$720
13549	282.1 to 291.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	45	SF	\$40	\$1,820
51899	283.4 to 284.4 feet	Vertical Change	-.3	5 ft	5	REF		
49231	286.6 to 287.6 feet	Vertical Change	-.36	5 ft	5	REF		
46968	290.1 to 291.1 feet	Vertical Change	-.44	5 ft	5	REF		
13552	291.2 to 293.4 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	11	SF	\$40	\$440
13554	294.3 to 297.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	14	SF	\$40	\$560
50209	297.3 to 302.3 feet	Vertical Change	-.33	5 ft	25	LF	\$75	\$1,875
13555	298.6 to 299.7 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	5	SF	\$120	\$660
13556	299.7 to 302.9 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	16	SF	\$120	\$1,920

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908231013	PEACH DR	SANTA CRUZ BLVD	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13558	302.9 to 333.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	152	SF	\$120	\$18,180
42519	303.2 to 308.2 feet	Vertical Change	-.69	5 ft	25	REF		
44583	311.1 to 312.1 feet	Vertical Change	-.55	5 ft	5	REF		
43348	319.2 to 324.3 feet	Vertical Change	-.62	5 ft	26	REF		
42727	327.3 to 350.0 feet	Vertical Change	-.67	5 ft	114	REF		
13559	333.2 to 347.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	71	SF	\$120	\$8,460
58716	339.6 to 367.7 feet	Driveway				REF		
13561	348.2 to 349.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200
13562	349.2 to 352.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	17	SF	\$40	\$680
13563	352.6 to 367.4 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	74	SF	\$40	\$2,960
42837	352.9 to 353.9 feet	Vertical Change	-.66	5 ft	5	REF		
42838	356.5 to 357.5 feet	Vertical Change	-.66	5 ft	5	REF		
42436	360.4 to 361.4 feet	Vertical Change	-.7	5 ft	5	REF		
42957	364.4 to 377.6 feet	Vertical Change	-.65	5 ft	66	REF		
13567	367.4 to 369.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	9	SF	\$40	\$360
13568	369.2 to 381.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	64	SF	\$120	\$7,620
58717	374.6 to 414.0 feet	Driveway				REF		
49232	378.7 to 386.6 feet	Vertical Change	-.36	5 ft	40	REF		
13570	381.9 to 383.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	6	SF	\$40	\$220
13571	383.7 to 397.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	69	SF	\$40	\$2,760
49233	389.7 to 390.7 feet	Vertical Change	-.36	5 ft	5	REF		
45662	393.9 to 394.9 feet	Vertical Change	-.5	5 ft	5	REF		
13574	397.5 to 399.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	9	SF	\$40	\$360
46518	398.5 to 399.5 feet	Vertical Change	-.46	5 ft	5	REF		
13575	399.3 to 410.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	55	SF	\$40	\$2,200
46969	403.2 to 404.2 feet	Vertical Change	-.44	5 ft	5	REF		
13577	410.3 to 413.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	18	SF	\$40	\$700
46970	411.9 to 417.7 feet	Vertical Change	-.44	5 ft	29	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1908231013	PEACH DR	SANTA CRUZ BLVD	COTTONWOOD DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
13578	417.0 to 419.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	12	SF	\$120	\$1,440	
13579	419.4 to 440.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	106	SF	\$120	\$12,660	
42329	428.6 to 429.6 feet	Vertical Change	-71	5 ft	5	REF			
58718	433.2 to 460.3 feet	Driveway				REF			
44367	438.3 to 441.1 feet	Vertical Change	-.56	5 ft	14	REF			
13582	442.0 to 450.1 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	41	SF	\$40	\$1,620	
13585	450.1 to 452.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	11	SF	\$40	\$440	
43828	450.6 to 451.6 feet	Vertical Change	-.59	5 ft	5	REF			
13586	452.3 to 456.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	23	SF	\$40	\$900	
13588	456.8 to 459.2 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	12	SF	\$40	\$480	
44796	461.1 to 464.9 feet	Vertical Change	-.54	5 ft	19	REF			
13589	461.9 to 465.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	16	SF	\$120	\$1,920	
13590	465.1 to 517.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	263	SF	\$120	\$31,500	
46286	491.0 to 492.0 feet	Vertical Change	-.47	5 ft	5	REF			
56634	491.0 to 492.0 feet	Vertical Change	.46	5 ft	5	REF			
43986	501.5 to 502.5 feet	Vertical Change	-.58	5 ft	5	REF			
46746	511.1 to 512.1 feet	Vertical Change	-.45	5 ft	5	REF			
58719	512.8 to 543.6 feet	Driveway				REF			
43987	517.5 to 522.6 feet	Vertical Change	-.58	5 ft	26	REF			
13598	517.6 to 578.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	303	SF	\$40	\$12,120	
42632	525.5 to 526.5 feet	Vertical Change	-.68	5 ft	5	REF			
43988	529.2 to 530.2 feet	Vertical Change	-.58	5 ft	5	REF			
42330	532.9 to 533.9 feet	Vertical Change	-.71	5 ft	5	REF			
47446	539.1 to 540.1 feet	Vertical Change	-.42	5 ft	5	REF			
43204	542.6 to 543.6 feet	Vertical Change	-.63	5 ft	5	REF			
45663	552.8 to 553.8 feet	Vertical Change	-.5	5 ft	5	REF			
46519	559.9 to 568.6 feet	Vertical Change	-.46	5 ft	44	REF			
58720	560.0 to 599.4 feet	Driveway				REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1908231013	PEACH DR	SANTA CRUZ BLVD	COTTONWOOD DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
46069	571.2 to 572.2 feet	Vertical Change	-.48	5 ft	5	REF			
46520	574.8 to 575.8 feet	Vertical Change	-.46	5 ft	5	REF			
48094	578.2 to 579.2 feet	Vertical Change	-.4	5 ft	5	REF			
13609	578.2 to 593.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	78	SF	\$40	\$3,140	
13611	593.9 to 602.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	43	SF	\$40	\$1,720	
48940	594.8 to 595.8 feet	Vertical Change	-.37	5 ft	5	REF			
13615	602.5 to 645.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	216	SF	\$120	\$25,920	
49549	607.1 to 608.1 feet	Vertical Change	-.35	5 ft	5	REF			
49550	615.9 to 616.9 feet	Vertical Change	-.35	5 ft	5	REF			
49873	625.5 to 626.5 feet	Vertical Change	-.34	5 ft	5	REF			
45664	635.8 to 636.8 feet	Vertical Change	-.5	5 ft	5	REF			
58721	637.7 to 668.4 feet	Driveway				REF			
43990	641.8 to 650.5 feet	Vertical Change	-.58	5 ft	44	REF			
13620	645.7 to 656.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	55	SF	\$40	\$2,220	
44371	653.2 to 654.2 feet	Vertical Change	-.56	5 ft	5	REF			
13624	656.8 to 665.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	45	SF	\$40	\$1,780	
47193	656.9 to 657.9 feet	Vertical Change	-.43	5 ft	5	REF			
44797	660.2 to 661.2 feet	Vertical Change	-.54	5 ft	5	REF			
44164	663.8 to 667.5 feet	Vertical Change	-.57	5 ft	19	REF			
13626	665.7 to 670.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	26	SF	\$40	\$1,040	
52791	667.6 to 671.9 feet	Vertical Change	-.28	5 ft	22	REF			
13628	670.9 to 690.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	98	SF	\$120	\$11,760	
49234	679.9 to 680.9 feet	Vertical Change	-.36	5 ft	5	REF			
58722	684.7 to 717.7 feet	Driveway				REF			
50210	686.6 to 690.9 feet	Vertical Change	-.33	5 ft	22	REF			
13630	690.5 to 692.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	11	SF	\$40	\$440	
13632	692.7 to 694.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	8	SF	\$40	\$320	
47447	693.8 to 694.8 feet	Vertical Change	-.42	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1908231013	PEACH DR	SANTA CRUZ BLVD	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13633	694.3 to 698.4 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	21	SF	\$40	\$820
49874	697.1 to 698.1 feet	Vertical Change	-.34	5 ft	5	REF		
13635	698.4 to 722.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	119	SF	\$40	\$4,760
46748	700.6 to 701.6 feet	Vertical Change	-.45	5 ft	5	REF		
49552	704.3 to 705.3 feet	Vertical Change	-.35	5 ft	5	REF		
47702	707.8 to 708.8 feet	Vertical Change	-.41	5 ft	5	REF		
50212	711.5 to 717.8 feet	Vertical Change	-.33	5 ft	32	REF		
48370	720.1 to 721.1 feet	Vertical Change	-.39	5 ft	5	REF		
13638	722.2 to 733.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,900
TOTAL COST FOR: N side of PEACH DR Starting at: SANTA CRUZ BLVD								\$275,710.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908231015	COTTONWOOD DR	PEACH DR	HOWELL RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13641	0.0 to 13.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	66	SF	\$120	\$7,920
13643	13.2 to 40.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	137	SF	\$120	\$16,440
54164	19.3 to 20.3 feet	Vertical Change	.29	5 ft	5	REF		
46288	31.8 to 32.8 feet	Vertical Change	-.47	5 ft	5	REF		
13645	40.6 to 88.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	239	SF	\$120	\$28,620
48941	41.5 to 42.5 feet	Vertical Change	-.37	5 ft	5	REF		
51900	60.3 to 61.3 feet	Vertical Change	-.3	5 ft	5	REF		
52793	69.2 to 70.2 feet	Vertical Change	-.28	5 ft	5	REF		
47194	78.3 to 79.3 feet	Vertical Change	-.43	5 ft	5	REF		
13652	91.4 to 201.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	552	SF	\$120	\$66,240
50213	97.0 to 98.0 feet	Vertical Change	-.33	5 ft	5	REF		
53279	106.2 to 107.2 feet	Vertical Change	-.27	5 ft	5	REF		
51901	113.6 to 114.6 feet	Vertical Change	-.3	5 ft	5	REF		
56957	125.7 to 126.7 feet	Vertical Change	.55	5 ft	5	REF		
53280	153.7 to 154.7 feet	Vertical Change	-.27	5 ft	5	REF		
53818	171.5 to 172.5 feet	Vertical Change	-.26	5 ft	5	REF		
13658	210.0 to 211.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,080
13659	211.8 to 214.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380
TOTAL COST FOR: E side of COTTONWOOD DR Starting at: PEACH DR								\$121,680.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
W	1908231017	COTTONWOOD DR	HOWELL RD	PEACH CT	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
13660	1.6 to 25.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	121	SF	\$120	\$14,460	
41533	6.1 to 7.1 feet	Vertical Change	-1.05	5 ft	5	REF			
49236	9.6 to 10.6 feet	Vertical Change	-.36	5 ft	5	REF			
48371	14.7 to 15.7 feet	Vertical Change	-.39	5 ft	5	REF			
44985	18.8 to 19.8 feet	Vertical Change	-.53	5 ft	5	REF			
13664	25.7 to 110.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	422	SF	\$120	\$50,580	
47195	29.2 to 30.2 feet	Vertical Change	-.43	5 ft	5	REF			
52315	38.9 to 39.9 feet	Vertical Change	-.29	5 ft	5	REF			
41384	49.2 to 50.2 feet	Vertical Change	-1.32	5 ft	5	REF			
56971	49.3 to 50.3 feet	Vertical Change	.56	5 ft	5	REF			
49237	59.6 to 60.6 feet	Vertical Change	-.36	5 ft	5	REF			
42023	69.8 to 70.8 feet	Vertical Change	-.77	5 ft	5	REF			
45170	101.5 to 102.5 feet	Vertical Change	-.52	5 ft	5	REF			
13677	110.0 to 112.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200	
49553	112.4 to 113.4 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$375	
46289	120.5 to 121.5 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375	
46290	130.2 to 131.2 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375	
46521	139.7 to 140.7 feet	Vertical Change	-.46	5 ft	5	LF	\$75	\$375	
43074	149.9 to 150.9 feet	Vertical Change	-.64	5 ft	5	SF	\$75	\$375	
45171	159.7 to 160.7 feet	Vertical Change	-.52	5 ft	5	SF	\$75	\$375	
47703	170.1 to 171.1 feet	Vertical Change	-.41	5 ft	5	LF	\$75	\$375	
50992	179.6 to 180.6 feet	Vertical Change	-.31	5 ft	5	LF	\$75	\$375	
49875	188.7 to 189.7 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375	
13678	197.5 to 200.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860	
46749	201.4 to 202.4 feet	Vertical Change	-.45	5 ft	5	LF	\$75	\$375	
50589	206.6 to 207.6 feet	Vertical Change	-.32	5 ft	5	REF			
13679	207.5 to 215.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,680	
52316	210.0 to 211.0 feet	Vertical Change	-.29	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231017	COTTONWOOD DR	HOWELL RD	PEACH CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
TOTAL COST FOR: W							<i>side of</i>	\$76,530.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N / W	1908231018	PEACH CT	COTTONWOOD DR	608 PEACH CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
13682	5.8 to 9.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,100	
48656	6.8 to 7.8 feet	Vertical Change	-38	5 ft	5	REF			
58723	19.9 to 45.9 feet	Driveway				REF			
44585	25.9 to 26.9 feet	Vertical Change	-55	5 ft	5	REF			
13683	30.1 to 44.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	72	SF	\$40	\$2,880	
42840	36.5 to 37.5 feet	Vertical Change	-66	5 ft	5	REF			
45364	47.3 to 48.3 feet	Vertical Change	-51	5 ft	5	SF	\$75	\$375	
58724	51.1 to 77.7 feet	Driveway				REF			
43829	55.9 to 56.9 feet	Vertical Change	-59	5 ft	5	REF			
13686	56.3 to 58.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	12	SF	\$40	\$480	
13688	58.7 to 73.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	74	SF	\$40	\$2,940	
46291	61.2 to 62.2 feet	Vertical Change	-47	5 ft	5	REF			
42209	66.6 to 67.6 feet	Vertical Change	-73	5 ft	5	REF			
42841	71.8 to 72.8 feet	Vertical Change	-66	5 ft	5	REF			
13692	73.4 to 74.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	7	SF	\$40	\$280	
13693	74.8 to 75.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200	
43674	77.1 to 78.1 feet	Vertical Change	-6	5 ft	5	REF			
13694	77.4 to 79.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	10	SF	\$40	\$420	
42331	84.9 to 85.9 feet	Vertical Change	-71	5 ft	5	SF	\$75	\$375	
42633	92.8 to 93.8 feet	Vertical Change	-68	5 ft	5	SF	\$75	\$375	
13695	100.4 to 110.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,820	
42438	100.7 to 101.7 feet	Vertical Change	-7	5 ft	5	REF			
42332	109.1 to 110.1 feet	Vertical Change	-71	5 ft	5	REF			
42068	118.0 to 119.0 feet	Vertical Change	-76	5 ft	5	SF	\$75	\$375	
58725	123.8 to 150.8 feet	Driveway				REF			
51903	126.6 to 127.6 feet	Vertical Change	-3	5 ft	5	REF			
43075	128.4 to 129.4 feet	Vertical Change	-64	5 ft	5	REF			
13696	133.4 to 150.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	87	SF	\$40	\$3,480	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N / W	1908231018	PEACH CT	COTTONWOOD DR	608 PEACH CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
42103	139.8 to 140.8 feet	Vertical Change	-.75	5 ft	5	REF		
13699	159.5 to 161.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
58726	165.4 to 192.6 feet	Driveway				REF		
13700	174.2 to 182.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	44	SF	\$40	\$1,740
41960	182.3 to 183.3 feet	Vertical Change	-.79	5 ft	5	REF		
13702	182.9 to 191.0 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	41	SF	\$40	\$1,620
46070	193.7 to 197.0 feet	Vertical Change	-.48	5 ft	17	LF	\$75	\$1,238
58727	198.9 to 229.8 feet	Driveway				REF		
46750	202.2 to 203.2 feet	Vertical Change	-.45	5 ft	5	REF		
50214	205.8 to 206.8 feet	Vertical Change	-.33	5 ft	5	REF		
13705	207.8 to 213.0 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	26	SF	\$40	\$1,040
46522	210.8 to 211.8 feet	Vertical Change	-.46	5 ft	5	REF		
13707	213.0 to 216.6 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	18	SF	\$40	\$720
46071	215.4 to 216.4 feet	Vertical Change	-.48	5 ft	5	REF		
13708	216.6 to 224.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	37	SF	\$40	\$1,480
42728	220.5 to 221.5 feet	Vertical Change	-.67	5 ft	5	REF		
13710	224.0 to 228.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	21	SF	\$40	\$840
46523	224.7 to 225.7 feet	Vertical Change	-.46	5 ft	5	REF		
13712	228.2 to 229.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200
44586	229.5 to 232.7 feet	Vertical Change	-.55	5 ft	16	REF		

TOTAL COST FOR: N / W side of PEACH CT Starting at: COTTONWOOD DR \$30,057.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908231020	PEACH CT	605 PEACH CT	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13713	3.4 to 7.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,640
58728	4.8 to 33.3 feet	Driveway				REF		
44165	9.8 to 10.8 feet	Vertical Change	-57	5 ft	5	REF		
13714	13.6 to 16.7 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	16	SF	\$40	\$620
13715	16.7 to 19.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	16	SF	\$40	\$620
13716	19.8 to 25.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	29	SF	\$40	\$1,160
42333	22.3 to 23.3 feet	Vertical Change	-71	5 ft	5	REF		
13717	25.6 to 33.1 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	38	SF	\$40	\$1,500
43830	28.2 to 29.2 feet	Vertical Change	-59	5 ft	5	REF		
13719	33.1 to 34.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$220
13720	34.2 to 41.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,440
43992	34.6 to 35.6 feet	Vertical Change	-58	5 ft	5	REF		
58729	38.3 to 66.3 feet	Driveway				REF		
53282	39.4 to 40.4 feet	Vertical Change	-27	5 ft	5	REF		
13722	43.9 to 44.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200
45172	44.4 to 45.4 feet	Vertical Change	-52	5 ft	5	REF		
13723	45.8 to 53.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	36	SF	\$40	\$1,440
43831	48.5 to 49.5 feet	Vertical Change	-59	5 ft	5	REF		
44798	52.5 to 53.5 feet	Vertical Change	-54	5 ft	5	REF		
13727	53.0 to 67.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	72	SF	\$40	\$2,860
45173	56.5 to 57.5 feet	Vertical Change	-52	5 ft	5	REF		
46971	60.3 to 61.3 feet	Vertical Change	-44	5 ft	5	REF		
48942	64.2 to 65.4 feet	Vertical Change	-37	5 ft	6	REF		
51904	67.9 to 68.9 feet	Vertical Change	-3	5 ft	5	LF	\$75	\$375
46752	72.8 to 73.8 feet	Vertical Change	-45	5 ft	5	LF	\$75	\$375
52317	77.3 to 78.3 feet	Vertical Change	-29	5 ft	5	LF	\$75	\$375
44587	81.6 to 82.6 feet	Vertical Change	-55	5 ft	5	SF	\$75	\$375
42634	90.4 to 91.4 feet	Vertical Change	-68	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908231020	PEACH CT	605 PEACH CT	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13730	91.3 to 105.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,700
42439	99.4 to 100.4 feet	Vertical Change	-7	5 ft	5	REF		
58730	109.2 to 139.8 feet	Driveway				REF		
50590	115.4 to 116.4 feet	Vertical Change	-.32	5 ft	5	REF		
13733	116.0 to 118.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	12	SF	\$40	\$480
13735	118.4 to 123.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	28	SF	\$40	\$1,100
42842	121.9 to 122.9 feet	Vertical Change	-.66	5 ft	5	REF		
13737	123.9 to 126.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	12	SF	\$40	\$480
42259	128.4 to 129.4 feet	Vertical Change	-.72	5 ft	5	REF		
13738	130.2 to 135.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	28	SF	\$40	\$1,100
42729	134.1 to 135.1 feet	Vertical Change	-.67	5 ft	5	REF		
13740	135.7 to 140.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	22	SF	\$40	\$880
44588	137.7 to 138.7 feet	Vertical Change	-.55	5 ft	5	REF		
57124	137.8 to 138.8 feet	Vertical Change	.6	5 ft	5	REF		
13742	140.1 to 141.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240
43675	140.6 to 141.6 feet	Vertical Change	-.6	5 ft	5	REF		
41794	144.0 to 145.0 feet	Vertical Change	-.85	5 ft	5	SF	\$75	\$375
58731	145.0 to 171.1 feet	Driveway				REF		
42522	148.5 to 149.5 feet	Vertical Change	-.69	5 ft	5	REF		
13743	152.3 to 157.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	25	SF	\$40	\$1,000
42440	156.4 to 157.4 feet	Vertical Change	-.7	5 ft	5	REF		
13745	157.3 to 170.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	63	SF	\$40	\$2,540
41961	160.3 to 161.3 feet	Vertical Change	-.79	5 ft	5	REF		
43349	164.0 to 165.0 feet	Vertical Change	-.62	5 ft	5	REF		
43076	167.7 to 168.7 feet	Vertical Change	-.64	5 ft	5	REF		
13748	170.0 to 171.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$260
42843	171.5 to 172.5 feet	Vertical Change	-.66	5 ft	5	SF	\$75	\$375
52794	173.8 to 174.8 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908231020	PEACH CT	605 PEACH CT	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
43993	181.6 to 182.6 feet	Vertical Change	-.58	5 ft	5	SF	\$75	\$375
13749	188.8 to 196.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,440
45860	189.4 to 190.4 feet	Vertical Change	-.49	5 ft	5	REF		
TOTAL COST FOR: S							<i>side of PEACH CT Starting at: 605 PEACH CT</i>	\$39,920.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908231021	COTTONWOOD DR	PEACH DR	SPRUCE CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
13750	4.1 to 16.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,200	
41403	5.8 to 6.8 feet	Vertical Change	-1.27	5 ft	5	REF			
41962	15.0 to 16.0 feet	Vertical Change	-.79	5 ft	5	REF			
43507	24.0 to 25.0 feet	Vertical Change	-.61	5 ft	5	SF	\$75	\$375	
41757	33.0 to 34.0 feet	Vertical Change	-.87	5 ft	5	SF	\$75	\$375	
42334	42.5 to 43.5 feet	Vertical Change	-.71	5 ft	5	SF	\$75	\$375	
53819	52.0 to 53.0 feet	Vertical Change	-.26	5 ft	5	REF			
13753	52.9 to 61.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$5,040	
43676	56.2 to 57.2 feet	Vertical Change	-.6	5 ft	5	REF			
46072	60.5 to 61.5 feet	Vertical Change	-.48	5 ft	5	REF			
42166	70.2 to 71.2 feet	Vertical Change	-.74	5 ft	5	SF	\$75	\$375	
45861	79.2 to 80.2 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$375	
42958	89.1 to 90.1 feet	Vertical Change	-.65	5 ft	5	SF	\$75	\$375	
13754	90.9 to 93.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680	
44166	98.6 to 99.6 feet	Vertical Change	-.57	5 ft	5	SF	\$75	\$375	
13755	102.5 to 103.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720	
41963	108.8 to 109.8 feet	Vertical Change	-.79	5 ft	5	SF	\$75	\$375	
13756	112.5 to 122.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,880	
52318	118.8 to 119.8 feet	Vertical Change	-.29	5 ft	5	REF			
44372	129.0 to 130.0 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375	
46292	138.3 to 139.3 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375	
13757	151.4 to 165.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	72	SF	\$120	\$8,580	
43994	152.0 to 153.0 feet	Vertical Change	-.58	5 ft	5	REF			
46524	157.1 to 158.1 feet	Vertical Change	-.46	5 ft	5	REF			
50216	161.8 to 162.8 feet	Vertical Change	-.33	5 ft	5	REF			
46753	167.0 to 168.0 feet	Vertical Change	-.45	5 ft	5	LF	\$75	\$375	
44799	176.3 to 177.3 feet	Vertical Change	-.54	5 ft	5	SF	\$75	\$375	
48372	186.5 to 187.5 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231021	COTTONWOOD DR	PEACH DR	SPRUCE CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47196	195.2 to 196.2 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375
47197	199.0 to 200.0 feet	Vertical Change	-.43	5 ft	5	LF	\$75	\$375
13759	206.2 to 208.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
46754	206.8 to 207.8 feet	Vertical Change	-.45	5 ft	5	REF		
TOTAL COST FOR: W side of COTTONWOOD DR Starting at: PEACH DR							\$36,225.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231023	WILLOW CT	COTTONWOOD DR	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13760	5.7 to 15.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,760
41542	7.5 to 8.5 feet	Vertical Change	-1.04	5 ft	5	REF		
58732	19.1 to 43.7 feet	Driveway				REF		
50217	20.1 to 23.1 feet	Vertical Change	-.33	5 ft	15	REF		
42844	24.1 to 25.1 feet	Vertical Change	-.66	5 ft	5	REF		
42441	28.1 to 29.1 feet	Vertical Change	-.7	5 ft	5	REF		
43508	33.8 to 34.8 feet	Vertical Change	-.61	5 ft	5	REF		
49876	38.7 to 40.6 feet	Vertical Change	-.34	5 ft	9	REF		
13761	38.7 to 41.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	13	SF	\$40	\$520
13763	41.3 to 43.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	11	SF	\$40	\$440
56937	43.2 to 44.2 feet	Vertical Change	.53	5 ft	5	REF		
13764	44.4 to 45.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200
48373	46.0 to 47.0 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375
58733	48.7 to 73.3 feet	Driveway				REF		
43996	54.5 to 55.5 feet	Vertical Change	-.58	5 ft	5	REF		
13765	58.2 to 59.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	8	SF	\$40	\$320
47448	59.8 to 60.8 feet	Vertical Change	-.42	5 ft	5	REF		
13766	59.8 to 71.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	59	SF	\$40	\$2,340
43205	65.0 to 66.0 feet	Vertical Change	-.63	5 ft	5	REF		
51905	70.2 to 71.2 feet	Vertical Change	-.3	5 ft	5	REF		
13770	71.5 to 72.9 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	7	SF	\$40	\$280
13771	72.9 to 74.1 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$240
45862	75.2 to 76.2 feet	Vertical Change	-.49	5 ft	5	REF		
13772	75.7 to 82.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,260
43677	84.4 to 85.4 feet	Vertical Change	-.6	5 ft	5	SF	\$75	\$375
13774	90.7 to 95.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000
49554	91.9 to 92.9 feet	Vertical Change	-.35	5 ft	5	REF		
52795	99.8 to 100.8 feet	Vertical Change	-.28	5 ft	5	LF	\$75	\$375

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231023	WILLOW CT	COTTONWOOD DR	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
45863	108.2 to 109.2 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$375
42845	116.4 to 117.4 feet	Vertical Change	-.66	5 ft	5	SF	\$75	\$375
58734	123.3 to 152.8 feet	Driveway				REF		
42635	130.7 to 131.7 feet	Vertical Change	-.68	5 ft	5	REF		
13775	135.0 to 144.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	46	SF	\$40	\$1,820
42523	136.7 to 137.7 feet	Vertical Change	-.69	5 ft	5	REF		
45366	142.6 to 143.6 feet	Vertical Change	-.51	5 ft	5	REF		
13779	144.1 to 151.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	37	SF	\$40	\$1,480
44986	154.4 to 155.4 feet	Vertical Change	-.53	5 ft	5	SF	\$75	\$375
58735	164.7 to 191.3 feet	Driveway				REF		
49877	170.1 to 171.1 feet	Vertical Change	-.34	5 ft	5	REF		
13782	173.8 to 189.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	78	SF	\$40	\$3,120
41461	181.8 to 182.8 feet	Vertical Change	-1.14	5 ft	5	REF		
40382	189.3 to 190.3 feet	Running Slope	7.0-8.0%	5 ft	5	REF		
43509	192.3 to 193.3 feet	Vertical Change	-.61	5 ft	5	SF	\$75	\$375
58736	194.9 to 221.5 feet	Driveway				REF		
43510	201.2 to 202.2 feet	Vertical Change	-.61	5 ft	5	REF		
13784	204.5 to 220.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	80	SF	\$40	\$3,200
42069	211.8 to 212.8 feet	Vertical Change	-.76	5 ft	5	REF		
40383	219.1 to 220.7 feet	Running Slope	6.0-7.0%	5 ft	8	REF		
43350	222.6 to 223.6 feet	Vertical Change	-.62	5 ft	5	SF	\$75	\$375
43997	233.5 to 234.5 feet	Vertical Change	-.58	5 ft	5	SF	\$75	\$375
13786	241.1 to 243.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440
43077	244.9 to 245.9 feet	Vertical Change	-.64	5 ft	5	SF	\$75	\$375
13787	247.2 to 248.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960
58737	247.7 to 280.5 feet	Driveway				REF		
42846	255.3 to 256.3 feet	Vertical Change	-.66	5 ft	5	REF		
13788	258.5 to 274.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	82	SF	\$40	\$3,260
43678	261.7 to 262.7 feet	Vertical Change	-.6	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231023	WILLOW CT	COTTONWOOD DR	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41736	267.4 to 268.4 feet	Vertical Change	-.88	5 ft	5	REF		
13794	274.8 to 277.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	15	SF	\$40	\$600
42636	280.1 to 281.1 feet	Vertical Change	-.68	5 ft	5	REF		
58738	282.1 to 310.8 feet	Driveway				REF		
13795	282.5 to 284.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	9	SF	\$40	\$340
41995	287.3 to 288.3 feet	Vertical Change	-.78	5 ft	5	REF		
13796	289.8 to 306.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	84	SF	\$40	\$3,340
43679	294.2 to 295.2 feet	Vertical Change	-.6	5 ft	5	REF		
42847	300.6 to 301.6 feet	Vertical Change	-.66	5 ft	5	REF		
13799	306.5 to 311.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	27	SF	\$40	\$1,080
43078	306.8 to 307.8 feet	Vertical Change	-.64	5 ft	5	REF		
13802	311.9 to 312.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
42024	313.0 to 314.0 feet	Vertical Change	-.77	5 ft	5	SF	\$75	\$375
52319	321.4 to 322.4 feet	Vertical Change	-.29	5 ft	5	LF	\$75	\$375
49878	329.4 to 330.4 feet	Vertical Change	-.34	5 ft	5	LF	\$75	\$375
44373	336.9 to 337.9 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375
49555	345.1 to 346.1 feet	Vertical Change	-.35	5 ft	5	LF	\$75	\$375
53283	354.0 to 355.0 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
58739	357.3 to 384.3 feet	Driveway				REF		
51906	361.6 to 364.6 feet	Vertical Change	-.3	5 ft	15	REF		
13803	364.1 to 366.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	12	SF	\$40	\$460
13805	366.4 to 384.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	89	SF	\$40	\$3,540
48374	367.4 to 370.1 feet	Vertical Change	-.39	5 ft	14	REF		
45367	374.7 to 375.7 feet	Vertical Change	-.51	5 ft	5	REF		
44374	379.2 to 380.2 feet	Vertical Change	-.56	5 ft	5	REF		
13809	384.1 to 385.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240
49556	385.1 to 388.2 feet	Vertical Change	-.35	5 ft	16	REF		
58740	389.5 to 416.3 feet	Driveway				REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231023	WILLOW CT	COTTONWOOD DR	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13810	389.9 to 390.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200
44375	394.5 to 395.5 feet	Vertical Change	-.56	5 ft	5	REF		
13811	396.3 to 403.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	34	SF	\$40	\$1,340
44800	399.0 to 400.0 feet	Vertical Change	-.54	5 ft	5	REF		
42730	403.4 to 404.4 feet	Vertical Change	-.67	5 ft	5	REF		
42731	410.7 to 411.7 feet	Vertical Change	-.67	5 ft	5	REF		
13814	411.3 to 413.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	13	SF	\$40	\$520
44801	417.7 to 418.7 feet	Vertical Change	-.54	5 ft	5	SF	\$75	\$375
13815	434.6 to 439.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060
45864	435.6 to 436.6 feet	Vertical Change	-.49	5 ft	5	REF		
TOTAL COST FOR: W side of WILLOW CT Starting at: COTTONWOOD DR							\$54,335.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231024	COTTONWOOD DR	WILLOW CT	ALMOND CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13816	5.3 to 16.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,480
43832	6.2 to 7.2 feet	Vertical Change	-.59	5 ft	5	REF		
48375	10.2 to 11.2 feet	Vertical Change	-.39	5 ft	5	REF		
48657	15.2 to 16.2 feet	Vertical Change	-.38	5 ft	5	REF		
13818	16.1 to 25.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	44	SF	\$120	\$5,340
13820	25.0 to 35.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,360
42848	27.0 to 28.0 feet	Vertical Change	-.66	5 ft	5	REF		
45174	35.3 to 36.3 feet	Vertical Change	-.52	5 ft	5	REF		
57137	35.3 to 36.3 feet	Vertical Change	.62	5 ft	5	REF		
44376	45.2 to 46.2 feet	Vertical Change	-.56	5 ft	5	SF	\$75	\$375
13821	47.8 to 49.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
13822	52.8 to 56.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,980
13823	58.8 to 63.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760
48943	63.8 to 64.8 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375
13824	66.2 to 73.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,260
13825	83.1 to 88.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,480
47198	83.2 to 84.2 feet	Vertical Change	-.43	5 ft	5	REF		
53284	94.1 to 95.1 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
45865	103.8 to 104.8 feet	Vertical Change	-.49	5 ft	5	LF	\$75	\$375
43998	113.5 to 114.5 feet	Vertical Change	-.58	5 ft	5	SF	\$75	\$375
13826	122.0 to 130.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,860
45175	122.7 to 123.7 feet	Vertical Change	-.52	5 ft	5	REF		
13827	141.3 to 145.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,280
43079	143.4 to 144.4 feet	Vertical Change	-.64	5 ft	5	REF		
13828	149.3 to 150.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960
42849	152.9 to 153.9 feet	Vertical Change	-.66	5 ft	5	SF	\$75	\$375
13829	159.4 to 162.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,100
42732	162.1 to 163.1 feet	Vertical Change	-.67	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231024	COTTONWOOD DR	WILLOW CT	ALMOND CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
42959	180.9 to 181.9 feet	Vertical Change	-.65	5 ft	5	SF	\$75	\$375
42850	189.8 to 190.8 feet	Vertical Change	-.66	5 ft	5	SF	\$75	\$375
43511	199.9 to 200.9 feet	Vertical Change	-.61	5 ft	5	SF	\$75	\$375
13830	203.0 to 213.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,060
TOTAL COST FOR: W side of COTTONWOOD DR Starting at: WILLOW CT							\$51,375.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908231026	ALMOND CT	COTTONWOOD DR	COTTONWOOD DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
13831	7.0 to 12.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060	
52321	12.4 to 13.4 feet	Vertical Change	-29	5 ft	5	LF	\$75	\$375	
58741	18.5 to 45.4 feet	Driveway				REF			
13832	20.1 to 25.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	28	SF	\$40	\$1,140	
42210	24.4 to 25.4 feet	Vertical Change	-.73	5 ft	5	REF			
13833	26.8 to 46.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	100	SF	\$40	\$3,980	
42442	35.4 to 36.4 feet	Vertical Change	-.7	5 ft	5	REF			
43351	41.2 to 42.2 feet	Vertical Change	-.62	5 ft	5	REF			
13839	46.7 to 54.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,860	
44377	46.8 to 47.8 feet	Vertical Change	-.56	5 ft	5	REF			
52322	49.2 to 50.2 feet	Vertical Change	-.29	5 ft	5	REF			
58742	50.7 to 75.0 feet	Driveway				REF			
45176	54.3 to 55.3 feet	Vertical Change	-.52	5 ft	5	REF			
53820	54.4 to 55.4 feet	Vertical Change	-.26	5 ft	5	REF			
45177	56.3 to 57.3 feet	Vertical Change	-.52	5 ft	5	REF			
13841	57.6 to 59.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	11	SF	\$40	\$420	
13843	59.7 to 73.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	68	SF	\$40	\$2,720	
49557	61.6 to 62.6 feet	Vertical Change	-.35	5 ft	5	REF			
41442	66.6 to 67.6 feet	Vertical Change	-1.19	5 ft	5	REF			
45178	71.5 to 72.5 feet	Vertical Change	-.52	5 ft	5	REF			
13847	73.3 to 75.1 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	9	SF	\$40	\$360	
13848	75.1 to 76.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$240	
44378	77.3 to 78.3 feet	Vertical Change	-.56	5 ft	5	REF			
13849	77.9 to 80.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,260	
51907	82.8 to 83.8 feet	Vertical Change	-.3	5 ft	5	LF	\$75	\$375	
42211	86.4 to 87.4 feet	Vertical Change	-.73	5 ft	5	SF	\$75	\$375	
45665	94.2 to 95.2 feet	Vertical Change	-.5	5 ft	5	SF	\$75	\$375	
42960	102.4 to 103.4 feet	Vertical Change	-.65	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231026	ALMOND CT	COTTONWOOD DR	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13850	103.0 to 125.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	115	SF	\$120	\$13,740
41875	110.6 to 111.6 feet	Vertical Change	-.81	5 ft	5	REF		
41964	118.7 to 119.7 feet	Vertical Change	-.79	5 ft	5	REF		
58743	122.2 to 153.0 feet	Driveway				REF		
43999	126.9 to 130.1 feet	Vertical Change	-.58	5 ft	16	REF		
13851	131.2 to 141.5 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	52	SF	\$40	\$2,060
42443	135.2 to 136.2 feet	Vertical Change	-.7	5 ft	5	REF		
41639	141.4 to 142.4 feet	Vertical Change	-.94	5 ft	5	REF		
13854	141.5 to 154.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	63	SF	\$40	\$2,500
42335	146.7 to 147.7 feet	Vertical Change	-.71	5 ft	5	REF		
42851	152.5 to 153.5 feet	Vertical Change	-.66	5 ft	5	REF		
44589	161.4 to 162.4 feet	Vertical Change	-.55	5 ft	5	SF	\$75	\$375
58744	165.4 to 196.7 feet	Driveway				REF		
52796	166.2 to 167.2 feet	Vertical Change	-.28	5 ft	5	REF		
42444	172.5 to 173.5 feet	Vertical Change	-.7	5 ft	5	REF		
13857	174.3 to 180.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	31	SF	\$40	\$1,240
57138	176.4 to 177.4 feet	Vertical Change	.62	5 ft	5	REF		
46073	177.2 to 178.2 feet	Vertical Change	-.48	5 ft	5	REF		
45866	181.7 to 182.7 feet	Vertical Change	-.49	5 ft	5	REF		
41783	186.4 to 187.4 feet	Vertical Change	-.86	5 ft	5	REF		
49558	192.5 to 193.5 feet	Vertical Change	-.35	5 ft	5	REF		
13860	194.7 to 196.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	11	SF	\$40	\$420
48096	198.4 to 201.4 feet	Vertical Change	-.4	5 ft	15	LF	\$75	\$1,125
58745	202.3 to 230.8 feet	Driveway				REF		
13861	202.4 to 211.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	46	SF	\$40	\$1,820
48376	206.1 to 207.1 feet	Vertical Change	-.39	5 ft	5	REF		
42852	207.7 to 208.7 feet	Vertical Change	-.66	5 ft	5	REF		
13864	212.4 to 229.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	85	SF	\$40	\$3,380

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231026	ALMOND CT	COTTONWOOD DR	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41813	218.2 to 219.2 feet	Vertical Change	-.84	5 ft	5	REF		
42637	230.6 to 231.6 feet	Vertical Change	-.68	5 ft	5	REF		
54125	232.4 to 233.4 feet	Vertical Change	-.25	5 ft	5	LF	\$75	\$375
13868	235.8 to 248.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,740
58746	242.0 to 284.8 feet	Driveway				REF		
42961	245.6 to 249.4 feet	Vertical Change	-.65	5 ft	19	REF		
13872	248.7 to 251.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	12	SF	\$40	\$480
13874	251.1 to 254.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	16	SF	\$40	\$640
13875	254.3 to 276.9 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	113	SF	\$40	\$4,520
46074	256.5 to 257.5 feet	Vertical Change	-.48	5 ft	5	REF		
41686	260.2 to 261.2 feet	Vertical Change	-.91	5 ft	5	REF		
42638	264.0 to 265.0 feet	Vertical Change	-.68	5 ft	5	REF		
44379	267.8 to 268.8 feet	Vertical Change	-.56	5 ft	5	REF		
41848	271.5 to 272.5 feet	Vertical Change	-.82	5 ft	5	REF		
44167	275.5 to 276.5 feet	Vertical Change	-.57	5 ft	5	REF		
13878	276.9 to 282.7 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	29	SF	\$40	\$1,160
43513	283.8 to 292.7 feet	Vertical Change	-.61	5 ft	45	REF		
13880	285.9 to 290.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,940
58747	286.3 to 315.5 feet	Driveway				REF		
13882	293.2 to 301.8 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	43	SF	\$40	\$1,720
48377	299.4 to 300.4 feet	Vertical Change	-.39	5 ft	5	REF		
13886	301.8 to 310.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	44	SF	\$40	\$1,740
44001	303.3 to 304.3 feet	Vertical Change	-.58	5 ft	5	REF		
48658	307.4 to 308.4 feet	Vertical Change	-.38	5 ft	5	REF		
13887	310.5 to 314.1 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	18	SF	\$40	\$720
13888	314.1 to 315.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$220
42853	315.1 to 320.6 feet	Vertical Change	-.66	5 ft	28	REF		
13889	316.1 to 321.5 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	27	SF	\$40	\$1,080

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231026	ALMOND CT	COTTONWOOD DR	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13890	321.5 to 357.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	179	SF	\$120	\$21,480
42640	328.4 to 329.4 feet	Vertical Change	-68	5 ft	5	REF		
46756	337.1 to 338.1 feet	Vertical Change	-45	5 ft	5	REF		
42733	345.6 to 346.6 feet	Vertical Change	-67	5 ft	5	REF		
58748	356.5 to 394.1 feet	Driveway				REF		
41201	358.2 to 359.2 feet	Vertical Change	-2.4	5 ft	5	REF		
43353	360.0 to 362.9 feet	Vertical Change	-62	5 ft	15	REF		
13895	361.6 to 363.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	11	SF	\$40	\$420
13897	363.7 to 370.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	35	SF	\$40	\$1,400
47199	365.7 to 366.7 feet	Vertical Change	-43	5 ft	5	REF		
48378	369.6 to 370.6 feet	Vertical Change	-39	5 ft	5	REF		
13901	370.7 to 390.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	101	SF	\$40	\$4,020
44591	373.3 to 374.3 feet	Vertical Change	-55	5 ft	5	REF		
43514	376.8 to 377.8 feet	Vertical Change	-61	5 ft	5	REF		
43680	380.0 to 381.0 feet	Vertical Change	-6	5 ft	5	REF		
42734	383.2 to 384.2 feet	Vertical Change	-67	5 ft	5	REF		
50591	386.7 to 387.7 feet	Vertical Change	-32	5 ft	5	REF		
43833	390.2 to 391.2 feet	Vertical Change	-59	5 ft	5	REF		
13904	390.8 to 395.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	26	SF	\$40	\$1,020
42524	393.8 to 399.3 feet	Vertical Change	-69	5 ft	28	REF		
13908	395.9 to 408.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	61	SF	\$120	\$7,320
58749	400.8 to 429.8 feet	Driveway				REF		
43080	403.7 to 408.3 feet	Vertical Change	-64	5 ft	23	REF		
13910	408.1 to 420.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	61	SF	\$40	\$2,420
43081	413.7 to 414.7 feet	Vertical Change	-64	5 ft	5	REF		
41965	417.0 to 418.0 feet	Vertical Change	-79	5 ft	5	REF		
13914	420.2 to 424.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	23	SF	\$40	\$900
42735	420.7 to 421.7 feet	Vertical Change	-67	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231026	ALMOND CT	COTTONWOOD DR	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
42736	424.4 to 425.4 feet	Vertical Change	-.67	5 ft	5	REF		
13916	424.7 to 431.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	32	SF	\$40	\$1,260
56938	428.0 to 429.0 feet	Vertical Change	.53	5 ft	5	REF		
42447	428.4 to 431.6 feet	Vertical Change	-.7	5 ft	16	REF		
13918	431.0 to 448.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	90	SF	\$120	\$10,740
48379	432.8 to 433.8 feet	Vertical Change	-.39	5 ft	5	REF		
41670	443.9 to 444.9 feet	Vertical Change	-.92	5 ft	5	REF		
56929	444.0 to 445.0 feet	Vertical Change	.52	5 ft	5	REF		
TOTAL COST FOR: W side of ALMOND CT Starting at: COTTONWOOD DR							\$120,515.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1908231028	COTTONWOOD DR	ALMOND CT	PARKRIDGE DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
13920	5.8 to 18.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,500	
50592	6.2 to 7.2 feet	Vertical Change	-32	5 ft	5	REF			
46757	17.6 to 18.6 feet	Vertical Change	-45	5 ft	5	REF			
13922	18.3 to 51.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	168	SF	\$120	\$20,100	
42260	29.8 to 30.8 feet	Vertical Change	-72	5 ft	5	REF			
46973	39.4 to 40.4 feet	Vertical Change	-44	5 ft	5	REF			
57141	39.5 to 40.5 feet	Vertical Change	.63	5 ft	5	REF			
45867	49.4 to 52.8 feet	Vertical Change	-49	5 ft	17	REF			
13928	51.8 to 53.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960	
45368	56.3 to 57.3 feet	Vertical Change	-51	5 ft	5	SF	\$75	\$375	
13929	59.7 to 61.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320	
48380	60.8 to 61.8 feet	Vertical Change	-39	5 ft	5	REF			
13931	61.9 to 72.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	52	SF	\$120	\$6,180	
46075	69.4 to 70.4 feet	Vertical Change	-48	5 ft	5	REF			
13935	72.2 to 91.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	95	SF	\$120	\$11,340	
52323	79.1 to 80.1 feet	Vertical Change	-29	5 ft	5	REF			
43206	89.8 to 90.8 feet	Vertical Change	-63	5 ft	5	REF			
13939	91.1 to 155.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	320	SF	\$120	\$38,400	
45179	100.5 to 101.5 feet	Vertical Change	-52	5 ft	5	REF			
48097	110.6 to 111.6 feet	Vertical Change	-4	5 ft	5	REF			
48098	120.4 to 121.4 feet	Vertical Change	-4	5 ft	5	REF			
13946	155.9 to 157.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840	
13947	164.3 to 170.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	31	SF	\$120	\$3,660	
13949	170.4 to 171.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	5	SF	\$120	\$600	
13950	171.4 to 191.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	102	SF	\$120	\$12,240	
13955	191.8 to 200.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	43	SF	\$120	\$5,160	
13957	200.4 to 210.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	53	SF	\$120	\$6,300	
13958	210.9 to 213.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231028	COTTONWOOD DR	ALMOND CT	PARKRIDGE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
TOTAL COST FOR: W							<i>side of</i>	\$116,535.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231030	PARKRIDGE CT	COTTONWOOD DR	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
13959	0.0 to 22.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	111	SF	\$120	\$13,320
41256	6.2 to 7.2 feet	Vertical Change	-1.8	5 ft	5	REF		
50993	6.2 to 7.2 feet	Vertical Change	-.31	5 ft	5	REF		
58750	18.8 to 43.3 feet	Driveway				REF		
48659	18.9 to 21.4 feet	Vertical Change	-.38	5 ft	13	REF		
42336	22.1 to 23.1 feet	Vertical Change	-.71	5 ft	5	REF		
13965	22.2 to 27.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	26	SF	\$40	\$1,020
46758	26.0 to 27.0 feet	Vertical Change	-.45	5 ft	5	REF		
13967	27.3 to 41.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	69	SF	\$40	\$2,740
45666	29.5 to 30.5 feet	Vertical Change	-.5	5 ft	5	REF		
43834	32.9 to 33.9 feet	Vertical Change	-.59	5 ft	5	REF		
44003	40.0 to 41.0 feet	Vertical Change	-.58	5 ft	5	REF		
13969	41.0 to 47.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	33	SF	\$40	\$1,300
48945	43.4 to 49.4 feet	Vertical Change	-.37	5 ft	30	REF		
13971	47.5 to 86.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	193	SF	\$120	\$23,160
48381	52.0 to 58.0 feet	Vertical Change	-.39	5 ft	30	REF		
58751	53.3 to 90.1 feet	Driveway				REF		
43082	62.7 to 63.7 feet	Vertical Change	-.64	5 ft	5	REF		
42854	65.8 to 69.8 feet	Vertical Change	-.66	5 ft	20	REF		
42449	72.2 to 73.2 feet	Vertical Change	-.7	5 ft	5	REF		
42337	75.4 to 76.4 feet	Vertical Change	-.71	5 ft	5	REF		
42025	78.8 to 79.8 feet	Vertical Change	-.77	5 ft	5	REF		
42262	82.3 to 83.3 feet	Vertical Change	-.72	5 ft	5	REF		
42963	85.9 to 86.9 feet	Vertical Change	-.65	5 ft	5	REF		
13975	86.1 to 128.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	211	SF	\$40	\$8,440
56987	89.2 to 90.2 feet	Vertical Change	.58	5 ft	5	REF		
43207	89.7 to 97.5 feet	Vertical Change	-.63	5 ft	39	REF		
42026	104.0 to 105.0 feet	Vertical Change	-.77	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231030	PARKRIDGE CT	COTTONWOOD DR	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
44802	112.8 to 113.8 feet	Vertical Change	-.54	5 ft	5	REF		
48099	121.7 to 122.7 feet	Vertical Change	-.4	5 ft	5	REF		
13981	128.3 to 134.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,540
41438	129.2 to 130.2 feet	Vertical Change	-1.2	5 ft	5	REF		
58752	130.4 to 157.7 feet	Driveway				REF		
43208	131.7 to 135.2 feet	Vertical Change	-.63	5 ft	18	REF		
13983	134.2 to 157.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	115	SF	\$40	\$4,580
43515	138.4 to 139.4 feet	Vertical Change	-.61	5 ft	5	REF		
42263	142.4 to 143.4 feet	Vertical Change	-.72	5 ft	5	REF		
42104	146.1 to 147.1 feet	Vertical Change	-.75	5 ft	5	REF		
42212	150.3 to 151.3 feet	Vertical Change	-.73	5 ft	5	REF		
42737	154.4 to 155.4 feet	Vertical Change	-.67	5 ft	5	REF		
13989	157.1 to 159.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	11	SF	\$40	\$440
41397	158.3 to 159.3 feet	Vertical Change	-1.28	5 ft	5	REF		
58753	164.8 to 202.8 feet	Driveway				REF		
13990	168.6 to 170.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	10	SF	\$40	\$400
41334	170.5 to 171.5 feet	Vertical Change	-1.44	5 ft	5	REF		
13991	174.6 to 200.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	131	SF	\$40	\$5,220
42027	179.2 to 180.2 feet	Vertical Change	-.77	5 ft	5	REF		
41923	191.5 to 192.5 feet	Vertical Change	-.8	5 ft	5	REF		
40384	200.4 to 201.4 feet	Running Slope	7.0-8.0%	5 ft	5	REF		
42856	203.2 to 207.9 feet	Vertical Change	-.66	5 ft	24	REF		
13994	204.7 to 210.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,600
58754	208.7 to 240.4 feet	Driveway				REF		
48660	209.3 to 213.1 feet	Vertical Change	-.38	5 ft	19	REF		
13995	215.0 to 216.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$220
41849	215.1 to 216.1 feet	Vertical Change	-.82	5 ft	5	REF		
13996	218.2 to 234.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	83	SF	\$40	\$3,320

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
W	1908231030	PARKRIDGE CT	COTTONWOOD DR	COTTONWOOD DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
42738	228.7 to 229.7 feet	Vertical Change	-.67	5 ft	5	REF			
14000	234.8 to 238.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	19	SF	\$40	\$760	
42339	239.9 to 240.9 feet	Vertical Change	-.71	5 ft	5	REF			
14003	241.3 to 267.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	130	SF	\$120	\$15,540	
41584	242.5 to 243.5 feet	Vertical Change	-1	5 ft	5	REF			
42857	255.4 to 256.4 feet	Vertical Change	-.66	5 ft	5	REF			
58755	260.4 to 304.8 feet	Driveway				REF			
42340	263.2 to 264.2 feet	Vertical Change	-.71	5 ft	5	REF			
46974	265.4 to 268.6 feet	Vertical Change	-.44	5 ft	16	REF			
14007	268.0 to 269.0 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200	
14008	269.0 to 272.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	18	SF	\$40	\$720	
44987	272.1 to 273.1 feet	Vertical Change	-.53	5 ft	5	REF			
14009	272.6 to 283.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	53	SF	\$40	\$2,140	
44004	276.5 to 277.5 feet	Vertical Change	-.58	5 ft	5	REF			
43516	280.8 to 281.8 feet	Vertical Change	-.61	5 ft	5	REF			
14012	283.3 to 302.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	96	SF	\$40	\$3,840	
45180	284.9 to 285.9 feet	Vertical Change	-.52	5 ft	5	REF			
43682	288.7 to 289.7 feet	Vertical Change	-.6	5 ft	5	REF			
44592	304.1 to 305.1 feet	Vertical Change	-.55	5 ft	5	REF			
14015	305.0 to 355.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	251	SF	\$40	\$10,020	
42964	316.7 to 317.7 feet	Vertical Change	-.65	5 ft	5	REF			
43084	327.5 to 328.5 feet	Vertical Change	-.64	5 ft	5	REF			
42739	337.0 to 338.0 feet	Vertical Change	-.67	5 ft	5	REF			
42858	345.6 to 346.6 feet	Vertical Change	-.66	5 ft	5	REF			
58756	347.9 to 373.4 feet	Driveway				REF			
41585	350.1 to 351.1 feet	Vertical Change	-1	5 ft	5	REF			
43836	351.8 to 355.0 feet	Vertical Change	-.59	5 ft	16	REF			
56988	354.7 to 355.7 feet	Vertical Change	.58	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231030	PARKRIDGE CT	COTTONWOOD DR	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14020	355.1 to 368.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	67	SF	\$40	\$2,680
42526	358.2 to 359.2 feet	Vertical Change	-.69	5 ft	5	REF		
42645	361.9 to 362.9 feet	Vertical Change	-.68	5 ft	5	REF		
41996	365.3 to 366.3 feet	Vertical Change	-.78	5 ft	5	REF		
42105	368.4 to 369.4 feet	Vertical Change	-.75	5 ft	5	REF		
14024	368.5 to 373.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	24	SF	\$40	\$960
14025	373.3 to 375.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	10	SF	\$40	\$400
42740	374.7 to 379.8 feet	Vertical Change	-.67	5 ft	26	REF		
14027	375.3 to 376.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$720
14028	376.5 to 400.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	121	SF	\$120	\$14,520
42965	382.1 to 383.1 feet	Vertical Change	-.65	5 ft	5	REF		
46759	391.3 to 392.3 feet	Vertical Change	-.45	5 ft	5	REF		
56624	391.3 to 392.3 feet	Vertical Change	.43	5 ft	5	REF		
50593	392.9 to 393.9 feet	Vertical Change	-.32	5 ft	5	REF		
58757	394.8 to 420.8 feet	Driveway				REF		
41455	396.4 to 397.4 feet	Vertical Change	-1.15	5 ft	5	REF		
42528	398.4 to 401.5 feet	Vertical Change	-.69	5 ft	16	REF		
14030	400.7 to 437.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	182	SF	\$40	\$7,280
43517	404.3 to 405.3 feet	Vertical Change	-.61	5 ft	5	REF		
42741	407.8 to 408.8 feet	Vertical Change	-.67	5 ft	5	REF		
42451	411.2 to 412.2 feet	Vertical Change	-.7	5 ft	5	REF		
42742	414.5 to 415.5 feet	Vertical Change	-.67	5 ft	5	REF		
42646	417.8 to 418.8 feet	Vertical Change	-.68	5 ft	5	REF		
42966	423.3 to 424.3 feet	Vertical Change	-.65	5 ft	5	REF		
41326	425.4 to 426.4 feet	Vertical Change	-1.48	5 ft	5	REF		
42647	428.0 to 431.8 feet	Vertical Change	-.68	5 ft	19	REF		
44005	435.7 to 436.7 feet	Vertical Change	-.58	5 ft	5	REF		
14038	437.1 to 444.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,260

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231030	PARKRIDGE CT	COTTONWOOD DR	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41876	438.9 to 439.9 feet	Vertical Change	-.81	5 ft	5	REF		
TOTAL COST FOR: W side of PARKRIDGE CT Starting at: COTTONWOOD DR							\$135,340.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1908231031	COTTONWOOD DR	PARKRIDGE CT	COTTONWOOD DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14039	4.4 to 7.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,740
41640	6.7 to 7.7 feet	Vertical Change	-.94	5 ft	5	REF		
14041	7.3 to 32.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	124	SF	\$120	\$14,820
42028	14.2 to 15.2 feet	Vertical Change	-.77	5 ft	5	REF		
42648	22.6 to 23.6 feet	Vertical Change	-.68	5 ft	5	REF		
46760	31.1 to 32.1 feet	Vertical Change	-.45	5 ft	5	REF		
14045	32.0 to 35.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,280
43354	40.7 to 41.7 feet	Vertical Change	-.62	5 ft	5	SF	\$75	\$375
42342	49.9 to 50.9 feet	Vertical Change	-.71	5 ft	5	REF		
14047	50.3 to 88.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	191	SF	\$120	\$22,860
42452	60.0 to 61.0 feet	Vertical Change	-.7	5 ft	5	REF		
41543	70.0 to 71.0 feet	Vertical Change	-1.04	5 ft	5	REF		
47704	73.7 to 74.7 feet	Vertical Change	-.41	5 ft	5	REF		
46975	79.4 to 80.4 feet	Vertical Change	-.44	5 ft	5	REF		
14049	88.4 to 103.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	74	SF	\$120	\$8,880
42529	88.8 to 89.8 feet	Vertical Change	-.69	5 ft	5	REF		
41232	99.3 to 100.3 feet	Vertical Change	-2.01	5 ft	5	REF		
56930	99.4 to 100.4 feet	Vertical Change	.52	5 ft	5	REF		
14053	103.2 to 105.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380
TOTAL COST FOR: W side of COTTONWOOD DR Starting at: PARKRIDGE CT							\$52,335.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1908231033	COTTONWOOD DR	COTTONWOOD DR	PARKRIDGE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46976	3.7 to 4.7 feet	Vertical Change	-.44	5 ft	5	LF	\$75	\$375
44006	12.4 to 13.4 feet	Vertical Change	-.58	5 ft	5	SF	\$75	\$375
46076	21.8 to 22.8 feet	Vertical Change	-.48	5 ft	5	LF	\$75	\$375
48382	31.0 to 32.0 feet	Vertical Change	-.39	5 ft	5	LF	\$75	\$375
46293	40.5 to 41.5 feet	Vertical Change	-.47	5 ft	5	LF	\$75	\$375
14054	42.8 to 46.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,920
45181	50.0 to 51.0 feet	Vertical Change	-.52	5 ft	5	SF	\$75	\$375
14055	57.7 to 67.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,120
43837	68.7 to 69.7 feet	Vertical Change	-.59	5 ft	5	SF	\$75	\$375
44593	78.5 to 79.5 feet	Vertical Change	-.55	5 ft	5	SF	\$75	\$375
14057	83.1 to 93.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,180
45182	88.1 to 89.1 feet	Vertical Change	-.52	5 ft	5	REF		
44168	96.2 to 97.2 feet	Vertical Change	-.57	5 ft	5	SF	\$75	\$375
TOTAL COST FOR: E							<i>side of COTTONWOOD DR Starting at: COTTONWOOD DR</i>	\$17,595.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1908231035	PARKRIDGE DR	COTTONWOOD DR	PINE ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
14058	0.0 to 7.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,680	
53285	4.9 to 5.9 feet	Vertical Change	-27	5 ft	5	REF			
14059	12.8 to 27.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	75	SF	\$120	\$8,940	
50219	13.6 to 14.6 feet	Vertical Change	-33	5 ft	5	REF			
48100	17.2 to 18.2 feet	Vertical Change	-4	5 ft	5	REF			
58758	25.1 to 55.5 feet	Driveway				REF			
48946	28.2 to 29.2 feet	Vertical Change	-37	5 ft	5	REF			
48383	32.9 to 36.3 feet	Vertical Change	-39	5 ft	17	REF			
44381	38.8 to 39.8 feet	Vertical Change	-56	5 ft	5	REF			
45370	44.2 to 45.2 feet	Vertical Change	-51	5 ft	5	REF			
44382	49.7 to 50.7 feet	Vertical Change	-56	5 ft	5	REF			
14060	51.7 to 55.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	20	SF	\$40	\$800	
57142	53.5 to 54.5 feet	Vertical Change	.63	5 ft	5	REF			
46077	55.6 to 56.6 feet	Vertical Change	-48	5 ft	5	REF			
43683	60.6 to 61.6 feet	Vertical Change	-6	5 ft	5	SF	\$75	\$375	
43355	69.4 to 70.4 feet	Vertical Change	-62	5 ft	5	SF	\$75	\$375	
44169	78.7 to 79.7 feet	Vertical Change	-57	5 ft	5	SF	\$75	\$375	
44803	87.8 to 88.8 feet	Vertical Change	-54	5 ft	5	SF	\$75	\$375	
14062	90.5 to 92.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020	
54126	91.0 to 92.0 feet	Vertical Change	-25	5 ft	5	REF			
58759	91.8 to 115.4 feet	Driveway				REF			
44988	93.9 to 94.9 feet	Vertical Change	-53	5 ft	5	REF			
14063	98.8 to 107.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	45	SF	\$40	\$1,800	
46294	99.9 to 100.9 feet	Vertical Change	-47	5 ft	5	REF			
48101	105.8 to 106.8 feet	Vertical Change	-4	5 ft	5	REF			
14066	107.8 to 110.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	12	SF	\$40	\$480	
14068	110.2 to 114.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	19	SF	\$40	\$760	
14070	116.4 to 117.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908231035	PARKRIDGE DR	COTTONWOOD DR	PINE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58760	119.8 to 144.5 feet	Driveway				REF		
52797	124.2 to 128.1 feet	Vertical Change	-0.28	5 ft	20	REF		
42343	133.0 to 134.0 feet	Vertical Change	-0.71	5 ft	5	REF		
14071	139.2 to 141.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	14	SF	\$40	\$540
42167	139.3 to 140.3 feet	Vertical Change	-0.74	5 ft	5	REF		
14073	141.9 to 144.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	14	SF	\$40	\$540
14075	144.6 to 147.2 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	13	SF	\$120	\$1,560
56958	144.7 to 145.7 feet	Vertical Change	.55	5 ft	5	REF		
14076	149.6 to 151.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320
14077	155.6 to 167.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	61	SF	\$120	\$7,320
43085	155.8 to 156.8 feet	Vertical Change	-0.64	5 ft	5	REF		
42859	163.7 to 164.7 feet	Vertical Change	-0.66	5 ft	5	REF		
42860	171.1 to 172.1 feet	Vertical Change	-0.66	5 ft	5	SF	\$75	\$375
44804	180.5 to 181.5 feet	Vertical Change	-0.54	5 ft	5	SF	\$75	\$375
14079	181.8 to 182.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
42106	188.5 to 189.5 feet	Vertical Change	-0.75	5 ft	5	SF	\$75	\$375
41967	196.8 to 197.8 feet	Vertical Change	-0.79	5 ft	5	SF	\$75	\$375
42344	207.2 to 208.2 feet	Vertical Change	-0.71	5 ft	5	SF	\$75	\$375
58761	210.2 to 245.3 feet	Driveway				REF		
42530	217.4 to 218.4 feet	Vertical Change	-0.69	5 ft	5	REF		
14080	218.3 to 223.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	28	SF	\$40	\$1,120
44383	223.0 to 224.0 feet	Vertical Change	-0.56	5 ft	5	REF		
41825	228.8 to 229.8 feet	Vertical Change	-0.83	5 ft	5	REF		
45371	234.1 to 235.1 feet	Vertical Change	-0.51	5 ft	5	REF		
42861	239.9 to 240.9 feet	Vertical Change	-0.66	5 ft	5	REF		
14083	241.3 to 250.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	44	SF	\$40	\$1,740
43356	245.9 to 246.9 feet	Vertical Change	-0.62	5 ft	5	REF		
42967	252.4 to 253.4 feet	Vertical Change	-0.65	5 ft	5	SF	\$75	\$375

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1908231035	PARKRIDGE DR	COTTONWOOD DR	PINE ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58762	254.2 to 286.3 feet	Driveway				REF		
44594	262.6 to 264.1 feet	Vertical Change	-55	5 ft	8	REF		
14086	262.8 to 283.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	105	SF	\$40	\$4,180
42531	267.7 to 268.7 feet	Vertical Change	-.69	5 ft	5	REF		
42264	272.2 to 273.2 feet	Vertical Change	-.72	5 ft	5	REF		
41381	276.8 to 277.8 feet	Vertical Change	-1.33	5 ft	5	REF		
42532	282.5 to 285.8 feet	Vertical Change	-.69	5 ft	17	REF		
14089	283.7 to 287.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	20	SF	\$40	\$800
57125	284.9 to 285.9 feet	Vertical Change	.6	5 ft	5	REF		
14091	287.7 to 292.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,640
43086	288.6 to 289.6 feet	Vertical Change	-.64	5 ft	5	REF		
48102	296.0 to 297.0 feet	Vertical Change	-.4	5 ft	5	LF	\$75	\$375
48948	306.1 to 307.1 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375
14092	314.3 to 327.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,800
53286	316.2 to 317.2 feet	Vertical Change	-.27	5 ft	5	REF		
50220	326.2 to 327.2 feet	Vertical Change	-.33	5 ft	5	REF		
14094	327.3 to 346.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	97	SF	\$120	\$11,640
48949	335.7 to 336.7 feet	Vertical Change	-.37	5 ft	5	REF		
14100	346.7 to 434.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	440	SF	\$120	\$52,800
54127	355.6 to 356.6 feet	Vertical Change	-.25	5 ft	5	REF		
41814	414.2 to 415.2 feet	Vertical Change	-.84	5 ft	5	REF		
45868	417.6 to 418.6 feet	Vertical Change	-.49	5 ft	5	REF		
45372	422.6 to 423.6 feet	Vertical Change	-.51	5 ft	5	REF		
41351	427.8 to 428.8 feet	Vertical Change	-1.4	5 ft	5	REF		
43209	432.9 to 433.9 feet	Vertical Change	-.63	5 ft	5	REF		
TOTAL COST FOR: SE							side of PARKRIDGE DR Starting at: COTTONWOOD DR	\$118,360.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1908231037	PARKRIDGE DR	PINE ST	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
44384	1.3 to 2.3 feet	Vertical Change	-.56	5 ft	5	REF			
14109	2.3 to 9.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020	
49880	6.3 to 7.3 feet	Vertical Change	-.34	5 ft	5	REF			
14111	9.0 to 20.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	56	SF	\$120	\$6,720	
45869	12.1 to 18.1 feet	Vertical Change	-.49	5 ft	30	REF			
14115	20.2 to 44.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	123	SF	\$120	\$14,700	
44595	20.6 to 21.6 feet	Vertical Change	-.55	5 ft	5	REF			
58763	23.1 to 50.8 feet	Driveway				REF			
49559	24.6 to 28.0 feet	Vertical Change	-.35	5 ft	17	REF			
42743	29.5 to 30.5 feet	Vertical Change	-.67	5 ft	5	REF			
43210	33.2 to 34.2 feet	Vertical Change	-.63	5 ft	5	REF			
44989	36.5 to 37.5 feet	Vertical Change	-.53	5 ft	5	REF			
42345	39.6 to 40.6 feet	Vertical Change	-.71	5 ft	5	REF			
43838	42.9 to 43.9 feet	Vertical Change	-.59	5 ft	5	REF			
14121	44.7 to 51.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	36	SF	\$40	\$1,420	
43087	46.4 to 47.4 feet	Vertical Change	-.64	5 ft	5	REF			
45668	50.0 to 55.5 feet	Vertical Change	-.5	5 ft	28	REF			
14123	51.8 to 77.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	127	SF	\$120	\$15,240	
43088	65.2 to 66.2 feet	Vertical Change	-.64	5 ft	5	REF			
58764	66.2 to 106.0 feet	Driveway				REF			
41416	70.2 to 71.2 feet	Vertical Change	-1.24	5 ft	5	REF			
42744	72.3 to 76.2 feet	Vertical Change	-.67	5 ft	20	REF			
14127	77.2 to 82.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	25	SF	\$40	\$1,000	
42533	79.3 to 80.3 feet	Vertical Change	-.69	5 ft	5	REF			
14129	82.2 to 91.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	49	SF	\$40	\$1,940	
42863	83.1 to 84.1 feet	Vertical Change	-.66	5 ft	5	REF			
45870	86.7 to 87.7 feet	Vertical Change	-.49	5 ft	5	REF			
42745	90.4 to 91.4 feet	Vertical Change	-.67	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908231037	PARKRIDGE DR	PINE ST	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
42649	94.4 to 95.4 feet	Vertical Change	-.68	5 ft	5	REF		
41997	98.0 to 99.0 feet	Vertical Change	-.78	5 ft	5	REF		
14130	102.0 to 105.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	16	SF	\$40	\$640
42534	102.1 to 103.1 feet	Vertical Change	-.69	5 ft	5	REF		
14132	105.2 to 110.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	26	SF	\$40	\$1,020
42746	105.4 to 109.5 feet	Vertical Change	-.67	5 ft	21	REF		
14134	110.3 to 118.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800
41474	110.5 to 111.5 feet	Vertical Change	-1.13	5 ft	5	REF		
43518	118.0 to 119.0 feet	Vertical Change	-.61	5 ft	5	REF		
43211	127.7 to 128.7 feet	Vertical Change	-.63	5 ft	5	SF	\$75	\$375
58765	129.1 to 159.3 feet	Driveway				REF		
14135	129.6 to 138.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	45	SF	\$40	\$1,780
53287	130.5 to 131.5 feet	Vertical Change	-.27	5 ft	5	REF		
42968	132.5 to 138.1 feet	Vertical Change	-.65	5 ft	28	REF		
14137	139.3 to 140.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	7	SF	\$40	\$280
14138	140.7 to 142.4 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	9	SF	\$40	\$340
14139	142.4 to 144.0 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	8	SF	\$40	\$320
14140	144.0 to 149.7 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	28	SF	\$40	\$1,140
42265	147.4 to 148.4 feet	Vertical Change	-.72	5 ft	5	REF		
14142	149.7 to 155.2 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	28	SF	\$40	\$1,100
44990	157.5 to 160.4 feet	Vertical Change	-.53	5 ft	15	REF		
41504	161.5 to 162.5 feet	Vertical Change	-1.09	5 ft	5	SF	\$75	\$375
44806	169.1 to 170.1 feet	Vertical Change	-.54	5 ft	5	SF	\$75	\$375
14144	177.1 to 180.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160
44170	179.1 to 180.1 feet	Vertical Change	-.57	5 ft	5	REF		
53288	187.1 to 188.1 feet	Vertical Change	-.27	5 ft	5	LF	\$75	\$375
44991	189.0 to 190.0 feet	Vertical Change	-.53	5 ft	5	REF		
14145	189.5 to 199.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,120

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908231037	PARKRIDGE DR	PINE ST	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
46763	199.0 to 200.0 feet	Vertical Change	-.45	5 ft	5	REF		
48950	208.8 to 209.8 feet	Vertical Change	-.37	5 ft	5	LF	\$75	\$375
14146	212.2 to 218.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,840
58766	212.2 to 240.3 feet	Driveway				REF		
44807	214.6 to 219.6 feet	Vertical Change	-.54	5 ft	25	REF		
14147	220.2 to 221.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$220
14148	221.3 to 223.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	9	SF	\$40	\$340
14149	223.0 to 226.9 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	20	SF	\$40	\$780
44007	225.4 to 226.4 feet	Vertical Change	-.58	5 ft	5	REF		
14151	226.9 to 229.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	15	SF	\$40	\$580
44008	228.8 to 229.8 feet	Vertical Change	-.58	5 ft	5	REF		
14152	229.8 to 235.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	29	SF	\$40	\$1,160
45871	232.1 to 233.1 feet	Vertical Change	-.49	5 ft	5	REF		
14154	235.6 to 239.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	20	SF	\$40	\$780
44992	235.7 to 236.7 feet	Vertical Change	-.53	5 ft	5	REF		
42266	239.2 to 240.2 feet	Vertical Change	-.72	5 ft	5	REF		
14156	239.5 to 240.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$260
47200	241.0 to 243.8 feet	Vertical Change	-.43	5 ft	14	LF	\$75	\$1,050
14157	245.3 to 251.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,540
44385	246.1 to 247.1 feet	Vertical Change	-.56	5 ft	5	REF		
43359	253.0 to 254.0 feet	Vertical Change	-.62	5 ft	5	SF	\$75	\$375
58767	255.8 to 294.3 feet	Driveway				REF		
49560	258.8 to 263.8 feet	Vertical Change	-.35	5 ft	25	REF		
14158	264.3 to 269.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	27	SF	\$40	\$1,080
44596	266.8 to 267.8 feet	Vertical Change	-.55	5 ft	5	REF		
47449	270.7 to 271.7 feet	Vertical Change	-.42	5 ft	5	REF		
46977	274.6 to 275.6 feet	Vertical Change	-.44	5 ft	5	REF		
43840	278.5 to 279.5 feet	Vertical Change	-.59	5 ft	5	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1908231037	PARKRIDGE DR	PINE ST	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
45872	281.7 to 282.7 feet	Vertical Change	-49	5 ft	5	REF		
44386	285.9 to 286.9 feet	Vertical Change	-56	5 ft	5	REF		
45374	290.2 to 291.2 feet	Vertical Change	-51	5 ft	5	REF		
14159	290.6 to 295.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	24	SF	\$40	\$960
48661	293.6 to 299.7 feet	Vertical Change	-38	5 ft	30	REF		
42535	306.5 to 307.5 feet	Vertical Change	-69	5 ft	5	SF	\$75	\$375
50594	316.1 to 317.1 feet	Vertical Change	-32	5 ft	5	LF	\$75	\$375
58768	336.3 to 365.1 feet	Driveway				REF		
50998	341.0 to 342.0 feet	Vertical Change	-31	5 ft	5	REF		
14162	348.5 to 363.2 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	74	SF	\$40	\$2,940
50221	364.9 to 368.5 feet	Vertical Change	-33	5 ft	18	REF		
48385	379.7 to 380.7 feet	Vertical Change	-39	5 ft	5	LF	\$75	\$375
58769	380.4 to 409.0 feet	Driveway				REF		
41485	385.3 to 386.3 feet	Vertical Change	-1.12	5 ft	5	REF		
44597	387.2 to 390.2 feet	Vertical Change	-55	5 ft	15	REF		
14165	388.8 to 394.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	30	SF	\$40	\$1,180
43842	392.7 to 393.7 feet	Vertical Change	-59	5 ft	5	REF		
44171	396.2 to 397.2 feet	Vertical Change	-57	5 ft	5	REF		
43360	399.4 to 400.4 feet	Vertical Change	-62	5 ft	5	REF		
43089	402.5 to 403.5 feet	Vertical Change	-64	5 ft	5	REF		
14167	403.2 to 406.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	15	SF	\$40	\$600
44172	406.0 to 407.0 feet	Vertical Change	-57	5 ft	5	REF		
14169	406.2 to 432.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	133	SF	\$40	\$5,320
44993	409.7 to 415.5 feet	Vertical Change	-53	5 ft	29	REF		
45670	420.1 to 421.1 feet	Vertical Change	-5	5 ft	5	REF		
48951	428.8 to 429.8 feet	Vertical Change	-37	5 ft	5	REF		
14175	432.8 to 434.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
44387	433.0 to 434.0 feet	Vertical Change	-56	5 ft	5	REF		

TOTAL COST FOR: S side of PARKRIDGE DR Starting at: PINE ST \$93,585.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1909231244	LINCOLN AVE	PALM PKY	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
16414	0.0 to 2.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,380	
16415	12.8 to 19.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,720	
54338	20.2 to 21.2 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
16417	23.7 to 25.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020	
16418	29.0 to 32.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,280	
58893	29.8 to 52.3 feet	Driveway				REF			
56037	30.6 to 31.6 feet	Vertical Change	.4	5 ft	5	REF			
16420	32.8 to 33.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	6	SF	\$40	\$220	
16421	35.1 to 43.4 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	42	SF	\$40	\$1,660	
56038	40.7 to 41.7 feet	Vertical Change	.4	5 ft	5	REF			
16423	44.6 to 49.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	26	SF	\$40	\$1,020	
16425	52.8 to 55.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560	
54339	56.9 to 57.9 feet	Vertical Change	.3	5 ft	5	REF			
16427	57.8 to 88.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	154	SF	\$120	\$18,480	
54340	77.8 to 78.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
58894	87.3 to 109.9 feet	Driveway				REF			
16430	91.6 to 107.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	78	SF	\$40	\$3,100	
16434	110.8 to 112.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780	
16435	117.3 to 119.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260	
58895	118.2 to 140.8 feet	Driveway				REF			
16436	122.8 to 137.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	74	SF	\$40	\$2,980	
16442	140.5 to 141.6 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$220	
16443	141.6 to 160.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	93	SF	\$120	\$11,160	
16445	162.3 to 165.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160	
54341	168.0 to 169.0 feet	Vertical Change	.3	5 ft	5	REF			
16446	168.1 to 188.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	100	SF	\$120	\$12,000	
16449	188.3 to 194.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	29	SF	\$120	\$3,420	
16451	194.3 to 198.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340	
58896	196.4 to 218.8 feet	Driveway				REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909231244	LINCOLN AVE	PALM PKY	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40444	198.7 to 200.4 feet	Running Slope	5.0-6.0%	5 ft	9	REF		
16453	201.3 to 216.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	77	SF	\$40	\$3,060
16458	218.6 to 221.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	14	SF	\$40	\$560
16459	222.5 to 229.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,080
59	223.8 to 224.8 feet	Continuous Width		5 ft	5	SF	\$120	\$600
58897	228.0 to 249.5 feet	Driveway				REF		
16461	231.1 to 232.1 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	5	SF	\$40	\$200
16462	233.5 to 244.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	57	SF	\$40	\$2,260
16465	246.1 to 247.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200
54342	248.5 to 249.5 feet	Vertical Change	.3	5 ft	5	REF		
16466	249.9 to 287.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	190	SF	\$40	\$7,580
54343	284.3 to 285.3 feet	Vertical Change	.3	5 ft	5	REF		
16475	288.2 to 302.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	71	SF	\$120	\$8,460
58898	300.0 to 322.0 feet	Driveway				REF		
16478	304.1 to 305.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200
16479	305.6 to 319.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	68	SF	\$40	\$2,740
16485	323.7 to 327.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,220
TOTAL COST FOR: E side of LINCOLN AVE Starting at: PALM PKY							\$103,670.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1909231251	LINCOLN AVE	SIDEWALK BEGINS	PALM PKY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
16341	3.3 to 6.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620	
54335	5.4 to 6.4 feet	Vertical Change	.3	5 ft	5	REF			
58887	5.5 to 28.0 feet	Driveway				REF			
40440	6.7 to 8.8 feet	Running Slope	6.0-7.0%	5 ft	11	REF			
16342	9.9 to 15.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	26	SF	\$40	\$1,020	
16344	15.0 to 23.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	44	SF	\$40	\$1,760	
54336	15.4 to 16.4 feet	Vertical Change	.3	5 ft	5	REF			
40441	24.5 to 26.1 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
16346	27.9 to 38.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	54	SF	\$40	\$2,180	
16348	38.8 to 52.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	71	SF	\$120	\$8,460	
16352	53.9 to 67.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	67	SF	\$120	\$8,040	
54337	64.6 to 65.6 feet	Vertical Change	.3	5 ft	5	REF			
58888	64.8 to 89.8 feet	Driveway				REF			
16354	72.3 to 86.2 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	70	SF	\$40	\$2,780	
16360	90.0 to 104.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	73	SF	\$40	\$2,920	
58	100.1 to 101.1 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
16365	104.6 to 112.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,920	
16369	113.8 to 120.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	32	SF	\$120	\$3,780	
16372	121.8 to 138.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,260	
58889	136.0 to 161.4 feet	Driveway				REF			
16375	142.1 to 149.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	37	SF	\$40	\$1,460	
16377	152.4 to 157.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	26	SF	\$40	\$1,060	
16378	162.1 to 169.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,620	
58890	169.0 to 192.2 feet	Driveway				REF			
16383	170.7 to 171.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200	
16384	174.1 to 177.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	18	SF	\$40	\$720	
16386	177.7 to 190.0 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	62	SF	\$40	\$2,460	
16388	193.4 to 241.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	241	SF	\$120	\$28,920	
58891	240.5 to 263.7 feet	Driveway				REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909231251	LINCOLN AVE	SIDEWALK BEGINS	PALM PKY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40442	243.3 to 244.7 feet	Running Slope	5.0-6.0%	5 ft	7	REF		
16398	245.6 to 260.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	73	SF	\$40	\$2,900
16402	263.8 to 264.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200
16403	264.8 to 273.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$4,980
58892	272.0 to 295.5 feet	Driveway				REF		
40443	274.1 to 276.4 feet	Running Slope	5.0-6.0%	5 ft	11	REF		
16404	276.5 to 278.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	11	SF	\$40	\$420
16405	281.8 to 286.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	24	SF	\$40	\$940
16407	288.7 to 291.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	14	SF	\$40	\$560
16408	295.6 to 307.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	58	SF	\$40	\$2,320
16410	309.3 to 311.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140
16411	316.5 to 326.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,060
TOTAL COST FOR: W							<i>side of LINCOLN AVE Starting at: SIDEWALK BEGINS</i>	\$107,300.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
N	1909231301	PALM PKY	LINCOLN AVE	ROBERTSON BLVD				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
16197	0.0 to 14.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	72	SF	\$120	\$8,640
16202	14.4 to 15.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	5	SF	\$120	\$600
16203	16.7 to 17.9 feet	Cross Slope (PAR)	7.0-8.0%	5 ft	6	SF	\$120	\$720
16204	20.6 to 32.6 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	60	SF	\$120	\$7,200
16207	32.6 to 35.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	13	SF	\$120	\$1,620
57452	35.0 to 36.0 feet	Vertical Change	1.4	5 ft	5	REF		
16209	35.3 to 36.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$840
16210	36.7 to 68.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	158	SF	\$120	\$18,960
16212	70.8 to 88.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	88	SF	\$120	\$10,500
54328	74.8 to 75.8 feet	Vertical Change	.3	5 ft	5	REF		
56033	84.9 to 85.9 feet	Vertical Change	.4	5 ft	5	REF		
16216	91.1 to 106.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	77	SF	\$120	\$9,180
54329	95.6 to 96.6 feet	Vertical Change	.3	5 ft	5	REF		
57408	106.0 to 107.0 feet	Vertical Change	1.2	5 ft	5	REF		
40437	106.6 to 108.1 feet	Running Slope	5.0-6.0%	5 ft	8	SF	\$120	\$900
16221	108.3 to 112.7 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	22	SF	\$120	\$2,640
16222	114.8 to 118.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	17	SF	\$120	\$2,040
16224	118.2 to 119.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,020
16225	120.3 to 166.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	229	SF	\$120	\$27,480
54330	126.7 to 127.7 feet	Vertical Change	.3	5 ft	5	REF		
54331	147.5 to 148.5 feet	Vertical Change	.3	5 ft	5	REF		
54332	158.0 to 159.0 feet	Vertical Change	.3	5 ft	5	REF		
56034	163.8 to 164.8 feet	Vertical Change	.4	5 ft	5	REF		
58885	167.1 to 200.6 feet	Driveway				REF		
16235	167.6 to 168.9 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	7	SF	\$40	\$260
16236	169.8 to 172.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	13	SF	\$40	\$500
16238	172.3 to 175.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	15	SF	\$40	\$600
16240	175.3 to 180.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	25	SF	\$40	\$980

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1909231301	PALM PKY	LINCOLN AVE	ROBERTSON BLVD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
16242	182.4 to 188.0 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	28	SF	\$40	\$1,120	
16244	189.3 to 198.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	45	SF	\$40	\$1,800	
16248	201.5 to 205.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	20	SF	\$120	\$2,340	
54333	204.6 to 205.6 feet	Vertical Change	.3	5 ft	5	REF			
16250	205.4 to 233.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	138	SF	\$120	\$16,560	
56035	231.2 to 232.2 feet	Vertical Change	.4	5 ft	5	REF			
16258	248.2 to 301.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	265	SF	\$120	\$31,740	
54334	252.2 to 253.2 feet	Vertical Change	.3	5 ft	5	REF			
16272	302.0 to 325.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	117	SF	\$120	\$14,040	
16274	325.9 to 332.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,840	
16276	332.8 to 365.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	162	SF	\$120	\$19,440	
16283	365.5 to 389.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	118	SF	\$120	\$14,100	
16286	392.3 to 407.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	76	SF	\$120	\$9,120	
16289	408.0 to 427.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	97	SF	\$120	\$11,580	
58886	423.3 to 470.3 feet	Driveway				REF			
40438	428.8 to 430.4 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
16293	429.3 to 434.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	25	SF	\$40	\$1,000	
16296	436.8 to 439.8 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	15	SF	\$40	\$600	
16298	441.9 to 444.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	15	SF	\$40	\$600	
16300	445.1 to 458.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	69	SF	\$40	\$2,760	
16304	458.9 to 465.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	33	SF	\$40	\$1,320	
40439	467.1 to 468.1 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
16307	469.8 to 483.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	68	SF	\$40	\$2,700	
16312	486.0 to 520.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	173	SF	\$120	\$20,760	
57544	492.0 to 493.0 feet	Vertical Change	2.2	5 ft	5	REF			
16320	521.0 to 530.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,640	
16323	530.8 to 540.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	47	SF	\$120	\$5,580	
16327	540.1 to 550.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$6,000	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909231301	PALM PKY	LINCOLN AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
16330	554.3 to 574.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	101	SF	\$120	\$12,060
56036	573.0 to 574.0 feet	Vertical Change	.4	5 ft	5	REF		
16335	574.4 to 605.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	154	SF	\$120	\$18,540
16340	605.3 to 606.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	6	SF	\$120	\$720
TOTAL COST FOR: N side of PALM PKY Starting at: LINCOLN AVE							\$298,640.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909231309	PALM PKY	ROBERTSON BLVD	KENNEDY CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
16108	0.0 to 3.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	18	SF	\$120	\$2,100
16109	3.5 to 7.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,640
16110	10.6 to 11.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$720
16111	15.0 to 19.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	22	SF	\$120	\$2,580
54323	16.3 to 17.3 feet	Vertical Change	.3	5 ft	5	REF		
16112	20.0 to 24.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,940
16113	30.8 to 35.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,880
16114	39.4 to 117.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	390	SF	\$120	\$46,740
16125	121.7 to 146.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	125	SF	\$120	\$15,000
54324	140.2 to 141.2 feet	Vertical Change	.3	5 ft	5	REF		
16127	150.4 to 153.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	15	SF	\$120	\$1,800
16128	153.4 to 178.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	128	SF	\$120	\$15,300
16134	181.3 to 209.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	140	SF	\$120	\$16,800
54325	202.4 to 203.4 feet	Vertical Change	.3	5 ft	5	REF		
16141	212.9 to 222.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,520
16143	224.3 to 227.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620
16144	230.8 to 237.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,960
16145	240.7 to 341.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	504	SF	\$120	\$60,480
54326	244.8 to 245.8 feet	Vertical Change	.3	5 ft	5	REF		
16164	342.3 to 351.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	45	SF	\$120	\$5,400
16166	356.3 to 371.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	78	SF	\$120	\$9,300
57431	361.3 to 362.3 feet	Vertical Change	1.3	5 ft	5	REF		
16169	372.2 to 447.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	377	SF	\$120	\$45,180
16188	448.6 to 487.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	196	SF	\$120	\$23,520
16193	490.8 to 500.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	48	SF	\$120	\$5,700
16195	500.6 to 515.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	75	SF	\$120	\$8,940
54327	508.8 to 509.8 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: S							side of PALM PKY Starting at: ROBERTSON BLVD	\$279,120.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
W	1909231315	KENNEDY CT	PALM PKY	2127 KENNEDY CT	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
16019	2.2 to 24.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	111	SF	\$120	\$13,380	
54308	4.6 to 8.6 feet	Vertical Change	.3	5 ft	20	REF			
58878	21.9 to 50.0 feet	Driveway				REF			
16024	27.7 to 35.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	41	SF	\$40	\$1,640	
54310	35.6 to 36.6 feet	Vertical Change	.3	5 ft	5	REF			
16026	35.9 to 45.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	49	SF	\$40	\$1,940	
16028	48.7 to 49.7 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200	
16029	49.7 to 59.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	47	SF	\$40	\$1,860	
57381	58.0 to 59.0 feet	Vertical Change	1.1	5 ft	5	REF			
16032	59.0 to 61.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	11	SF	\$120	\$1,260	
16034	61.1 to 73.5 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	62	SF	\$120	\$7,440	
56031	67.3 to 68.3 feet	Vertical Change	.4	5 ft	5	REF			
16035	73.5 to 79.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	32	SF	\$120	\$3,780	
54311	76.8 to 77.8 feet	Vertical Change	.3	5 ft	5	REF			
58879	76.8 to 104.0 feet	Driveway				REF			
16037	82.0 to 86.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	24	SF	\$40	\$940	
16039	86.7 to 101.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	72	SF	\$40	\$2,860	
54312	103.3 to 104.3 feet	Vertical Change	.3	5 ft	5	REF			
16044	104.5 to 106.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	9	SF	\$40	\$340	
16045	107.2 to 115.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800	
58880	113.2 to 142.8 feet	Driveway				REF			
16047	118.7 to 138.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	98	SF	\$40	\$3,920	
16051	141.7 to 191.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	248	SF	\$40	\$9,920	
56032	150.4 to 151.4 feet	Vertical Change	.4	5 ft	5	REF			
54313	159.2 to 160.2 feet	Vertical Change	.3	5 ft	5	REF			
58881	189.2 to 218.1 feet	Driveway				REF			
54314	189.7 to 190.7 feet	Vertical Change	.3	5 ft	5	REF			
16062	191.5 to 192.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	5	SF	\$40	\$200	
40435	192.3 to 193.8 feet	Running Slope	5.0-6.0%	5 ft	8	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909231315	KENNEDY CT	PALM PKY	2127 KENNEDY CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
16063	194.8 to 214.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	98	SF	\$40	\$3,920
54315	212.9 to 213.9 feet	Vertical Change	.3	5 ft	5	REF		
54316	216.5 to 217.5 feet	Vertical Change	.3	5 ft	5	REF		
16071	217.3 to 226.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	44	SF	\$40	\$1,760
58882	226.5 to 254.9 feet	Driveway				REF		
16073	232.3 to 251.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	95	SF	\$40	\$3,800
54317	241.1 to 242.1 feet	Vertical Change	.3	5 ft	5	REF		
54318	253.9 to 254.9 feet	Vertical Change	.3	5 ft	5	REF		
16078	254.7 to 255.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$220
16079	255.8 to 266.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,660
16081	269.6 to 288.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	95	SF	\$120	\$11,460
57000	284.8 to 285.8 feet	Vertical Change	.6	5 ft	5	REF		
16085	288.7 to 294.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,360
54319	294.0 to 295.0 feet	Vertical Change	.3	5 ft	5	REF		
58883	294.4 to 322.1 feet	Driveway				REF		
16088	295.1 to 296.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$220
16089	299.3 to 318.0 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	94	SF	\$40	\$3,740
54320	317.5 to 318.5 feet	Vertical Change	.3	5 ft	5	REF		
40436	318.9 to 320.3 feet	Running Slope	5.0-6.0%	5 ft	7	REF		
54321	320.8 to 321.8 feet	Vertical Change	.3	5 ft	5	REF		
16096	321.7 to 325.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	18	SF	\$40	\$720
16097	325.3 to 331.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,480
58884	328.8 to 357.8 feet	Driveway				REF		
16099	333.9 to 339.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	29	SF	\$40	\$1,140
16103	339.6 to 354.4 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	74	SF	\$40	\$2,960
54322	342.7 to 343.7 feet	Vertical Change	.3	5 ft	5	REF		
16106	356.6 to 357.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$240
16107	357.8 to 359.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$300

TOTAL COST FOR: W side of KENNEDY CT Starting at: PALM PKY \$98,460.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1909231321	KENNEDY CT	2127 KENNEDY CT	PALM PKY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
15937	0.0 to 6.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	34	SF	\$120	\$4,080	
58872	3.8 to 31.6 feet	Driveway				REF			
40432	7.2 to 8.3 feet	Running Slope	6.0-7.0%	5 ft	6	REF			
15939	10.4 to 18.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	40	SF	\$40	\$1,580	
15942	18.6 to 28.0 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	47	SF	\$40	\$1,880	
15945	32.1 to 55.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	116	SF	\$40	\$4,620	
58873	53.7 to 81.1 feet	Driveway				REF			
40433	55.9 to 57.7 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
15953	58.8 to 77.0 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	91	SF	\$40	\$3,640	
15957	82.1 to 92.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	51	SF	\$120	\$6,120	
58874	90.0 to 118.7 feet	Driveway				REF			
15961	96.3 to 100.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	22	SF	\$40	\$880	
15963	100.7 to 115.0 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	72	SF	\$40	\$2,860	
54304	104.5 to 105.5 feet	Vertical Change	.3	5 ft	5	REF			
15965	118.6 to 171.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	262	SF	\$40	\$10,480	
58875	168.9 to 196.6 feet	Driveway				REF			
40434	171.9 to 174.0 feet	Running Slope	5.0-6.0%	5 ft	11	REF			
15973	174.4 to 180.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	31	SF	\$40	\$1,220	
15975	180.9 to 185.7 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	24	SF	\$40	\$960	
15977	185.7 to 192.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	36	SF	\$40	\$1,420	
15979	192.8 to 193.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200	
15980	196.8 to 205.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	45	SF	\$40	\$1,800	
15981	205.8 to 208.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500	
58876	205.8 to 234.3 feet	Driveway				REF			
15983	210.6 to 212.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	11	SF	\$40	\$440	
15985	212.8 to 228.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	78	SF	\$40	\$3,100	
15990	228.3 to 230.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	10	SF	\$40	\$400	
15991	232.4 to 236.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	19	SF	\$40	\$740	
54305	233.1 to 234.1 feet	Vertical Change	.3	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
E	1909231321	KENNEDY CT	2127 KENNEDY CT	PALM PKY	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
15993	238.8 to 264.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	129	SF	\$120	\$15,420			
58877	262.2 to 290.9 feet	Driveway				REF					
16002	268.0 to 286.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	93	SF	\$40	\$3,720			
16009	286.6 to 287.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$220			
54306	289.8 to 290.8 feet	Vertical Change	.3	5 ft	5	REF					
16010	290.3 to 303.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	64	SF	\$40	\$2,540			
54307	302.7 to 303.7 feet	Vertical Change	.3	5 ft	5	REF					
16012	303.2 to 305.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	13	SF	\$120	\$1,560			
16013	309.4 to 312.6 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	16	SF	\$120	\$1,920			
16014	314.1 to 315.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	6	SF	\$120	\$720			
56030	314.8 to 315.8 feet	Vertical Change	.4	5 ft	5	REF					
16015	315.3 to 318.3 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	15	SF	\$120	\$1,800			
16017	318.3 to 319.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	5	SF	\$120	\$600			
16018	320.2 to 321.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$960			
TOTAL COST FOR: E							<i>side of</i>	KENNEDY CT	<i>Starting at:</i>	2127 KENNEDY CT	\$77,380.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909231324	PALM PKY	KENNEDY CT	LINCOLN AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
15919	0.0 to 15.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	79	SF	\$120	\$9,480
15923	15.8 to 56.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	201	SF	\$120	\$24,120
54303	30.0 to 31.0 feet	Vertical Change	.3	5 ft	5	REF		
15931	58.5 to 65.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	34	SF	\$120	\$4,020
15934	65.2 to 72.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,560
TOTAL COST FOR: S							side of PALM PKY Starting at: KENNEDY CT	\$42,180.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1909231333	LINCOLN AVE	PALM PKY	2140 LINCOLN AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
15795	0.0 to 5.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,180	
54286	3.8 to 4.8 feet	Vertical Change	.3	5 ft	5	REF			
15797	5.7 to 10.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	26	SF	\$120	\$3,060	
15799	12.4 to 23.5 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	56	SF	\$120	\$6,660	
57249	14.6 to 15.6 feet	Vertical Change	.8	5 ft	5	REF			
54287	20.3 to 21.3 feet	Vertical Change	.3	5 ft	5	REF			
15802	24.2 to 61.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	186	SF	\$120	\$22,260	
54288	25.5 to 26.5 feet	Vertical Change	.3	5 ft	5	REF			
54289	32.8 to 33.8 feet	Vertical Change	.3	5 ft	5	REF			
56026	37.0 to 38.0 feet	Vertical Change	.4	5 ft	5	REF			
54290	45.1 to 46.1 feet	Vertical Change	.3	5 ft	5	REF			
54291	51.5 to 52.5 feet	Vertical Change	.3	5 ft	5	REF			
54292	55.0 to 56.0 feet	Vertical Change	.3	5 ft	5	REF			
56027	59.5 to 62.9 feet	Vertical Change	.4	5 ft	17	REF			
15814	61.8 to 63.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900	
15815	65.6 to 66.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$780	
15816	67.8 to 82.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,760	
15820	88.3 to 96.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,100	
15821	101.8 to 167.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	328	SF	\$120	\$39,360	
56997	113.7 to 114.7 feet	Vertical Change	.6	5 ft	5	REF			
56661	133.7 to 134.7 feet	Vertical Change	.5	5 ft	5	REF			
15835	171.1 to 188.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,260	
15837	188.2 to 218.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	153	SF	\$120	\$18,360	
56662	190.4 to 191.4 feet	Vertical Change	.5	5 ft	5	REF			
56028	195.1 to 196.1 feet	Vertical Change	.4	5 ft	5	REF			
15843	219.3 to 274.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	278	SF	\$120	\$33,360	
54294	225.6 to 226.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
56029	256.6 to 259.8 feet	Vertical Change	.4	5 ft	16	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909231333	LINCOLN AVE	PALM PKY	2140 LINCOLN AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54295	262.9 to 263.9 feet	Vertical Change	.3	5 ft	5	REF		
15853	285.7 to 347.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	311	SF	\$120	\$37,260
54296	287.6 to 288.6 feet	Vertical Change	.3	5 ft	5	REF		
57407	312.3 to 313.3 feet	Vertical Change	1.2	5 ft	5	REF		
54297	328.6 to 329.6 feet	Vertical Change	.3	5 ft	5	REF		
57494	334.5 to 335.5 feet	Vertical Change	1.7	5 ft	5	REF		
15863	352.0 to 361.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,400
15866	364.4 to 367.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040
15868	378.0 to 403.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	126	SF	\$120	\$15,060
15873	406.5 to 433.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	136	SF	\$120	\$16,320
40429	413.2 to 414.6 feet	Running Slope	8.0-9.0%	5 ft	7	REF		
56999	415.7 to 416.7 feet	Vertical Change	.6	5 ft	5	REF		
40430	418.4 to 419.9 feet	Running Slope	9.0-10.0%	5 ft	8	REF		
58869	436.2 to 458.9 feet	Driveway				REF		
15883	441.4 to 450.1 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	44	SF	\$40	\$1,740
54298	447.0 to 448.0 feet	Vertical Change	.3	5 ft	5	REF		
15885	450.5 to 451.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$220
15886	451.6 to 456.4 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	24	SF	\$40	\$960
15888	456.4 to 457.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$220
54299	457.3 to 458.3 feet	Vertical Change	.3	5 ft	5	REF		
15889	459.0 to 460.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$220
15890	465.1 to 466.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960
58870	467.6 to 510.4 feet	Driveway				REF		
54300	468.7 to 469.7 feet	Vertical Change	.3	5 ft	5	REF		
15891	469.1 to 470.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240
15892	472.4 to 478.4 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	30	SF	\$40	\$1,200
15895	478.4 to 508.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	150	SF	\$40	\$5,980
15899	511.3 to 532.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	104	SF	\$120	\$12,420

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909231333	LINCOLN AVE	PALM PKY	2140 LINCOLN AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
15906	532.4 to 533.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	5	SF	\$120	\$600
54301	534.4 to 535.4 feet	Vertical Change	.3	5 ft	5	REF		
15907	534.5 to 539.3 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	24	SF	\$120	\$2,880
54302	537.8 to 538.8 feet	Vertical Change	.3	5 ft	5	REF		
15909	539.5 to 542.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	15	SF	\$120	\$1,740
15911	542.4 to 544.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,140
58871	561.9 to 585.8 feet	Driveway				REF		
15912	567.3 to 583.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	80	SF	\$40	\$3,200
56663	574.7 to 575.7 feet	Vertical Change	.5	5 ft	5	REF		
40431	584.7 to 585.8 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
15917	585.0 to 586.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200
15918	586.0 to 587.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$300
TOTAL COST FOR: W side of LINCOLN AVE Starting at: PALM PKY							\$262,715.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909231335	LINCOLN AVE	2142 LINCOLN AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
15793	1.9 to 3.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960
15794	11.8 to 13.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
TOTAL COST FOR: W side of LINCOLN AVE Starting at: 2142 LINCOLN AVE							\$1,800.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1909231338	LINCOLN AVE	SIDEWALK BEGINS	JEFFERSON ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
15774	0.4 to 7.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,500	
15775	12.4 to 61.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	245	SF	\$120	\$29,340	
54283	23.9 to 24.9 feet	Vertical Change	.3	5 ft	5	REF			
54284	33.7 to 34.7 feet	Vertical Change	.3	5 ft	5	REF			
54285	54.2 to 55.2 feet	Vertical Change	.3	5 ft	5	REF			
15785	61.3 to 79.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	93	SF	\$120	\$11,100	
TOTAL COST FOR:		E	<i>side of</i> LINCOLN AVE	<i>Starting at:</i> SIDEWALK BEGINS				\$44,940.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
S	1909231350	JEFFERSON ST	LINCOLN AVE	TRUMAN DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
15624	0.0 to 25.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	129	SF	\$120	\$15,480	
56659	12.4 to 13.4 feet	Vertical Change	.5	5 ft	5	REF			
15630	26.6 to 29.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,920	
58856	30.3 to 53.0 feet	Driveway				REF			
54269	31.0 to 32.0 feet	Vertical Change	.3	5 ft	5	REF			
15631	35.4 to 40.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	24	SF	\$40	\$960	
15633	41.0 to 47.2 feet	Cross Slope (Driveway)	13.014	5 ft	31	SF	\$40	\$1,240	
15635	48.0 to 49.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	8	SF	\$40	\$320	
56660	51.5 to 52.5 feet	Vertical Change	.5	5 ft	5	REF			
15636	53.3 to 56.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	15	SF	\$40	\$600	
15637	58.4 to 81.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	116	SF	\$120	\$13,860	
54270	59.0 to 60.0 feet	Vertical Change	.3	5 ft	5	REF			
54271	67.6 to 68.6 feet	Vertical Change	.3	5 ft	5	REF			
15642	86.3 to 89.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	15	SF	\$120	\$1,740	
58857	87.6 to 110.3 feet	Driveway				REF			
15643	93.3 to 100.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	38	SF	\$40	\$1,520	
56022	99.3 to 100.3 feet	Vertical Change	.4	5 ft	5	REF			
15645	100.9 to 106.6 feet	Cross Slope (Driveway)	13.014	5 ft	29	SF	\$40	\$1,140	
15647	106.6 to 107.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	5	SF	\$40	\$200	
54272	109.0 to 110.0 feet	Vertical Change	.3	5 ft	5	REF			
15648	111.2 to 113.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	12	SF	\$120	\$1,440	
15649	113.6 to 119.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,480	
58858	118.5 to 140.9 feet	Driveway				REF			
40421	120.8 to 122.0 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
15652	122.9 to 137.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	71	SF	\$40	\$2,840	
54273	129.4 to 130.4 feet	Vertical Change	.3	5 ft	5	REF			
15655	141.0 to 159.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	93	SF	\$40	\$3,700	
15657	159.5 to 204.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	223	SF	\$120	\$26,700	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909231350	JEFFERSON ST	LINCOLN AVE	TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54274	162.3 to 163.3 feet	Vertical Change	.3	5 ft	5	REF		
56023	182.6 to 183.6 feet	Vertical Change	.4	5 ft	5	REF		
58859	203.1 to 225.3 feet	Driveway				REF		
15664	208.3 to 215.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	37	SF	\$40	\$1,480
15666	218.0 to 221.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	19	SF	\$40	\$760
15668	225.3 to 233.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	42	SF	\$40	\$1,660
58860	234.6 to 256.7 feet	Driveway				REF		
15671	238.8 to 253.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	72	SF	\$40	\$2,880
15672	256.7 to 262.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	30	SF	\$40	\$1,180
15675	262.6 to 268.9 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	31	SF	\$120	\$3,780
15676	269.6 to 288.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	93	SF	\$120	\$11,100
15679	288.1 to 316.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	141	SF	\$120	\$16,920
58861	317.2 to 340.8 feet	Driveway				REF		
56024	317.7 to 318.7 feet	Vertical Change	.4	5 ft	5	REF		
15684	322.8 to 336.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	70	SF	\$40	\$2,800
15689	340.7 to 342.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	8	SF	\$40	\$300
15690	343.9 to 356.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	64	SF	\$120	\$7,620
15694	357.3 to 375.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	91	SF	\$120	\$10,860
58862	374.8 to 396.6 feet	Driveway				REF		
57638	380.2 to 381.2 feet	Vertical Change	3.4	5 ft	5	REF		
15697	381.0 to 395.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	71	SF	\$40	\$2,840
54275	397.4 to 398.4 feet	Vertical Change	.3	5 ft	5	REF		
15702	398.2 to 404.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	30	SF	\$120	\$3,540
40422	400.3 to 401.4 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
58863	405.7 to 428.6 feet	Driveway				REF		
15704	406.3 to 407.7 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	7	SF	\$40	\$280
40423	408.5 to 410.3 feet	Running Slope	5.0-6.0%	5 ft	9	REF		
15705	410.8 to 425.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	73	SF	\$40	\$2,900
40424	426.1 to 427.8 feet	Running Slope	5.0-6.0%	5 ft	9	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909231350	JEFFERSON ST	LINCOLN AVE	TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
15712	441.3 to 443.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440
15713	448.4 to 452.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340
15714	457.7 to 458.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720
15715	464.7 to 489.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	123	SF	\$120	\$14,760
58864	489.5 to 512.5 feet	Driveway				REF		
54276	490.7 to 491.7 feet	Vertical Change	.3	5 ft	5	REF		
40425	491.9 to 492.9 feet	Running Slope	6.0-7.0%	5 ft	5	REF		
15720	494.4 to 509.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	75	SF	\$40	\$2,980
56025	500.9 to 501.9 feet	Vertical Change	.4	5 ft	5	REF		
40426	509.5 to 511.9 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
54277	511.0 to 512.0 feet	Vertical Change	.3	5 ft	5	REF		
15723	520.6 to 522.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260
58865	520.7 to 543.6 feet	Driveway				REF		
40427	522.8 to 523.8 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
15724	526.8 to 541.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	72	SF	\$40	\$2,860
54278	531.5 to 532.5 feet	Vertical Change	.3	5 ft	5	REF		
15729	544.3 to 545.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240
15730	556.3 to 558.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140
15731	568.6 to 603.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	173	SF	\$120	\$20,820
54279	583.6 to 584.6 feet	Vertical Change	.3	5 ft	5	REF		
54280	596.8 to 597.8 feet	Vertical Change	.3	5 ft	5	REF		
57	599.3 to 600.3 feet	Continuous Width		5 ft	5	SF	\$120	\$600
15738	603.3 to 607.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	23	SF	\$120	\$2,760
57346	604.6 to 605.6 feet	Vertical Change	1	5 ft	5	REF		
58866	606.4 to 628.1 feet	Driveway				REF		
15741	609.8 to 613.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	21	SF	\$40	\$820
15743	613.9 to 624.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	53	SF	\$40	\$2,120
54281	616.7 to 617.7 feet	Vertical Change	.3	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909231350	JEFFERSON ST	LINCOLN AVE	TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
15746	627.9 to 629.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$280
15747	632.0 to 633.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900
58867	635.8 to 658.4 feet	Driveway				REF		
54282	636.7 to 637.7 feet	Vertical Change	.3	5 ft	5	REF		
15748	641.0 to 655.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	71	SF	\$40	\$2,860
15752	659.3 to 671.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	63	SF	\$120	\$7,500
15755	671.8 to 684.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,800
15757	685.8 to 688.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	12	SF	\$120	\$1,380
15759	688.1 to 707.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	98	SF	\$120	\$11,700
58868	706.9 to 753.9 feet	Driveway				REF		
40428	708.3 to 710.0 feet	Running Slope	6.0-7.0%	5 ft	9	REF		
15765	711.9 to 726.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	72	SF	\$40	\$2,880
15769	729.9 to 730.9 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200
15770	734.2 to 749.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	78	SF	\$40	\$3,120
15773	753.1 to 754.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	9	SF	\$40	\$340
TOTAL COST FOR: S side of JEFFERSON ST Starting at: LINCOLN AVE							\$241,860.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1909231357	TRUMAN DR	JEFFERSON ST	PALM PKY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
15506	0.0 to 1.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660	
15507	6.4 to 14.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$5,040	
15509	14.8 to 21.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	33	SF	\$120	\$3,900	
15511	21.3 to 24.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800	
58846	22.8 to 46.3 feet	Driveway				REF			
15512	28.0 to 43.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	75	SF	\$40	\$3,000	
57169	43.9 to 44.9 feet	Vertical Change	.7	5 ft	5	REF			
15514	46.6 to 57.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,600	
58847	56.5 to 79.1 feet	Driveway				REF			
40414	57.5 to 58.9 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
15519	61.0 to 75.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	74	SF	\$40	\$2,940	
15526	79.3 to 96.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	87	SF	\$40	\$3,480	
15532	96.7 to 115.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	94	SF	\$120	\$11,220	
15539	118.8 to 124.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	29	SF	\$120	\$3,480	
15542	124.8 to 136.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,840	
58848	135.3 to 156.9 feet	Driveway				REF			
15546	140.3 to 142.4 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	10	SF	\$40	\$420	
15547	146.7 to 154.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	38	SF	\$40	\$1,520	
56018	155.6 to 156.6 feet	Vertical Change	.4	5 ft	5	REF			
15550	157.3 to 166.9 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	48	SF	\$40	\$1,920	
58849	164.9 to 187.9 feet	Driveway				REF			
15555	170.4 to 183.9 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	68	SF	\$40	\$2,700	
57300	176.5 to 177.5 feet	Vertical Change	.9	5 ft	5	REF			
56019	186.5 to 187.5 feet	Vertical Change	.4	5 ft	5	REF			
15559	188.6 to 244.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	280	SF	\$120	\$33,540	
54258	223.6 to 224.6 feet	Vertical Change	.3	5 ft	5	REF			
58850	243.3 to 266.1 feet	Driveway				REF			
40415	246.3 to 247.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
15575	248.7 to 262.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	71	SF	\$40	\$2,820	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
E	1909231357	TRUMAN DR	JEFFERSON ST	PALM PKY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
54259	264.5 to 265.5 feet	Vertical Change	.3	5 ft	5	REF			
40416	264.5 to 266.0 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
15579	266.4 to 275.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	47	SF	\$40	\$1,860	
54260	271.7 to 272.7 feet	Vertical Change	.3	5 ft	5	REF			
58851	273.6 to 296.8 feet	Driveway				REF			
40417	275.5 to 278.0 feet	Running Slope	6.0-7.0%	5 ft	13	REF			
15582	279.2 to 293.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	73	SF	\$40	\$2,940	
56020	295.6 to 296.6 feet	Vertical Change	.4	5 ft	5	REF			
15587	297.4 to 308.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	53	SF	\$40	\$2,120	
15588	314.8 to 338.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	118	SF	\$120	\$14,100	
15592	343.3 to 352.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,520	
15595	354.9 to 356.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900	
58852	356.0 to 377.3 feet	Driveway				REF			
15596	360.6 to 375.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	74	SF	\$40	\$2,940	
54261	378.9 to 379.9 feet	Vertical Change	.3	5 ft	5	REF			
15599	379.0 to 387.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,340	
40418	383.1 to 385.3 feet	Running Slope	7.0-8.0%	5 ft	11	REF			
40419	386.2 to 387.5 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
54262	386.7 to 387.7 feet	Vertical Change	.3	5 ft	5	REF			
58853	386.8 to 409.3 feet	Driveway				REF			
15603	391.1 to 406.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	75	SF	\$40	\$2,980	
54263	407.7 to 408.7 feet	Vertical Change	.3	5 ft	5	REF			
54264	419.2 to 420.2 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
15606	421.6 to 439.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	87	SF	\$120	\$10,440	
54265	429.4 to 430.4 feet	Vertical Change	.3	5 ft	5	REF			
56021	440.0 to 441.0 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
15609	447.6 to 453.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,720	
58854	469.9 to 493.7 feet	Driveway				REF			
40420	472.3 to 474.2 feet	Running Slope	6.0-7.0%	5 ft	10	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909231357	TRUMAN DR	JEFFERSON ST	PALM PKY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
15610	474.7 to 486.4 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	59	SF	\$40	\$2,340
54266	481.9 to 482.9 feet	Vertical Change	.3	5 ft	5	REF		
15613	486.4 to 490.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	19	SF	\$40	\$740
54267	492.3 to 493.3 feet	Vertical Change	.3	5 ft	5	REF		
15614	494.3 to 502.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	40	SF	\$40	\$1,580
58855	500.9 to 524.0 feet	Driveway				REF		
15616	505.6 to 515.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	51	SF	\$40	\$2,040
54268	513.0 to 514.0 feet	Vertical Change	.3	5 ft	5	REF		
15618	518.3 to 521.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	16	SF	\$40	\$620
15619	525.3 to 549.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	120	SF	\$120	\$14,400
TOTAL COST FOR: E side of TRUMAN DR Starting at: JEFFERSON ST							\$167,210.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
W	1909231405	TRUMAN DR	PALM PKY	JEFFERSON ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
15399	2.4 to 6.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,460	
54250	5.7 to 6.7 feet	Vertical Change	.3	5 ft	5	REF			
15401	9.2 to 12.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740	
58837	37.6 to 58.3 feet	Driveway				REF			
15402	42.8 to 56.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	67	SF	\$40	\$2,680	
40410	57.0 to 58.3 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
15407	59.8 to 69.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,520	
58838	67.9 to 90.2 feet	Driveway				REF			
57168	68.1 to 69.1 feet	Vertical Change	.7	5 ft	5	REF			
15409	72.3 to 79.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	34	SF	\$40	\$1,360	
15411	82.1 to 85.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	18	SF	\$40	\$720	
40411	87.7 to 89.9 feet	Running Slope	5.0-6.0%	5 ft	11	REF			
56014	89.8 to 90.8 feet	Vertical Change	.4	5 ft	5	REF			
15412	90.4 to 95.6 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	26	SF	\$40	\$1,040	
15414	95.8 to 105.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,640	
54251	96.5 to 97.5 feet	Vertical Change	.3	5 ft	5	REF			
15416	105.2 to 147.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	211	SF	\$120	\$25,320	
56015	116.2 to 117.2 feet	Vertical Change	.4	5 ft	5	REF			
58839	146.2 to 168.7 feet	Driveway				REF			
40412	147.8 to 149.0 feet	Running Slope	6.0-7.0%	5 ft	6	REF			
15426	151.3 to 165.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	72	SF	\$40	\$2,900	
15431	169.5 to 179.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,760	
58840	176.8 to 199.5 feet	Driveway				REF			
56016	177.8 to 178.8 feet	Vertical Change	.4	5 ft	5	REF			
15433	183.9 to 197.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	66	SF	\$40	\$2,640	
15436	201.3 to 236.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	178	SF	\$120	\$21,300	
15443	236.8 to 238.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	8	SF	\$120	\$900	
15444	240.4 to 256.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	80	SF	\$120	\$9,540	
54252	245.8 to 246.8 feet	Vertical Change	.3	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909231405	TRUMAN DR	PALM PKY	JEFFERSON ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57380	252.3 to 253.3 feet	Vertical Change	1.1	5 ft	5	REF		
58841	254.7 to 277.5 feet	Driveway				REF		
40413	257.2 to 258.4 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
15446	260.0 to 273.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	68	SF	\$40	\$2,720
15450	279.1 to 287.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,220
58842	285.3 to 308.2 feet	Driveway				REF		
15453	291.3 to 298.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	37	SF	\$40	\$1,460
15455	301.3 to 305.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	19	SF	\$40	\$740
15457	308.3 to 362.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	269	SF	\$40	\$10,740
54253	324.6 to 325.6 feet	Vertical Change	.3	5 ft	5	REF		
57627	357.5 to 358.5 feet	Vertical Change	3.3	5 ft	5	REF		
58843	364.6 to 386.4 feet	Driveway				REF		
15467	369.0 to 373.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	25	SF	\$40	\$980
15470	373.9 to 383.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	48	SF	\$40	\$1,920
15473	383.5 to 384.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200
54254	385.6 to 386.6 feet	Vertical Change	.3	5 ft	5	REF		
15474	388.7 to 408.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	98	SF	\$120	\$11,760
54255	409.0 to 410.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
15478	412.8 to 420.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,860
56017	415.5 to 416.5 feet	Vertical Change	.4	5 ft	5	REF		
58844	418.5 to 441.4 feet	Driveway				REF		
15482	422.4 to 426.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	20	SF	\$40	\$780
15484	426.3 to 437.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	56	SF	\$40	\$2,240
15486	443.2 to 445.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	11	SF	\$120	\$1,320
15487	446.0 to 451.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,180
58845	450.1 to 472.3 feet	Driveway				REF		
15489	455.3 to 469.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	70	SF	\$40	\$2,800
15494	471.5 to 503.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	162	SF	\$40	\$6,480
54256	477.8 to 478.8 feet	Vertical Change	.3	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909231405	TRUMAN DR	PALM PKY	JEFFERSON ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54257	496.8 to 497.8 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: W side of TRUMAN DR Starting at: PALM PKY							\$147,295.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909231408	JEFFERSON ST	TRUMAN DR	MADISON CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
15363	0.0 to 5.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	25	SF	\$120	\$3,000
15365	7.5 to 29.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	109	SF	\$120	\$13,080
15369	29.3 to 43.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,700
15374	46.3 to 77.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	156	SF	\$120	\$18,720
15379	77.8 to 92.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	73	SF	\$120	\$8,700
15382	93.1 to 169.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	380	SF	\$120	\$45,540
54249	144.8 to 145.8 feet	Vertical Change	.3	5 ft	5	REF		
15398	169.4 to 172.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620
TOTAL COST FOR: N side of JEFFERSON ST Starting at: TRUMAN DR							\$99,360.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
N	1909231420	MADISON CT	JEFFERSON ST	JEFFERSON ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
15170	0.0 to 13.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	66	SF	\$120	\$7,920	
54227	10.3 to 11.3 feet	Vertical Change	.3	5 ft	5	REF			
15175	15.3 to 25.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	50	SF	\$120	\$6,000	
15178	25.3 to 31.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,900	
58819	30.7 to 53.5 feet	Driveway				REF			
40400	33.5 to 34.7 feet	Running Slope	6.0-7.0%	5 ft	6	REF			
15181	35.1 to 50.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	77	SF	\$40	\$3,080	
40401	50.6 to 52.8 feet	Running Slope	5.0-6.0%	5 ft	11	REF			
15187	54.0 to 63.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	46	SF	\$40	\$1,820	
58820	62.3 to 85.5 feet	Driveway				REF			
15191	67.1 to 79.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	61	SF	\$40	\$2,440	
15193	79.6 to 81.5 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	10	SF	\$40	\$380	
15194	85.6 to 112.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	133	SF	\$40	\$5,300	
15198	112.3 to 124.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,500	
54228	121.5 to 122.5 feet	Vertical Change	.3	5 ft	5	REF			
15203	125.3 to 137.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	63	SF	\$120	\$7,500	
15206	138.2 to 142.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760	
58821	141.5 to 163.8 feet	Driveway				REF			
54229	142.2 to 143.2 feet	Vertical Change	.3	5 ft	5	REF			
15208	146.9 to 161.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	71	SF	\$40	\$2,840	
15211	164.4 to 173.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	47	SF	\$40	\$1,880	
58822	172.3 to 194.7 feet	Driveway				REF			
15212	174.7 to 175.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200	
15213	177.4 to 191.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	68	SF	\$40	\$2,720	
15219	195.0 to 196.6 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	8	SF	\$40	\$320	
15220	196.6 to 216.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	99	SF	\$120	\$11,820	
54230	200.6 to 201.6 feet	Vertical Change	.3	5 ft	5	REF			
15223	219.6 to 225.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	29	SF	\$120	\$3,420	
54231	220.0 to 221.0 feet	Vertical Change	.3	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1909231420	MADISON CT	JEFFERSON ST	JEFFERSON ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
15224	225.3 to 251.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	131	SF	\$120	\$15,660	
58823	250.8 to 274.2 feet	Driveway				REF			
15228	251.4 to 252.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$200	
15229	255.2 to 271.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	81	SF	\$40	\$3,220	
54232	272.6 to 273.6 feet	Vertical Change	.3	5 ft	5	REF			
15233	274.8 to 283.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,460	
58824	281.8 to 303.5 feet	Driveway				REF			
15235	286.2 to 290.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	19	SF	\$40	\$760	
15237	290.5 to 300.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	49	SF	\$40	\$1,980	
56008	302.2 to 303.2 feet	Vertical Change	.4	5 ft	5	REF			
15240	304.3 to 316.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	63	SF	\$40	\$2,500	
15241	316.8 to 358.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	207	SF	\$120	\$24,780	
56656	323.4 to 324.4 feet	Vertical Change	.5	5 ft	5	REF			
15249	358.5 to 365.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	37	SF	\$120	\$4,380	
58825	365.0 to 386.8 feet	Driveway				REF			
15251	369.3 to 383.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	73	SF	\$40	\$2,900	
15255	387.1 to 390.5 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	17	SF	\$40	\$680	
15256	390.7 to 393.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440	
58826	396.8 to 419.0 feet	Driveway				REF			
40402	398.5 to 399.7 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
15257	403.8 to 414.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	55	SF	\$40	\$2,180	
40403	415.8 to 418.3 feet	Running Slope	5.0-6.0%	5 ft	13	REF			
54233	417.3 to 418.3 feet	Vertical Change	.3	5 ft	5	REF			
15258	418.7 to 426.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	41	SF	\$40	\$1,640	
15260	426.9 to 431.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	25	SF	\$120	\$3,000	
15262	431.9 to 451.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	98	SF	\$120	\$11,760	
54234	450.3 to 451.3 feet	Vertical Change	.3	5 ft	5	REF			
58827	450.3 to 473.5 feet	Driveway				REF			
15265	455.3 to 469.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	71	SF	\$40	\$2,820	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909231420	MADISON CT	JEFFERSON ST	JEFFERSON ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40404	470.3 to 471.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
56009	471.4 to 472.4 feet	Vertical Change	.4	5 ft	5	REF		
15267	473.2 to 476.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	18	SF	\$40	\$720
15268	476.8 to 503.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	132	SF	\$120	\$15,840
56657	494.1 to 495.1 feet	Vertical Change	.5	5 ft	5	REF		
15274	503.2 to 511.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	42	SF	\$120	\$4,980
15276	512.1 to 518.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,960
56658	513.7 to 514.7 feet	Vertical Change	.5	5 ft	5	REF		
54235	517.1 to 518.1 feet	Vertical Change	.3	5 ft	5	REF		
15277	521.3 to 524.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860
15279	524.4 to 527.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	14	SF	\$120	\$1,740
56010	525.6 to 526.6 feet	Vertical Change	.4	5 ft	5	REF		
58828	525.8 to 548.1 feet	Driveway				REF		
40405	526.9 to 528.8 feet	Running Slope	6.0-7.0%	5 ft	9	REF		
15281	528.0 to 529.2 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	6	SF	\$40	\$240
15282	530.0 to 543.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	70	SF	\$40	\$2,780
54236	536.0 to 537.0 feet	Vertical Change	.3	5 ft	5	REF		
15284	547.7 to 553.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	28	SF	\$40	\$1,120
15286	556.5 to 572.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	78	SF	\$120	\$9,360
15293	572.4 to 579.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,140
58829	578.7 to 600.7 feet	Driveway				REF		
56011	578.9 to 579.9 feet	Vertical Change	.4	5 ft	5	REF		
15295	583.0 to 597.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	71	SF	\$40	\$2,860
56012	588.6 to 589.6 feet	Vertical Change	.4	5 ft	5	REF		
15298	601.3 to 613.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	61	SF	\$40	\$2,420
58830	612.0 to 635.0 feet	Driveway				REF		
54237	612.3 to 613.3 feet	Vertical Change	.3	5 ft	5	REF		
15303	616.7 to 624.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	40	SF	\$40	\$1,620

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1909231420	MADISON CT	JEFFERSON ST	JEFFERSON ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
15306	625.0 to 630.7 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	29	SF	\$40	\$1,140	
54238	633.4 to 634.4 feet	Vertical Change	.3	5 ft	5	REF			
15309	634.8 to 637.6 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	14	SF	\$40	\$560	
15310	637.6 to 643.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,420	
54239	661.6 to 662.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
58831	692.2 to 712.8 feet	Driveway				REF			
54240	692.6 to 693.6 feet	Vertical Change	.3	5 ft	5	REF			
15311	696.9 to 710.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	70	SF	\$40	\$2,780	
40406	712.8 to 714.0 feet	Running Slope	10.0-11.0%	5 ft	6	REF			
54241	713.9 to 714.9 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
15313	715.5 to 717.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$900	
15314	717.0 to 719.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500	
15315	722.3 to 723.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960	
58832	722.8 to 745.1 feet	Driveway				REF			
15316	727.3 to 742.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	76	SF	\$40	\$3,040	
15324	745.7 to 747.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
15325	773.1 to 783.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,420	
15327	786.8 to 796.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$5,940	
58833	801.1 to 823.4 feet	Driveway				REF			
15329	801.8 to 803.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$280	
54242	802.2 to 803.2 feet	Vertical Change	.3	5 ft	5	REF			
15330	807.1 to 815.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	41	SF	\$40	\$1,640	
15333	819.3 to 821.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	9	SF	\$40	\$340	
56013	822.6 to 823.6 feet	Vertical Change	.4	5 ft	5	REF			
15334	824.3 to 833.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,400	
58834	832.3 to 854.6 feet	Driveway				REF			
15335	837.3 to 851.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	73	SF	\$40	\$2,900	
15339	854.8 to 856.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	7	SF	\$40	\$260	
15340	856.3 to 912.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	279	SF	\$120	\$33,480	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909231420	MADISON CT	JEFFERSON ST	JEFFERSON ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54243	881.2 to 882.2 feet	Vertical Change	.3	5 ft	5	REF		
58835	910.9 to 932.7 feet	Driveway				REF		
54244	911.5 to 912.5 feet	Vertical Change	.3	5 ft	5	REF		
15348	915.0 to 919.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	22	SF	\$40	\$860
15350	920.3 to 929.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	47	SF	\$40	\$1,880
54245	920.9 to 921.9 feet	Vertical Change	.3	5 ft	5	REF		
40407	929.8 to 931.0 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
54246	931.4 to 932.4 feet	Vertical Change	.3	5 ft	5	REF		
15352	934.5 to 936.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
15353	939.0 to 940.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,080
58836	939.3 to 962.3 feet	Driveway				REF		
54247	939.8 to 940.8 feet	Vertical Change	.3	5 ft	5	REF		
40408	941.1 to 943.1 feet	Running Slope	6.0-7.0%	5 ft	10	REF		
15354	944.8 to 949.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	21	SF	\$40	\$840
15356	951.3 to 958.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	38	SF	\$40	\$1,520
40409	960.6 to 961.7 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
54248	960.9 to 961.9 feet	Vertical Change	.3	5 ft	5	REF		
15357	967.7 to 987.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	98	SF	\$120	\$11,760
15361	987.4 to 993.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	30	SF	\$120	\$3,600
TOTAL COST FOR: N side of MADISON CT Starting at: JEFFERSON ST							\$306,210.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1909231423	JEFFERSON ST	MADISON CT	HARRISON CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
15134	0.0 to 9.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,820	
15139	13.9 to 18.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,940	
15140	28.3 to 31.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040	
56655	28.6 to 29.6 feet	Vertical Change	.5	5 ft	5	REF			
15141	36.3 to 51.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	75	SF	\$120	\$9,000	
57621	52.6 to 53.6 feet	Vertical Change	3.2	5 ft	5	SF	\$75	\$375	
15144	53.8 to 80.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	133	SF	\$120	\$15,900	
15149	81.3 to 151.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	349	SF	\$120	\$41,880	
15163	153.4 to 184.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	153	SF	\$120	\$18,360	
TOTAL COST FOR: N side of JEFFERSON ST Starting at: MADISON CT								\$96,315.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1909231430	HARRISON CT	JEFFERSON ST	2102 HARRISON CT	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
15012	0.0 to 4.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,460	
15014	5.3 to 29.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	120	SF	\$120	\$14,340	
58810	30.8 to 53.7 feet	Driveway				REF			
40398	34.2 to 35.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
15022	36.4 to 38.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	12	SF	\$40	\$480	
15023	41.6 to 51.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	49	SF	\$40	\$1,960	
56007	41.9 to 42.9 feet	Vertical Change	.4	5 ft	5	REF			
15027	53.3 to 61.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	40	SF	\$40	\$1,600	
58811	61.3 to 83.9 feet	Driveway				REF			
15029	66.0 to 81.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	79	SF	\$40	\$3,140	
15034	84.8 to 95.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	54	SF	\$120	\$6,480	
54222	90.5 to 91.5 feet	Vertical Change	.3	5 ft	5	REF			
15038	98.7 to 99.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$600	
15039	102.6 to 141.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	197	SF	\$120	\$23,580	
58812	140.5 to 163.3 feet	Driveway				REF			
15049	145.8 to 159.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	70	SF	\$40	\$2,800	
15052	163.5 to 170.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	35	SF	\$120	\$4,140	
58813	171.3 to 194.0 feet	Driveway				REF			
15056	177.0 to 190.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	67	SF	\$40	\$2,660	
15060	193.6 to 208.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	75	SF	\$40	\$3,000	
15064	211.2 to 220.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	45	SF	\$120	\$5,340	
15066	223.7 to 228.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	23	SF	\$120	\$2,760	
15067	229.1 to 250.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	106	SF	\$120	\$12,720	
58814	249.1 to 271.9 feet	Driveway				REF			
15073	253.9 to 268.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	71	SF	\$40	\$2,840	
15076	272.5 to 276.9 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	22	SF	\$40	\$880	
15078	276.9 to 281.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,820	
58815	279.6 to 302.7 feet	Driveway				REF			
54223	280.2 to 281.2 feet	Vertical Change	.3	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909231430	HARRISON CT	JEFFERSON ST	2102 HARRISON CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
15080	285.0 to 299.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	73	SF	\$40	\$2,920
15085	303.1 to 309.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	31	SF	\$40	\$1,240
15088	309.3 to 328.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	96	SF	\$120	\$11,460
54224	318.6 to 319.6 feet	Vertical Change	.3	5 ft	5	REF		
15093	328.4 to 344.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	82	SF	\$120	\$9,840
54225	328.5 to 329.5 feet	Vertical Change	.3	5 ft	5	REF		
15097	347.3 to 357.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	51	SF	\$120	\$6,120
15101	358.4 to 360.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	9	SF	\$120	\$1,020
58816	358.8 to 380.9 feet	Driveway				REF		
15102	360.7 to 361.7 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	5	SF	\$40	\$200
15103	363.6 to 376.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	66	SF	\$40	\$2,620
15106	377.3 to 378.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	5	SF	\$40	\$200
15107	381.7 to 386.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	22	SF	\$120	\$2,640
15108	386.1 to 390.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340
15109	392.3 to 396.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	22	SF	\$120	\$2,640
54226	395.6 to 396.6 feet	Vertical Change	.3	5 ft	5	REF		
58817	395.7 to 417.4 feet	Driveway				REF		
15110	400.1 to 413.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	68	SF	\$40	\$2,700
40399	415.4 to 416.9 feet	Running Slope	5.0-6.0%	5 ft	8	REF		
15115	417.9 to 445.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	137	SF	\$120	\$16,440
15122	445.3 to 448.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040
58818	447.6 to 470.9 feet	Driveway				REF		
15124	448.7 to 449.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$200
15125	452.2 to 457.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	26	SF	\$40	\$1,040
15127	458.1 to 466.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	44	SF	\$40	\$1,760
15129	466.9 to 468.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	6	SF	\$40	\$220
15130	471.3 to 481.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	52	SF	\$40	\$2,080
15133	502.5 to 509.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,140

TOTAL COST FOR: E side of HARRISON CT Starting at: JEFFERSON ST \$168,460.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
W	1909231436	HARRISON CT	2102 HARRISON CT	JEFFERSON ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
14904	0.0 to 9.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	48	SF	\$120	\$5,820	
58801	7.5 to 31.3 feet	Driveway				REF			
54216	8.1 to 9.1 feet	Vertical Change	.3	5 ft	5	REF			
14906	10.3 to 11.4 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	6	SF	\$40	\$220	
14907	12.2 to 17.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	28	SF	\$40	\$1,100	
14909	17.7 to 28.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	56	SF	\$40	\$2,220	
14912	34.1 to 37.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,920	
14913	45.5 to 59.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	72	SF	\$120	\$8,580	
58802	59.7 to 83.7 feet	Driveway				REF			
14915	63.2 to 78.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	78	SF	\$40	\$3,120	
14921	79.1 to 80.9 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	9	SF	\$40	\$360	
56004	79.6 to 80.6 feet	Vertical Change	.4	5 ft	5	REF			
14922	87.4 to 97.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,120	
58803	95.3 to 117.8 feet	Driveway				REF			
56005	95.6 to 96.6 feet	Vertical Change	.4	5 ft	5	REF			
14924	100.2 to 115.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	79	SF	\$40	\$3,140	
54217	116.0 to 117.0 feet	Vertical Change	.3	5 ft	5	REF			
14930	117.9 to 119.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	7	SF	\$40	\$280	
14931	119.3 to 146.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	135	SF	\$120	\$16,200	
57248	125.7 to 126.7 feet	Vertical Change	.8	5 ft	5	REF			
14936	150.1 to 160.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,420	
54218	152.6 to 153.6 feet	Vertical Change	.3	5 ft	5	REF			
56006	163.3 to 164.3 feet	Vertical Change	.4	5 ft	5	REF			
14938	164.2 to 174.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	54	SF	\$120	\$6,420	
58804	173.6 to 196.5 feet	Driveway				REF			
14939	178.6 to 193.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	76	SF	\$40	\$3,040	
14943	197.4 to 204.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	35	SF	\$120	\$4,140	
58805	202.8 to 226.1 feet	Driveway				REF			
56652	203.2 to 204.2 feet	Vertical Change	.5	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909231436	HARRISON CT	2102 HARRISON CT	JEFFERSON ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14945	208.8 to 222.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	67	SF	\$40	\$2,660
14947	222.1 to 223.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	5	SF	\$40	\$200
40397	223.5 to 225.8 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
14948	224.3 to 230.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	31	SF	\$40	\$1,240
14950	233.1 to 249.5 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	82	SF	\$120	\$9,840
56653	234.5 to 235.5 feet	Vertical Change	.5	5 ft	5	REF		
14953	249.5 to 252.0 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	13	SF	\$120	\$1,500
14955	252.3 to 282.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	152	SF	\$120	\$18,240
58806	281.4 to 303.5 feet	Driveway				REF		
14960	282.7 to 283.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200
14961	284.3 to 286.5 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	11	SF	\$40	\$440
14963	286.5 to 300.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	70	SF	\$40	\$2,800
14967	303.4 to 308.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	26	SF	\$40	\$1,040
14969	308.6 to 314.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,720
58807	313.0 to 336.7 feet	Driveway				REF		
14971	319.1 to 333.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	74	SF	\$40	\$2,960
54219	324.6 to 325.6 feet	Vertical Change	.3	5 ft	5	REF		
14976	336.8 to 339.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	15	SF	\$40	\$600
14978	339.8 to 343.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400
14980	344.3 to 391.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	234	SF	\$120	\$28,020
56654	369.6 to 370.6 feet	Vertical Change	.5	5 ft	5	REF		
58808	389.8 to 411.6 feet	Driveway				REF		
54220	390.0 to 391.0 feet	Vertical Change	.3	5 ft	5	REF		
14994	394.7 to 400.0 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	27	SF	\$40	\$1,060
14996	400.0 to 408.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	42	SF	\$40	\$1,680
14998	412.0 to 423.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	59	SF	\$40	\$2,360
58809	422.0 to 444.8 feet	Driveway				REF		
54221	422.4 to 423.4 feet	Vertical Change	.3	5 ft	5	REF		
15001	426.9 to 442.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	77	SF	\$40	\$3,080

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909231436	HARRISON CT	2102 HARRISON CT	JEFFERSON ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
15006	444.4 to 448.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	22	SF	\$40	\$880
15008	448.8 to 471.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	113	SF	\$120	\$13,560
15011	471.7 to 475.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,980
TOTAL COST FOR: W side of HARRISON CT Starting at: 2102 HARRISON CT							\$169,560.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909231439	JEFFERSON ST	HARRISON CT	LINCOLN AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14876	0.7 to 20.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	98	SF	\$120	\$11,700
14880	20.2 to 148.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	643	SF	\$120	\$77,160
54213	81.5 to 82.5 feet	Vertical Change	.3	5 ft	5	REF		
54214	88.3 to 89.3 feet	Vertical Change	.3	5 ft	5	REF		
14899	148.8 to 175.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	133	SF	\$120	\$15,960
56003	160.6 to 161.6 feet	Vertical Change	.4	5 ft	5	REF		
54215	170.8 to 171.8 feet	Vertical Change	.3	5 ft	5	REF		
14903	176.0 to 180.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,880
TOTAL COST FOR: N side of JEFFERSON ST Starting at: HARRISON CT							\$107,700.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1909231446	LINCOLN AVE	JEFFERSON ST	PALM PKY	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
14781	4.4 to 28.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	119	SF	\$120	\$14,280	
54205	10.6 to 11.6 feet	Vertical Change	.3	5 ft	5	REF			
56000	19.8 to 20.8 feet	Vertical Change	.4	5 ft	5	REF			
14786	28.2 to 30.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	11	SF	\$120	\$1,260	
58792	28.5 to 51.2 feet	Driveway				REF			
14787	34.0 to 48.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	74	SF	\$40	\$2,940	
14791	52.3 to 56.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	23	SF	\$120	\$2,760	
54206	54.4 to 55.4 feet	Vertical Change	.3	5 ft	5	REF			
14792	56.9 to 59.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260	
58793	59.0 to 81.6 feet	Driveway				REF			
14794	63.2 to 78.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	78	SF	\$40	\$3,100	
14797	82.1 to 93.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	55	SF	\$40	\$2,180	
14800	93.0 to 138.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	229	SF	\$120	\$27,480	
54207	116.9 to 117.9 feet	Vertical Change	.3	5 ft	5	REF			
54208	127.2 to 128.2 feet	Vertical Change	.3	5 ft	5	REF			
58794	137.0 to 160.0 feet	Driveway				REF			
14811	142.0 to 156.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	75	SF	\$40	\$2,980	
14815	156.9 to 157.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200	
56001	158.5 to 159.5 feet	Vertical Change	.4	5 ft	5	REF			
14816	161.3 to 163.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
58795	166.6 to 191.2 feet	Driveway				REF			
54209	166.9 to 167.9 feet	Vertical Change	.3	5 ft	5	REF			
40394	168.3 to 169.6 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
14817	171.6 to 188.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	84	SF	\$40	\$3,360	
14822	188.4 to 189.4 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200	
40395	188.5 to 189.8 feet	Running Slope	6.0-7.0%	5 ft	7	REF			
14823	191.8 to 192.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$660	
14824	192.9 to 203.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,300	
14825	207.3 to 218.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,660	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909231446	LINCOLN AVE	JEFFERSON ST	PALM PKY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14826	228.3 to 234.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,480
56651	235.6 to 236.6 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375
14827	236.9 to 246.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$6,000
58796	246.1 to 268.9 feet	Driveway				REF		
14831	250.5 to 263.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	63	SF	\$40	\$2,500
14833	263.3 to 265.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	13	SF	\$40	\$500
54210	267.4 to 268.4 feet	Vertical Change	.3	5 ft	5	REF		
14835	269.4 to 278.6 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	46	SF	\$40	\$1,840
58797	277.2 to 300.1 feet	Driveway				REF		
40396	279.6 to 280.7 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
14838	280.3 to 281.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200
14839	282.2 to 295.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	68	SF	\$40	\$2,720
14842	300.3 to 317.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	85	SF	\$40	\$3,380
54211	313.6 to 314.6 feet	Vertical Change	.3	5 ft	5	REF		
14847	317.2 to 323.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,900
14848	326.4 to 354.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	139	SF	\$120	\$16,620
58798	354.5 to 377.7 feet	Driveway				REF		
14851	358.6 to 363.2 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	23	SF	\$40	\$920
14853	363.8 to 369.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	27	SF	\$40	\$1,060
14854	372.9 to 374.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	9	SF	\$40	\$360
14855	378.8 to 386.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	40	SF	\$120	\$4,800
57167	383.6 to 384.6 feet	Vertical Change	.7	5 ft	5	REF		
58799	385.6 to 407.8 feet	Driveway				REF		
14857	389.8 to 404.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	74	SF	\$40	\$2,940
14860	408.6 to 410.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
14861	413.8 to 439.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	130	SF	\$120	\$15,540
58800	438.8 to 461.9 feet	Driveway				REF		
14865	443.7 to 458.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	76	SF	\$40	\$3,020
54212	450.4 to 451.4 feet	Vertical Change	.3	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1909231446	LINCOLN AVE	JEFFERSON ST	PALM PKY	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
14868	461.6 to 462.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$240	
14869	465.1 to 482.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	87	SF	\$120	\$10,440	
56002	468.4 to 469.4 feet	Vertical Change	.4	5 ft	5	REF			
14875	485.8 to 490.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	22	SF	\$120	\$2,640	
TOTAL COST FOR: E							<i>side of</i> LINCOLN AVE	<i>Starting at:</i> JEFFERSON ST	\$161,255.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909231448	PALM PKY	LINCOLN AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14771	0.9 to 4.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,100
14773	4.4 to 32.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	139	SF	\$120	\$16,740
14778	33.2 to 38.0 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	24	SF	\$120	\$2,880
14780	38.0 to 41.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	17	SF	\$120	\$1,980
TOTAL COST FOR: S side of PALM PKY Starting at: LINCOLN AVE							\$23,700.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909231511	PALM PKY	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14770	1.7 to 6.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760
54204	2.8 to 3.8 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR:		S	<i>side of</i> PALM PKY Starting at: SIDEWALK BEGINS					\$2,760.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909231512	PALM PKY	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14768	0.0 to 6.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,840
TOTAL COST FOR: S side of PALM PKY Starting at: SIDEWALK BEGINS								\$3,840.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909231513	PALM PKY	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14758	0.0 to 6.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	31	SF	\$120	\$3,720
14760	6.2 to 8.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	11	SF	\$120	\$1,320
14761	8.4 to 28.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	102	SF	\$120	\$12,240
57379	17.3 to 18.3 feet	Vertical Change	1.1	5 ft	5	REF		
14766	28.8 to 37.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	42	SF	\$120	\$5,100
TOTAL COST FOR: S side of PALM PKY Starting at: SIDEWALK BEGINS							\$22,380.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909231514	PALM PKY	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14744	0.0 to 7.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	40	SF	\$120	\$4,740
14747	7.9 to 10.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	15	SF	\$120	\$1,740
14749	11.6 to 20.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	46	SF	\$120	\$5,520
14752	21.0 to 27.3 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	32	SF	\$120	\$3,780
54203	22.4 to 23.4 feet	Vertical Change	.3	5 ft	5	REF		
14753	27.6 to 30.0 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	12	SF	\$120	\$1,440
14755	30.0 to 36.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	31	SF	\$120	\$3,780
14757	36.3 to 37.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660
TOTAL COST FOR: S side of PALM PKY Starting at: SIDEWALK BEGINS							\$21,660.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909231515	PALM PKY	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14742	0.0 to 6.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	31	SF	\$120	\$3,660
TOTAL COST FOR: S side of PALM PKY Starting at: SIDEWALK BEGINS								\$3,660.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909231516	PALM PKY	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14737	0.0 to 4.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	24	SF	\$120	\$2,820
14739	7.0 to 11.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	24	SF	\$120	\$2,880
14741	16.4 to 17.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$720
TOTAL COST FOR: S side of PALM PKY Starting at: SIDEWALK BEGINS								\$6,420.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
S	1909231522	PALM PKY	SIDEWALK BEGINS	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
14654	0.0 to 8.0 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	40	SF	\$120	\$4,800	
14656	8.0 to 9.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,080	
14657	9.8 to 19.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,880	
14659	19.6 to 35.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	78	SF	\$120	\$9,420	
14663	38.1 to 47.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	49	SF	\$120	\$5,820	
14667	47.8 to 59.0 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	56	SF	\$120	\$6,720	
54201	57.2 to 58.2 feet	Vertical Change	.3	5 ft	5	REF			
14672	61.7 to 75.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	71	SF	\$120	\$8,460	
14676	80.3 to 88.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,100	
56996	84.4 to 85.4 feet	Vertical Change	.6	5 ft	5	REF			
14678	88.8 to 99.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	55	SF	\$120	\$6,600	
55999	93.4 to 94.4 feet	Vertical Change	.4	5 ft	5	REF			
14680	104.0 to 108.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	23	SF	\$120	\$2,700	
14682	108.7 to 115.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,200	
14686	115.7 to 125.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	51	SF	\$120	\$6,120	
54202	124.0 to 125.0 feet	Vertical Change	.3	5 ft	5	REF			
14691	128.5 to 131.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	16	SF	\$120	\$1,920	
14692	132.9 to 135.3 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	12	SF	\$120	\$1,440	
14693	137.5 to 140.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	14	SF	\$120	\$1,680	
14694	142.7 to 155.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	63	SF	\$120	\$7,560	
14699	159.6 to 167.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	42	SF	\$120	\$4,980	
14701	168.2 to 171.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,980	
14702	181.3 to 183.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140	
14703	186.3 to 201.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	75	SF	\$120	\$8,940	
14705	206.8 to 224.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	89	SF	\$120	\$10,680	
14711	227.0 to 238.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	59	SF	\$120	\$7,020	
14715	238.8 to 287.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	244	SF	\$120	\$29,280	
14727	291.0 to 345.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	272	SF	\$120	\$32,640	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909231522	PALM PKY	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56650	335.9 to 336.9 feet	Vertical Change	.5	5 ft	5	REF		
TOTAL COST FOR: S side of PALM PKY Starting at: SIDEWALK BEGINS							\$176,160.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909231523	PALM PKY	SIDEWALK BEGINS	TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14639	0.0 to 36.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	180	SF	\$120	\$21,600
14645	37.1 to 57.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	102	SF	\$120	\$12,180
14649	57.4 to 76.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	93	SF	\$120	\$11,220
54200	67.4 to 68.4 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: S side of PALM PKY Starting at: SIDEWALK BEGINS							\$45,000.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909231525	PALM PKY	TRUMAN DR	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54197	14.9 to 15.9 feet	Vertical Change	.3	5 ft	5	REF		
14624	15.2 to 29.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	70	SF	\$120	\$8,340
14627	31.9 to 46.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	71	SF	\$120	\$8,520
54198	44.5 to 45.5 feet	Vertical Change	.3	5 ft	5	REF		
14630	46.1 to 54.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,160
14632	55.1 to 62.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	37	SF	\$120	\$4,380
14634	62.4 to 69.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,080
14636	71.2 to 94.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	119	SF	\$120	\$14,220
54199	75.0 to 76.0 feet	Vertical Change	.3	5 ft	5	REF		
57451	85.3 to 86.3 feet	Vertical Change	1.4	5 ft	5	REF		
TOTAL COST FOR: S side of PALM PKY Starting at: TRUMAN DR							\$44,700.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909231528	PALM PKY	SIDEWALK BEGINS	TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14606	0.0 to 13.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	69	SF	\$120	\$8,280
14609	17.9 to 19.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780
14610	23.2 to 51.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	141	SF	\$120	\$16,860
14615	51.3 to 67.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	81	SF	\$120	\$9,720
14618	67.5 to 79.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,380
14622	84.8 to 89.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,640
TOTAL COST FOR: N side of PALM PKY Starting at: SIDEWALK BEGINS							\$45,660.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1909231533	PALM PKY	TRUMAN DR	MONROE CT	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
14545	0.0 to 19.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	99	SF	\$120	\$11,820	
54193	2.7 to 3.7 feet	Vertical Change	.3	5 ft	5	REF			
54194	9.9 to 10.9 feet	Vertical Change	.3	5 ft	5	REF			
14551	20.5 to 29.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	45	SF	\$120	\$5,340	
14553	31.3 to 34.6 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	17	SF	\$120	\$1,980	
14554	34.6 to 40.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	28	SF	\$120	\$3,360	
54195	38.0 to 39.0 feet	Vertical Change	.3	5 ft	5	REF			
14556	40.8 to 53.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	62	SF	\$120	\$7,440	
57493	46.1 to 47.1 feet	Vertical Change	1.7	5 ft	5	REF			
14560	57.0 to 70.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	65	SF	\$120	\$7,800	
57247	60.0 to 61.0 feet	Vertical Change	.8	5 ft	5	REF			
14565	70.8 to 79.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,100	
14567	83.3 to 96.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	66	SF	\$120	\$7,860	
14573	98.8 to 101.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800	
14574	103.8 to 109.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	28	SF	\$120	\$3,300	
14576	109.7 to 136.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	133	SF	\$120	\$15,960	
57558	112.3 to 113.3 feet	Vertical Change	2.4	5 ft	5	REF			
54196	126.0 to 127.0 feet	Vertical Change	.3	5 ft	5	REF			
57626	131.1 to 132.1 feet	Vertical Change	3.3	5 ft	5	REF			
14582	140.1 to 153.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,800	
14586	155.2 to 160.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	25	SF	\$120	\$2,940	
14587	160.4 to 161.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600	
14588	164.6 to 184.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	100	SF	\$120	\$12,000	
14592	184.6 to 210.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	128	SF	\$120	\$15,300	
14598	213.0 to 245.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	162	SF	\$120	\$19,440	
14605	246.9 to 248.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960	
TOTAL COST FOR: N							side of PALM PKY Starting at: TRUMAN DR	\$130,800.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1909231537	MONROE CT	PALM PKY	2003 MONROE CT	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
14474	0.1 to 5.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,420	
14476	5.8 to 10.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	26	SF	\$120	\$3,060	
14478	10.9 to 31.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	102	SF	\$120	\$12,240	
58787	30.0 to 52.8 feet	Driveway				REF			
14479	36.3 to 49.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	65	SF	\$40	\$2,580	
14483	53.5 to 63.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,880	
58788	61.1 to 83.3 feet	Driveway				REF			
14485	67.4 to 80.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	68	SF	\$40	\$2,700	
14489	80.9 to 82.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$220	
54188	82.0 to 83.0 feet	Vertical Change	.3	5 ft	5	REF			
40392	82.0 to 83.1 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
14490	84.0 to 85.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	7	SF	\$120	\$780	
14491	86.1 to 103.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,320	
14496	107.1 to 118.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,840	
54189	116.9 to 117.9 feet	Vertical Change	.3	5 ft	5	REF			
14501	118.5 to 119.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	7	SF	\$120	\$780	
14502	122.9 to 140.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	88	SF	\$120	\$10,560	
58789	138.5 to 161.3 feet	Driveway				REF			
14506	143.6 to 158.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	74	SF	\$40	\$2,940	
14510	162.1 to 163.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,080	
14511	163.9 to 171.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,560	
58790	169.7 to 193.0 feet	Driveway				REF			
40393	172.2 to 173.5 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
14512	175.3 to 182.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	38	SF	\$40	\$1,520	
54190	180.8 to 181.8 feet	Vertical Change	.3	5 ft	5	REF			
14514	185.8 to 190.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	22	SF	\$40	\$880	
55998	191.3 to 192.3 feet	Vertical Change	.4	5 ft	5	REF			
14516	193.6 to 194.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$660	
14517	194.7 to 198.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,980	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909231537	MONROE CT	PALM PKY	2003 MONROE CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14519	198.0 to 203.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	27	SF	\$120	\$3,180
54191	202.5 to 203.5 feet	Vertical Change	.3	5 ft	5	REF		
14521	203.8 to 210.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,080
14523	212.7 to 221.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,100
14526	221.8 to 226.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	23	SF	\$120	\$2,700
54192	222.2 to 223.2 feet	Vertical Change	.3	5 ft	5	REF		
14528	226.3 to 255.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	145	SF	\$120	\$17,400
58791	254.4 to 278.8 feet	Driveway				REF		
14537	259.6 to 266.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	32	SF	\$40	\$1,280
14540	268.3 to 276.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	39	SF	\$40	\$1,560
14543	278.7 to 281.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	16	SF	\$40	\$620
TOTAL COST FOR: E							<i>side of MONROE CT Starting at: PALM PKY</i>	\$108,920.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
W	1909231542	MONROE CT	2003 MONROE CT	PALM PKY	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
14403	0.0 to 56.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	283	SF	\$120	\$33,960	
54183	43.6 to 44.6 feet	Vertical Change	.3	5 ft	5	REF			
58781	55.2 to 78.8 feet	Driveway				REF			
55995	55.4 to 56.4 feet	Vertical Change	.4	5 ft	5	REF			
40387	57.4 to 58.5 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
14415	59.6 to 65.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	29	SF	\$40	\$1,140	
14417	65.5 to 75.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	49	SF	\$40	\$1,940	
14419	75.8 to 76.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200	
54184	77.5 to 78.5 feet	Vertical Change	.3	5 ft	5	REF			
14420	79.8 to 84.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,580	
58782	82.6 to 106.3 feet	Driveway				REF			
14422	87.5 to 93.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	31	SF	\$40	\$1,220	
14424	93.6 to 95.0 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	7	SF	\$40	\$280	
14425	98.7 to 103.5 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	24	SF	\$40	\$960	
14427	107.1 to 108.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,080	
14428	108.9 to 113.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,640	
14429	116.6 to 119.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	13	SF	\$120	\$1,560	
14430	119.7 to 130.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,300	
14432	132.4 to 157.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	126	SF	\$120	\$15,180	
54185	147.7 to 148.7 feet	Vertical Change	.3	5 ft	5	REF			
14435	160.9 to 169.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,160	
58783	167.0 to 190.4 feet	Driveway				REF			
40388	170.2 to 171.3 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
14438	172.6 to 188.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	79	SF	\$40	\$3,160	
14442	190.4 to 194.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	23	SF	\$40	\$900	
14444	194.9 to 198.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,280	
58784	197.6 to 220.5 feet	Driveway				REF			
54186	197.9 to 198.9 feet	Vertical Change	.3	5 ft	5	REF			
40389	199.8 to 201.2 feet	Running Slope	5.0-6.0%	5 ft	7	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909231542	MONROE CT	2003 MONROE CT	PALM PKY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14445	201.3 to 206.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	25	SF	\$40	\$1,000
14447	206.8 to 216.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	51	SF	\$40	\$2,020
14448	220.5 to 221.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$220
14449	232.8 to 237.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,640
14450	240.3 to 243.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740
14451	254.3 to 255.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660
14452	257.5 to 269.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,140
58785	276.7 to 300.0 feet	Driveway				REF		
14454	277.1 to 278.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$220
14455	281.8 to 296.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	74	SF	\$40	\$2,960
55996	287.4 to 288.4 feet	Vertical Change	.4	5 ft	5	REF		
55997	299.2 to 300.2 feet	Vertical Change	.4	5 ft	5	REF		
14460	305.6 to 308.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680
54187	307.6 to 308.6 feet	Vertical Change	.3	5 ft	5	REF		
58786	308.3 to 329.1 feet	Driveway				REF		
14462	312.1 to 326.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	71	SF	\$40	\$2,840
40390	327.9 to 328.9 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
14467	329.9 to 331.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$840
14468	333.7 to 339.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,420
14471	343.6 to 361.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	87	SF	\$120	\$10,440
40391	359.6 to 361.3 feet	Running Slope	5.0-6.0%	5 ft	9	REF		
TOTAL COST FOR: W side of MONROE CT Starting at: 2003 MONROE CT							\$118,360.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909231545	PALM PKY	MONROE CT	TAFT CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14361	0.0 to 13.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	69	SF	\$120	\$8,220
14364	20.2 to 46.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	133	SF	\$120	\$15,960
14371	49.3 to 50.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780
14372	52.0 to 73.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	107	SF	\$120	\$12,780
14377	77.3 to 101.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	122	SF	\$120	\$14,640
54177	95.0 to 96.0 feet	Vertical Change	.3	5 ft	5	REF		
14384	101.7 to 103.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	11	SF	\$120	\$1,260
54178	102.3 to 103.3 feet	Vertical Change	.3	5 ft	5	REF		
14385	103.8 to 111.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	40	SF	\$120	\$4,800
14387	112.8 to 121.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	43	SF	\$120	\$5,100
54179	117.9 to 118.9 feet	Vertical Change	.3	5 ft	5	REF		
14389	122.0 to 126.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,580
54180	128.3 to 129.3 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
14390	129.8 to 161.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	156	SF	\$120	\$18,780
55994	138.5 to 139.5 feet	Vertical Change	.4	5 ft	5	REF		
54181	149.3 to 150.3 feet	Vertical Change	.3	5 ft	5	REF		
14397	165.3 to 188.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	114	SF	\$120	\$13,620
54182	190.7 to 191.7 feet	Vertical Change	.3	5 ft	5	REF		
14399	191.7 to 208.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	83	SF	\$120	\$9,900
TOTAL COST FOR: N side of PALM PKY Starting at: MONROE CT							\$108,795.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1909231551	TAFT CT	PALM PKY	2006 TAFT CT	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
14259	0.0 to 29.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	148	SF	\$120	\$17,700	
14262	29.8 to 31.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	11	SF	\$120	\$1,260	
58773	30.7 to 53.3 feet	Driveway				REF			
54169	30.8 to 31.8 feet	Vertical Change	.3	5 ft	5	REF			
14263	35.7 to 50.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	72	SF	\$40	\$2,880	
56649	41.3 to 42.3 feet	Vertical Change	.5	5 ft	5	REF			
14268	50.1 to 51.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200	
54170	51.6 to 52.6 feet	Vertical Change	.3	5 ft	5	REF			
14269	52.5 to 54.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	12	SF	\$40	\$460	
14271	55.3 to 85.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	152	SF	\$120	\$18,180	
58774	84.8 to 107.8 feet	Driveway				REF			
14278	88.2 to 102.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	70	SF	\$40	\$2,780	
54171	96.0 to 97.0 feet	Vertical Change	.3	5 ft	5	REF			
14282	102.1 to 103.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	9	SF	\$40	\$340	
54172	106.1 to 107.1 feet	Vertical Change	.3	5 ft	5	REF			
14283	108.4 to 109.6 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$240	
14284	110.1 to 115.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,420	
58775	114.8 to 138.6 feet	Driveway				REF			
14286	119.0 to 135.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	81	SF	\$40	\$3,220	
14292	137.6 to 140.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	12	SF	\$40	\$480	
14294	142.4 to 189.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	238	SF	\$120	\$28,500	
14299	192.0 to 194.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440	
58776	193.0 to 215.5 feet	Driveway				REF			
14300	198.0 to 212.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	73	SF	\$40	\$2,900	
14304	212.7 to 213.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	6	SF	\$40	\$220	
14305	215.8 to 217.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	7	SF	\$40	\$260	
14306	217.4 to 229.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,380	
58777	228.6 to 252.8 feet	Driveway				REF			
40385	230.8 to 232.5 feet	Running Slope	8.0-9.0%	5 ft	9	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1909231551	TAFT CT	PALM PKY	2006 TAFT CT					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
14309	233.9 to 242.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	41	SF	\$40	\$1,640	
14311	242.7 to 249.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	32	SF	\$40	\$1,260	
40386	249.2 to 250.6 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
14314	259.1 to 260.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720	
54173	261.0 to 262.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
14315	274.5 to 275.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780	
58778	282.2 to 304.2 feet	Driveway				REF			
55992	282.4 to 283.4 feet	Vertical Change	.4	5 ft	5	REF			
14316	286.5 to 300.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	68	SF	\$40	\$2,700	
54174	294.1 to 295.1 feet	Vertical Change	.3	5 ft	5	REF			
14319	300.8 to 302.1 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	7	SF	\$40	\$260	
54175	302.8 to 303.8 feet	Vertical Change	.3	5 ft	5	REF			
14320	303.5 to 306.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	14	SF	\$40	\$560	
14322	306.3 to 313.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,500	
14324	316.4 to 342.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	131	SF	\$120	\$15,720	
14332	342.9 to 364.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	110	SF	\$120	\$13,200	
58779	363.5 to 387.0 feet	Driveway				REF			
14338	368.9 to 382.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	70	SF	\$40	\$2,780	
14344	386.6 to 390.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	19	SF	\$40	\$740	
54176	390.6 to 391.6 feet	Vertical Change	.3	5 ft	5	REF			
14346	390.6 to 398.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800	
55993	397.0 to 398.0 feet	Vertical Change	.4	5 ft	5	REF			
56	407.7 to 408.7 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
14349	409.3 to 412.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620	
14351	412.0 to 418.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	35	SF	\$120	\$4,140	
58780	417.3 to 441.2 feet	Driveway				REF			
14352	420.5 to 421.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200	
14353	421.8 to 437.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	79	SF	\$40	\$3,140	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909231551	TAFT CT	PALM PKY	2006 TAFT CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14358	440.5 to 450.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	49	SF	\$40	\$1,940
TOTAL COST FOR: E side of TAFT CT Starting at: PALM PKY							\$153,535.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
W	1909231555	TAFT CT	2010 TAFT CT	PALM PKY				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14211	0.0 to 5.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	27	SF	\$120	\$3,180
14213	5.6 to 26.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	104	SF	\$120	\$12,480
57523	12.2 to 13.2 feet	Vertical Change	2	5 ft	5	REF		
57468	21.6 to 22.6 feet	Vertical Change	1.5	5 ft	5	REF		
14218	29.5 to 58.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	144	SF	\$120	\$17,280
58770	56.4 to 78.8 feet	Driveway				REF		
55991	56.7 to 57.7 feet	Vertical Change	.4	5 ft	5	REF		
14226	61.4 to 74.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	68	SF	\$40	\$2,700
14230	78.9 to 82.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	15	SF	\$40	\$620
14231	83.5 to 87.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340
58771	86.5 to 108.9 feet	Driveway				REF		
14233	91.0 to 107.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	82	SF	\$40	\$3,280
54166	107.6 to 108.6 feet	Vertical Change	.3	5 ft	5	REF		
14237	109.2 to 119.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	51	SF	\$40	\$2,020
14241	120.2 to 131.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,720
14244	131.9 to 142.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	54	SF	\$120	\$6,480
58772	141.4 to 163.6 feet	Driveway				REF		
14248	147.5 to 159.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	59	SF	\$40	\$2,360
14251	164.1 to 191.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	139	SF	\$40	\$5,540
54167	188.3 to 191.1 feet	Vertical Change	.3	5 ft	14	REF		
14258	191.8 to 194.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
TOTAL COST FOR: W							<i>side of TAFT CT Starting at: 2010 TAFT CT</i>	\$66,500.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909231600	PALM PKY	SIDEWALK BEGINS	LINCOLN AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
14176	0.0 to 46.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	232	SF	\$120	\$27,780
14189	46.3 to 75.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	145	SF	\$120	\$17,400
54165	77.7 to 78.7 feet	Vertical Change	.3	5 ft	5	REF		
14199	77.9 to 79.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	9	SF	\$120	\$1,140
14200	80.0 to 81.5 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	8	SF	\$120	\$900
14201	82.3 to 93.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	57	SF	\$120	\$6,780
14203	94.5 to 110.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	82	SF	\$120	\$9,780
14208	110.8 to 130.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	101	SF	\$120	\$12,060
55990	129.4 to 130.4 feet	Vertical Change	.4	5 ft	5	REF		
TOTAL COST FOR: N side of PALM PKY Starting at: SIDEWALK BEGINS							\$75,840.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1909240830	TRUMAN DR	PALM PKY	ADAMS DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
20540	0.0 to 4.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,820	
20542	4.7 to 13.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	42	SF	\$120	\$5,040	
54662	5.9 to 6.9 feet	Vertical Change	.3	5 ft	5	REF			
20547	14.7 to 19.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120	
20549	20.1 to 43.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	117	SF	\$120	\$14,040	
59152	43.1 to 67.1 feet	Driveway				REF			
20556	48.8 to 63.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	73	SF	\$40	\$2,900	
20560	66.7 to 71.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	26	SF	\$40	\$1,020	
20562	71.8 to 76.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060	
59153	75.6 to 98.8 feet	Driveway				REF			
20565	81.6 to 84.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	15	SF	\$40	\$580	
20566	89.0 to 95.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	34	SF	\$40	\$1,340	
20568	99.3 to 105.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	31	SF	\$40	\$1,220	
20569	105.8 to 111.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,480	
20571	111.8 to 114.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	15	SF	\$120	\$1,740	
20573	114.8 to 118.5 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	19	SF	\$120	\$2,220	
57024	118.8 to 119.8 feet	Vertical Change	.6	5 ft	5	REF			
20575	118.8 to 121.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	13	SF	\$120	\$1,500	
20577	125.8 to 131.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,540	
59154	129.1 to 152.5 feet	Driveway				REF			
20579	135.1 to 149.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	72	SF	\$40	\$2,880	
20583	152.8 to 168.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	80	SF	\$120	\$9,600	
56158	160.7 to 161.7 feet	Vertical Change	.4	5 ft	5	REF			
20589	173.6 to 206.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	166	SF	\$120	\$19,920	
20599	208.9 to 213.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,640	
59155	214.0 to 236.8 feet	Driveway				REF			
20601	220.0 to 223.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	19	SF	\$40	\$740	
20603	223.7 to 226.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	16	SF	\$40	\$620	
20605	227.0 to 232.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	26	SF	\$40	\$1,020	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1909240830	TRUMAN DR	PALM PKY	ADAMS DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
20608	232.8 to 233.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	5	SF	\$40	\$200	
20609	240.0 to 245.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,300	
59156	244.3 to 267.1 feet	Driveway				REF			
20610	246.3 to 247.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$200	
20611	250.3 to 257.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	37	SF	\$40	\$1,480	
20614	260.1 to 263.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	16	SF	\$40	\$640	
20615	268.8 to 276.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800	
20618	281.1 to 324.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	214	SF	\$120	\$25,740	
59157	322.6 to 345.4 feet	Driveway				REF			
20627	328.0 to 341.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	67	SF	\$40	\$2,680	
20630	345.8 to 347.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$840	
20631	347.2 to 357.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,300	
59158	355.8 to 379.3 feet	Driveway				REF			
20634	361.4 to 375.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	72	SF	\$40	\$2,880	
20639	379.0 to 396.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	87	SF	\$40	\$3,460	
20644	398.2 to 399.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	7	SF	\$120	\$780	
20645	402.5 to 437.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	175	SF	\$120	\$21,000	
59159	440.0 to 463.3 feet	Driveway				REF			
20655	441.1 to 442.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$240	
40510	442.4 to 444.2 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
20656	446.1 to 459.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	68	SF	\$40	\$2,700	
20661	459.6 to 460.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	6	SF	\$40	\$220	
40511	460.4 to 461.4 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
20662	463.9 to 471.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800	
59160	471.8 to 493.9 feet	Driveway				REF			
20666	471.9 to 473.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	6	SF	\$40	\$220	
40512	472.9 to 475.2 feet	Running Slope	5.0-6.0%	5 ft	12	REF			
20667	477.1 to 479.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	13	SF	\$40	\$500	
20669	479.6 to 483.3 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	19	SF	\$40	\$740	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1909240830	TRUMAN DR	PALM PKY	ADAMS DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
20671	485.4 to 489.6 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	21	SF	\$40	\$840	
20674	496.1 to 527.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	156	SF	\$120	\$18,660	
20681	527.2 to 546.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	97	SF	\$120	\$11,640	
20686	546.6 to 561.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	75	SF	\$120	\$9,000	
59161	559.0 to 582.6 feet	Driveway				REF			
40513	560.9 to 562.8 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
20691	565.2 to 579.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	73	SF	\$40	\$2,920	
20694	583.0 to 590.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	36	SF	\$40	\$1,460	
59162	590.2 to 613.3 feet	Driveway				REF			
20696	595.3 to 600.1 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	24	SF	\$40	\$960	
20698	600.1 to 608.5 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	42	SF	\$40	\$1,680	
20702	608.7 to 609.9 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	6	SF	\$40	\$240	
54663	611.5 to 612.5 feet	Vertical Change	.3	5 ft	5	REF			
20703	613.8 to 621.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	39	SF	\$120	\$4,620	
20705	624.4 to 634.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	51	SF	\$120	\$6,120	
20708	638.9 to 640.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$840	
20709	640.7 to 667.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	134	SF	\$120	\$16,140	
54664	644.8 to 645.8 feet	Vertical Change	.3	5 ft	5	REF			
20714	671.1 to 677.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020	
20716	677.8 to 694.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	86	SF	\$120	\$10,260	
20718	694.9 to 710.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	80	SF	\$120	\$9,540	
72	700.3 to 701.3 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
54665	709.7 to 710.7 feet	Vertical Change	.3	5 ft	5	REF			
59163	710.0 to 735.8 feet	Driveway				REF			
40514	710.8 to 712.2 feet	Running Slope	6.0-7.0%	5 ft	7	REF			
20720	715.3 to 726.5 feet	Cross Slope (Driveway)	13.014	5 ft	56	SF	\$40	\$2,240	
20725	727.3 to 732.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	25	SF	\$40	\$1,000	
20727	736.1 to 737.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$240	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909240830	TRUMAN DR	PALM PKY	ADAMS DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
20728	738.0 to 750.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	64	SF	\$120	\$7,680
54666	739.8 to 740.8 feet	Vertical Change	.3	5 ft	5	REF		
59164	748.8 to 776.3 feet	Driveway				REF		
20731	756.4 to 761.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	24	SF	\$40	\$940
20733	762.5 to 771.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	47	SF	\$40	\$1,860
40515	774.3 to 775.5 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
56703	775.4 to 776.4 feet	Vertical Change	.5	5 ft	5	REF		
20735	776.3 to 798.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	112	SF	\$40	\$4,460
20741	798.6 to 799.7 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	6	SF	\$120	\$660
20742	801.4 to 810.8 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	47	SF	\$120	\$5,640
20747	816.5 to 819.5 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	15	SF	\$120	\$1,800
20749	819.5 to 828.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	45	SF	\$120	\$5,400
20751	829.7 to 836.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,260
59165	833.8 to 861.2 feet	Driveway				REF		
20753	836.8 to 837.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	6	SF	\$40	\$220
40516	837.9 to 839.3 feet	Running Slope	5.0-6.0%	5 ft	7	REF		
20754	840.0 to 844.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	22	SF	\$40	\$860
20756	844.3 to 857.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	66	SF	\$40	\$2,620
54667	859.8 to 860.8 feet	Vertical Change	.3	5 ft	5	REF		
20761	860.8 to 861.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200
20762	863.3 to 914.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	255	SF	\$120	\$30,600
54668	898.8 to 899.8 feet	Vertical Change	.3	5 ft	5	REF		
20774	918.2 to 929.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	54	SF	\$120	\$6,480
20776	931.9 to 965.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	167	SF	\$120	\$20,040
59166	963.0 to 989.6 feet	Driveway				REF		
20783	969.1 to 985.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	84	SF	\$40	\$3,340
54669	988.5 to 989.5 feet	Vertical Change	.3	5 ft	5	REF		
20787	990.0 to 991.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909240830	TRUMAN DR	PALM PKY	ADAMS DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
20788	991.4 to 997.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,720
TOTAL COST FOR: E side of TRUMAN DR Starting at: PALM PKY							\$372,760.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1909240838	TRUMAN DR	ADAMS DR	WILSON WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
20439	0.0 to 8.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	40	SF	\$120	\$4,800	
59146	5.3 to 31.7 feet	Driveway				REF			
20441	10.5 to 20.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	49	SF	\$40	\$1,940	
20445	24.8 to 27.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	13	SF	\$40	\$520	
20446	32.8 to 45.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	64	SF	\$120	\$7,680	
20448	46.6 to 61.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	76	SF	\$120	\$9,120	
54653	58.3 to 59.3 feet	Vertical Change	.3	5 ft	5	REF			
20451	63.9 to 66.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	15	SF	\$120	\$1,740	
20452	67.7 to 78.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,300	
20454	85.2 to 86.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960	
59147	90.1 to 117.6 feet	Driveway				REF			
20455	91.4 to 92.7 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	7	SF	\$40	\$260	
40503	92.8 to 94.1 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
20456	97.3 to 106.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	45	SF	\$40	\$1,800	
20459	109.0 to 114.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	27	SF	\$40	\$1,080	
20461	117.9 to 129.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	60	SF	\$40	\$2,380	
20464	129.8 to 158.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	141	SF	\$120	\$16,980	
54654	139.5 to 140.5 feet	Vertical Change	.3	5 ft	5	REF			
20470	160.0 to 161.7 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	8	SF	\$120	\$1,020	
54655	161.2 to 162.2 feet	Vertical Change	.3	5 ft	5	REF			
20471	162.5 to 165.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	15	SF	\$120	\$1,740	
20472	165.4 to 205.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	199	SF	\$120	\$23,820	
54656	172.0 to 173.0 feet	Vertical Change	.3	5 ft	5	REF			
54657	188.0 to 189.0 feet	Vertical Change	.3	5 ft	5	REF			
54658	204.4 to 205.4 feet	Vertical Change	.3	5 ft	5	REF			
20481	208.5 to 210.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320	
20482	215.0 to 221.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,960	
59148	220.8 to 246.9 feet	Driveway				REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909240838	TRUMAN DR	ADAMS DR	WILSON WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54659	221.6 to 222.6 feet	Vertical Change	.3	5 ft	5	REF		
40504	223.3 to 224.9 feet	Running Slope	6.0-7.0%	5 ft	8	REF		
20484	226.1 to 233.7 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	38	SF	\$40	\$1,520
20486	237.2 to 244.0 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	34	SF	\$40	\$1,360
20488	246.7 to 253.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	35	SF	\$40	\$1,400
54660	250.4 to 251.4 feet	Vertical Change	.3	5 ft	5	REF		
54661	255.1 to 256.1 feet	Vertical Change	.3	5 ft	5	REF		
70	255.3 to 256.3 feet	Continuous Width		5 ft	5	SF	\$120	\$600
20492	255.8 to 266.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,300
59149	264.2 to 291.8 feet	Driveway				REF		
20495	266.3 to 267.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	6	SF	\$40	\$240
40505	267.4 to 269.4 feet	Running Slope	5.0-6.0%	5 ft	10	REF		
20496	271.2 to 274.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	17	SF	\$40	\$680
20498	274.6 to 285.9 feet	Cross Slope (Driveway)	13.014	5 ft	56	SF	\$40	\$2,260
20500	291.5 to 311.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	98	SF	\$40	\$3,900
20506	311.0 to 327.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	83	SF	\$120	\$9,960
56157	324.5 to 325.5 feet	Vertical Change	.4	5 ft	5	REF		
20511	334.3 to 338.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,640
71	338.6 to 339.6 feet	Continuous Width		5 ft	5	SF	\$120	\$600
20512	348.1 to 372.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	123	SF	\$120	\$14,700
20516	411.1 to 413.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
59150	411.3 to 440.7 feet	Driveway				REF		
40506	414.3 to 415.7 feet	Running Slope	6.0-7.0%	5 ft	7	REF		
20518	416.5 to 430.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	68	SF	\$40	\$2,720
20520	430.4 to 437.3 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	35	SF	\$40	\$1,380
40507	437.8 to 440.1 feet	Running Slope	7.0-8.0%	5 ft	12	REF		
56702	439.3 to 440.3 feet	Vertical Change	.5	5 ft	5	REF		
20523	442.6 to 454.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	61	SF	\$120	\$7,260

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909240838	TRUMAN DR	ADAMS DR	WILSON WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
20526	456.8 to 468.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	61	SF	\$120	\$7,260
20529	477.9 to 502.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	124	SF	\$120	\$14,820
59151	500.3 to 524.0 feet	Driveway				REF		
40509	502.1 to 503.8 feet	Running Slope	7.0-8.0%	5 ft	9	REF		
20533	508.4 to 521.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	64	SF	\$40	\$2,580
20539	521.3 to 524.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	17	SF	\$40	\$660
TOTAL COST FOR: E							side of TRUMAN DR Starting at: ADAMS DR	\$171,760.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909240844	TRUMAN DR	1537 TRUMAN DR	FREE WILL BAPTIST CHURCH	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59144	0.5 to 14.0 feet	Driveway				REF		
20404	1.0 to 8.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	39	SF	\$40	\$1,560
54650	8.6 to 9.6 feet	Vertical Change	.3	5 ft	5	REF		
20406	20.2 to 21.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
54651	21.2 to 22.2 feet	Vertical Change	.3	5 ft	5	REF		
20407	22.9 to 24.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	7	SF	\$120	\$780
20408	28.0 to 47.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	98	SF	\$120	\$11,700
59145	29.3 to 179.5 feet	Driveway				REF		
20414	65.0 to 73.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	40	SF	\$40	\$1,620
20415	75.3 to 89.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	71	SF	\$40	\$2,840
20419	89.5 to 95.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	32	SF	\$40	\$1,260
20420	98.8 to 108.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	47	SF	\$40	\$1,880
20423	110.3 to 120.1 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	49	SF	\$40	\$1,960
20426	120.1 to 122.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	14	SF	\$40	\$540
20427	122.8 to 131.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	44	SF	\$40	\$1,780
20430	134.7 to 136.6 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	10	SF	\$40	\$380
20431	137.3 to 142.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	25	SF	\$40	\$1,000
20433	145.8 to 154.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	43	SF	\$40	\$1,700
20435	174.6 to 179.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	25	SF	\$40	\$1,000
54652	178.1 to 179.1 feet	Vertical Change	.3	5 ft	5	REF		

TOTAL COST FOR:	E	<i>side of</i>	TRUMAN DR	<i>Starting at:</i>	1537 TRUMAN DR	\$30,600.00
------------------------	----------	----------------	------------------	---------------------	-----------------------	--------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909240846	TRUMAN DR	SIDEWALK BEGINS	1513 TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
20375	0.0 to 12.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	51	SF	\$120	\$6,144
20377	12.8 to 23.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	42	SF	\$120	\$5,040
20380	23.3 to 34.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	45	SF	\$120	\$5,376
59143	33.7 to 45.4 feet	Driveway				REF		
20385	34.7 to 40.7 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	24	SF	\$40	\$960
20388	40.7 to 52.8 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	48	SF	\$40	\$1,936
54648	46.1 to 47.1 feet	Vertical Change	.3	4 ft	4	REF		
20392	52.8 to 60.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	30	SF	\$120	\$3,600
54649	58.4 to 59.4 feet	Vertical Change	.3	4 ft	4	REF		
20395	60.3 to 100.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	160	SF	\$120	\$19,200
56701	100.9 to 101.9 feet	Vertical Change	.5	4 ft	4	SF	\$75	\$300
TOTAL COST FOR: E side of TRUMAN DR Starting at: SIDEWALK BEGINS							\$42,556.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909240850	TRUMAN DR	1513 TRUMAN DR	15TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
20354	0.0 to 79.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	319	SF	\$120	\$38,256
59142	0.3 to 85.9 feet	Driveway				REF		
54646	40.1 to 41.1 feet	Vertical Change	.3	4 ft	4	REF		
54647	44.1 to 45.1 feet	Vertical Change	.3	4 ft	4	REF		
20372	81.3 to 87.4 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	24	SF	\$40	\$976
56156	86.1 to 87.1 feet	Vertical Change	.4	4 ft	4	REF		
TOTAL COST FOR: E							<i>side of TRUMAN DR Starting at: 1513 TRUMAN DR</i>	\$39,232.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909240852	TRUMAN DR	15TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54642	1.6 to 2.6 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
20335	6.8 to 14.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	32	SF	\$120	\$3,840
20338	14.8 to 39.2 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	98	SF	\$120	\$11,712
54643	16.6 to 17.6 feet	Vertical Change	.3	4 ft	4	REF		
57022	31.4 to 32.4 feet	Vertical Change	.6	4 ft	4	REF		
20347	39.8 to 53.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	54	SF	\$120	\$6,528
57023	46.6 to 47.6 feet	Vertical Change	.6	4 ft	4	REF		
54644	54.5 to 58.4 feet	Vertical Change	.3	4 ft	16	LF	\$75	\$1,170
20353	59.8 to 62.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	12	SF	\$120	\$1,392
56155	61.3 to 62.3 feet	Vertical Change	.4	4 ft	4	REF		
TOTAL COST FOR: W side of TRUMAN DR Starting at: 15TH ST							\$24,942.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909240855	TRUMAN DR	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
20318	0.8 to 30.8 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	240	SF	\$120	\$28,800
20325	30.8 to 33.8 feet	Cross Slope (PAR)	6.0-7.0%	8 ft	24	SF	\$120	\$2,880
20326	33.8 to 56.8 feet	Cross Slope (PAR)	5.0-6.0%	8 ft	184	SF	\$120	\$22,080
54640	43.7 to 44.7 feet	Vertical Change	.3	8 ft	8	REF		
20330	58.9 to 66.1 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	58	SF	\$120	\$6,912
54641	64.3 to 65.3 feet	Vertical Change	.3	8 ft	8	REF		
20333	66.1 to 70.5 feet	Cross Slope (PAR)	6.0-7.0%	8 ft	35	SF	\$120	\$4,224
TOTAL COST FOR: W side of TRUMAN DR Starting at: SIDEWALK BEGINS							\$64,896.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909240859	TRUMAN DR	SIDEWALK BEGINS	1526 TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40500	0.3 to 3.7 feet	Running Slope	6.0-7.0%	4 ft	14	REF		
20284	0.7 to 4.5 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	15	SF	\$120	\$1,824
54634	2.6 to 9.9 feet	Vertical Change	.3	4 ft	29	REF		
20285	6.7 to 8.8 feet	Cross Slope (PAR)	8.0-9.0%	4 ft	8	SF	\$120	\$1,008
40502	8.8 to 10.3 feet	Running Slope	5.0-6.0%	4 ft	6	REF		
20287	10.6 to 12.3 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	7	SF	\$120	\$816
54637	12.0 to 14.7 feet	Vertical Change	.3	4 ft	11	REF		
20288	15.2 to 25.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	40	SF	\$120	\$4,848
20291	27.6 to 30.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	11	SF	\$120	\$1,296
20292	30.3 to 33.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	13	SF	\$120	\$1,584
20294	33.6 to 37.5 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	16	SF	\$120	\$1,872
20297	37.9 to 40.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	12	SF	\$120	\$1,440
20298	44.8 to 52.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	30	SF	\$120	\$3,600
20300	52.3 to 66.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	56	SF	\$120	\$6,720
56154	55.8 to 56.8 feet	Vertical Change	.4	4 ft	4	REF		
20303	68.3 to 69.8 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	6	SF	\$120	\$720
20304	70.2 to 91.5 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	85	SF	\$120	\$10,224
20307	93.1 to 107.2 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	56	SF	\$120	\$6,768
54639	107.6 to 108.6 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
20310	108.9 to 130.0 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	84	SF	\$120	\$10,128
59141	110.1 to 122.0 feet	Driveway				REF		
57550	114.3 to 115.3 feet	Vertical Change	2.3	4 ft	4	REF		
20314	133.1 to 136.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	13	SF	\$120	\$1,536
20316	139.8 to 145.5 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	23	SF	\$120	\$2,736
TOTAL COST FOR: W side of TRUMAN DR Starting at: SIDEWALK BEGINS							\$57,420.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909240905	WILSON WAY	TRUMAN DR	HARDING AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
20242	12.0 to 31.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	74	SF	\$120	\$8,910
20245	32.7 to 38.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	21	SF	\$120	\$2,520
20248	38.9 to 45.1 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	23	SF	\$120	\$2,790
20250	45.1 to 60.6 feet	Cross Slope (PAR)	8.0-9.0%	4 ft	58	SF	\$120	\$6,975
20257	62.5 to 68.3 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	22	SF	\$120	\$2,610
20258	69.9 to 79.5 feet	Cross Slope (PAR)	8.0-9.0%	4 ft	36	SF	\$120	\$4,320
56153	81.4 to 82.4 feet	Vertical Change	.4	4 ft	4	LF	\$75	\$281
20262	82.6 to 84.9 feet	Cross Slope (PAR)	13.014	4 ft	9	SF	\$120	\$1,035
54632	85.0 to 88.3 feet	Vertical Change	.3	4 ft	12	LF	\$75	\$928
20264	88.2 to 93.2 feet	Cross Slope (PAR)	7.0-8.0%	4 ft	19	SF	\$120	\$2,250
20266	96.1 to 98.7 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	10	SF	\$120	\$1,170
20268	100.6 to 122.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	82	SF	\$120	\$9,810
20276	127.3 to 129.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	10	SF	\$120	\$1,170
20278	129.9 to 142.9 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	49	SF	\$120	\$5,850
20283	144.2 to 147.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	13	SF	\$120	\$1,530
TOTAL COST FOR: N side of WILSON WAY Starting at: TRUMAN DR							\$52,149.38	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909240908	HARDING AVE	WILSON WAY	525 HARDING AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
20230	2.7 to 11.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	34	SF	\$120	\$4,128
20233	13.9 to 21.4 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	30	SF	\$120	\$3,600
20235	24.2 to 46.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	90	SF	\$120	\$10,800
59140	28.1 to 47.3 feet	Driveway				REF		
TOTAL COST FOR: E side of HARDING AVE Starting at: WILSON WAY							\$18,528.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909240911	HARDING AVE	1529 HARDING AVE	1525 HARDING AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
20199	0.0 to 2.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	11	SF	\$120	\$1,380
20200	2.3 to 8.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,600
59138	2.9 to 28.4 feet	Driveway				REF		
20201	10.4 to 14.7 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	22	SF	\$40	\$860
20203	14.7 to 32.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	89	SF	\$40	\$3,560
56152	30.8 to 31.8 feet	Vertical Change	.4	5 ft	5	REF		
57630	45.3 to 46.3 feet	Vertical Change	3.3	5 ft	5	SF	\$75	\$375
20207	48.4 to 64.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	82	SF	\$120	\$9,840
54631	61.5 to 62.5 feet	Vertical Change	.3	5 ft	5	REF		
20209	67.5 to 101.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	170	SF	\$120	\$20,400
59139	85.8 to 104.9 feet	Driveway				REF		
20217	104.7 to 106.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$260
20218	106.9 to 152.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	229	SF	\$120	\$27,420
40499	149.4 to 150.4 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
TOTAL COST FOR: E side of HARDING AVE Starting at: 1529 HARDING AVE							\$67,695.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1909240916	HARDING AVE	1517 HARDING AVE	1517 HARDING AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
57256	5.2 to 6.2 feet	Vertical Change	.8	5 ft	5	SF	\$75	\$375	
20186	22.4 to 44.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	113	SF	\$120	\$13,500	
20193	49.5 to 70.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	103	SF	\$120	\$12,360	
59137	50.6 to 70.9 feet	Driveway				REF			
TOTAL COST FOR:		E	side of HARDING AVE Starting at: 1517 HARDING AVE						\$26,235.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909240918	HARDING AVE	SIDEWALK BEGINS	1509 HARDING AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59135	0.4 to 14.4 feet	Driveway				REF		
59136	21.2 to 49.2 feet	Driveway				REF		
20168	21.3 to 23.6 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	9	SF	\$40	\$368
20170	23.6 to 29.2 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	22	SF	\$40	\$896
20172	29.2 to 30.4 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	5	SF	\$40	\$192
20173	30.4 to 36.2 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	23	SF	\$40	\$928
20176	37.2 to 40.1 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	12	SF	\$40	\$464
57176	38.7 to 39.7 feet	Vertical Change	.7	4 ft	4	REF		
56699	42.0 to 43.0 feet	Vertical Change	.5	4 ft	4	REF		
20178	47.0 to 59.8 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	51	SF	\$40	\$2,048
20182	59.8 to 67.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	31	SF	\$120	\$3,696
20185	80.8 to 85.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	17	SF	\$120	\$2,064
TOTAL COST FOR: E side of HARDING AVE Starting at: SIDEWALK BEGINS							\$10,656.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909240921	HARDING AVE	1505 HARDING AVE	15TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
20154	0.0 to 3.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	12	SF	\$120	\$1,440
59134	0.3 to 15.2 feet	Driveway				REF		
20155	17.3 to 24.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	28	SF	\$120	\$3,360
56151	26.5 to 27.5 feet	Vertical Change	.4	4 ft	4	LF	\$75	\$300
20158	36.0 to 38.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	11	SF	\$120	\$1,344
57306	42.9 to 43.9 feet	Vertical Change	.9	4 ft	4	SF	\$75	\$300
57175	48.1 to 49.1 feet	Vertical Change	.7	4 ft	4	SF	\$75	\$300
57383	52.8 to 53.8 feet	Vertical Change	1.1	4 ft	4	SF	\$75	\$300
20160	64.3 to 72.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	32	SF	\$120	\$3,840
57591	68.8 to 69.8 feet	Vertical Change	2.9	4 ft	4	REF		
20163	72.8 to 90.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	69	SF	\$120	\$8,256
57307	83.1 to 84.1 feet	Vertical Change	.9	4 ft	4	REF		
TOTAL COST FOR: E side of HARDING AVE Starting at: 1505 HARDING AVE							\$19,440.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909240926	HARDING AVE	15TH ST	1508 HARDING AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54622	17.9 to 18.9 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
20142	21.4 to 23.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	8	SF	\$120	\$960
54623	35.0 to 36.0 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
20143	66.8 to 69.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	10	SF	\$120	\$1,248
54624	71.5 to 72.5 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
54625	93.4 to 94.4 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
20144	108.8 to 144.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	144	SF	\$120	\$17,232
54626	112.0 to 113.0 feet	Vertical Change	.3	4 ft	4	REF		
59133	118.0 to 176.4 feet	Driveway				REF		
54627	129.8 to 130.8 feet	Vertical Change	.3	4 ft	4	REF		
54628	149.2 to 150.2 feet	Vertical Change	.3	4 ft	4	REF		
20153	161.9 to 174.0 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	48	SF	\$40	\$1,936
54629	166.3 to 169.6 feet	Vertical Change	.3	4 ft	13	REF		
TOTAL COST FOR: W side of HARDING AVE Starting at: 15TH ST							\$22,576.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909240929	HARDING AVE	1520 HARDING AVE	1520 HARDING AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59132	0.2 to 24.1 feet	Driveway				REF		
20140	42.5 to 44.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	9	SF	\$120	\$1,056
20141	63.8 to 66.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	10	SF	\$120	\$1,152
TOTAL COST FOR: W side of HARDING AVE Starting at: 1520 HARDING AVE							\$2,208.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909240932	HARDING AVE	1528 HARDING AVE	1528 HARDING AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
20126	0.0 to 11.0 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	41	SF	\$120	\$4,950
54621	7.4 to 8.4 feet	Vertical Change	.3	4 ft	4	REF		
20127	11.2 to 30.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	73	SF	\$120	\$8,775
20132	31.4 to 34.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	13	SF	\$120	\$1,530
20134	34.8 to 51.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	62	SF	\$120	\$7,425
59131	47.8 to 75.5 feet	Driveway				REF		
56698	63.1 to 64.1 feet	Vertical Change	.5	4 ft	4	REF		
20139	71.4 to 75.7 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	16	SF	\$40	\$645
TOTAL COST FOR: W side of HARDING AVE Starting at: 1528 HARDING AVE							\$23,325.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909240937	WILSON WAY	SIDEWALK BEGINS	COOLIDGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54611	2.4 to 5.5 feet	Vertical Change	.3	4 ft	12	LF	\$75	\$930
20100	5.8 to 13.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	30	SF	\$120	\$3,648
57629	8.0 to 9.0 feet	Vertical Change	3.3	4 ft	4	REF		
54613	14.3 to 18.2 feet	Vertical Change	.3	4 ft	16	LF	\$75	\$1,170
20102	17.8 to 27.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	40	SF	\$120	\$4,800
54615	20.7 to 21.7 feet	Vertical Change	.3	4 ft	4	REF		
20105	39.1 to 40.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	6	SF	\$120	\$768
20106	42.9 to 48.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	23	SF	\$120	\$2,784
20108	50.9 to 58.5 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	30	SF	\$120	\$3,648
54616	59.7 to 60.7 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
20110	61.0 to 67.6 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	26	SF	\$120	\$3,168
54617	65.4 to 66.4 feet	Vertical Change	.3	4 ft	4	REF		
20113	67.6 to 71.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	14	SF	\$120	\$1,632
59130	70.6 to 90.4 feet	Driveway				REF		
20114	74.4 to 79.0 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	18	SF	\$40	\$736
20116	79.0 to 87.0 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	32	SF	\$40	\$1,280
20119	87.0 to 95.1 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	32	SF	\$40	\$1,296
54618	118.7 to 121.4 feet	Vertical Change	.3	4 ft	11	REF		
20121	119.1 to 134.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	61	SF	\$120	\$7,344
57583	138.7 to 139.7 feet	Vertical Change	2.8	4 ft	4	SF	\$75	\$300
20125	146.6 to 148.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	9	SF	\$120	\$1,056
54620	150.9 to 151.9 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
TOTAL COST FOR: N side of WILSON WAY Starting at: SIDEWALK BEGINS							\$35,160.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909240940	COOLIDGE AVE	WILSON WAY	1537 COOLIDGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
20097	0.7 to 1.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$576
20098	8.3 to 12.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	18	SF	\$120	\$2,112
TOTAL COST FOR:		E	<i>side of</i> COOLIDGE AVE	<i>Starting at:</i> WILSON WAY				\$2,688.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1909240948	COOLIDGE AVE	1537 COOLIDGE AVE	15TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
19919	0.0 to 60.0 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	240	SF	\$120	\$28,800	
54601	17.7 to 18.7 feet	Vertical Change	.3	4 ft	4	REF			
59121	32.3 to 46.7 feet	Driveway				REF			
19935	62.3 to 64.6 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	9	SF	\$120	\$1,104	
19936	64.6 to 78.5 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	56	SF	\$120	\$6,672	
19939	78.5 to 80.3 feet	Cross Slope (PAR)	8.0-9.0%	4 ft	7	SF	\$120	\$864	
57173	79.1 to 80.1 feet	Vertical Change	.7	4 ft	4	REF			
19940	80.9 to 82.4 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	6	SF	\$120	\$720	
19941	82.4 to 84.5 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	8	SF	\$120	\$1,008	
19942	84.7 to 86.1 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	6	SF	\$120	\$672	
19943	86.4 to 93.5 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	28	SF	\$120	\$3,408	
57018	94.5 to 95.5 feet	Vertical Change	.6	4 ft	4	SF	\$75	\$300	
19944	98.8 to 102.2 feet	Cross Slope (PAR)	7.0-8.0%	4 ft	14	SF	\$120	\$1,632	
19946	102.7 to 112.4 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	39	SF	\$120	\$4,656	
59122	103.4 to 119.4 feet	Driveway				REF			
19949	115.9 to 117.3 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	6	SF	\$40	\$224	
19950	119.0 to 124.3 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	21	SF	\$40	\$848	
19952	124.3 to 144.1 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	79	SF	\$120	\$9,504	
19957	144.1 to 148.9 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	19	SF	\$120	\$2,304	
19960	150.7 to 152.6 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	8	SF	\$120	\$912	
19961	152.8 to 156.7 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	16	SF	\$120	\$1,872	
19962	159.0 to 161.8 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	11	SF	\$120	\$1,344	
19963	161.8 to 166.8 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	20	SF	\$120	\$2,400	
19965	166.8 to 170.0 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	13	SF	\$120	\$1,536	
19967	170.5 to 176.4 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	24	SF	\$120	\$2,832	
19968	176.6 to 177.6 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	4	SF	\$120	\$480	
19969	177.9 to 180.5 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	10	SF	\$120	\$1,248	
19970	181.1 to 184.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	13	SF	\$120	\$1,536	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909240948	COOLIDGE AVE	1537 COOLIDGE AVE	15TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59123	184.7 to 201.3 feet	Driveway				REF		
19971	185.2 to 186.5 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	5	SF	\$40	\$208
19972	188.6 to 189.8 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	5	SF	\$40	\$192
19973	189.8 to 194.1 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	17	SF	\$40	\$688
19975	196.2 to 199.4 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	13	SF	\$40	\$512
19977	205.7 to 207.3 feet	Cross Slope (PAR)	8.0-9.0%	4 ft	6	SF	\$120	\$768
57019	211.0 to 212.0 feet	Vertical Change	.6	4 ft	4	SF	\$75	\$300
59124	213.3 to 224.2 feet	Driveway				REF		
19978	215.2 to 224.4 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	37	SF	\$40	\$1,472
19982	229.0 to 232.1 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	12	SF	\$120	\$1,488
56147	231.4 to 232.4 feet	Vertical Change	.4	4 ft	4	REF		
19983	233.4 to 252.8 feet	Cross Slope (PAR)	7.0-8.0%	4 ft	78	SF	\$120	\$9,312
57481	234.4 to 235.4 feet	Vertical Change	1.6	4 ft	4	REF		
56148	247.2 to 248.2 feet	Vertical Change	.4	4 ft	4	REF		
19990	257.0 to 259.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	9	SF	\$120	\$1,104
57020	275.0 to 276.0 feet	Vertical Change	.6	4 ft	4	SF	\$75	\$300
19991	276.8 to 291.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	59	SF	\$120	\$7,056
19995	291.8 to 297.6 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	23	SF	\$120	\$2,784
19998	299.2 to 314.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	61	SF	\$120	\$7,344
54602	306.4 to 307.4 feet	Vertical Change	.3	4 ft	4	REF		
20003	314.5 to 317.2 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	11	SF	\$120	\$1,296
20004	322.0 to 328.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	25	SF	\$120	\$3,024
20006	329.7 to 350.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	81	SF	\$120	\$9,744
59125	334.1 to 358.5 feet	Driveway				REF		
54603	344.3 to 345.3 feet	Vertical Change	.3	4 ft	4	REF		
54604	363.3 to 366.0 feet	Vertical Change	.3	4 ft	11	LF	\$75	\$810
57021	366.7 to 367.7 feet	Vertical Change	.6	4 ft	4	SF	\$75	\$300
54606	368.7 to 373.6 feet	Vertical Change	.3	4 ft	20	LF	\$75	\$1,470

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909240948	COOLIDGE AVE	1537 COOLIDGE AVE	15TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
20011	383.0 to 393.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	42	SF	\$120	\$5,088
20014	393.6 to 406.1 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	50	SF	\$120	\$6,000
54607	397.5 to 398.5 feet	Vertical Change	.3	4 ft	4	REF		
20019	406.8 to 454.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	192	SF	\$120	\$23,040
57565	413.6 to 414.6 feet	Vertical Change	2.5	4 ft	4	REF		
59126	417.2 to 427.6 feet	Driveway				REF		
54608	418.1 to 419.1 feet	Vertical Change	.3	4 ft	4	REF		
20031	460.7 to 473.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	50	SF	\$120	\$6,048
54609	474.9 to 475.9 feet	Vertical Change	.3	4 ft	4	REF		
20035	475.4 to 476.5 feet	Cross Slope (PAR)	7.0-8.0%	4 ft	4	SF	\$120	\$528
20036	479.4 to 507.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	113	SF	\$120	\$13,584
59127	484.3 to 501.0 feet	Driveway				REF		
20043	507.7 to 537.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	120	SF	\$120	\$14,352
59128	512.3 to 522.3 feet	Driveway				REF		
57622	524.2 to 525.2 feet	Vertical Change	3.2	4 ft	4	REF		
54610	541.4 to 542.4 feet	Vertical Change	.3	4 ft	4	REF		
20049	542.3 to 553.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	44	SF	\$120	\$5,280
20054	553.3 to 563.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	39	SF	\$120	\$4,656
20057	564.3 to 570.4 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	24	SF	\$120	\$2,928
20059	575.3 to 581.8 feet	Cross Slope (PAR)	10.0-11.0%	4 ft	26	SF	\$120	\$3,120
20063	581.8 to 592.9 feet	Cross Slope (PAR)	12.0-13.0%	4 ft	44	SF	\$120	\$5,328
20066	592.9 to 602.4 feet	Cross Slope (PAR)	10.0-11.0%	4 ft	38	SF	\$120	\$4,560
57305	603.0 to 604.0 feet	Vertical Change	.9	4 ft	4	SF	\$75	\$300
20068	605.8 to 618.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	50	SF	\$120	\$6,000
56150	620.6 to 621.6 feet	Vertical Change	.4	4 ft	4	REF		
20071	620.7 to 622.2 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	6	SF	\$120	\$720
20072	624.0 to 633.5 feet	Cross Slope (PAR)	7.0-8.0%	4 ft	38	SF	\$120	\$4,560
20075	633.5 to 642.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	35	SF	\$120	\$4,224
59129	633.7 to 673.3 feet	Driveway				REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909240948	COOLIDGE AVE	1537 COOLIDGE AVE	15TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
20079	642.3 to 661.4 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	76	SF	\$40	\$3,056
20084	662.1 to 673.7 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	46	SF	\$40	\$1,856
20087	673.8 to 749.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	302	SF	\$120	\$36,240
57174	683.2 to 684.2 feet	Vertical Change	.7	4 ft	4	REF		
20096	749.3 to 751.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	8	SF	\$120	\$960
TOTAL COST FOR: E side of COOLIDGE AVE Starting at: 1537 COOLIDGE AVE							\$279,476.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909240955	COOLIDGE AVE	15TH ST	1524 COOLIDGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
19817	16.5 to 19.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	11	SF	\$120	\$1,296
56143	21.5 to 22.5 feet	Vertical Change	.4	4 ft	4	LF	\$75	\$300
19818	29.7 to 45.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	62	SF	\$120	\$7,392
19822	48.4 to 52.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,872
54594	62.5 to 63.5 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
19823	72.8 to 92.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	80	SF	\$120	\$9,552
54595	72.9 to 73.9 feet	Vertical Change	.3	4 ft	4	REF		
19829	93.0 to 117.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	97	SF	\$120	\$11,664
19831	117.6 to 142.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	98	SF	\$120	\$11,808
59115	126.7 to 143.2 feet	Driveway				REF		
19835	142.2 to 166.3 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	96	SF	\$40	\$3,856
59116	157.4 to 167.3 feet	Driveway				REF		
57016	165.2 to 166.2 feet	Vertical Change	.6	4 ft	4	REF		
19840	166.5 to 168.7 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	9	SF	\$40	\$352
19841	168.9 to 209.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	164	SF	\$120	\$19,632
54596	207.6 to 208.6 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
19848	214.3 to 229.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	60	SF	\$120	\$7,200
19852	232.4 to 240.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	33	SF	\$120	\$3,984
56144	242.5 to 243.5 feet	Vertical Change	.4	4 ft	4	LF	\$75	\$300
19855	244.0 to 248.0 feet	Cross Slope (PAR)	10.0-11.0%	4 ft	16	SF	\$120	\$1,920
19857	248.0 to 253.7 feet	Cross Slope (PAR)	8.0-9.0%	4 ft	23	SF	\$120	\$2,736
19859	254.8 to 257.3 feet	Cross Slope (PAR)	10.0-11.0%	4 ft	10	SF	\$120	\$1,200
19860	260.8 to 285.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	100	SF	\$120	\$12,000
59117	283.3 to 306.7 feet	Driveway				REF		
19866	286.9 to 294.8 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	32	SF	\$40	\$1,264
54597	287.0 to 288.0 feet	Vertical Change	.3	4 ft	4	REF		
19869	295.3 to 309.7 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	58	SF	\$40	\$2,304
19873	310.8 to 328.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	71	SF	\$120	\$8,544

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909240955	COOLIDGE AVE	15TH ST	1524 COOLIDGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56145	319.2 to 322.0 feet	Vertical Change	.4	4 ft	11	REF		
19878	329.0 to 395.5 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	266	SF	\$120	\$31,920
54598	349.9 to 350.9 feet	Vertical Change	.3	4 ft	4	REF		
59118	358.1 to 376.7 feet	Driveway				REF		
57172	388.0 to 389.0 feet	Vertical Change	.7	4 ft	4	REF		
19894	396.8 to 421.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	97	SF	\$120	\$11,664
54599	411.6 to 412.6 feet	Vertical Change	.3	4 ft	4	REF		
19901	422.1 to 436.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	59	SF	\$120	\$7,056
19905	436.8 to 438.1 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	5	SF	\$120	\$624
19906	439.0 to 440.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	5	SF	\$120	\$624
59119	440.0 to 455.8 feet	Driveway				REF		
19907	441.9 to 470.5 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	114	SF	\$40	\$4,576
57017	442.4 to 443.4 feet	Vertical Change	.6	4 ft	4	REF		
59120	470.2 to 481.3 feet	Driveway				REF		
19915	470.5 to 472.1 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	6	SF	\$40	\$256
54600	473.3 to 474.3 feet	Vertical Change	.3	4 ft	4	REF		
19916	476.3 to 483.7 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	30	SF	\$40	\$1,184
19918	483.7 to 485.8 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	8	SF	\$120	\$1,008
TOTAL COST FOR: W side of COOLIDGE AVE Starting at: 15TH ST							\$168,688.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1909240959	COOLIDGE AVE	1524 COOLIDGE AVE	WILSON WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
19741	0.0 to 6.9 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	28	SF	\$120	\$3,312	
19745	7.8 to 9.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	6	SF	\$120	\$720	
19746	9.3 to 15.3 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	24	SF	\$120	\$2,880	
19748	16.0 to 28.2 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	49	SF	\$120	\$5,856	
19752	28.2 to 38.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	40	SF	\$120	\$4,848	
54592	38.2 to 39.2 feet	Vertical Change	.3	4 ft	4	REF			
19756	39.2 to 47.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	32	SF	\$120	\$3,888	
19758	48.8 to 59.6 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	43	SF	\$120	\$5,184	
19760	63.7 to 68.4 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	19	SF	\$120	\$2,256	
19761	68.8 to 82.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	54	SF	\$120	\$6,432	
19763	82.5 to 160.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	311	SF	\$120	\$37,344	
56140	99.8 to 100.8 feet	Vertical Change	.4	4 ft	4	REF			
59111	100.5 to 118.6 feet	Driveway				REF			
59112	124.1 to 140.2 feet	Driveway				REF			
19784	160.9 to 164.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,872	
56141	161.3 to 162.3 feet	Vertical Change	.4	4 ft	4	REF			
19786	164.8 to 166.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	6	SF	\$120	\$720	
19787	168.5 to 180.9 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	50	SF	\$120	\$5,952	
59113	176.7 to 196.3 feet	Driveway				REF			
19790	181.1 to 186.8 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	23	SF	\$40	\$912	
19792	186.8 to 192.4 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	22	SF	\$40	\$896	
19793	192.4 to 195.1 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	11	SF	\$40	\$432	
54593	195.1 to 196.1 feet	Vertical Change	.3	4 ft	4	REF			
19795	195.1 to 197.7 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	10	SF	\$40	\$416	
19796	198.3 to 217.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	77	SF	\$120	\$9,264	
59114	203.4 to 225.3 feet	Driveway				REF			
19801	224.2 to 234.6 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	42	SF	\$40	\$1,664	
19804	237.6 to 259.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	89	SF	\$120	\$10,656	
56142	243.2 to 244.2 feet	Vertical Change	.4	4 ft	4	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909240959	COOLIDGE AVE	1524 COOLIDGE AVE	WILSON WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
19808	259.8 to 277.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	72	SF	\$120	\$8,592
19815	280.0 to 282.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	9	SF	\$120	\$1,104
19816	282.3 to 286.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	18	SF	\$120	\$2,112
TOTAL COST FOR: W side of COOLIDGE AVE Starting at: 1524 COOLIDGE AVE							\$117,312.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909241004	WILSON WAY	COOLIDGE AVE	HOOVER AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
19651	0.7 to 18.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	71	SF	\$120	\$8,544
57655	4.1 to 5.1 feet	Vertical Change	3.5	4 ft	4	REF		
19655	18.5 to 42.4 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	96	SF	\$120	\$11,472
19663	44.5 to 95.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	205	SF	\$120	\$24,576
19674	97.8 to 112.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	58	SF	\$120	\$6,960
19678	115.1 to 127.5 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	50	SF	\$120	\$5,952
56138	120.2 to 121.2 feet	Vertical Change	.4	4 ft	4	REF		
57499	125.7 to 126.7 feet	Vertical Change	1.7	4 ft	4	REF		
57255	130.2 to 131.2 feet	Vertical Change	.8	4 ft	4	REF		
19683	130.6 to 134.4 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	15	SF	\$120	\$1,824
19685	136.6 to 139.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	11	SF	\$120	\$1,296
19686	141.8 to 156.6 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	59	SF	\$120	\$7,104
59110	157.0 to 170.3 feet	Driveway				REF		
57469	158.6 to 159.6 feet	Vertical Change	1.5	4 ft	4	REF		
19691	158.7 to 161.2 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	10	SF	\$40	\$400
19693	162.3 to 166.3 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	16	SF	\$40	\$640
56139	163.2 to 164.2 feet	Vertical Change	.4	4 ft	4	REF		
19695	166.9 to 179.2 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	49	SF	\$40	\$1,968
57516	167.1 to 168.1 feet	Vertical Change	1.9	4 ft	4	REF		
19700	179.2 to 231.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	210	SF	\$120	\$25,200
57559	190.6 to 191.6 feet	Vertical Change	2.4	4 ft	4	REF		
54589	224.4 to 225.4 feet	Vertical Change	.3	4 ft	4	REF		
19712	233.8 to 241.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	30	SF	\$120	\$3,648
19715	244.8 to 277.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	130	SF	\$120	\$15,552
19724	277.2 to 280.2 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	12	SF	\$120	\$1,440
19725	280.6 to 283.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	12	SF	\$120	\$1,392
54590	286.0 to 287.0 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
19726	287.4 to 296.1 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	35	SF	\$120	\$4,176

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909241004	WILSON WAY	COOLIDGE AVE	HOOVER AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
19729	296.3 to 299.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	12	SF	\$120	\$1,488
19731	299.4 to 307.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	34	SF	\$120	\$4,032
19735	307.8 to 319.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	46	SF	\$120	\$5,472
54591	317.0 to 318.0 feet	Vertical Change	.3	4 ft	4	REF		
TOTAL COST FOR: N side of WILSON WAY Starting at: COOLIDGE AVE							\$133,436.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909241009	HOOVER AVE	WILSON WAY	1529 HOOVER DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
19590	0.2 to 16.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	66	SF	\$120	\$7,920
59108	15.2 to 36.8 feet	Driveway				REF		
19596	16.7 to 39.7 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	92	SF	\$40	\$3,680
19603	39.7 to 45.6 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	24	SF	\$120	\$2,832
19605	45.8 to 62.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	68	SF	\$120	\$8,208
54585	60.4 to 61.4 feet	Vertical Change	.3	4 ft	4	REF		
19611	65.7 to 68.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	11	SF	\$120	\$1,344
19612	71.7 to 84.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	52	SF	\$120	\$6,192
19618	85.8 to 99.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	56	SF	\$120	\$6,672
59109	90.7 to 101.0 feet	Driveway				REF		
19620	100.4 to 146.4 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	184	SF	\$40	\$7,360
54586	101.9 to 102.9 feet	Vertical Change	.3	4 ft	4	REF		
19629	147.1 to 150.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	13	SF	\$120	\$1,536
19630	152.8 to 162.6 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	39	SF	\$120	\$4,704
19632	162.6 to 166.1 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	14	SF	\$120	\$1,680
19633	167.2 to 181.4 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	57	SF	\$120	\$6,816
54587	173.6 to 174.6 feet	Vertical Change	.3	4 ft	4	REF		
56137	179.5 to 180.5 feet	Vertical Change	.4	4 ft	4	REF		
19637	183.8 to 186.4 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	10	SF	\$120	\$1,248
54588	184.2 to 185.2 feet	Vertical Change	.3	4 ft	4	REF		
19639	187.7 to 192.8 feet	Cross Slope (PAR)	7.0-8.0%	4 ft	20	SF	\$120	\$2,448
19641	195.3 to 196.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	4	SF	\$120	\$480
19642	198.6 to 206.4 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	31	SF	\$120	\$3,744
56696	204.6 to 205.6 feet	Vertical Change	.5	4 ft	4	REF		
19645	206.4 to 229.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	94	SF	\$120	\$11,232
TOTAL COST FOR: E side of HOOVER AVE Starting at: WILSON WAY							\$78,096.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1909241019	HOOVER AVE	1529 HOOVER AVE	15TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
19456	0.0 to 16.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	65	SF	\$120	\$7,824	
54576	1.1 to 2.1 feet	Vertical Change	.3	4 ft	4	REF			
19461	16.8 to 22.8 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	24	SF	\$120	\$2,880	
56132	17.1 to 18.1 feet	Vertical Change	.4	4 ft	4	REF			
19464	22.8 to 23.9 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	4	SF	\$120	\$528	
19465	23.9 to 35.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	46	SF	\$120	\$5,472	
19467	35.5 to 43.4 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	32	SF	\$120	\$3,792	
19470	43.4 to 44.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	6	SF	\$120	\$720	
54577	48.7 to 49.7 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300	
19471	51.7 to 59.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	30	SF	\$120	\$3,648	
59099	56.4 to 68.6 feet	Driveway				REF			
19474	59.3 to 92.8 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	134	SF	\$40	\$5,360	
19486	93.2 to 96.5 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	13	SF	\$120	\$1,584	
19487	96.5 to 101.9 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	22	SF	\$120	\$2,592	
59100	99.7 to 121.9 feet	Driveway				REF			
19489	101.9 to 103.7 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	7	SF	\$40	\$288	
19490	103.7 to 139.8 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	144	SF	\$40	\$5,776	
54578	123.4 to 124.4 feet	Vertical Change	.3	4 ft	4	REF			
19498	160.8 to 186.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	101	SF	\$120	\$12,144	
59101	177.8 to 185.4 feet	Driveway				REF			
19502	197.8 to 201.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	14	SF	\$120	\$1,680	
54579	198.1 to 199.1 feet	Vertical Change	.3	4 ft	4	REF			
59102	201.4 to 208.4 feet	Driveway				REF			
56133	206.2 to 207.2 feet	Vertical Change	.4	4 ft	4	REF			
19503	223.9 to 228.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	18	SF	\$120	\$2,160	
19505	228.4 to 233.1 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	19	SF	\$120	\$2,256	
19507	233.1 to 249.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	66	SF	\$120	\$7,872	
54580	242.2 to 243.2 feet	Vertical Change	.3	4 ft	4	REF			
59103	248.9 to 272.4 feet	Driveway				REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909241019	HOOVER AVE	1529 HOOVER AVE	15TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
19512	260.9 to 275.7 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	59	SF	\$40	\$2,368
19517	278.8 to 289.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	42	SF	\$120	\$5,040
19521	289.4 to 307.9 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	74	SF	\$120	\$8,880
54581	298.2 to 299.2 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
19524	310.2 to 311.8 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	6	SF	\$120	\$768
19525	312.4 to 318.3 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	24	SF	\$120	\$2,832
19526	318.3 to 328.6 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	41	SF	\$120	\$4,944
57254	329.2 to 330.2 feet	Vertical Change	.8	4 ft	4	REF		
19529	329.5 to 331.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	7	SF	\$120	\$864
19530	331.3 to 332.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$576
59104	331.4 to 341.9 feet	Driveway				REF		
19531	333.6 to 368.1 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	138	SF	\$40	\$5,520
54582	344.3 to 345.3 feet	Vertical Change	.3	4 ft	4	REF		
56134	360.0 to 361.0 feet	Vertical Change	.4	4 ft	4	REF		
19539	368.1 to 371.0 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	12	SF	\$120	\$1,392
19540	371.0 to 393.0 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	88	SF	\$120	\$10,560
54583	377.7 to 378.7 feet	Vertical Change	.3	4 ft	4	REF		
19550	394.1 to 401.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	30	SF	\$120	\$3,552
59105	401.8 to 422.8 feet	Driveway				REF		
19552	404.2 to 413.7 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	38	SF	\$40	\$1,520
19554	413.7 to 438.6 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	100	SF	\$40	\$3,984
59106	430.3 to 438.9 feet	Driveway				REF		
19560	444.0 to 478.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	139	SF	\$120	\$16,704
56135	446.4 to 447.4 feet	Vertical Change	.4	4 ft	4	REF		
19568	482.9 to 491.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	36	SF	\$120	\$4,272
59107	483.6 to 491.8 feet	Driveway				REF		
19570	491.8 to 496.8 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	20	SF	\$40	\$800
19572	497.1 to 502.5 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	22	SF	\$120	\$2,592
19574	503.7 to 525.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	86	SF	\$120	\$10,368

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909241019	HOOVER AVE	1529 HOOVER AVE	15TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
19579	529.8 to 531.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$576
19580	545.1 to 573.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	113	SF	\$120	\$13,536
56136	556.0 to 557.0 feet	Vertical Change	.4	4 ft	4	REF		
54584	564.8 to 565.8 feet	Vertical Change	.3	4 ft	4	REF		
19587	574.5 to 581.5 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	28	SF	\$120	\$3,360
TOTAL COST FOR: E side of HOOVER AVE Starting at: 1529 HOOVER AVE							\$172,184.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1909241028	HOOVER AVE	15TH ST	WILSON WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
54563	1.4 to 2.4 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300	
54564	6.2 to 7.2 feet	Vertical Change	.3	4 ft	4	REF			
19263	6.7 to 14.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	30	SF	\$120	\$3,552	
19267	14.1 to 21.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	29	SF	\$120	\$3,456	
56693	21.2 to 22.2 feet	Vertical Change	.5	4 ft	4	REF			
19269	24.8 to 31.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	26	SF	\$120	\$3,120	
19270	31.5 to 69.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	151	SF	\$120	\$18,096	
54565	55.0 to 56.0 feet	Vertical Change	.3	4 ft	4	REF			
59089	57.7 to 70.5 feet	Driveway				REF			
19278	76.6 to 82.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	22	SF	\$120	\$2,640	
59090	77.8 to 95.4 feet	Driveway				REF			
19280	83.1 to 96.7 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	54	SF	\$40	\$2,176	
19283	96.7 to 103.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	28	SF	\$120	\$3,408	
19286	113.1 to 115.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	10	SF	\$120	\$1,200	
19287	121.5 to 142.0 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	82	SF	\$120	\$9,840	
56126	124.4 to 125.4 feet	Vertical Change	.4	4 ft	4	REF			
19294	143.4 to 159.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	65	SF	\$120	\$7,824	
54566	146.5 to 147.5 feet	Vertical Change	.3	4 ft	4	REF			
57253	151.0 to 152.0 feet	Vertical Change	.8	4 ft	4	REF			
19297	161.8 to 172.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	44	SF	\$120	\$5,280	
59091	166.3 to 177.3 feet	Driveway				REF			
19299	174.1 to 189.4 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	61	SF	\$40	\$2,448	
19306	189.4 to 202.4 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	52	SF	\$120	\$6,240	
54567	200.7 to 201.7 feet	Vertical Change	.3	4 ft	4	REF			
19309	202.8 to 206.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,968	
19311	206.9 to 209.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	12	SF	\$120	\$1,392	
19313	209.9 to 211.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	6	SF	\$120	\$672	
19314	213.8 to 219.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	24	SF	\$120	\$2,832	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909241028	HOOVER AVE	15TH ST	WILSON WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54568	219.0 to 220.0 feet	Vertical Change	.3	4 ft	4	REF		
57013	221.1 to 222.1 feet	Vertical Change	.6	4 ft	4	SF	\$75	\$300
19316	233.3 to 246.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	54	SF	\$120	\$6,480
59092	233.3 to 248.5 feet	Driveway				REF		
19318	247.2 to 257.7 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	42	SF	\$40	\$1,680
19321	260.1 to 267.4 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	29	SF	\$120	\$3,504
19323	268.3 to 271.1 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	11	SF	\$120	\$1,344
19325	271.5 to 277.2 feet	Cross Slope (PAR)	8.0-9.0%	4 ft	23	SF	\$120	\$2,736
57349	272.5 to 273.5 feet	Vertical Change	1	4 ft	4	REF		
19327	277.2 to 278.4 feet	Cross Slope (PAR)	10.0-11.0%	4 ft	5	SF	\$120	\$576
54569	278.4 to 279.4 feet	Vertical Change	.3	4 ft	4	REF		
19328	281.6 to 290.9 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	37	SF	\$120	\$4,464
19330	291.3 to 299.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	32	SF	\$120	\$3,888
54570	298.5 to 299.5 feet	Vertical Change	.3	4 ft	4	REF		
19331	327.6 to 333.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	23	SF	\$120	\$2,736
54571	334.7 to 335.7 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
54572	358.6 to 361.5 feet	Vertical Change	.3	4 ft	12	LF	\$75	\$870
59093	362.3 to 383.7 feet	Driveway				REF		
19334	376.3 to 383.6 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	29	SF	\$40	\$1,168
54573	386.1 to 387.1 feet	Vertical Change	.3	4 ft	4	REF		
19336	386.1 to 408.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	89	SF	\$120	\$10,656
57014	391.3 to 392.3 feet	Vertical Change	.6	4 ft	4	REF		
59094	395.9 to 408.9 feet	Driveway				REF		
19340	408.3 to 420.6 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	49	SF	\$40	\$1,968
56127	420.5 to 424.5 feet	Vertical Change	.4	4 ft	16	REF		
19343	426.7 to 430.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	15	SF	\$120	\$1,824
19345	430.5 to 441.1 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	42	SF	\$120	\$5,088
56128	437.3 to 438.3 feet	Vertical Change	.4	4 ft	4	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909241028	HOOVER AVE	15TH ST	WILSON WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
19349	441.1 to 454.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	52	SF	\$120	\$6,192
19354	456.8 to 464.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	30	SF	\$120	\$3,552
19357	466.3 to 475.7 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	38	SF	\$120	\$4,512
59095	470.5 to 494.1 feet	Driveway				REF		
19360	479.3 to 482.0 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	11	SF	\$40	\$432
19361	483.3 to 499.8 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	66	SF	\$40	\$2,640
19366	503.1 to 515.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	48	SF	\$120	\$5,808
19369	517.7 to 544.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	108	SF	\$120	\$13,008
59096	540.6 to 559.8 feet	Driveway				REF		
19379	548.6 to 574.0 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	102	SF	\$40	\$4,064
56129	565.5 to 566.5 feet	Vertical Change	.4	4 ft	4	REF		
19388	574.0 to 586.4 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	50	SF	\$120	\$5,952
19393	586.4 to 587.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	6	SF	\$120	\$720
19394	590.2 to 598.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	33	SF	\$120	\$3,936
19397	598.4 to 607.6 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	37	SF	\$120	\$4,416
54574	606.5 to 607.5 feet	Vertical Change	.3	4 ft	4	REF		
19400	608.6 to 625.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	66	SF	\$120	\$7,872
59097	626.4 to 639.9 feet	Driveway				REF		
19407	627.9 to 649.6 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	87	SF	\$40	\$3,472
19411	650.8 to 652.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	6	SF	\$120	\$720
19412	657.3 to 659.8 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	10	SF	\$120	\$1,200
19413	661.1 to 663.3 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	9	SF	\$120	\$1,056
57350	661.7 to 662.7 feet	Vertical Change	1	4 ft	4	REF		
19414	663.7 to 668.9 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	21	SF	\$120	\$2,496
19417	669.3 to 675.6 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	25	SF	\$120	\$3,024
19419	675.6 to 691.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	64	SF	\$120	\$7,728
19424	692.3 to 710.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	74	SF	\$120	\$8,880
19429	713.5 to 735.4 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	88	SF	\$120	\$10,512

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909241028	HOOVER AVE	15TH ST	WILSON WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56130	719.8 to 723.0 feet	Vertical Change	.4	4 ft	13	REF		
19436	737.9 to 749.0 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	44	SF	\$120	\$5,328
59098	746.6 to 766.1 feet	Driveway				REF		
19439	749.3 to 765.6 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	65	SF	\$40	\$2,608
19441	769.8 to 822.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	212	SF	\$120	\$25,440
56131	822.1 to 823.1 feet	Vertical Change	.4	4 ft	4	REF		
19450	844.4 to 848.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	17	SF	\$120	\$2,064
19452	849.5 to 851.0 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	6	SF	\$120	\$720
19453	851.2 to 853.2 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	8	SF	\$120	\$960
54575	853.0 to 854.0 feet	Vertical Change	.3	4 ft	4	REF		
19454	853.2 to 855.9 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	11	SF	\$120	\$1,296
TOTAL COST FOR: W side of HOOVER AVE Starting at: 15TH ST							\$266,634.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1909241033	WILSON WAY	HOOVER AVE	ROOSEVELT DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
19169	0.0 to 13.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	53	SF	\$120	\$6,384	
19175	13.3 to 22.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	38	SF	\$120	\$4,608	
56125	19.9 to 20.9 feet	Vertical Change	.4	4 ft	4	REF			
54560	30.2 to 31.2 feet	Vertical Change	.3	4 ft	4	REF			
19179	30.8 to 58.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	109	SF	\$120	\$13,056	
19186	60.5 to 73.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	53	SF	\$120	\$6,336	
19192	76.4 to 109.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	132	SF	\$120	\$15,888	
19198	113.7 to 122.1 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	34	SF	\$120	\$4,032	
59087	114.6 to 142.8 feet	Driveway				REF			
19201	122.3 to 123.3 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	4	SF	\$40	\$160	
19202	134.3 to 143.1 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	35	SF	\$40	\$1,408	
19205	143.1 to 156.1 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	52	SF	\$40	\$2,080	
19209	157.8 to 207.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	197	SF	\$120	\$23,616	
59088	168.0 to 193.6 feet	Driveway				REF			
54561	184.2 to 185.2 feet	Vertical Change	.3	4 ft	4	REF			
54562	189.2 to 190.2 feet	Vertical Change	.3	4 ft	4	REF			
19226	209.9 to 212.4 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	10	SF	\$120	\$1,200	
19227	212.7 to 222.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	40	SF	\$120	\$4,848	
19230	223.6 to 228.0 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	18	SF	\$120	\$2,112	
19232	228.4 to 232.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	18	SF	\$120	\$2,112	
19234	233.2 to 237.2 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	16	SF	\$120	\$1,920	
19235	239.3 to 241.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	10	SF	\$120	\$1,152	
19237	242.6 to 258.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	63	SF	\$120	\$7,536	
19240	261.9 to 267.1 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	21	SF	\$120	\$2,496	
19242	267.1 to 270.6 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	14	SF	\$120	\$1,680	
19243	271.5 to 273.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	7	SF	\$120	\$864	
19244	273.3 to 277.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,920	
19246	280.9 to 282.2 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	5	SF	\$120	\$624	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909241033	WILSON WAY	HOOVER AVE	ROOSEVELT DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
19247	283.2 to 297.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	57	SF	\$120	\$6,816
19251	298.6 to 304.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	25	SF	\$120	\$2,976
56692	301.6 to 302.6 feet	Vertical Change	.5	4 ft	4	REF		
19253	306.9 to 315.2 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	33	SF	\$120	\$3,984
19255	315.2 to 318.8 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	14	SF	\$120	\$1,728
19256	319.2 to 325.5 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	25	SF	\$120	\$3,024
19257	325.8 to 328.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	10	SF	\$120	\$1,200
19259	328.5 to 341.9 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	54	SF	\$120	\$6,432
TOTAL COST FOR: N side of WILSON WAY Starting at: HOOVER AVE							\$132,192.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1909241043	ROOSEVELT DR	WILSON WAY	15TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
18957	0.0 to 3.6 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	14	SF	\$120	\$1,728	
18959	4.1 to 9.5 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	22	SF	\$120	\$2,592	
18961	9.5 to 30.5 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	84	SF	\$120	\$10,080	
18968	31.3 to 34.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	12	SF	\$120	\$1,440	
54555	44.2 to 45.2 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300	
18969	45.7 to 55.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	38	SF	\$120	\$4,608	
54556	64.6 to 65.6 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300	
18971	81.5 to 99.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	72	SF	\$120	\$8,592	
18975	111.3 to 118.2 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	28	SF	\$120	\$3,312	
18978	118.2 to 141.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	93	SF	\$120	\$11,136	
59077	118.8 to 138.8 feet	Driveway				REF			
18985	146.1 to 156.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	40	SF	\$120	\$4,848	
18988	156.3 to 179.2 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	92	SF	\$120	\$10,992	
59078	158.8 to 168.8 feet	Driveway				REF			
18994	182.3 to 185.6 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	13	SF	\$120	\$1,584	
18996	189.3 to 192.2 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	12	SF	\$120	\$1,392	
18998	195.2 to 205.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	40	SF	\$120	\$4,848	
19001	205.3 to 243.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	153	SF	\$120	\$18,336	
59079	220.6 to 255.4 feet	Driveway				REF			
19012	249.0 to 253.6 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	18	SF	\$40	\$736	
19014	253.9 to 260.9 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	28	SF	\$40	\$1,120	
19016	263.1 to 281.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	72	SF	\$120	\$8,640	
19020	285.6 to 292.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	26	SF	\$120	\$3,072	
59080	298.3 to 315.0 feet	Driveway				REF			
19023	306.4 to 311.6 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	21	SF	\$40	\$832	
19025	314.1 to 339.3 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	101	SF	\$40	\$4,032	
19030	339.3 to 340.4 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	4	SF	\$120	\$528	
19031	341.4 to 343.7 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	9	SF	\$120	\$1,104	
19032	344.5 to 347.8 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	13	SF	\$120	\$1,584	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909241043	ROOSEVELT DR	WILSON WAY	15TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59081	345.8 to 361.8 feet	Driveway				REF		
19034	347.8 to 373.8 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	104	SF	\$40	\$4,160
19041	374.2 to 381.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	28	SF	\$120	\$3,312
19044	381.3 to 399.2 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	72	SF	\$120	\$8,592
59082	389.6 to 401.8 feet	Driveway				REF		
19049	400.7 to 408.3 feet	Cross Slope (Driveway)	8.0-9.0%	4 ft	30	SF	\$40	\$1,216
19053	408.3 to 410.7 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	10	SF	\$120	\$1,152
19054	411.1 to 415.2 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	16	SF	\$120	\$1,968
19055	416.0 to 421.4 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	22	SF	\$120	\$2,592
19056	421.4 to 429.0 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	30	SF	\$120	\$3,648
19060	431.5 to 434.4 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	12	SF	\$120	\$1,392
19062	434.4 to 469.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	138	SF	\$120	\$16,608
19070	469.3 to 475.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	26	SF	\$120	\$3,072
19072	475.7 to 481.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	23	SF	\$120	\$2,736
19075	484.4 to 518.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	137	SF	\$120	\$16,416
59083	498.5 to 517.3 feet	Driveway				REF		
19081	521.3 to 526.4 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	20	SF	\$120	\$2,448
54557	525.1 to 526.1 feet	Vertical Change	.3	4 ft	4	REF		
19083	528.4 to 533.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	20	SF	\$120	\$2,400
19086	535.5 to 539.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,920
19088	539.5 to 588.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	195	SF	\$120	\$23,424
59084	574.8 to 602.8 feet	Driveway				REF		
19102	588.3 to 596.8 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	34	SF	\$40	\$1,360
19105	599.0 to 610.3 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	45	SF	\$40	\$1,808
19107	610.8 to 623.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	52	SF	\$120	\$6,240
54558	632.6 to 633.6 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
19110	635.5 to 640.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	19	SF	\$120	\$2,304
19112	640.3 to 658.2 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	72	SF	\$120	\$8,592
59085	654.3 to 675.8 feet	Driveway				REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909241043	ROOSEVELT DR	WILSON WAY	15TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
19118	660.3 to 701.3 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	164	SF	\$40	\$6,560
59086	704.0 to 714.0 feet	Driveway				REF		
19130	706.0 to 714.3 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	33	SF	\$40	\$1,328
19133	714.9 to 721.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	28	SF	\$120	\$3,312
19135	721.8 to 723.4 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	6	SF	\$120	\$768
19136	723.9 to 725.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	7	SF	\$120	\$864
19137	728.4 to 755.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	108	SF	\$120	\$12,912
19144	764.3 to 774.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	40	SF	\$120	\$4,752
54559	771.4 to 772.4 feet	Vertical Change	.3	4 ft	4	REF		
19148	774.2 to 800.5 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	105	SF	\$120	\$12,624
19157	803.2 to 806.6 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	14	SF	\$120	\$1,632
19159	806.6 to 814.9 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	33	SF	\$120	\$3,984
19161	817.4 to 845.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	113	SF	\$120	\$13,584
57590	839.5 to 840.5 feet	Vertical Change	2.9	4 ft	4	REF		
19168	845.7 to 848.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	9	SF	\$120	\$1,104
TOTAL COST FOR: E side of ROOSEVELT DR Starting at: WILSON WAY							\$288,820.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
W	1909241047	ROOSEVELT DR	15TH ST	1512 ROOSEVELT DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
18888	7.6 to 23.2 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	62	SF	\$120	\$7,488	
56121	17.6 to 18.6 feet	Vertical Change	.4	4 ft	4	REF			
18891	23.8 to 45.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	85	SF	\$120	\$10,224	
18898	54.4 to 63.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	37	SF	\$120	\$4,464	
18901	68.8 to 100.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	128	SF	\$120	\$15,360	
59074	77.1 to 94.4 feet	Driveway				REF			
56122	79.1 to 80.1 feet	Vertical Change	.4	4 ft	4	REF			
56691	89.4 to 90.4 feet	Vertical Change	.5	4 ft	4	REF			
18909	103.1 to 106.6 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	14	SF	\$120	\$1,680	
18910	106.8 to 113.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	26	SF	\$120	\$3,120	
18911	116.0 to 119.1 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	12	SF	\$120	\$1,488	
18913	119.3 to 122.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	12	SF	\$120	\$1,392	
59075	122.7 to 144.3 feet	Driveway				REF			
18914	125.3 to 141.8 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	66	SF	\$40	\$2,640	
56123	140.4 to 141.4 feet	Vertical Change	.4	4 ft	4	REF			
18918	141.8 to 154.0 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	49	SF	\$40	\$1,952	
18921	160.6 to 172.6 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	48	SF	\$120	\$5,760	
18926	172.8 to 186.1 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	53	SF	\$120	\$6,384	
56124	177.8 to 178.8 feet	Vertical Change	.4	4 ft	4	REF			
18929	186.1 to 197.3 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	45	SF	\$120	\$5,376	
59076	195.1 to 203.5 feet	Driveway				REF			
18932	197.3 to 200.3 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	12	SF	\$40	\$480	
18934	200.3 to 202.8 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	10	SF	\$40	\$400	
18935	203.3 to 210.9 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	30	SF	\$40	\$1,216	
18937	213.4 to 221.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	33	SF	\$120	\$3,984	
18940	224.0 to 237.5 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	54	SF	\$120	\$6,480	
18943	237.7 to 241.4 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	15	SF	\$120	\$1,776	
18944	242.1 to 246.6 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	18	SF	\$120	\$2,160	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909241047	ROOSEVELT DR	15TH ST	1512 ROOSEVELT DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
18946	248.2 to 255.7 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	30	SF	\$120	\$3,600
18949	255.7 to 263.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	30	SF	\$120	\$3,648
18952	264.0 to 282.0 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	72	SF	\$120	\$8,640
TOTAL COST FOR: W side of ROOSEVELT DR Starting at: 15TH ST							\$99,712.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909241057	ROOSEVELT DR	1512 ROOSEVELT DR	WASHINGTON DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
18686	1.4 to 9.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	32	SF	\$120	\$3,888
59061	1.5 to 24.0 feet	Driveway				REF		
57497	7.7 to 8.7 feet	Vertical Change	1.7	4 ft	4	REF		
18688	12.3 to 15.0 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	11	SF	\$40	\$432
18690	15.0 to 18.5 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	14	SF	\$40	\$560
18691	21.9 to 33.9 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	48	SF	\$40	\$1,920
18695	34.7 to 65.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	122	SF	\$120	\$14,688
56117	35.0 to 36.0 feet	Vertical Change	.4	4 ft	4	REF		
18705	67.9 to 83.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	61	SF	\$120	\$7,296
18710	86.4 to 90.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	15	SF	\$120	\$1,824
18712	90.2 to 137.4 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	189	SF	\$120	\$22,656
56118	109.2 to 110.2 feet	Vertical Change	.4	4 ft	4	REF		
59062	127.0 to 152.3 feet	Driveway				REF		
56688	129.7 to 130.7 feet	Vertical Change	.5	4 ft	4	REF		
18726	139.6 to 144.9 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	21	SF	\$40	\$848
18728	147.8 to 178.5 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	123	SF	\$40	\$4,912
59063	156.9 to 175.8 feet	Driveway				REF		
57498	171.5 to 172.5 feet	Vertical Change	1.7	4 ft	4	REF		
18734	178.5 to 189.7 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	45	SF	\$120	\$5,376
18736	191.5 to 205.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	55	SF	\$120	\$6,624
18740	205.3 to 209.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,920
59064	206.4 to 229.0 feet	Driveway				REF		
18742	209.3 to 222.7 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	54	SF	\$40	\$2,144
57012	221.8 to 222.8 feet	Vertical Change	.6	4 ft	4	REF		
18745	222.9 to 226.8 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	16	SF	\$40	\$624
18747	228.1 to 242.0 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	56	SF	\$40	\$2,224
18752	244.4 to 248.0 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	14	SF	\$120	\$1,728
18754	248.0 to 255.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	29	SF	\$120	\$3,456
59065	251.8 to 263.8 feet	Driveway				REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909241057	ROOSEVELT DR	1512 ROOSEVELT DR	WASHINGTON DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
18757	262.4 to 266.5 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	16	SF	\$40	\$656
18759	267.3 to 279.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	50	SF	\$120	\$6,000
18763	279.8 to 284.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	18	SF	\$120	\$2,208
18765	299.2 to 301.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	10	SF	\$120	\$1,200
56689	314.1 to 315.1 feet	Vertical Change	.5	4 ft	4	SF	\$75	\$300
18766	316.7 to 317.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	4	SF	\$120	\$480
18767	320.1 to 333.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	52	SF	\$120	\$6,240
18770	335.3 to 350.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	59	SF	\$120	\$7,056
54547	344.9 to 345.9 feet	Vertical Change	.3	4 ft	4	REF		
18774	352.0 to 355.4 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	14	SF	\$120	\$1,632
59066	356.2 to 370.4 feet	Driveway				REF		
18776	357.2 to 367.7 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	42	SF	\$40	\$1,680
18780	390.5 to 440.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	200	SF	\$120	\$24,048
59067	430.3 to 446.8 feet	Driveway				REF		
18792	440.8 to 463.0 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	89	SF	\$40	\$3,552
18798	463.0 to 466.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	15	SF	\$120	\$1,776
59068	463.1 to 481.2 feet	Driveway				REF		
18800	472.7 to 497.3 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	98	SF	\$40	\$3,936
54548	483.2 to 484.2 feet	Vertical Change	.3	4 ft	4	REF		
18804	500.1 to 501.1 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	4	SF	\$120	\$480
18805	501.1 to 502.1 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	4	SF	\$120	\$480
18806	502.6 to 511.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	35	SF	\$120	\$4,176
18810	513.7 to 520.2 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	26	SF	\$120	\$3,120
18812	520.4 to 542.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	87	SF	\$120	\$10,464
54549	529.3 to 530.3 feet	Vertical Change	.3	4 ft	4	REF		
18818	545.3 to 564.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	76	SF	\$120	\$9,168
54550	545.6 to 546.6 feet	Vertical Change	.3	4 ft	4	REF		
59069	546.3 to 562.6 feet	Driveway				REF		
18824	564.4 to 581.6 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	69	SF	\$120	\$8,256

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909241057	ROOSEVELT DR	1512 ROOSEVELT DR	WASHINGTON DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
18826	581.6 to 582.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$576
18827	592.2 to 599.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	27	SF	\$120	\$3,264
54551	596.8 to 597.8 feet	Vertical Change	.3	4 ft	4	REF		
18830	603.7 to 613.9 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	41	SF	\$120	\$4,896
18834	613.9 to 617.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	14	SF	\$120	\$1,632
59070	619.1 to 632.9 feet	Driveway				REF		
18835	624.4 to 631.8 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	30	SF	\$40	\$1,184
54552	632.2 to 635.8 feet	Vertical Change	.3	4 ft	14	REF		
59071	634.8 to 646.7 feet	Driveway				REF		
18838	635.8 to 652.3 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	66	SF	\$40	\$2,640
18842	652.5 to 660.2 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	31	SF	\$120	\$3,696
18844	662.8 to 674.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	46	SF	\$120	\$5,472
18846	684.5 to 689.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	18	SF	\$120	\$2,208
18848	712.5 to 727.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	59	SF	\$120	\$7,056
18852	728.3 to 736.6 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	33	SF	\$120	\$3,984
18855	739.2 to 747.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	34	SF	\$120	\$4,128
59072	743.8 to 766.4 feet	Driveway				REF		
18857	750.7 to 758.7 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	32	SF	\$40	\$1,280
18859	765.6 to 778.3 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	51	SF	\$40	\$2,032
54553	770.3 to 771.3 feet	Vertical Change	.3	4 ft	4	REF		
57433	775.4 to 776.4 feet	Vertical Change	1.3	4 ft	4	REF		
18862	778.3 to 789.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	44	SF	\$120	\$5,280
54554	778.7 to 779.7 feet	Vertical Change	.3	4 ft	4	REF		
40498	781.7 to 782.7 feet	Running Slope	5.0-6.0%	4 ft	4	REF		
18866	789.4 to 791.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	10	SF	\$120	\$1,152
18867	795.9 to 799.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	15	SF	\$120	\$1,776
57525	797.5 to 798.5 feet	Vertical Change	2	4 ft	4	REF		
18868	803.5 to 805.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	7	SF	\$120	\$864
59073	809.8 to 834.0 feet	Driveway				REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909241057	ROOSEVELT DR	1512 ROOSEVELT DR	WASHINGTON DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56690	832.0 to 833.0 feet	Vertical Change	.5	4 ft	4	REF		
18869	834.3 to 840.8 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	26	SF	\$40	\$1,040
56120	837.3 to 838.3 feet	Vertical Change	.4	4 ft	4	REF		
18873	840.8 to 845.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	18	SF	\$120	\$2,160
18874	845.9 to 891.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	184	SF	\$120	\$22,032
18882	891.8 to 909.2 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	70	SF	\$120	\$8,352
18887	909.2 to 912.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	12	SF	\$120	\$1,392
TOTAL COST FOR: W side of ROOSEVELT DR Starting at: 1512 ROOSEVELT DR							\$268,124.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1909241101	ROOSEVELT DR	WASHINGTON DR	WILSON WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
18642	2.9 to 24.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	85	SF	\$120	\$10,176	
54546	18.2 to 19.2 feet	Vertical Change	.3	4 ft	4	REF			
18644	30.2 to 31.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	4	SF	\$120	\$528	
18645	34.9 to 55.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	81	SF	\$120	\$9,696	
18648	70.2 to 79.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	38	SF	\$120	\$4,608	
18651	79.8 to 80.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	4	SF	\$120	\$480	
18652	83.3 to 89.4 feet	Cross Slope (PAR)	8.0-9.0%	4 ft	24	SF	\$120	\$2,928	
18655	103.5 to 110.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	27	SF	\$120	\$3,216	
59060	114.5 to 131.8 feet	Driveway				REF			
18656	128.0 to 133.2 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	21	SF	\$40	\$832	
18658	135.8 to 142.8 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	28	SF	\$120	\$3,360	
18659	143.3 to 144.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	6	SF	\$120	\$720	
18660	147.3 to 148.6 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	5	SF	\$120	\$624	
18661	151.0 to 157.9 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	28	SF	\$120	\$3,312	
18664	162.3 to 172.9 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	42	SF	\$120	\$5,088	
56116	173.1 to 174.1 feet	Vertical Change	.4	4 ft	4	LF	\$75	\$300	
18668	177.5 to 186.8 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	37	SF	\$120	\$4,464	
18672	186.8 to 190.6 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	15	SF	\$120	\$1,824	
18674	190.6 to 203.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	51	SF	\$120	\$6,096	
18678	205.8 to 221.0 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	61	SF	\$120	\$7,296	
18681	223.6 to 237.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	55	SF	\$120	\$6,576	
18685	239.8 to 240.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	4	SF	\$120	\$528	

TOTAL COST FOR: E side of ROOSEVELT DR Starting at: WASHINGTON DR \$72,652.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1909241112	WILSON WAY	ROOSEVELT DR	360 WILSON WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
18366	0.0 to 4.6 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	18	SF	\$120	\$2,208	
18367	4.6 to 10.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	25	SF	\$120	\$2,976	
18369	16.5 to 38.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	88	SF	\$120	\$10,512	
54529	36.3 to 37.3 feet	Vertical Change	.3	4 ft	4	REF			
18375	38.8 to 56.2 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	70	SF	\$120	\$8,352	
54530	51.5 to 52.5 feet	Vertical Change	.3	4 ft	4	REF			
18378	56.2 to 66.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	42	SF	\$120	\$5,088	
56683	67.1 to 68.1 feet	Vertical Change	.5	4 ft	4	SF	\$75	\$300	
18380	74.1 to 86.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	50	SF	\$120	\$5,952	
56684	82.3 to 83.3 feet	Vertical Change	.5	4 ft	4	REF			
59042	88.3 to 97.9 feet	Driveway				REF			
18384	89.8 to 129.9 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	160	SF	\$40	\$6,416	
54531	93.2 to 94.2 feet	Vertical Change	.3	4 ft	4	REF			
54532	128.6 to 129.6 feet	Vertical Change	.3	4 ft	4	REF			
18396	131.1 to 179.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	194	SF	\$120	\$23,232	
59043	143.8 to 154.5 feet	Driveway				REF			
59044	165.3 to 181.5 feet	Driveway				REF			
18408	189.8 to 220.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	122	SF	\$120	\$14,592	
57639	195.5 to 196.5 feet	Vertical Change	3.4	4 ft	4	REF			
18414	220.5 to 224.2 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	15	SF	\$120	\$1,776	
18415	226.4 to 229.5 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	12	SF	\$120	\$1,488	
59045	226.7 to 259.3 feet	Driveway				REF			
18416	232.2 to 234.1 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	8	SF	\$40	\$304	
18417	251.2 to 265.8 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	58	SF	\$40	\$2,336	
56112	251.5 to 252.5 feet	Vertical Change	.4	4 ft	4	REF			
57589	258.3 to 259.3 feet	Vertical Change	2.9	4 ft	4	REF			
18421	273.0 to 281.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	35	SF	\$120	\$4,224	
54533	282.3 to 283.3 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300	
18424	286.1 to 304.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	74	SF	\$120	\$8,880	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909241112	WILSON WAY	ROOSEVELT DR	360 WILSON WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
18430	307.4 to 313.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	25	SF	\$120	\$2,976
18433	313.6 to 325.5 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	48	SF	\$120	\$5,712
59046	314.6 to 326.8 feet	Driveway				REF		
18437	327.6 to 332.4 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	19	SF	\$120	\$2,304
18440	332.4 to 344.3 feet	Cross Slope (PAR)	8.0-9.0%	4 ft	48	SF	\$120	\$5,712
18444	344.5 to 347.0 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	10	SF	\$120	\$1,200
18445	347.3 to 359.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	48	SF	\$120	\$5,760
54534	359.0 to 360.0 feet	Vertical Change	.3	4 ft	4	REF		
18449	360.2 to 364.0 feet	Cross Slope (PAR)	7.0-8.0%	4 ft	15	SF	\$120	\$1,824
59047	362.1 to 387.8 feet	Driveway				REF		
18450	365.4 to 366.4 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	4	SF	\$40	\$160
18451	367.1 to 369.3 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	9	SF	\$40	\$352
18452	369.3 to 374.3 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	20	SF	\$40	\$800
54535	376.8 to 377.8 feet	Vertical Change	.3	4 ft	4	REF		
18454	376.8 to 399.7 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	92	SF	\$40	\$3,664
18461	402.0 to 411.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	39	SF	\$120	\$4,704
59048	402.8 to 412.8 feet	Driveway				REF		
18463	411.8 to 418.9 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	28	SF	\$40	\$1,136
18466	418.9 to 422.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	14	SF	\$120	\$1,728
18467	425.9 to 445.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	79	SF	\$120	\$9,504
54536	426.0 to 427.0 feet	Vertical Change	.3	4 ft	4	REF		
18473	451.0 to 454.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	13	SF	\$120	\$1,584
18475	456.4 to 469.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	50	SF	\$120	\$6,048
56685	459.5 to 460.5 feet	Vertical Change	.5	4 ft	4	REF		
18479	469.0 to 470.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	5	SF	\$120	\$624
59049	470.8 to 481.8 feet	Driveway				REF		
18480	473.5 to 479.3 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	23	SF	\$40	\$928
56113	476.2 to 477.2 feet	Vertical Change	.4	4 ft	4	REF		
18483	479.3 to 481.3 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	8	SF	\$40	\$320

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909241112	WILSON WAY	ROOSEVELT DR	360 WILSON WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
18484	481.3 to 511.4 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	120	SF	\$40	\$4,816
18496	513.6 to 541.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	111	SF	\$120	\$13,296
59050	530.4 to 542.8 feet	Driveway				REF		
18503	543.7 to 551.6 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	32	SF	\$120	\$3,792
18505	551.6 to 562.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	43	SF	\$120	\$5,136
57496	561.7 to 562.7 feet	Vertical Change	1.7	4 ft	4	REF		
18509	562.3 to 563.4 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	4	SF	\$120	\$528
18510	563.4 to 574.1 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	43	SF	\$120	\$5,136
18514	575.9 to 576.9 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	4	SF	\$120	\$480
18515	577.8 to 590.4 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	50	SF	\$120	\$6,048
18517	590.4 to 612.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	89	SF	\$120	\$10,656
59051	597.1 to 613.4 feet	Driveway				REF		
56114	613.0 to 614.0 feet	Vertical Change	.4	4 ft	4	REF		
18523	618.3 to 619.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$624
18524	622.8 to 636.2 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	54	SF	\$120	\$6,432
18529	636.2 to 641.1 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	20	SF	\$120	\$2,352
18532	643.1 to 655.5 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	50	SF	\$120	\$5,952
18533	656.3 to 685.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	116	SF	\$120	\$13,968
54537	667.3 to 668.3 feet	Vertical Change	.3	4 ft	4	REF		
59052	671.8 to 692.5 feet	Driveway				REF		
18540	687.5 to 698.4 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	44	SF	\$40	\$1,744
18543	698.4 to 724.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	104	SF	\$120	\$12,432
59053	698.7 to 716.1 feet	Driveway				REF		
18551	728.3 to 764.8 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	146	SF	\$120	\$17,520
18562	764.8 to 774.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	39	SF	\$120	\$4,704
18563	781.1 to 786.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	21	SF	\$120	\$2,496
18565	786.3 to 792.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	26	SF	\$120	\$3,120
56115	790.3 to 793.2 feet	Vertical Change	.4	4 ft	12	REF		
18570	794.1 to 803.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	39	SF	\$120	\$4,656

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909241112	WILSON WAY	ROOSEVELT DR	360 WILSON WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
18572	806.6 to 813.0 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	26	SF	\$120	\$3,072
59054	810.9 to 830.8 feet	Driveway				REF		
18573	815.0 to 824.3 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	37	SF	\$40	\$1,488
18576	832.9 to 837.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	19	SF	\$120	\$2,256
18578	841.7 to 854.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	50	SF	\$120	\$6,048
18580	854.3 to 859.5 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	21	SF	\$120	\$2,496
18582	859.5 to 861.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	8	SF	\$120	\$960
54538	867.2 to 868.2 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
18583	868.9 to 877.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	34	SF	\$120	\$4,032
18585	881.3 to 904.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	92	SF	\$120	\$11,088
59055	899.0 to 929.0 feet	Driveway				REF		
18589	904.4 to 908.3 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	16	SF	\$40	\$624
18591	910.7 to 916.9 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	25	SF	\$40	\$992
18593	916.9 to 925.8 feet	Cross Slope (Driveway)	3.0-4.0%	4 ft	36	SF	\$40	\$1,424
18595	925.8 to 930.0 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	17	SF	\$40	\$672
18596	934.8 to 941.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	26	SF	\$120	\$3,120
59056	941.8 to 962.2 feet	Driveway				REF		
18597	943.5 to 946.8 feet	Cross Slope (Driveway)	7.0-8.0%	4 ft	13	SF	\$40	\$528
56687	944.5 to 945.5 feet	Vertical Change	.5	4 ft	4	REF		
18599	946.8 to 948.2 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	6	SF	\$40	\$224
18600	948.5 to 951.9 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	14	SF	\$40	\$544
18602	951.9 to 956.0 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	16	SF	\$40	\$656
18603	956.0 to 957.2 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	5	SF	\$40	\$192
18604	961.7 to 963.6 feet	Cross Slope (Driveway)	7.0-8.0%	4 ft	8	SF	\$40	\$304
54539	962.1 to 963.1 feet	Vertical Change	.3	4 ft	4	REF		
18605	966.1 to 972.7 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	26	SF	\$120	\$3,168
18607	973.8 to 982.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	35	SF	\$120	\$4,224
18608	989.3 to 990.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$576

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909241112	WILSON WAY	ROOSEVELT DR	360 WILSON WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
18609	1000.3 to 1001.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	6	SF	\$120	\$720
18610	1017.9 to 1033.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	62	SF	\$120	\$7,488
18612	1037.8 to 1049.5 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	47	SF	\$120	\$5,616
18614	1049.5 to 1060.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	46	SF	\$120	\$5,472
59057	1058.8 to 1078.0 feet	Driveway				REF		
54540	1059.2 to 1060.2 feet	Vertical Change	.3	4 ft	4	REF		
18617	1060.9 to 1062.0 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	4	SF	\$40	\$176
54541	1062.6 to 1069.0 feet	Vertical Change	.3	4 ft	26	REF		
18618	1075.1 to 1080.9 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	23	SF	\$40	\$928
18620	1080.9 to 1086.1 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	21	SF	\$120	\$2,496
18622	1089.3 to 1090.3 feet	Cross Slope (PAR)	8.0-9.0%	4 ft	4	SF	\$120	\$480
54544	1090.2 to 1091.2 feet	Vertical Change	.3	4 ft	4	REF		
18623	1092.8 to 1101.2 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	34	SF	\$120	\$4,032
18627	1104.5 to 1109.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	19	SF	\$120	\$2,304
54545	1106.3 to 1107.3 feet	Vertical Change	.3	4 ft	4	REF		
18629	1115.6 to 1141.1 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	102	SF	\$120	\$12,240
18636	1141.1 to 1152.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	47	SF	\$120	\$5,616
59058	1158.8 to 1180.6 feet	Driveway				REF		
18640	1178.1 to 1191.0 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	52	SF	\$40	\$2,064
59059	1189.9 to 1204.0 feet	Driveway				REF		
TOTAL COST FOR: S side of WILSON WAY Starting at: ROOSEVELT DR							\$380,484.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909241117	TRUMAN DR	SIDEWALK BEGINS	WASHINGTON DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
18352	1.3 to 18.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	85	SF	\$120	\$10,200
18355	18.3 to 21.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	14	SF	\$120	\$1,620
18357	21.0 to 28.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,200
54528	24.5 to 25.5 feet	Vertical Change	.3	5 ft	5	REF		
18359	29.3 to 39.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	52	SF	\$120	\$6,180
18361	41.1 to 53.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	61	SF	\$120	\$7,260
18362	59.8 to 75.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	78	SF	\$120	\$9,300
TOTAL COST FOR: W side of TRUMAN DR Starting at: SIDEWALK BEGINS							\$38,760.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1909241129	WASHINGTON DR	TRUMAN DR	ROOSEVELT DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
18181	0.0 to 5.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,180	
59027	3.3 to 31.2 feet	Driveway				REF			
40491	7.1 to 8.7 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
18184	13.6 to 15.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	9	SF	\$40	\$360	
54516	17.2 to 18.2 feet	Vertical Change	.3	5 ft	5	REF			
18185	18.6 to 27.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	43	SF	\$40	\$1,720	
54517	29.4 to 30.4 feet	Vertical Change	.3	5 ft	5	REF			
18188	30.3 to 31.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200	
18189	37.0 to 38.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
56103	42.2 to 43.2 feet	Vertical Change	.4	5 ft	5	REF			
18190	42.3 to 49.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,260	
18193	68.4 to 72.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400	
18194	81.1 to 83.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620	
18195	105.9 to 121.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	80	SF	\$120	\$9,600	
59028	121.3 to 149.1 feet	Driveway				REF			
18201	121.9 to 124.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	11	SF	\$40	\$440	
18202	129.6 to 138.1 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	43	SF	\$40	\$1,700	
18205	138.3 to 140.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	11	SF	\$40	\$460	
18206	142.8 to 145.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	13	SF	\$40	\$540	
18207	149.3 to 155.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	29	SF	\$40	\$1,180	
57532	155.6 to 156.6 feet	Vertical Change	2.1	5 ft	5	SF	\$75	\$375	
59029	156.8 to 183.5 feet	Driveway				REF			
54518	157.7 to 158.7 feet	Vertical Change	.3	5 ft	5	REF			
40492	159.8 to 161.0 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
18208	163.6 to 179.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	78	SF	\$40	\$3,120	
56104	181.9 to 182.9 feet	Vertical Change	.4	5 ft	5	REF			
18213	194.5 to 208.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	72	SF	\$120	\$8,580	
18216	209.3 to 244.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	176	SF	\$120	\$21,060	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909241129	WASHINGTON DR	TRUMAN DR	ROOSEVELT DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
68	233.5 to 234.5 feet	Continuous Width		5 ft	5	SF	\$120	\$600
59030	241.3 to 267.9 feet	Driveway				REF		
18227	247.3 to 264.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	85	SF	\$40	\$3,380
18232	267.2 to 272.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	25	SF	\$40	\$1,000
18234	272.2 to 297.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	128	SF	\$120	\$15,360
54519	285.0 to 286.0 feet	Vertical Change	.3	5 ft	5	REF		
18235	300.7 to 320.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	101	SF	\$120	\$12,060
59031	320.8 to 346.4 feet	Driveway				REF		
54520	321.1 to 322.1 feet	Vertical Change	.3	5 ft	5	REF		
40493	323.3 to 324.5 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
18237	325.2 to 328.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	17	SF	\$40	\$660
18239	328.5 to 337.0 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	43	SF	\$40	\$1,700
18241	337.3 to 342.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	28	SF	\$40	\$1,100
54521	345.6 to 346.6 feet	Vertical Change	.3	5 ft	5	REF		
18242	347.0 to 352.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,300
18243	359.2 to 401.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	210	SF	\$120	\$25,200
56105	366.6 to 367.6 feet	Vertical Change	.4	5 ft	5	REF		
54522	399.3 to 400.3 feet	Vertical Change	.3	5 ft	5	REF		
59032	448.5 to 475.2 feet	Driveway				REF		
18252	453.1 to 463.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	53	SF	\$40	\$2,100
18256	463.8 to 466.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	12	SF	\$40	\$460
18258	466.1 to 469.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	17	SF	\$40	\$680
18259	470.3 to 471.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200
56106	473.8 to 474.8 feet	Vertical Change	.4	5 ft	5	REF		
18260	474.5 to 482.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	40	SF	\$40	\$1,580
59033	483.9 to 509.3 feet	Driveway				REF		
18262	484.5 to 485.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$280
40494	486.2 to 488.4 feet	Running Slope	5.0-6.0%	5 ft	11	REF		
18263	490.5 to 503.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	67	SF	\$40	\$2,660

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1909241129	WASHINGTON DR	TRUMAN DR	ROOSEVELT DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
54523	496.4 to 497.4 feet	Vertical Change	.3	5 ft	5	REF			
18268	522.6 to 567.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	226	SF	\$120	\$27,120	
54524	547.9 to 551.9 feet	Vertical Change	.3	5 ft	20	REF			
59034	567.5 to 593.5 feet	Driveway				REF			
57382	567.8 to 568.8 feet	Vertical Change	1.1	5 ft	5	REF			
40495	570.1 to 571.3 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
18273	574.3 to 590.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	82	SF	\$40	\$3,260	
18276	615.5 to 628.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	64	SF	\$120	\$7,620	
18277	630.3 to 632.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440	
18278	635.7 to 642.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	34	SF	\$120	\$4,140	
18279	642.6 to 649.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,200	
59035	645.9 to 673.3 feet	Driveway				REF			
40496	648.9 to 650.6 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
18281	652.6 to 660.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	38	SF	\$40	\$1,520	
18283	660.8 to 668.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	41	SF	\$40	\$1,620	
18285	679.9 to 684.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000	
18286	699.2 to 718.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	95	SF	\$120	\$11,340	
69	727.8 to 728.8 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
59036	731.1 to 757.3 feet	Driveway				REF			
18292	736.2 to 746.4 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	51	SF	\$40	\$2,040	
18294	749.1 to 753.8 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	24	SF	\$40	\$940	
56108	756.1 to 757.1 feet	Vertical Change	.4	5 ft	5	REF			
56109	774.6 to 775.6 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
18296	779.0 to 786.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,380	
54525	793.6 to 794.6 feet	Vertical Change	.3	5 ft	5	REF			
18297	794.1 to 813.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	97	SF	\$120	\$11,580	
18301	824.7 to 845.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	104	SF	\$120	\$12,420	
54526	842.0 to 843.0 feet	Vertical Change	.3	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909241129	WASHINGTON DR	TRUMAN DR	ROOSEVELT DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
18303	847.9 to 853.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,480
59037	857.8 to 884.8 feet	Driveway				REF		
18304	863.7 to 879.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	78	SF	\$40	\$3,120
18308	879.6 to 881.5 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	10	SF	\$40	\$380
59038	894.8 to 919.6 feet	Driveway				REF		
18309	900.1 to 916.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	83	SF	\$40	\$3,300
18313	920.5 to 974.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	269	SF	\$40	\$10,740
59039	972.3 to 1000.0 feet	Driveway				REF		
18324	975.0 to 976.1 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$220
18325	977.8 to 979.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	10	SF	\$40	\$380
18326	981.8 to 996.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	73	SF	\$40	\$2,900
18330	1054.2 to 1056.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,140
59040	1057.7 to 1084.7 feet	Driveway				REF		
54527	1058.4 to 1059.4 feet	Vertical Change	.3	5 ft	5	REF		
18331	1058.8 to 1060.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$260
18332	1063.2 to 1080.2 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	85	SF	\$40	\$3,400
56110	1083.1 to 1084.1 feet	Vertical Change	.4	5 ft	5	REF		
18335	1103.3 to 1131.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	140	SF	\$120	\$16,740
18340	1133.6 to 1156.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	113	SF	\$120	\$13,500
18346	1162.8 to 1172.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,060
59041	1176.5 to 1202.7 feet	Driveway				REF		
40497	1180.0 to 1181.0 feet	Running Slope	7.0-8.0%	5 ft	5	REF		
18347	1182.4 to 1199.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	86	SF	\$40	\$3,460
56111	1201.0 to 1202.0 feet	Vertical Change	.4	5 ft	5	REF		
18351	1204.3 to 1209.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120
TOTAL COST FOR: N side of WASHINGTON DR Starting at: TRUMAN DR							\$303,990.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1909241133	WASHINGTON DR	ROOSEVELT DR	VERNAL DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
18144	2.3 to 10.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800	
59025	9.8 to 36.0 feet	Driveway				REF			
18147	10.3 to 12.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	13	SF	\$40	\$500	
40489	12.8 to 14.4 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
18149	16.7 to 31.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	76	SF	\$40	\$3,020	
18153	35.0 to 54.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	95	SF	\$40	\$3,800	
18155	54.0 to 65.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,660	
54512	80.0 to 81.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
18156	84.7 to 98.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	70	SF	\$120	\$8,400	
54513	102.5 to 103.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
18159	106.2 to 128.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	111	SF	\$120	\$13,320	
59026	133.0 to 159.8 feet	Driveway				REF			
18168	133.3 to 134.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240	
56102	133.9 to 134.9 feet	Vertical Change	.4	5 ft	5	REF			
18169	139.9 to 141.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	6	SF	\$40	\$260	
18170	143.3 to 155.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	61	SF	\$40	\$2,460	
40490	156.5 to 158.5 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
54514	158.6 to 159.6 feet	Vertical Change	.3	5 ft	5	REF			
18175	159.0 to 161.9 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	15	SF	\$40	\$580	
18177	163.3 to 170.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	35	SF	\$120	\$4,200	
54515	168.9 to 169.9 feet	Vertical Change	.3	5 ft	5	REF			
18180	170.3 to 175.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000	
67	170.7 to 171.7 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
TOTAL COST FOR:		N	<i>side of</i> WASHINGTON DR	<i>Starting at:</i> ROOSEVELT DR				\$52,590.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909241136	VERNAL DR	WASHINGTON DR	ADAMS DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
18106	0.0 to 6.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,960
59022	4.3 to 49.1 feet	Driveway				REF		
54508	4.4 to 5.4 feet	Vertical Change	.3	5 ft	5	REF		
18108	11.9 to 45.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	168	SF	\$40	\$6,720
54509	26.9 to 27.9 feet	Vertical Change	.3	5 ft	5	REF		
18117	47.0 to 48.1 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	6	SF	\$40	\$220
18118	48.8 to 63.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	73	SF	\$40	\$2,900
56100	58.7 to 59.7 feet	Vertical Change	.4	5 ft	5	REF		
18120	63.3 to 75.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,440
59023	72.4 to 100.3 feet	Driveway				REF		
18122	79.1 to 94.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	76	SF	\$40	\$3,020
18127	94.2 to 96.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	11	SF	\$40	\$440
56101	98.9 to 99.9 feet	Vertical Change	.4	5 ft	5	REF		
18128	101.3 to 111.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,880
18130	116.7 to 128.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,960
54510	126.9 to 127.9 feet	Vertical Change	.3	5 ft	5	REF		
56682	134.3 to 135.3 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375
18131	184.1 to 194.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,480
59024	192.9 to 218.7 feet	Driveway				REF		
40488	195.7 to 196.8 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
18136	199.0 to 215.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	84	SF	\$40	\$3,340
18141	218.9 to 225.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	31	SF	\$40	\$1,220
54511	221.9 to 222.9 feet	Vertical Change	.3	5 ft	5	REF		
18143	225.5 to 226.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780
TOTAL COST FOR: W side of VERNAL DR Starting at: WASHINGTON DR							\$49,735.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1909241139	ADAMS DR	VERNAL DR	1 ADAMS DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
18071	1.1 to 69.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	343	SF	\$120	\$41,220	
18082	70.6 to 73.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440	
59020	78.2 to 95.0 feet	Driveway				REF			
54507	78.6 to 79.6 feet	Vertical Change	.3	5 ft	5	REF			
18083	82.1 to 92.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	51	SF	\$40	\$2,040	
18086	94.3 to 110.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	81	SF	\$40	\$3,240	
59021	107.9 to 134.4 feet	Driveway				REF			
56098	108.7 to 109.7 feet	Vertical Change	.4	5 ft	5	REF			
40487	110.0 to 111.9 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
18090	110.5 to 114.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	19	SF	\$40	\$740	
18092	114.7 to 132.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	90	SF	\$40	\$3,600	
18097	133.5 to 134.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	5	SF	\$40	\$200	
18098	135.8 to 154.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	93	SF	\$120	\$11,160	
18101	154.4 to 172.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	92	SF	\$120	\$11,040	
56099	161.5 to 162.5 feet	Vertical Change	.4	5 ft	5	REF			
18105	172.8 to 176.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	18	SF	\$120	\$2,100	
TOTAL COST FOR: N side of ADAMS DR Starting at: VERNAL DR								\$76,780.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909241141	ADAMS DR	SIDEWALK BEGINS	VERNAL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54506	8.9 to 9.9 feet	Vertical Change	.3	5 ft	5	REF		
18060	9.6 to 25.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	77	SF	\$120	\$9,240
57432	22.3 to 23.3 feet	Vertical Change	1.3	5 ft	5	REF		
18064	28.8 to 34.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	30	SF	\$120	\$3,540
56097	33.7 to 34.7 feet	Vertical Change	.4	5 ft	5	REF		
18066	35.1 to 37.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140
18067	46.4 to 53.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,080
18070	70.0 to 76.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,080
TOTAL COST FOR: S side of ADAMS DR Starting at: SIDEWALK BEGINS							\$22,080.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1909241144	VERNAL DR	ADAMS DR	GRANT DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
18008	0.0 to 8.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800	
59017	6.9 to 33.2 feet	Driveway				REF			
40485	9.3 to 11.3 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
18010	11.4 to 15.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	23	SF	\$40	\$900	
18013	16.3 to 28.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	63	SF	\$40	\$2,520	
18016	33.2 to 35.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	10	SF	\$40	\$420	
18017	37.5 to 87.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	250	SF	\$120	\$30,000	
57564	66.2 to 67.2 feet	Vertical Change	2.5	5 ft	5	REF			
18027	89.1 to 91.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	11	SF	\$120	\$1,320	
18029	92.8 to 108.2 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	77	SF	\$120	\$9,240	
18034	111.8 to 112.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$660	
18035	113.2 to 124.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,480	
59018	121.8 to 148.0 feet	Driveway				REF			
18037	127.3 to 130.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	16	SF	\$40	\$620	
18039	130.4 to 144.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	69	SF	\$40	\$2,760	
40486	144.2 to 146.3 feet	Running Slope	5.0-6.0%	5 ft	11	REF			
54505	151.3 to 152.3 feet	Vertical Change	.3	5 ft	5	REF			
18041	151.4 to 154.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680	
18042	157.8 to 160.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440	
18043	163.2 to 178.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	76	SF	\$120	\$9,060	
59019	192.3 to 240.0 feet	Driveway				REF			
18046	197.4 to 199.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	12	SF	\$40	\$480	
18048	199.8 to 202.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	15	SF	\$40	\$600	
18050	203.2 to 211.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	43	SF	\$40	\$1,720	
18052	211.8 to 234.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	115	SF	\$40	\$4,600	
57011	238.7 to 239.7 feet	Vertical Change	.6	5 ft	5	REF			
TOTAL COST FOR: W							side of VERNAL DR Starting at: ADAMS DR	\$79,300.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1909241159	GRANT DR	VERNAL DR	TRUMAN DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
56086	5.1 to 6.1 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
66	16.0 to 17.0 feet	Continuous Width		5 ft	5	SF	\$120	\$600	
57453	18.0 to 19.0 feet	Vertical Change	1.4	5 ft	5	SF	\$75	\$375	
59000	20.3 to 44.3 feet	Driveway				REF			
17791	22.0 to 25.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	15	SF	\$40	\$600	
17793	25.6 to 38.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	66	SF	\$40	\$2,640	
17796	38.8 to 39.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200	
17797	42.3 to 43.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200	
17798	43.3 to 57.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	70	SF	\$40	\$2,800	
17801	63.1 to 65.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620	
17802	69.5 to 73.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,580	
17803	78.1 to 99.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	105	SF	\$120	\$12,540	
54488	81.2 to 82.2 feet	Vertical Change	.3	5 ft	5	REF			
59001	98.2 to 124.9 feet	Driveway				REF			
56087	98.4 to 99.4 feet	Vertical Change	.4	5 ft	5	REF			
17808	106.2 to 121.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	78	SF	\$40	\$3,100	
40477	123.3 to 124.5 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
17813	124.0 to 133.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	46	SF	\$40	\$1,820	
54489	132.9 to 133.9 feet	Vertical Change	.3	5 ft	5	REF			
17817	133.1 to 136.6 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	18	SF	\$120	\$2,100	
17818	136.6 to 142.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	29	SF	\$120	\$3,420	
17820	142.3 to 144.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	10	SF	\$120	\$1,200	
17821	145.3 to 146.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720	
17822	152.0 to 162.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,480	
54490	160.0 to 161.0 feet	Vertical Change	.3	5 ft	5	REF			
17825	163.6 to 168.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	22	SF	\$120	\$2,640	
56088	166.9 to 170.9 feet	Vertical Change	.4	5 ft	20	REF			
17828	168.0 to 171.0 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	15	SF	\$120	\$1,800	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1909241159	GRANT DR	VERNAL DR	TRUMAN DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
17829	171.0 to 176.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	27	SF	\$120	\$3,180	
56089	176.5 to 177.5 feet	Vertical Change	.4	5 ft	5	REF			
17831	176.5 to 177.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$780	
17832	177.8 to 178.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600	
54491	198.7 to 199.7 feet	Vertical Change	.3	5 ft	5	REF			
17833	199.2 to 228.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	148	SF	\$120	\$17,760	
59002	227.0 to 253.2 feet	Driveway				REF			
17835	233.2 to 250.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	85	SF	\$40	\$3,380	
40478	250.8 to 252.4 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
56090	251.9 to 252.9 feet	Vertical Change	.4	5 ft	5	REF			
17838	253.3 to 254.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$220	
17839	254.4 to 297.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	216	SF	\$120	\$25,860	
17843	301.1 to 304.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,860	
59003	304.8 to 332.3 feet	Driveway				REF			
17844	306.5 to 307.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$220	
17845	311.1 to 329.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	91	SF	\$40	\$3,640	
17850	331.3 to 337.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	30	SF	\$40	\$1,180	
59004	334.3 to 361.4 feet	Driveway				REF			
40479	337.5 to 339.4 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
17852	339.9 to 357.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	89	SF	\$40	\$3,540	
17856	361.2 to 362.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	6	SF	\$40	\$240	
56091	361.3 to 362.3 feet	Vertical Change	.4	5 ft	5	REF			
17857	365.0 to 381.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	84	SF	\$120	\$10,080	
54492	365.9 to 366.9 feet	Vertical Change	.3	5 ft	5	REF			
54493	377.2 to 378.2 feet	Vertical Change	.3	5 ft	5	REF			
17863	381.8 to 430.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	245	SF	\$120	\$29,400	
17869	437.5 to 457.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	98	SF	\$120	\$11,700	
56092	446.4 to 447.4 feet	Vertical Change	.4	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
S	1909241159	GRANT DR	VERNAL DR	TRUMAN DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
17871	460.9 to 467.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,720	
59005	463.8 to 490.1 feet	Driveway				REF			
54494	464.1 to 465.1 feet	Vertical Change	.3	5 ft	5	REF			
17873	470.9 to 474.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	20	SF	\$40	\$780	
17875	475.2 to 479.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	21	SF	\$40	\$820	
17877	479.3 to 485.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	33	SF	\$40	\$1,300	
56093	502.3 to 503.3 feet	Vertical Change	.4	5 ft	5	REF			
17880	503.2 to 544.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	206	SF	\$120	\$24,720	
56680	523.6 to 524.6 feet	Vertical Change	.5	5 ft	5	REF			
56681	530.4 to 531.4 feet	Vertical Change	.5	5 ft	5	REF			
59006	542.7 to 568.8 feet	Driveway				REF			
57010	543.0 to 544.0 feet	Vertical Change	.6	5 ft	5	REF			
40480	545.5 to 547.1 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
17887	548.6 to 565.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	86	SF	\$40	\$3,440	
17891	569.3 to 570.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$220	
17892	570.9 to 585.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,940	
57495	582.7 to 583.7 feet	Vertical Change	1.7	5 ft	5	REF			
54495	590.2 to 591.2 feet	Vertical Change	.3	5 ft	5	REF			
17894	590.4 to 594.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	22	SF	\$120	\$2,640	
17895	597.6 to 602.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	23	SF	\$120	\$2,820	
57574	601.5 to 602.5 feet	Vertical Change	2.7	5 ft	5	REF			
17896	602.7 to 607.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000	
17898	608.2 to 624.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	81	SF	\$120	\$9,720	
59007	621.5 to 647.8 feet	Driveway				REF			
17900	626.8 to 628.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	10	SF	\$40	\$400	
17902	629.0 to 644.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	76	SF	\$40	\$3,060	
17906	647.8 to 651.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	20	SF	\$40	\$800	
17909	651.8 to 668.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	82	SF	\$120	\$9,780	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
S	1909241159	GRANT DR	VERNAL DR	TRUMAN DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
17913	670.8 to 704.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	167	SF	\$120	\$19,980	
56094	676.8 to 677.8 feet	Vertical Change	.4	5 ft	5	REF			
59008	700.6 to 727.3 feet	Driveway				REF			
56095	701.5 to 702.5 feet	Vertical Change	.4	5 ft	5	REF			
17920	706.3 to 708.4 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	11	SF	\$40	\$420	
17922	708.4 to 718.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	50	SF	\$40	\$1,980	
17927	720.8 to 722.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	10	SF	\$40	\$380	
59009	731.5 to 757.1 feet	Driveway				REF			
54496	731.9 to 732.9 feet	Vertical Change	.3	5 ft	5	REF			
17928	732.7 to 733.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200	
40481	734.2 to 735.2 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
17929	737.7 to 752.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	75	SF	\$40	\$2,980	
54497	779.9 to 780.9 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
56096	795.1 to 796.1 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
59010	859.1 to 884.7 feet	Driveway				REF			
17934	859.9 to 861.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$220	
17935	865.8 to 878.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	65	SF	\$40	\$2,580	
17938	879.1 to 881.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	13	SF	\$40	\$520	
17939	883.2 to 884.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	5	SF	\$40	\$200	
17940	885.1 to 907.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	113	SF	\$40	\$4,520	
17945	907.7 to 929.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	109	SF	\$120	\$13,020	
17950	937.6 to 939.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260	
59011	938.0 to 963.8 feet	Driveway				REF			
40482	940.9 to 942.4 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
54498	943.0 to 944.0 feet	Vertical Change	.3	5 ft	5	REF			
17951	944.0 to 959.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	76	SF	\$40	\$3,040	
54499	962.7 to 963.7 feet	Vertical Change	.3	5 ft	5	REF			
57171	972.8 to 973.8 feet	Vertical Change	.7	5 ft	5	SF	\$75	\$375	
17955	977.5 to 981.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,460	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1909241159	GRANT DR	VERNAL DR	TRUMAN DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
54500	978.7 to 979.7 feet	Vertical Change	.3	5 ft	5	REF			
17956	986.1 to 1006.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	103	SF	\$120	\$12,300	
17957	1010.3 to 1013.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620	
59012	1017.8 to 1043.2 feet	Driveway				REF			
17959	1018.2 to 1019.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$280	
40483	1019.4 to 1021.0 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
17960	1023.7 to 1040.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	83	SF	\$40	\$3,320	
17965	1063.9 to 1097.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	166	SF	\$120	\$19,980	
54501	1079.9 to 1080.9 feet	Vertical Change	.3	5 ft	5	REF			
59013	1096.0 to 1121.4 feet	Driveway				REF			
17968	1100.5 to 1116.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	81	SF	\$40	\$3,240	
17972	1116.9 to 1118.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	7	SF	\$40	\$280	
17973	1121.9 to 1125.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,340	
59014	1125.2 to 1151.3 feet	Driveway				REF			
17974	1129.3 to 1133.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	19	SF	\$40	\$740	
17976	1133.0 to 1141.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	40	SF	\$40	\$1,620	
17978	1141.1 to 1147.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	34	SF	\$40	\$1,360	
17979	1151.0 to 1255.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	523	SF	\$40	\$20,920	
54502	1174.2 to 1175.2 feet	Vertical Change	.3	5 ft	5	REF			
59015	1253.9 to 1279.4 feet	Driveway				REF			
40484	1256.5 to 1257.8 feet	Running Slope	6.0-7.0%	5 ft	7	REF			
17988	1258.4 to 1276.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	89	SF	\$40	\$3,580	
17992	1279.8 to 1287.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,380	
17995	1287.1 to 1291.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	20	SF	\$120	\$2,400	
54503	1288.8 to 1289.8 feet	Vertical Change	.3	5 ft	5	REF			
17997	1291.1 to 1333.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	210	SF	\$120	\$25,140	
59016	1332.8 to 1357.6 feet	Driveway				REF			
18000	1336.9 to 1354.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	86	SF	\$40	\$3,440	
18005	1358.0 to 1373.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	75	SF	\$40	\$3,000	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909241159	GRANT DR	VERNAL DR	TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54504	1359.2 to 1360.2 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: S side of GRANT DR Starting at: VERNAL DR							\$402,435.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909241202	TRUMAN DR	GRANT DR	VAN BUREN ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
17749	1.8 to 12.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,180
54484	11.0 to 12.0 feet	Vertical Change	.3	5 ft	5	REF		
17752	22.8 to 27.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700
54485	26.5 to 27.5 feet	Vertical Change	.3	5 ft	5	REF		
17754	55.8 to 67.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,080
17757	68.5 to 77.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	43	SF	\$120	\$5,100
17758	78.1 to 88.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,420
17760	88.8 to 126.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	189	SF	\$120	\$22,680
56678	95.5 to 96.5 feet	Vertical Change	.5	5 ft	5	REF		
56083	115.9 to 116.9 feet	Vertical Change	.4	5 ft	5	REF		
58998	125.1 to 147.9 feet	Driveway				REF		
17769	131.0 to 144.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	68	SF	\$40	\$2,700
54486	146.2 to 147.2 feet	Vertical Change	.3	5 ft	5	REF		
17776	147.9 to 149.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$220
17777	149.0 to 157.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,220
58999	155.8 to 178.7 feet	Driveway				REF		
40476	158.9 to 160.1 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
17779	161.1 to 175.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	73	SF	\$40	\$2,920
56084	177.2 to 178.2 feet	Vertical Change	.4	5 ft	5	REF		
17783	179.5 to 185.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,540
17785	185.4 to 221.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	182	SF	\$120	\$21,780
54487	191.6 to 192.6 feet	Vertical Change	.3	5 ft	5	REF		
56085	196.3 to 197.3 feet	Vertical Change	.4	5 ft	5	REF		
TOTAL COST FOR: W side of TRUMAN DR Starting at: GRANT DR							\$86,540.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909241205	VAN BUREN ST	TRUMAN DR	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
17735	0.0 to 13.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	67	SF	\$120	\$8,040
54483	6.9 to 7.9 feet	Vertical Change	.3	5 ft	5	REF		
17738	15.6 to 36.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	103	SF	\$120	\$12,360
17742	53.3 to 89.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	181	SF	\$120	\$21,660
57410	83.9 to 84.9 feet	Vertical Change	1.2	5 ft	5	REF		
17748	89.9 to 95.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	28	SF	\$120	\$3,300
TOTAL COST FOR: N side of VAN BUREN ST Starting at: TRUMAN DR							\$45,360.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909241207	VAN BUREN ST	SIDEWALK BEGINS	TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
17728	0.0 to 6.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	32	SF	\$120	\$3,780
17729	6.7 to 18.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,960
57009	56.2 to 57.2 feet	Vertical Change	.6	5 ft	5	SF	\$75	\$375
17732	57.9 to 76.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	91	SF	\$120	\$10,920
17734	79.0 to 81.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380
TOTAL COST FOR: S side of VAN BUREN ST Starting at: SIDEWALK BEGINS							\$23,415.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909241210	TRUMAN DR	VAN BUREN ST	JACKSON CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
17677	0.0 to 5.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,360
17679	5.6 to 9.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	18	SF	\$120	\$2,160
17681	9.2 to 15.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,660
17684	19.5 to 29.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$6,000
17685	31.8 to 34.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,500
58994	32.4 to 55.3 feet	Driveway				REF		
56081	33.1 to 34.1 feet	Vertical Change	.4	5 ft	5	REF		
17686	37.8 to 52.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	75	SF	\$40	\$2,980
40472	52.8 to 53.9 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
54478	53.8 to 54.8 feet	Vertical Change	.3	5 ft	5	REF		
17689	57.3 to 63.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,780
58995	62.7 to 85.9 feet	Driveway				REF		
40473	64.9 to 66.4 feet	Running Slope	6.0-7.0%	5 ft	8	REF		
17691	67.6 to 81.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	69	SF	\$40	\$2,740
40474	83.3 to 85.5 feet	Running Slope	5.0-6.0%	5 ft	11	REF		
17693	86.3 to 90.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	20	SF	\$40	\$780
56082	90.2 to 91.2 feet	Vertical Change	.4	5 ft	5	REF		
17694	93.7 to 102.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	43	SF	\$120	\$5,160
17696	103.3 to 110.5 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	36	SF	\$120	\$4,320
17698	110.5 to 115.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	24	SF	\$120	\$2,880
17699	115.6 to 157.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	208	SF	\$120	\$24,900
58996	155.8 to 178.5 feet	Driveway				REF		
17706	161.5 to 168.5 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	35	SF	\$40	\$1,400
17708	168.5 to 175.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	34	SF	\$40	\$1,360
17711	178.4 to 184.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	30	SF	\$40	\$1,180
17712	184.3 to 187.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,100
58997	186.2 to 209.2 feet	Driveway				REF		
54479	186.6 to 187.6 feet	Vertical Change	.3	5 ft	5	REF		
40475	188.4 to 190.3 feet	Running Slope	5.0-6.0%	5 ft	10	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909241210	TRUMAN DR	VAN BUREN ST	JACKSON CT	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
17714	191.3 to 203.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	63	SF	\$40	\$2,500
17717	205.1 to 206.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	6	SF	\$40	\$240
17718	209.2 to 242.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	168	SF	\$40	\$6,720
54480	216.7 to 217.7 feet	Vertical Change	.3	5 ft	5	REF		
54481	226.1 to 227.1 feet	Vertical Change	.3	5 ft	5	REF		
54482	236.6 to 237.6 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: W side of TRUMAN DR Starting at: VAN BUREN ST							\$79,720.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
W	1909241215	JACKSON CT	TRUMAN DR	TRUMAN DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
17613	0.0 to 1.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$780	
17614	2.4 to 64.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	310	SF	\$120	\$37,140	
17623	67.1 to 110.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	219	SF	\$120	\$26,280	
54469	110.3 to 111.3 feet	Vertical Change	.3	5 ft	5	REF			
58991	110.7 to 133.7 feet	Driveway				REF			
40471	112.2 to 113.4 feet	Running Slope	6.0-7.0%	5 ft	6	REF			
17629	114.5 to 131.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	83	SF	\$40	\$3,300	
17631	133.2 to 134.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$220	
17632	134.8 to 138.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,460	
58992	136.6 to 160.5 feet	Driveway				REF			
54470	136.7 to 137.7 feet	Vertical Change	.3	5 ft	5	REF			
17634	142.2 to 145.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	17	SF	\$40	\$680	
17636	146.1 to 148.7 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	13	SF	\$40	\$520	
17638	148.7 to 157.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	43	SF	\$40	\$1,700	
54471	159.0 to 160.0 feet	Vertical Change	.3	5 ft	5	REF			
17642	160.4 to 172.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	62	SF	\$40	\$2,460	
54472	168.1 to 169.1 feet	Vertical Change	.3	5 ft	5	REF			
54473	176.2 to 177.2 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
17645	190.4 to 193.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620	
56079	199.8 to 200.8 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
54474	211.7 to 212.7 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
17647	215.5 to 246.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	155	SF	\$120	\$18,600	
58993	244.5 to 270.7 feet	Driveway				REF			
54475	245.3 to 246.3 feet	Vertical Change	.3	5 ft	5	REF			
17651	250.7 to 265.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	75	SF	\$40	\$3,000	
17656	271.8 to 276.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,940	
17657	280.3 to 282.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200	
17658	285.1 to 307.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	111	SF	\$120	\$13,320	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909241215	JACKSON CT	TRUMAN DR	TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
17664	308.2 to 313.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	28	SF	\$120	\$3,420
17665	317.6 to 330.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	63	SF	\$120	\$7,620
17667	330.3 to 338.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,680
17669	340.7 to 355.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,700
54476	343.0 to 344.0 feet	Vertical Change	.3	5 ft	5	REF		
56080	353.3 to 354.3 feet	Vertical Change	.4	5 ft	5	REF		
17671	358.5 to 390.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	161	SF	\$120	\$19,320
54477	363.4 to 364.4 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: W side of JACKSON CT Starting at: TRUMAN DR							\$161,085.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
W	1909241217	TRUMAN DR	JACKSON CT	PALM PKY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
17583	0.0 to 5.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	30	SF	\$120	\$3,540	
17586	6.4 to 14.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,860	
54466	6.6 to 7.6 feet	Vertical Change	.3	5 ft	5	REF			
17589	14.5 to 20.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	32	SF	\$120	\$3,780	
17591	20.8 to 22.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
17592	29.3 to 30.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900	
58989	29.4 to 51.9 feet	Driveway				REF			
17593	35.8 to 48.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	64	SF	\$40	\$2,560	
54467	40.5 to 41.5 feet	Vertical Change	.3	5 ft	5	REF			
17596	52.7 to 55.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	12	SF	\$120	\$1,440	
17597	55.1 to 62.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320	
58990	60.3 to 83.4 feet	Driveway				REF			
40469	62.5 to 64.0 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
17599	66.0 to 80.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	72	SF	\$40	\$2,860	
17604	84.3 to 85.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$720	
17605	85.5 to 94.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,460	
54468	92.2 to 93.2 feet	Vertical Change	.3	5 ft	5	REF			
17607	95.8 to 103.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	37	SF	\$120	\$4,440	
17608	103.2 to 109.6 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	32	SF	\$120	\$3,840	
17609	109.6 to 114.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	23	SF	\$120	\$2,700	
40470	113.2 to 115.3 feet	Running Slope	5.0-6.0%	5 ft	11	REF			
57409	113.3 to 114.3 feet	Vertical Change	1.2	5 ft	5	REF			
17611	114.3 to 116.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,080	
17612	116.1 to 118.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440	
TOTAL COST FOR: W							<i>side of TRUMAN DR Starting at: JACKSON CT</i>	\$45,020.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909241318	GRANT DR	TRUMAN DR	VERNAL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
17383	4.2 to 5.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720
58972	4.3 to 30.2 feet	Driveway				REF		
54454	4.5 to 5.5 feet	Vertical Change	.3	5 ft	5	REF		
17384	9.3 to 26.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	84	SF	\$40	\$3,360
17391	36.2 to 41.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,420
54455	61.6 to 62.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
17392	63.2 to 91.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	144	SF	\$120	\$17,220
17394	100.9 to 112.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,900
17396	114.7 to 116.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,020
17397	116.4 to 117.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
17398	125.5 to 129.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	18	SF	\$120	\$2,220
58973	126.8 to 153.5 feet	Driveway				REF		
56075	127.0 to 128.0 feet	Vertical Change	.4	5 ft	5	REF		
17400	131.2 to 132.2 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200
17401	134.4 to 136.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	8	SF	\$40	\$320
17402	140.5 to 147.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	33	SF	\$40	\$1,320
17404	147.1 to 149.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	11	SF	\$40	\$440
17405	151.1 to 155.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	20	SF	\$40	\$780
65	154.0 to 155.0 feet	Continuous Width		5 ft	5	SF	\$120	\$600
17407	155.0 to 157.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
58974	156.3 to 181.8 feet	Driveway				REF		
17408	160.9 to 179.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	91	SF	\$40	\$3,620
57628	188.8 to 189.8 feet	Vertical Change	3.3	5 ft	5	SF	\$75	\$375
17413	204.3 to 213.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,760
17414	222.5 to 237.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,820
58975	235.7 to 261.3 feet	Driveway				REF		
17416	240.7 to 257.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	85	SF	\$40	\$3,400
17419	261.6 to 262.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$720
17420	262.8 to 269.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1909241318	GRANT DR	TRUMAN DR	VERNAL DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
17422	273.0 to 274.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900	
17423	277.1 to 315.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	191	SF	\$120	\$22,920	
54456	314.4 to 315.4 feet	Vertical Change	.3	5 ft	5	REF			
58976	314.7 to 340.3 feet	Driveway				REF			
17429	315.3 to 316.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	8	SF	\$40	\$320	
17430	319.8 to 323.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	20	SF	\$40	\$800	
17432	323.8 to 333.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	48	SF	\$40	\$1,920	
17434	333.4 to 337.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	19	SF	\$40	\$740	
17435	339.8 to 340.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200	
17436	340.8 to 349.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$4,980	
17439	351.5 to 422.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	356	SF	\$120	\$42,660	
54457	374.4 to 375.4 feet	Vertical Change	.3	5 ft	5	REF			
56076	391.4 to 392.4 feet	Vertical Change	.4	5 ft	5	REF			
17449	422.6 to 443.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	106	SF	\$120	\$12,660	
58977	442.0 to 467.9 feet	Driveway				REF			
54458	442.1 to 443.1 feet	Vertical Change	.3	5 ft	5	REF			
17453	447.2 to 465.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	89	SF	\$40	\$3,560	
17458	468.4 to 469.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$280	
58978	472.5 to 498.1 feet	Driveway				REF			
40463	475.1 to 476.2 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
17459	477.3 to 494.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	88	SF	\$40	\$3,500	
17463	498.3 to 499.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$220	
17464	499.4 to 516.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	84	SF	\$120	\$10,140	
17466	516.3 to 529.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	68	SF	\$120	\$8,160	
54459	517.0 to 518.0 feet	Vertical Change	.3	5 ft	5	REF			
17468	529.9 to 537.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,500	
17471	539.5 to 549.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	51	SF	\$120	\$6,180	
17472	550.3 to 552.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560	
58979	551.4 to 577.1 feet	Driveway				REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1909241318	GRANT DR	TRUMAN DR	VERNAL DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
40464	553.0 to 554.9 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
17473	556.6 to 573.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	83	SF	\$40	\$3,340	
17475	577.3 to 595.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	91	SF	\$40	\$3,640	
17477	611.3 to 630.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	94	SF	\$120	\$11,280	
58980	628.8 to 655.1 feet	Driveway				REF			
54460	629.0 to 630.0 feet	Vertical Change	.3	5 ft	5	REF			
40465	631.6 to 632.8 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
17478	634.4 to 637.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	16	SF	\$40	\$640	
17480	638.0 to 641.0 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	15	SF	\$40	\$600	
17482	641.0 to 651.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	55	SF	\$40	\$2,180	
17487	655.6 to 656.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600	
17488	678.1 to 734.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	282	SF	\$120	\$33,840	
17493	752.6 to 757.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760	
56677	758.9 to 759.9 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375	
58981	759.0 to 784.0 feet	Driveway				REF			
17495	763.3 to 781.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	90	SF	\$40	\$3,580	
58982	787.1 to 813.8 feet	Driveway				REF			
17498	792.1 to 809.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	85	SF	\$40	\$3,380	
17502	809.0 to 811.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	12	SF	\$40	\$480	
56077	813.0 to 814.0 feet	Vertical Change	.4	5 ft	5	REF			
17504	815.3 to 816.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$900	
17505	816.8 to 868.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	259	SF	\$120	\$31,080	
58983	867.1 to 892.5 feet	Driveway				REF			
17512	872.5 to 888.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	81	SF	\$40	\$3,240	
54461	891.6 to 892.6 feet	Vertical Change	.3	5 ft	5	REF			
17517	892.9 to 894.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660	
17518	902.0 to 946.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	223	SF	\$120	\$26,760	
54462	902.7 to 903.7 feet	Vertical Change	.3	5 ft	5	REF			
58984	945.1 to 971.3 feet	Driveway				REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	1909241318	GRANT DR	TRUMAN DR	VERNAL DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
54463	945.7 to 946.7 feet	Vertical Change	.3	5 ft	5	REF			
17522	946.6 to 947.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	6	SF	\$40	\$240	
17523	950.3 to 956.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	30	SF	\$40	\$1,200	
17526	956.3 to 959.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	15	SF	\$40	\$580	
17527	962.3 to 967.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	27	SF	\$40	\$1,080	
17529	967.7 to 968.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	6	SF	\$40	\$220	
17530	971.3 to 1027.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	280	SF	\$40	\$11,180	
58985	1024.4 to 1050.2 feet	Driveway				REF			
17542	1031.2 to 1046.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	79	SF	\$40	\$3,140	
17545	1052.7 to 1071.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	96	SF	\$120	\$11,520	
17547	1072.1 to 1132.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	302	SF	\$120	\$36,240	
17553	1132.5 to 1138.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,660	
17554	1140.8 to 1153.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,740	
54464	1152.9 to 1153.9 feet	Vertical Change	.3	5 ft	5	REF			
58986	1153.1 to 1178.5 feet	Driveway				REF			
40466	1154.8 to 1156.6 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
17558	1158.6 to 1163.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	26	SF	\$40	\$1,020	
17560	1163.7 to 1175.4 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	59	SF	\$40	\$2,340	
40467	1176.2 to 1178.3 feet	Running Slope	5.0-6.0%	5 ft	11	REF			
17562	1178.9 to 1183.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,460	
54465	1180.1 to 1181.1 feet	Vertical Change	.3	5 ft	5	REF			
58987	1183.2 to 1208.4 feet	Driveway				REF			
17564	1187.7 to 1205.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	88	SF	\$40	\$3,500	
57008	1207.7 to 1208.7 feet	Vertical Change	.6	5 ft	5	REF			
17572	1208.7 to 1209.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$600	
17573	1209.7 to 1258.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	243	SF	\$120	\$29,100	
58988	1302.8 to 1328.2 feet	Driveway				REF			
40468	1304.5 to 1306.0 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
17577	1308.8 to 1324.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	80	SF	\$40	\$3,180	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909241318	GRANT DR	TRUMAN DR	VERNAL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56078	1326.8 to 1327.8 feet	Vertical Change	.4	5 ft	5	REF		
17582	1330.0 to 1333.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340
TOTAL COST FOR: N side of GRANT DR Starting at: TRUMAN DR							\$444,585.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
E	1909241323	VERNAL DR	GRANT DR	WASHINGTON DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
54447	20.9 to 21.9 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
56073	36.7 to 37.7 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
54448	54.7 to 61.2 feet	Vertical Change	.3	5 ft	33	LF	\$75	\$2,438	
17336	56.9 to 60.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340	
17337	70.8 to 119.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	245	SF	\$120	\$29,400	
17343	120.8 to 123.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	12	SF	\$120	\$1,380	
54451	121.1 to 122.1 feet	Vertical Change	.3	5 ft	5	REF			
58969	121.1 to 147.3 feet	Driveway				REF			
40462	122.5 to 124.3 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
17345	126.7 to 143.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	83	SF	\$40	\$3,320	
54452	145.7 to 146.7 feet	Vertical Change	.3	5 ft	5	REF			
17348	147.6 to 160.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	62	SF	\$120	\$7,440	
17349	162.2 to 175.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	66	SF	\$120	\$7,860	
17351	176.3 to 183.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020	
17352	190.5 to 201.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,420	
58970	198.3 to 225.0 feet	Driveway				REF			
17354	204.8 to 210.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	30	SF	\$40	\$1,180	
17356	210.7 to 213.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	13	SF	\$40	\$520	
17358	213.8 to 222.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	41	SF	\$40	\$1,640	
17361	229.3 to 230.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720	
58971	229.5 to 254.5 feet	Driveway				REF			
17362	233.8 to 243.2 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	47	SF	\$40	\$1,880	
17364	243.2 to 250.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	39	SF	\$40	\$1,540	
57252	254.0 to 255.0 feet	Vertical Change	.8	5 ft	5	REF			
17365	255.0 to 256.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780	
17366	264.1 to 347.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	416	SF	\$120	\$49,980	
54453	301.4 to 302.4 feet	Vertical Change	.3	5 ft	5	REF			
17380	347.4 to 374.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	136	SF	\$120	\$16,260	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
E	1909241323	VERNAL DR	GRANT DR	WASHINGTON DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
56676	350.1 to 351.1 feet	Vertical Change	.5	5 ft	5	REF			
56074	366.9 to 367.9 feet	Vertical Change	.4	5 ft	5	REF			
TOTAL COST FOR: E							<i>side of</i> VERNAL DR	<i>Starting at:</i> GRANT DR	\$139,867.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
S	1909241326	WASHINGTON DR	VERNAL DR	ROOSEVELT DR				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
17319	1.6 to 8.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020
58968	7.0 to 32.4 feet	Driveway				REF		
17321	8.3 to 9.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$200
17322	12.8 to 26.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	71	SF	\$40	\$2,820
17328	27.1 to 29.1 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	10	SF	\$40	\$400
17329	33.5 to 44.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,660
54442	46.9 to 47.9 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
54443	63.0 to 64.0 feet	Vertical Change	.3	5 ft	5	REF		
17330	63.8 to 108.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	223	SF	\$120	\$26,760
54444	68.4 to 69.4 feet	Vertical Change	.3	5 ft	5	REF		
54445	95.6 to 96.6 feet	Vertical Change	.3	5 ft	5	REF		
54446	111.6 to 112.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
17335	136.3 to 153.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	83	SF	\$120	\$10,020
TOTAL COST FOR:		S	<i>side of</i> WASHINGTON DR	<i>Starting at:</i> VERNAL DR				\$51,630.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority		
W	1909241328	ROOSEVELT DR	WASHINGTON DR	ADAMS DR					TBD		
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
17282	2.5 to 8.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,360			
58966	7.3 to 31.7 feet	Driveway				REF					
17285	11.8 to 28.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	85	SF	\$40	\$3,380			
54439	18.9 to 19.9 feet	Vertical Change	.3	5 ft	5	REF					
17289	31.6 to 33.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	7	SF	\$40	\$280			
17290	34.3 to 63.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	147	SF	\$120	\$17,580			
17296	86.7 to 95.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,340			
17298	95.6 to 130.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	173	SF	\$120	\$20,700			
54440	129.1 to 130.1 feet	Vertical Change	.3	5 ft	5	REF					
58967	129.2 to 155.3 feet	Driveway				REF					
17307	135.5 to 152.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	83	SF	\$40	\$3,340			
17312	154.8 to 165.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	51	SF	\$40	\$2,060			
54441	158.4 to 159.4 feet	Vertical Change	.3	5 ft	5	REF					
17316	165.1 to 177.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,560			
TOTAL COST FOR: W							<i>side of</i>	ROOSEVELT DR	<i>Starting at:</i>	WASHINGTON DR	\$63,600.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909241341	ROOSEVELT DR	ROOSEVELT DR	TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
17074	3.9 to 8.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760
17076	9.4 to 11.0 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	8	SF	\$120	\$960
54420	9.5 to 10.5 feet	Vertical Change	.3	5 ft	5	REF		
58951	10.4 to 53.3 feet	Driveway				REF		
57605	12.2 to 13.2 feet	Vertical Change	3	5 ft	5	REF		
17077	12.5 to 13.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	6	SF	\$40	\$220
17078	16.3 to 19.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	18	SF	\$40	\$700
54421	20.4 to 21.4 feet	Vertical Change	.3	5 ft	5	REF		
17080	20.8 to 27.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	32	SF	\$40	\$1,280
17082	27.2 to 44.8 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	88	SF	\$40	\$3,520
17086	44.8 to 48.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	17	SF	\$40	\$660
17088	48.1 to 50.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	11	SF	\$40	\$440
17090	51.8 to 52.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200
17091	53.2 to 59.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	30	SF	\$40	\$1,180
17092	63.8 to 66.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
54422	68.2 to 69.2 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
17093	70.3 to 80.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$6,000
64	88.8 to 89.8 feet	Continuous Width		5 ft	5	SF	\$120	\$600
17095	90.1 to 95.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120
58952	94.1 to 120.1 feet	Driveway				REF		
17097	99.1 to 108.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	45	SF	\$40	\$1,800
17099	108.1 to 116.4 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	42	SF	\$40	\$1,660
17101	116.4 to 117.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	6	SF	\$40	\$240
40457	117.9 to 119.3 feet	Running Slope	6.0-7.0%	5 ft	7	REF		
57006	118.8 to 119.8 feet	Vertical Change	.6	5 ft	5	REF		
17102	120.2 to 125.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	28	SF	\$40	\$1,120
17104	126.6 to 138.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	59	SF	\$120	\$7,080
17106	138.4 to 140.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
S	1909241341	ROOSEVELT DR	ROOSEVELT DR	TRUMAN DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
171107	142.9 to 148.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120	
171108	155.5 to 157.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200	
54423	170.8 to 171.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
171109	178.7 to 183.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760	
171111	191.2 to 219.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	141	SF	\$120	\$16,860	
171114	220.3 to 222.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	11	SF	\$120	\$1,320	
54424	220.9 to 221.9 feet	Vertical Change	.3	5 ft	5	REF			
58953	221.1 to 247.3 feet	Driveway				REF			
171115	226.3 to 243.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	85	SF	\$40	\$3,400	
54425	245.6 to 246.6 feet	Vertical Change	.3	5 ft	5	REF			
171121	247.8 to 252.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520	
171123	254.3 to 256.3 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	10	SF	\$120	\$1,200	
57170	254.7 to 255.7 feet	Vertical Change	.7	5 ft	5	REF			
58954	256.8 to 281.9 feet	Driveway				REF			
171124	257.1 to 258.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$220	
171125	261.2 to 278.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	85	SF	\$40	\$3,400	
54426	280.5 to 281.5 feet	Vertical Change	.3	5 ft	5	REF			
171131	282.8 to 284.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840	
171132	298.3 to 320.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	110	SF	\$120	\$13,200	
171135	328.7 to 331.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500	
171136	342.1 to 343.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020	
171137	346.4 to 355.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,640	
171139	360.3 to 379.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	94	SF	\$120	\$11,280	
56674	367.7 to 368.7 feet	Vertical Change	.5	5 ft	5	REF			
171143	379.1 to 383.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	24	SF	\$120	\$2,820	
58955	383.2 to 410.8 feet	Driveway				REF			
171145	389.6 to 393.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	19	SF	\$40	\$760	
171147	394.3 to 400.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	32	SF	\$40	\$1,260	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909241341	ROOSEVELT DR	ROOSEVELT DR	TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
17149	400.6 to 406.5 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	30	SF	\$40	\$1,180
54427	415.5 to 416.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
57007	447.7 to 448.7 feet	Vertical Change	.6	5 ft	5	REF		
17152	448.4 to 452.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220
17153	458.4 to 462.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340
58956	463.3 to 489.8 feet	Driveway				REF		
57303	463.6 to 464.6 feet	Vertical Change	.9	5 ft	5	REF		
40458	465.3 to 466.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
17154	469.1 to 471.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	12	SF	\$40	\$480
17156	471.5 to 482.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	56	SF	\$40	\$2,240
17159	483.0 to 485.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	13	SF	\$40	\$520
54428	488.7 to 489.7 feet	Vertical Change	.3	5 ft	5	REF		
58957	498.1 to 524.3 feet	Driveway				REF		
17160	506.1 to 508.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	12	SF	\$40	\$480
17162	508.8 to 520.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	57	SF	\$40	\$2,280
54429	523.0 to 524.0 feet	Vertical Change	.3	5 ft	5	REF		
17165	555.5 to 562.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,900
17167	563.6 to 569.1 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	28	SF	\$120	\$3,300
17169	569.4 to 572.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	14	SF	\$120	\$1,680
54430	570.6 to 571.6 feet	Vertical Change	.3	5 ft	5	REF		
17171	572.2 to 582.9 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	53	SF	\$120	\$6,420
17174	586.3 to 596.1 feet	Cross Slope (PAR)	7.0-8.0%	5 ft	49	SF	\$120	\$5,880
54431	589.7 to 590.7 feet	Vertical Change	.3	5 ft	5	REF		
17177	596.1 to 614.0 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	90	SF	\$120	\$10,740
54432	602.0 to 603.0 feet	Vertical Change	.3	5 ft	5	REF		
17184	614.0 to 615.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,080
17185	616.7 to 627.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,720
58958	626.1 to 652.3 feet	Driveway				REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909241341	ROOSEVELT DR	ROOSEVELT DR	TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40459	628.3 to 629.6 feet	Running Slope	5.0-6.0%	5 ft	7	REF		
17187	632.8 to 649.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	83	SF	\$40	\$3,300
58959	709.8 to 736.3 feet	Driveway				REF		
17191	715.8 to 732.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	82	SF	\$40	\$3,280
54433	735.0 to 736.0 feet	Vertical Change	.3	5 ft	5	REF		
17195	738.4 to 746.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	39	SF	\$120	\$4,680
17198	746.2 to 761.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	77	SF	\$120	\$9,240
17200	764.3 to 766.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	10	SF	\$120	\$1,200
17201	766.8 to 787.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	103	SF	\$120	\$12,300
58960	788.6 to 814.7 feet	Driveway				REF		
56070	789.4 to 790.4 feet	Vertical Change	.4	5 ft	5	REF		
17207	789.8 to 791.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	7	SF	\$40	\$280
17208	796.1 to 810.6 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	73	SF	\$40	\$2,900
17211	810.6 to 811.7 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	6	SF	\$40	\$220
17212	814.8 to 822.6 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	39	SF	\$40	\$1,560
58961	823.5 to 849.8 feet	Driveway				REF		
17214	828.4 to 836.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	40	SF	\$40	\$1,580
17217	836.3 to 846.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	50	SF	\$40	\$2,000
17221	849.2 to 850.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$200
17222	850.2 to 862.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	63	SF	\$40	\$2,520
17226	868.7 to 876.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,740
54434	883.7 to 884.7 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
57304	887.6 to 888.6 feet	Vertical Change	.9	5 ft	5	SF	\$75	\$375
17228	889.0 to 891.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	14	SF	\$120	\$1,680
17230	891.8 to 893.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	7	SF	\$120	\$840
57251	893.3 to 894.3 feet	Vertical Change	.8	5 ft	5	SF	\$75	\$375
17231	896.5 to 902.6 feet	Cross Slope (PAR)	10.0-11.0%	5 ft	31	SF	\$120	\$3,660
17232	905.8 to 954.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	246	SF	\$120	\$29,460

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909241341	ROOSEVELT DR	ROOSEVELT DR	TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54435	952.8 to 953.8 feet	Vertical Change	.3	5 ft	5	REF		
58962	952.9 to 978.2 feet	Driveway				REF		
40460	954.4 to 956.1 feet	Running Slope	5.0-6.0%	5 ft	9	REF		
17239	958.2 to 969.5 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	57	SF	\$40	\$2,260
17243	971.1 to 974.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	18	SF	\$40	\$700
17244	990.9 to 992.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960
54436	998.4 to 999.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
58963	1036.0 to 1062.4 feet	Driveway				REF		
17245	1041.9 to 1058.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	81	SF	\$40	\$3,240
17248	1063.0 to 1073.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,180
58964	1071.1 to 1097.8 feet	Driveway				REF		
40461	1073.0 to 1075.2 feet	Running Slope	5.0-6.0%	5 ft	11	REF		
17251	1077.0 to 1094.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	87	SF	\$40	\$3,480
17258	1098.3 to 1202.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	522	SF	\$40	\$20,880
56675	1135.7 to 1136.7 feet	Vertical Change	.5	5 ft	5	REF		
54437	1142.0 to 1143.0 feet	Vertical Change	.3	5 ft	5	REF		
54438	1146.6 to 1147.6 feet	Vertical Change	.3	5 ft	5	REF		
58965	1200.8 to 1227.3 feet	Driveway				REF		
56071	1202.1 to 1203.1 feet	Vertical Change	.4	5 ft	5	REF		
17273	1209.0 to 1221.0 feet	Cross Slope (Driveway)	13.014	5 ft	60	SF	\$40	\$2,400
17277	1221.0 to 1225.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	21	SF	\$40	\$840
56072	1226.9 to 1227.9 feet	Vertical Change	.4	5 ft	5	REF		
17279	1228.2 to 1229.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	9	SF	\$120	\$1,020
17280	1232.7 to 1238.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	31	SF	\$120	\$3,720
TOTAL COST FOR: S side of ROOSEVELT DR Starting at: ROOSEVELT DR							\$296,205.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
N	1909241354	ROOSEVELT DR	TRUMAN DR	ROOSEVELT DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
16896	0.0 to 6.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	32	SF	\$120	\$3,780	
58937	4.4 to 30.0 feet	Driveway				REF			
54403	4.8 to 5.8 feet	Vertical Change	.3	5 ft	5	REF			
40450	6.3 to 8.3 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
16898	9.6 to 25.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	81	SF	\$40	\$3,240	
56064	28.3 to 29.3 feet	Vertical Change	.4	5 ft	5	REF			
16903	29.5 to 31.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	8	SF	\$40	\$300	
16904	31.0 to 40.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,520	
16905	45.1 to 48.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,980	
58938	73.1 to 100.0 feet	Driveway				REF			
40451	75.7 to 77.0 feet	Running Slope	6.0-7.0%	5 ft	7	REF			
16906	80.3 to 96.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	82	SF	\$40	\$3,260	
16913	98.7 to 105.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	36	SF	\$40	\$1,420	
16916	105.8 to 112.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,960	
16919	115.3 to 158.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	218	SF	\$120	\$26,100	
16927	158.8 to 204.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	227	SF	\$120	\$27,300	
57302	168.6 to 169.6 feet	Vertical Change	.9	5 ft	5	REF			
58939	202.1 to 228.6 feet	Driveway				REF			
40452	204.0 to 205.1 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
16934	207.9 to 215.7 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	39	SF	\$40	\$1,560	
16937	218.1 to 223.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	26	SF	\$40	\$1,020	
54404	227.2 to 228.2 feet	Vertical Change	.3	5 ft	5	REF			
16939	228.3 to 239.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	55	SF	\$40	\$2,200	
16942	239.3 to 245.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	29	SF	\$120	\$3,480	
58940	242.5 to 268.7 feet	Driveway				REF			
16944	250.8 to 263.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	65	SF	\$40	\$2,580	
16948	269.0 to 291.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	112	SF	\$40	\$4,460	
16951	324.6 to 328.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520	
54405	326.8 to 327.8 feet	Vertical Change	.3	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909241354	ROOSEVELT DR	TRUMAN DR	ROOSEVELT DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
58941	327.0 to 353.3 feet	Driveway				REF		
16954	332.1 to 349.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	88	SF	\$40	\$3,520
16960	353.5 to 376.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	117	SF	\$120	\$14,040
16965	378.3 to 412.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	170	SF	\$120	\$20,400
62	408.0 to 409.0 feet	Continuous Width		5 ft	5	SF	\$120	\$600
58942	410.8 to 436.8 feet	Driveway				REF		
16969	415.5 to 433.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	89	SF	\$40	\$3,540
16976	437.2 to 473.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	181	SF	\$40	\$7,220
54406	472.2 to 473.2 feet	Vertical Change	.3	5 ft	5	REF		
16980	473.3 to 504.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	156	SF	\$120	\$18,660
54407	489.2 to 490.2 feet	Vertical Change	.3	5 ft	5	REF		
56065	505.6 to 506.6 feet	Vertical Change	.4	5 ft	5	REF		
16987	506.1 to 508.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440
16988	516.9 to 521.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,460
63	531.6 to 532.6 feet	Continuous Width		5 ft	5	SF	\$120	\$600
56066	539.1 to 540.1 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
58943	539.3 to 565.7 feet	Driveway				REF		
16989	544.0 to 561.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	90	SF	\$40	\$3,580
40453	563.8 to 564.9 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
56067	564.4 to 565.4 feet	Vertical Change	.4	5 ft	5	REF		
16994	565.8 to 581.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	78	SF	\$40	\$3,100
54408	579.3 to 580.3 feet	Vertical Change	.3	5 ft	5	REF		
58944	579.6 to 605.3 feet	Driveway				REF		
40454	581.3 to 582.3 feet	Running Slope	6.0-7.0%	5 ft	5	REF		
16997	584.6 to 601.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	83	SF	\$40	\$3,320
17001	601.2 to 602.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$220
56068	604.1 to 605.1 feet	Vertical Change	.4	5 ft	5	REF		
17002	605.3 to 606.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$260
17003	608.7 to 614.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,420

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909241354	ROOSEVELT DR	TRUMAN DR	ROOSEVELT DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
17004	621.8 to 629.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320
54409	630.5 to 631.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
17005	632.9 to 644.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,960
54410	641.7 to 642.7 feet	Vertical Change	.3	5 ft	5	REF		
17007	659.8 to 666.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020
58945	663.3 to 689.9 feet	Driveway				REF		
17009	669.7 to 673.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	21	SF	\$40	\$840
17011	673.9 to 683.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	49	SF	\$40	\$1,940
17014	683.9 to 685.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	8	SF	\$40	\$320
40455	686.2 to 687.6 feet	Running Slope	5.0-6.0%	5 ft	7	REF		
17015	689.5 to 691.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	9	SF	\$40	\$360
17016	698.3 to 724.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	133	SF	\$120	\$15,900
54411	709.4 to 710.4 feet	Vertical Change	.3	5 ft	5	REF		
17019	727.1 to 749.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	110	SF	\$120	\$13,200
54412	729.6 to 730.6 feet	Vertical Change	.3	5 ft	5	REF		
58946	748.0 to 774.1 feet	Driveway				REF		
17022	752.3 to 757.9 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	28	SF	\$40	\$1,120
17024	757.9 to 766.6 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	44	SF	\$40	\$1,740
17027	766.6 to 769.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	13	SF	\$40	\$520
54413	772.5 to 773.5 feet	Vertical Change	.3	5 ft	5	REF		
17028	773.6 to 774.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200
17029	781.5 to 796.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	76	SF	\$120	\$9,060
17030	799.4 to 809.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,880
17032	828.3 to 844.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	81	SF	\$120	\$9,720
17033	864.7 to 877.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,560
58947	875.3 to 901.5 feet	Driveway				REF		
56672	875.5 to 876.5 feet	Vertical Change	.5	5 ft	5	REF		
17035	881.1 to 898.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	89	SF	\$40	\$3,540

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	1909241354	ROOSEVELT DR	TRUMAN DR	ROOSEVELT DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
17043	901.9 to 917.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	76	SF	\$40	\$3,040
56673	915.8 to 916.8 feet	Vertical Change	.5	5 ft	5	REF		
58948	916.3 to 941.8 feet	Driveway				REF		
17045	917.1 to 918.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$200
17046	922.4 to 932.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	49	SF	\$40	\$1,940
17050	934.3 to 938.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	19	SF	\$40	\$760
17052	942.2 to 943.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	8	SF	\$40	\$320
17053	943.8 to 1000.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	285	SF	\$120	\$34,200
54414	953.6 to 954.6 feet	Vertical Change	.3	5 ft	5	REF		
56069	967.9 to 968.9 feet	Vertical Change	.4	5 ft	5	REF		
58949	999.6 to 1025.3 feet	Driveway				REF		
54415	1000.1 to 1001.1 feet	Vertical Change	.3	5 ft	5	REF		
17062	1005.3 to 1019.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	73	SF	\$40	\$2,900
17066	1020.6 to 1021.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	6	SF	\$40	\$240
54416	1024.7 to 1025.7 feet	Vertical Change	.3	5 ft	5	REF		
54417	1055.2 to 1056.2 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
17067	1068.9 to 1075.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,780
54418	1071.9 to 1072.9 feet	Vertical Change	.3	5 ft	5	REF		
17068	1085.6 to 1101.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	80	SF	\$120	\$9,600
58950	1121.6 to 1146.4 feet	Driveway				REF		
54419	1122.3 to 1123.3 feet	Vertical Change	.3	5 ft	5	REF		
40456	1124.5 to 1125.7 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
17069	1127.4 to 1142.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	76	SF	\$40	\$3,060
TOTAL COST FOR: N side of ROOSEVELT DR Starting at: TRUMAN DR							\$329,425.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	1909241357	ROOSEVELT DR	ADAMS DR	WASHINGTON DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54400	40.8 to 41.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
54401	57.8 to 58.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
56671	74.6 to 75.6 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375
54402	91.7 to 92.7 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
16887	95.2 to 96.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720
16888	104.5 to 108.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220
16889	115.8 to 151.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	180	SF	\$120	\$21,600
TOTAL COST FOR: E							side of ROOSEVELT DR Starting at: ADAMS DR	\$26,040.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	1909241411	WASHINGTON DR	ROOSEVELT DR	TRUMAN DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
58923	4.6 to 29.8 feet	Driveway				REF			
16711	8.9 to 24.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	77	SF	\$40	\$3,080	
16715	24.3 to 27.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	14	SF	\$40	\$540	
16716	29.9 to 36.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	34	SF	\$40	\$1,360	
16718	42.6 to 65.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	116	SF	\$120	\$13,920	
16720	66.1 to 67.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	9	SF	\$120	\$1,020	
16721	70.4 to 71.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$780	
16722	71.7 to 76.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700	
54388	79.8 to 80.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
16723	83.3 to 96.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,740	
16726	98.3 to 120.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	113	SF	\$120	\$13,560	
58924	125.7 to 152.3 feet	Driveway				REF			
56668	126.2 to 127.2 feet	Vertical Change	.5	5 ft	5	REF			
16730	127.1 to 128.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$220	
40448	128.2 to 129.5 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
16731	132.0 to 145.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	68	SF	\$40	\$2,740	
16736	146.8 to 148.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	8	SF	\$40	\$300	
54389	150.7 to 151.7 feet	Vertical Change	.3	5 ft	5	REF			
16737	153.4 to 164.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,840	
58925	164.7 to 191.8 feet	Driveway				REF			
16739	164.8 to 167.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	13	SF	\$40	\$520	
54390	165.5 to 166.5 feet	Vertical Change	.3	5 ft	5	REF			
16740	172.6 to 179.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	36	SF	\$40	\$1,440	
16743	179.8 to 183.3 feet	Cross Slope (Driveway)	13.014	5 ft	18	SF	\$40	\$700	
16745	183.3 to 186.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	18	SF	\$40	\$700	
54391	190.0 to 191.0 feet	Vertical Change	.3	5 ft	5	REF			
16746	191.8 to 231.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	199	SF	\$40	\$7,940	
16750	233.8 to 252.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	92	SF	\$120	\$11,040	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909241411	WASHINGTON DR	ROOSEVELT DR	TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60	242.9 to 243.9 feet	Continuous Width		5 ft	5	SF	\$120	\$600
56059	246.3 to 249.5 feet	Vertical Change	.4	5 ft	16	REF		
16756	252.2 to 258.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	31	SF	\$120	\$3,720
16757	262.3 to 272.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	49	SF	\$120	\$5,820
54393	264.5 to 265.5 feet	Vertical Change	.3	5 ft	5	REF		
16762	275.3 to 295.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	100	SF	\$120	\$12,060
56060	276.2 to 277.2 feet	Vertical Change	.4	5 ft	5	REF		
57250	293.0 to 294.0 feet	Vertical Change	.8	5 ft	5	REF		
58926	293.3 to 319.2 feet	Driveway				REF		
16767	298.2 to 304.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	33	SF	\$40	\$1,320
16768	307.1 to 315.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	41	SF	\$40	\$1,640
16771	315.3 to 316.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200
56669	377.8 to 378.8 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375
58927	378.6 to 403.7 feet	Driveway				REF		
16772	383.3 to 400.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	86	SF	\$40	\$3,440
56061	402.4 to 403.4 feet	Vertical Change	.4	5 ft	5	REF		
16777	403.5 to 408.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	24	SF	\$40	\$960
54394	409.6 to 410.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
16779	426.8 to 429.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
16780	440.0 to 463.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	119	SF	\$120	\$14,280
56062	445.2 to 446.2 feet	Vertical Change	.4	5 ft	5	REF		
58928	462.7 to 488.2 feet	Driveway				REF		
16782	467.5 to 484.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	87	SF	\$40	\$3,460
58929	546.3 to 571.8 feet	Driveway				REF		
16787	550.9 to 567.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	83	SF	\$40	\$3,320
16791	571.0 to 572.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$220
16792	572.1 to 573.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240
16793	583.8 to 585.4 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	8	SF	\$120	\$960
58930	587.0 to 611.9 feet	Driveway				REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909241411	WASHINGTON DR	ROOSEVELT DR	TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
16794	593.5 to 601.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	38	SF	\$40	\$1,500
16798	601.0 to 608.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	36	SF	\$40	\$1,460
16800	612.2 to 613.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$220
16801	653.3 to 668.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	78	SF	\$120	\$9,360
16803	672.7 to 682.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,820
16805	688.9 to 708.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	100	SF	\$120	\$12,000
16806	713.5 to 715.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200
58931	715.3 to 740.7 feet	Driveway				REF		
16807	719.8 to 737.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	87	SF	\$40	\$3,460
16814	739.7 to 745.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	28	SF	\$40	\$1,120
56670	741.7 to 742.7 feet	Vertical Change	.5	5 ft	5	REF		
61	745.0 to 746.0 feet	Continuous Width		5 ft	5	SF	\$120	\$600
16816	745.3 to 754.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,400
16818	757.2 to 783.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	131	SF	\$120	\$15,720
56063	764.8 to 765.8 feet	Vertical Change	.4	5 ft	5	REF		
57005	781.8 to 782.8 feet	Vertical Change	.6	5 ft	5	REF		
16823	783.4 to 790.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	37	SF	\$120	\$4,380
54395	786.2 to 787.2 feet	Vertical Change	.3	5 ft	5	REF		
16826	793.1 to 798.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	25	SF	\$120	\$3,000
16828	798.1 to 800.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260
58932	799.0 to 824.8 feet	Driveway				REF		
16829	803.3 to 821.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	91	SF	\$40	\$3,620
54396	810.9 to 811.9 feet	Vertical Change	.3	5 ft	5	REF		
54397	823.5 to 824.5 feet	Vertical Change	.3	5 ft	5	REF		
16835	824.3 to 825.5 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$240
16836	826.7 to 831.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760
16837	868.3 to 883.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	76	SF	\$120	\$9,060
58933	881.8 to 908.3 feet	Driveway				REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	1909241411	WASHINGTON DR	ROOSEVELT DR	TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
16841	887.8 to 904.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	85	SF	\$40	\$3,400
54398	907.4 to 908.4 feet	Vertical Change	.3	5 ft	5	REF		
16846	908.3 to 909.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$260
58934	921.8 to 948.8 feet	Driveway				REF		
16847	928.0 to 944.1 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	81	SF	\$40	\$3,220
16852	948.8 to 950.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$240
16853	950.7 to 954.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520
16854	985.8 to 994.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,160
16855	1002.0 to 1025.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	115	SF	\$120	\$13,860
16859	1029.7 to 1053.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	118	SF	\$120	\$14,160
58935	1050.8 to 1077.1 feet	Driveway				REF		
16862	1056.0 to 1074.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	94	SF	\$40	\$3,740
16869	1077.2 to 1082.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	28	SF	\$40	\$1,100
16872	1088.7 to 1117.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	143	SF	\$120	\$17,100
54399	1118.1 to 1119.1 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
16876	1127.9 to 1129.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$660
58936	1134.1 to 1161.5 feet	Driveway				REF		
16877	1134.3 to 1135.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240
40449	1136.4 to 1137.6 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
16878	1140.3 to 1152.5 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	61	SF	\$40	\$2,440
16880	1153.5 to 1156.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	15	SF	\$40	\$620
16881	1160.4 to 1172.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	62	SF	\$40	\$2,480
16886	1172.8 to 1174.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$780
TOTAL COST FOR: S side of WASHINGTON DR Starting at: ROOSEVELT DR							\$286,540.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909241413	TRUMAN DR	WASHINGTON DR	ADAMS DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
16704	17.0 to 21.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,580
16705	89.3 to 90.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900
16706	108.4 to 109.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
16707	113.7 to 150.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	183	SF	\$120	\$21,960
TOTAL COST FOR: W side of TRUMAN DR Starting at: WASHINGTON DR							\$26,040.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	1909241416	TRUMAN DR	ADAMS DR	GRANT DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
16694	0.0 to 25.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	126	SF	\$120	\$15,060
16697	56.5 to 67.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,300
54384	59.6 to 60.6 feet	Vertical Change	.3	5 ft	5	REF		
54385	63.0 to 64.0 feet	Vertical Change	.3	5 ft	5	REF		
54386	66.5 to 67.5 feet	Vertical Change	.3	5 ft	5	REF		
16698	82.3 to 86.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400
54387	83.0 to 84.0 feet	Vertical Change	.3	5 ft	5	REF		
56058	132.7 to 133.7 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
16700	140.8 to 156.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	76	SF	\$120	\$9,120
TOTAL COST FOR: W side of TRUMAN DR Starting at: ADAMS DR							\$33,255.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	1909241445	TRINITY AVE	6TH ST	7TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
16668	0.0 to 23.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	118	SF	\$120	\$14,160	
54375	24.8 to 25.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
54376	37.5 to 38.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
16669	44.7 to 50.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,360	
54377	47.7 to 48.7 feet	Vertical Change	.3	5 ft	5	REF			
16670	57.3 to 82.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	128	SF	\$120	\$15,300	
54378	60.5 to 61.5 feet	Vertical Change	.3	5 ft	5	REF			
58920	71.6 to 88.7 feet	Driveway				REF			
54379	79.5 to 80.5 feet	Vertical Change	.3	5 ft	5	REF			
16673	89.4 to 94.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	25	SF	\$40	\$980	
57003	92.8 to 93.8 feet	Vertical Change	.6	5 ft	5	REF			
16674	101.2 to 139.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	192	SF	\$120	\$22,980	
58921	137.9 to 154.5 feet	Driveway				REF			
54380	148.4 to 149.4 feet	Vertical Change	.3	5 ft	5	REF			
16681	152.5 to 168.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	80	SF	\$40	\$3,200	
56667	156.4 to 157.4 feet	Vertical Change	.5	5 ft	5	REF			
54381	169.0 to 170.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
16685	186.8 to 200.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	71	SF	\$120	\$8,460	
58922	202.2 to 237.1 feet	Driveway				REF			
16689	207.0 to 208.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$300	
16690	212.9 to 214.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240	
16691	222.7 to 227.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	26	SF	\$40	\$1,020	
54382	253.5 to 254.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
54383	284.7 to 285.7 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
56057	298.8 to 299.8 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
57004	307.8 to 308.8 feet	Vertical Change	.6	5 ft	5	REF			
16693	307.8 to 309.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	

TOTAL COST FOR: NW side of TRINITY AVE Starting at: 6TH ST \$73,330.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909241449	TRINITY AVE	7TH ST	8TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
16632	4.8 to 31.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	134	SF	\$120	\$16,020	
54369	6.3 to 7.3 feet	Vertical Change	.3	5 ft	5	REF			
56049	32.0 to 33.0 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
16640	39.1 to 43.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340	
58916	60.2 to 70.1 feet	Driveway				REF			
16642	75.8 to 79.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160	
56050	83.3 to 84.3 feet	Vertical Change	.4	5 ft	5	REF			
16643	83.5 to 90.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,200	
16644	102.6 to 107.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060	
54370	108.9 to 109.9 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
16645	112.3 to 149.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	185	SF	\$120	\$22,200	
56051	147.3 to 148.3 feet	Vertical Change	.4	5 ft	5	REF			
58917	148.0 to 159.3 feet	Driveway				REF			
56052	160.2 to 161.2 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
16652	163.9 to 165.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780	
16653	193.3 to 198.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,300	
16654	202.4 to 204.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380	
16655	210.0 to 211.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
16656	217.4 to 221.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520	
54371	219.4 to 220.4 feet	Vertical Change	.3	5 ft	5	REF			
16658	221.6 to 231.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	51	SF	\$120	\$6,060	
56053	222.6 to 225.9 feet	Vertical Change	.4	5 ft	17	REF			
54372	231.9 to 232.9 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
56054	237.1 to 238.1 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
16662	239.8 to 247.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,620	
58918	249.3 to 261.0 feet	Driveway				REF			
56055	255.2 to 256.2 feet	Vertical Change	.4	5 ft	5	REF			
16663	257.6 to 266.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	45	SF	\$40	\$1,820	
58919	262.8 to 274.7 feet	Driveway				REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909241449	TRINITY AVE	7TH ST	8TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54373	265.4 to 266.4 feet	Vertical Change	.3	5 ft	5	REF		
16665	273.5 to 279.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	29	SF	\$40	\$1,180
16666	285.6 to 293.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,920
54374	293.6 to 294.6 feet	Vertical Change	.3	5 ft	5	REF		
56056	306.5 to 307.5 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: NW side of TRINITY AVE Starting at: 7TH ST							\$79,890.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909241454	TRINITY AVE	804 TRINITY AVE	9TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
16611	0.0 to 1.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
58913	2.6 to 10.8 feet	Driveway				REF		
16612	14.3 to 16.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320
16613	29.6 to 32.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680
58914	51.3 to 61.5 feet	Driveway				REF		
56048	65.6 to 66.6 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
54367	73.5 to 74.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
16614	80.2 to 93.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,160
57348	89.7 to 90.7 feet	Vertical Change	1	5 ft	5	REF		
16618	97.3 to 98.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
16619	126.3 to 129.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040
16621	151.2 to 159.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,160
16624	162.1 to 167.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120
58915	167.8 to 189.0 feet	Driveway				REF		
16625	170.9 to 194.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	117	SF	\$40	\$4,660
16628	211.0 to 251.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	203	SF	\$120	\$24,360
54368	218.8 to 219.8 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: NW side of TRINITY AVE Starting at: 804 TRINITY AVE							\$52,930.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909241459	TRINITY AVE	9TH ST	10TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
16551	0.0 to 23.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	117	SF	\$120	\$13,980
16556	26.2 to 47.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	106	SF	\$120	\$12,720
54363	41.6 to 42.6 feet	Vertical Change	.3	5 ft	5	REF		
16559	47.6 to 59.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	58	SF	\$120	\$6,900
56047	51.7 to 52.7 feet	Vertical Change	.4	5 ft	5	REF		
16562	61.3 to 70.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	45	SF	\$120	\$5,400
16564	70.3 to 72.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020
16565	82.0 to 93.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,080
58910	90.7 to 103.5 feet	Driveway				REF		
16569	102.9 to 114.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	56	SF	\$40	\$2,240
58911	105.9 to 117.6 feet	Driveway				REF		
16572	124.1 to 173.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	246	SF	\$120	\$29,460
54364	144.1 to 145.1 feet	Vertical Change	.3	5 ft	5	REF		
58912	155.0 to 168.4 feet	Driveway				REF		
54365	156.8 to 157.8 feet	Vertical Change	.3	5 ft	5	REF		
16583	175.7 to 191.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	77	SF	\$120	\$9,180
16587	191.3 to 212.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	108	SF	\$120	\$12,900
16593	216.6 to 224.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	39	SF	\$120	\$4,680
16595	225.2 to 246.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	107	SF	\$120	\$12,840
16600	249.9 to 258.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,860
16601	264.2 to 270.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,720
16604	272.6 to 283.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,540
16606	292.8 to 311.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	93	SF	\$120	\$11,160
54366	308.0 to 309.0 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: NW side of TRINITY AVE Starting at: 9TH ST							\$144,680.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909241508	TRINITY AVE	1001 TRINITY AVE	10TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54360	6.9 to 7.9 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
16548	13.3 to 14.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960
56045	16.6 to 17.6 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
57347	26.5 to 27.5 feet	Vertical Change	1	5 ft	5	SF	\$75	\$375
54361	36.8 to 37.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
16549	43.9 to 47.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340
54362	46.9 to 47.9 feet	Vertical Change	.3	5 ft	5	REF		
56046	52.6 to 53.6 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
40447	54.8 to 56.4 feet	Running Slope	5.0-6.0%	5 ft	8	SF	\$120	\$960
TOTAL COST FOR: SE side of TRINITY AVE Starting at: 1001 TRINITY AVE							\$6,135.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909241512	TRINITY AVE	10TH ST	9TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
16529	0.0 to 14.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,880
54354	0.4 to 1.4 feet	Vertical Change	.3	5 ft	5	REF		
54355	37.8 to 38.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
16530	39.2 to 50.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,840
58906	95.9 to 104.9 feet	Driveway				REF		
54356	129.4 to 130.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
16533	134.8 to 142.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,440
54357	143.5 to 144.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
58907	145.5 to 156.0 feet	Driveway				REF		
58908	163.4 to 175.0 feet	Driveway				REF		
16534	223.7 to 226.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680
16535	236.3 to 241.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,880
16537	241.5 to 265.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	121	SF	\$120	\$14,520
16544	266.6 to 267.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$660
58909	267.1 to 304.3 feet	Driveway				REF		
16545	284.7 to 288.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	18	SF	\$40	\$700
54358	288.8 to 289.8 feet	Vertical Change	.3	5 ft	5	REF		
54359	304.0 to 305.0 feet	Vertical Change	.3	5 ft	5	REF		
16546	309.3 to 312.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,100
40446	310.7 to 312.8 feet	Running Slope	5.0-6.0%	5 ft	11	REF		

TOTAL COST FOR: SE side of TRINITY AVE Starting at: 10TH ST \$43,825.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909241515	TRINITY AVE	9TH ST	813 TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57002	0.5 to 1.5 feet	Vertical Change	.6	5 ft	5	SF	\$75	\$375
16521	7.8 to 9.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
16522	36.6 to 47.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,600
16524	51.0 to 68.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	85	SF	\$120	\$10,260
56665	77.7 to 78.7 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375
16526	93.0 to 102.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,580
TOTAL COST FOR: SE side of TRINITY AVE Starting at: 9TH ST							\$24,030.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909241518	TRINITY AVE	809 TRINITY AVE	809 TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57001	0.4 to 1.4 feet	Vertical Change	.6	5 ft	5	SF	\$75	\$375
58905	1.9 to 14.6 feet	Driveway				REF		
57301	2.1 to 3.1 feet	Vertical Change	.9	5 ft	5	REF		
16520	36.1 to 47.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,660
56664	42.7 to 43.7 feet	Vertical Change	.5	5 ft	5	REF		
57524	44.8 to 45.8 feet	Vertical Change	2	5 ft	5	REF		
TOTAL COST FOR: SE							<i>side of TRINITY AVE Starting at: 809 TRINITY AVE</i>	\$7,035.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909241520	TRINITY AVE	805 TRINITY AVE	8TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
16517	0.0 to 13.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	67	SF	\$120	\$7,980
58904	13.1 to 25.2 feet	Driveway				REF		
54353	45.4 to 46.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: SE side of TRINITY AVE Starting at: 805 TRINITY AVE							\$8,355.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
SE	1909241524	TRINITY AVE	8TH ST	7TH ST				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
16491	9.9 to 13.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400
54347	20.5 to 21.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
16492	44.9 to 50.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,600
54348	48.6 to 49.6 feet	Vertical Change	.3	5 ft	5	REF		
58901	48.8 to 59.8 feet	Driveway				REF		
16494	60.9 to 68.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,740
54349	84.6 to 85.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
54350	112.8 to 113.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
16495	116.6 to 122.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,780
56042	123.0 to 124.0 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
16497	126.7 to 132.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,540
58902	134.6 to 148.9 feet	Driveway				REF		
56043	140.9 to 141.9 feet	Vertical Change	.4	5 ft	5	REF		
16499	144.8 to 152.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	39	SF	\$40	\$1,580
54351	149.4 to 150.4 feet	Vertical Change	.3	5 ft	5	REF		
16501	156.7 to 177.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	105	SF	\$120	\$12,600
58903	167.4 to 191.8 feet	Driveway				REF		
16506	180.3 to 198.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	91	SF	\$40	\$3,620
56044	207.8 to 208.8 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
16509	214.8 to 219.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520
54352	234.7 to 235.7 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
16511	252.7 to 266.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	69	SF	\$120	\$8,280
16512	275.0 to 278.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,280
16513	281.5 to 287.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,300
16515	303.9 to 311.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,680
40445	310.4 to 312.1 feet	Running Slope	5.0-6.0%	5 ft	9	REF		

TOTAL COST FOR: SE side of TRINITY AVE Starting at: 8TH ST \$59,170.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1909241533	TRINITY AVE	7TH ST	6TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
54344	4.9 to 5.9 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
16486	44.7 to 47.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620	
58899	135.6 to 152.5 feet	Driveway				REF			
54345	186.2 to 187.2 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
58900	198.8 to 211.1 feet	Driveway				REF			
56039	227.5 to 228.5 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
56040	264.8 to 265.8 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
16487	269.3 to 273.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,460	
56041	273.6 to 274.6 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
16488	290.1 to 306.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	83	SF	\$120	\$10,020	
54346	296.4 to 297.4 feet	Vertical Change	.3	5 ft	5	REF			
TOTAL COST FOR: SE							<i>side of TRINITY AVE Starting at: 7TH ST</i>	\$15,975.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	1909250821	ORANGE AVE	1ST ST	3RD ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
24202	11.2 to 27.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	130	SF	\$120	\$15,552	
56754	27.4 to 28.4 feet	Vertical Change	.5	8 ft	8	REF			
24207	29.0 to 37.7 feet	Cross Slope (PAR)	6.0-7.0%	8 ft	70	SF	\$120	\$8,352	
56755	33.6 to 34.6 feet	Vertical Change	.5	8 ft	8	REF			
55017	41.5 to 42.5 feet	Vertical Change	.3	8 ft	8	REF			
24209	41.6 to 42.7 feet	Cross Slope (PAR)	6.0-7.0%	8 ft	9	SF	\$120	\$1,056	
24210	42.7 to 55.2 feet	Cross Slope (PAR)	5.0-6.0%	8 ft	100	SF	\$120	\$12,000	
57046	55.0 to 56.0 feet	Vertical Change	.6	8 ft	8	REF			
24212	56.7 to 57.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	8	SF	\$120	\$960	
56274	65.0 to 66.0 feet	Vertical Change	.4	8 ft	8	LF	\$75	\$600	
24213	71.8 to 73.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	14	SF	\$120	\$1,728	
56275	75.2 to 76.2 feet	Vertical Change	.4	8 ft	8	LF	\$75	\$600	
57047	95.1 to 96.1 feet	Vertical Change	.6	8 ft	8	SF	\$75	\$600	
24214	104.2 to 111.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	58	SF	\$120	\$7,008	
24215	116.2 to 121.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	41	SF	\$120	\$4,896	
24218	124.4 to 137.8 feet	Cross Slope (PAR)	3.0-4.0%	8 ft	107	SF	\$120	\$12,864	
24222	137.8 to 139.4 feet	Cross Slope (PAR)	5.0-6.0%	8 ft	13	SF	\$120	\$1,536	
55018	140.0 to 141.0 feet	Vertical Change	.3	8 ft	8	REF			
24223	140.3 to 161.9 feet	Cross Slope (PAR)	3.0-4.0%	8 ft	173	SF	\$120	\$20,736	
24227	162.9 to 216.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	428	SF	\$120	\$51,360	
57413	216.0 to 217.0 feet	Vertical Change	1.2	8 ft	8	REF			
24240	217.3 to 218.3 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	8	SF	\$120	\$960	
24241	218.8 to 236.3 feet	Cross Slope (PAR)	6.0-7.0%	8 ft	140	SF	\$120	\$16,800	
40712	235.8 to 237.0 feet	Running Slope	5.0-6.0%	8 ft	10	REF			
57190	236.5 to 237.5 feet	Vertical Change	.7	8 ft	8	SF	\$75	\$600	
24244	238.1 to 239.3 feet	Cross Slope (PAR)	3.0-4.0%	8 ft	10	SF	\$120	\$1,152	
24245	239.3 to 242.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	26	SF	\$120	\$3,072	
24247	246.2 to 255.2 feet	Cross Slope (PAR)	3.0-4.0%	8 ft	72	SF	\$120	\$8,640	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909250821	ORANGE AVE	1ST ST	3RD ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24249	256.3 to 260.3 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	32	SF	\$120	\$3,840
55019	256.6 to 257.6 feet	Vertical Change	.3	8 ft	8	REF		
24251	261.3 to 282.7 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	171	SF	\$120	\$20,544
24258	282.7 to 286.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	31	SF	\$120	\$3,744
56276	289.7 to 290.7 feet	Vertical Change	.4	8 ft	8	LF	\$75	\$600
24259	295.7 to 300.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	41	SF	\$120	\$4,896
24261	302.2 to 311.1 feet	Cross Slope (PAR)	6.0-7.0%	8 ft	71	SF	\$120	\$8,544
24264	311.1 to 314.6 feet	Cross Slope (PAR)	5.0-6.0%	8 ft	28	SF	\$120	\$3,360
24266	315.5 to 316.7 feet	Cross Slope (PAR)	7.0-8.0%	8 ft	10	SF	\$120	\$1,152
24267	317.3 to 325.1 feet	Cross Slope (PAR)	9.0-10.0%	8 ft	62	SF	\$120	\$7,488
40713	326.5 to 328.3 feet	Running Slope	5.0-6.0%	8 ft	14	SF	\$120	\$1,728
57510	326.9 to 327.9 feet	Vertical Change	1.8	8 ft	8	SF	\$75	\$600
24269	328.9 to 340.1 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	90	SF	\$120	\$10,752
24275	340.1 to 350.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	81	SF	\$120	\$9,696
56756	342.8 to 343.8 feet	Vertical Change	.5	8 ft	8	REF		
24278	351.0 to 365.5 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	116	SF	\$120	\$13,920
57609	353.3 to 354.3 feet	Vertical Change	3	8 ft	8	REF		
24282	366.9 to 375.3 feet	Cross Slope (PAR)	7.0-8.0%	8 ft	67	SF	\$120	\$8,064
56757	373.7 to 374.7 feet	Vertical Change	.5	8 ft	8	REF		
24286	378.0 to 387.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	76	SF	\$120	\$9,120
24288	389.7 to 421.7 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	256	SF	\$120	\$30,720
24294	422.1 to 442.1 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	160	SF	\$120	\$19,200
55020	439.7 to 440.7 feet	Vertical Change	.3	8 ft	8	REF		
24301	443.8 to 482.2 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	307	SF	\$120	\$36,864
56277	459.6 to 460.6 feet	Vertical Change	.4	8 ft	8	REF		
24311	482.2 to 501.6 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	155	SF	\$120	\$18,624
55021	499.6 to 500.6 feet	Vertical Change	.3	8 ft	8	REF		
24318	503.7 to 514.8 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	89	SF	\$120	\$10,656

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909250821	ORANGE AVE	1ST ST	3RD ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24321	516.7 to 525.5 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	70	SF	\$120	\$8,448
57526	519.4 to 520.4 feet	Vertical Change	2	8 ft	8	REF		
24325	526.2 to 542.0 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	126	SF	\$120	\$15,168
24329	542.0 to 565.4 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	187	SF	\$120	\$22,464
55022	587.6 to 588.6 feet	Vertical Change	.3	8 ft	8	LF	\$75	\$600
24335	594.1 to 599.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	44	SF	\$120	\$5,280
24338	601.7 to 621.8 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	161	SF	\$120	\$19,296
24343	624.2 to 642.6 feet	Cross Slope (PAR)	2.0-3.0%	8 ft	147	SF	\$120	\$17,664
55023	640.0 to 641.0 feet	Vertical Change	.3	8 ft	8	REF		
24347	644.3 to 671.6 feet	Cross Slope (PAR)	4.0-5.0%	8 ft	218	SF	\$120	\$26,208
24352	676.8 to 678.3 feet	Cross Slope (PAR)	5.0-6.0%	8 ft	12	SF	\$120	\$1,440
24353	681.4 to 685.7 feet	Cross Slope (PAR)	3.0-4.0%	8 ft	34	SF	\$120	\$4,128
TOTAL COST FOR: NW side of ORANGE AVE Starting at: 1ST ST							\$515,880.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909250827	ORANGE AVE	3RD ST	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24136	0.9 to 2.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
57536	2.1 to 3.1 feet	Vertical Change	2.1	5 ft	5	REF		
24137	9.3 to 10.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
24138	20.8 to 36.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	77	SF	\$120	\$9,240
24142	36.4 to 68.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	162	SF	\$120	\$19,440
24152	71.1 to 75.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	20	SF	\$120	\$2,340
59413	75.3 to 101.5 feet	Driveway				REF		
24154	79.3 to 87.0 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	39	SF	\$40	\$1,540
24156	87.0 to 92.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	25	SF	\$40	\$1,000
24158	92.0 to 98.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	35	SF	\$40	\$1,380
57483	101.3 to 102.3 feet	Vertical Change	1.6	5 ft	5	REF		
24161	101.8 to 103.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	8	SF	\$40	\$300
24162	104.1 to 105.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780
59414	106.2 to 145.7 feet	Driveway				REF		
24163	107.8 to 110.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	12	SF	\$40	\$480
24165	110.2 to 114.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	21	SF	\$40	\$840
24167	114.6 to 124.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	49	SF	\$40	\$1,940
24170	131.3 to 142.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	55	SF	\$40	\$2,200
24172	145.7 to 149.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	21	SF	\$40	\$820
59415	158.2 to 194.7 feet	Driveway				REF		
24173	162.6 to 177.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	76	SF	\$40	\$3,020
24175	179.8 to 193.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	70	SF	\$40	\$2,800
24179	193.8 to 196.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	12	SF	\$40	\$460
24180	198.8 to 214.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	81	SF	\$120	\$9,660
56272	207.0 to 208.0 feet	Vertical Change	.4	5 ft	5	REF		
59416	208.7 to 245.7 feet	Driveway				REF		
24185	217.6 to 237.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	98	SF	\$40	\$3,900
24188	237.1 to 239.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	10	SF	\$40	\$380
57314	242.6 to 243.6 feet	Vertical Change	.9	5 ft	5	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909250827	ORANGE AVE	3RD ST	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24189	242.6 to 249.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	36	SF	\$40	\$1,440
24193	250.3 to 252.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	12	SF	\$120	\$1,380
55016	255.5 to 256.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
24194	256.6 to 261.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	26	SF	\$120	\$3,120
59417	260.2 to 299.3 feet	Driveway				REF		
24196	261.8 to 262.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200
24197	267.2 to 303.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	182	SF	\$40	\$7,260
56273	303.2 to 304.2 feet	Vertical Change	.4	5 ft	5	REF		
TOTAL COST FOR: NW side of ORANGE AVE Starting at: 3RD ST							\$78,215.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909250831	ORANGE AVE	4TH ST	5TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
24064	0.0 to 1.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660	
55003	1.4 to 2.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
24065	5.0 to 10.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,240	
55004	16.2 to 17.2 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
59409	18.8 to 49.3 feet	Driveway				REF			
24067	22.3 to 24.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	9	SF	\$40	\$340	
24068	24.4 to 29.8 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	27	SF	\$40	\$1,080	
24070	30.3 to 31.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200	
24071	32.0 to 39.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	39	SF	\$40	\$1,560	
56753	32.4 to 33.4 feet	Vertical Change	.5	5 ft	5	REF			
24074	39.8 to 42.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	15	SF	\$40	\$580	
24076	45.6 to 47.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	10	SF	\$40	\$380	
55005	46.4 to 47.4 feet	Vertical Change	.3	5 ft	5	REF			
56266	50.7 to 51.7 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
24077	53.1 to 54.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660	
24078	57.9 to 63.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,600	
24081	66.3 to 78.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	60	SF	\$120	\$7,200	
55006	67.4 to 68.4 feet	Vertical Change	.3	5 ft	5	REF			
55007	70.8 to 71.8 feet	Vertical Change	.3	5 ft	5	REF			
24083	78.3 to 91.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,740	
24087	91.2 to 95.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	20	SF	\$120	\$2,400	
24089	95.2 to 96.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600	
59410	95.3 to 122.6 feet	Driveway				REF			
56267	96.7 to 97.7 feet	Vertical Change	.4	5 ft	5	REF			
24090	97.9 to 100.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	14	SF	\$40	\$540	
24092	101.9 to 106.0 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	21	SF	\$40	\$820	
55008	103.5 to 104.5 feet	Vertical Change	.3	5 ft	5	REF			
24093	109.7 to 113.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	21	SF	\$40	\$820	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909250831	ORANGE AVE	4TH ST	5TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
55009	114.2 to 115.2 feet	Vertical Change	.3	5 ft	5	REF			
24094	114.2 to 119.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	26	SF	\$40	\$1,020	
24097	119.3 to 120.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	5	SF	\$40	\$200	
24098	120.7 to 121.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$220	
24099	128.8 to 145.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	85	SF	\$120	\$10,200	
55010	140.0 to 141.0 feet	Vertical Change	.3	5 ft	5	REF			
24106	148.8 to 149.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$600	
24107	149.8 to 157.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,680	
59411	153.1 to 177.8 feet	Driveway				REF			
24109	171.4 to 175.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	18	SF	\$40	\$720	
55011	181.4 to 182.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
24110	184.1 to 204.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	100	SF	\$120	\$12,000	
55012	197.8 to 198.8 feet	Vertical Change	.3	5 ft	5	REF			
59412	205.1 to 230.3 feet	Driveway				REF			
24114	207.6 to 210.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	14	SF	\$40	\$540	
55013	210.9 to 211.9 feet	Vertical Change	.3	5 ft	5	REF			
24115	211.1 to 212.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$200	
24116	221.0 to 229.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	42	SF	\$40	\$1,680	
24118	233.2 to 243.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,240	
56268	234.3 to 235.3 feet	Vertical Change	.4	5 ft	5	REF			
57045	243.5 to 244.5 feet	Vertical Change	.6	5 ft	5	REF			
24120	245.3 to 246.5 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	6	SF	\$120	\$720	
24121	246.5 to 247.6 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	6	SF	\$120	\$660	
24122	247.6 to 250.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	15	SF	\$120	\$1,800	
24124	250.6 to 254.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	19	SF	\$120	\$2,280	
56269	253.9 to 254.9 feet	Vertical Change	.4	5 ft	5	REF			
24126	254.4 to 255.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720	
24127	269.8 to 272.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909250831	ORANGE AVE	4TH ST	5TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55014	274.4 to 275.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
24128	275.9 to 278.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260
56270	278.0 to 279.0 feet	Vertical Change	.4	5 ft	5	REF		
24129	281.7 to 294.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,800
55015	288.3 to 289.3 feet	Vertical Change	.3	5 ft	5	REF		
24132	296.9 to 297.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$600
24133	297.9 to 308.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,360
56271	298.4 to 299.4 feet	Vertical Change	.4	5 ft	5	REF		
TOTAL COST FOR: NW side of ORANGE AVE Starting at: 4TH ST							\$96,475.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	1909250836	ORANGE AVE	5TH ST	6TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
24014	1.3 to 6.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	25	SF	\$120	\$3,000	
57641	3.5 to 4.5 feet	Vertical Change	3.4	5 ft	5	REF			
24017	6.4 to 9.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800	
24019	10.3 to 12.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	10	SF	\$120	\$1,200	
59404	10.8 to 46.6 feet	Driveway				REF			
54994	14.0 to 15.0 feet	Vertical Change	.3	5 ft	5	REF			
24020	15.1 to 28.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	66	SF	\$40	\$2,640	
24024	29.1 to 37.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	43	SF	\$40	\$1,740	
24027	37.8 to 40.1 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	12	SF	\$40	\$460	
24028	45.7 to 47.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	7	SF	\$40	\$260	
24029	47.0 to 54.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	37	SF	\$40	\$1,460	
56261	47.1 to 48.1 feet	Vertical Change	.4	5 ft	5	REF			
24032	59.3 to 62.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860	
59405	63.5 to 82.1 feet	Driveway				REF			
24033	69.1 to 79.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	51	SF	\$40	\$2,020	
40711	80.2 to 81.7 feet	Running Slope	6.0-7.0%	5 ft	8	REF			
56262	81.7 to 82.7 feet	Vertical Change	.4	5 ft	5	REF			
24036	83.3 to 100.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	87	SF	\$120	\$10,380	
24042	100.6 to 104.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520	
59406	103.2 to 119.1 feet	Driveway				REF			
24045	104.9 to 109.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	21	SF	\$40	\$820	
24047	109.8 to 111.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$300	
24048	127.7 to 129.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260	
56263	130.0 to 131.0 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
54995	141.0 to 142.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
24049	143.6 to 151.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,500	
59407	151.2 to 168.7 feet	Driveway				REF			
24052	155.1 to 157.8 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	14	SF	\$40	\$540	
24054	157.8 to 166.4 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	43	SF	\$40	\$1,720	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909250836	ORANGE AVE	5TH ST	6TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24058	166.4 to 167.7 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	7	SF	\$40	\$260
54996	166.7 to 167.7 feet	Vertical Change	.3	5 ft	5	REF		
24059	167.7 to 177.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	48	SF	\$40	\$1,900
54997	187.7 to 188.7 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
54998	200.8 to 201.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
54999	225.8 to 226.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
55000	246.2 to 247.2 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
56264	252.9 to 253.9 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
59408	254.5 to 268.2 feet	Driveway				REF		
56265	266.0 to 267.0 feet	Vertical Change	.4	5 ft	5	REF		
55001	280.5 to 281.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
24063	289.9 to 293.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400
55002	301.9 to 302.9 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: NW side of ORANGE AVE Starting at: 5TH ST							\$46,415.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909250840	ORANGE AVE	6TH ST	7TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
56750	5.0 to 6.0 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375	
54984	25.5 to 26.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
23984	45.8 to 50.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700	
59400	49.4 to 63.5 feet	Driveway				REF			
54985	61.0 to 62.0 feet	Vertical Change	.3	5 ft	5	REF			
54986	82.1 to 83.1 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
23985	83.8 to 88.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060	
59401	89.8 to 105.4 feet	Driveway				REF			
56258	103.6 to 104.6 feet	Vertical Change	.4	5 ft	5	REF			
54987	107.8 to 108.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
23986	111.8 to 119.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,380	
23987	125.3 to 136.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,540	
59402	134.5 to 149.5 feet	Driveway				REF			
23989	160.9 to 193.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	165	SF	\$120	\$19,740	
54988	164.5 to 165.5 feet	Vertical Change	.3	5 ft	5	REF			
54989	174.8 to 178.4 feet	Vertical Change	.3	5 ft	18	REF			
56259	182.6 to 183.6 feet	Vertical Change	.4	5 ft	5	REF			
54990	193.0 to 194.0 feet	Vertical Change	.3	5 ft	5	REF			
59403	193.3 to 217.4 feet	Driveway				REF			
24000	195.4 to 196.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$220	
24001	196.9 to 209.2 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	62	SF	\$40	\$2,460	
24006	211.8 to 215.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	20	SF	\$40	\$800	
54991	214.1 to 215.1 feet	Vertical Change	.3	5 ft	5	REF			
24008	215.8 to 217.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	8	SF	\$40	\$300	
24009	217.6 to 220.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800	
54992	225.1 to 226.1 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
56752	257.4 to 258.4 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375	
24010	267.4 to 275.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,100	
56260	272.8 to 273.8 feet	Vertical Change	.4	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909250840	ORANGE AVE	6TH ST	7TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24012	278.5 to 296.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	88	SF	\$120	\$10,560
24013	300.0 to 302.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620
54993	302.2 to 303.2 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: NW side of ORANGE AVE Starting at: 6TH ST							\$61,530.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909250844	ORANGE AVE	7TH ST	8TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
23972	23.7 to 35.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,780
54977	32.9 to 33.9 feet	Vertical Change	.3	5 ft	5	REF		
23974	41.9 to 47.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,540
23975	50.7 to 54.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340
23977	58.3 to 59.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780
59397	73.3 to 87.5 feet	Driveway				REF		
23978	73.5 to 88.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	75	SF	\$40	\$2,980
54978	85.8 to 86.8 feet	Vertical Change	.3	5 ft	5	REF		
54979	91.0 to 92.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
59398	120.4 to 136.1 feet	Driveway				REF		
54980	121.0 to 122.0 feet	Vertical Change	.3	5 ft	5	REF		
54981	128.2 to 129.2 feet	Vertical Change	.3	5 ft	5	REF		
23982	133.5 to 135.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$300
56257	135.4 to 136.4 feet	Vertical Change	.4	5 ft	5	REF		
59399	200.3 to 210.1 feet	Driveway				REF		
23983	203.3 to 206.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	14	SF	\$40	\$540
54982	208.3 to 209.3 feet	Vertical Change	.3	5 ft	5	REF		
54983	220.4 to 221.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: NW side of ORANGE AVE Starting at: 7TH ST								\$18,010.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909250847	ORANGE AVE	8TH ST	9TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
23914	0.0 to 1.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	10	SF	\$120	\$1,140	
23915	1.9 to 4.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320	
23916	10.8 to 25.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,760	
23917	27.8 to 37.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	50	SF	\$120	\$6,000	
57043	34.8 to 35.8 feet	Vertical Change	.6	5 ft	5	REF			
59394	36.9 to 49.1 feet	Driveway				REF			
57386	37.5 to 38.5 feet	Vertical Change	1.1	5 ft	5	REF			
23920	38.7 to 66.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	136	SF	\$40	\$5,460	
23925	70.9 to 91.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	102	SF	\$120	\$12,300	
59395	89.9 to 100.3 feet	Driveway				REF			
23930	94.3 to 96.5 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	11	SF	\$40	\$440	
23931	96.5 to 116.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	98	SF	\$40	\$3,900	
23934	120.8 to 128.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	39	SF	\$120	\$4,620	
23935	128.7 to 132.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220	
23937	133.2 to 161.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	141	SF	\$120	\$16,920	
23944	165.1 to 181.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	84	SF	\$120	\$10,020	
23948	182.6 to 184.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140	
23949	187.9 to 188.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600	
23950	206.0 to 216.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$6,000	
23952	216.8 to 219.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	15	SF	\$120	\$1,740	
54976	217.4 to 218.4 feet	Vertical Change	.3	5 ft	5	REF			
23954	219.8 to 233.1 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	67	SF	\$120	\$7,980	
23957	233.3 to 236.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	18	SF	\$120	\$2,100	
56256	234.1 to 235.1 feet	Vertical Change	.4	5 ft	5	REF			
59396	238.3 to 267.0 feet	Driveway				REF			
23959	240.2 to 249.1 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	45	SF	\$40	\$1,780	
23963	249.1 to 264.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	78	SF	\$40	\$3,120	
57044	251.7 to 252.7 feet	Vertical Change	.6	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909250847	ORANGE AVE	8TH ST	9TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
23967	269.5 to 277.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	38	SF	\$120	\$4,500
23970	277.0 to 283.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,900
TOTAL COST FOR: NW side of ORANGE AVE Starting at: 8TH ST							\$105,960.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909250853	ORANGE AVE	908 ORANGE AVE	912 ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40708	0.3 to 3.7 feet	Running Slope	5.0-6.0%	5 ft	17	SF	\$120	\$2,040
59392	0.5 to 25.4 feet	Driveway				REF		
54971	0.6 to 1.6 feet	Vertical Change	.3	5 ft	5	REF		
23901	4.0 to 8.1 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	21	SF	\$40	\$820
23903	8.1 to 22.0 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	70	SF	\$40	\$2,780
54972	12.2 to 13.2 feet	Vertical Change	.3	5 ft	5	REF		
40709	22.8 to 25.1 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
54973	23.9 to 24.9 feet	Vertical Change	.3	5 ft	5	REF		
23908	29.6 to 33.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,220
56255	30.2 to 31.2 feet	Vertical Change	.4	5 ft	5	REF		
54974	35.4 to 36.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
54975	40.6 to 41.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
59393	48.0 to 61.6 feet	Driveway				REF		
23909	48.1 to 49.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240
40710	50.7 to 52.6 feet	Running Slope	7.0-8.0%	5 ft	10	REF		
23910	54.3 to 59.8 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	28	SF	\$40	\$1,100
23913	59.8 to 61.3 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	8	SF	\$40	\$300
TOTAL COST FOR: NW side of ORANGE AVE Starting at: 908 ORANGE AVE							\$10,250.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909250859	ORANGE AVE	1004 ORANGE AVE	11TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
23864	0.0 to 3.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,938	
23866	6.5 to 12.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	27	SF	\$120	\$3,213	
23869	16.0 to 21.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	21	SF	\$120	\$2,550	
59389	20.8 to 36.3 feet	Driveway				REF			
40704	21.0 to 22.0 feet	Running Slope	5.0-6.0%	4 ft	4	REF			
23871	25.6 to 33.8 feet	Cross Slope (Driveway)	14.0-15.0%	4 ft	35	SF	\$40	\$1,394	
56749	34.5 to 35.5 feet	Vertical Change	.5	4 ft	4	REF			
23875	37.6 to 41.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	18	SF	\$120	\$2,142	
23876	51.9 to 63.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	48	SF	\$120	\$5,712	
23877	66.3 to 73.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	29	SF	\$120	\$3,519	
23878	76.0 to 79.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	13	SF	\$120	\$1,581	
23880	95.8 to 100.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	20	SF	\$120	\$2,397	
59390	99.5 to 121.1 feet	Driveway				REF			
40705	101.3 to 102.8 feet	Running Slope	5.0-6.0%	4 ft	6	REF			
23882	104.6 to 109.3 feet	Cross Slope (Driveway)	14.0-15.0%	4 ft	20	SF	\$40	\$799	
23884	111.7 to 118.0 feet	Cross Slope (Driveway)	14.0-15.0%	4 ft	27	SF	\$40	\$1,071	
56254	119.5 to 120.5 feet	Vertical Change	.4	4 ft	4	REF			
59391	122.0 to 135.8 feet	Driveway				REF			
40706	124.9 to 125.9 feet	Running Slope	6.0-7.0%	4 ft	4	REF			
23886	129.3 to 132.3 feet	Cross Slope (Driveway)	13.014	4 ft	13	SF	\$40	\$510	
40707	134.3 to 136.0 feet	Running Slope	6.0-7.0%	4 ft	7	REF			
23887	137.0 to 146.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	40	SF	\$120	\$4,743	
23889	158.8 to 190.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	133	SF	\$120	\$16,014	
54968	173.8 to 174.8 feet	Vertical Change	.3	4 ft	4	REF			
54969	183.1 to 184.1 feet	Vertical Change	.3	4 ft	4	REF			
23897	192.3 to 209.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	75	SF	\$120	\$8,976	
54970	207.8 to 208.8 feet	Vertical Change	.3	4 ft	4	REF			
TOTAL COST FOR: NW side of ORANGE AVE Starting at: 1004 ORANGE AVE								\$56,559.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909250905	ORANGE AVE	11TH ST	13TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
23744	6.8 to 9.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500	
23745	11.9 to 19.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	37	SF	\$120	\$4,500	
23746	19.4 to 67.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	240	SF	\$120	\$28,800	
56746	59.4 to 60.4 feet	Vertical Change	.5	5 ft	5	REF			
23755	74.3 to 78.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400	
23756	83.6 to 98.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	76	SF	\$120	\$9,120	
54955	90.1 to 91.1 feet	Vertical Change	.3	5 ft	5	REF			
23757	110.3 to 116.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,420	
23759	124.0 to 131.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	37	SF	\$120	\$4,440	
54956	129.5 to 130.5 feet	Vertical Change	.3	5 ft	5	REF			
23760	132.4 to 168.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	179	SF	\$120	\$21,480	
57640	134.5 to 135.5 feet	Vertical Change	3.4	5 ft	5	REF			
54957	150.0 to 151.0 feet	Vertical Change	.3	5 ft	5	REF			
23769	172.0 to 181.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	46	SF	\$120	\$5,460	
23771	184.8 to 186.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	11	SF	\$120	\$1,260	
23772	189.8 to 199.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	47	SF	\$120	\$5,640	
56747	191.2 to 192.2 feet	Vertical Change	.5	5 ft	5	REF			
23774	202.7 to 211.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	42	SF	\$120	\$4,980	
23776	215.4 to 228.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	68	SF	\$120	\$8,100	
54958	222.0 to 223.0 feet	Vertical Change	.3	5 ft	5	REF			
23778	229.6 to 240.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,720	
23781	242.4 to 244.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	12	SF	\$120	\$1,380	
57434	242.5 to 243.5 feet	Vertical Change	1.3	5 ft	5	REF			
23783	245.7 to 251.1 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	27	SF	\$120	\$3,240	
23785	251.1 to 254.5 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	17	SF	\$120	\$2,040	
23787	254.8 to 286.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	160	SF	\$120	\$19,200	
54959	263.0 to 264.0 feet	Vertical Change	.3	5 ft	5	REF			
54960	283.1 to 284.1 feet	Vertical Change	.3	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909250905	ORANGE AVE	11TH ST	13TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
23799	309.1 to 310.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$780	
23800	312.5 to 317.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	24	SF	\$120	\$2,940	
23801	317.4 to 324.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,440	
23803	328.0 to 340.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	64	SF	\$120	\$7,680	
56252	338.4 to 339.4 feet	Vertical Change	.4	5 ft	5	REF			
54961	343.4 to 344.4 feet	Vertical Change	.3	5 ft	5	REF			
23808	343.9 to 402.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	295	SF	\$120	\$35,340	
56748	374.2 to 375.2 feet	Vertical Change	.5	5 ft	5	REF			
57657	390.9 to 391.9 feet	Vertical Change	3.5	5 ft	5	REF			
23815	414.8 to 460.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	230	SF	\$120	\$27,600	
54962	419.7 to 420.7 feet	Vertical Change	.3	5 ft	5	REF			
54963	446.0 to 447.0 feet	Vertical Change	.3	5 ft	5	REF			
57435	451.9 to 452.9 feet	Vertical Change	1.3	5 ft	5	REF			
40702	466.4 to 468.1 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
54964	466.5 to 467.5 feet	Vertical Change	.3	5 ft	5	REF			
23826	467.3 to 470.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	14	SF	\$120	\$1,680	
40703	468.1 to 469.1 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
23828	470.6 to 477.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	35	SF	\$120	\$4,200	
23831	477.6 to 479.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,020	
23832	480.4 to 526.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	232	SF	\$120	\$27,840	
56253	497.6 to 498.6 feet	Vertical Change	.4	5 ft	5	REF			
54965	507.8 to 508.8 feet	Vertical Change	.3	5 ft	5	REF			
23840	528.9 to 533.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	22	SF	\$120	\$2,580	
23841	533.6 to 548.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,700	
23844	552.0 to 556.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520	
23845	562.5 to 573.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,780	
54966	569.3 to 570.3 feet	Vertical Change	.3	5 ft	5	REF			
23846	576.1 to 578.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	10	SF	\$120	\$1,140	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909250905	ORANGE AVE	11TH ST	13TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
23847	579.2 to 587.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800
54967	579.6 to 580.6 feet	Vertical Change	.3	5 ft	5	REF		
23849	591.7 to 593.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960
23850	599.6 to 615.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	78	SF	\$120	\$9,420
23854	620.1 to 645.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	126	SF	\$120	\$15,120
57584	621.3 to 622.3 feet	Vertical Change	2.8	5 ft	5	REF		
23861	645.3 to 652.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	38	SF	\$120	\$4,500
TOTAL COST FOR: NW side of ORANGE AVE Starting at: 11TH ST							\$303,720.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909250910	ORANGE AVE	13TH ST	14TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
23716	0.3 to 1.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$594	
23717	17.0 to 18.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$810	
23718	21.4 to 25.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,430	
54952	24.4 to 25.4 feet	Vertical Change	.3	5 ft	5	REF			
23719	30.8 to 32.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$972	
56250	40.2 to 41.2 feet	Vertical Change	.4	5 ft	4	LF	\$75	\$338	
23720	81.6 to 83.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$864	
59385	95.8 to 108.4 feet	Driveway				REF			
23721	101.8 to 105.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	15	SF	\$40	\$594	
23722	121.0 to 128.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,266	
23724	142.8 to 152.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,130	
23726	154.5 to 159.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,862	
23728	164.8 to 173.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,806	
59386	175.6 to 187.9 feet	Driveway				REF			
56251	185.8 to 186.8 feet	Vertical Change	.4	5 ft	5	REF			
23732	189.2 to 196.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	32	SF	\$120	\$3,888	
23733	196.4 to 219.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	103	SF	\$120	\$12,366	
23735	219.6 to 232.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	58	SF	\$120	\$6,912	
59387	231.4 to 242.9 feet	Driveway				REF			
57042	232.4 to 233.4 feet	Vertical Change	.6	5 ft	5	REF			
54953	234.2 to 235.2 feet	Vertical Change	.3	5 ft	5	REF			
57313	235.9 to 236.9 feet	Vertical Change	.9	5 ft	5	REF			
23740	241.8 to 247.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	27	SF	\$40	\$1,080	
54954	245.2 to 246.2 feet	Vertical Change	.3	5 ft	5	REF			
23742	247.8 to 249.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$702	
23743	254.3 to 258.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,430	

TOTAL COST FOR: NW side of ORANGE AVE Starting at: 13TH ST \$51,043.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909250914	ORANGE AVE	14TH ST	15TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
23674	0.0 to 25.8 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	110	SF	\$120	\$13,158	
56246	21.1 to 22.1 feet	Vertical Change	.4	4 ft	4	REF			
23680	25.8 to 42.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	71	SF	\$120	\$8,466	
23684	42.7 to 65.1 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	95	SF	\$120	\$11,424	
23691	65.6 to 80.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	65	SF	\$120	\$7,803	
23692	87.1 to 88.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$612	
59381	95.4 to 111.9 feet	Driveway				REF			
56247	96.3 to 97.3 feet	Vertical Change	.4	4 ft	4	REF			
40697	96.5 to 98.4 feet	Running Slope	7.0-8.0%	4 ft	8	REF			
23693	102.0 to 109.4 feet	Cross Slope (Driveway)	>15%	4 ft	31	SF	\$40	\$1,258	
40698	109.4 to 111.0 feet	Running Slope	5.0-6.0%	4 ft	7	REF			
54951	110.2 to 111.2 feet	Vertical Change	.3	4 ft	4	REF			
40699	111.0 to 112.1 feet	Running Slope	6.0-7.0%	4 ft	5	REF			
23695	113.3 to 120.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	30	SF	\$120	\$3,570	
23698	123.4 to 124.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$561	
59382	124.0 to 140.3 feet	Driveway				REF			
40700	125.8 to 127.5 feet	Running Slope	8.0-9.0%	4 ft	7	REF			
23699	128.3 to 134.2 feet	Cross Slope (Driveway)	13.014	4 ft	25	SF	\$40	\$1,003	
40701	136.9 to 138.5 feet	Running Slope	7.0-8.0%	4 ft	7	REF			
23701	139.4 to 140.4 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	4	SF	\$40	\$170	
23702	150.8 to 160.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	41	SF	\$120	\$4,947	
56248	162.0 to 163.0 feet	Vertical Change	.4	4 ft	4	LF	\$75	\$319	
23705	163.7 to 170.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	29	SF	\$120	\$3,468	
23707	170.5 to 173.0 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	11	SF	\$120	\$1,275	
59383	171.5 to 186.2 feet	Driveway				REF			
56249	172.3 to 173.3 feet	Vertical Change	.4	4 ft	4	REF			
23709	177.2 to 183.9 feet	Cross Slope (Driveway)	>15%	4 ft	28	SF	\$40	\$1,139	
23710	187.4 to 192.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	21	SF	\$120	\$2,499	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909250914	ORANGE AVE	14TH ST	15TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
23712	192.3 to 193.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$612
23713	203.7 to 224.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	89	SF	\$120	\$10,659
59384	229.1 to 252.6 feet	Driveway				REF		
TOTAL COST FOR: NW side of ORANGE AVE Starting at: 14TH ST							\$72,942.75	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909250919	ORANGE AVE	15TH ST	14TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
23630	0.6 to 3.0 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	10	SF	\$120	\$1,224
54944	2.0 to 3.0 feet	Vertical Change	.3	4 ft	4	REF		
23631	3.0 to 4.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	8	SF	\$120	\$918
23632	28.1 to 30.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	9	SF	\$120	\$1,071
23633	33.7 to 40.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	27	SF	\$120	\$3,264
59377	43.9 to 66.2 feet	Driveway				REF		
40689	46.4 to 48.4 feet	Running Slope	5.0-6.0%	4 ft	9	REF		
23635	49.2 to 62.4 feet	Cross Slope (Driveway)	>15%	4 ft	56	SF	\$40	\$2,244
40690	63.5 to 64.7 feet	Running Slope	5.0-6.0%	4 ft	5	REF		
54945	64.3 to 65.3 feet	Vertical Change	.3	4 ft	4	REF		
23636	67.9 to 76.0 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	34	SF	\$120	\$4,131
23638	76.0 to 80.5 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	19	SF	\$120	\$2,295
23639	80.5 to 92.6 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	51	SF	\$120	\$6,171
23644	92.6 to 94.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	7	SF	\$120	\$867
54946	94.0 to 95.0 feet	Vertical Change	.3	4 ft	4	REF		
23645	94.8 to 107.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	55	SF	\$120	\$6,630
23650	110.4 to 125.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	63	SF	\$120	\$7,548
23655	131.7 to 132.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$561
23656	136.9 to 138.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	8	SF	\$120	\$969
23657	156.5 to 164.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	34	SF	\$120	\$4,131
23660	165.6 to 175.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	41	SF	\$120	\$4,947
56745	172.7 to 173.7 feet	Vertical Change	.5	4 ft	4	REF		
23662	175.3 to 180.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	23	SF	\$120	\$2,754
59378	178.5 to 195.1 feet	Driveway				REF		
23664	184.3 to 192.0 feet	Cross Slope (Driveway)	13.014	4 ft	33	SF	\$40	\$1,309
40691	194.6 to 195.8 feet	Running Slope	5.0-6.0%	4 ft	5	REF		
54947	195.7 to 196.7 feet	Vertical Change	.3	4 ft	4	REF		
23665	196.5 to 209.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	55	SF	\$120	\$6,630

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909250919	ORANGE AVE	15TH ST	14TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56245	208.6 to 209.6 feet	Vertical Change	.4	4 ft	4	REF		
59379	222.3 to 238.9 feet	Driveway				REF		
54948	224.3 to 225.3 feet	Vertical Change	.3	4 ft	4	REF		
40692	224.4 to 225.5 feet	Running Slope	6.0-7.0%	4 ft	5	REF		
23667	227.5 to 231.8 feet	Cross Slope (Driveway)	12.0-13.0%	4 ft	18	SF	\$40	\$731
23668	233.9 to 235.8 feet	Cross Slope (Driveway)	11.0-12.0%	4 ft	8	SF	\$40	\$323
54949	237.4 to 238.4 feet	Vertical Change	.3	4 ft	4	REF		
40693	237.8 to 238.8 feet	Running Slope	5.0-6.0%	4 ft	4	REF		
54950	248.3 to 249.3 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$319
59380	252.0 to 274.3 feet	Driveway				REF		
23669	252.3 to 253.6 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	6	SF	\$40	\$221
40694	254.7 to 256.3 feet	Running Slope	7.0-8.0%	4 ft	7	REF		
23670	257.1 to 271.6 feet	Cross Slope (Driveway)	>15%	4 ft	62	SF	\$40	\$2,465
40695	271.8 to 274.1 feet	Running Slope	6.0-7.0%	4 ft	10	REF		
23671	275.5 to 282.1 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	28	SF	\$120	\$3,366
23673	285.2 to 286.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	5	SF	\$120	\$561
TOTAL COST FOR: SE side of ORANGE AVE Starting at: 15TH ST								\$65,649.75

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
SE	1909250922	ORANGE AVE	1305 ORANGE AVE	13TH ST	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
23624	0.0 to 13.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	56	SF	\$120	\$6,681			
23625	17.9 to 20.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	12	SF	\$120	\$1,428			
23626	24.4 to 33.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	37	SF	\$120	\$4,488			
TOTAL COST FOR: SE							<i>side of</i>	ORANGE AVE	<i>Starting at:</i>	1305 ORANGE AVE	\$12,597.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909250925	ORANGE AVE	1217 ORANGE AVE	1209 ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
23611	0.0 to 2.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680
23612	25.3 to 49.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	120	SF	\$120	\$14,400
23616	49.7 to 60.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	55	SF	\$120	\$6,540
56244	58.6 to 59.6 feet	Vertical Change	.4	5 ft	5	REF		
23620	60.6 to 76.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	78	SF	\$120	\$9,360
54943	76.9 to 77.9 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
23621	79.3 to 103.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	120	SF	\$120	\$14,400
59375	82.4 to 99.1 feet	Driveway				REF		
59376	102.3 to 117.9 feet	Driveway				REF		
23623	108.3 to 119.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	54	SF	\$40	\$2,160
TOTAL COST FOR: SE side of ORANGE AVE Starting at: 1217 ORANGE AVE							\$48,915.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1909250927	ORANGE AVE	1205 ORANGE AVE	1205 ORANGE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
54942	2.8 to 3.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
59374	2.8 to 21.6 feet	Driveway				REF			
23606	11.8 to 13.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240	
23607	14.0 to 21.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	35	SF	\$40	\$1,400	
TOTAL COST FOR: SE side of ORANGE AVE Starting at: 1205 ORANGE AVE								\$2,015.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909250931	ORANGE AVE	12TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
23575	0.8 to 10.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	45	SF	\$120	\$5,454
23579	10.9 to 37.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	118	SF	\$120	\$14,202
23586	41.3 to 80.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	178	SF	\$120	\$21,330
59373	79.3 to 116.9 feet	Driveway				REF		
23596	84.6 to 91.3 feet	Cross Slope (Driveway)	13.014	5 ft	30	SF	\$40	\$1,206
23599	94.0 to 95.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$234
40688	95.5 to 96.5 feet	Running Slope	7.0-8.0%	5 ft	5	REF		
23600	99.2 to 101.7 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	11	SF	\$40	\$450
23602	103.7 to 117.0 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	60	SF	\$40	\$2,394
56243	116.9 to 117.9 feet	Vertical Change	.4	5 ft	5	REF		

TOTAL COST FOR: SE	<i>side of</i>	ORANGE AVE	<i>Starting at:</i>	12TH ST	\$45,270.00
---------------------------	----------------	-------------------	---------------------	----------------	--------------------

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909250934	ORANGE AVE	1105 ORANGE AVE	1105 ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
23566	0.0 to 23.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	104	SF	\$120	\$12,474
54940	12.0 to 13.0 feet	Vertical Change	.3	5 ft	5	REF		
54941	17.2 to 18.2 feet	Vertical Change	.3	5 ft	5	REF		
23570	26.1 to 34.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,590
59372	33.4 to 50.4 feet	Driveway				REF		
40687	35.1 to 36.2 feet	Running Slope	7.0-8.0%	5 ft	5	REF		
23573	38.3 to 48.3 feet	Cross Slope (Driveway)	>15%	5 ft	45	SF	\$40	\$1,800
23574	48.8 to 49.9 feet	Cross Slope (Driveway)	13.014	5 ft	5	SF	\$40	\$198
TOTAL COST FOR: SE side of ORANGE AVE Starting at: 1105 ORANGE AVE							\$19,062.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	1909250938	ORANGE AVE	11TH ST	10TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
23518	2.9 to 29.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	133	SF	\$120	\$15,960	
54934	7.1 to 8.1 feet	Vertical Change	.3	5 ft	5	REF			
23521	31.8 to 33.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020	
23522	38.7 to 52.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	71	SF	\$120	\$8,520	
56744	43.0 to 44.0 feet	Vertical Change	.5	5 ft	5	REF			
54935	52.9 to 53.9 feet	Vertical Change	.3	5 ft	5	REF			
23523	66.8 to 80.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,160	
23526	82.6 to 85.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	17	SF	\$120	\$1,980	
23527	86.5 to 92.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,420	
54936	94.3 to 95.3 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
23528	96.5 to 145.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	247	SF	\$120	\$29,640	
54937	125.2 to 126.2 feet	Vertical Change	.3	5 ft	5	REF			
54938	135.4 to 136.4 feet	Vertical Change	.3	5 ft	5	REF			
59371	145.3 to 183.6 feet	Driveway				REF			
23539	149.0 to 151.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	13	SF	\$40	\$540	
23541	151.7 to 154.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	13	SF	\$40	\$500	
23542	155.3 to 161.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	30	SF	\$40	\$1,200	
23544	162.6 to 175.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	65	SF	\$40	\$2,600	
54939	171.7 to 172.7 feet	Vertical Change	.3	5 ft	5	REF			
23549	176.2 to 178.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	11	SF	\$40	\$420	
23550	180.7 to 181.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	5	SF	\$40	\$200	
23551	184.5 to 186.5 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	10	SF	\$40	\$400	
23552	190.0 to 192.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	10	SF	\$120	\$1,200	
23553	192.0 to 193.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780	
23554	209.3 to 215.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,900	
23557	218.3 to 226.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,920	
23560	237.8 to 244.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,140	
23563	284.3 to 290.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,960	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909250938	ORANGE AVE	11TH ST	10TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40686	288.7 to 290.9 feet	Running Slope	5.0-6.0%	5 ft	11	REF		
TOTAL COST FOR: SE side of ORANGE AVE Starting at: 11TH ST							\$93,835.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909250941	ORANGE AVE	10TH ST	917 ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
23507	0.0 to 2.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	13	SF	\$120	\$1,512
23508	2.9 to 10.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,266
54931	6.1 to 7.1 feet	Vertical Change	.3	5 ft	5	REF		
23511	14.6 to 38.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	109	SF	\$120	\$13,068
54932	26.3 to 27.3 feet	Vertical Change	.3	5 ft	5	REF		
54933	36.1 to 37.1 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: SE side of ORANGE AVE Starting at: 10TH ST							\$18,846.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909250944	ORANGE AVE	917 ORANGE AVE	909 ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59369	0.3 to 9.8 feet	Driveway				REF		
23505	13.6 to 27.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	67	SF	\$120	\$8,040
54930	41.2 to 42.2 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
59370	48.1 to 58.0 feet	Driveway				REF		
TOTAL COST FOR: SE side of ORANGE AVE Starting at: 917 ORANGE AVE							\$8,415.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1909250949	ORANGE AVE	8TH ST	7TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
23476	5.6 to 7.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020	
54926	5.7 to 6.7 feet	Vertical Change	.3	5 ft	5	REF			
23477	49.5 to 51.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
23478	64.5 to 70.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,780	
59366	71.2 to 83.0 feet	Driveway				REF			
56242	71.7 to 72.7 feet	Vertical Change	.4	5 ft	5	REF			
23479	86.4 to 96.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,240	
23484	96.8 to 101.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	25	SF	\$120	\$2,940	
23487	103.8 to 124.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	103	SF	\$120	\$12,300	
59367	121.4 to 136.1 feet	Driveway				REF			
23493	124.3 to 132.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	40	SF	\$40	\$1,600	
23495	132.3 to 136.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	23	SF	\$40	\$920	
56742	134.9 to 135.9 feet	Vertical Change	.5	5 ft	5	REF			
23497	136.9 to 138.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$780	
23498	146.3 to 150.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,220	
57535	147.4 to 148.4 feet	Vertical Change	2.1	5 ft	5	REF			
23499	153.0 to 156.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800	
23500	206.2 to 210.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,460	
23501	225.8 to 230.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,580	
59368	229.3 to 243.3 feet	Driveway				REF			
54927	230.2 to 231.2 feet	Vertical Change	.3	5 ft	5	REF			
23502	233.3 to 236.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	18	SF	\$40	\$700	
54928	242.0 to 243.0 feet	Vertical Change	.3	5 ft	5	REF			
23503	248.1 to 249.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840	
56743	256.8 to 257.8 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375	
54929	280.4 to 281.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
23504	282.8 to 283.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$660	
TOTAL COST FOR: SE							side of ORANGE AVE	Starting at: 8TH ST	\$42,670.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1909250953	ORANGE AVE	7TH ST	6TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
56741	2.4 to 3.4 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375	
23454	37.1 to 38.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900	
54916	40.9 to 41.9 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
59362	40.9 to 63.2 feet	Driveway				REF			
23455	45.3 to 49.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	23	SF	\$40	\$900	
54917	60.5 to 61.5 feet	Vertical Change	.3	5 ft	5	REF			
23456	66.9 to 68.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$1,020	
23457	84.8 to 89.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,580	
59363	90.3 to 105.3 feet	Driveway				REF			
54918	90.9 to 91.9 feet	Vertical Change	.3	5 ft	5	REF			
23458	92.5 to 94.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	11	SF	\$40	\$420	
23459	112.8 to 113.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660	
54919	122.2 to 123.2 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
23460	156.5 to 170.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,160	
54920	170.0 to 171.0 feet	Vertical Change	.3	5 ft	5	REF			
59364	174.7 to 190.8 feet	Driveway				REF			
23465	175.4 to 179.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	20	SF	\$40	\$780	
23468	179.3 to 180.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$300	
23469	194.6 to 195.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720	
54921	215.2 to 216.2 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
23470	221.5 to 224.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,980	
59365	224.8 to 242.7 feet	Driveway				REF			
54922	225.7 to 228.4 feet	Vertical Change	.3	5 ft	14	REF			
54924	239.7 to 240.7 feet	Vertical Change	.3	5 ft	5	REF			
23471	244.3 to 246.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440	
23472	250.6 to 253.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620	
23473	256.4 to 259.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740	
23474	281.8 to 283.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200	
54925	290.9 to 291.9 feet	Vertical Change	.3	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909250953	ORANGE AVE	7TH ST	6TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
23475	291.7 to 293.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$1,020
TOTAL COST FOR: SE side of ORANGE AVE Starting at: 7TH ST							\$26,940.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1909250957	ORANGE AVE	6TH ST	5TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
57188	0.6 to 1.6 feet	Vertical Change	.7	5 ft	5	SF	\$75	\$375	
54910	22.3 to 23.3 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
23420	46.5 to 47.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600	
56240	68.1 to 69.1 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
23421	76.9 to 83.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,960	
57353	81.8 to 82.8 feet	Vertical Change	1	5 ft	5	REF			
57189	87.1 to 88.1 feet	Vertical Change	.7	5 ft	5	SF	\$75	\$375	
59358	87.3 to 98.8 feet	Driveway				REF			
57454	91.0 to 92.0 feet	Vertical Change	1.4	5 ft	5	REF			
23424	93.5 to 96.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	16	SF	\$40	\$640	
23425	99.0 to 100.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$240	
59359	100.6 to 122.0 feet	Driveway				REF			
23426	105.7 to 114.6 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	45	SF	\$40	\$1,780	
23428	114.6 to 116.7 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	11	SF	\$40	\$420	
23430	117.8 to 119.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	8	SF	\$40	\$300	
23431	123.4 to 126.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040	
23433	127.0 to 135.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	41	SF	\$120	\$4,920	
54911	131.9 to 132.9 feet	Vertical Change	.3	5 ft	5	REF			
23435	135.2 to 142.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320	
56241	139.8 to 140.8 feet	Vertical Change	.4	5 ft	5	REF			
23437	143.1 to 153.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	51	SF	\$120	\$6,120	
23441	153.9 to 165.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,840	
23444	167.4 to 174.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	36	SF	\$120	\$4,320	
23445	177.1 to 181.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	23	SF	\$120	\$2,700	
23446	182.1 to 184.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380	
59360	192.9 to 218.3 feet	Driveway				REF			
23447	213.3 to 216.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	15	SF	\$40	\$580	
54912	221.0 to 222.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909250957	ORANGE AVE	6TH ST	5TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56740	254.2 to 255.2 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375
23448	257.7 to 262.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060
54913	259.2 to 260.2 feet	Vertical Change	.3	5 ft	5	REF		
59361	265.2 to 285.5 feet	Driveway				REF		
54914	265.5 to 266.5 feet	Vertical Change	.3	5 ft	5	REF		
23449	266.7 to 267.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$220
23450	290.6 to 300.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,760
54915	295.9 to 296.9 feet	Vertical Change	.3	5 ft	5	REF		
23453	302.8 to 306.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,920
TOTAL COST FOR: SE side of ORANGE AVE Starting at: 6TH ST							\$54,370.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1909251001	ORANGE AVE	5TH ST	4TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
23372	1.0 to 4.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220	
23374	26.9 to 29.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740	
54905	47.1 to 48.1 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
23375	60.5 to 64.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,640	
23378	68.8 to 72.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,280	
59353	72.1 to 93.2 feet	Driveway				REF			
23380	77.9 to 87.9 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	50	SF	\$40	\$2,000	
23384	88.8 to 90.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	10	SF	\$40	\$400	
23385	94.8 to 98.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,920	
54906	98.4 to 99.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
23387	100.8 to 101.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$660	
23388	105.5 to 120.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	77	SF	\$120	\$9,180	
59354	119.8 to 149.5 feet	Driveway				REF			
40681	122.5 to 123.7 feet	Running Slope	6.0-7.0%	5 ft	6	REF			
23391	124.1 to 131.4 feet	Cross Slope (Driveway)	>15%	5 ft	37	SF	\$40	\$1,460	
23393	131.4 to 134.8 feet	Cross Slope (Driveway)	13.014	5 ft	17	SF	\$40	\$680	
23394	136.7 to 146.5 feet	Cross Slope (Driveway)	>15%	5 ft	49	SF	\$40	\$1,960	
40682	147.8 to 149.4 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
23396	150.3 to 151.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	5	SF	\$40	\$200	
59355	150.8 to 165.9 feet	Driveway				REF			
40683	152.0 to 153.6 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
23397	156.5 to 163.8 feet	Cross Slope (Driveway)	13.014	5 ft	37	SF	\$40	\$1,460	
40684	163.5 to 166.3 feet	Running Slope	6.0-7.0%	5 ft	14	REF			
23399	168.2 to 171.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,920	
23401	173.7 to 184.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,240	
54907	183.3 to 184.3 feet	Vertical Change	.3	5 ft	5	REF			
23403	191.0 to 204.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	66	SF	\$120	\$7,920	
59356	204.3 to 225.1 feet	Driveway				REF			
23407	209.2 to 222.0 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	64	SF	\$40	\$2,560	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251001	ORANGE AVE	5TH ST	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40685	222.7 to 225.1 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
23411	227.7 to 244.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	85	SF	\$120	\$10,200
23413	262.2 to 263.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720
23414	265.8 to 276.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	55	SF	\$120	\$6,660
54908	272.8 to 273.8 feet	Vertical Change	.3	5 ft	5	REF		
59357	276.8 to 291.8 feet	Driveway				REF		
23418	276.9 to 278.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$280
56239	277.3 to 278.3 feet	Vertical Change	.4	5 ft	5	REF		
54909	290.4 to 291.4 feet	Vertical Change	.3	5 ft	5	REF		
23419	294.6 to 298.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,280
TOTAL COST FOR: SE side of ORANGE AVE Starting at: 5TH ST								\$68,330.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251006	ORANGE AVE	4TH ST	3RD ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
23316	2.4 to 12.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,120
54897	2.6 to 3.6 feet	Vertical Change	.3	5 ft	5	REF		
54898	8.0 to 9.0 feet	Vertical Change	.3	5 ft	5	REF		
23318	14.9 to 41.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	134	SF	\$120	\$16,020
23320	41.9 to 48.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,200
23323	59.3 to 101.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	213	SF	\$120	\$25,500
57041	90.4 to 91.4 feet	Vertical Change	.6	5 ft	5	SF	\$75	\$375
59350	100.3 to 115.1 feet	Driveway				REF		
40677	102.1 to 104.3 feet	Running Slope	6.0-7.0%	5 ft	11	REF		
23334	105.9 to 111.4 feet	Cross Slope (Driveway)	>15%	5 ft	28	SF	\$40	\$1,100
40678	112.7 to 114.4 feet	Running Slope	5.0-6.0%	5 ft	9	REF		
40679	114.4 to 115.6 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
23336	116.5 to 127.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	56	SF	\$120	\$6,660
23340	127.6 to 147.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	101	SF	\$120	\$12,120
54899	141.6 to 142.6 feet	Vertical Change	.3	5 ft	5	REF		
23346	149.2 to 151.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	11	SF	\$120	\$1,260
59351	150.5 to 175.6 feet	Driveway				REF		
23347	156.3 to 172.0 feet	Cross Slope (Driveway)	>15%	5 ft	78	SF	\$40	\$3,140
56739	177.6 to 178.6 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375
23351	187.4 to 190.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800
56237	187.9 to 188.9 feet	Vertical Change	.4	5 ft	5	REF		
23353	193.3 to 203.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	52	SF	\$120	\$6,180
59352	203.1 to 218.8 feet	Driveway				REF		
56238	203.9 to 204.9 feet	Vertical Change	.4	5 ft	5	REF		
23356	207.3 to 216.5 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	46	SF	\$40	\$1,840
57261	215.9 to 216.9 feet	Vertical Change	.8	5 ft	5	REF		
40680	216.0 to 217.4 feet	Running Slope	6.0-7.0%	5 ft	7	REF		
54900	219.0 to 220.0 feet	Vertical Change	.3	5 ft	5	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251006	ORANGE AVE	4TH ST	3RD ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
23361	222.9 to 226.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160
54901	229.1 to 232.4 feet	Vertical Change	.3	5 ft	17	LF	\$75	\$1,238
23362	230.7 to 258.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	138	SF	\$120	\$16,560
54903	254.9 to 255.9 feet	Vertical Change	.3	5 ft	5	REF		
23366	272.8 to 283.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,600
23370	289.8 to 296.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,960
54904	296.8 to 297.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
23371	298.8 to 300.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960
TOTAL COST FOR: SE side of ORANGE AVE Starting at: 4TH ST								\$118,542.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251012	ORANGE AVE	3RD ST	2ND ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
23292	5.8 to 18.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	74	SF	\$120	\$8,928
56235	29.9 to 32.9 feet	Vertical Change	.4	6 ft	18	LF	\$75	\$1,350
23293	56.1 to 57.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$864
54895	67.6 to 68.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$450
59348	69.1 to 89.3 feet	Driveway				REF		
23294	92.5 to 131.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	235	SF	\$120	\$28,152
23302	144.1 to 155.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	68	SF	\$120	\$8,208
59349	167.0 to 181.4 feet	Driveway				REF		
23304	168.7 to 175.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	38	SF	\$40	\$1,536
54896	172.4 to 173.4 feet	Vertical Change	.3	6 ft	6	REF		
56236	194.0 to 195.0 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$450
57260	197.0 to 198.0 feet	Vertical Change	.8	6 ft	6	SF	\$75	\$450
23307	242.5 to 244.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,224
23308	247.3 to 253.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,248
23309	268.6 to 274.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,464
23310	276.9 to 286.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	58	SF	\$120	\$6,984
23314	289.4 to 306.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	104	SF	\$120	\$12,456
57040	306.1 to 307.1 feet	Vertical Change	.6	6 ft	6	REF		
TOTAL COST FOR: SE side of ORANGE AVE Starting at: 3RD ST							\$79,764.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1909251016	ORANGE AVE	2ND ST	1ST ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
23235	0.6 to 2.9 feet	Cross Slope (PAR)	7.0-8.0%	5 ft	10	SF	\$120	\$1,242	
54885	2.0 to 3.0 feet	Vertical Change	.3	5 ft	5	REF			
23237	2.9 to 4.0 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	5	SF	\$120	\$594	
23238	4.8 to 16.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	52	SF	\$120	\$6,210	
54886	8.4 to 9.4 feet	Vertical Change	.3	5 ft	5	REF			
57312	14.8 to 15.8 feet	Vertical Change	.9	5 ft	5	REF			
54887	17.0 to 18.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338	
23242	18.9 to 40.0 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	95	SF	\$120	\$11,394	
57472	22.3 to 23.3 feet	Vertical Change	1.5	5 ft	5	SF	\$75	\$338	
54888	29.5 to 32.4 feet	Vertical Change	.3	5 ft	13	REF			
54890	39.1 to 40.1 feet	Vertical Change	.3	5 ft	5	REF			
23249	42.6 to 100.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	259	SF	\$120	\$31,050	
56234	44.8 to 45.8 feet	Vertical Change	.4	5 ft	5	REF			
57608	78.6 to 79.6 feet	Vertical Change	3	5 ft	5	REF			
23257	101.0 to 108.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,996	
23259	111.3 to 150.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	178	SF	\$120	\$21,330	
54891	155.9 to 156.9 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338	
23264	163.8 to 187.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	108	SF	\$120	\$12,960	
23270	190.1 to 191.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$972	
59345	191.2 to 208.1 feet	Driveway				REF			
57534	191.8 to 192.8 feet	Vertical Change	2.1	5 ft	5	REF			
23271	195.3 to 196.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	5	SF	\$40	\$180	
23272	196.8 to 205.7 feet	Cross Slope (Driveway)	13.014	5 ft	40	SF	\$40	\$1,602	
23274	209.9 to 240.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	140	SF	\$120	\$16,740	
57551	215.9 to 216.9 feet	Vertical Change	2.3	5 ft	5	REF			
56738	238.3 to 239.3 feet	Vertical Change	.5	5 ft	5	REF			
59346	240.8 to 254.8 feet	Driveway				REF			
23279	246.6 to 251.3 feet	Cross Slope (Driveway)	>15%	5 ft	21	SF	\$40	\$846	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251016	ORANGE AVE	2ND ST	1ST ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
23281	251.3 to 252.5 feet	Cross Slope (Driveway)	13.014	5 ft	5	SF	\$40	\$216
23282	255.6 to 266.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	47	SF	\$120	\$5,616
54892	258.6 to 259.6 feet	Vertical Change	.3	5 ft	5	REF		
59347	263.8 to 282.8 feet	Driveway				REF		
40675	266.3 to 267.4 feet	Running Slope	6.0-7.0%	5 ft	5	REF		
23286	269.7 to 278.5 feet	Cross Slope (Driveway)	>15%	5 ft	40	SF	\$40	\$1,584
40676	279.8 to 281.8 feet	Running Slope	7.0-8.0%	5 ft	9	REF		
54893	281.5 to 282.5 feet	Vertical Change	.3	5 ft	5	REF		
23288	284.4 to 287.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,836
23289	292.4 to 309.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	78	SF	\$120	\$9,342
TOTAL COST FOR: SE side of ORANGE AVE Starting at: 2ND ST								\$128,722.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251022	ORANGE AVE	23 ORANGE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57352	0.6 to 1.6 feet	Vertical Change	1	5 ft	5	SF	\$75	\$338
54883	3.0 to 4.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
56737	7.2 to 8.2 feet	Vertical Change	.5	5 ft	4	SF	\$75	\$338
59344	29.2 to 45.1 feet	Driveway				REF		
23230	35.0 to 39.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	20	SF	\$40	\$792
54884	36.4 to 37.4 feet	Vertical Change	.3	5 ft	5	REF		
23232	39.4 to 40.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	6	SF	\$40	\$252
23233	41.7 to 43.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	9	SF	\$40	\$342
23234	43.8 to 45.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	8	SF	\$40	\$324
56233	45.5 to 46.5 feet	Vertical Change	.4	5 ft	5	REF		
TOTAL COST FOR: SE side of ORANGE AVE Starting at: 23 ORANGE AVE							\$2,722.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251027	ORANGE AVE	11 ORANGE AVE	FRONT ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
23222	3.0 to 12.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,292
23225	22.0 to 33.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,318
54882	22.3 to 23.3 feet	Vertical Change	.3	5 ft	5	REF		
23229	36.0 to 51.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	72	SF	\$120	\$8,586
82	52.2 to 53.2 feet	Continuous Width		5 ft	5	SF	\$120	\$540
56232	52.8 to 53.8 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338
TOTAL COST FOR: SE side of ORANGE AVE Starting at: 11 ORANGE AVE							\$21,073.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
SW	1909251032	FRONT ST	ORANGE AVE	SIDEWALK ENDS				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
80	1.4 to 2.4 feet	Continuous Width		5 ft	5	SF	\$120	\$540
23213	5.8 to 10.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,592
56231	57.1 to 58.1 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338
23214	60.2 to 71.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,156
59343	70.3 to 92.4 feet	Driveway				REF		
40674	72.3 to 73.6 feet	Running Slope	7.0-8.0%	5 ft	6	REF		
23217	75.7 to 78.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	14	SF	\$40	\$558
23219	78.8 to 89.1 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	46	SF	\$40	\$1,854
54881	91.5 to 92.5 feet	Vertical Change	.3	5 ft	5	REF		
23221	126.9 to 132.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,024
81	143.1 to 144.1 feet	Continuous Width		5 ft	5	SF	\$120	\$540
TOTAL COST FOR: SW side of FRONT ST Starting at: ORANGE AVE							\$15,601.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909251037	FRONT ST	SIDEWALK BEGINS	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54880	1.5 to 2.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
23184	3.5 to 19.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	71	SF	\$120	\$8,478
78	19.0 to 20.0 feet	Continuous Width		5 ft	5	SF	\$120	\$540
57259	19.4 to 20.4 feet	Vertical Change	.8	5 ft	5	SF	\$75	\$338
56230	26.2 to 27.2 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338
23186	43.5 to 67.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	109	SF	\$120	\$13,122
23191	70.6 to 93.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	103	SF	\$120	\$12,366
23198	96.0 to 104.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,590
23201	106.8 to 124.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	80	SF	\$120	\$9,558
23206	124.7 to 145.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	94	SF	\$120	\$11,232
79	139.2 to 140.2 feet	Continuous Width		5 ft	5	SF	\$120	\$540
TOTAL COST FOR: SW side of FRONT ST Starting at: SIDEWALK BEGINS							\$61,438.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251040	HUMBOLDT AVE	FRONT ST	10 HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
23172	0.9 to 5.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	18	SF	\$120	\$2,214
23173	5.0 to 8.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,052
23174	9.9 to 37.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	126	SF	\$120	\$15,066
59342	36.2 to 50.9 feet	Driveway				REF		
40673	38.5 to 40.2 feet	Running Slope	5.0-6.0%	5 ft	8	REF		
23181	41.5 to 47.8 feet	Cross Slope (Driveway)	13.014	5 ft	28	SF	\$40	\$1,134
23183	51.8 to 54.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,242
TOTAL COST FOR: NW side of HUMBOLDT AVE Starting at: FRONT ST							\$21,708.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909251045	HUMBOLDT AVE	1ST ST	2ND ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
57311	0.8 to 1.8 feet	Vertical Change	.9	5 ft	5	SF	\$75	\$338	
23118	4.7 to 19.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	67	SF	\$120	\$7,992	
54873	7.5 to 8.5 feet	Vertical Change	.3	5 ft	5	REF			
54874	17.9 to 18.9 feet	Vertical Change	.3	5 ft	5	REF			
23121	23.3 to 44.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	95	SF	\$120	\$11,448	
23126	44.8 to 68.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	108	SF	\$120	\$12,960	
23131	71.5 to 78.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	33	SF	\$120	\$3,942	
59337	77.8 to 99.3 feet	Driveway				REF			
40665	79.3 to 81.1 feet	Running Slope	7.0-8.0%	5 ft	8	REF			
23132	82.3 to 96.3 feet	Cross Slope (Driveway)	>15%	5 ft	63	SF	\$40	\$2,520	
40666	96.7 to 98.4 feet	Running Slope	6.0-7.0%	5 ft	8	REF			
23133	99.3 to 108.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	41	SF	\$40	\$1,656	
56227	108.6 to 109.6 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338	
23135	111.3 to 122.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	50	SF	\$120	\$5,940	
23139	122.3 to 124.2 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	9	SF	\$120	\$1,026	
59338	124.8 to 149.0 feet	Driveway				REF			
23140	125.3 to 127.6 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	10	SF	\$40	\$414	
40667	127.4 to 128.9 feet	Running Slope	7.0-8.0%	5 ft	7	REF			
23142	136.0 to 145.9 feet	Cross Slope (Driveway)	>15%	5 ft	45	SF	\$40	\$1,782	
54875	138.6 to 139.6 feet	Vertical Change	.3	5 ft	5	REF			
23145	150.1 to 152.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
59339	155.2 to 171.9 feet	Driveway				REF			
54876	156.1 to 157.1 feet	Vertical Change	.3	5 ft	5	REF			
40668	156.7 to 158.8 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
23146	160.5 to 168.9 feet	Cross Slope (Driveway)	>15%	5 ft	38	SF	\$40	\$1,512	
54877	170.1 to 171.1 feet	Vertical Change	.3	5 ft	5	REF			
23149	173.2 to 186.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	59	SF	\$120	\$7,074	
23154	186.4 to 190.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,268	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251045	HUMBOLDT AVE	1ST ST	2ND ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57039	195.6 to 196.6 feet	Vertical Change	.6	5 ft	5	SF	\$75	\$338
23155	199.4 to 203.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160
54878	201.1 to 202.1 feet	Vertical Change	.3	5 ft	5	REF		
59340	203.1 to 222.5 feet	Driveway				REF		
40669	205.8 to 207.3 feet	Running Slope	6.0-7.0%	5 ft	7	REF		
23156	209.0 to 219.4 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	47	SF	\$40	\$1,872
40670	219.3 to 220.7 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
23159	223.2 to 251.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	126	SF	\$120	\$15,174
23162	251.7 to 253.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
54879	252.5 to 253.5 feet	Vertical Change	.3	5 ft	5	REF		
59341	254.5 to 269.4 feet	Driveway				REF		
40671	255.3 to 256.7 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
23163	257.7 to 266.8 feet	Cross Slope (Driveway)	>15%	5 ft	41	SF	\$40	\$1,638
40672	266.1 to 269.1 feet	Running Slope	5.0-6.0%	5 ft	14	REF		
23164	270.0 to 286.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	75	SF	\$120	\$9,018
56228	279.2 to 280.2 feet	Vertical Change	.4	5 ft	5	REF		
23167	288.8 to 304.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	72	SF	\$120	\$8,640
56229	299.8 to 300.8 feet	Vertical Change	.4	5 ft	5	REF		
TOTAL COST FOR: NW side of HUMBOLDT AVE Starting at: 1ST ST							\$102,208.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909251049	HUMBOLDT AVE	SIDEWALK BEGINS	3RD ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
59336	0.5 to 26.9 feet	Driveway				REF			
40663	1.5 to 2.8 feet	Running Slope	8.0-9.0%	5 ft	6	REF			
23066	6.1 to 7.4 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	6	SF	\$40	\$234	
23067	10.0 to 15.3 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	24	SF	\$40	\$954	
23069	15.3 to 20.6 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	24	SF	\$40	\$954	
23071	22.8 to 24.2 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	6	SF	\$40	\$252	
40664	23.8 to 26.1 feet	Running Slope	5.0-6.0%	5 ft	10	REF			
56221	29.0 to 30.0 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338	
23072	32.8 to 34.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
56734	33.4 to 34.4 feet	Vertical Change	.5	5 ft	5	REF			
23073	38.8 to 62.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	104	SF	\$120	\$12,528	
57594	39.6 to 40.6 feet	Vertical Change	2.9	5 ft	5	REF			
56222	44.6 to 45.6 feet	Vertical Change	.4	5 ft	5	REF			
56223	52.6 to 53.6 feet	Vertical Change	.4	5 ft	5	REF			
56224	58.0 to 61.5 feet	Vertical Change	.4	5 ft	16	REF			
23078	62.0 to 64.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	12	SF	\$120	\$1,458	
23080	64.7 to 72.0 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	33	SF	\$120	\$3,942	
54872	65.3 to 69.3 feet	Vertical Change	.3	5 ft	18	REF			
23081	72.0 to 74.0 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	9	SF	\$120	\$1,080	
23082	74.0 to 77.2 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	14	SF	\$120	\$1,728	
56735	75.1 to 76.1 feet	Vertical Change	.5	5 ft	5	REF			
23083	77.3 to 82.7 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	24	SF	\$120	\$2,916	
23085	83.1 to 88.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	24	SF	\$120	\$2,916	
57038	85.4 to 86.4 feet	Vertical Change	.6	5 ft	5	REF			
23088	92.9 to 96.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	14	SF	\$120	\$1,728	
23089	99.8 to 104.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	21	SF	\$120	\$2,538	
23090	104.5 to 133.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	128	SF	\$120	\$15,390	
23096	133.0 to 175.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	193	SF	\$120	\$23,112	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251049	HUMBOLDT AVE	SIDEWALK BEGINS	3RD ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56736	164.7 to 165.7 feet	Vertical Change	.5	5 ft	5	REF		
23103	175.8 to 178.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,566
23104	182.8 to 188.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,186
23106	188.7 to 190.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	9	SF	\$120	\$1,134
23107	193.0 to 195.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	10	SF	\$120	\$1,242
56226	195.6 to 196.6 feet	Vertical Change	.4	5 ft	5	REF		
23109	196.4 to 198.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$972
23110	200.3 to 232.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	143	SF	\$120	\$17,172
23117	232.1 to 233.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$540
TOTAL COST FOR: NW side of HUMBOLDT AVE Starting at: SIDEWALK BEGINS							\$98,959.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251051	HUMBOLDT AVE	3RD ST	304 HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
23056	0.6 to 9.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	87	SF	\$120	\$10,488
23058	10.0 to 14.1 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	39	SF	\$120	\$4,674
23060	14.5 to 24.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	96	SF	\$120	\$11,514
56733	18.8 to 19.8 feet	Vertical Change	.5	10 ft	10	REF		
59335	20.5 to 36.6 feet	Driveway				REF		
23062	34.3 to 46.3 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	114	SF	\$40	\$4,560
54870	41.5 to 42.5 feet	Vertical Change	.3	10 ft	10	REF		
TOTAL COST FOR: NW side of HUMBOLDT AVE Starting at: 3RD ST							\$31,236.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251053	HUMBOLDT AVE	308 HUMBOLDT AVE	312 HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59334	28.8 to 43.3 feet	Driveway				REF		
54869	29.9 to 33.4 feet	Vertical Change	.3	10 ft	33	REF		
TOTAL COST FOR: NW side of HUMBOLDT AVE Starting at: 308 HUMBOLDT AVE								\$0.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909251059	HUMBOLDT AVE	5TH ST	6TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
23026	0.0 to 4.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	24	SF	\$120	\$2,880	
23027	5.3 to 19.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	70	SF	\$120	\$8,400	
23031	23.9 to 30.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,960	
23034	35.0 to 47.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	61	SF	\$120	\$7,320	
59330	47.2 to 63.1 feet	Driveway				REF			
40662	49.3 to 50.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
23038	51.9 to 60.8 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	45	SF	\$40	\$1,780	
23040	64.6 to 96.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	161	SF	\$120	\$19,320	
54864	64.9 to 65.9 feet	Vertical Change	.3	5 ft	5	REF			
54865	85.5 to 86.5 feet	Vertical Change	.3	5 ft	5	REF			
59331	98.0 to 112.8 feet	Driveway				REF			
23044	120.6 to 132.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,260	
23048	138.1 to 140.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440	
23049	143.2 to 144.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600	
59332	151.3 to 163.6 feet	Driveway				REF			
23050	153.5 to 159.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	31	SF	\$40	\$1,220	
23051	174.1 to 176.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320	
23052	181.3 to 186.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,820	
56730	201.2 to 202.2 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375	
59333	201.7 to 216.8 feet	Driveway				REF			
54866	216.6 to 217.6 feet	Vertical Change	.3	5 ft	5	REF			
54867	229.4 to 230.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
23053	240.2 to 253.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	68	SF	\$120	\$8,160	
54868	243.8 to 244.8 feet	Vertical Change	.3	5 ft	5	REF			
56731	285.3 to 286.3 feet	Vertical Change	.5	5 ft	5	REF			
23055	286.1 to 288.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,620	
57412	297.0 to 298.0 feet	Vertical Change	1.2	5 ft	5	SF	\$75	\$375	

TOTAL COST FOR: NW	<i>side of HUMBOLDT AVE</i>	<i>Starting at: 5TH ST</i>	\$69,225.00
---------------------------	-----------------------------	----------------------------	--------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251103	HUMBOLDT AVE	6TH ST	7TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
22974	0.9 to 15.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	72	SF	\$120	\$8,640
54861	20.4 to 21.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
22978	24.5 to 58.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	172	SF	\$120	\$20,580
59327	45.9 to 61.5 feet	Driveway				REF		
22985	58.8 to 64.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	29	SF	\$40	\$1,140
22987	64.8 to 106.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	210	SF	\$120	\$25,200
56220	65.2 to 66.2 feet	Vertical Change	.4	5 ft	5	REF		
54862	91.4 to 92.4 feet	Vertical Change	.3	5 ft	5	REF		
59328	106.4 to 125.8 feet	Driveway				REF		
22994	131.1 to 153.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	114	SF	\$120	\$13,620
23000	158.8 to 172.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	69	SF	\$120	\$8,280
23005	173.5 to 176.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	13	SF	\$120	\$1,560
23006	179.8 to 181.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260
23007	184.0 to 190.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	32	SF	\$120	\$3,780
23008	190.3 to 201.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,780
23013	201.6 to 203.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	12	SF	\$120	\$1,380
59329	203.6 to 217.8 feet	Driveway				REF		
57310	219.1 to 220.1 feet	Vertical Change	.9	5 ft	5	SF	\$75	\$375
23015	221.6 to 232.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	54	SF	\$120	\$6,420
23019	232.6 to 243.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,300
23022	247.5 to 287.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	199	SF	\$120	\$23,940
57037	261.2 to 262.2 feet	Vertical Change	.6	5 ft	5	REF		
54863	283.5 to 284.5 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: NW side of HUMBOLDT AVE Starting at: 6TH ST							\$129,630.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	1909251107	HUMBOLDT AVE	7TH ST	8TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
22942	0.0 to 33.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	168	SF	\$120	\$20,100	
57533	11.3 to 12.3 feet	Vertical Change	2.1	5 ft	5	REF			
54854	22.5 to 23.5 feet	Vertical Change	.3	5 ft	5	REF			
59323	37.3 to 47.8 feet	Driveway				REF			
54855	45.3 to 46.3 feet	Vertical Change	.3	5 ft	5	REF			
22948	49.4 to 53.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400	
22949	55.5 to 74.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	95	SF	\$120	\$11,340	
54856	66.3 to 67.3 feet	Vertical Change	.3	5 ft	5	REF			
22952	76.5 to 78.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,080	
54857	77.9 to 78.9 feet	Vertical Change	.3	5 ft	5	REF			
22953	80.0 to 96.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	84	SF	\$120	\$10,020	
59324	86.6 to 105.1 feet	Driveway				REF			
22957	103.6 to 109.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	31	SF	\$40	\$1,220	
57036	103.8 to 104.8 feet	Vertical Change	.6	5 ft	5	REF			
59325	138.0 to 152.0 feet	Driveway				REF			
22958	152.6 to 161.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	45	SF	\$120	\$5,460	
22960	161.7 to 166.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060	
22962	170.1 to 177.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,440	
54858	172.9 to 173.9 feet	Vertical Change	.3	5 ft	5	REF			
22964	179.8 to 181.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,080	
22965	181.6 to 183.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140	
59326	189.7 to 202.7 feet	Driveway				REF			
57471	207.3 to 208.3 feet	Vertical Change	1.5	5 ft	5	SF	\$75	\$375	
22966	214.9 to 218.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400	
22968	236.5 to 243.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,380	
54859	252.5 to 253.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
22971	256.1 to 258.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,260	
22972	262.0 to 265.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,340	
22973	274.7 to 280.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,240	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251107	HUMBOLDT AVE	7TH ST	8TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57385	279.3 to 280.3 feet	Vertical Change	1.1	5 ft	5	REF		
54860	281.9 to 284.9 feet	Vertical Change	.3	5 ft	15	LF	\$75	\$1,125
TOTAL COST FOR: NW side of HUMBOLDT AVE Starting at: 7TH ST							\$76,835.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251110	HUMBOLDT AVE	8TH ST	9TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
22899	0.3 to 21.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	104	SF	\$120	\$12,480
57482	2.7 to 3.7 feet	Vertical Change	1.6	5 ft	5	REF		
54846	6.2 to 9.6 feet	Vertical Change	.3	5 ft	17	REF		
22904	31.3 to 34.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	14	SF	\$120	\$1,680
22905	35.2 to 43.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,740
22907	46.4 to 62.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	83	SF	\$120	\$9,900
22912	74.2 to 84.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,360
54847	79.2 to 80.2 feet	Vertical Change	.3	5 ft	5	REF		
59319	83.3 to 95.7 feet	Driveway				REF		
54848	83.4 to 84.4 feet	Vertical Change	.3	5 ft	5	REF		
54849	88.6 to 89.6 feet	Vertical Change	.3	5 ft	5	REF		
22915	102.3 to 113.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,600
22916	118.7 to 130.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,080
59320	132.8 to 144.6 feet	Driveway				REF		
22920	148.1 to 153.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120
54850	151.2 to 152.2 feet	Vertical Change	.3	5 ft	5	REF		
22921	155.8 to 162.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	33	SF	\$120	\$3,960
22922	164.9 to 177.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	61	SF	\$120	\$7,320
54851	171.9 to 172.9 feet	Vertical Change	.3	5 ft	5	REF		
22927	181.6 to 183.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$840
54852	182.4 to 183.4 feet	Vertical Change	.3	5 ft	5	REF		
22928	183.0 to 184.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720
59321	186.5 to 199.1 feet	Driveway				REF		
59322	204.5 to 216.8 feet	Driveway				REF		
54853	205.1 to 206.1 feet	Vertical Change	.3	5 ft	5	REF		
22929	221.3 to 267.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	232	SF	\$120	\$27,780
22937	271.7 to 295.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	119	SF	\$120	\$14,280

TOTAL COST FOR: NW side of HUMBOLDT AVE Starting at: 8TH ST \$106,860.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251113	HUMBOLDT AVE	9TH ST	908 HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
22884	13.8 to 24.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,886
54839	13.9 to 17.3 feet	Vertical Change	.3	5 ft	15	REF		
54840	27.8 to 28.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
54841	39.6 to 40.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
59317	44.9 to 57.7 feet	Driveway				REF		
22887	55.3 to 70.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	68	SF	\$40	\$2,718
22891	70.9 to 92.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	96	SF	\$120	\$11,502
54842	73.2 to 74.2 feet	Vertical Change	.3	5 ft	5	REF		
54843	85.3 to 86.3 feet	Vertical Change	.3	5 ft	5	REF		
22895	92.2 to 93.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$702
59318	94.0 to 107.5 feet	Driveway				REF		
54844	95.0 to 96.0 feet	Vertical Change	.3	5 ft	5	REF		
22896	105.4 to 109.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	17	SF	\$40	\$684
54845	117.0 to 118.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
22897	119.1 to 125.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,402
TOTAL COST FOR: NW side of HUMBOLDT AVE Starting at: 9TH ST								\$25,906.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251117	HUMBOLDT AVE	912 HUMBOLDT AVE	10TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
22870	0.3 to 30.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	138	SF	\$120	\$16,524
54835	8.9 to 9.9 feet	Vertical Change	.3	5 ft	5	REF		
56729	17.0 to 18.0 feet	Vertical Change	.5	5 ft	5	REF		
54836	21.1 to 22.1 feet	Vertical Change	.3	5 ft	5	REF		
22873	38.6 to 47.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,860
22875	58.6 to 59.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$594
54837	59.9 to 60.9 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
59316	64.5 to 76.5 feet	Driveway				REF		
22876	79.5 to 106.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	122	SF	\$120	\$14,634
54838	88.5 to 89.5 feet	Vertical Change	.3	5 ft	5	REF		
22881	111.6 to 122.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$5,940
22883	124.9 to 133.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,536
TOTAL COST FOR: NW side of HUMBOLDT AVE Starting at: 912 HUMBOLDT AVE							\$47,425.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	1909251121	HUMBOLDT AVE	10TH ST	11TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
22820	4.0 to 14.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,120	
22822	45.8 to 50.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,520	
22823	74.6 to 83.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$5,040	
22824	91.4 to 102.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,780	
54833	95.4 to 96.4 feet	Vertical Change	.3	5 ft	5	REF			
59315	102.8 to 135.3 feet	Driveway				REF			
22828	106.5 to 120.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	69	SF	\$40	\$2,760	
54834	118.0 to 119.0 feet	Vertical Change	.3	5 ft	5	REF			
22831	136.3 to 139.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800	
22833	139.8 to 149.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	49	SF	\$120	\$5,880	
22837	151.8 to 154.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	13	SF	\$120	\$1,560	
57258	152.9 to 153.9 feet	Vertical Change	.8	5 ft	5	REF			
22838	155.1 to 158.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160	
22839	166.5 to 174.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,920	
22841	180.9 to 198.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	88	SF	\$120	\$10,500	
22847	202.1 to 203.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720	
56216	203.1 to 204.1 feet	Vertical Change	.4	5 ft	5	REF			
22848	212.6 to 216.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400	
22849	228.3 to 229.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840	
22850	233.0 to 250.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,320	
22858	252.9 to 258.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,480	
22860	262.8 to 281.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	95	SF	\$120	\$11,340	
22867	285.1 to 298.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,800	
TOTAL COST FOR: NW side of HUMBOLDT AVE Starting at: 10TH ST								\$86,940.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251124	HUMBOLDT AVE	11TH ST	12TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
22788	30.1 to 32.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	8	SF	\$120	\$912
22789	46.3 to 47.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$624
22790	49.9 to 73.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	96	SF	\$120	\$11,520
54829	50.5 to 51.5 feet	Vertical Change	.3	4 ft	4	REF		
54830	60.8 to 61.8 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
59311	75.9 to 88.1 feet	Driveway				REF		
22797	78.3 to 80.8 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	10	SF	\$40	\$400
59312	94.2 to 108.3 feet	Driveway				REF		
22798	97.3 to 102.8 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	22	SF	\$40	\$880
22799	106.8 to 112.9 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	24	SF	\$40	\$976
56215	111.6 to 112.6 feet	Vertical Change	.4	4 ft	4	REF		
59313	146.8 to 190.5 feet	Driveway				REF		
22800	151.8 to 163.4 feet	Cross Slope (Driveway)	12.0-13.0%	4 ft	46	SF	\$40	\$1,856
22802	163.7 to 186.9 feet	Cross Slope (Driveway)	14.0-15.0%	4 ft	93	SF	\$40	\$3,712
40661	187.9 to 190.0 feet	Running Slope	5.0-6.0%	4 ft	8	REF		
22807	194.1 to 195.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	5	SF	\$120	\$624
59314	194.8 to 212.2 feet	Driveway				REF		
57187	195.4 to 196.4 feet	Vertical Change	.7	4 ft	4	REF		
22808	200.7 to 206.0 feet	Cross Slope (Driveway)	14.0-15.0%	4 ft	21	SF	\$40	\$848
22810	206.3 to 209.8 feet	Cross Slope (Driveway)	12.0-13.0%	4 ft	14	SF	\$40	\$560
57309	211.8 to 212.8 feet	Vertical Change	.9	4 ft	4	REF		
22812	237.8 to 241.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,968
22813	251.3 to 271.9 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	82	SF	\$120	\$9,888
54831	271.2 to 272.2 feet	Vertical Change	.3	4 ft	4	REF		
22816	271.9 to 273.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	6	SF	\$120	\$672
22817	273.6 to 282.9 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	37	SF	\$120	\$4,464
54832	274.4 to 275.4 feet	Vertical Change	.3	4 ft	4	REF		
TOTAL COST FOR: NW side of HUMBOLDT AVE Starting at: 11TH ST							\$40,204.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251127	HUMBOLDT AVE	12TH ST	13TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
22748	0.9 to 3.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	12	SF	\$120	\$1,440
54824	2.0 to 3.0 feet	Vertical Change	.3	4 ft	4	REF		
54825	11.9 to 12.9 feet	Vertical Change	.3	4 ft	4	REF		
22749	12.8 to 34.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	88	SF	\$120	\$10,608
22754	37.1 to 46.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	39	SF	\$120	\$4,704
22755	51.2 to 55.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	16	SF	\$120	\$1,968
22757	74.0 to 89.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	62	SF	\$120	\$7,488
22761	89.6 to 107.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	73	SF	\$120	\$8,736
22767	110.0 to 111.9 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	8	SF	\$120	\$912
59308	110.5 to 130.3 feet	Driveway				REF		
54826	110.8 to 111.8 feet	Vertical Change	.3	4 ft	4	REF		
54827	131.5 to 132.5 feet	Vertical Change	.3	4 ft	4	REF		
22768	131.6 to 140.1 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	34	SF	\$120	\$4,080
54828	138.7 to 139.7 feet	Vertical Change	.3	4 ft	4	REF		
59309	140.7 to 154.8 feet	Driveway				REF		
22771	141.1 to 143.2 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	8	SF	\$40	\$336
22772	156.1 to 159.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	15	SF	\$120	\$1,824
22774	165.6 to 169.1 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	14	SF	\$120	\$1,680
22775	169.7 to 193.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	95	SF	\$120	\$11,376
22780	196.1 to 198.5 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	10	SF	\$120	\$1,152
59310	198.8 to 235.8 feet	Driveway				REF		
22781	215.8 to 219.3 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	14	SF	\$40	\$560
22782	235.0 to 239.2 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	17	SF	\$40	\$672
22784	242.9 to 255.8 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	52	SF	\$120	\$6,192
56214	256.0 to 257.0 feet	Vertical Change	.4	4 ft	4	REF		
22786	256.2 to 264.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	34	SF	\$120	\$4,080
57500	264.2 to 265.2 feet	Vertical Change	1.7	4 ft	4	REF		
22787	268.3 to 269.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	4	SF	\$120	\$528

TOTAL COST FOR: NW side of HUMBOLDT AVE Starting at: 12TH ST \$68,336.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909251130	HUMBOLDT AVE	13TH ST	14TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
22703	0.0 to 1.7 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	7	SF	\$120	\$816	
59302	0.1 to 20.8 feet	Driveway				REF			
22704	6.2 to 17.0 feet	Cross Slope (Driveway)	12.0-13.0%	4 ft	43	SF	\$40	\$1,728	
54815	9.8 to 10.8 feet	Vertical Change	.3	4 ft	4	REF			
54816	19.6 to 20.6 feet	Vertical Change	.3	4 ft	4	REF			
22708	21.3 to 33.6 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	49	SF	\$40	\$1,968	
22711	33.6 to 34.9 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	5	SF	\$120	\$624	
22712	37.3 to 41.4 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	16	SF	\$120	\$1,968	
22713	44.7 to 45.7 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	4	SF	\$120	\$480	
54817	47.0 to 48.0 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300	
22714	48.5 to 63.1 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	58	SF	\$120	\$7,008	
54818	50.1 to 51.1 feet	Vertical Change	.3	4 ft	4	REF			
59303	67.3 to 87.3 feet	Driveway				REF			
54819	67.4 to 68.4 feet	Vertical Change	.3	4 ft	4	REF			
22717	71.0 to 77.1 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	24	SF	\$40	\$976	
54820	71.6 to 72.6 feet	Vertical Change	.3	4 ft	4	REF			
22719	77.1 to 86.4 feet	Cross Slope (Driveway)	4.0-5.0%	4 ft	37	SF	\$40	\$1,488	
22722	86.4 to 90.8 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	18	SF	\$40	\$704	
59304	90.8 to 103.9 feet	Driveway				REF			
22724	97.3 to 101.3 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	16	SF	\$40	\$640	
22725	107.6 to 129.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	88	SF	\$120	\$10,560	
54821	108.7 to 109.7 feet	Vertical Change	.3	4 ft	4	REF			
54822	129.0 to 130.0 feet	Vertical Change	.3	4 ft	4	REF			
22731	131.8 to 145.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	54	SF	\$120	\$6,480	
57035	141.1 to 142.1 feet	Vertical Change	.6	4 ft	4	REF			
59305	145.8 to 158.7 feet	Driveway				REF			
57186	153.9 to 154.9 feet	Vertical Change	.7	4 ft	4	REF			
56728	161.8 to 162.8 feet	Vertical Change	.5	4 ft	4	REF			
22735	162.0 to 164.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	10	SF	\$120	\$1,248	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251130	HUMBOLDT AVE	13TH ST	14TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
22736	167.7 to 172.5 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	19	SF	\$120	\$2,304
22737	193.3 to 199.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	26	SF	\$120	\$3,072
59306	199.2 to 220.9 feet	Driveway				REF		
22738	203.7 to 205.9 feet	Cross Slope (Driveway)	13.014	4 ft	9	SF	\$40	\$352
22740	209.5 to 217.9 feet	Cross Slope (Driveway)	14.0-15.0%	4 ft	34	SF	\$40	\$1,344
22742	221.5 to 231.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	40	SF	\$120	\$4,752
22743	236.7 to 239.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	11	SF	\$120	\$1,296
22744	243.1 to 245.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	8	SF	\$120	\$912
59307	246.8 to 263.2 feet	Driveway				REF		
54823	271.9 to 272.9 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
22745	275.4 to 284.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	37	SF	\$120	\$4,464
TOTAL COST FOR: NW side of HUMBOLDT AVE Starting at: 13TH ST							\$55,784.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909251133	HUMBOLDT AVE	14TH ST	15TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
22656	0.0 to 16.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,802	
59297	19.2 to 36.6 feet	Driveway				REF			
56724	19.4 to 20.4 feet	Vertical Change	.5	5 ft	5	REF			
22658	24.9 to 29.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	18	SF	\$40	\$738	
22659	31.6 to 33.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	7	SF	\$40	\$288	
54810	35.5 to 36.5 feet	Vertical Change	.3	5 ft	5	REF			
59298	38.3 to 52.1 feet	Driveway				REF			
22660	42.7 to 48.9 feet	Cross Slope (Driveway)	>15%	5 ft	28	SF	\$40	\$1,116	
22661	52.5 to 68.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	71	SF	\$40	\$2,826	
22666	70.1 to 73.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620	
22667	75.2 to 85.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,454	
22670	86.0 to 89.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	15	SF	\$120	\$1,782	
59299	89.9 to 102.5 feet	Driveway				REF			
22671	103.7 to 116.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,912	
22674	122.0 to 134.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,480	
54811	127.5 to 128.5 feet	Vertical Change	.3	5 ft	5	REF			
22676	138.3 to 144.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,348	
54812	141.1 to 142.1 feet	Vertical Change	.3	5 ft	5	REF			
59300	144.9 to 157.8 feet	Driveway				REF			
22678	162.9 to 172.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,130	
56725	189.1 to 190.1 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$338	
22680	198.3 to 203.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,970	
22682	213.0 to 217.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,646	
22683	220.0 to 230.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,724	
59301	230.3 to 244.8 feet	Driveway				REF			
22687	232.9 to 234.1 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	5	SF	\$40	\$216	
22688	235.0 to 242.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	36	SF	\$40	\$1,422	
40660	241.9 to 243.4 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
22690	246.0 to 267.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	95	SF	\$120	\$11,448	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251133	HUMBOLDT AVE	14TH ST	15TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56726	251.2 to 252.2 feet	Vertical Change	.5	5 ft	5	REF		
57033	265.5 to 266.5 feet	Vertical Change	.6	5 ft	5	REF		
22696	267.2 to 279.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	53	SF	\$120	\$6,372
54813	273.0 to 276.7 feet	Vertical Change	.3	5 ft	17	REF		
22699	279.0 to 282.9 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	18	SF	\$120	\$2,106
57034	281.3 to 284.1 feet	Vertical Change	.6	5 ft	13	REF		
54814	285.1 to 286.1 feet	Vertical Change	.3	5 ft	5	REF		
22701	285.6 to 287.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$810
22702	287.1 to 290.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,728
TOTAL COST FOR: NW side of HUMBOLDT AVE Starting at: 14TH ST							\$80,275.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1909251137	HUMBOLDT AVE	15TH ST	14TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
22607	0.3 to 5.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,808	
22609	5.7 to 18.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	57	SF	\$120	\$6,804	
22613	20.4 to 46.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	119	SF	\$120	\$14,256	
54807	45.7 to 46.7 feet	Vertical Change	.3	5 ft	5	REF			
59293	45.8 to 59.3 feet	Driveway				REF			
22620	46.8 to 48.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$324	
22621	63.5 to 71.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,482	
22623	76.3 to 86.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,670	
22627	91.5 to 97.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,078	
59294	97.8 to 112.7 feet	Driveway				REF			
22628	101.3 to 104.2 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	13	SF	\$40	\$522	
22630	105.1 to 108.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	14	SF	\$40	\$576	
22632	115.4 to 117.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$972	
22633	118.7 to 125.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	32	SF	\$120	\$3,780	
57032	123.0 to 124.0 feet	Vertical Change	.6	5 ft	5	REF			
22635	127.6 to 135.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,374	
22636	139.1 to 145.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,564	
59295	146.6 to 163.3 feet	Driveway				REF			
22638	150.8 to 159.9 feet	Cross Slope (Driveway)	13.014	5 ft	41	SF	\$40	\$1,638	
54808	158.6 to 159.6 feet	Vertical Change	.3	5 ft	5	REF			
22641	171.9 to 175.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160	
22643	178.2 to 183.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,754	
22644	186.9 to 197.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,778	
59296	195.8 to 212.3 feet	Driveway				REF			
56213	196.7 to 197.7 feet	Vertical Change	.4	5 ft	5	REF			
22646	201.0 to 208.7 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	35	SF	\$40	\$1,386	
54809	210.9 to 211.9 feet	Vertical Change	.3	5 ft	5	REF			
22649	213.8 to 215.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$918	
22650	233.3 to 242.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,752	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251137	HUMBOLDT AVE	15TH ST	14TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
22653	251.7 to 254.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,242
22654	269.9 to 279.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,130
22655	283.7 to 286.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,566
TOTAL COST FOR: SE side of HUMBOLDT AVE Starting at: 15TH ST							\$78,534.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	1909251140	HUMBOLDT AVE	14TH ST	13TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
22559	6.8 to 10.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,106	
59288	21.5 to 34.4 feet	Driveway				REF			
22561	27.8 to 36.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	38	SF	\$40	\$1,512	
59289	36.3 to 51.2 feet	Driveway				REF			
56723	37.7 to 38.7 feet	Vertical Change	.5	5 ft	5	REF			
22562	44.6 to 50.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	26	SF	\$40	\$1,044	
54799	47.6 to 48.6 feet	Vertical Change	.3	5 ft	5	REF			
22564	50.4 to 57.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	32	SF	\$40	\$1,260	
22567	57.4 to 69.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,480	
22569	74.4 to 82.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,374	
59290	88.2 to 102.4 feet	Driveway				REF			
22572	93.8 to 99.3 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	25	SF	\$40	\$990	
56212	100.9 to 101.9 feet	Vertical Change	.4	5 ft	5	REF			
54800	105.4 to 106.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338	
54801	115.8 to 116.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338	
54802	126.0 to 127.0 feet	Vertical Change	.3	5 ft	5	REF			
22574	126.2 to 169.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	195	SF	\$120	\$23,382	
54803	138.9 to 139.9 feet	Vertical Change	.3	5 ft	5	REF			
22585	169.8 to 173.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	17	SF	\$120	\$1,998	
59291	173.5 to 186.6 feet	Driveway				REF			
22587	177.8 to 185.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	35	SF	\$40	\$1,404	
54804	185.2 to 186.2 feet	Vertical Change	.3	5 ft	5	REF			
59292	189.5 to 207.3 feet	Driveway				REF			
54805	190.7 to 191.7 feet	Vertical Change	.3	5 ft	5	REF			
54806	205.3 to 206.3 feet	Vertical Change	.3	5 ft	5	REF			
22589	210.0 to 214.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,592	
22590	222.7 to 224.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,026	
22591	230.9 to 236.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,970	
22593	240.8 to 242.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251140	HUMBOLDT AVE	14TH ST	13TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
22594	252.8 to 259.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	28	SF	\$120	\$3,402
22597	259.1 to 271.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,588
22603	271.3 to 284.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	61	SF	\$120	\$7,344
TOTAL COST FOR: SE side of HUMBOLDT AVE Starting at: 14TH ST							\$70,227.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251144	HUMBOLDT AVE	13TH ST	12TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56722	0.1 to 1.1 feet	Vertical Change	.5	4 ft	4	REF		
22518	0.2 to 1.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	4	SF	\$120	\$480
57031	10.4 to 11.4 feet	Vertical Change	.6	4 ft	4	REF		
22519	10.5 to 16.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	24	SF	\$120	\$2,832
22520	21.4 to 24.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	13	SF	\$120	\$1,584
59283	24.1 to 36.8 feet	Driveway				REF		
22522	27.9 to 30.1 feet	Cross Slope (Driveway)	10.0-11.0%	4 ft	9	SF	\$40	\$352
22523	31.2 to 32.8 feet	Cross Slope (Driveway)	8.0-9.0%	4 ft	6	SF	\$40	\$256
59284	65.6 to 95.8 feet	Driveway				REF		
54794	67.1 to 68.1 feet	Vertical Change	.3	4 ft	4	REF		
40656	69.5 to 74.6 feet	Running Slope	6.0-7.0%	4 ft	20	REF		
22524	72.2 to 85.8 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	54	SF	\$40	\$2,176
54795	76.5 to 77.5 feet	Vertical Change	.3	4 ft	4	REF		
40659	88.8 to 91.7 feet	Running Slope	5.0-6.0%	4 ft	12	REF		
22529	89.4 to 96.0 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	26	SF	\$40	\$1,056
22532	112.1 to 125.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	53	SF	\$120	\$6,336
54796	126.0 to 127.0 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
59285	128.9 to 139.8 feet	Driveway				REF		
57593	129.8 to 130.8 feet	Vertical Change	2.9	4 ft	4	REF		
22533	132.2 to 133.6 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	6	SF	\$40	\$224
22534	136.0 to 138.8 feet	Cross Slope (Driveway)	6.0-7.0%	4 ft	11	SF	\$40	\$448
22536	138.8 to 139.8 feet	Cross Slope (Driveway)	5.0-6.0%	4 ft	4	SF	\$40	\$160
22537	140.6 to 142.7 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	8	SF	\$120	\$1,008
54797	142.0 to 143.0 feet	Vertical Change	.3	4 ft	4	REF		
22538	146.5 to 149.2 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	11	SF	\$120	\$1,296
59286	148.0 to 160.3 feet	Driveway				REF		
22539	149.2 to 163.2 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	56	SF	\$40	\$2,240
22544	165.8 to 190.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	100	SF	\$120	\$12,048
22550	194.7 to 209.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	59	SF	\$120	\$7,056

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251144	HUMBOLDT AVE	13TH ST	12TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
22554	221.8 to 231.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	37	SF	\$120	\$4,464
59287	231.2 to 247.7 feet	Driveway				REF		
54798	232.9 to 233.9 feet	Vertical Change	.3	4 ft	4	REF		
22555	249.3 to 264.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	60	SF	\$120	\$7,200
22558	268.2 to 270.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	7	SF	\$120	\$864
TOTAL COST FOR: SE side of HUMBOLDT AVE Starting at: 13TH ST							\$52,380.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251147	HUMBOLDT AVE	12TH ST	11TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
22491	15.2 to 16.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$1,020
22492	20.4 to 38.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	89	SF	\$120	\$10,620
54792	20.5 to 21.5 feet	Vertical Change	.3	5 ft	5	REF		
22495	53.9 to 56.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320
22496	65.0 to 74.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,580
22498	81.0 to 87.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020
22501	95.3 to 101.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,600
22502	108.2 to 112.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700
22503	120.9 to 123.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320
22504	153.2 to 157.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400
22505	160.6 to 166.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,540
56211	164.5 to 165.5 feet	Vertical Change	.4	5 ft	5	REF		
22507	169.2 to 178.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,580
22510	194.9 to 197.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740
22511	204.1 to 210.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,720
22515	223.2 to 225.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440
54793	236.4 to 237.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
57184	246.7 to 247.7 feet	Vertical Change	.7	5 ft	5	SF	\$75	\$375
22516	269.3 to 271.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020
22517	277.3 to 283.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,660

TOTAL COST FOR: SE side of HUMBOLDT AVE Starting at: 12TH ST \$54,030.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251154	HUMBOLDT AVE	11TH ST	8TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
22287	0.5 to 5.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,808
54783	4.7 to 5.7 feet	Vertical Change	.3	5 ft	5	REF		
54784	8.7 to 9.7 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
22288	16.3 to 21.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,808
54785	19.8 to 20.8 feet	Vertical Change	.3	5 ft	5	REF		
22290	21.7 to 23.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	7	SF	\$120	\$864
22291	26.1 to 50.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	109	SF	\$120	\$13,122
22298	50.4 to 111.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	276	SF	\$120	\$33,102
22310	114.4 to 115.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$594
22311	115.5 to 120.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,862
22314	123.2 to 131.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,698
22318	134.2 to 143.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,184
22321	143.8 to 166.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	104	SF	\$120	\$12,474
22328	171.7 to 207.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	162	SF	\$120	\$19,494
22341	211.3 to 215.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	20	SF	\$120	\$2,376
22343	218.1 to 230.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	54	SF	\$120	\$6,426
22346	230.0 to 241.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$5,940
22349	241.3 to 248.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	32	SF	\$120	\$3,834
22352	248.4 to 255.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,888
22354	257.8 to 263.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	25	SF	\$120	\$2,970
22356	263.6 to 293.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	134	SF	\$120	\$16,092
22364	303.9 to 325.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	96	SF	\$120	\$11,556
59282	313.3 to 337.9 feet	Driveway				REF		
22370	338.9 to 340.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	7	SF	\$120	\$810
22371	341.7 to 344.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	14	SF	\$120	\$1,674
54786	341.9 to 342.9 feet	Vertical Change	.3	5 ft	5	REF		
22372	345.6 to 354.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	38	SF	\$120	\$4,590
22373	354.6 to 359.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	23	SF	\$120	\$2,808

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	1909251154	HUMBOLDT AVE	11TH ST	8TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
22376	372.8 to 375.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,350	
22377	379.4 to 393.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,398	
22383	395.2 to 406.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$5,940	
22386	408.3 to 409.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$810	
22387	414.0 to 435.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	99	SF	\$120	\$11,826	
22392	435.9 to 437.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	5	SF	\$120	\$594	
57030	438.6 to 439.6 feet	Vertical Change	.6	5 ft	5	SF	\$75	\$338	
22393	440.2 to 441.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	7	SF	\$120	\$864	
22394	441.8 to 443.3 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	7	SF	\$120	\$810	
22395	443.3 to 455.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	54	SF	\$120	\$6,534	
22399	455.4 to 517.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	279	SF	\$120	\$33,534	
56209	495.1 to 496.1 feet	Vertical Change	.4	5 ft	5	REF			
22411	518.6 to 553.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	157	SF	\$120	\$18,792	
22421	556.8 to 573.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	77	SF	\$120	\$9,180	
22423	573.8 to 578.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	19	SF	\$120	\$2,268	
22425	582.3 to 585.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,890	
22427	596.2 to 597.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$594	
22428	604.4 to 608.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	18	SF	\$120	\$2,214	
22430	608.7 to 629.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	92	SF	\$120	\$11,016	
22435	629.1 to 636.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	32	SF	\$120	\$3,834	
22436	638.4 to 640.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	11	SF	\$120	\$1,296	
22438	643.3 to 645.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	11	SF	\$120	\$1,350	
22439	646.0 to 652.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,456	
22442	657.8 to 675.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	78	SF	\$120	\$9,342	
56210	666.6 to 667.6 feet	Vertical Change	.4	5 ft	5	REF			
22445	675.6 to 689.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	62	SF	\$120	\$7,452	
22448	689.4 to 695.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,132	
22450	697.9 to 710.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,858	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251154	HUMBOLDT AVE	11TH ST	8TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
22452	710.6 to 729.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	84	SF	\$120	\$10,044
22456	729.2 to 782.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	238	SF	\$120	\$28,566
54787	748.7 to 749.7 feet	Vertical Change	.3	5 ft	5	REF		
54788	771.9 to 772.9 feet	Vertical Change	.3	5 ft	5	REF		
22465	782.1 to 805.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	104	SF	\$120	\$12,420
22471	812.7 to 825.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,020
22474	929.0 to 963.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	153	SF	\$120	\$18,414
54789	941.0 to 942.0 feet	Vertical Change	.3	5 ft	5	REF		
22480	964.9 to 972.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	35	SF	\$120	\$4,212
22482	975.1 to 1006.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	143	SF	\$120	\$17,118
54790	982.0 to 983.0 feet	Vertical Change	.3	5 ft	5	REF		
54791	1005.2 to 1006.2 feet	Vertical Change	.3	5 ft	5	REF		

TOTAL COST FOR: SE	<i>side of HUMBOLDT AVE Starting at: 11TH ST</i>	\$411,777.00
---------------------------	--	---------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251158	HUMBOLDT AVE	8TH ST	7TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
22244	0.0 to 2.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	10	SF	\$120	\$1,242
54781	2.4 to 3.4 feet	Vertical Change	.3	5 ft	5	REF		
22245	3.2 to 4.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$756
22246	4.6 to 18.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,614
56208	9.5 to 10.5 feet	Vertical Change	.4	5 ft	5	REF		
22250	31.8 to 36.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,430
22251	43.3 to 72.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	131	SF	\$120	\$15,714
54782	43.5 to 44.5 feet	Vertical Change	.3	5 ft	5	REF		
22256	74.8 to 87.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	55	SF	\$120	\$6,588
22259	87.0 to 88.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$702
59279	91.6 to 117.9 feet	Driveway				REF		
22260	97.2 to 115.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	81	SF	\$40	\$3,258
22265	118.7 to 119.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$648
22266	122.3 to 136.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,398
22269	139.5 to 146.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,834
22270	151.3 to 152.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$702
22271	158.6 to 162.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,106
59280	181.5 to 209.1 feet	Driveway				REF		
40655	183.4 to 185.6 feet	Running Slope	5.0-6.0%	5 ft	10	REF		
22272	186.9 to 205.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	85	SF	\$40	\$3,402
22278	209.9 to 211.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$594
22279	211.0 to 286.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	341	SF	\$120	\$40,878
TOTAL COST FOR: SE side of HUMBOLDT AVE Starting at: 8TH ST							\$97,866.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	1909251201	HUMBOLDT AVE	7TH ST	6TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
22194	0.0 to 43.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	217	SF	\$120	\$26,040	
22202	49.7 to 67.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	89	SF	\$120	\$10,740	
22205	70.4 to 108.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	189	SF	\$120	\$22,740	
59275	91.4 to 115.6 feet	Driveway				REF			
22211	116.8 to 123.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,200	
22213	125.6 to 141.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	79	SF	\$120	\$9,480	
56207	139.2 to 140.2 feet	Vertical Change	.4	5 ft	5	REF			
22216	143.0 to 167.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	123	SF	\$120	\$14,760	
59276	144.4 to 167.8 feet	Driveway				REF			
22220	169.7 to 179.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,640	
22222	179.7 to 187.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	40	SF	\$120	\$4,740	
22224	187.8 to 189.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720	
22225	191.1 to 193.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200	
54780	191.6 to 192.6 feet	Vertical Change	.3	5 ft	5	REF			
22226	196.2 to 210.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,820	
59277	196.5 to 219.4 feet	Driveway				REF			
22228	221.0 to 224.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,980	
22230	224.3 to 246.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	112	SF	\$120	\$13,440	
22233	247.1 to 250.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160	
59278	248.3 to 272.0 feet	Driveway				REF			
22235	251.1 to 252.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	6	SF	\$40	\$240	
22236	253.7 to 255.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$280	
22237	258.3 to 263.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	24	SF	\$40	\$940	
22238	268.2 to 278.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	52	SF	\$40	\$2,060	
22242	278.5 to 290.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	62	SF	\$120	\$7,440	
TOTAL COST FOR: SE							side of HUMBOLDT AVE	Starting at: 7TH ST	\$137,620.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	1909251205	HUMBOLDT AVE	6TH ST	5TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
22148	0.0 to 16.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	73	SF	\$120	\$8,748	
22152	16.3 to 21.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700	
22153	24.3 to 26.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,134	
22154	39.8 to 41.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$918	
22155	50.8 to 60.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,968	
59270	79.2 to 95.7 feet	Driveway				REF			
40654	80.9 to 82.0 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
22158	83.3 to 93.2 feet	Cross Slope (Driveway)	>15%	5 ft	45	SF	\$40	\$1,782	
22161	96.5 to 97.6 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$198	
59271	96.9 to 113.2 feet	Driveway				REF			
22162	100.6 to 110.8 feet	Cross Slope (Driveway)	>15%	5 ft	46	SF	\$40	\$1,836	
22163	114.2 to 115.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$918	
22164	118.2 to 127.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	41	SF	\$120	\$4,914	
22166	127.5 to 148.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	96	SF	\$120	\$11,556	
59272	154.8 to 168.9 feet	Driveway				REF			
22169	164.5 to 178.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	62	SF	\$40	\$2,466	
54778	175.0 to 176.0 feet	Vertical Change	.3	5 ft	5	REF			
22174	188.6 to 191.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,458	
22176	191.3 to 204.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	59	SF	\$120	\$7,074	
22180	204.4 to 219.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	67	SF	\$120	\$8,046	
22184	226.2 to 238.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,642	
59273	235.8 to 247.8 feet	Driveway				REF			
59274	250.9 to 263.1 feet	Driveway				REF			
22187	254.6 to 262.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	34	SF	\$40	\$1,368	
22190	264.8 to 267.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,566	
54779	265.8 to 266.8 feet	Vertical Change	.3	5 ft	5	REF			
22191	271.4 to 277.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,132	
22192	280.3 to 282.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,404	
22193	285.3 to 287.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$918	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251205	HUMBOLDT AVE	6TH ST	5TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
TOTAL COST FOR: SE							<i>side of</i>	\$73,746.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251207	HUMBOLDT AVE	5TH ST	413 HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
22136	0.0 to 1.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	9	SF	\$120	\$1,080
22137	2.1 to 4.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	14	SF	\$120	\$1,620
59268	4.2 to 19.7 feet	Driveway				REF		
22138	8.3 to 10.3 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	10	SF	\$40	\$400
22139	11.2 to 16.5 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	27	SF	\$40	\$1,060
22141	16.5 to 17.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	5	SF	\$40	\$200
22142	35.9 to 39.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160
56206	40.4 to 41.4 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
22143	41.8 to 45.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400
59269	44.0 to 62.1 feet	Driveway				REF		
22145	50.0 to 58.0 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	40	SF	\$40	\$1,600
54777	58.5 to 59.5 feet	Vertical Change	.3	5 ft	5	REF		
40652	58.5 to 60.0 feet	Running Slope	6.0-7.0%	5 ft	8	REF		
40653	60.0 to 61.5 feet	Running Slope	5.0-6.0%	5 ft	8	REF		
22147	62.7 to 67.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060
TOTAL COST FOR: SE side of HUMBOLDT AVE Starting at: 5TH ST								\$13,955.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251209	HUMBOLDT AVE	405 HUMBOLDT AVE	405 HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
22131	0.0 to 4.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	19	SF	\$120	\$2,322
22132	4.3 to 9.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700
54776	25.5 to 26.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
59267	27.6 to 44.6 feet	Driveway				REF		
40649	28.3 to 31.0 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
22133	32.3 to 41.9 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	43	SF	\$40	\$1,728
40650	41.9 to 44.3 feet	Running Slope	6.0-7.0%	5 ft	11	REF		
22135	45.6 to 48.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	12	SF	\$120	\$1,458
TOTAL COST FOR: SE side of HUMBOLDT AVE Starting at: 405 HUMBOLDT AVE							\$8,545.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251213	HUMBOLDT AVE	309 HUMBOLDT AVE	3RD ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59266	0.5 to 16.8 feet	Driveway				REF		
22109	4.3 to 14.4 feet	Cross Slope (Driveway)	>15%	5 ft	51	SF	\$40	\$2,020
40648	14.1 to 15.7 feet	Running Slope	7.0-8.0%	5 ft	8	REF		
56204	14.8 to 15.8 feet	Vertical Change	.4	5 ft	5	REF		
22110	18.1 to 27.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	49	SF	\$120	\$5,880
22112	28.2 to 42.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,760
22115	48.1 to 50.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560
22117	51.3 to 66.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	78	SF	\$120	\$9,300
54775	63.6 to 64.6 feet	Vertical Change	.3	5 ft	5	REF		
22121	66.8 to 95.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	141	SF	\$120	\$16,920
22123	109.3 to 114.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,180
22125	115.0 to 121.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	34	SF	\$120	\$4,080
22127	122.3 to 130.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800
56205	122.6 to 123.6 feet	Vertical Change	.4	5 ft	5	REF		
22128	133.2 to 140.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,560
57029	144.8 to 145.8 feet	Vertical Change	.6	5 ft	5	SF	\$75	\$375
22130	148.6 to 149.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$660
TOTAL COST FOR: SE side of HUMBOLDT AVE Starting at: 309 HUMBOLDT AVE							\$62,095.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	1909251217	HUMBOLDT AVE	3RD ST	2ND ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
22064	0.0 to 4.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160	
59260	28.6 to 46.7 feet	Driveway				REF			
40643	30.0 to 32.2 feet	Running Slope	6.0-7.0%	5 ft	10	REF			
22065	36.0 to 42.9 feet	Cross Slope (Driveway)	13.014	5 ft	31	SF	\$40	\$1,242	
40644	45.2 to 46.4 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
54767	48.1 to 49.1 feet	Vertical Change	.3	5 ft	5	REF			
22067	48.9 to 63.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	64	SF	\$120	\$7,668	
22071	63.1 to 72.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	41	SF	\$120	\$4,968	
54768	68.7 to 69.7 feet	Vertical Change	.3	5 ft	5	REF			
56199	72.5 to 76.4 feet	Vertical Change	.4	5 ft	18	REF			
22073	72.8 to 74.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$756	
54769	81.5 to 82.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338	
22074	82.6 to 89.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,564	
59261	83.6 to 98.2 feet	Driveway				REF			
57384	95.0 to 96.0 feet	Vertical Change	1.1	5 ft	5	REF			
22077	99.6 to 103.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	19	SF	\$120	\$2,268	
59262	102.3 to 118.5 feet	Driveway				REF			
22078	107.4 to 114.6 feet	Cross Slope (Driveway)	>15%	5 ft	32	SF	\$40	\$1,296	
40645	115.4 to 117.0 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
40646	117.0 to 118.1 feet	Running Slope	6.0-7.0%	5 ft	5	REF			
22080	119.4 to 135.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	73	SF	\$120	\$8,748	
22082	138.3 to 152.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	63	SF	\$120	\$7,506	
54770	144.0 to 145.0 feet	Vertical Change	.3	5 ft	5	REF			
59263	149.8 to 167.7 feet	Driveway				REF			
54771	151.0 to 152.0 feet	Vertical Change	.3	5 ft	5	REF			
22086	156.9 to 162.8 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	27	SF	\$40	\$1,062	
22088	162.8 to 164.5 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	8	SF	\$40	\$306	
22089	168.3 to 182.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	65	SF	\$40	\$2,610	
56201	173.1 to 174.1 feet	Vertical Change	.4	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251217	HUMBOLDT AVE	3RD ST	2ND ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54772	179.4 to 180.4 feet	Vertical Change	.3	5 ft	5	REF		
22090	182.8 to 204.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	99	SF	\$120	\$11,880
56202	194.9 to 195.9 feet	Vertical Change	.4	5 ft	5	REF		
54773	200.0 to 201.0 feet	Vertical Change	.3	5 ft	5	REF		
59264	204.8 to 226.4 feet	Driveway				REF		
22094	209.1 to 223.9 feet	Cross Slope (Driveway)	>15%	5 ft	67	SF	\$40	\$2,664
57592	221.3 to 222.3 feet	Vertical Change	2.9	5 ft	5	REF		
22095	228.2 to 231.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	14	SF	\$120	\$1,620
22096	233.4 to 253.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	92	SF	\$120	\$11,070
54774	254.5 to 255.5 feet	Vertical Change	.3	5 ft	5	REF		
22097	254.5 to 256.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,242
59265	256.4 to 270.1 feet	Driveway				REF		
22098	260.8 to 267.5 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	30	SF	\$40	\$1,206
40647	268.0 to 269.7 feet	Running Slope	5.0-6.0%	5 ft	8	REF		
56203	272.0 to 273.0 feet	Vertical Change	.4	5 ft	5	REF		
22101	272.6 to 284.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	54	SF	\$120	\$6,534
22105	285.2 to 312.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	124	SF	\$120	\$14,904
TOTAL COST FOR: SE side of HUMBOLDT AVE Starting at: 3RD ST								\$95,611.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251221	HUMBOLDT AVE	113 HUMBOLDT AVE	105 HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
22035	0.9 to 10.1 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	37	SF	\$120	\$4,416
22037	11.1 to 23.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	51	SF	\$120	\$6,096
54763	17.9 to 18.9 feet	Vertical Change	.3	4 ft	4	REF		
22042	24.6 to 31.4 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	27	SF	\$120	\$3,264
22045	31.4 to 40.3 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	36	SF	\$120	\$4,272
22048	43.7 to 45.2 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	6	SF	\$120	\$720
22049	45.8 to 49.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	13	SF	\$120	\$1,536
22050	55.5 to 68.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	52	SF	\$120	\$6,192
59258	67.7 to 85.0 feet	Driveway				REF		
40642	68.9 to 71.7 feet	Running Slope	5.0-6.0%	4 ft	11	REF		
56198	69.0 to 70.0 feet	Vertical Change	.4	4 ft	4	REF		
22053	72.4 to 82.8 feet	Cross Slope (Driveway)	>15%	4 ft	42	SF	\$40	\$1,664
22054	86.3 to 88.8 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	10	SF	\$120	\$1,200
22055	91.0 to 102.5 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	46	SF	\$120	\$5,520
54764	97.1 to 98.1 feet	Vertical Change	.3	4 ft	4	REF		
56721	103.1 to 104.1 feet	Vertical Change	.5	4 ft	4	SF	\$75	\$300
22058	105.7 to 109.0 feet	Cross Slope (PAR)	11.0-12.0%	4 ft	13	SF	\$120	\$1,584
22060	109.0 to 113.1 feet	Cross Slope (PAR)	9.0-10.0%	4 ft	16	SF	\$120	\$1,968
54765	111.3 to 112.3 feet	Vertical Change	.3	4 ft	4	REF		
22061	113.9 to 116.2 feet	Cross Slope (PAR)	7.0-8.0%	4 ft	9	SF	\$120	\$1,104
54766	114.5 to 115.5 feet	Vertical Change	.3	4 ft	4	REF		
22062	118.1 to 122.4 feet	Cross Slope (PAR)	10.0-11.0%	4 ft	17	SF	\$120	\$2,064
59259	122.4 to 135.2 feet	Driveway				REF		
TOTAL COST FOR: SE							<i>side of HUMBOLDT AVE Starting at: 113 HUMBOLDT AVE</i>	\$41,900.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	1909251225	HUMBOLDT AVE	27 HUMBOLDT AVE	23 HUMBOLDT AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
22018	0.0 to 13.6 feet	Cross Slope (PAR)	7.0-8.0%	4 ft	58	SF	\$120	\$6,936	
22021	13.8 to 31.8 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	77	SF	\$120	\$9,180	
40638	31.8 to 32.9 feet	Running Slope	5.0-6.0%	4 ft	5	REF			
59256	32.3 to 48.4 feet	Driveway				REF			
40639	32.9 to 34.2 feet	Running Slope	6.0-7.0%	4 ft	6	REF			
22024	35.8 to 44.4 feet	Cross Slope (Driveway)	>15%	4 ft	37	SF	\$40	\$1,462	
40640	45.3 to 46.7 feet	Running Slope	5.0-6.0%	4 ft	6	REF			
40641	46.7 to 47.7 feet	Running Slope	6.0-7.0%	4 ft	4	REF			
57257	48.3 to 49.3 feet	Vertical Change	.8	4 ft	4	REF			
22025	48.8 to 84.2 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	150	SF	\$120	\$18,054	
54762	61.5 to 62.5 feet	Vertical Change	.3	4 ft	4	REF			
59257	82.6 to 96.0 feet	Driveway				REF			
22032	88.1 to 90.8 feet	Cross Slope (Driveway)	13.014	4 ft	11	SF	\$40	\$459	
22034	90.8 to 93.5 feet	Cross Slope (Driveway)	>15%	4 ft	11	SF	\$40	\$459	
TOTAL COST FOR: SE							side of HUMBOLDT AVE	Starting at: 27 HUMBOLDT AVE	\$36,550.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909251331	ALAMEDA AVE	2ND ST	212 ALAMEDA AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
21990	0.0 to 19.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	87	SF	\$120	\$10,422	
54755	17.3 to 18.3 feet	Vertical Change	.3	5 ft	5	REF			
21996	20.7 to 28.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,050	
54756	27.5 to 28.5 feet	Vertical Change	.3	5 ft	5	REF			
59252	27.7 to 53.3 feet	Driveway				REF			
40635	29.3 to 31.7 feet	Running Slope	5.0-6.0%	5 ft	11	REF			
21997	32.0 to 50.1 feet	Cross Slope (Driveway)	>15%	5 ft	81	SF	\$40	\$3,258	
21998	54.3 to 57.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,890	
54757	55.8 to 56.8 feet	Vertical Change	.3	5 ft	5	REF			
59253	57.7 to 80.4 feet	Driveway				REF			
21999	62.4 to 77.8 feet	Cross Slope (Driveway)	>15%	5 ft	69	SF	\$40	\$2,772	
22001	81.5 to 113.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	145	SF	\$120	\$17,442	
56720	98.9 to 99.9 feet	Vertical Change	.5	5 ft	5	REF			
54758	107.4 to 108.4 feet	Vertical Change	.3	5 ft	5	REF			
22009	114.5 to 116.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,026	
59254	116.1 to 137.4 feet	Driveway				REF			
22010	121.0 to 127.7 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	30	SF	\$40	\$1,206	
22012	130.8 to 135.3 feet	Cross Slope (Driveway)	13.014	5 ft	20	SF	\$40	\$810	
40637	135.4 to 136.4 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
22013	138.6 to 144.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,348	
22015	147.1 to 149.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	12	SF	\$120	\$1,458	
22016	150.0 to 157.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,888	
59255	157.2 to 171.3 feet	Driveway				REF			
54759	157.7 to 158.7 feet	Vertical Change	.3	5 ft	5	REF			
57183	159.4 to 160.4 feet	Vertical Change	.7	5 ft	5	REF			
54760	169.2 to 172.1 feet	Vertical Change	.3	5 ft	13	REF			
TOTAL COST FOR: NW side of ALAMEDA AVE Starting at: 2ND ST								\$51,570.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251333	ALAMEDA AVE	SIDEWALK BEGINS	3RD ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21984	0.0 to 11.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,660
54754	1.6 to 2.6 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: NW								\$6,660.00
<i>side of ALAMEDA AVE Starting at: SIDEWALK BEGINS</i>								

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251337	ALAMEDA AVE	408 ALAMEDA AVE	408 ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21980	0.0 to 3.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	16	SF	\$120	\$1,944
21981	3.6 to 5.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
54752	4.0 to 5.0 feet	Vertical Change	.3	5 ft	5	REF		
59251	4.4 to 25.8 feet	Driveway				REF		
40633	7.0 to 8.3 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
21982	10.1 to 21.2 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	50	SF	\$40	\$1,998
40634	22.9 to 24.0 feet	Running Slope	7.0-8.0%	5 ft	5	REF		
54753	25.6 to 26.6 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: NW side of ALAMEDA AVE Starting at: 408 ALAMEDA AVE							\$5,022.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251339	ALAMEDA AVE	416 ALAMEDA AVE	5TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21963	0.0 to 34.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	154	SF	\$120	\$18,468
54750	23.2 to 24.2 feet	Vertical Change	.3	5 ft	5	REF		
21968	36.2 to 51.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	69	SF	\$120	\$8,262
21971	54.9 to 65.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	46	SF	\$120	\$5,508
21974	65.1 to 68.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	14	SF	\$120	\$1,728
21976	68.3 to 79.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	51	SF	\$120	\$6,102
54751	80.8 to 81.8 feet	Vertical Change	.3	5 ft	5	REF		
21979	81.3 to 85.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	18	SF	\$120	\$2,160
TOTAL COST FOR: NW side of ALAMEDA AVE Starting at: 416 ALAMEDA AVE							\$42,228.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909251343	ALAMEDA AVE	5TH ST	6TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
21927	0.0 to 5.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	27	SF	\$120	\$3,240	
54745	4.2 to 5.2 feet	Vertical Change	.3	5 ft	5	REF			
21929	5.4 to 56.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	255	SF	\$120	\$30,600	
56197	15.0 to 16.0 feet	Vertical Change	.4	5 ft	5	REF			
59248	40.6 to 69.3 feet	Driveway				REF			
21937	60.6 to 63.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	12	SF	\$40	\$480	
21938	77.8 to 100.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	113	SF	\$120	\$13,560	
56717	99.8 to 100.8 feet	Vertical Change	.5	5 ft	5	REF			
54746	104.9 to 105.9 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
59249	107.0 to 118.2 feet	Driveway				REF			
21943	107.4 to 111.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	20	SF	\$40	\$780	
21944	114.7 to 116.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$300	
57624	122.7 to 123.7 feet	Vertical Change	3.2	5 ft	5	SF	\$75	\$375	
56718	125.7 to 126.7 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375	
54747	141.6 to 142.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
59250	142.4 to 162.2 feet	Driveway				REF			
21945	145.1 to 171.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	132	SF	\$40	\$5,260	
56719	163.2 to 164.2 feet	Vertical Change	.5	5 ft	5	REF			
54748	180.0 to 181.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
21949	189.4 to 216.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	134	SF	\$120	\$16,080	
54749	195.4 to 196.4 feet	Vertical Change	.3	5 ft	5	REF			
21954	219.9 to 229.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,520	
21955	243.3 to 247.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760	
21956	252.0 to 285.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	169	SF	\$120	\$20,280	
TOTAL COST FOR: NW							<i>side of ALAMEDA AVE Starting at: 5TH ST</i>	\$100,735.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251347	ALAMEDA AVE	6TH ST	7TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21893	0.6 to 6.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,720
21894	9.2 to 44.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	178	SF	\$120	\$21,360
56194	15.7 to 16.7 feet	Vertical Change	.4	5 ft	5	REF		
21904	50.9 to 53.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320
21905	59.5 to 63.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,280
56716	62.5 to 63.5 feet	Vertical Change	.5	5 ft	5	REF		
56195	66.4 to 69.1 feet	Vertical Change	.4	5 ft	13	LF	\$75	\$1,013
21906	83.4 to 87.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340
21907	111.7 to 113.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
21908	119.8 to 120.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660
54742	159.6 to 160.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
21909	160.9 to 182.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	109	SF	\$120	\$13,020
21912	188.3 to 213.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	127	SF	\$120	\$15,180
54743	195.4 to 196.4 feet	Vertical Change	.3	5 ft	5	REF		
54744	203.0 to 204.0 feet	Vertical Change	.3	5 ft	5	REF		
21918	223.4 to 229.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,540
59246	230.5 to 241.2 feet	Driveway				REF		
21920	231.8 to 240.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	46	SF	\$40	\$1,820
59247	248.9 to 261.1 feet	Driveway				REF		
21922	261.5 to 262.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720
21923	267.8 to 277.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,700
21926	283.1 to 288.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,420
40631	286.8 to 288.8 feet	Running Slope	6.0-7.0%	5 ft	10	REF		
TOTAL COST FOR: NW side of ALAMEDA AVE Starting at: 6TH ST							\$77,547.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251350	ALAMEDA AVE	7TH ST	8TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21845	0.0 to 33.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	151	SF	\$120	\$18,090
56193	20.8 to 21.8 feet	Vertical Change	.4	5 ft	5	REF		
21849	38.6 to 51.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,128
21850	53.9 to 64.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$5,940
59244	63.9 to 95.5 feet	Driveway				REF		
21854	64.9 to 69.7 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	22	SF	\$40	\$864
54741	65.4 to 66.4 feet	Vertical Change	.3	5 ft	5	REF		
21856	69.7 to 72.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	12	SF	\$40	\$486
21858	73.8 to 95.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	97	SF	\$40	\$3,888
21862	95.8 to 109.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	63	SF	\$40	\$2,520
21867	110.0 to 112.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	11	SF	\$120	\$1,350
59245	113.6 to 131.2 feet	Driveway				REF		
21869	118.4 to 128.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	45	SF	\$40	\$1,782
21872	132.3 to 230.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	441	SF	\$120	\$52,974
21887	236.1 to 290.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	244	SF	\$120	\$29,322
40630	286.7 to 289.8 feet	Running Slope	5.0-6.0%	5 ft	14	REF		
TOTAL COST FOR: NW side of ALAMEDA AVE Starting at: 7TH ST							\$124,344.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251353	ALAMEDA AVE	717 ALAMEDA AVE	709 ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21831	0.3 to 3.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	16	SF	\$120	\$1,944
21833	5.2 to 9.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	18	SF	\$120	\$2,106
21834	9.1 to 12.5 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	15	SF	\$120	\$1,836
21835	12.5 to 28.7 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	73	SF	\$120	\$8,748
21837	31.9 to 63.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	144	SF	\$120	\$17,226
59242	62.8 to 77.0 feet	Driveway				REF		
21842	67.1 to 74.9 feet	Cross Slope (Driveway)	>15%	5 ft	35	SF	\$40	\$1,404
40629	74.0 to 76.6 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
21843	78.0 to 80.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	10	SF	\$120	\$1,242
59243	80.4 to 99.0 feet	Driveway				REF		
TOTAL COST FOR: SE side of ALAMEDA AVE Starting at: 717 ALAMEDA AVE							\$34,506.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251356	ALAMEDA AVE	705 ALAMEDA AVE	701 ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21821	2.3 to 26.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	110	SF	\$120	\$13,176
77	2.7 to 3.7 feet	Continuous Width		5 ft	5	SF	\$120	\$540
54738	4.5 to 8.1 feet	Vertical Change	.3	5 ft	16	REF		
54740	19.7 to 20.7 feet	Vertical Change	.3	5 ft	5	REF		
21826	28.8 to 29.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$540
59240	29.8 to 45.8 feet	Driveway				REF		
56192	29.9 to 30.9 feet	Vertical Change	.4	5 ft	5	REF		
40627	32.6 to 33.6 feet	Running Slope	7.0-8.0%	5 ft	5	REF		
21827	34.1 to 43.8 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	44	SF	\$40	\$1,746
40628	43.7 to 45.3 feet	Running Slope	7.0-8.0%	5 ft	7	REF		
59241	47.9 to 62.3 feet	Driveway				REF		
57182	61.7 to 62.7 feet	Vertical Change	.7	5 ft	5	REF		
TOTAL COST FOR: SE side of ALAMEDA AVE Starting at: 705 ALAMEDA AVE							\$16,002.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251359	ALAMEDA AVE	7TH ST	609 ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21803	0.0 to 6.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	34	SF	\$120	\$4,080
21804	6.8 to 10.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040
56188	12.5 to 13.5 feet	Vertical Change	.4	5 ft	5	REF		
21805	12.7 to 92.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	401	SF	\$120	\$48,060
59236	53.1 to 65.3 feet	Driveway				REF		
54734	69.0 to 70.0 feet	Vertical Change	.3	5 ft	5	REF		
54735	85.2 to 86.2 feet	Vertical Change	.3	5 ft	5	REF		
59237	89.6 to 97.5 feet	Driveway				REF		
56189	90.3 to 96.4 feet	Vertical Change	.4	5 ft	31	REF		
21817	96.3 to 97.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	8	SF	\$120	\$900
59238	97.8 to 108.9 feet	Driveway				REF		
54737	103.0 to 104.0 feet	Vertical Change	.3	5 ft	5	REF		
21818	109.6 to 112.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,920
59239	147.3 to 157.2 feet	Driveway				REF		
21819	170.8 to 175.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000
21820	179.8 to 181.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960
TOTAL COST FOR: SE side of ALAMEDA AVE Starting at: 7TH ST							\$60,960.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251402	ALAMEDA AVE	517 ALAMEDA AVE	517 ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21797	1.1 to 29.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	126	SF	\$120	\$15,066
TOTAL COST FOR: SE side of ALAMEDA AVE Starting at: 517 ALAMEDA AVE							\$15,066.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251405	ALAMEDA AVE	5TH ST	417 ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21778	2.5 to 22.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	98	SF	\$120	\$11,700
54732	11.1 to 12.1 feet	Vertical Change	.3	5 ft	5	REF		
59234	20.3 to 43.3 feet	Driveway				REF		
21784	26.0 to 40.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	74	SF	\$40	\$2,960
40625	40.3 to 43.2 feet	Running Slope	5.0-6.0%	5 ft	15	REF		
21788	45.1 to 46.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$660
21789	47.7 to 72.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	122	SF	\$120	\$14,640
21793	72.7 to 79.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	33	SF	\$120	\$3,960
59235	79.3 to 93.7 feet	Driveway				REF		
54733	80.2 to 81.2 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: SE							<i>side of ALAMEDA AVE Starting at: 5TH ST</i>	\$33,920.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251408	ALAMEDA AVE	405 ALAMEDA AVE	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21772	0.0 to 16.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	81	SF	\$120	\$9,720
56715	6.4 to 7.4 feet	Vertical Change	.5	5 ft	5	REF		
21776	18.8 to 25.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,960
21777	35.3 to 54.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	96	SF	\$120	\$11,460
TOTAL COST FOR: SE side of ALAMEDA AVE Starting at: 405 ALAMEDA AVE							\$25,140.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251413	ALAMEDA AVE	4TH ST	301 ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21725	0.0 to 7.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	38	SF	\$120	\$4,500
21726	7.5 to 34.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	136	SF	\$120	\$16,260
54728	10.5 to 11.5 feet	Vertical Change	.3	5 ft	5	REF		
57656	22.5 to 23.5 feet	Vertical Change	3.5	5 ft	5	REF		
21732	34.8 to 38.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	17	SF	\$120	\$2,040
21733	42.6 to 62.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	99	SF	\$120	\$11,880
56713	51.8 to 52.8 feet	Vertical Change	.5	5 ft	5	REF		
21740	63.0 to 86.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	118	SF	\$120	\$14,100
59230	86.0 to 103.1 feet	Driveway				REF		
40619	86.8 to 89.3 feet	Running Slope	6.0-7.0%	5 ft	13	REF		
54729	86.9 to 87.9 feet	Vertical Change	.3	5 ft	5	REF		
21744	90.0 to 100.8 feet	Cross Slope (Driveway)	>15%	5 ft	54	SF	\$40	\$2,160
40621	100.3 to 101.7 feet	Running Slope	6.0-7.0%	5 ft	7	REF		
54730	101.4 to 102.4 feet	Vertical Change	.3	5 ft	5	REF		
21745	104.2 to 109.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	26	SF	\$120	\$3,120
21747	109.4 to 112.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	15	SF	\$120	\$1,740
59231	111.0 to 135.2 feet	Driveway				REF		
40622	113.8 to 114.8 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
21748	115.9 to 131.4 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	78	SF	\$40	\$3,100
40623	133.8 to 134.9 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
21751	136.2 to 141.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	25	SF	\$120	\$2,940
21752	143.3 to 146.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	15	SF	\$120	\$1,800
21753	146.3 to 157.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,600
54731	154.8 to 155.8 feet	Vertical Change	.3	5 ft	5	REF		
21756	161.4 to 175.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	72	SF	\$120	\$8,580
59232	175.4 to 198.8 feet	Driveway				REF		
21757	181.3 to 184.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	15	SF	\$40	\$580
21759	184.2 to 187.4 feet	Cross Slope (Driveway)	13.014	5 ft	16	SF	\$40	\$640

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251413	ALAMEDA AVE	4TH ST	301 ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21761	187.8 to 192.4 feet	Cross Slope (Driveway)	>15%	5 ft	23	SF	\$40	\$920
21762	193.3 to 194.4 feet	Cross Slope (Driveway)	13.014	5 ft	6	SF	\$40	\$220
21763	199.2 to 207.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	41	SF	\$40	\$1,620
21765	207.7 to 210.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860
59233	209.9 to 236.2 feet	Driveway				REF		
21766	214.2 to 233.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	97	SF	\$40	\$3,880
56714	229.6 to 230.6 feet	Vertical Change	.5	5 ft	5	REF		
40624	232.9 to 234.6 feet	Running Slope	5.0-6.0%	5 ft	9	REF		
TOTAL COST FOR: SE side of ALAMEDA AVE Starting at: 4TH ST							\$88,540.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251414	ALAMEDA AVE	301 ALAMEDA AVE	3RD ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21717	0.0 to 1.6 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	8	SF	\$120	\$960
21718	2.5 to 18.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	79	SF	\$120	\$9,480
21724	18.5 to 23.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	25	SF	\$120	\$2,940
TOTAL COST FOR: SE side of ALAMEDA AVE Starting at: 301 ALAMEDA AVE							\$13,380.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251416	ALAMEDA AVE	3RD ST	221 ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21710	0.0 to 14.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	74	SF	\$120	\$8,880
54726	5.4 to 6.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
59229	13.3 to 39.7 feet	Driveway				REF		
21712	18.3 to 29.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	55	SF	\$40	\$2,200
21714	29.3 to 35.8 feet	Cross Slope (Driveway)	13.014	5 ft	32	SF	\$40	\$1,300
40618	36.7 to 39.4 feet	Running Slope	5.0-6.0%	5 ft	13	REF		
54727	38.3 to 39.3 feet	Vertical Change	.3	5 ft	5	REF		
21715	39.8 to 45.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	28	SF	\$40	\$1,120
TOTAL COST FOR: SE side of ALAMEDA AVE Starting at: 3RD ST							\$13,875.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251419	ALAMEDA AVE	213 ALAMEDA AVE	201 ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21682	0.0 to 6.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,294
56185	5.8 to 6.8 feet	Vertical Change	.4	5 ft	5	REF		
21684	6.1 to 27.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	96	SF	\$120	\$11,556
54725	10.3 to 11.3 feet	Vertical Change	.3	5 ft	5	REF		
59226	26.3 to 42.5 feet	Driveway				REF		
56186	27.3 to 28.3 feet	Vertical Change	.4	5 ft	5	REF		
40611	28.3 to 29.8 feet	Running Slope	7.0-8.0%	5 ft	7	REF		
21688	30.9 to 33.3 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	11	SF	\$40	\$432
21689	37.8 to 39.2 feet	Cross Slope (Driveway)	13.014	5 ft	6	SF	\$40	\$252
40612	39.8 to 41.3 feet	Running Slope	5.0-6.0%	5 ft	7	REF		
40613	41.3 to 42.6 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
21690	43.6 to 46.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	14	SF	\$120	\$1,728
21692	46.8 to 58.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,210
21695	60.5 to 82.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	98	SF	\$120	\$11,772
59227	84.2 to 97.7 feet	Driveway				REF		
21700	88.4 to 95.4 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	32	SF	\$40	\$1,260
40614	95.3 to 96.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
40615	96.3 to 97.8 feet	Running Slope	6.0-7.0%	5 ft	7	REF		
21702	99.0 to 118.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	86	SF	\$120	\$10,368
21704	118.5 to 134.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	70	SF	\$120	\$8,424
56187	129.4 to 130.4 feet	Vertical Change	.4	5 ft	5	REF		
59228	134.1 to 147.5 feet	Driveway				REF		
40616	135.1 to 137.1 feet	Running Slope	6.0-7.0%	5 ft	9	REF		
21707	138.3 to 143.2 feet	Cross Slope (Driveway)	13.014	5 ft	22	SF	\$40	\$882
21709	143.4 to 144.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	5	SF	\$40	\$180
40617	146.4 to 147.4 feet	Running Slope	6.0-7.0%	5 ft	5	REF		
TOTAL COST FOR: SE side of ALAMEDA AVE Starting at: 213 ALAMEDA AVE							\$56,358.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251422	ALAMEDA AVE	121 ALAMEDA AVE	115 ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21666	0.0 to 24.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	110	SF	\$120	\$13,176
21671	24.4 to 55.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	139	SF	\$120	\$16,686
21680	55.6 to 57.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$810
21681	60.8 to 62.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$864
TOTAL COST FOR: SE side of ALAMEDA AVE Starting at: 121 ALAMEDA AVE							\$31,536.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1909251424	ALAMEDA AVE	109 ALAMEDA AVE	1ST ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
21644	0.7 to 14.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,560	
21648	18.5 to 20.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$972	
21649	24.4 to 25.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$702	
57181	27.2 to 28.2 feet	Vertical Change	.7	5 ft	5	SF	\$75	\$338	
21650	45.8 to 68.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	104	SF	\$120	\$12,474	
21654	75.8 to 85.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,292	
54723	85.2 to 86.2 feet	Vertical Change	.3	5 ft	5	REF			
21658	87.8 to 93.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,132	
59225	92.8 to 109.8 feet	Driveway				REF			
40609	96.3 to 97.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
21660	97.8 to 106.8 feet	Cross Slope (Driveway)	13.014	5 ft	41	SF	\$40	\$1,620	
40610	107.4 to 108.8 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
21662	110.3 to 112.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$324	
54724	124.5 to 125.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338	
21663	126.1 to 127.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$972	
21664	131.3 to 139.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,536	
TOTAL COST FOR: SE							side of ALAMEDA AVE	Starting at: 109 ALAMEDA AVE	\$38,259.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SW	1909251430	1ST ST	ALAMEDA AVE	540 1ST ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
21600	6.6 to 29.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	101	SF	\$120	\$12,096	
21603	32.1 to 80.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	217	SF	\$120	\$26,082	
56710	54.5 to 55.5 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$338	
56181	83.2 to 84.2 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338	
54721	88.6 to 89.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338	
59222	88.6 to 115.2 feet	Driveway				REF			
21616	91.8 to 105.3 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	61	SF	\$40	\$2,430	
21622	105.3 to 112.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	31	SF	\$40	\$1,242	
40604	113.2 to 115.3 feet	Running Slope	8.0-9.0%	5 ft	9	REF			
21625	115.3 to 116.4 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	5	SF	\$40	\$198	
21626	116.4 to 127.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,210	
76	122.4 to 123.4 feet	Continuous Width		5 ft	5	SF	\$120	\$540	
21629	130.2 to 131.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$594	
21630	134.3 to 137.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	16	SF	\$120	\$1,890	
21631	137.8 to 140.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,674	
59223	150.6 to 171.4 feet	Driveway				REF			
40605	152.9 to 154.5 feet	Running Slope	9.0-10.0%	5 ft	7	REF			
21633	156.1 to 165.7 feet	Cross Slope (Driveway)	>15%	5 ft	43	SF	\$40	\$1,728	
21635	165.7 to 167.1 feet	Cross Slope (Driveway)	13.014	5 ft	6	SF	\$40	\$252	
54722	166.9 to 170.9 feet	Vertical Change	.3	5 ft	18	REF			
40606	170.1 to 171.1 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
59224	186.5 to 206.2 feet	Driveway				REF			
56182	187.3 to 188.3 feet	Vertical Change	.4	5 ft	5	REF			
40607	188.6 to 190.3 feet	Running Slope	7.0-8.0%	5 ft	8	REF			
21636	190.9 to 196.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	27	SF	\$40	\$1,062	
56712	193.4 to 194.4 feet	Vertical Change	.5	5 ft	5	REF			
21637	199.3 to 203.3 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	18	SF	\$40	\$720	
56183	201.9 to 205.6 feet	Vertical Change	.4	5 ft	17	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909251430	1ST ST	ALAMEDA AVE	540 1ST ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40608	204.2 to 205.2 feet	Running Slope	7.0-8.0%	5 ft	5	REF		
21639	233.0 to 237.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160
21640	239.5 to 253.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,776
56184	241.9 to 242.9 feet	Vertical Change	.4	5 ft	5	REF		
TOTAL COST FOR: SW side of 1ST ST Starting at: ALAMEDA AVE							\$67,666.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	1909251441	COLUSA AVE	2ND ST	208 COLUSA AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
21579	0.8 to 13.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	58	SF	\$120	\$6,912	
21581	14.7 to 60.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	205	SF	\$120	\$24,624	
59220	61.9 to 85.5 feet	Driveway				REF			
40600	63.7 to 65.3 feet	Running Slope	9.0-10.0%	5 ft	7	REF			
21587	66.7 to 82.4 feet	Cross Slope (Driveway)	>15%	5 ft	71	SF	\$40	\$2,826	
40601	83.1 to 85.2 feet	Running Slope	8.0-9.0%	5 ft	9	REF			
21588	87.3 to 103.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,802	
56180	87.9 to 88.9 feet	Vertical Change	.4	5 ft	5	REF			
21591	103.6 to 129.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	118	SF	\$120	\$14,148	
59221	129.7 to 153.9 feet	Driveway				REF			
21597	129.8 to 131.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	6	SF	\$40	\$252	
40602	131.5 to 133.7 feet	Running Slope	6.0-7.0%	5 ft	10	REF			
21598	133.8 to 152.7 feet	Cross Slope (Driveway)	>15%	5 ft	85	SF	\$40	\$3,402	
40603	150.8 to 152.0 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
21599	154.9 to 156.0 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	5	SF	\$120	\$594	
TOTAL COST FOR: NW side of COLUSA AVE Starting at: 2ND ST								\$61,560.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909251447	COLUSA AVE	3RD ST	4TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
56179	2.5 to 3.5 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338	
21527	7.3 to 8.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$810	
21528	41.9 to 44.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,134	
21529	66.2 to 102.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	162	SF	\$120	\$19,494	
21534	102.3 to 127.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	112	SF	\$120	\$13,392	
59218	102.4 to 138.8 feet	Driveway				REF			
40596	105.3 to 106.4 feet	Running Slope	9.0-10.0%	5 ft	5	REF			
21543	127.1 to 134.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	35	SF	\$40	\$1,404	
40597	136.7 to 138.2 feet	Running Slope	10.0-11.0%	5 ft	7	REF			
59219	140.3 to 183.6 feet	Driveway				REF			
40598	141.6 to 142.9 feet	Running Slope	7.0-8.0%	5 ft	6	REF			
21546	144.8 to 180.4 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	160	SF	\$40	\$6,408	
57568	175.0 to 176.0 feet	Vertical Change	2.6	5 ft	5	REF			
40599	181.0 to 183.3 feet	Running Slope	9.0-10.0%	5 ft	10	REF			
54720	182.9 to 183.9 feet	Vertical Change	.3	5 ft	5	REF			
21555	184.8 to 205.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	93	SF	\$120	\$11,124	
21557	210.3 to 265.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	248	SF	\$120	\$29,700	
21566	265.8 to 278.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	59	SF	\$120	\$7,020	
21570	279.0 to 286.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,158	
21572	287.1 to 312.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	115	SF	\$120	\$13,824	
75	303.0 to 304.0 feet	Continuous Width		5 ft	5	SF	\$120	\$540	
TOTAL COST FOR: NW							<i>side of COLUSA AVE Starting at: 3RD ST</i>	\$109,345.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	1909251451	COLUSA AVE	4TH ST	5TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
21468	2.3 to 5.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,782	
21470	9.1 to 20.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,210	
57180	30.1 to 31.1 feet	Vertical Change	.7	5 ft	5	SF	\$75	\$338	
21472	31.4 to 37.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,456	
21474	42.7 to 57.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	64	SF	\$120	\$7,722	
21476	67.8 to 81.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,614	
59215	80.8 to 100.8 feet	Driveway				REF			
21479	86.7 to 93.7 feet	Cross Slope (Driveway)	>15%	5 ft	32	SF	\$40	\$1,260	
21480	96.5 to 97.9 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	6	SF	\$40	\$252	
40595	98.4 to 99.9 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
21481	102.1 to 137.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	158	SF	\$120	\$19,008	
57575	110.4 to 111.4 feet	Vertical Change	2.7	5 ft	5	SF	\$75	\$338	
54718	135.3 to 136.3 feet	Vertical Change	.3	5 ft	5	REF			
59216	137.8 to 167.4 feet	Driveway				REF			
21488	142.8 to 164.8 feet	Cross Slope (Driveway)	13.014	5 ft	99	SF	\$40	\$3,960	
54719	168.6 to 169.6 feet	Vertical Change	.3	5 ft	5	REF			
21495	168.6 to 169.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$648	
21496	172.0 to 180.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,752	
21499	183.6 to 189.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,240	
21501	201.0 to 252.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	233	SF	\$120	\$27,972	
59217	203.2 to 216.0 feet	Driveway				REF			
57623	255.7 to 256.7 feet	Vertical Change	3.2	5 ft	5	SF	\$75	\$338	
21514	259.2 to 272.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,236	
21518	273.4 to 277.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	20	SF	\$120	\$2,430	
21520	278.3 to 295.9 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	79	SF	\$120	\$9,504	
21524	295.9 to 301.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	27	SF	\$120	\$3,186	
21526	302.4 to 303.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$648	
TOTAL COST FOR: NW side of COLUSA AVE Starting at: 4TH ST								\$111,892.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251458	COLUSA AVE	SIDEWALK BEGINS	7TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21437	2.0 to 5.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	14	SF	\$120	\$1,674
21439	10.4 to 23.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,966
21441	25.8 to 31.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	24	SF	\$120	\$2,916
21443	34.1 to 46.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	54	SF	\$120	\$6,480
21445	46.1 to 59.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,236
59212	58.3 to 76.2 feet	Driveway				REF		
21452	63.0 to 73.2 feet	Cross Slope (Driveway)	>15%	5 ft	46	SF	\$40	\$1,836
40591	74.4 to 75.8 feet	Running Slope	7.0-8.0%	5 ft	6	REF		
21453	83.7 to 101.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	80	SF	\$120	\$9,558
21458	106.1 to 111.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,754
59213	110.9 to 127.4 feet	Driveway				REF		
54715	111.4 to 112.4 feet	Vertical Change	.3	5 ft	5	REF		
40592	112.6 to 114.3 feet	Running Slope	9.0-10.0%	5 ft	8	REF		
21459	114.9 to 125.0 feet	Cross Slope (Driveway)	>15%	5 ft	45	SF	\$40	\$1,818
40593	124.9 to 126.6 feet	Running Slope	8.0-9.0%	5 ft	8	REF		
54716	127.8 to 128.8 feet	Vertical Change	.3	5 ft	5	REF		
21460	128.2 to 129.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	5	SF	\$120	\$540
59214	129.1 to 145.7 feet	Driveway				REF		
21461	133.4 to 141.8 feet	Cross Slope (Driveway)	>15%	5 ft	38	SF	\$40	\$1,512
40594	143.1 to 145.0 feet	Running Slope	8.0-9.0%	5 ft	9	REF		
54717	153.8 to 154.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
21463	164.2 to 180.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	75	SF	\$120	\$9,018
74	179.8 to 180.8 feet	Continuous Width		5 ft	5	SF	\$120	\$540
TOTAL COST FOR: NW side of COLUSA AVE Starting at: SIDEWALK BEGINS							\$53,185.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	1909251501	COLUSA AVE	7TH ST	8TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
21390	0.9 to 24.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	105	SF	\$120	\$12,636	
21394	26.7 to 30.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,944	
56178	32.3 to 33.3 feet	Vertical Change	.4	5 ft	5	REF			
21395	32.4 to 47.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	66	SF	\$120	\$7,938	
21396	51.2 to 81.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	134	SF	\$120	\$16,092	
59207	80.3 to 97.2 feet	Driveway				REF			
40583	81.3 to 83.4 feet	Running Slope	7.0-8.0%	5 ft	9	REF			
54712	82.2 to 83.2 feet	Vertical Change	.3	5 ft	5	REF			
21402	85.1 to 90.4 feet	Cross Slope (Driveway)	>15%	5 ft	24	SF	\$40	\$954	
21404	90.8 to 91.8 feet	Cross Slope (Driveway)	13.014	5 ft	5	SF	\$40	\$180	
40584	94.3 to 95.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
40585	95.3 to 96.6 feet	Running Slope	6.0-7.0%	5 ft	6	REF			
21405	98.7 to 101.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,674	
21406	105.5 to 107.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,188	
21407	110.5 to 123.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,804	
21409	130.2 to 131.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$864	
59208	132.2 to 148.5 feet	Driveway				REF			
40586	133.9 to 135.5 feet	Running Slope	7.0-8.0%	5 ft	7	REF			
21410	136.5 to 145.2 feet	Cross Slope (Driveway)	>15%	5 ft	39	SF	\$40	\$1,566	
40587	145.6 to 148.2 feet	Running Slope	6.0-7.0%	5 ft	12	REF			
21412	150.5 to 153.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	13	SF	\$120	\$1,512	
21413	154.3 to 156.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	10	SF	\$120	\$1,242	
21414	157.8 to 163.6 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	26	SF	\$120	\$3,132	
21415	164.8 to 173.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	38	SF	\$120	\$4,536	
21416	173.3 to 184.1 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	49	SF	\$120	\$5,832	
21417	184.1 to 192.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	37	SF	\$120	\$4,482	
59209	191.4 to 206.3 feet	Driveway				REF			
40589	192.7 to 195.1 feet	Running Slope	7.0-8.0%	5 ft	11	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251501	COLUSA AVE	7TH ST	8TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21420	196.1 to 202.3 feet	Cross Slope (Driveway)	>15%	5 ft	28	SF	\$40	\$1,116
40590	203.7 to 204.7 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
21421	211.2 to 222.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,210
59210	221.8 to 247.2 feet	Driveway				REF		
21424	226.3 to 244.8 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	83	SF	\$40	\$3,330
21427	248.3 to 251.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,890
54713	250.6 to 251.6 feet	Vertical Change	.3	5 ft	5	REF		
21429	251.8 to 255.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	16	SF	\$120	\$1,890
21430	257.6 to 262.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	23	SF	\$120	\$2,700
54714	260.3 to 261.3 feet	Vertical Change	.3	5 ft	5	REF		
21432	262.6 to 267.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	22	SF	\$120	\$2,592
59211	265.2 to 284.7 feet	Driveway				REF		
21434	267.4 to 268.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$234
21435	284.1 to 291.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	32	SF	\$40	\$1,296
TOTAL COST FOR: NW side of COLUSA AVE Starting at: 7TH ST								\$93,834.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251505	COLUSA AVE	8TH ST	709 COLUSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21360	0.0 to 3.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	15	SF	\$120	\$1,782
21361	3.3 to 8.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,808
21363	8.5 to 49.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	185	SF	\$120	\$22,194
54705	15.7 to 16.7 feet	Vertical Change	.3	5 ft	5	REF		
54706	47.5 to 48.5 feet	Vertical Change	.3	5 ft	5	REF		
59204	49.3 to 64.3 feet	Driveway				REF		
21371	53.0 to 61.9 feet	Cross Slope (Driveway)	>15%	5 ft	40	SF	\$40	\$1,602
40578	61.8 to 63.5 feet	Running Slope	5.0-6.0%	5 ft	8	REF		
56177	62.3 to 63.3 feet	Vertical Change	.4	5 ft	5	REF		
21372	65.5 to 78.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	57	SF	\$120	\$6,858
21375	80.4 to 101.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	94	SF	\$120	\$11,286
54707	99.0 to 100.0 feet	Vertical Change	.3	5 ft	5	REF		
21377	101.3 to 104.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,458
59205	103.8 to 118.3 feet	Driveway				REF		
40579	104.8 to 106.3 feet	Running Slope	5.0-6.0%	5 ft	7	REF		
21378	108.0 to 115.1 feet	Cross Slope (Driveway)	>15%	5 ft	32	SF	\$40	\$1,278
40580	115.3 to 117.3 feet	Running Slope	6.0-7.0%	5 ft	9	REF		
21379	119.1 to 123.9 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	22	SF	\$120	\$2,592
21381	124.4 to 135.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	49	SF	\$120	\$5,886
54708	132.0 to 133.0 feet	Vertical Change	.3	5 ft	5	REF		
21383	138.3 to 155.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	78	SF	\$120	\$9,396
54709	142.0 to 143.0 feet	Vertical Change	.3	5 ft	5	REF		
59206	154.8 to 169.7 feet	Driveway				REF		
40581	157.3 to 159.1 feet	Running Slope	7.0-8.0%	5 ft	8	REF		
21386	159.4 to 166.6 feet	Cross Slope (Driveway)	>15%	5 ft	32	SF	\$40	\$1,296
40582	166.6 to 169.1 feet	Running Slope	7.0-8.0%	5 ft	11	REF		
54710	168.3 to 169.3 feet	Vertical Change	.3	5 ft	5	REF		
21387	171.0 to 200.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	132	SF	\$120	\$15,822

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251505	COLUSA AVE	8TH ST	709 COLUSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54711	189.1 to 190.1 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: SE side of COLUSA AVE Starting at: 8TH ST							\$84,258.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251507	COLUSA AVE	SIDEWALK BEGINS	7TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21355	0.0 to 43.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	194	SF	\$120	\$23,274
TOTAL COST FOR: SE side of COLUSA AVE Starting at: SIDEWALK BEGINS							\$23,274.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251510	COLUSA AVE	7TH ST	617 COLUSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21344	15.8 to 34.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	85	SF	\$120	\$10,260
56176	27.7 to 28.7 feet	Vertical Change	.4	5 ft	5	REF		
21348	44.7 to 52.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,942
59203	51.5 to 68.5 feet	Driveway				REF		
40576	52.8 to 54.2 feet	Running Slope	8.0-9.0%	5 ft	6	REF		
21349	56.3 to 65.0 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	39	SF	\$40	\$1,566
40577	66.8 to 67.9 feet	Running Slope	7.0-8.0%	5 ft	5	REF		
21352	73.7 to 95.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	99	SF	\$120	\$11,934
TOTAL COST FOR: SE side of COLUSA AVE Starting at: 7TH ST							\$27,702.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251513	COLUSA AVE	517 COLUSA AVE	513 COLUSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
54700	0.4 to 1.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
21331	5.3 to 8.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,566
54701	10.4 to 11.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
21332	12.6 to 20.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,374
59201	20.3 to 45.3 feet	Driveway				REF		
40573	21.6 to 24.3 feet	Running Slope	6.0-7.0%	5 ft	12	REF		
21333	24.9 to 42.4 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	79	SF	\$40	\$3,150
54702	31.1 to 32.1 feet	Vertical Change	.3	5 ft	5	REF		
40574	42.5 to 44.6 feet	Running Slope	7.0-8.0%	5 ft	9	REF		
57607	43.9 to 44.9 feet	Vertical Change	3	5 ft	5	REF		
21337	46.0 to 50.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160
59202	50.7 to 77.3 feet	Driveway				REF		
54703	50.9 to 51.9 feet	Vertical Change	.3	5 ft	5	REF		
40575	52.4 to 53.6 feet	Running Slope	8.0-9.0%	5 ft	5	REF		
21338	55.3 to 73.7 feet	Cross Slope (Driveway)	>15%	5 ft	83	SF	\$40	\$3,312
56709	63.3 to 64.3 feet	Vertical Change	.5	5 ft	5	REF		
54704	75.6 to 76.6 feet	Vertical Change	.3	5 ft	5	REF		
21340	77.4 to 78.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$252
21341	78.8 to 98.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	90	SF	\$120	\$10,746
TOTAL COST FOR: SE side of COLUSA AVE Starting at: 517 COLUSA AVE							\$26,235.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1909251518	COLUSA AVE	5TH ST	4TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
21248	1.3 to 10.2 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	44	SF	\$120	\$5,340	
56708	1.6 to 2.6 feet	Vertical Change	.5	5 ft	5	REF			
56173	5.5 to 6.5 feet	Vertical Change	.4	5 ft	5	REF			
21252	12.7 to 21.5 feet	Cross Slope (PAR)	7.0-8.0%	5 ft	44	SF	\$120	\$5,280	
56174	13.0 to 14.0 feet	Vertical Change	.4	5 ft	5	REF			
21255	21.5 to 30.9 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	47	SF	\$120	\$5,640	
21258	30.9 to 69.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	191	SF	\$120	\$22,920	
54694	48.9 to 49.9 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
21268	69.3 to 71.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140	
59199	69.8 to 100.9 feet	Driveway				REF			
21269	75.7 to 78.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	13	SF	\$40	\$520	
21271	78.3 to 96.2 feet	Cross Slope (Driveway)	13.014	5 ft	90	SF	\$40	\$3,580	
21277	101.3 to 102.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	7	SF	\$40	\$260	
57027	107.5 to 108.5 feet	Vertical Change	.6	5 ft	5	SF	\$75	\$375	
21278	112.2 to 122.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,360	
21280	123.1 to 147.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	123	SF	\$120	\$14,760	
56175	136.0 to 137.0 feet	Vertical Change	.4	5 ft	5	REF			
57351	140.9 to 141.9 feet	Vertical Change	1	5 ft	5	REF			
21289	148.8 to 153.4 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	23	SF	\$120	\$2,760	
21290	153.4 to 157.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	20	SF	\$120	\$2,400	
21292	157.7 to 163.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	31	SF	\$120	\$3,660	
21295	164.6 to 176.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	58	SF	\$120	\$6,900	
21297	177.0 to 188.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	59	SF	\$120	\$7,020	
59200	186.7 to 218.5 feet	Driveway				REF			
40571	189.9 to 190.9 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
21301	192.0 to 195.7 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	19	SF	\$40	\$740	
21303	198.3 to 203.3 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	25	SF	\$40	\$1,000	
21306	203.3 to 206.3 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	15	SF	\$40	\$600	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251518	COLUSA AVE	5TH ST	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21308	206.3 to 214.8 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	43	SF	\$40	\$1,700
40572	215.9 to 217.3 feet	Running Slope	6.0-7.0%	5 ft	7	REF		
54695	217.0 to 218.0 feet	Vertical Change	.3	5 ft	5	REF		
21311	218.7 to 227.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	44	SF	\$120	\$5,280
21313	227.5 to 229.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	12	SF	\$120	\$1,380
21314	230.8 to 240.6 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	49	SF	\$120	\$5,880
21315	240.8 to 241.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	5	SF	\$120	\$600
21316	242.3 to 243.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	8	SF	\$120	\$900
54696	244.1 to 245.1 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
21317	248.8 to 269.8 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	105	SF	\$120	\$12,600
57179	249.1 to 250.1 feet	Vertical Change	.7	5 ft	5	REF		
54697	266.4 to 267.4 feet	Vertical Change	.3	5 ft	5	REF		
21323	269.8 to 278.0 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	41	SF	\$120	\$4,920
21325	278.9 to 281.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	12	SF	\$120	\$1,380
54698	279.1 to 280.1 feet	Vertical Change	.3	5 ft	5	REF		
21327	281.2 to 289.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	39	SF	\$120	\$4,680
21329	289.7 to 305.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	78	SF	\$120	\$9,300
54699	304.8 to 305.8 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: SE side of COLUSA AVE Starting at: 5TH ST							\$140,625.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1909251524	COLUSA AVE	4TH ST	3RD ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
21186	0.4 to 2.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$972	
21187	3.9 to 8.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,268	
21188	11.6 to 73.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	276	SF	\$120	\$33,156	
56170	72.6 to 73.6 feet	Vertical Change	.4	5 ft	5	REF			
21194	73.0 to 89.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	72	SF	\$120	\$8,694	
59194	88.3 to 104.1 feet	Driveway				REF			
40562	89.5 to 91.2 feet	Running Slope	7.0-8.0%	5 ft	8	REF			
21198	92.8 to 101.4 feet	Cross Slope (Driveway)	>15%	5 ft	39	SF	\$40	\$1,548	
40563	101.7 to 103.9 feet	Running Slope	7.0-8.0%	5 ft	10	REF			
21200	106.3 to 109.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	13	SF	\$120	\$1,512	
21202	109.1 to 112.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	15	SF	\$120	\$1,782	
21203	112.4 to 113.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	6	SF	\$120	\$756	
21204	113.8 to 119.7 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	27	SF	\$120	\$3,186	
21206	120.0 to 128.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	37	SF	\$120	\$4,482	
21211	128.3 to 140.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,750	
59195	141.4 to 155.4 feet	Driveway				REF			
40565	141.5 to 144.0 feet	Running Slope	5.0-6.0%	5 ft	11	REF			
21215	145.3 to 151.8 feet	Cross Slope (Driveway)	>15%	5 ft	29	SF	\$40	\$1,170	
40567	152.8 to 155.4 feet	Running Slope	5.0-6.0%	5 ft	12	REF			
21216	156.1 to 157.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$918	
56171	158.5 to 159.5 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338	
59196	161.2 to 176.6 feet	Driveway				REF			
40568	163.4 to 164.8 feet	Running Slope	6.0-7.0%	5 ft	6	REF			
21217	166.6 to 173.1 feet	Cross Slope (Driveway)	13.014	5 ft	29	SF	\$40	\$1,170	
40569	173.9 to 176.0 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
21220	178.6 to 185.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,780	
21221	190.8 to 215.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	109	SF	\$120	\$13,122	
57308	214.3 to 215.3 feet	Vertical Change	.9	5 ft	5	REF			
59197	215.1 to 228.1 feet	Driveway				REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251524	COLUSA AVE	4TH ST	3RD ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21229	218.5 to 225.5 feet	Cross Slope (Driveway)	13.014	5 ft	32	SF	\$40	\$1,260
57026	227.1 to 228.1 feet	Vertical Change	.6	5 ft	5	REF		
21232	229.1 to 235.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,672
21234	239.5 to 252.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	58	SF	\$120	\$6,966
21237	252.4 to 268.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,802
59198	272.0 to 291.4 feet	Driveway				REF		
40570	272.6 to 274.0 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
21242	277.5 to 284.4 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	31	SF	\$40	\$1,242
21244	284.4 to 286.3 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	9	SF	\$40	\$342
56172	289.3 to 290.3 feet	Vertical Change	.4	5 ft	5	REF		
21245	291.3 to 308.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	77	SF	\$40	\$3,078
TOTAL COST FOR: SE side of COLUSA AVE Starting at: 4TH ST							\$110,965.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1909251530	COLUSA AVE	3RD ST	105 COLUSA AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
21059	1.9 to 16.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	67	SF	\$120	\$8,100	
21062	20.5 to 23.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,836	
21063	28.2 to 29.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$756	
59183	28.8 to 44.0 feet	Driveway				REF			
40541	30.4 to 32.3 feet	Running Slope	7.0-8.0%	5 ft	9	REF			
21064	34.2 to 41.0 feet	Cross Slope (Driveway)	>15%	5 ft	31	SF	\$40	\$1,224	
40542	41.2 to 44.0 feet	Running Slope	6.0-7.0%	5 ft	13	REF			
21066	45.8 to 61.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	69	SF	\$120	\$8,262	
21069	62.3 to 73.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$5,940	
21071	73.3 to 82.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	43	SF	\$120	\$5,130	
59184	81.5 to 96.8 feet	Driveway				REF			
40543	83.3 to 84.9 feet	Running Slope	8.0-9.0%	5 ft	7	REF			
21074	86.5 to 90.9 feet	Cross Slope (Driveway)	>15%	5 ft	20	SF	\$40	\$792	
21076	90.9 to 93.2 feet	Cross Slope (Driveway)	13.014	5 ft	10	SF	\$40	\$414	
40544	94.1 to 95.4 feet	Running Slope	7.0-8.0%	5 ft	6	REF			
21077	98.1 to 101.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,998	
21078	106.6 to 124.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	81	SF	\$120	\$9,666	
21081	126.7 to 132.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	27	SF	\$120	\$3,294	
59185	132.3 to 146.3 feet	Driveway				REF			
40545	133.3 to 134.4 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
21083	135.9 to 144.1 feet	Cross Slope (Driveway)	>15%	5 ft	37	SF	\$40	\$1,476	
40546	143.6 to 146.5 feet	Running Slope	5.0-6.0%	5 ft	13	REF			
54692	145.2 to 146.2 feet	Vertical Change	.3	5 ft	5	REF			
21084	147.4 to 148.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	6	SF	\$120	\$756	
21085	149.1 to 150.9 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	8	SF	\$120	\$972	
21086	155.1 to 156.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	8	SF	\$120	\$918	
21087	157.4 to 160.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	13	SF	\$120	\$1,566	
56707	157.9 to 158.9 feet	Vertical Change	.5	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251530	COLUSA AVE	3RD ST	105 COLUSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21089	160.3 to 170.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	47	SF	\$120	\$5,670
21091	170.8 to 183.5 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	57	SF	\$120	\$6,858
54693	178.5 to 179.5 feet	Vertical Change	.3	5 ft	5	REF		
59186	183.5 to 197.4 feet	Driveway				REF		
40547	185.2 to 186.9 feet	Running Slope	6.0-7.0%	5 ft	8	REF		
21093	187.9 to 194.3 feet	Cross Slope (Driveway)	>15%	5 ft	29	SF	\$40	\$1,152
40548	195.8 to 197.1 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
21094	198.5 to 201.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620
21095	206.8 to 221.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	68	SF	\$120	\$8,100
56167	208.3 to 209.3 feet	Vertical Change	.4	5 ft	5	REF		
21098	222.3 to 224.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,026
21099	226.4 to 235.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$5,076
57606	229.8 to 230.8 feet	Vertical Change	3	5 ft	5	REF		
59187	234.4 to 249.0 feet	Driveway				REF		
40549	236.0 to 237.2 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
40550	237.2 to 238.3 feet	Running Slope	6.0-7.0%	5 ft	5	REF		
21100	239.3 to 246.4 feet	Cross Slope (Driveway)	>15%	5 ft	32	SF	\$40	\$1,278
40551	246.4 to 248.3 feet	Running Slope	7.0-8.0%	5 ft	9	REF		
21101	250.8 to 255.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,376
21103	256.0 to 267.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	51	SF	\$120	\$6,102
21105	267.3 to 283.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	72	SF	\$120	\$8,640
59188	285.9 to 300.3 feet	Driveway				REF		
21110	286.0 to 287.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$180
21111	291.4 to 297.4 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	27	SF	\$40	\$1,080
40552	298.2 to 299.2 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
40553	299.2 to 300.3 feet	Running Slope	6.0-7.0%	5 ft	5	REF		
21113	301.3 to 327.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	117	SF	\$120	\$13,986
21120	327.8 to 339.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,372

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	1909251530	COLUSA AVE	3RD ST	105 COLUSA AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
57177	328.2 to 329.2 feet	Vertical Change	.7	5 ft	5	REF			
59189	339.1 to 359.7 feet	Driveway				REF			
21124	344.6 to 348.6 feet	Cross Slope (Driveway)	13.014	5 ft	18	SF	\$40	\$720	
21126	348.6 to 353.7 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	23	SF	\$40	\$918	
21128	353.7 to 356.0 feet	Cross Slope (Driveway)	13.014	5 ft	10	SF	\$40	\$414	
21129	365.8 to 384.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	85	SF	\$120	\$10,206	
21134	384.7 to 386.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$864	
21135	388.6 to 401.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	56	SF	\$120	\$6,696	
59190	399.9 to 414.8 feet	Driveway				REF			
40554	400.8 to 403.3 feet	Running Slope	7.0-8.0%	5 ft	11	REF			
21138	405.1 to 409.4 feet	Cross Slope (Driveway)	>15%	5 ft	19	SF	\$40	\$774	
40555	411.4 to 413.6 feet	Running Slope	6.0-7.0%	5 ft	10	REF			
21140	418.0 to 420.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	11	SF	\$120	\$1,350	
21142	421.8 to 441.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	88	SF	\$120	\$10,530	
21146	442.2 to 444.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$972	
21147	444.0 to 449.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,024	
59191	450.2 to 466.2 feet	Driveway				REF			
40556	451.4 to 452.9 feet	Running Slope	6.0-7.0%	5 ft	7	REF			
21149	455.2 to 462.3 feet	Cross Slope (Driveway)	13.014	5 ft	32	SF	\$40	\$1,278	
40557	464.5 to 465.6 feet	Running Slope	7.0-8.0%	5 ft	5	REF			
21152	467.2 to 473.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,240	
21155	473.2 to 494.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	96	SF	\$120	\$11,502	
21162	496.7 to 502.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	27	SF	\$120	\$3,240	
59192	501.3 to 516.3 feet	Driveway				REF			
40558	503.8 to 505.6 feet	Running Slope	6.0-7.0%	5 ft	8	REF			
21163	506.5 to 511.5 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	23	SF	\$40	\$900	
40559	513.4 to 516.3 feet	Running Slope	5.0-6.0%	5 ft	13	REF			
21166	519.8 to 553.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	150	SF	\$120	\$17,982	
56168	524.2 to 525.2 feet	Vertical Change	.4	5 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251530	COLUSA AVE	3RD ST	105 COLUSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57178	526.8 to 527.8 feet	Vertical Change	.7	5 ft	5	REF		
56169	540.8 to 541.8 feet	Vertical Change	.4	5 ft	5	REF		
59193	552.1 to 568.1 feet	Driveway				REF		
40560	554.3 to 555.4 feet	Running Slope	7.0-8.0%	5 ft	5	REF		
21174	557.5 to 563.4 feet	Cross Slope (Driveway)	>15%	5 ft	27	SF	\$40	\$1,062
40561	565.8 to 567.3 feet	Running Slope	6.0-7.0%	5 ft	7	REF		
21176	568.3 to 572.6 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	19	SF	\$40	\$774
21177	572.6 to 606.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	151	SF	\$120	\$18,090
TOTAL COST FOR: SE side of COLUSA AVE Starting at: 3RD ST							\$217,152.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	1909251532	COLUSA AVE	105 COLUSA AVE	1ST ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21043	2.4 to 13.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,156
21048	14.7 to 35.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	92	SF	\$120	\$11,070
56166	19.5 to 20.5 feet	Vertical Change	.4	5 ft	5	REF		
59182	34.2 to 50.0 feet	Driveway				REF		
40539	35.8 to 38.2 feet	Running Slope	5.0-6.0%	5 ft	11	REF		
21055	38.7 to 47.8 feet	Cross Slope (Driveway)	>15%	5 ft	41	SF	\$40	\$1,638
40540	47.1 to 48.8 feet	Running Slope	5.0-6.0%	5 ft	8	REF		
21056	51.3 to 61.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	48	SF	\$120	\$5,724
TOTAL COST FOR: SE side of COLUSA AVE Starting at: 105 COLUSA AVE							\$24,588.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909251536	1ST ST	COLUSA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
21009	1.2 to 6.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	21	SF	\$120	\$2,550
21012	6.2 to 14.4 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	35	SF	\$120	\$4,182
21015	14.4 to 17.3 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	12	SF	\$120	\$1,479
21016	17.7 to 21.3 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	15	SF	\$120	\$1,836
21018	21.3 to 24.8 feet	Cross Slope (PAR)	6.0-7.0%	4 ft	15	SF	\$120	\$1,785
54690	25.0 to 26.0 feet	Vertical Change	.3	4 ft	4	REF		
21019	25.0 to 28.6 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	15	SF	\$120	\$1,836
21021	28.8 to 36.3 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	32	SF	\$120	\$3,825
21023	36.3 to 42.5 feet	Cross Slope (PAR)	5.0-6.0%	4 ft	26	SF	\$120	\$3,162
21026	45.0 to 47.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	10	SF	\$120	\$1,173
21027	49.4 to 54.3 feet	Cross Slope (PAR)	4.0-5.0%	4 ft	21	SF	\$120	\$2,499
21029	56.4 to 73.4 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	72	SF	\$120	\$8,670
21034	73.8 to 138.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	277	SF	\$120	\$33,201
54691	115.0 to 116.0 feet	Vertical Change	.3	4 ft	4	REF		
73	139.0 to 140.0 feet	Continuous Width		4 ft	4	SF	\$120	\$510
TOTAL COST FOR: SW side of 1ST ST Starting at: COLUSA AVE							\$66,708.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909251540	1ST ST	SIDEWALK BEGINS	MARIPOSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
20980	0.0 to 12.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	54	SF	\$120	\$6,480
20984	13.2 to 44.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	140	SF	\$120	\$16,794
56706	25.1 to 26.1 feet	Vertical Change	.5	5 ft	5	REF		
54689	40.1 to 41.1 feet	Vertical Change	.3	5 ft	5	REF		
20988	44.5 to 45.7 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	5	SF	\$120	\$648
20989	45.7 to 49.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	16	SF	\$120	\$1,944
20991	50.9 to 88.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	171	SF	\$120	\$20,466
57470	83.2 to 84.2 feet	Vertical Change	1.5	5 ft	5	REF		
20999	90.2 to 98.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,644
21001	99.8 to 114.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	68	SF	\$120	\$8,100
21004	117.8 to 128.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	50	SF	\$120	\$5,994
TOTAL COST FOR: SW side of 1ST ST Starting at: SIDEWALK BEGINS							\$65,070.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909251546	MARIPOSA AVE	1ST ST	3RD ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
20841	0.0 to 6.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	31	SF	\$120	\$3,726	
20843	10.2 to 16.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	30	SF	\$120	\$3,564	
20846	16.8 to 37.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	95	SF	\$120	\$11,394	
20851	37.9 to 39.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	5	SF	\$120	\$594	
59170	38.1 to 53.1 feet	Driveway				REF			
20852	44.3 to 49.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	24	SF	\$40	\$954	
20854	49.6 to 51.1 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	7	SF	\$40	\$270	
40522	51.8 to 53.2 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
20855	54.1 to 69.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	71	SF	\$120	\$8,532	
57025	59.7 to 60.7 feet	Vertical Change	.6	5 ft	5	REF			
54674	70.6 to 71.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338	
20859	74.3 to 80.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,510	
20860	84.4 to 89.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,862	
59171	88.7 to 103.7 feet	Driveway				REF			
40523	90.7 to 91.8 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
20861	94.2 to 101.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	33	SF	\$40	\$1,314	
20864	105.2 to 109.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160	
20866	110.1 to 111.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	6	SF	\$120	\$756	
57411	114.6 to 115.6 feet	Vertical Change	1.2	5 ft	5	REF			
20867	114.6 to 125.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	47	SF	\$120	\$5,670	
54675	122.3 to 123.3 feet	Vertical Change	.3	5 ft	5	REF			
20872	125.1 to 140.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	69	SF	\$120	\$8,262	
54676	137.6 to 138.6 feet	Vertical Change	.3	5 ft	5	REF			
59172	140.8 to 156.3 feet	Driveway				REF			
20874	144.8 to 153.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	39	SF	\$40	\$1,548	
40524	155.1 to 156.6 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
20875	156.8 to 190.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	150	SF	\$120	\$17,982	
54677	166.1 to 167.1 feet	Vertical Change	.3	5 ft	5	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251546	MARIPOSA AVE	1ST ST	3RD ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56704	169.3 to 170.3 feet	Vertical Change	.5	5 ft	5	REF		
56160	176.0 to 177.0 feet	Vertical Change	.4	5 ft	5	REF		
56705	181.9 to 188.6 feet	Vertical Change	.5	5 ft	30	REF		
59173	190.9 to 207.2 feet	Driveway				REF		
40525	191.9 to 193.3 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
54680	192.3 to 193.3 feet	Vertical Change	.3	5 ft	5	REF		
54681	196.1 to 197.1 feet	Vertical Change	.3	5 ft	5	REF		
20884	196.6 to 202.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	26	SF	\$40	\$1,044
40526	204.5 to 205.9 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
40527	205.9 to 207.1 feet	Running Slope	6.0-7.0%	5 ft	5	REF		
20887	208.4 to 213.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,754
20889	213.8 to 231.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	77	SF	\$120	\$9,288
20895	231.3 to 236.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,754
20897	236.4 to 240.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	18	SF	\$120	\$2,160
59174	242.1 to 259.3 feet	Driveway				REF		
20900	242.7 to 244.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	7	SF	\$40	\$288
20901	247.8 to 255.3 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	34	SF	\$40	\$1,350
56161	261.1 to 262.1 feet	Vertical Change	.4	5 ft	5	REF		
20903	261.8 to 265.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,998
20905	265.5 to 287.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	98	SF	\$120	\$11,772
54682	282.4 to 283.4 feet	Vertical Change	.3	5 ft	5	REF		
20909	287.3 to 295.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,374
59175	294.3 to 311.3 feet	Driveway				REF		
20911	295.4 to 296.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$198
20912	301.0 to 306.4 feet	Cross Slope (Driveway)	13.014	5 ft	24	SF	\$40	\$972
20915	307.8 to 308.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	5	SF	\$40	\$180
20916	313.9 to 350.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	165	SF	\$120	\$19,764
56162	345.8 to 346.8 feet	Vertical Change	.4	5 ft	5	REF		
59176	348.8 to 371.7 feet	Driveway				REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909251546	MARIPOSA AVE	1ST ST	3RD ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
20924	356.5 to 369.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	56	SF	\$40	\$2,250	
40528	369.4 to 371.3 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
20928	372.4 to 389.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	76	SF	\$40	\$3,042	
56163	375.1 to 376.1 feet	Vertical Change	.4	5 ft	5	REF			
59177	407.9 to 425.2 feet	Driveway				REF			
40529	410.4 to 411.8 feet	Running Slope	6.0-7.0%	5 ft	6	REF			
20931	412.4 to 422.1 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	44	SF	\$40	\$1,746	
40530	422.6 to 423.8 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
40531	423.8 to 425.1 feet	Running Slope	6.0-7.0%	5 ft	6	REF			
20934	426.9 to 430.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,674	
56164	449.9 to 450.9 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338	
20935	453.2 to 459.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,618	
59178	458.5 to 476.0 feet	Driveway				REF			
40532	460.3 to 461.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
20936	463.8 to 472.8 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	41	SF	\$40	\$1,620	
40533	474.0 to 476.0 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
54683	475.2 to 476.2 feet	Vertical Change	.3	5 ft	5	REF			
20939	476.7 to 485.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	41	SF	\$120	\$4,914	
56165	480.0 to 481.0 feet	Vertical Change	.4	5 ft	5	REF			
54684	483.5 to 484.5 feet	Vertical Change	.3	5 ft	5	REF			
20942	487.4 to 499.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	52	SF	\$120	\$6,264	
54685	492.0 to 493.0 feet	Vertical Change	.3	5 ft	5	REF			
20947	499.0 to 503.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,322	
54686	500.0 to 501.0 feet	Vertical Change	.3	5 ft	5	REF			
54687	505.4 to 506.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338	
20949	507.8 to 510.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,404	
59179	510.6 to 525.7 feet	Driveway				REF			
40534	511.0 to 513.0 feet	Running Slope	6.0-7.0%	5 ft	9	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251546	MARIPOSA AVE	1ST ST	3RD ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
20950	515.1 to 522.7 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	34	SF	\$40	\$1,368
40535	522.8 to 525.5 feet	Running Slope	6.0-7.0%	5 ft	12	REF		
20954	526.9 to 539.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,966
59180	561.3 to 577.2 feet	Driveway				REF		
20958	561.8 to 562.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$198
40537	562.8 to 564.5 feet	Running Slope	7.0-8.0%	5 ft	8	REF		
20959	567.3 to 573.5 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	28	SF	\$40	\$1,116
40538	573.6 to 575.7 feet	Running Slope	6.0-7.0%	5 ft	9	REF		
20962	581.6 to 589.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,428
20964	597.8 to 614.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,910
59181	613.0 to 629.0 feet	Driveway				REF		
20969	619.3 to 625.1 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	26	SF	\$40	\$1,044
20971	629.4 to 647.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	81	SF	\$40	\$3,222
20974	647.6 to 651.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	18	SF	\$120	\$2,160
20975	653.9 to 665.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	50	SF	\$120	\$6,048
20978	669.1 to 676.0 feet	Cross Slope (PAR)	12.0-13.0%	5 ft	31	SF	\$120	\$3,726
54688	676.2 to 677.2 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
20979	679.8 to 681.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$648
TOTAL COST FOR: NW side of MARIPOSA AVE Starting at: 1ST ST							\$202,032.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	1909251549	MARIPOSA AVE	3RD ST	4TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
20790	0.0 to 13.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,506	
54670	14.4 to 15.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338	
20794	21.6 to 88.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	302	SF	\$120	\$36,180	
56159	77.8 to 78.8 feet	Vertical Change	.4	5 ft	5	REF			
20803	91.0 to 92.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$972	
20804	94.9 to 107.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,020	
20807	110.8 to 124.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	61	SF	\$120	\$7,290	
20808	124.9 to 132.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,996	
59167	131.1 to 146.7 feet	Driveway				REF			
40517	132.5 to 134.2 feet	Running Slope	7.0-8.0%	5 ft	8	REF			
20810	136.8 to 143.0 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	28	SF	\$40	\$1,116	
40518	143.9 to 145.1 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
40519	145.1 to 146.7 feet	Running Slope	6.0-7.0%	5 ft	7	REF			
20812	147.3 to 154.0 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	30	SF	\$40	\$1,206	
54671	150.0 to 151.0 feet	Vertical Change	.3	5 ft	5	REF			
59168	154.2 to 169.8 feet	Driveway				REF			
40520	155.1 to 157.4 feet	Running Slope	6.0-7.0%	5 ft	10	REF			
20815	159.3 to 164.8 feet	Cross Slope (Driveway)	>15%	5 ft	25	SF	\$40	\$990	
20817	164.8 to 166.0 feet	Cross Slope (Driveway)	13.014	5 ft	5	SF	\$40	\$216	
20818	170.1 to 179.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	41	SF	\$40	\$1,656	
20819	184.3 to 234.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	224	SF	\$120	\$26,838	
54672	206.0 to 207.0 feet	Vertical Change	.3	5 ft	5	REF			
20828	238.3 to 239.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$756	
20829	240.1 to 263.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	106	SF	\$120	\$12,690	
54673	247.6 to 248.6 feet	Vertical Change	.3	5 ft	5	REF			
59169	262.9 to 283.2 feet	Driveway				REF			
20833	266.8 to 268.3 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	7	SF	\$40	\$270	
20834	273.6 to 279.6 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	27	SF	\$40	\$1,080	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	1909251549	MARIPOSA AVE	3RD ST	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40521	281.6 to 283.1 feet	Running Slope	7.0-8.0%	5 ft	7	REF		
20838	283.7 to 290.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,726
20839	294.3 to 300.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,348
20840	304.4 to 308.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,998
TOTAL COST FOR: NW side of MARIPOSA AVE Starting at: 3RD ST							\$119,191.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909260828	1ST ST	ORANGE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28066	0.0 to 66.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	300	SF	\$120	\$35,964
56385	2.9 to 3.9 feet	Vertical Change	.4	5 ft	5	REF		
55323	64.4 to 65.4 feet	Vertical Change	.3	5 ft	5	REF		
28078	76.3 to 79.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,890
28080	82.0 to 111.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	131	SF	\$120	\$15,660
59591	109.2 to 128.1 feet	Driveway				REF		
28087	114.6 to 124.7 feet	Cross Slope (Driveway)	13.014	5 ft	45	SF	\$40	\$1,818
28089	128.4 to 138.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	45	SF	\$40	\$1,782
104	138.5 to 139.5 feet	Continuous Width		5 ft	5	SF	\$120	\$540

TOTAL COST FOR: SW	<i>side of 1ST ST Starting at: ORANGE AVE</i>	\$57,654.00
---------------------------	---	--------------------

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909260831	1ST ST	SIDEWALK BEGINS	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28044	0.0 to 26.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	118	SF	\$120	\$14,202
59589	26.7 to 43.8 feet	Driveway				REF		
28049	32.5 to 41.5 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	41	SF	\$40	\$1,620
56383	41.9 to 42.9 feet	Vertical Change	.4	5 ft	5	REF		
28052	44.8 to 45.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$594
28053	45.9 to 54.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,428
28054	61.4 to 63.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,350
28055	68.2 to 69.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$540
59590	68.8 to 86.0 feet	Driveway				REF		
55321	69.6 to 70.6 feet	Vertical Change	.3	5 ft	5	REF		
28056	73.9 to 83.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	42	SF	\$40	\$1,674
28058	87.4 to 106.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,260
55322	94.6 to 95.6 feet	Vertical Change	.3	5 ft	5	REF		
28062	108.5 to 121.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	57	SF	\$120	\$6,804
56384	115.1 to 116.1 feet	Vertical Change	.4	5 ft	5	REF		
28065	121.1 to 122.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$756
TOTAL COST FOR: SW side of 1ST ST Starting at: SIDEWALK BEGINS							\$42,228.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909260834	1ST ST	440 1ST ST	440 1ST ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59588	0.5 to 13.8 feet	Driveway				REF		
55320	30.5 to 31.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: SW side of 1ST ST Starting at: 440 1ST ST								\$375.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909260839	1ST ST	325 1ST ST	325 1ST ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28020	0.0 to 9.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	47	SF	\$120	\$5,580
59586	7.7 to 24.6 feet	Driveway				REF		
55316	7.8 to 8.8 feet	Vertical Change	.3	5 ft	5	REF		
40821	9.0 to 10.3 feet	Running Slope	6.0-7.0%	5 ft	7	REF		
28024	10.3 to 12.7 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	12	SF	\$40	\$480
28026	12.7 to 21.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	43	SF	\$40	\$1,720
40822	22.9 to 24.5 feet	Running Slope	6.0-7.0%	5 ft	8	REF		
55317	23.0 to 24.0 feet	Vertical Change	.3	5 ft	5	REF		
28029	25.7 to 29.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040
28031	29.9 to 34.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	25	SF	\$120	\$3,000
28033	35.8 to 46.2 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	52	SF	\$120	\$6,240
55318	37.0 to 38.0 feet	Vertical Change	.3	5 ft	5	REF		
55319	43.4 to 44.4 feet	Vertical Change	.3	5 ft	5	REF		
28037	47.6 to 51.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	18	SF	\$120	\$2,100
28039	51.6 to 54.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	12	SF	\$120	\$1,440
28040	54.0 to 55.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960
59587	55.3 to 69.9 feet	Driveway				REF		
56382	56.2 to 57.2 feet	Vertical Change	.4	5 ft	5	REF		
40823	57.3 to 58.7 feet	Running Slope	8.0-9.0%	5 ft	7	REF		
28041	60.8 to 70.2 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	47	SF	\$40	\$1,880

TOTAL COST FOR: NE side of 1ST ST Starting at: 325 1ST ST \$25,440.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909260845	2ND ST	ORANGE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28000	1.4 to 10.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,580
57066	7.2 to 8.2 feet	Vertical Change	.6	5 ft	5	REF		
28004	30.6 to 40.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,060
28007	52.9 to 72.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	97	SF	\$120	\$11,640
28012	74.4 to 75.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$660
28013	92.5 to 99.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020
28014	108.9 to 115.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020
28016	118.7 to 124.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,660
28018	127.0 to 129.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380
28019	148.2 to 152.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340
59585	150.9 to 171.1 feet	Driveway				REF		
TOTAL COST FOR: SW side of 2ND ST Starting at: ORANGE AVE							\$39,360.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909260849	2ND ST	HUMBOLDT AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
27996	10.3 to 16.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,294
55315	17.9 to 18.9 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
57321	39.5 to 40.5 feet	Vertical Change	.9	5 ft	5	SF	\$75	\$338
27997	42.3 to 50.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,428
59584	50.0 to 60.8 feet	Driveway				REF		
40820	51.1 to 53.1 feet	Running Slope	6.0-7.0%	5 ft	9	REF		
27999	54.3 to 60.3 feet	Cross Slope (Driveway)	>15%	5 ft	27	SF	\$40	\$1,080
TOTAL COST FOR: SW side of 2ND ST Starting at: HUMBOLDT AVE								\$9,477.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909260853	2ND ST	SIDEWALK BEGINS	ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
27984	0.0 to 6.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,780
27985	8.9 to 17.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$5,040
27988	39.6 to 42.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,980
55312	49.7 to 52.5 feet	Vertical Change	.3	5 ft	14	REF		
27989	50.7 to 52.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260
27990	59.8 to 77.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	90	SF	\$120	\$10,800
27991	84.5 to 87.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,980
27992	97.4 to 102.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,940
56381	101.9 to 102.9 feet	Vertical Change	.4	5 ft	5	REF		
55314	122.3 to 123.3 feet	Vertical Change	.3	5 ft	5	REF		
27993	122.4 to 124.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140
27994	131.6 to 148.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	82	SF	\$120	\$9,840
103	144.6 to 145.6 feet	Continuous Width		5 ft	5	SF	\$120	\$600
TOTAL COST FOR: SW side of 2ND ST Starting at: SIDEWALK BEGINS							\$39,360.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909260857	2ND ST	SIDEWALK BEGINS	COLUSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55310	14.7 to 15.7 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
27963	16.6 to 21.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,430
56380	35.4 to 36.4 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338
27964	37.9 to 42.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,376
27965	45.2 to 58.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,966
59583	57.6 to 71.9 feet	Driveway				REF		
40818	59.1 to 60.8 feet	Running Slope	6.0-7.0%	5 ft	8	REF		
27969	62.5 to 68.8 feet	Cross Slope (Driveway)	13.014	5 ft	28	SF	\$40	\$1,134
40819	68.9 to 70.3 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
55311	70.0 to 71.0 feet	Vertical Change	.3	5 ft	5	REF		
27971	72.8 to 79.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	32	SF	\$120	\$3,780
27974	80.4 to 143.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	284	SF	\$120	\$34,128
102	140.3 to 141.3 feet	Continuous Width		5 ft	5	SF	\$120	\$540
TOTAL COST FOR: SW side of 2ND ST Starting at: SIDEWALK BEGINS							\$52,029.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1909260903	2ND ST	535 2ND ST	525 2ND ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
27937	0.0 to 3.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,674	
59581	3.3 to 19.2 feet	Driveway				REF			
40814	4.5 to 5.8 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
40815	5.8 to 6.9 feet	Running Slope	6.0-7.0%	5 ft	5	REF			
27938	9.0 to 13.4 feet	Cross Slope (Driveway)	>15%	5 ft	20	SF	\$40	\$792	
27940	14.6 to 15.6 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	5	SF	\$40	\$180	
40816	16.4 to 17.8 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
40817	17.8 to 18.9 feet	Running Slope	6.0-7.0%	5 ft	5	REF			
27941	20.0 to 32.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	58	SF	\$120	\$6,966	
55308	22.7 to 23.7 feet	Vertical Change	.3	5 ft	5	REF			
27943	32.9 to 49.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	75	SF	\$120	\$8,964	
101	40.3 to 41.3 feet	Continuous Width		5 ft	5	SF	\$120	\$540	
57441	51.1 to 52.1 feet	Vertical Change	1.3	5 ft	5	SF	\$75	\$338	
27947	53.3 to 55.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,404	
27949	55.9 to 60.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	19	SF	\$120	\$2,268	
27951	60.1 to 61.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$540	
59582	60.3 to 91.8 feet	Driveway				REF			
27952	66.8 to 69.7 feet	Cross Slope (Driveway)	13.014	5 ft	13	SF	\$40	\$522	
27954	69.7 to 88.5 feet	Cross Slope (Driveway)	>15%	5 ft	85	SF	\$40	\$3,384	
57065	91.4 to 92.4 feet	Vertical Change	.6	5 ft	5	REF			
27957	102.6 to 106.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,214	
56379	103.2 to 104.2 feet	Vertical Change	.4	5 ft	5	REF			
27958	109.6 to 123.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	64	SF	\$120	\$7,668	
55309	115.0 to 116.0 feet	Vertical Change	.3	5 ft	5	REF			
27961	123.8 to 127.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	16	SF	\$120	\$1,890	
TOTAL COST FOR: NE							<i>side of 2ND ST Starting at: 535 2ND ST</i>	\$39,343.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	1909260910	3RD ST	COLUSA AVE	MARIPOSA AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
27887	6.9 to 49.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	193	SF	\$120	\$23,112	
100	28.0 to 29.0 feet	Continuous Width		5 ft	5	SF	\$120	\$540	
27897	52.8 to 65.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,020	
59577	65.8 to 90.8 feet	Driveway				REF			
27899	70.0 to 72.1 feet	Cross Slope (Driveway)	13.014	5 ft	9	SF	\$40	\$378	
27900	75.9 to 86.8 feet	Cross Slope (Driveway)	13.014	5 ft	49	SF	\$40	\$1,962	
27903	91.8 to 102.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,832	
27906	107.4 to 135.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	127	SF	\$120	\$15,228	
59578	135.1 to 157.8 feet	Driveway				REF			
27910	137.9 to 139.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	5	SF	\$40	\$198	
27911	141.4 to 153.8 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	56	SF	\$40	\$2,232	
40811	155.5 to 157.8 feet	Running Slope	6.0-7.0%	5 ft	10	REF			
27914	158.4 to 160.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	8	SF	\$40	\$324	
56796	158.5 to 159.5 feet	Vertical Change	.5	5 ft	5	REF			
27915	161.8 to 183.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	95	SF	\$120	\$11,448	
55307	181.7 to 182.7 feet	Vertical Change	.3	5 ft	5	REF			
59579	192.8 to 208.5 feet	Driveway				REF			
40812	195.5 to 197.3 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
27920	198.7 to 206.0 feet	Cross Slope (Driveway)	13.014	5 ft	33	SF	\$40	\$1,314	
40813	206.2 to 207.4 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
27923	209.8 to 210.9 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	5	SF	\$120	\$594	
56797	210.0 to 211.0 feet	Vertical Change	.5	5 ft	5	REF			
27924	210.9 to 213.6 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	12	SF	\$120	\$1,458	
57440	213.6 to 214.6 feet	Vertical Change	1.3	5 ft	5	REF			
27925	214.9 to 216.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,026	
27926	216.8 to 231.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,776	
56798	230.9 to 231.9 feet	Vertical Change	.5	5 ft	5	REF			
27929	251.3 to 257.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,510	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909260910	3RD ST	COLUSA AVE	MARIPOSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
27932	257.8 to 259.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	7	SF	\$120	\$864
59580	258.6 to 275.3 feet	Driveway				REF		
27933	266.3 to 272.8 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	29	SF	\$40	\$1,170
56378	273.8 to 274.8 feet	Vertical Change	.4	5 ft	5	REF		
27935	276.9 to 279.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	13	SF	\$120	\$1,566
27936	280.6 to 282.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$864
TOTAL COST FOR: SW side of 3RD ST Starting at: COLUSA AVE							\$88,416.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW/W	1909260920	3RD ST	MARIPOSA AVE	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
27716	2.9 to 37.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	173	SF	\$120	\$20,700	
55304	13.5 to 14.5 feet	Vertical Change	.3	5 ft	5	REF			
59573	37.2 to 61.9 feet	Driveway				REF			
40805	38.4 to 40.2 feet	Running Slope	8.0-9.0%	5 ft	9	REF			
27728	40.6 to 44.6 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	20	SF	\$40	\$800	
27730	44.6 to 59.0 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	72	SF	\$40	\$2,880	
40806	58.8 to 60.5 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
55305	60.4 to 61.4 feet	Vertical Change	.3	5 ft	5	REF			
27734	62.3 to 76.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	71	SF	\$40	\$2,840	
27737	80.8 to 95.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,880	
27738	97.8 to 110.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,560	
27741	115.9 to 117.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840	
27742	132.9 to 139.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,900	
27743	151.3 to 189.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	188	SF	\$120	\$22,620	
56376	175.8 to 176.8 feet	Vertical Change	.4	5 ft	5	REF			
56795	185.3 to 186.3 feet	Vertical Change	.5	5 ft	5	REF			
27749	195.8 to 244.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	246	SF	\$120	\$29,460	
27759	247.2 to 248.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$660	
27760	248.9 to 279.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	151	SF	\$120	\$18,120	
27767	279.3 to 287.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	42	SF	\$120	\$4,980	
27769	290.3 to 360.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	353	SF	\$120	\$42,360	
55306	329.4 to 330.4 feet	Vertical Change	.3	5 ft	5	REF			
27782	365.2 to 378.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	66	SF	\$120	\$7,860	
27784	381.3 to 382.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$900	
27785	386.3 to 395.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,640	
27788	395.7 to 396.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	6	SF	\$120	\$660	
27789	398.8 to 422.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	119	SF	\$120	\$14,280	
57064	410.5 to 411.5 feet	Vertical Change	.6	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW/W	1909260920	3RD ST	MARIPOSA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56377	415.4 to 416.4 feet	Vertical Change	.4	5 ft	5	REF		
59574	420.1 to 447.3 feet	Driveway				REF		
40807	423.3 to 424.3 feet	Running Slope	7.0-8.0%	5 ft	5	REF		
27797	426.1 to 433.1 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	35	SF	\$40	\$1,400
27799	433.1 to 437.4 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	22	SF	\$40	\$860
27801	440.1 to 444.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	22	SF	\$40	\$880
40808	444.8 to 445.8 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
27803	448.1 to 468.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	101	SF	\$120	\$12,120
27809	469.0 to 489.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	102	SF	\$120	\$12,180
27814	490.1 to 513.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	115	SF	\$120	\$13,800
27821	515.8 to 529.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	67	SF	\$120	\$8,040
27823	529.2 to 533.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	22	SF	\$120	\$2,640
27826	534.2 to 581.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	235	SF	\$120	\$28,260
57199	573.0 to 574.0 feet	Vertical Change	.7	5 ft	5	REF		
27838	583.6 to 598.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,820
27842	611.7 to 618.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$4,020
27843	637.3 to 638.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900
27844	640.9 to 647.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,140
59575	646.7 to 669.2 feet	Driveway				REF		
40809	648.0 to 650.3 feet	Running Slope	6.0-7.0%	5 ft	11	REF		
27847	652.5 to 666.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	69	SF	\$40	\$2,760
27850	669.8 to 695.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	127	SF	\$120	\$15,240
27857	695.2 to 702.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	38	SF	\$120	\$4,500
27860	705.3 to 715.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	53	SF	\$120	\$6,300
27863	719.3 to 721.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	12	SF	\$120	\$1,440
27864	721.7 to 745.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	121	SF	\$120	\$14,520
27870	748.4 to 756.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	39	SF	\$120	\$4,620
27873	756.1 to 766.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,480

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW/W	1909260920	3RD ST	MARIPOSA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
27875	774.1 to 789.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	77	SF	\$120	\$9,240
27881	794.2 to 796.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
59576	799.4 to 826.2 feet	Driveway				REF		
40810	802.0 to 803.4 feet	Running Slope	6.0-7.0%	5 ft	7	REF		
27882	805.1 to 822.0 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	85	SF	\$40	\$3,380
27886	832.9 to 836.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160
TOTAL COST FOR: SW/W side of 3RD ST Starting at: MARIPOSA AVE							\$366,140.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NE	1909260929	3RD ST	MARIPOSA AVE	COLUSA AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
27659	0.0 to 7.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	32	SF	\$120	\$3,888	
27661	9.8 to 49.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	176	SF	\$120	\$21,168	
57063	13.7 to 14.7 feet	Vertical Change	.6	5 ft	5	REF			
55303	20.1 to 21.1 feet	Vertical Change	.3	5 ft	4	REF			
99	21.8 to 22.8 feet	Continuous Width		5 ft	5	SF	\$120	\$540	
56375	38.7 to 39.7 feet	Vertical Change	.4	5 ft	5	REF			
27670	49.0 to 77.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	128	SF	\$120	\$15,390	
27676	84.4 to 85.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$756	
27677	91.1 to 95.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,538	
27678	115.6 to 123.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,158	
59571	123.1 to 146.1 feet	Driveway				REF			
27681	129.9 to 141.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	51	SF	\$40	\$2,052	
40803	143.1 to 144.2 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
27685	147.4 to 155.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	35	SF	\$120	\$4,158	
59572	156.8 to 184.2 feet	Driveway				REF			
27687	161.8 to 180.6 feet	Cross Slope (Driveway)	13.014	5 ft	85	SF	\$40	\$3,384	
27693	186.1 to 213.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	125	SF	\$120	\$14,958	
27698	215.8 to 219.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,106	
27700	219.7 to 220.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	5	SF	\$120	\$648	
27701	222.1 to 227.6 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	25	SF	\$120	\$2,970	
27702	227.6 to 240.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	56	SF	\$120	\$6,750	
27703	240.3 to 241.3 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	5	SF	\$120	\$540	
27704	241.5 to 278.9 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	168	SF	\$120	\$20,196	
27714	279.1 to 280.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$594	
27715	280.2 to 282.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
40804	281.2 to 282.2 feet	Running Slope	5.0-6.0%	5 ft	5	REF			

TOTAL COST FOR: NE	<i>side of 3RD ST Starting at: MARIPOSA AVE</i>	\$107,874.00
---------------------------	---	---------------------

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909260933	3RD ST	COLUSA AVE	ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
27603	0.0 to 9.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,640
55299	3.1 to 4.1 feet	Vertical Change	.3	5 ft	5	REF		
56792	9.2 to 10.2 feet	Vertical Change	.5	5 ft	5	REF		
27606	18.0 to 81.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	315	SF	\$120	\$37,860
56374	51.8 to 52.8 feet	Vertical Change	.4	5 ft	5	REF		
59569	57.3 to 80.8 feet	Driveway				REF		
27618	83.4 to 88.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	27	SF	\$120	\$3,240
27620	88.8 to 107.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	94	SF	\$120	\$11,220
27627	107.9 to 109.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	9	SF	\$120	\$1,080
27628	114.0 to 132.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	95	SF	\$120	\$11,340
27633	134.3 to 135.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$780
59570	134.8 to 156.8 feet	Driveway				REF		
27634	137.3 to 152.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	73	SF	\$40	\$2,940
27640	153.2 to 154.2 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	5	SF	\$40	\$200
27641	157.6 to 214.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	286	SF	\$120	\$34,320
55300	158.1 to 159.1 feet	Vertical Change	.3	5 ft	5	REF		
27648	218.3 to 294.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	382	SF	\$120	\$45,840
55301	224.6 to 225.6 feet	Vertical Change	.3	5 ft	5	REF		
56793	265.7 to 266.7 feet	Vertical Change	.5	5 ft	5	REF		
55302	276.0 to 277.0 feet	Vertical Change	.3	5 ft	5	REF		
56794	292.8 to 293.8 feet	Vertical Change	.5	5 ft	5	REF		
TOTAL COST FOR: NE side of 3RD ST Starting at: COLUSA AVE							\$154,460.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909260937	3RD ST	ALAMEDA AVE	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
27551	0.0 to 6.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,348
55297	2.2 to 3.2 feet	Vertical Change	.3	5 ft	4	REF		
27554	35.4 to 47.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,750
27559	49.7 to 56.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	29	SF	\$120	\$3,456
59566	55.0 to 77.2 feet	Driveway				REF		
40800	56.4 to 58.5 feet	Running Slope	7.0-8.0%	5 ft	9	REF		
27561	60.4 to 68.7 feet	Cross Slope (Driveway)	>15%	5 ft	37	SF	\$40	\$1,494
27563	68.7 to 73.6 feet	Cross Slope (Driveway)	13.014	5 ft	22	SF	\$40	\$882
27565	77.3 to 81.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	20	SF	\$40	\$792
27567	82.7 to 85.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	11	SF	\$120	\$1,296
27568	88.3 to 91.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620
27569	94.2 to 95.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$594
56791	110.1 to 111.1 feet	Vertical Change	.5	5 ft	5	REF		
27570	110.3 to 123.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,020
59567	123.1 to 139.3 feet	Driveway				REF		
27575	125.3 to 127.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	10	SF	\$40	\$396
27576	128.6 to 140.2 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	52	SF	\$40	\$2,088
27580	140.2 to 142.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,026
59568	144.8 to 165.9 feet	Driveway				REF		
27581	152.0 to 157.3 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	24	SF	\$40	\$954
27583	157.3 to 159.4 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	9	SF	\$40	\$378
27585	159.8 to 163.8 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	18	SF	\$40	\$720
40802	164.4 to 165.5 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
27588	166.3 to 170.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	19	SF	\$40	\$756
57198	167.5 to 168.5 feet	Vertical Change	.7	5 ft	5	REF		
27591	173.9 to 182.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	40	SF	\$120	\$4,806
27594	183.8 to 188.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700
27597	241.5 to 243.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,134

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909260937	3RD ST	ALAMEDA AVE	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
27598	273.4 to 277.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,214
27600	294.1 to 305.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,372
55298	298.5 to 299.5 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: NE side of 3RD ST Starting at: ALAMEDA AVE							\$50,796.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NE	1909260942	3RD ST	HUMBOLDT AVE	ORANGE AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
27482	0.0 to 23.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	115	SF	\$120	\$13,800	
56372	24.3 to 25.3 feet	Vertical Change	.4	5 ft	5	REF			
27487	24.5 to 53.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	146	SF	\$120	\$17,460	
57659	37.1 to 38.1 feet	Vertical Change	3.5	5 ft	5	REF			
55293	45.0 to 46.0 feet	Vertical Change	.3	5 ft	5	REF			
27496	53.6 to 75.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	107	SF	\$120	\$12,900	
27500	84.2 to 98.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,760	
27504	101.0 to 107.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,900	
55294	101.5 to 102.5 feet	Vertical Change	.3	5 ft	5	REF			
27507	111.1 to 164.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	266	SF	\$120	\$31,920	
59565	140.3 to 159.2 feet	Driveway				REF			
27518	167.2 to 171.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	21	SF	\$120	\$2,460	
27519	171.3 to 179.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,100	
27522	180.7 to 196.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	78	SF	\$120	\$9,360	
56373	196.8 to 197.8 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
55295	206.0 to 207.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
27526	207.1 to 232.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	127	SF	\$120	\$15,240	
55296	230.5 to 231.5 feet	Vertical Change	.3	5 ft	5	REF			
27533	232.5 to 251.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	96	SF	\$120	\$11,460	
27537	251.6 to 257.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,720	
27540	257.8 to 270.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	64	SF	\$120	\$7,620	
27543	272.8 to 304.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	158	SF	\$120	\$18,900	
40799	297.4 to 298.5 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
TOTAL COST FOR: NE side of 3RD ST Starting at: HUMBOLDT AVE								\$163,350.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1909260946	3RD ST	ORANGE AVE	TRINITY AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
27416	7.8 to 17.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,580	
27417	20.2 to 33.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	64	SF	\$120	\$7,680	
27419	37.3 to 42.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	26	SF	\$120	\$3,120	
27420	42.9 to 48.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,420	
27422	53.2 to 67.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	69	SF	\$120	\$8,340	
57320	67.6 to 68.6 feet	Vertical Change	.9	5 ft	5	REF			
27429	67.9 to 72.0 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	20	SF	\$120	\$2,460	
27430	73.3 to 77.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	21	SF	\$120	\$2,460	
27431	79.1 to 91.1 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	60	SF	\$120	\$7,200	
27435	93.8 to 97.3 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	18	SF	\$120	\$2,100	
27438	99.9 to 101.2 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	7	SF	\$120	\$780	
27439	101.8 to 117.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	78	SF	\$120	\$9,300	
55289	118.8 to 119.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
27442	120.1 to 124.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	24	SF	\$120	\$2,880	
27444	125.8 to 135.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,700	
57416	131.5 to 132.5 feet	Vertical Change	1.2	5 ft	5	REF			
27445	138.2 to 145.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,500	
57359	142.2 to 143.2 feet	Vertical Change	1	5 ft	5	REF			
59564	146.4 to 162.9 feet	Driveway				REF			
27447	150.8 to 166.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	78	SF	\$40	\$3,120	
55290	166.1 to 167.1 feet	Vertical Change	.3	5 ft	5	REF			
27450	166.4 to 167.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	6	SF	\$120	\$660	
27451	169.1 to 176.7 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	38	SF	\$120	\$4,560	
27454	180.5 to 186.4 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	30	SF	\$120	\$3,540	
27455	187.3 to 188.4 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	6	SF	\$120	\$660	
27456	189.8 to 205.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	79	SF	\$120	\$9,420	
27460	208.4 to 211.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	17	SF	\$120	\$1,980	
27461	213.4 to 251.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	190	SF	\$120	\$22,800	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909260946	3RD ST	ORANGE AVE	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
27468	251.4 to 253.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	10	SF	\$120	\$1,140
27469	256.1 to 264.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	40	SF	\$120	\$4,860
27470	264.2 to 281.3 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	86	SF	\$120	\$10,260
27473	281.3 to 303.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	110	SF	\$120	\$13,200
55291	301.9 to 302.9 feet	Vertical Change	.3	5 ft	5	REF		
27480	303.3 to 322.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	95	SF	\$120	\$11,400
55292	312.3 to 313.3 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: NE side of 3RD ST Starting at: ORANGE AVE							\$153,495.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NE	1909260950	3RD ST	TRINITY AVE	ROBERTSON BLVD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
27353	1.4 to 37.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	178	SF	\$120	\$21,360	
55284	5.1 to 6.1 feet	Vertical Change	.3	5 ft	5	REF			
55285	24.3 to 25.3 feet	Vertical Change	.3	5 ft	5	REF			
27359	39.6 to 47.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	38	SF	\$120	\$4,560	
27362	47.8 to 65.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	89	SF	\$120	\$10,680	
55286	63.3 to 64.3 feet	Vertical Change	.3	5 ft	5	REF			
27367	72.2 to 73.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840	
55287	73.2 to 74.2 feet	Vertical Change	.3	5 ft	5	REF			
27368	79.8 to 98.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	92	SF	\$120	\$10,980	
27371	102.9 to 129.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	134	SF	\$120	\$16,020	
55288	105.9 to 106.9 feet	Vertical Change	.3	5 ft	5	REF			
27378	142.2 to 151.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,400	
40798	143.1 to 144.3 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
59563	145.2 to 163.7 feet	Driveway				REF			
27381	153.9 to 155.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$220	
27382	156.8 to 181.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	125	SF	\$40	\$5,020	
27393	185.9 to 187.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$780	
27394	187.4 to 191.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340	
27395	195.4 to 207.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,440	
27397	211.1 to 222.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	57	SF	\$120	\$6,840	
27400	222.5 to 233.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,300	
27402	235.8 to 242.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	34	SF	\$120	\$4,020	
27404	245.6 to 254.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	43	SF	\$120	\$5,160	
27405	257.7 to 273.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	80	SF	\$120	\$9,600	
27408	275.8 to 298.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	115	SF	\$120	\$13,740	
27413	301.5 to 309.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	42	SF	\$120	\$5,040	
TOTAL COST FOR: NE							<i>side of 3RD ST Starting at: TRINITY AVE</i>	\$136,340.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909260953	3RD ST	ROBERTSON BLVD	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
27300	0.0 to 58.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	291	SF	\$120	\$34,860
27313	60.8 to 119.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	295	SF	\$120	\$35,400
27323	120.1 to 138.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	93	SF	\$120	\$11,100
27326	140.8 to 145.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,060
59562	144.4 to 160.1 feet	Driveway				REF		
27328	146.2 to 150.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	23	SF	\$40	\$920
27330	152.0 to 167.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	79	SF	\$40	\$3,160
55283	176.3 to 179.9 feet	Vertical Change	.3	5 ft	18	LF	\$75	\$1,350
27335	179.7 to 180.8 feet	Cross Slope (PAR)	13.014	5 ft	6	SF	\$120	\$660
27336	188.0 to 189.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140
27337	195.9 to 198.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260
27338	204.2 to 205.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720
27339	232.8 to 252.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	98	SF	\$120	\$11,700
27345	264.1 to 271.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,620
27346	275.8 to 281.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,300
27348	285.4 to 292.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320
56371	293.7 to 294.7 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
27351	302.1 to 305.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,100
TOTAL COST FOR: SW side of 3RD ST Starting at: ROBERTSON BLVD							\$120,045.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909260957	3RD ST	TRINITY AVE	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
27241	19.7 to 69.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	225	SF	\$120	\$27,054
55279	26.1 to 27.1 feet	Vertical Change	.3	5 ft	5	REF		
98	26.8 to 27.8 feet	Continuous Width		5 ft	5	SF	\$120	\$540
56369	51.8 to 52.8 feet	Vertical Change	.4	5 ft	5	REF		
55280	65.1 to 66.1 feet	Vertical Change	.3	5 ft	5	REF		
27253	69.8 to 79.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	43	SF	\$120	\$5,130
55281	77.4 to 78.4 feet	Vertical Change	.3	5 ft	5	REF		
27256	79.3 to 129.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	225	SF	\$120	\$27,000
56370	98.0 to 99.0 feet	Vertical Change	.4	5 ft	5	REF		
27271	132.4 to 141.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,752
55282	138.4 to 139.4 feet	Vertical Change	.3	5 ft	5	REF		
59558	140.1 to 163.8 feet	Driveway				REF		
27274	145.3 to 161.3 feet	Cross Slope (Driveway)	>15%	5 ft	72	SF	\$40	\$2,880
59559	181.6 to 207.3 feet	Driveway				REF		
27278	184.7 to 185.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	5	SF	\$40	\$198
27279	188.6 to 194.1 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	25	SF	\$40	\$990
27281	195.9 to 197.9 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	9	SF	\$40	\$360
27283	198.3 to 201.7 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	15	SF	\$40	\$612
27285	201.8 to 203.2 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	6	SF	\$40	\$252
59560	235.5 to 252.2 feet	Driveway				REF		
27286	240.9 to 249.2 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	37	SF	\$40	\$1,494
27287	253.0 to 257.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160
27289	260.2 to 268.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,536
59561	267.8 to 283.0 feet	Driveway				REF		
40794	268.9 to 271.2 feet	Running Slope	7.0-8.0%	5 ft	10	REF		
27291	274.5 to 279.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	22	SF	\$40	\$864
40796	280.0 to 281.0 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
40797	281.0 to 282.2 feet	Running Slope	6.0-7.0%	5 ft	5	REF		
27292	282.5 to 288.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	27	SF	\$40	\$1,080

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909260957	3RD ST	TRINITY AVE	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
27295	288.5 to 289.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$702
27296	293.3 to 295.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,026
27297	299.0 to 301.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,404
27299	304.5 to 306.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,026
TOTAL COST FOR: SW side of 3RD ST Starting at: TRINITY AVE							\$84,060.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	1909261001	3RD ST	ORANGE AVE	HUMBOLDT AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
27181	3.7 to 8.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,640	
27183	9.5 to 12.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	17	SF	\$120	\$1,980	
27185	28.4 to 40.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,140	
27188	42.4 to 45.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740	
27189	48.0 to 56.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	41	SF	\$120	\$4,920	
59555	51.2 to 66.3 feet	Driveway				REF			
27191	56.2 to 59.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	17	SF	\$40	\$660	
27193	69.7 to 111.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	209	SF	\$120	\$25,020	
55273	86.8 to 87.8 feet	Vertical Change	.3	5 ft	5	REF			
57062	95.2 to 96.2 feet	Vertical Change	.6	5 ft	5	REF			
55274	108.2 to 109.2 feet	Vertical Change	.3	5 ft	5	REF			
59556	111.5 to 128.9 feet	Driveway				REF			
27201	111.8 to 116.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	24	SF	\$40	\$960	
55275	119.8 to 120.8 feet	Vertical Change	.3	5 ft	5	REF			
27202	130.1 to 132.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	10	SF	\$120	\$1,260	
55276	131.2 to 132.2 feet	Vertical Change	.3	5 ft	5	REF			
57596	133.7 to 134.7 feet	Vertical Change	2.9	5 ft	5	SF	\$75	\$375	
27203	135.7 to 138.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	16	SF	\$120	\$1,920	
55277	138.4 to 139.4 feet	Vertical Change	.3	5 ft	5	REF			
27205	139.9 to 142.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260	
59557	140.7 to 162.8 feet	Driveway				REF			
27206	145.3 to 150.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	23	SF	\$40	\$940	
27208	152.1 to 154.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	14	SF	\$40	\$540	
27209	155.3 to 159.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	18	SF	\$40	\$740	
27211	159.0 to 160.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	5	SF	\$40	\$200	
27212	165.6 to 181.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	79	SF	\$120	\$9,480	
27215	184.7 to 217.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	163	SF	\$120	\$19,560	
55278	205.6 to 206.6 feet	Vertical Change	.3	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261001	3RD ST	ORANGE AVE	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
27222	221.9 to 225.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,280
27223	227.8 to 229.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140
27224	232.0 to 242.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,540
27227	248.7 to 300.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	259	SF	\$120	\$31,080
TOTAL COST FOR: SW side of 3RD ST Starting at: ORANGE AVE							\$122,375.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	1909261004	3RD ST	HUMBOLDT AVE	ALAMEDA AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
56368	4.1 to 5.1 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
27135	18.1 to 24.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,540	
55269	29.8 to 30.8 feet	Vertical Change	.3	5 ft	5	REF			
27136	30.5 to 60.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	152	SF	\$120	\$18,180	
59552	60.8 to 86.1 feet	Driveway				REF			
27144	64.8 to 72.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	39	SF	\$40	\$1,560	
27146	72.6 to 82.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	50	SF	\$40	\$2,000	
27148	86.6 to 106.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	101	SF	\$120	\$12,060	
27151	127.2 to 141.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	70	SF	\$120	\$8,340	
59553	139.3 to 162.6 feet	Driveway				REF			
40790	142.3 to 143.5 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
27155	145.8 to 149.3 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	18	SF	\$40	\$700	
27157	149.3 to 154.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	28	SF	\$40	\$1,120	
27159	154.9 to 159.4 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	23	SF	\$40	\$900	
40791	161.0 to 162.0 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
27161	163.0 to 191.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	141	SF	\$40	\$5,620	
27166	193.6 to 195.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$840	
59554	194.2 to 226.3 feet	Driveway				REF			
57197	194.9 to 195.9 feet	Vertical Change	.7	5 ft	5	REF			
27167	198.4 to 206.2 feet	Cross Slope (Driveway)	13.014	5 ft	39	SF	\$40	\$1,560	
27169	206.2 to 223.7 feet	Cross Slope (Driveway)	>15%	5 ft	88	SF	\$40	\$3,500	
40792	223.6 to 225.2 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
55270	224.5 to 225.5 feet	Vertical Change	.3	5 ft	5	REF			
40793	225.2 to 226.2 feet	Running Slope	6.0-7.0%	5 ft	5	REF			
27170	227.3 to 232.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	28	SF	\$120	\$3,300	
27171	234.2 to 236.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080	
27172	239.4 to 243.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160	
55271	250.8 to 251.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261004	3RD ST	HUMBOLDT AVE	ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
27174	261.1 to 279.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	93	SF	\$120	\$11,220
55272	276.4 to 277.4 feet	Vertical Change	.3	5 ft	5	REF		
27179	284.9 to 286.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900
27180	300.8 to 303.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
TOTAL COST FOR: SW side of 3RD ST Starting at: HUMBOLDT AVE							\$80,830.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SW	1909261009	3RD ST	ALAMEDA AVE	COLUSA AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
27099	2.3 to 7.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,916	
27100	9.9 to 47.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	170	SF	\$120	\$20,412	
55266	44.7 to 45.7 feet	Vertical Change	.3	5 ft	5	REF			
27108	51.0 to 57.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	28	SF	\$120	\$3,348	
55267	55.5 to 56.5 feet	Vertical Change	.3	5 ft	5	REF			
27109	58.9 to 61.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,188	
27110	63.7 to 88.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	110	SF	\$120	\$13,230	
59549	110.9 to 133.6 feet	Driveway				REF			
27117	117.3 to 130.0 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	57	SF	\$40	\$2,286	
59550	140.1 to 162.8 feet	Driveway				REF			
40786	141.1 to 143.0 feet	Running Slope	6.0-7.0%	5 ft	9	REF			
27122	143.2 to 144.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	5	SF	\$40	\$198	
27123	146.9 to 157.8 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	49	SF	\$40	\$1,962	
40787	159.9 to 161.1 feet	Running Slope	6.0-7.0%	5 ft	5	REF			
40788	161.8 to 162.8 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
27126	165.3 to 172.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,104	
27129	183.7 to 186.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,512	
27130	190.2 to 206.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,748	
57618	192.8 to 193.8 feet	Vertical Change	3.1	5 ft	5	REF			
27132	212.3 to 224.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,750	
59551	229.1 to 247.2 feet	Driveway				REF			
40789	231.3 to 232.9 feet	Running Slope	5.0-6.0%	5 ft	7	REF			
27134	236.4 to 243.8 feet	Cross Slope (Driveway)	>15%	5 ft	33	SF	\$40	\$1,332	
55268	274.0 to 275.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338	
TOTAL COST FOR: SW							<i>side of 3RD ST Starting at: ALAMEDA AVE</i>	\$68,323.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
SW	1909261015	4TH ST	COLUSA AVE	MARIPOSA AVE				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
27048	0.0 to 19.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	98	SF	\$120	\$11,760
27052	23.3 to 42.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	97	SF	\$120	\$11,580
27056	45.0 to 52.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,560
55263	56.4 to 57.4 feet	Vertical Change	.3	5 ft	5	REF		
27059	56.4 to 83.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	136	SF	\$120	\$16,260
27066	87.3 to 94.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020
56364	89.9 to 90.9 feet	Vertical Change	.4	5 ft	5	REF		
27068	104.6 to 138.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	168	SF	\$120	\$20,100
59548	134.9 to 153.4 feet	Driveway				REF		
55264	135.8 to 136.8 feet	Vertical Change	.3	5 ft	5	REF		
40785	139.3 to 140.4 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
27077	141.3 to 150.6 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	46	SF	\$40	\$1,860
27079	154.6 to 158.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040
56365	163.6 to 164.6 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
27081	167.1 to 189.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	114	SF	\$120	\$13,620
27086	194.5 to 204.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	52	SF	\$120	\$6,240
55265	203.4 to 204.4 feet	Vertical Change	.3	5 ft	5	REF		
27088	205.9 to 228.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	115	SF	\$120	\$13,800
57537	228.9 to 229.9 feet	Vertical Change	2.1	5 ft	5	REF		
27092	232.7 to 277.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	222	SF	\$120	\$26,580
56366	249.6 to 250.6 feet	Vertical Change	.4	5 ft	5	REF		
56367	275.5 to 276.5 feet	Vertical Change	.4	5 ft	5	REF		
27096	279.5 to 280.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$600
27097	280.5 to 294.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	72	SF	\$120	\$8,640
TOTAL COST FOR: SW side of 4TH ST Starting at: COLUSA AVE							\$142,035.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261019	4TH ST	MARIPOSA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
27021	0.2 to 2.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,404
27022	5.7 to 38.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	147	SF	\$120	\$17,658
56363	25.4 to 26.4 feet	Vertical Change	.4	5 ft	5	REF		
27030	39.2 to 44.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	25	SF	\$120	\$2,970
59546	43.8 to 59.3 feet	Driveway				REF		
27032	44.7 to 45.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$198
40782	45.3 to 47.5 feet	Running Slope	6.0-7.0%	5 ft	10	REF		
27033	49.3 to 56.6 feet	Cross Slope (Driveway)	>15%	5 ft	33	SF	\$40	\$1,314
40783	56.2 to 57.5 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
27034	60.7 to 62.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
59547	63.8 to 84.3 feet	Driveway				REF		
40784	66.0 to 67.3 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
27035	71.7 to 80.7 feet	Cross Slope (Driveway)	13.014	5 ft	41	SF	\$40	\$1,620
27038	84.9 to 108.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	106	SF	\$120	\$12,690
55262	108.0 to 109.0 feet	Vertical Change	.3	5 ft	5	REF		
27045	111.0 to 119.6 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	39	SF	\$120	\$4,644
27047	122.7 to 128.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	24	SF	\$120	\$2,862
TOTAL COST FOR: NE side of 4TH ST Starting at: MARIPOSA AVE							\$46,440.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261021	4TH ST	SIDEWALK BEGINS	COLUSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26992	0.0 to 17.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	77	SF	\$120	\$9,288
55259	15.1 to 16.1 feet	Vertical Change	.3	5 ft	5	REF		
26997	17.8 to 25.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	34	SF	\$120	\$4,050
55260	22.2 to 23.2 feet	Vertical Change	.3	5 ft	5	REF		
27000	27.9 to 37.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	41	SF	\$120	\$4,914
27002	37.2 to 39.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,026
27003	41.9 to 69.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	123	SF	\$120	\$14,796
55261	45.5 to 46.5 feet	Vertical Change	.3	5 ft	5	REF		
27008	73.0 to 88.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	70	SF	\$120	\$8,370
27012	88.9 to 100.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	53	SF	\$120	\$6,372
59545	100.3 to 117.8 feet	Driveway				REF		
40780	100.7 to 103.6 feet	Running Slope	5.0-6.0%	5 ft	13	REF		
27016	104.4 to 115.1 feet	Cross Slope (Driveway)	13.014	5 ft	48	SF	\$40	\$1,926
40781	115.2 to 116.2 feet	Running Slope	6.0-7.0%	5 ft	5	REF		
27018	120.8 to 139.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,260
TOTAL COST FOR: NE side of 4TH ST Starting at: SIDEWALK BEGINS								\$61,002.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261024	4TH ST	COLUSA AVE	535 4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26978	1.5 to 5.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	18	SF	\$120	\$2,214
57439	3.0 to 4.0 feet	Vertical Change	1.3	5 ft	5	REF		
26980	5.6 to 22.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	76	SF	\$120	\$9,126
56789	14.2 to 15.2 feet	Vertical Change	.5	5 ft	5	REF		
26983	26.3 to 42.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,910
59544	42.3 to 59.1 feet	Driveway				REF		
40779	44.6 to 45.7 feet	Running Slope	6.0-7.0%	5 ft	5	REF		
26988	46.9 to 55.2 feet	Cross Slope (Driveway)	13.014	5 ft	37	SF	\$40	\$1,494
55258	59.2 to 60.2 feet	Vertical Change	.3	5 ft	5	REF		
26991	60.5 to 66.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,024
TOTAL COST FOR: NE side of 4TH ST Starting at: COLUSA AVE							\$24,768.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261030	4TH ST	SIDEWALK BEGINS	ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
96	0.3 to 1.3 feet	Continuous Width		5 ft	5	SF	\$120	\$540
57196	14.4 to 15.4 feet	Vertical Change	.7	5 ft	5	SF	\$75	\$338
55255	16.0 to 17.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
56360	35.6 to 36.6 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338
59543	60.1 to 84.3 feet	Driveway				REF		
40777	61.6 to 62.7 feet	Running Slope	5.0-6.0%	5 ft	5	REF		
40778	62.7 to 64.1 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
26966	64.9 to 80.8 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	72	SF	\$40	\$2,862
56361	82.5 to 83.5 feet	Vertical Change	.4	5 ft	5	REF		
26973	85.0 to 98.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,182
26975	101.5 to 107.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	27	SF	\$120	\$3,294
55256	107.3 to 108.3 feet	Vertical Change	.3	5 ft	5	REF		
26976	107.9 to 112.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,376
56362	135.6 to 136.6 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338
26977	140.0 to 143.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,998
97	140.4 to 141.4 feet	Continuous Width		5 ft	5	SF	\$120	\$540
55257	143.2 to 144.2 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: NE side of 4TH ST Starting at: SIDEWALK BEGINS							\$20,142.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261040	4TH ST	SIDEWALK BEGINS	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26948	0.9 to 7.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	29	SF	\$120	\$3,456
26950	7.6 to 9.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,026
55254	8.7 to 9.7 feet	Vertical Change	.3	5 ft	5	REF		
26951	23.5 to 34.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$6,048
26955	35.0 to 42.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	32	SF	\$120	\$3,888
26957	44.3 to 45.3 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	5	SF	\$120	\$540
26958	47.9 to 51.0 feet	Cross Slope (PAR)	10.0-11.0%	5 ft	14	SF	\$120	\$1,674
26959	76.8 to 79.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,188
26961	90.9 to 92.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$756
26962	102.7 to 108.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	27	SF	\$120	\$3,186
26965	108.6 to 109.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$540
TOTAL COST FOR: NE side of 4TH ST Starting at: SIDEWALK BEGINS							\$22,302.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261044	4TH ST	ORANGE AVE	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26880	0.0 to 3.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	19	SF	\$120	\$2,220
26882	3.7 to 5.0 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	7	SF	\$120	\$780
26883	5.0 to 7.3 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	12	SF	\$120	\$1,380
56788	7.1 to 8.1 feet	Vertical Change	.5	5 ft	5	REF		
26884	8.5 to 21.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	65	SF	\$120	\$7,740
26888	24.1 to 34.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	53	SF	\$120	\$6,420
26890	35.0 to 45.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	54	SF	\$120	\$6,420
55250	46.4 to 47.4 feet	Vertical Change	.3	5 ft	5	REF		
26892	47.4 to 71.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	119	SF	\$120	\$14,280
26894	71.2 to 148.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	386	SF	\$120	\$46,320
55251	108.9 to 109.9 feet	Vertical Change	.3	5 ft	5	REF		
59542	142.3 to 163.5 feet	Driveway				REF		
26918	149.8 to 155.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	28	SF	\$40	\$1,120
55252	151.2 to 152.2 feet	Vertical Change	.3	5 ft	5	REF		
26921	155.4 to 160.8 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	27	SF	\$40	\$1,080
26923	162.1 to 167.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	25	SF	\$40	\$980
57265	173.3 to 174.3 feet	Vertical Change	.8	5 ft	5	SF	\$75	\$375
26925	174.8 to 175.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
26926	181.3 to 208.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	137	SF	\$120	\$16,440
26934	211.3 to 213.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
26935	218.1 to 229.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,600
26938	232.8 to 245.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,500
26941	252.1 to 254.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620
55253	269.6 to 270.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
26942	282.2 to 283.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900
26943	289.4 to 303.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	71	SF	\$120	\$8,460
TOTAL COST FOR: NE side of 4TH ST Starting at: ORANGE AVE							\$133,110.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261048	4TH ST	TRINITY AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26815	7.2 to 24.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	162	SF	\$120	\$19,494
55247	23.4 to 24.4 feet	Vertical Change	.3	10 ft	10	REF		
26817	27.7 to 33.1 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	51	SF	\$120	\$6,156
26820	33.5 to 38.9 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	51	SF	\$120	\$6,156
55248	35.2 to 38.0 feet	Vertical Change	.3	10 ft	27	REF		
57061	40.7 to 41.7 feet	Vertical Change	.6	10 ft	9	REF		
26822	40.8 to 43.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	24	SF	\$120	\$2,850
26823	46.5 to 90.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	416	SF	\$120	\$49,932
56359	47.8 to 48.8 feet	Vertical Change	.4	10 ft	10	REF		
56787	63.9 to 64.9 feet	Vertical Change	.5	10 ft	10	REF		
59539	88.3 to 113.0 feet	Driveway				REF		
26832	99.1 to 141.3 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	401	SF	\$40	\$16,036
59540	138.2 to 162.1 feet	Driveway				REF		
26839	141.8 to 151.4 feet	Cross Slope (Driveway)	4.0-5.0%	10 ft	91	SF	\$40	\$3,648
26843	154.0 to 156.2 feet	Cross Slope (Driveway)	5.0-6.0%	10 ft	21	SF	\$40	\$836
26844	156.2 to 158.9 feet	Cross Slope (Driveway)	6.0-7.0%	10 ft	26	SF	\$40	\$1,026
26845	158.9 to 175.5 feet	Cross Slope (Driveway)	5.0-6.0%	10 ft	158	SF	\$40	\$6,308
55249	160.2 to 161.2 feet	Vertical Change	.3	10 ft	10	REF		
26852	177.8 to 181.4 feet	Cross Slope (PAR)	5.0-6.0%	10 ft	34	SF	\$120	\$4,104
26854	183.9 to 244.9 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	580	SF	\$120	\$69,540
26869	244.9 to 259.2 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	136	SF	\$120	\$16,302
26872	262.0 to 269.1 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	67	SF	\$120	\$8,094
59541	269.0 to 304.9 feet	Driveway				REF		
26873	273.9 to 284.8 feet	Cross Slope (Driveway)	13.014	10 ft	104	SF	\$40	\$4,142
26876	287.7 to 300.9 feet	Cross Slope (Driveway)	13.014	10 ft	125	SF	\$40	\$5,016
40776	301.9 to 303.1 feet	Running Slope	7.0-8.0%	10 ft	11	REF		
TOTAL COST FOR: NE side of 4TH ST Starting at: TRINITY AVE							\$219,640.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261052	4TH ST	ROBERTSON BLVD	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26783	6.5 to 7.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	11	SF	\$120	\$1,368
26784	20.3 to 22.4 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	20	SF	\$120	\$2,394
26785	42.4 to 48.9 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	62	SF	\$120	\$7,410
26786	52.2 to 54.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	23	SF	\$120	\$2,736
26787	123.6 to 130.9 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	69	SF	\$120	\$8,322
59537	141.5 to 163.1 feet	Driveway				REF		
26789	143.1 to 144.1 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	10	SF	\$40	\$380
26790	146.4 to 150.8 feet	Cross Slope (Driveway)	6.0-7.0%	10 ft	42	SF	\$40	\$1,672
26792	151.4 to 154.1 feet	Cross Slope (Driveway)	5.0-6.0%	10 ft	26	SF	\$40	\$1,026
26793	154.1 to 158.3 feet	Cross Slope (Driveway)	6.0-7.0%	10 ft	40	SF	\$40	\$1,596
26794	158.6 to 160.4 feet	Cross Slope (Driveway)	5.0-6.0%	10 ft	17	SF	\$40	\$684
26795	163.3 to 164.8 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	14	SF	\$40	\$570
56786	163.8 to 167.7 feet	Vertical Change	.5	10 ft	37	REF		
26796	170.0 to 179.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	92	SF	\$120	\$11,058
26799	183.3 to 198.2 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	142	SF	\$120	\$16,986
26803	201.8 to 216.2 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	137	SF	\$120	\$16,416
59538	203.8 to 233.3 feet	Driveway				REF		
26805	218.4 to 223.5 feet	Cross Slope (Driveway)	3.0-4.0%	10 ft	48	SF	\$40	\$1,938
26806	227.3 to 233.1 feet	Cross Slope (Driveway)	3.0-4.0%	10 ft	55	SF	\$40	\$2,204
26808	233.1 to 252.8 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	187	SF	\$40	\$7,486
56357	236.2 to 237.2 feet	Vertical Change	.4	10 ft	10	REF		
26811	257.5 to 273.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	147	SF	\$120	\$17,670
26813	275.9 to 299.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	225	SF	\$120	\$27,018
26814	305.7 to 307.5 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	17	SF	\$120	\$2,052
TOTAL COST FOR: SW side of 4TH ST Starting at: ROBERTSON BLVD							\$130,986.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	1909261056	4TH ST	TRINITY AVE	ORANGE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
55242	2.3 to 3.3 feet	Vertical Change	.3	10 ft	10	LF	\$75	\$713	
26735	8.2 to 41.2 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	314	SF	\$120	\$37,620	
55243	13.5 to 14.5 feet	Vertical Change	.3	10 ft	10	REF			
26740	43.6 to 47.6 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	38	SF	\$120	\$4,560	
26742	50.9 to 53.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	23	SF	\$120	\$2,736	
26744	55.9 to 94.1 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	363	SF	\$120	\$43,548	
26749	96.8 to 105.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	78	SF	\$120	\$9,348	
26750	113.0 to 117.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	38	SF	\$120	\$4,560	
26751	120.6 to 142.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	209	SF	\$120	\$25,080	
59536	141.6 to 165.6 feet	Driveway				REF			
26756	144.3 to 147.5 feet	Cross Slope (Driveway)	5.0-6.0%	10 ft	30	SF	\$40	\$1,216	
26757	148.8 to 150.2 feet	Cross Slope (Driveway)	3.0-4.0%	10 ft	13	SF	\$40	\$532	
26758	150.3 to 151.7 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	13	SF	\$40	\$532	
26759	157.2 to 163.2 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	57	SF	\$40	\$2,280	
55244	166.7 to 167.7 feet	Vertical Change	.3	10 ft	10	LF	\$75	\$713	
26761	169.6 to 171.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	16	SF	\$120	\$1,938	
56356	175.7 to 176.7 feet	Vertical Change	.4	10 ft	10	LF	\$75	\$713	
26762	177.1 to 184.9 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	74	SF	\$120	\$8,892	
26765	188.8 to 198.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	93	SF	\$120	\$11,172	
26768	200.7 to 210.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	96	SF	\$120	\$11,514	
26771	212.1 to 228.8 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	159	SF	\$120	\$19,038	
26775	229.8 to 238.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	86	SF	\$120	\$10,260	
26778	244.6 to 247.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	26	SF	\$120	\$3,078	
26780	269.5 to 270.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	12	SF	\$120	\$1,482	
26781	275.1 to 279.9 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	46	SF	\$120	\$5,472	
26782	291.8 to 295.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	30	SF	\$120	\$3,648	
55245	297.4 to 298.4 feet	Vertical Change	.3	10 ft	10	LF	\$75	\$713	

TOTAL COST FOR: SW side of 4TH ST Starting at: TRINITY AVE \$211,356.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261115	4TH ST	ALAMEDA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26706	0.0 to 46.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	234	SF	\$120	\$28,020
59534	45.8 to 62.6 feet	Driveway				REF		
55240	47.0 to 48.0 feet	Vertical Change	.3	5 ft	5	REF		
26712	51.7 to 53.5 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	9	SF	\$40	\$360
26713	56.7 to 59.8 feet	Cross Slope (Driveway)	13.014	5 ft	16	SF	\$40	\$620
26715	63.6 to 70.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	36	SF	\$120	\$4,320
26718	71.2 to 75.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700
26720	76.7 to 80.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	18	SF	\$120	\$2,160
55241	77.0 to 79.8 feet	Vertical Change	.3	5 ft	14	REF		
59535	82.3 to 111.3 feet	Driveway				REF		
56355	82.9 to 83.9 feet	Vertical Change	.4	5 ft	5	REF		
26722	86.7 to 108.7 feet	Cross Slope (Driveway)	13.014	5 ft	110	SF	\$40	\$4,400
26727	112.8 to 144.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	156	SF	\$120	\$18,720
TOTAL COST FOR: SW side of 4TH ST Starting at: ALAMEDA AVE							\$61,300.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
SW	1909261121	5TH ST	COLUSA AVE	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
26647	0.0 to 3.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220	
57501	1.2 to 2.2 feet	Vertical Change	1.7	5 ft	5	REF			
26649	3.9 to 10.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	31	SF	\$120	\$3,780	
55234	7.0 to 8.0 feet	Vertical Change	.3	5 ft	5	REF			
26651	10.2 to 20.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,300	
26654	20.9 to 41.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	105	SF	\$120	\$12,540	
26659	41.8 to 43.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960	
59529	42.2 to 59.1 feet	Driveway				REF			
26660	46.9 to 49.5 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	13	SF	\$40	\$520	
26662	49.5 to 50.7 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	6	SF	\$40	\$240	
26663	50.7 to 56.9 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	31	SF	\$40	\$1,240	
26667	57.8 to 68.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	54	SF	\$40	\$2,160	
56353	61.7 to 62.7 feet	Vertical Change	.4	5 ft	5	REF			
26669	72.2 to 74.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560	
55235	102.9 to 103.9 feet	Vertical Change	.3	5 ft	5	REF			
26670	103.8 to 116.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,800	
59530	107.8 to 128.3 feet	Driveway				REF			
55236	118.1 to 119.1 feet	Vertical Change	.3	5 ft	5	REF			
26672	119.9 to 139.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	100	SF	\$40	\$3,980	
59531	137.8 to 156.1 feet	Driveway				REF			
26678	155.1 to 156.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	9	SF	\$40	\$360	
55237	159.2 to 160.2 feet	Vertical Change	.3	5 ft	5	REF			
26679	159.5 to 193.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	169	SF	\$120	\$20,280	
26687	195.4 to 206.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,420	
55238	199.2 to 200.2 feet	Vertical Change	.3	5 ft	5	REF			
26690	206.1 to 229.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	119	SF	\$120	\$14,280	
59532	237.4 to 252.2 feet	Driveway				REF			
26695	238.8 to 240.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	9	SF	\$40	\$340	
26696	243.5 to 245.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	12	SF	\$40	\$460	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261121	5TH ST	COLUSA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26697	255.8 to 271.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	80	SF	\$120	\$9,660
55239	269.8 to 270.8 feet	Vertical Change	.3	5 ft	5	REF		
26701	273.3 to 278.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000
59533	274.6 to 292.0 feet	Driveway				REF		
26702	280.7 to 287.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	32	SF	\$40	\$1,260
26704	292.3 to 300.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	41	SF	\$40	\$1,640
TOTAL COST FOR: SW side of 5TH ST Starting at: COLUSA AVE							\$101,000.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261125	5TH ST	SIDEWALK BEGINS	COLUSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26589	0.0 to 8.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,160
26590	11.0 to 64.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	267	SF	\$120	\$32,040
55230	31.1 to 32.1 feet	Vertical Change	.3	5 ft	5	REF		
26602	65.4 to 81.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	78	SF	\$120	\$9,420
26604	81.1 to 84.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220
26605	91.3 to 113.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	113	SF	\$120	\$13,500
26608	116.0 to 148.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	163	SF	\$120	\$19,500
59528	143.6 to 160.2 feet	Driveway				REF		
26614	161.3 to 170.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,220
26616	172.5 to 179.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320
55231	183.5 to 184.5 feet	Vertical Change	.3	5 ft	5	REF		
26619	183.5 to 206.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	113	SF	\$120	\$13,560
26625	206.9 to 232.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	127	SF	\$120	\$15,240
26630	235.8 to 252.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	84	SF	\$120	\$10,080
26633	254.5 to 272.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	89	SF	\$120	\$10,680
55232	265.8 to 266.8 feet	Vertical Change	.3	5 ft	5	REF		
26638	272.3 to 275.9 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	18	SF	\$120	\$2,160
57264	276.0 to 277.0 feet	Vertical Change	.8	5 ft	5	SF	\$75	\$375
26640	277.8 to 298.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	105	SF	\$120	\$12,540
55233	291.3 to 292.3 feet	Vertical Change	.3	5 ft	5	REF		

TOTAL COST FOR: NE	<i>side of 5TH ST Starting at: SIDEWALK BEGINS</i>	\$156,015.00
---------------------------	--	---------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261130	5TH ST	COLUSA AVE	ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26532	1.8 to 5.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	17	SF	\$120	\$2,040
26533	6.3 to 7.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	5	SF	\$120	\$600
26534	8.4 to 11.1 feet	Cross Slope (PAR)	7.0-8.0%	5 ft	14	SF	\$120	\$1,620
26536	20.2 to 31.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,660
57415	25.7 to 26.7 feet	Vertical Change	1.2	5 ft	5	REF		
26538	38.1 to 48.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,240
26540	51.2 to 58.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	39	SF	\$120	\$4,620
26543	58.9 to 65.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,660
59526	59.5 to 75.0 feet	Driveway				REF		
26545	73.8 to 84.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	53	SF	\$40	\$2,120
26549	85.1 to 97.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	62	SF	\$120	\$7,440
26552	99.2 to 132.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	165	SF	\$120	\$19,800
26560	132.8 to 134.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	10	SF	\$120	\$1,200
55228	133.7 to 134.7 feet	Vertical Change	.3	5 ft	5	REF		
26561	136.1 to 137.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$660
59527	136.8 to 159.8 feet	Driveway				REF		
26562	141.5 to 143.5 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	10	SF	\$40	\$400
26563	143.8 to 145.8 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	10	SF	\$40	\$400
26564	145.8 to 155.1 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	46	SF	\$40	\$1,860
26566	156.2 to 159.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	14	SF	\$40	\$560
26568	160.8 to 162.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$1,020
26569	162.8 to 234.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	360	SF	\$120	\$43,200
56785	179.5 to 180.5 feet	Vertical Change	.5	5 ft	5	REF		
56350	196.0 to 197.0 feet	Vertical Change	.4	5 ft	5	REF		
56351	215.4 to 216.4 feet	Vertical Change	.4	5 ft	5	REF		
55229	234.3 to 235.3 feet	Vertical Change	.3	5 ft	5	REF		
26582	244.2 to 247.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,740
26583	260.1 to 272.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,620

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261130	5TH ST	COLUSA AVE	ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26585	275.7 to 282.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,080
26587	286.1 to 291.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,940
26588	294.5 to 297.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,980
56352	294.7 to 295.7 feet	Vertical Change	.4	5 ft	5	REF		
TOTAL COST FOR: NE side of 5TH ST Starting at: COLUSA AVE							\$122,460.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1909261133	5TH ST	ALAMEDA AVE	HUMBOLDT AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
55223	2.0 to 3.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
26463	4.4 to 8.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160	
55224	8.5 to 9.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
26464	12.1 to 13.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840	
26465	17.0 to 23.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,660	
26467	29.9 to 31.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$960	
26468	34.8 to 38.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,460	
26469	41.4 to 49.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$5,040	
59522	48.4 to 76.0 feet	Driveway				REF			
26470	53.3 to 62.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	45	SF	\$40	\$1,800	
26472	64.8 to 68.9 feet	Cross Slope (Driveway)	11.0-12.0%	5 ft	21	SF	\$40	\$820	
26474	69.1 to 73.9 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	24	SF	\$40	\$960	
26476	77.6 to 88.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,780	
57060	89.5 to 90.5 feet	Vertical Change	.6	5 ft	5	SF	\$75	\$375	
26478	94.8 to 113.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	93	SF	\$120	\$11,100	
26484	113.5 to 119.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,660	
26488	122.2 to 131.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,460	
59523	126.3 to 136.4 feet	Driveway				REF			
26490	133.7 to 139.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	31	SF	\$40	\$1,220	
26493	139.8 to 140.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$660	
59524	141.0 to 161.9 feet	Driveway				REF			
26494	144.7 to 158.2 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	68	SF	\$40	\$2,700	
26498	162.3 to 167.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	26	SF	\$40	\$1,060	
55225	162.7 to 163.7 feet	Vertical Change	.3	5 ft	5	REF			
57595	166.6 to 167.6 feet	Vertical Change	2.9	5 ft	5	REF			
26500	169.3 to 203.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	170	SF	\$120	\$20,400	
59525	200.8 to 230.5 feet	Driveway				REF			
26508	203.3 to 207.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	21	SF	\$40	\$840	
26509	213.1 to 221.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	42	SF	\$40	\$1,680	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261133	5TH ST	ALAMEDA AVE	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26511	221.5 to 224.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	17	SF	\$40	\$680
26513	226.8 to 229.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	13	SF	\$40	\$500
26515	232.7 to 241.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	42	SF	\$120	\$4,980
57358	235.1 to 236.1 feet	Vertical Change	1	5 ft	5	REF		
26519	242.3 to 253.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,420
55226	243.1 to 244.1 feet	Vertical Change	.3	5 ft	5	REF		
26520	255.2 to 257.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,620
26521	260.1 to 268.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,280
26523	272.1 to 273.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900
26524	279.2 to 291.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,440
26527	294.0 to 300.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,660
55227	297.0 to 298.0 feet	Vertical Change	.3	5 ft	5	REF		
26530	300.4 to 304.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	20	SF	\$120	\$2,400
TOTAL COST FOR: NE side of 5TH ST Starting at: ALAMEDA AVE							\$109,265.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1909261136	5TH ST	HUMBOLDT AVE	ORANGE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
56784	2.0 to 3.0 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375	
26409	5.7 to 23.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	88	SF	\$120	\$10,560	
57059	9.3 to 10.3 feet	Vertical Change	.6	5 ft	5	REF			
26412	34.8 to 83.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	243	SF	\$120	\$29,160	
26426	86.0 to 101.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	78	SF	\$120	\$9,300	
26429	101.9 to 116.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,880	
26431	118.8 to 137.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	92	SF	\$120	\$10,980	
56347	131.8 to 132.8 feet	Vertical Change	.4	5 ft	5	REF			
59521	138.8 to 162.1 feet	Driveway				REF			
26434	143.8 to 160.0 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	81	SF	\$40	\$3,240	
56348	149.9 to 150.9 feet	Vertical Change	.4	5 ft	5	REF			
26438	163.0 to 164.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$780	
26439	164.5 to 200.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	179	SF	\$120	\$21,480	
56349	189.9 to 190.9 feet	Vertical Change	.4	5 ft	5	REF			
26447	203.4 to 208.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,120	
26448	210.9 to 235.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	122	SF	\$120	\$14,640	
55221	235.7 to 236.7 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
26451	255.3 to 268.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,800	
26455	270.5 to 280.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,240	
55222	276.2 to 277.2 feet	Vertical Change	.3	5 ft	5	REF			
26459	283.2 to 293.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,360	
26461	297.2 to 301.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,820	
TOTAL COST FOR: NE side of 5TH ST Starting at: HUMBOLDT AVE							\$136,110.00		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
NE	1909261139	5TH ST	ORANGE AVE	TRINITY AVE				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26360	3.3 to 41.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	190	SF	\$120	\$22,800
26371	41.8 to 48.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	35	SF	\$120	\$4,140
26373	50.2 to 78.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	143	SF	\$120	\$17,160
26379	79.6 to 92.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	66	SF	\$120	\$7,920
26383	92.8 to 99.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,080
26384	111.3 to 114.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860
55220	115.0 to 116.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
26385	118.7 to 119.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$600
26386	121.3 to 143.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	111	SF	\$120	\$13,320
59519	139.9 to 167.5 feet	Driveway				REF		
26392	154.6 to 157.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	13	SF	\$40	\$500
26393	165.6 to 168.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	14	SF	\$40	\$560
26394	172.5 to 175.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040
26396	181.8 to 184.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860
59520	183.8 to 198.3 feet	Driveway				REF		
26397	209.0 to 233.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	121	SF	\$120	\$14,460
26402	239.7 to 241.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320
26404	259.4 to 271.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,440
26406	275.6 to 293.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	89	SF	\$120	\$10,740
26407	300.8 to 304.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400

TOTAL COST FOR: NE	<i>side of 5TH ST Starting at: ORANGE AVE</i>	\$113,575.00
---------------------------	---	---------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261143	5TH ST	TRINITY AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56346	2.1 to 3.1 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
26319	35.0 to 38.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,980
26320	46.9 to 48.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140
55216	49.7 to 50.7 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
55217	62.8 to 63.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
55218	77.7 to 78.7 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
26321	88.8 to 91.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800
26322	124.0 to 125.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
26323	141.5 to 143.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$900
59515	141.5 to 163.6 feet	Driveway				REF		
55219	141.9 to 142.9 feet	Vertical Change	.3	5 ft	5	REF		
26324	143.8 to 158.9 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	75	SF	\$40	\$3,020
26329	158.9 to 161.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	11	SF	\$40	\$420
59516	165.2 to 181.3 feet	Driveway				REF		
26330	172.1 to 193.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	105	SF	\$40	\$4,180
26338	195.4 to 230.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	176	SF	\$120	\$21,060
59517	206.3 to 229.2 feet	Driveway				REF		
26344	242.2 to 264.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	111	SF	\$120	\$13,320
59518	258.9 to 301.4 feet	Driveway				REF		
26349	264.4 to 287.2 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	114	SF	\$40	\$4,560
26356	287.2 to 288.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	8	SF	\$40	\$320
26357	291.8 to 298.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	33	SF	\$40	\$1,300
26358	301.6 to 305.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,220
TOTAL COST FOR: NE side of 5TH ST Starting at: TRINITY AVE							\$58,800.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	1909261148	5TH ST	ROBERTSON BLVD	TRINITY AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
26274	0.0 to 2.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	14	SF	\$120	\$1,680	
26276	2.8 to 4.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	10	SF	\$120	\$1,140	
26277	4.9 to 8.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340	
26278	11.1 to 20.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,820	
55214	19.6 to 20.6 feet	Vertical Change	.3	5 ft	5	REF			
26283	23.3 to 32.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	48	SF	\$120	\$5,760	
26286	35.0 to 49.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	72	SF	\$120	\$8,640	
26290	49.7 to 57.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	40	SF	\$120	\$4,800	
59511	54.0 to 77.2 feet	Driveway				REF			
26293	61.4 to 65.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	18	SF	\$40	\$740	
26294	69.3 to 85.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	82	SF	\$40	\$3,280	
26297	88.5 to 94.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,660	
26299	99.5 to 102.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620	
26300	104.9 to 125.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	102	SF	\$120	\$12,240	
59512	108.3 to 130.0 feet	Driveway				REF			
26303	133.1 to 140.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320	
55215	140.8 to 141.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
59513	145.9 to 162.8 feet	Driveway				REF			
26305	148.0 to 152.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	23	SF	\$40	\$920	
26306	156.7 to 161.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	25	SF	\$40	\$1,000	
26307	181.1 to 183.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680	
26308	187.6 to 194.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,140	
26310	203.5 to 210.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,440	
59514	214.3 to 239.3 feet	Driveway				REF			
26311	234.2 to 238.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	23	SF	\$40	\$920	
26313	257.4 to 267.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,300	
26314	274.1 to 279.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000	
26316	283.8 to 291.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,680	
26318	303.1 to 305.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261148	5TH ST	ROBERTSON BLVD	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
TOTAL COST FOR: SW							<i>side of 5TH ST Starting at: ROBERTSON BLVD</i>	\$84,935.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	1909261151	5TH ST	TRINITY AVE	ORANGE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
26203	3.1 to 7.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,460	
26205	7.3 to 23.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	79	SF	\$120	\$9,480	
57438	17.2 to 18.2 feet	Vertical Change	1.3	5 ft	5	REF			
26210	23.1 to 35.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,620	
26212	41.3 to 53.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	60	SF	\$120	\$7,200	
55211	56.5 to 57.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
57561	58.3 to 59.3 feet	Vertical Change	2.4	5 ft	5	SF	\$75	\$375	
26214	60.8 to 96.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	176	SF	\$120	\$21,120	
55212	96.0 to 97.0 feet	Vertical Change	.3	5 ft	5	REF			
26221	96.3 to 97.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	7	SF	\$120	\$780	
26222	98.3 to 101.0 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	14	SF	\$120	\$1,620	
26224	101.0 to 123.3 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	112	SF	\$120	\$13,380	
55213	128.6 to 129.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
26230	136.5 to 145.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,520	
56783	136.8 to 137.8 feet	Vertical Change	.5	5 ft	5	REF			
59510	140.0 to 161.3 feet	Driveway				REF			
26233	150.3 to 154.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	19	SF	\$40	\$760	
26235	154.1 to 156.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	12	SF	\$40	\$480	
26237	156.8 to 158.9 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	10	SF	\$40	\$420	
26239	161.8 to 184.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	113	SF	\$120	\$13,560	
26245	184.4 to 204.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	100	SF	\$120	\$11,940	
26250	204.3 to 207.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800	
26252	209.8 to 217.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,500	
26254	219.0 to 224.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	28	SF	\$120	\$3,300	
57357	221.8 to 222.8 feet	Vertical Change	1	5 ft	5	REF			
26258	224.7 to 225.7 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	5	SF	\$120	\$600	
26259	225.7 to 236.9 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	56	SF	\$120	\$6,720	
40775	225.8 to 231.3 feet	Running Slope	5.0-6.0%	5 ft	28	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261151	5TH ST	TRINITY AVE	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26262	237.5 to 244.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	33	SF	\$120	\$3,960
26264	244.3 to 263.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	95	SF	\$120	\$11,400
57642	261.9 to 262.9 feet	Vertical Change	3.4	5 ft	5	REF		
26268	263.3 to 264.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$720
26269	264.5 to 284.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	99	SF	\$120	\$11,820
26272	286.8 to 287.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$660
57195	287.4 to 288.4 feet	Vertical Change	.7	5 ft	5	REF		
26273	291.8 to 299.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,680
TOTAL COST FOR: SW side of 5TH ST Starting at: TRINITY AVE							\$147,625.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261154	5TH ST	ORANGE AVE	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26151	3.1 to 12.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,700
26152	16.2 to 74.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	293	SF	\$120	\$35,160
59508	72.1 to 95.3 feet	Driveway				REF		
26166	88.4 to 141.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	265	SF	\$40	\$10,600
59509	140.8 to 164.2 feet	Driveway				REF		
26179	144.3 to 145.5 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	6	SF	\$40	\$240
26180	146.7 to 149.6 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	15	SF	\$40	\$580
26181	149.6 to 153.5 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	20	SF	\$40	\$780
26183	153.5 to 160.1 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	33	SF	\$40	\$1,320
26186	161.2 to 162.2 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	5	SF	\$40	\$200
40774	162.0 to 164.0 feet	Running Slope	5.0-6.0%	5 ft	10	REF		
26187	165.3 to 167.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,440
26188	170.4 to 203.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	165	SF	\$120	\$19,800
55210	200.8 to 201.8 feet	Vertical Change	.3	5 ft	5	REF		
26189	206.7 to 219.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	65	SF	\$120	\$7,800
26192	223.4 to 260.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	187	SF	\$120	\$22,500
26199	266.3 to 276.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,180
26200	283.7 to 301.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	88	SF	\$120	\$10,560
TOTAL COST FOR: SW side of 5TH ST Starting at: ORANGE AVE							\$122,860.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261158	5TH ST	HUMBOLDT AVE	ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26081	1.3 to 19.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	92	SF	\$120	\$10,980
26085	20.4 to 35.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	77	SF	\$120	\$9,240
26089	35.9 to 56.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	101	SF	\$120	\$12,060
26093	60.5 to 68.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	40	SF	\$120	\$4,740
26095	70.5 to 94.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	118	SF	\$120	\$14,100
26102	99.8 to 109.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,700
26104	112.9 to 138.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	130	SF	\$120	\$15,600
55206	137.0 to 138.0 feet	Vertical Change	.3	5 ft	5	REF		
59506	139.6 to 160.2 feet	Driveway				REF		
26111	143.1 to 151.3 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	41	SF	\$40	\$1,640
26115	151.5 to 153.1 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	8	SF	\$40	\$320
26116	154.4 to 160.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	28	SF	\$40	\$1,120
26118	160.2 to 224.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	321	SF	\$40	\$12,840
55207	212.2 to 213.2 feet	Vertical Change	.3	5 ft	5	REF		
59507	213.0 to 249.4 feet	Driveway				REF		
26133	227.3 to 229.8 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	13	SF	\$40	\$500
26134	231.3 to 239.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	40	SF	\$40	\$1,580
26137	242.9 to 248.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	29	SF	\$40	\$1,140
26138	255.8 to 258.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,680
26139	262.5 to 271.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,220
26142	274.0 to 281.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	37	SF	\$120	\$4,440
26144	281.7 to 286.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,820
26145	289.0 to 297.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	44	SF	\$120	\$5,280
55208	289.4 to 290.4 feet	Vertical Change	.3	5 ft	5	REF		
55209	297.1 to 298.1 feet	Vertical Change	.3	5 ft	5	REF		
26149	297.8 to 305.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,560
TOTAL COST FOR: SW side of 5TH ST Starting at: HUMBOLDT AVE							\$115,560.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
SW	1909261201	5TH ST	ALAMEDA AVE	COLUSA AVE				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26033	4.0 to 18.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,820
26038	21.1 to 38.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	88	SF	\$120	\$10,560
26040	41.4 to 54.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	66	SF	\$120	\$7,920
26043	61.1 to 94.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	167	SF	\$120	\$20,040
56345	75.3 to 76.3 feet	Vertical Change	.4	5 ft	5	REF		
26048	98.7 to 125.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	133	SF	\$120	\$15,960
26054	129.5 to 130.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780
26055	133.5 to 137.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	22	SF	\$120	\$2,580
59503	137.4 to 158.5 feet	Driveway				REF		
26057	139.8 to 142.0 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	11	SF	\$40	\$440
26059	143.3 to 144.4 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	5	SF	\$40	\$220
26060	147.8 to 155.0 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	36	SF	\$40	\$1,440
26061	164.2 to 173.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	46	SF	\$120	\$5,460
26063	173.6 to 178.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,940
59504	180.7 to 212.3 feet	Driveway				REF		
55203	181.7 to 182.7 feet	Vertical Change	.3	5 ft	5	REF		
55204	196.0 to 197.0 feet	Vertical Change	.3	5 ft	5	REF		
26064	220.8 to 237.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	85	SF	\$120	\$10,200
55205	224.9 to 225.9 feet	Vertical Change	.3	5 ft	5	REF		
26068	244.8 to 273.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	141	SF	\$120	\$16,920
59505	273.6 to 286.3 feet	Driveway				REF		
26075	277.7 to 278.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$240
26076	282.9 to 291.3 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	42	SF	\$40	\$1,680
26080	298.2 to 299.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660
TOTAL COST FOR: SW side of 5TH ST Starting at: ALAMEDA AVE								\$106,860.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261310	11TH ST	ROBERTSON BLVD	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25945	13.8 to 46.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	148	SF	\$120	\$17,712
95	28.5 to 29.5 feet	Continuous Width		5 ft	5	SF	\$120	\$540
25954	47.2 to 150.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	466	SF	\$120	\$55,944
56781	87.8 to 88.8 feet	Vertical Change	.5	5 ft	5	REF		
55192	103.0 to 104.0 feet	Vertical Change	.3	5 ft	5	REF		
57319	108.4 to 109.4 feet	Vertical Change	.9	5 ft	5	REF		
56782	111.6 to 112.6 feet	Vertical Change	.5	5 ft	5	REF		
57356	115.3 to 116.3 feet	Vertical Change	1	5 ft	5	REF		
55193	117.1 to 118.1 feet	Vertical Change	.3	5 ft	5	REF		
56342	120.4 to 130.9 feet	Vertical Change	.4	5 ft	47	REF		
55198	133.8 to 134.8 feet	Vertical Change	.3	5 ft	5	REF		
56343	137.5 to 138.5 feet	Vertical Change	.4	5 ft	5	REF		
57058	141.3 to 142.3 feet	Vertical Change	.6	5 ft	5	REF		
57517	143.8 to 144.8 feet	Vertical Change	1.9	5 ft	5	REF		
56344	146.3 to 147.3 feet	Vertical Change	.4	5 ft	5	REF		
59497	151.4 to 181.3 feet	Driveway				REF		
25982	181.2 to 187.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	29	SF	\$40	\$1,170
25985	188.4 to 208.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	91	SF	\$120	\$10,908
25987	208.8 to 217.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,590
59498	215.8 to 263.3 feet	Driveway				REF		
40765	221.4 to 222.9 feet	Running Slope	8.0-9.0%	5 ft	7	REF		
25990	223.3 to 225.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	9	SF	\$40	\$360
25991	243.7 to 252.9 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	41	SF	\$40	\$1,656
40766	256.9 to 258.8 feet	Running Slope	7.0-8.0%	5 ft	9	REF		
55199	265.6 to 266.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
55200	272.4 to 273.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
25993	289.3 to 294.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,862
25996	294.6 to 302.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	34	SF	\$120	\$4,050

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261310	11TH ST	ROBERTSON BLVD	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
26002	332.0 to 342.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,400
26006	408.9 to 411.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,242
26007	415.0 to 420.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,132
26010	426.8 to 429.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,296
55201	429.3 to 430.3 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
26011	441.4 to 444.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,404
59501	445.0 to 466.3 feet	Driveway				REF		
55202	467.0 to 468.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
26012	477.8 to 500.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	100	SF	\$120	\$12,042
59502	501.3 to 524.0 feet	Driveway				REF		
26017	507.6 to 520.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	59	SF	\$40	\$2,376
40773	521.5 to 523.0 feet	Running Slope	5.0-6.0%	5 ft	7	REF		
57414	527.3 to 528.3 feet	Vertical Change	1.2	5 ft	5	SF	\$75	\$338
26022	528.8 to 530.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$810
26023	533.6 to 543.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,238
26027	543.7 to 559.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	70	SF	\$120	\$8,370
26030	559.2 to 561.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,404
26031	565.4 to 567.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
26032	591.5 to 595.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,998
TOTAL COST FOR: SW side of 11TH ST Starting at: ROBERTSON BLVD							\$147,271.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261314	11TH ST	ORANGE AVE	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25930	0.0 to 2.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	9	SF	\$120	\$1,056
94	3.1 to 4.1 feet	Continuous Width		4 ft	4	SF	\$120	\$480
25931	38.3 to 43.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	22	SF	\$120	\$2,640
59494	47.7 to 79.3 feet	Driveway				REF		
25933	55.6 to 62.7 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	28	SF	\$40	\$1,136
25935	66.5 to 72.1 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	22	SF	\$40	\$896
57057	71.9 to 72.9 feet	Vertical Change	.6	4 ft	4	REF		
59495	128.3 to 160.9 feet	Driveway				REF		
25936	145.6 to 150.3 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	19	SF	\$40	\$752
25939	158.9 to 162.9 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	16	SF	\$40	\$640
25940	176.8 to 177.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	4	SF	\$120	\$480
55191	195.4 to 196.4 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$300
25941	205.3 to 207.4 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	8	SF	\$120	\$1,008
59496	242.5 to 282.3 feet	Driveway				REF		
25942	257.8 to 266.4 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	34	SF	\$40	\$1,376
TOTAL COST FOR: SW side of 11TH ST Starting at: ORANGE AVE							\$10,764.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261316	11TH ST	HUMBOLDT AVE	ENTRANCE TO SCHOOL	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25921	6.4 to 35.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	146	SF	\$120	\$17,460
25928	36.3 to 56.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	99	SF	\$120	\$11,880
TOTAL COST FOR: NE side of 11TH ST Starting at: HUMBOLDT AVE							\$29,340.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261317	11TH ST	ENTRANCE TO SCHOOL	ENTRANCE TO SCHOOL	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55189	1.7 to 2.7 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
55190	12.1 to 13.1 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: NE side of 11TH ST Starting at: ENTRANCE TO SCHOOL								\$750.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261319	11TH ST	ENTRANCE TO SCHOOL	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25917	17.1 to 22.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,360
55188	37.7 to 38.7 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
25919	47.3 to 48.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$720
25920	62.4 to 64.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200
TOTAL COST FOR: NE side of 11TH ST Starting at: ENTRANCE TO SCHOOL								\$5,655.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261323	11TH ST	ORANGE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25891	10.1 to 14.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,214
93	15.7 to 16.7 feet	Continuous Width		5 ft	5	SF	\$120	\$540
25892	20.7 to 49.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	131	SF	\$120	\$15,768
25900	53.3 to 74.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	95	SF	\$120	\$11,448
25905	77.0 to 87.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,400
25908	91.7 to 107.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	69	SF	\$120	\$8,316
57437	96.8 to 97.8 feet	Vertical Change	1.3	5 ft	5	REF		
59493	105.6 to 138.9 feet	Driveway				REF		
40763	107.7 to 109.0 feet	Running Slope	7.0-8.0%	5 ft	6	REF		
25914	111.4 to 136.0 feet	Cross Slope (Driveway)	>15%	5 ft	111	SF	\$40	\$4,428
56341	137.8 to 138.8 feet	Vertical Change	.4	5 ft	5	REF		
40764	138.2 to 139.3 feet	Running Slope	6.0-7.0%	5 ft	5	REF		
TOTAL COST FOR: NE side of 11TH ST Starting at: ORANGE AVE							\$48,114.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1909261329	11TH ST	SIDEWALK BEGINS	ROBERTSON BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
25864	2.2 to 5.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,566	
25865	10.4 to 16.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,510	
25868	19.5 to 21.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	9	SF	\$120	\$1,080	
59492	21.4 to 66.2 feet	Driveway				REF			
25869	26.3 to 61.1 feet	Cross Slope (Driveway)	>15%	5 ft	157	SF	\$40	\$6,264	
25873	67.3 to 93.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	120	SF	\$120	\$14,364	
25877	97.8 to 129.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	144	SF	\$120	\$17,280	
25886	129.8 to 139.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	43	SF	\$120	\$5,184	
92	140.1 to 141.1 feet	Continuous Width		5 ft	5	SF	\$120	\$540	

TOTAL COST FOR: NE	<i>side of 11TH ST Starting at: SIDEWALK BEGINS</i>	\$49,788.00
---------------------------	---	--------------------

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261335	10TH ST	TRINITY AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25827	0.0 to 14.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	64	SF	\$120	\$7,668
57552	2.5 to 3.5 feet	Vertical Change	2.3	5 ft	5	REF		
25833	16.7 to 24.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	34	SF	\$120	\$4,104
57056	23.6 to 24.6 feet	Vertical Change	.6	5 ft	5	REF		
25835	25.9 to 36.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,670
57388	33.8 to 34.8 feet	Vertical Change	1.1	5 ft	5	REF		
25837	36.6 to 56.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	89	SF	\$120	\$10,692
25842	56.8 to 83.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	122	SF	\$120	\$14,580
25853	84.9 to 89.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	22	SF	\$120	\$2,646
59491	88.0 to 107.4 feet	Driveway				REF		
40761	89.4 to 90.9 feet	Running Slope	5.0-6.0%	5 ft	7	REF		
25855	93.9 to 103.3 feet	Cross Slope (Driveway)	13.014	5 ft	42	SF	\$40	\$1,692
40762	105.0 to 106.4 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
55187	105.8 to 106.8 feet	Vertical Change	.3	5 ft	5	REF		
25859	108.2 to 109.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$594
25860	113.2 to 127.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,452
56780	126.3 to 127.3 feet	Vertical Change	.5	5 ft	5	REF		
TOTAL COST FOR: SW side of 10TH ST Starting at: TRINITY AVE								\$55,098.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261339	10TH ST	ORANGE AVE	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40759	1.1 to 2.1 feet	Running Slope	6.0-7.0%	5 ft	4	SF	\$120	\$540
55186	2.5 to 3.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
25811	27.8 to 33.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,240
25813	58.6 to 61.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	13	SF	\$120	\$1,566
25814	82.2 to 84.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
56339	176.7 to 177.7 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338
25815	187.3 to 188.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$540
25816	192.1 to 193.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$918
25817	194.7 to 196.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$702
25818	203.2 to 206.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	16	SF	\$120	\$1,944
25819	208.2 to 209.2 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	5	SF	\$120	\$540
25820	217.4 to 219.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,134
25821	228.6 to 230.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,188
25823	233.1 to 234.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$540
25824	248.7 to 250.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$864
56340	298.6 to 299.6 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338
25825	300.1 to 303.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,998
40760	302.9 to 304.0 feet	Running Slope	8.0-9.0%	5 ft	5	REF		
TOTAL COST FOR: SW side of 10TH ST Starting at: ORANGE AVE							\$17,806.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261343	10TH ST	SIDEWALK BEGINS	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25784	2.4 to 7.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	24	SF	\$120	\$2,916
25786	7.8 to 15.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	36	SF	\$120	\$4,320
25788	16.3 to 44.7 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	128	SF	\$120	\$15,336
25794	45.0 to 61.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	72	SF	\$120	\$8,694
55184	55.0 to 56.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
25798	63.3 to 84.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	97	SF	\$120	\$11,610
55185	66.1 to 67.1 feet	Vertical Change	.3	5 ft	5	REF		
25801	88.3 to 90.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,026
25802	91.5 to 107.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	72	SF	\$120	\$8,586
25807	110.4 to 111.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$756
25808	117.7 to 119.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$702
25809	131.2 to 136.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,916
TOTAL COST FOR: NE side of 10TH ST Starting at: SIDEWALK BEGINS							\$57,199.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261347	10TH ST	ORANGE AVE	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25741	0.8 to 12.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	58	SF	\$120	\$6,900
25742	14.5 to 15.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$780
25743	16.5 to 21.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$2,940
25745	26.4 to 41.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	77	SF	\$120	\$9,240
56779	27.1 to 28.1 feet	Vertical Change	.5	5 ft	5	REF		
25748	42.5 to 63.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	104	SF	\$120	\$12,480
59488	63.4 to 77.3 feet	Driveway				REF		
25753	78.4 to 80.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,380
25754	83.8 to 92.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,280
25757	96.0 to 107.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	55	SF	\$120	\$6,600
25758	112.5 to 124.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,380
56337	124.4 to 125.4 feet	Vertical Change	.4	5 ft	5	REF		
25762	124.8 to 126.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	11	SF	\$120	\$1,260
25763	129.3 to 137.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	39	SF	\$120	\$4,680
57055	135.4 to 136.4 feet	Vertical Change	.6	5 ft	5	REF		
59489	137.5 to 157.5 feet	Driveway				REF		
55180	156.8 to 162.9 feet	Vertical Change	.3	5 ft	30	REF		
25768	157.4 to 163.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	30	SF	\$40	\$1,180
25770	165.8 to 177.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,720
25773	185.3 to 186.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
59490	185.8 to 221.2 feet	Driveway				REF		
56338	186.5 to 187.5 feet	Vertical Change	.4	5 ft	5	REF		
40757	187.7 to 189.1 feet	Running Slope	6.0-7.0%	5 ft	7	REF		
25774	189.8 to 218.6 feet	Cross Slope (Driveway)	>15%	5 ft	144	SF	\$40	\$5,760
55183	219.2 to 220.2 feet	Vertical Change	.3	5 ft	5	REF		
40758	219.6 to 221.1 feet	Running Slope	5.0-6.0%	5 ft	8	REF		
25775	238.8 to 245.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,260
25776	249.8 to 305.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	277	SF	\$120	\$33,180

TOTAL COST FOR: NE side of 10TH ST Starting at: ORANGE AVE \$110,620.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261350	10TH ST	SIDEWALK BEGINS	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25726	0.0 to 1.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
56777	4.6 to 5.6 feet	Vertical Change	.5	5 ft	5	REF		
25727	4.8 to 5.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660
56333	9.5 to 10.5 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
40755	19.6 to 20.8 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
55177	19.8 to 20.8 feet	Vertical Change	.3	5 ft	5	REF		
25728	20.3 to 21.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$900
25729	39.1 to 42.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220
25730	45.3 to 47.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
25732	48.3 to 52.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	22	SF	\$120	\$2,580
40756	50.0 to 51.6 feet	Running Slope	5.0-6.0%	5 ft	8	REF		
57355	53.3 to 54.3 feet	Vertical Change	1	5 ft	5	SF	\$75	\$375
55178	55.9 to 59.6 feet	Vertical Change	.3	5 ft	19	REF		
25733	56.9 to 62.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060
59487	60.9 to 78.0 feet	Driveway				REF		
25736	67.3 to 73.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	31	SF	\$40	\$1,220
25739	73.4 to 77.9 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	23	SF	\$40	\$900
57318	79.2 to 80.2 feet	Vertical Change	.9	5 ft	5	SF	\$75	\$375
56335	107.7 to 108.7 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
56336	111.4 to 115.1 feet	Vertical Change	.4	5 ft	19	LF	\$75	\$1,388
56778	126.2 to 127.2 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375
TOTAL COST FOR: NE side of 10TH ST Starting at: SIDEWALK BEGINS							\$17,142.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	1909261354	9TH ST	ROBERTSON BLVD	TRINITY AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
25687	2.8 to 6.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	17	SF	\$120	\$2,040	
25688	9.8 to 12.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	12	SF	\$120	\$1,479	
25689	18.3 to 22.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	19	SF	\$120	\$2,244	
25690	30.6 to 53.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	96	SF	\$120	\$11,475	
25695	57.3 to 64.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	32	SF	\$120	\$3,876	
59484	64.2 to 84.8 feet	Driveway				REF			
25697	69.8 to 73.3 feet	Cross Slope (Driveway)	13.014	4 ft	15	SF	\$40	\$595	
25699	73.8 to 81.3 feet	Cross Slope (Driveway)	>15%	4 ft	32	SF	\$40	\$1,275	
25702	85.9 to 98.8 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	55	SF	\$120	\$6,579	
25705	117.8 to 131.7 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	59	SF	\$120	\$7,089	
59485	131.3 to 154.1 feet	Driveway				REF			
40752	134.1 to 135.3 feet	Running Slope	7.0-8.0%	4 ft	5	REF			
55171	134.2 to 135.2 feet	Vertical Change	.3	4 ft	4	REF			
55172	140.2 to 141.2 feet	Vertical Change	.3	4 ft	4	REF			
25708	142.3 to 143.9 feet	Cross Slope (Driveway)	9.0-10.0%	4 ft	7	SF	\$40	\$272	
25709	144.4 to 148.8 feet	Cross Slope (Driveway)	11.0-12.0%	4 ft	19	SF	\$40	\$748	
40753	151.4 to 154.2 feet	Running Slope	7.0-8.0%	4 ft	12	REF			
25712	161.1 to 167.2 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	26	SF	\$120	\$3,111	
25714	170.8 to 173.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	9	SF	\$120	\$1,122	
55173	194.0 to 195.0 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$319	
59486	199.5 to 215.3 feet	Driveway				REF			
25715	199.6 to 200.6 feet	Cross Slope (Driveway)	2.0-3.0%	4 ft	4	SF	\$40	\$170	
40754	200.5 to 203.1 feet	Running Slope	5.0-6.0%	4 ft	11	REF			
25716	206.3 to 212.1 feet	Cross Slope (Driveway)	14.0-15.0%	4 ft	25	SF	\$40	\$986	
55174	214.6 to 215.6 feet	Vertical Change	.3	4 ft	4	REF			
25718	215.6 to 218.4 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	12	SF	\$120	\$1,428	
25719	221.6 to 224.1 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	11	SF	\$120	\$1,275	
25720	226.3 to 231.6 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	23	SF	\$120	\$2,703	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261354	9TH ST	ROBERTSON BLVD	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25721	234.8 to 246.0 feet	Cross Slope (PAR)	3.0-4.0%	4 ft	48	SF	\$120	\$5,712
25723	246.0 to 251.9 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	25	SF	\$120	\$3,009
56332	255.7 to 256.7 feet	Vertical Change	.4	4 ft	4	LF	\$75	\$319
25725	279.3 to 287.0 feet	Cross Slope (PAR)	2.0-3.0%	4 ft	33	SF	\$120	\$3,927
55175	281.4 to 282.4 feet	Vertical Change	.3	4 ft	4	REF		
55176	296.5 to 297.5 feet	Vertical Change	.3	4 ft	4	LF	\$75	\$319
TOTAL COST FOR: SW side of 9TH ST Starting at: ROBERTSON BLVD							\$62,071.25	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261357	9TH ST	TRINITY AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57054	2.5 to 3.5 feet	Vertical Change	.6	5 ft	5	SF	\$75	\$338
25661	22.1 to 30.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	36	SF	\$120	\$4,320
25663	32.8 to 44.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,264
25666	47.8 to 60.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,696
55169	53.8 to 54.8 feet	Vertical Change	.3	5 ft	5	REF		
25670	67.3 to 82.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	70	SF	\$120	\$8,370
55170	74.3 to 75.3 feet	Vertical Change	.3	5 ft	5	REF		
56775	84.3 to 85.3 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$338
25674	85.4 to 86.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$540
25675	90.6 to 117.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	120	SF	\$120	\$14,364
56776	110.1 to 111.1 feet	Vertical Change	.5	5 ft	5	REF		
25679	117.4 to 126.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	39	SF	\$120	\$4,698
25684	126.1 to 132.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,402
25686	135.9 to 141.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,078
TOTAL COST FOR: SW side of 9TH ST Starting at: TRINITY AVE							\$52,407.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261401	9TH ST	SIDEWALK BEGINS	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25635	0.0 to 3.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	17	SF	\$120	\$2,052
59482	3.3 to 19.7 feet	Driveway				REF		
40748	4.0 to 6.6 feet	Running Slope	7.0-8.0%	5 ft	12	REF		
25636	7.9 to 16.9 feet	Cross Slope (Driveway)	13.014	5 ft	40	SF	\$40	\$1,620
40749	17.9 to 18.9 feet	Running Slope	6.0-7.0%	5 ft	5	REF		
25639	21.4 to 31.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	44	SF	\$120	\$5,238
25641	31.3 to 35.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$1,998
59483	34.3 to 69.3 feet	Driveway				REF		
55166	35.1 to 36.1 feet	Vertical Change	.3	5 ft	5	REF		
40750	35.2 to 36.6 feet	Running Slope	6.0-7.0%	5 ft	6	REF		
40751	36.6 to 37.9 feet	Running Slope	5.0-6.0%	5 ft	6	REF		
57658	38.7 to 39.7 feet	Vertical Change	3.5	5 ft	5	REF		
25643	40.8 to 50.5 feet	Cross Slope (Driveway)	>15%	5 ft	44	SF	\$40	\$1,746
25646	50.5 to 64.1 feet	Cross Slope (Driveway)	13.014	5 ft	61	SF	\$40	\$2,448
57194	66.7 to 67.7 feet	Vertical Change	.7	5 ft	5	REF		
25650	70.3 to 93.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	103	SF	\$120	\$12,312
55167	79.8 to 80.8 feet	Vertical Change	.3	5 ft	5	REF		
25651	93.7 to 112.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	84	SF	\$120	\$10,098
55168	105.5 to 106.5 feet	Vertical Change	.3	5 ft	5	REF		
25654	115.6 to 121.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,078
25656	121.5 to 131.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	44	SF	\$120	\$5,292
TOTAL COST FOR: SW side of 9TH ST Starting at: SIDEWALK BEGINS							\$45,882.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1909261405	9TH ST	HUMBOLDT AVE	ORANGE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
25588	0.0 to 13.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,398	
25592	19.5 to 27.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,050	
25594	33.6 to 36.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,458	
55161	35.2 to 36.2 feet	Vertical Change	.3	5 ft	5	REF			
57052	70.2 to 71.2 feet	Vertical Change	.6	5 ft	5	SF	\$75	\$338	
25595	76.7 to 87.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,616	
25597	89.2 to 105.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,856	
25600	105.6 to 106.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	6	SF	\$120	\$702	
59479	106.0 to 128.7 feet	Driveway				REF			
25601	110.3 to 113.5 feet	Cross Slope (Driveway)	13.014	5 ft	14	SF	\$40	\$576	
25603	113.8 to 125.7 feet	Cross Slope (Driveway)	>15%	5 ft	54	SF	\$40	\$2,142	
55162	127.0 to 128.0 feet	Vertical Change	.3	5 ft	5	REF			
25605	129.0 to 135.3 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	28	SF	\$40	\$1,134	
59480	134.4 to 156.6 feet	Driveway				REF			
40747	136.7 to 137.8 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
25606	138.6 to 144.5 feet	Cross Slope (Driveway)	>15%	5 ft	27	SF	\$40	\$1,062	
55163	141.3 to 142.3 feet	Vertical Change	.3	5 ft	5	REF			
25608	144.5 to 154.1 feet	Cross Slope (Driveway)	13.014	5 ft	43	SF	\$40	\$1,728	
55164	155.1 to 156.1 feet	Vertical Change	.3	5 ft	5	REF			
25612	157.8 to 187.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	135	SF	\$120	\$16,146	
91	158.3 to 159.3 feet	Continuous Width		5 ft	5	SF	\$120	\$540	
59481	187.4 to 203.1 feet	Driveway				REF			
25619	192.3 to 198.8 feet	Cross Slope (Driveway)	>15%	5 ft	29	SF	\$40	\$1,170	
25620	199.3 to 200.4 feet	Cross Slope (Driveway)	13.014	5 ft	5	SF	\$40	\$198	
25621	204.0 to 211.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	33	SF	\$120	\$3,942	
25622	212.2 to 235.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	104	SF	\$120	\$12,474	
57053	212.7 to 213.7 feet	Vertical Change	.6	5 ft	5	REF			
56331	218.9 to 219.9 feet	Vertical Change	.4	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261405	9TH ST	HUMBOLDT AVE	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25626	237.8 to 242.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	23	SF	\$120	\$2,754
55165	244.8 to 245.8 feet	Vertical Change	.3	5 ft	5	REF		
25627	245.1 to 249.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,484
25629	251.8 to 261.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	43	SF	\$120	\$5,130
25630	261.3 to 264.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,782
25631	267.1 to 290.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	104	SF	\$120	\$12,528
TOTAL COST FOR: NE side of 9TH ST Starting at: HUMBOLDT AVE							\$94,207.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1909261408	9TH ST	ORANGE AVE	TRINITY AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
25531	4.6 to 36.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	145	SF	\$120	\$17,388	
55157	34.7 to 35.7 feet	Vertical Change	.3	5 ft	5	REF			
25536	36.8 to 54.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	77	SF	\$120	\$9,288	
57317	51.8 to 52.8 feet	Vertical Change	.9	5 ft	5	REF			
25543	54.0 to 55.0 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	5	SF	\$120	\$540	
25544	56.2 to 63.7 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	34	SF	\$120	\$4,050	
25547	66.7 to 75.8 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	41	SF	\$120	\$4,914	
25550	76.0 to 77.3 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	6	SF	\$120	\$702	
25551	79.3 to 82.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	16	SF	\$120	\$1,890	
25553	85.0 to 112.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	123	SF	\$120	\$14,742	
25559	112.3 to 135.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	104	SF	\$120	\$12,420	
56774	113.5 to 114.5 feet	Vertical Change	.5	5 ft	5	REF			
25562	135.3 to 136.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	7	SF	\$120	\$810	
59478	135.9 to 158.7 feet	Driveway				REF			
55158	141.0 to 142.0 feet	Vertical Change	.3	5 ft	5	REF			
25563	142.2 to 143.7 feet	Cross Slope (Driveway)	13.014	5 ft	7	SF	\$40	\$270	
25564	146.7 to 148.3 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	7	SF	\$40	\$288	
55159	146.9 to 147.9 feet	Vertical Change	.3	5 ft	5	REF			
25565	150.6 to 156.1 feet	Cross Slope (Driveway)	13.014	5 ft	25	SF	\$40	\$990	
40746	156.3 to 158.1 feet	Running Slope	8.0-9.0%	5 ft	8	REF			
90	159.4 to 160.4 feet	Continuous Width		5 ft	5	SF	\$120	\$540	
25567	164.8 to 166.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$756	
56328	178.6 to 179.6 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338	
25568	188.9 to 191.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,296	
25570	196.6 to 198.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,242	
57455	199.0 to 200.0 feet	Vertical Change	1.4	5 ft	5	SF	\$75	\$338	
57354	203.0 to 204.0 feet	Vertical Change	1	5 ft	5	SF	\$75	\$338	
25572	215.2 to 229.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,560	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261408	9TH ST	ORANGE AVE	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56329	252.1 to 253.1 feet	Vertical Change	.4	5 ft	5	REF		
25577	252.8 to 254.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,134
25579	255.2 to 261.5 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	28	SF	\$120	\$3,402
25581	261.5 to 263.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$972
25582	263.3 to 300.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	167	SF	\$120	\$19,980
55160	278.0 to 279.0 feet	Vertical Change	.3	5 ft	5	REF		
56330	301.1 to 302.1 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338
25587	304.6 to 309.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	21	SF	\$120	\$2,538
TOTAL COST FOR: NE side of 9TH ST Starting at: ORANGE AVE							\$109,062.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1909261414	9TH ST	TRINITY AVE	ROBERTSON BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
25472	2.5 to 10.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,536	
55153	7.5 to 8.5 feet	Vertical Change	.3	5 ft	5	REF			
25476	10.9 to 72.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	279	SF	\$120	\$33,426	
25486	74.9 to 77.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	13	SF	\$120	\$1,512	
25487	77.7 to 81.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,890	
25488	87.6 to 91.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	16	SF	\$120	\$1,944	
25489	94.3 to 125.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	139	SF	\$120	\$16,632	
59474	123.9 to 142.9 feet	Driveway				REF			
25498	132.0 to 139.1 feet	Cross Slope (Driveway)	13.014	5 ft	32	SF	\$40	\$1,278	
40743	142.0 to 143.0 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
55154	142.7 to 143.7 feet	Vertical Change	.3	5 ft	5	REF			
25501	146.1 to 149.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	16	SF	\$120	\$1,890	
59475	150.3 to 173.5 feet	Driveway				REF			
25502	155.8 to 166.6 feet	Cross Slope (Driveway)	13.014	5 ft	49	SF	\$40	\$1,944	
55155	164.9 to 165.9 feet	Vertical Change	.3	5 ft	5	REF			
25505	167.3 to 170.1 feet	Cross Slope (Driveway)	>15%	5 ft	13	SF	\$40	\$504	
40744	169.8 to 170.8 feet	Running Slope	6.0-7.0%	5 ft	5	REF			
55156	171.5 to 172.5 feet	Vertical Change	.3	5 ft	5	REF			
88	174.3 to 175.3 feet	Continuous Width		5 ft	5	SF	\$120	\$540	
25506	175.3 to 184.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	42	SF	\$120	\$5,022	
59476	184.3 to 206.9 feet	Driveway				REF			
57193	185.9 to 186.9 feet	Vertical Change	.7	5 ft	5	REF			
25507	189.8 to 193.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	18	SF	\$40	\$738	
25508	199.1 to 200.1 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	5	SF	\$40	\$180	
25509	207.1 to 208.5 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$252	
25510	208.5 to 274.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	295	SF	\$120	\$35,370	
59477	273.3 to 288.3 feet	Driveway				REF			
25526	278.4 to 285.2 feet	Cross Slope (Driveway)	>15%	5 ft	31	SF	\$40	\$1,224	
40745	285.4 to 287.7 feet	Running Slope	5.0-6.0%	5 ft	10	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261414	9TH ST	TRINITY AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25527	289.5 to 315.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	117	SF	\$120	\$13,986
57316	292.1 to 293.1 feet	Vertical Change	.9	5 ft	5	REF		
89	315.0 to 316.0 feet	Continuous Width		5 ft	5	SF	\$120	\$540
TOTAL COST FOR: NE side of 9TH ST Starting at: TRINITY AVE							\$123,408.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261417	8TH ST	ROBERTSON BLVD	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25457	2.5 to 4.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,242
25458	14.1 to 15.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$540
57436	44.5 to 45.5 feet	Vertical Change	1.3	5 ft	5	SF	\$75	\$338
25459	61.3 to 71.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,508
59471	70.7 to 91.8 feet	Driveway				REF		
25462	77.5 to 88.0 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	47	SF	\$40	\$1,890
40740	89.0 to 90.7 feet	Running Slope	6.0-7.0%	5 ft	8	REF		
55149	90.2 to 91.2 feet	Vertical Change	.3	5 ft	5	REF		
25464	93.0 to 96.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,782
25465	100.5 to 112.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,480
59472	110.8 to 126.3 feet	Driveway				REF		
40741	113.3 to 114.7 feet	Running Slope	8.0-9.0%	5 ft	6	REF		
25468	116.8 to 124.3 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	34	SF	\$40	\$1,350
40742	125.1 to 126.6 feet	Running Slope	7.0-8.0%	5 ft	7	REF		
25471	128.4 to 129.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$702
59473	131.6 to 148.7 feet	Driveway				REF		
55150	134.4 to 135.4 feet	Vertical Change	.3	5 ft	5	REF		
55151	139.9 to 140.9 feet	Vertical Change	.3	5 ft	5	REF		
56773	145.0 to 146.0 feet	Vertical Change	.5	5 ft	5	REF		
55152	148.6 to 149.6 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: SW side of 8TH ST Starting at: ROBERTSON BLVD							\$19,831.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261421	8TH ST	TRINITY AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25428	0.0 to 4.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,430
25430	5.8 to 15.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	42	SF	\$120	\$5,076
55146	10.0 to 11.0 feet	Vertical Change	.3	5 ft	5	REF		
25433	15.2 to 20.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,024
56326	29.6 to 33.0 feet	Vertical Change	.4	5 ft	15	LF	\$75	\$1,148
56327	37.9 to 38.9 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338
55148	44.1 to 45.1 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
25434	45.8 to 46.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$594
25435	62.8 to 64.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$648
25436	66.9 to 80.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	60	SF	\$120	\$7,236
25440	80.4 to 84.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,214
25441	86.7 to 95.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	41	SF	\$120	\$4,968
25443	96.8 to 109.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,750
25447	111.8 to 116.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	19	SF	\$120	\$2,322
25448	118.4 to 133.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	67	SF	\$120	\$7,992
25453	133.2 to 145.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	55	SF	\$40	\$2,196
TOTAL COST FOR: SW side of 8TH ST Starting at: TRINITY AVE							\$47,272.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	1909261424	8TH ST	ORANGE AVE	HUMBOLDT AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
25361	0.0 to 15.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	69	SF	\$120	\$8,262	
25366	15.3 to 17.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	11	SF	\$120	\$1,350	
25367	17.8 to 34.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,910	
25370	36.0 to 60.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	112	SF	\$120	\$13,446	
56772	55.5 to 56.5 feet	Vertical Change	.5	5 ft	5	REF			
25375	61.5 to 71.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,454	
25378	71.8 to 88.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	74	SF	\$120	\$8,856	
25383	88.6 to 99.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	49	SF	\$120	\$5,832	
25385	100.4 to 115.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	67	SF	\$120	\$8,046	
59468	113.9 to 132.3 feet	Driveway				REF			
25389	119.9 to 129.3 feet	Cross Slope (Driveway)	>15%	5 ft	42	SF	\$40	\$1,692	
40734	129.8 to 131.6 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
25391	132.3 to 134.0 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	8	SF	\$40	\$306	
59469	133.3 to 155.2 feet	Driveway				REF			
40735	135.3 to 136.4 feet	Running Slope	6.0-7.0%	5 ft	5	REF			
25392	138.5 to 143.0 feet	Cross Slope (Driveway)	13.014	5 ft	20	SF	\$40	\$810	
25394	145.9 to 150.5 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	21	SF	\$40	\$828	
25396	151.2 to 152.6 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	6	SF	\$40	\$252	
25397	156.5 to 174.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	81	SF	\$120	\$9,666	
25403	175.0 to 179.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160	
25405	182.4 to 226.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	199	SF	\$120	\$23,868	
25413	230.1 to 237.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	34	SF	\$120	\$4,104	
59470	237.1 to 268.4 feet	Driveway				REF			
40736	237.9 to 239.1 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
40737	239.1 to 240.6 feet	Running Slope	6.0-7.0%	5 ft	7	REF			
25415	242.6 to 264.1 feet	Cross Slope (Driveway)	>15%	5 ft	97	SF	\$40	\$3,870	
25419	264.7 to 265.8 feet	Cross Slope (Driveway)	13.014	5 ft	5	SF	\$40	\$198	
40738	265.3 to 267.7 feet	Running Slope	5.0-6.0%	5 ft	11	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261424	8TH ST	ORANGE AVE	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55145	266.7 to 267.7 feet	Vertical Change	.3	5 ft	5	REF		
25420	272.4 to 296.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	108	SF	\$120	\$13,014
40739	297.7 to 298.9 feet	Running Slope	5.0-6.0%	5 ft	5	SF	\$120	\$648
TOTAL COST FOR: SW side of 8TH ST Starting at: ORANGE AVE							\$121,572.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261431	8TH ST	HUMBOLDT AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25218	2.3 to 10.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	38	SF	\$120	\$4,536
55137	4.5 to 5.5 feet	Vertical Change	.3	5 ft	5	REF		
25220	11.2 to 15.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,484
25222	17.9 to 27.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	43	SF	\$120	\$5,184
56325	27.9 to 28.9 feet	Vertical Change	.4	5 ft	5	REF		
25224	28.0 to 32.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,160
25225	36.3 to 76.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	180	SF	\$120	\$21,600
55138	45.2 to 46.2 feet	Vertical Change	.3	5 ft	5	REF		
56771	55.5 to 56.5 feet	Vertical Change	.5	5 ft	5	REF		
25237	77.7 to 89.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	54	SF	\$120	\$6,426
25241	89.6 to 100.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,670
25243	117.3 to 150.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	149	SF	\$120	\$17,874
25249	153.3 to 159.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	28	SF	\$120	\$3,402
25251	159.6 to 161.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$810
55139	160.5 to 161.5 feet	Vertical Change	.3	5 ft	5	REF		
25252	164.1 to 185.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	98	SF	\$120	\$11,718
25257	195.2 to 218.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	107	SF	\$120	\$12,798
55140	212.9 to 213.9 feet	Vertical Change	.3	5 ft	5	REF		
25261	222.7 to 232.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	44	SF	\$120	\$5,238
25271	258.3 to 272.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,452
25275	275.4 to 288.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	57	SF	\$120	\$6,804
25277	291.0 to 293.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,242
25278	296.6 to 309.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	57	SF	\$120	\$6,804
25279	310.3 to 320.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,562
59467	320.3 to 354.7 feet	Driveway				REF		
25281	323.9 to 329.8 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	27	SF	\$40	\$1,062
25283	330.2 to 333.8 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	16	SF	\$40	\$648
25285	333.8 to 340.2 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	29	SF	\$40	\$1,152

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261431	8TH ST	HUMBOLDT AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25288	340.2 to 343.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	14	SF	\$40	\$540
25290	343.2 to 345.6 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	11	SF	\$40	\$432
25292	345.6 to 351.5 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	27	SF	\$40	\$1,062
25294	356.2 to 361.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	23	SF	\$120	\$2,754
25296	362.2 to 381.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	86	SF	\$120	\$10,314
25300	381.3 to 383.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	8	SF	\$120	\$918
25301	385.2 to 396.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	49	SF	\$120	\$5,832
25304	396.2 to 414.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	83	SF	\$120	\$9,936
25308	521.3 to 564.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	193	SF	\$120	\$23,112
55142	522.2 to 523.2 feet	Vertical Change	.3	5 ft	5	REF		
55143	531.5 to 532.5 feet	Vertical Change	.3	5 ft	5	REF		
25316	566.4 to 594.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	128	SF	\$120	\$15,336
25320	597.3 to 606.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	42	SF	\$120	\$5,076
55144	604.1 to 605.1 feet	Vertical Change	.3	5 ft	5	REF		
25324	608.8 to 611.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	13	SF	\$120	\$1,512
25325	611.6 to 633.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	97	SF	\$120	\$11,610
25331	635.6 to 646.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$5,940
25334	648.8 to 651.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,296
25335	654.3 to 666.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,426
25337	669.9 to 674.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,484
25339	681.5 to 701.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	89	SF	\$120	\$10,638
25341	702.5 to 705.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	15	SF	\$120	\$1,782
25342	717.8 to 719.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$864
25343	724.1 to 726.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,458
25344	758.3 to 759.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$864
25345	780.5 to 781.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$540
25346	796.0 to 799.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,106
25348	815.0 to 816.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$972

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261431	8TH ST	HUMBOLDT AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25349	819.0 to 824.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,808
25351	833.5 to 834.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$648
25352	837.0 to 839.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,188
57051	850.9 to 851.9 feet	Vertical Change	.6	5 ft	5	SF	\$75	\$338
25353	863.6 to 866.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,728
25355	878.3 to 885.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	32	SF	\$120	\$3,888
25358	885.5 to 892.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	33	SF	\$120	\$3,942
25360	893.2 to 894.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$540
TOTAL COST FOR: SW side of 8TH ST Starting at: HUMBOLDT AVE							\$269,509.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261435	8TH ST	COLUSA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25146	0.0 to 15.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	70	SF	\$120	\$8,424
25151	20.0 to 53.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	153	SF	\$120	\$18,306
25161	57.6 to 76.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	84	SF	\$120	\$10,044
25165	79.6 to 84.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	21	SF	\$120	\$2,484
25166	85.1 to 104.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	89	SF	\$120	\$10,638
25174	106.1 to 125.5 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	87	SF	\$120	\$10,476
25180	126.3 to 132.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,132
25182	134.5 to 148.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	62	SF	\$120	\$7,452
25183	149.3 to 165.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,856
25187	173.0 to 174.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$702
25188	176.8 to 181.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	22	SF	\$120	\$2,646
25191	185.1 to 211.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	119	SF	\$120	\$14,310
55136	194.4 to 195.4 feet	Vertical Change	.3	5 ft	5	REF		
25196	212.6 to 215.9 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	15	SF	\$120	\$1,782
25198	216.6 to 236.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	88	SF	\$120	\$10,530
25207	257.7 to 274.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,910
25213	277.6 to 279.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,134
25214	279.7 to 291.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	53	SF	\$120	\$6,372
25217	291.8 to 294.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	14	SF	\$120	\$1,620
TOTAL COST FOR: SW side of 8TH ST Starting at: COLUSA AVE							\$127,818.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261438	8TH ST	SIDEWALK BEGINS	635 8TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25119	1.6 to 19.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	82	SF	\$120	\$9,882
55132	8.8 to 11.9 feet	Vertical Change	.3	5 ft	14	REF		
55134	14.0 to 15.0 feet	Vertical Change	.3	5 ft	5	REF		
25124	19.9 to 21.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	9	SF	\$120	\$1,026
56318	21.2 to 22.2 feet	Vertical Change	.4	5 ft	5	REF		
59463	24.0 to 41.3 feet	Driveway				REF		
56319	24.3 to 25.3 feet	Vertical Change	.4	5 ft	5	REF		
25125	26.3 to 28.0 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	8	SF	\$40	\$306
57527	29.1 to 30.1 feet	Vertical Change	2	5 ft	5	REF		
25126	29.3 to 36.9 feet	Cross Slope (Driveway)	8.0-9.0%	5 ft	34	SF	\$40	\$1,368
56320	33.4 to 34.4 feet	Vertical Change	.4	5 ft	5	REF		
56321	36.6 to 39.6 feet	Vertical Change	.4	5 ft	14	REF		
25129	42.1 to 78.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	163	SF	\$120	\$19,548
56323	70.7 to 71.7 feet	Vertical Change	.4	5 ft	5	REF		
25135	84.3 to 91.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	33	SF	\$120	\$3,996
25137	94.8 to 103.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	41	SF	\$120	\$4,914
25138	104.8 to 109.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,538
59464	108.2 to 128.7 feet	Driveway				REF		
40733	108.8 to 110.5 feet	Running Slope	6.0-7.0%	5 ft	8	REF		
56324	108.9 to 109.9 feet	Vertical Change	.4	5 ft	5	REF		
25139	113.0 to 125.8 feet	Cross Slope (Driveway)	10.0-11.0%	5 ft	58	SF	\$40	\$2,304
55135	127.5 to 128.5 feet	Vertical Change	.3	5 ft	5	REF		
25142	128.8 to 130.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$234
25143	130.1 to 140.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,508
TOTAL COST FOR: NE side of 8TH ST Starting at: SIDEWALK BEGINS							\$51,624.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261440	8TH ST	SIDEWALK BEGINS	COLUSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25087	0.0 to 20.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	91	SF	\$120	\$10,962
87	0.5 to 1.5 feet	Continuous Width		5 ft	5	SF	\$120	\$540
25092	25.3 to 37.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	53	SF	\$120	\$6,318
25095	37.0 to 43.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,348
25098	44.2 to 51.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	32	SF	\$120	\$3,888
25100	51.4 to 57.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,024
25103	59.2 to 71.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,696
25108	73.8 to 81.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	34	SF	\$120	\$4,050
55131	76.1 to 77.1 feet	Vertical Change	.3	5 ft	5	REF		
25110	82.3 to 92.5 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	46	SF	\$120	\$5,508
59462	92.5 to 116.1 feet	Driveway				REF		
25112	97.9 to 113.4 feet	Cross Slope (Driveway)	>15%	5 ft	70	SF	\$40	\$2,790
25113	117.1 to 123.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	28	SF	\$120	\$3,348
56317	121.5 to 122.5 feet	Vertical Change	.4	5 ft	5	REF		
25115	123.3 to 134.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	52	SF	\$120	\$6,210
25118	137.8 to 138.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	5	SF	\$120	\$540
TOTAL COST FOR: NE side of 8TH ST Starting at: SIDEWALK BEGINS								\$57,222.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261443	8TH ST	COLUSA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25071	0.0 to 5.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,808
55129	7.1 to 8.1 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
25072	14.7 to 16.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,134
55130	17.3 to 18.3 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
25073	27.8 to 33.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,078
25076	66.9 to 87.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	93	SF	\$120	\$11,178
25081	102.8 to 105.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,458
25082	110.7 to 115.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700
25085	119.6 to 130.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,102
59461	130.3 to 145.6 feet	Driveway				REF		
TOTAL COST FOR: NE side of 8TH ST Starting at: COLUSA AVE							\$29,133.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261447	8TH ST	ALAMEDA AVE	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
25006	0.0 to 13.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	59	SF	\$120	\$7,128
56314	13.2 to 14.2 feet	Vertical Change	.4	5 ft	5	REF		
25009	13.3 to 17.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	18	SF	\$120	\$2,160
25014	44.6 to 49.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	23	SF	\$120	\$2,700
25016	50.3 to 56.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	27	SF	\$120	\$3,294
25018	56.9 to 81.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	111	SF	\$120	\$13,284
25022	82.0 to 124.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	191	SF	\$120	\$22,896
55125	97.9 to 98.9 feet	Vertical Change	.3	5 ft	5	REF		
25033	124.4 to 136.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	56	SF	\$120	\$6,696
25036	139.8 to 143.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	15	SF	\$120	\$1,836
25037	144.5 to 170.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	116	SF	\$120	\$13,932
56315	156.9 to 157.9 feet	Vertical Change	.4	5 ft	5	REF		
25043	174.3 to 181.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,104
56770	182.6 to 183.6 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$338
25045	184.5 to 185.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$702
25046	185.8 to 207.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	96	SF	\$120	\$11,556
55126	187.8 to 188.8 feet	Vertical Change	.3	5 ft	5	REF		
55127	195.4 to 196.4 feet	Vertical Change	.3	5 ft	5	REF		
25050	209.3 to 232.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	105	SF	\$120	\$12,636
56316	226.1 to 227.1 feet	Vertical Change	.4	5 ft	5	REF		
25056	234.8 to 254.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	90	SF	\$120	\$10,746
25059	264.7 to 271.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,564
25062	275.5 to 303.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	126	SF	\$120	\$15,174
55128	299.4 to 300.4 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: NE side of 8TH ST Starting at: ALAMEDA AVE							\$132,745.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261450	8TH ST	HUMBOLDT AVE	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55118	27.1 to 28.1 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
59458	54.5 to 92.6 feet	Driveway				REF		
55119	55.3 to 56.3 feet	Vertical Change	.3	5 ft	5	REF		
24982	87.5 to 92.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	20	SF	\$40	\$810
24983	92.9 to 123.4 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	137	SF	\$40	\$5,490
59459	121.7 to 167.8 feet	Driveway				REF		
24991	123.4 to 124.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$198
55120	153.4 to 154.4 feet	Vertical Change	.3	5 ft	5	REF		
55121	168.7 to 173.3 feet	Vertical Change	.3	5 ft	21	LF	\$75	\$1,553
24992	169.8 to 174.0 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	19	SF	\$120	\$2,268
24994	174.3 to 175.8 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	7	SF	\$120	\$810
24995	179.6 to 186.1 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	29	SF	\$120	\$3,510
24998	186.8 to 194.3 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	34	SF	\$120	\$4,050
56313	187.3 to 188.3 feet	Vertical Change	.4	5 ft	5	REF		
25001	195.1 to 198.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	17	SF	\$120	\$1,998
25003	199.8 to 202.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	10	SF	\$120	\$1,242
25004	202.8 to 203.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$540
25005	203.8 to 204.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$540
55122	232.0 to 233.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
55123	253.0 to 254.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338

TOTAL COST FOR: NE	<i>side of 8TH ST Starting at: HUMBOLDT AVE</i>	\$24,021.00
---------------------------	---	--------------------

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261454	8TH ST	ORANGE AVE	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59455	46.5 to 79.0 feet	Driveway				REF		
55114	47.4 to 48.4 feet	Vertical Change	.3	5 ft	5	REF		
55115	77.9 to 78.9 feet	Vertical Change	.3	5 ft	5	REF		
59456	123.5 to 167.4 feet	Driveway				REF		
55116	193.6 to 194.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
59457	220.3 to 255.3 feet	Driveway				REF		
56308	221.2 to 222.2 feet	Vertical Change	.4	5 ft	5	REF		
24981	234.9 to 237.7 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	13	SF	\$40	\$504
56309	254.1 to 255.1 feet	Vertical Change	.4	5 ft	5	REF		
55117	270.3 to 271.3 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
56310	290.9 to 291.9 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338
TOTAL COST FOR: NE side of 8TH ST Starting at: ORANGE AVE								\$1,516.50

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1909261458	8TH ST	TRINITY AVE	ROBERTSON BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
57050	6.4 to 7.4 feet	Vertical Change	.6	5 ft	5	REF			
24938	7.2 to 20.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,398	
24941	23.2 to 73.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	228	SF	\$120	\$27,378	
56306	24.4 to 25.4 feet	Vertical Change	.4	5 ft	5	REF			
55110	55.1 to 56.1 feet	Vertical Change	.3	5 ft	5	REF			
24952	77.7 to 79.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$702	
24953	80.3 to 82.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	8	SF	\$120	\$918	
59452	80.5 to 97.1 feet	Driveway				REF			
24954	86.7 to 93.3 feet	Cross Slope (Driveway)	>15%	5 ft	30	SF	\$40	\$1,188	
40727	95.1 to 96.9 feet	Running Slope	5.0-6.0%	5 ft	8	REF			
24955	97.6 to 113.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,748	
59453	113.0 to 128.3 feet	Driveway				REF			
40728	113.5 to 114.6 feet	Running Slope	6.0-7.0%	5 ft	5	REF			
40729	114.6 to 115.9 feet	Running Slope	5.0-6.0%	5 ft	6	REF			
24960	117.7 to 119.0 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	6	SF	\$40	\$234	
24961	122.1 to 125.5 feet	Cross Slope (Driveway)	13.014	5 ft	15	SF	\$40	\$612	
40730	125.3 to 127.2 feet	Running Slope	5.0-6.0%	5 ft	9	REF			
24963	133.3 to 137.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	18	SF	\$120	\$2,214	
24964	144.2 to 149.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,024	
59454	149.2 to 172.1 feet	Driveway				REF			
55111	149.5 to 150.5 feet	Vertical Change	.3	5 ft	5	REF			
24966	154.4 to 164.6 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	46	SF	\$40	\$1,836	
55112	156.0 to 157.0 feet	Vertical Change	.3	5 ft	5	REF			
24971	167.3 to 168.9 feet	Cross Slope (Driveway)	>15%	5 ft	7	SF	\$40	\$288	
40731	167.3 to 168.3 feet	Running Slope	5.0-6.0%	5 ft	5	REF			
40732	170.3 to 171.6 feet	Running Slope	6.0-7.0%	5 ft	6	REF			
86	172.4 to 173.4 feet	Continuous Width		5 ft	5	SF	\$120	\$540	
24972	173.3 to 178.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,808	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261458	8TH ST	TRINITY AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24974	182.5 to 193.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	50	SF	\$120	\$6,048
55113	191.7 to 192.7 feet	Vertical Change	.3	5 ft	5	REF		
24976	198.8 to 201.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,350
56307	212.2 to 213.2 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338
24977	247.9 to 256.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	38	SF	\$120	\$4,590
24978	266.9 to 273.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,348
24980	287.9 to 293.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,916
TOTAL COST FOR: NE side of 8TH ST Starting at: TRINITY AVE							\$76,477.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261519	7TH ST	SIDEWALK BEGINS	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24914	0.0 to 2.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,380
24915	6.3 to 10.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,460
55101	9.9 to 10.9 feet	Vertical Change	.3	5 ft	5	REF		
56305	17.6 to 18.6 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
55102	25.1 to 26.1 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
24916	33.2 to 38.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,420
55103	35.6 to 36.6 feet	Vertical Change	.3	5 ft	5	REF		
24919	41.3 to 49.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,620
24921	56.7 to 59.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860
24922	66.3 to 70.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400
24924	72.6 to 73.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$780
24925	73.9 to 79.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,420
59451	77.3 to 88.6 feet	Driveway				REF		
24926	83.4 to 88.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	25	SF	\$40	\$980
55104	86.5 to 87.5 feet	Vertical Change	.3	5 ft	5	REF		
24927	91.8 to 114.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	113	SF	\$120	\$13,500
55105	104.3 to 105.3 feet	Vertical Change	.3	5 ft	5	REF		
55106	114.6 to 115.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
24934	124.4 to 130.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	28	SF	\$120	\$3,360
55107	125.0 to 126.0 feet	Vertical Change	.3	5 ft	5	REF		
24935	137.0 to 145.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,160
55108	140.3 to 141.3 feet	Vertical Change	.3	5 ft	5	REF		
55109	148.0 to 149.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
40726	148.3 to 150.1 feet	Running Slope	5.0-6.0%	5 ft	9	SF	\$120	\$1,080
TOTAL COST FOR: SW side of 7TH ST Starting at: SIDEWALK BEGINS							\$45,920.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261524	7TH ST	TRINITY AVE	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24875	3.6 to 18.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	76	SF	\$120	\$9,180
55098	11.9 to 12.9 feet	Vertical Change	.3	5 ft	5	REF		
24877	28.7 to 44.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	81	SF	\$120	\$9,720
56302	68.3 to 69.3 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
24882	88.7 to 92.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,220
24883	113.3 to 116.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860
24885	130.7 to 133.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,560
24886	137.7 to 151.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	70	SF	\$120	\$8,340
59449	149.7 to 172.6 feet	Driveway				REF		
24889	169.3 to 170.6 feet	Cross Slope (Driveway)	7.0-8.0%	5 ft	7	SF	\$40	\$260
24890	177.1 to 213.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	181	SF	\$120	\$21,720
56303	211.8 to 212.8 feet	Vertical Change	.4	5 ft	5	REF		
59450	212.1 to 234.8 feet	Driveway				REF		
40725	214.9 to 216.2 feet	Running Slope	5.0-6.0%	5 ft	7	REF		
56304	215.0 to 216.0 feet	Vertical Change	.4	5 ft	5	REF		
24894	216.9 to 231.1 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	71	SF	\$40	\$2,840
55099	234.4 to 235.4 feet	Vertical Change	.3	5 ft	5	REF		
24898	235.3 to 236.3 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	5	SF	\$40	\$200
24899	246.1 to 251.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,480
55100	247.9 to 248.9 feet	Vertical Change	.3	5 ft	5	REF		
24901	251.9 to 288.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	185	SF	\$120	\$22,140
24910	288.8 to 292.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	19	SF	\$120	\$2,280
24912	292.6 to 308.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	81	SF	\$120	\$9,720
TOTAL COST FOR: SW side of 7TH ST Starting at: TRINITY AVE							\$95,895.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261527	7TH ST	ORANGE AVE	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59447	66.5 to 98.9 feet	Driveway				REF		
55094	67.4 to 68.4 feet	Vertical Change	.3	5 ft	5	REF		
56299	97.4 to 98.4 feet	Vertical Change	.4	5 ft	5	REF		
57049	119.2 to 120.2 feet	Vertical Change	.6	5 ft	5	SF	\$75	\$375
59448	126.2 to 181.6 feet	Driveway				REF		
55095	127.7 to 128.7 feet	Vertical Change	.3	5 ft	5	REF		
56300	180.0 to 181.0 feet	Vertical Change	.4	5 ft	5	REF		
55096	211.5 to 212.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
56301	229.4 to 230.4 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
24873	236.8 to 238.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
55097	270.4 to 271.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
24874	287.9 to 290.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	12	SF	\$120	\$1,380
TOTAL COST FOR: SW side of 7TH ST Starting at: ORANGE AVE							\$3,720.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261531	7TH ST	HUMBOLDT AVE	ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24833	0.5 to 2.6 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,134
24834	3.4 to 23.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	89	SF	\$120	\$10,638
24837	27.4 to 51.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	108	SF	\$120	\$12,906
24841	58.4 to 61.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620
24842	63.8 to 65.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$864
24843	69.5 to 71.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$972
24844	71.3 to 76.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,862
24845	80.9 to 92.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,156
24846	95.8 to 109.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	61	SF	\$120	\$7,290
24847	113.1 to 138.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	116	SF	\$120	\$13,878
24852	140.4 to 152.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	53	SF	\$120	\$6,318
24856	152.9 to 172.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	90	SF	\$120	\$10,746
55091	173.0 to 174.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
55092	214.0 to 215.0 feet	Vertical Change	.3	5 ft	5	REF		
24860	214.4 to 217.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,620
24861	221.8 to 227.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,078
24864	244.5 to 252.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	37	SF	\$120	\$4,482
24865	255.0 to 256.1 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	5	SF	\$120	\$594
24866	256.1 to 261.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,808
24868	264.1 to 265.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$648
24869	275.3 to 286.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,210
24871	289.5 to 294.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	24	SF	\$120	\$2,862
TOTAL COST FOR: SW side of 7TH ST Starting at: HUMBOLDT AVE							\$98,023.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261534	7TH ST	SIDEWALK BEGINS	COLUSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24807	0.0 to 1.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	9	SF	\$120	\$1,026
24808	2.3 to 30.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	126	SF	\$120	\$15,120
24814	33.3 to 47.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,560
24817	48.8 to 55.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	31	SF	\$120	\$3,672
24819	55.6 to 73.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	80	SF	\$120	\$9,612
59446	73.3 to 91.0 feet	Driveway				REF		
40723	74.3 to 75.8 feet	Running Slope	8.0-9.0%	5 ft	7	REF		
24823	77.8 to 80.5 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	12	SF	\$40	\$486
24825	80.7 to 87.7 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	32	SF	\$40	\$1,260
40724	89.4 to 90.4 feet	Running Slope	9.0-10.0%	5 ft	5	REF		
24827	92.0 to 94.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
24828	97.6 to 98.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$648
24829	103.9 to 116.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,750
55090	117.0 to 118.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
24831	125.8 to 127.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,026
24832	139.4 to 141.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,134
TOTAL COST FOR: SW side of 7TH ST Starting at: SIDEWALK BEGINS								\$49,711.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261537	7TH ST	COLUSA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24789	18.8 to 36.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	81	SF	\$120	\$9,720
59445	64.1 to 83.4 feet	Driveway				REF		
40722	67.0 to 68.1 feet	Running Slope	11.012	5 ft	5	REF		
24793	68.3 to 80.0 feet	Cross Slope (Driveway)	13.014	5 ft	53	SF	\$40	\$2,106
55086	81.3 to 82.3 feet	Vertical Change	.3	5 ft	5	REF		
24800	89.8 to 113.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	108	SF	\$120	\$12,906
55087	91.7 to 92.7 feet	Vertical Change	.3	5 ft	5	REF		
55088	96.8 to 97.8 feet	Vertical Change	.3	5 ft	5	REF		
24805	113.7 to 133.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	87	SF	\$120	\$10,476
55089	127.5 to 128.5 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: SW side of 7TH ST Starting at: COLUSA AVE							\$35,208.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261540	7TH ST	SIDEWALK BEGINS	COLUSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55083	40.0 to 41.0 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
59444	53.2 to 76.7 feet	Driveway				REF		
40720	54.5 to 56.0 feet	Running Slope	6.0-7.0%	5 ft	7	REF		
24777	57.4 to 63.0 feet	Cross Slope (Driveway)	12.0-13.0%	5 ft	25	SF	\$40	\$1,008
24779	63.0 to 73.1 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	45	SF	\$40	\$1,818
40721	74.6 to 76.8 feet	Running Slope	6.0-7.0%	5 ft	10	REF		
55084	74.9 to 75.9 feet	Vertical Change	.3	5 ft	5	REF		
24781	77.8 to 113.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	159	SF	\$120	\$19,116
55085	117.5 to 118.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
24787	120.8 to 127.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	31	SF	\$120	\$3,672
TOTAL COST FOR: NE side of 7TH ST Starting at: SIDEWALK BEGINS							\$26,289.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261542	7TH ST	COLUSA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24767	0.0 to 3.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	14	SF	\$120	\$1,728
24768	3.2 to 17.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	64	SF	\$120	\$7,668
24769	67.1 to 77.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,346
24772	81.2 to 85.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,538
24774	90.4 to 93.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	14	SF	\$120	\$1,728
55081	91.7 to 92.7 feet	Vertical Change	.3	5 ft	5	REF		
59443	96.3 to 115.2 feet	Driveway				REF		
55082	96.8 to 97.8 feet	Vertical Change	.3	5 ft	5	REF		
40719	98.3 to 100.2 feet	Running Slope	5.0-6.0%	5 ft	9	REF		
24775	101.5 to 112.1 feet	Cross Slope (Driveway)	>15%	5 ft	48	SF	\$40	\$1,908
24776	120.7 to 123.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,566
TOTAL COST FOR: NE side of 7TH ST Starting at: COLUSA AVE							\$22,482.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261544	7TH ST	SIDEWALK BEGINS	ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24737	0.0 to 6.2 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	28	SF	\$120	\$3,348
59442	4.6 to 22.9 feet	Driveway				REF		
40716	6.9 to 8.3 feet	Running Slope	7.0-8.0%	5 ft	6	REF		
24740	9.8 to 20.1 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	46	SF	\$40	\$1,854
40717	20.0 to 22.6 feet	Running Slope	5.0-6.0%	5 ft	12	REF		
24742	24.6 to 56.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	143	SF	\$120	\$17,118
55080	55.7 to 56.7 feet	Vertical Change	.3	5 ft	5	REF		
24750	56.3 to 75.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	86	SF	\$120	\$10,314
24754	75.4 to 89.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,560
24758	89.4 to 123.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	153	SF	\$120	\$18,306
24764	128.0 to 135.1 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	32	SF	\$120	\$3,834
40718	133.3 to 135.0 feet	Running Slope	5.0-6.0%	5 ft	8	REF		
TOTAL COST FOR: NE side of 7TH ST Starting at: SIDEWALK BEGINS							\$62,334.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261549	7TH ST	ALAMEDA AVE	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24676	0.0 to 18.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	81	SF	\$120	\$9,774
24682	45.3 to 100.0 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	246	SF	\$120	\$29,538
55077	52.0 to 53.0 feet	Vertical Change	.3	5 ft	5	REF		
24695	102.8 to 129.4 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	120	SF	\$120	\$14,364
24699	130.8 to 132.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$864
59440	133.9 to 155.2 feet	Driveway				REF		
57192	136.1 to 137.1 feet	Vertical Change	.7	5 ft	5	REF		
84	138.8 to 139.8 feet	Continuous Width		5 ft	5	SF	\$120	\$540
55078	157.1 to 158.1 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
85	158.5 to 159.5 feet	Continuous Width		5 ft	5	SF	\$120	\$540
24700	161.0 to 196.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	158	SF	\$120	\$19,008
57048	191.1 to 192.1 feet	Vertical Change	.6	5 ft	5	REF		
24711	196.2 to 200.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	20	SF	\$120	\$2,430
59441	199.3 to 220.9 feet	Driveway				REF		
24712	203.6 to 218.6 feet	Cross Slope (Driveway)	>15%	5 ft	68	SF	\$40	\$2,700
24713	221.5 to 227.4 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	27	SF	\$120	\$3,186
24716	227.8 to 232.2 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	20	SF	\$120	\$2,376
24719	232.7 to 236.7 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	18	SF	\$120	\$2,160
24721	237.6 to 242.4 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	22	SF	\$120	\$2,592
57387	240.5 to 241.5 feet	Vertical Change	1.1	5 ft	5	REF		
24724	243.3 to 274.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	140	SF	\$120	\$16,740
55079	271.3 to 272.3 feet	Vertical Change	.3	5 ft	5	REF		
24730	274.7 to 277.6 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	13	SF	\$120	\$1,566
24731	277.6 to 281.7 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	18	SF	\$120	\$2,214
24732	281.7 to 285.3 feet	Cross Slope (PAR)	6.0-7.0%	5 ft	16	SF	\$120	\$1,944
24734	285.3 to 293.1 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	35	SF	\$120	\$4,212
TOTAL COST FOR: NE side of 7TH ST Starting at: ALAMEDA AVE							\$117,085.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261553	7TH ST	HUMBOLDT AVE	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55073	27.2 to 28.2 feet	Vertical Change	.3	5 ft	5	REF		
24674	28.2 to 32.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,340
59438	62.8 to 90.8 feet	Driveway				REF		
56295	63.4 to 64.4 feet	Vertical Change	.4	5 ft	5	REF		
55074	71.3 to 72.3 feet	Vertical Change	.3	5 ft	5	REF		
56296	121.9 to 122.9 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
59439	122.5 to 180.4 feet	Driveway				REF		
83	154.9 to 155.9 feet	Continuous Width		5 ft	5	SF	\$120	\$600
55075	178.9 to 179.9 feet	Vertical Change	.3	5 ft	5	REF		
55076	222.5 to 223.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
24675	271.6 to 274.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,920
56297	283.7 to 284.7 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: NE side of 7TH ST Starting at: HUMBOLDT AVE							\$5,985.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261557	7TH ST	ORANGE AVE	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24652	0.0 to 6.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	34	SF	\$120	\$4,020
24653	21.2 to 22.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,020
24654	27.0 to 28.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
24655	28.8 to 33.6 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	24	SF	\$120	\$2,880
24657	33.6 to 34.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$780
24658	40.8 to 46.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	27	SF	\$120	\$3,180
24660	48.3 to 52.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700
24663	55.0 to 56.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	10	SF	\$120	\$1,140
24664	57.8 to 59.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840
56767	58.0 to 59.0 feet	Vertical Change	.5	5 ft	5	REF		
59435	63.5 to 87.5 feet	Driveway				REF		
57315	64.7 to 65.7 feet	Vertical Change	.9	5 ft	5	REF		
40714	83.8 to 85.2 feet	Running Slope	9.0-10.0%	5 ft	7	REF		
24665	99.6 to 120.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	106	SF	\$120	\$12,720
56768	119.5 to 120.5 feet	Vertical Change	.5	5 ft	5	REF		
40715	130.3 to 131.6 feet	Running Slope	5.0-6.0%	5 ft	6	SF	\$120	\$780
59436	134.1 to 160.5 feet	Driveway				REF		
56769	166.3 to 167.3 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375
59437	201.2 to 222.1 feet	Driveway				REF		
55072	211.2 to 212.2 feet	Vertical Change	.3	5 ft	5	REF		
24673	226.0 to 236.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,240
56294	294.4 to 295.4 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: NE side of 7TH ST Starting at: ORANGE AVE								\$37,890.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261600	7TH ST	TRINITY AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55067	1.8 to 2.8 feet	Vertical Change	.3	5 ft	5	REF		
24639	2.3 to 17.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	74	SF	\$120	\$8,820
56293	6.9 to 7.9 feet	Vertical Change	.4	5 ft	5	REF		
24643	19.9 to 46.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	132	SF	\$120	\$15,840
55068	47.6 to 48.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
24647	52.3 to 53.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$600
24648	65.6 to 71.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	29	SF	\$120	\$3,480
24649	80.8 to 93.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,500
55069	83.8 to 84.8 feet	Vertical Change	.3	5 ft	5	REF		
57263	94.1 to 95.1 feet	Vertical Change	.8	5 ft	5	SF	\$75	\$375
55070	104.5 to 105.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
24650	124.8 to 126.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260
55071	125.1 to 126.1 feet	Vertical Change	.3	5 ft	5	REF		
24651	129.7 to 142.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	63	SF	\$120	\$7,500
TOTAL COST FOR: NE side of 7TH ST Starting at: TRINITY AVE							\$46,125.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261602	7TH ST	SIDEWALK BEGINS	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24610	0.0 to 23.8 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	119	SF	\$120	\$14,280
55058	15.2 to 16.2 feet	Vertical Change	.3	5 ft	5	REF		
24615	27.2 to 42.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	79	SF	\$120	\$9,420
55059	27.4 to 28.4 feet	Vertical Change	.3	5 ft	5	REF		
24619	44.6 to 46.3 feet	Cross Slope (PAR)	8.0-9.0%	5 ft	9	SF	\$120	\$1,020
56766	46.0 to 47.0 feet	Vertical Change	.5	5 ft	5	REF		
24620	48.1 to 50.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	14	SF	\$120	\$1,620
55060	49.1 to 50.1 feet	Vertical Change	.3	5 ft	5	REF		
24622	50.8 to 52.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	8	SF	\$120	\$900
24623	52.7 to 54.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,200
24624	57.8 to 60.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	11	SF	\$120	\$1,320
24625	61.0 to 81.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	103	SF	\$120	\$12,360
55061	63.6 to 64.6 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
24628	81.8 to 93.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	60	SF	\$120	\$7,200
55062	82.1 to 83.1 feet	Vertical Change	.3	5 ft	5	REF		
55063	88.3 to 89.3 feet	Vertical Change	.3	5 ft	5	REF		
24632	94.6 to 100.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,600
24633	103.8 to 105.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	6	SF	\$120	\$720
24634	109.0 to 118.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	46	SF	\$120	\$5,520
55064	109.9 to 110.9 feet	Vertical Change	.3	5 ft	5	REF		
57262	112.1 to 113.1 feet	Vertical Change	.8	5 ft	5	REF		
55065	117.2 to 118.2 feet	Vertical Change	.3	5 ft	5	REF		
24636	120.4 to 129.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	47	SF	\$120	\$5,640
55066	125.4 to 126.4 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: NE side of 7TH ST Starting at: SIDEWALK BEGINS							\$65,175.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261606	6TH ST	ROBERTSON BLVD	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24580	0.0 to 4.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,760
24581	8.1 to 19.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	56	SF	\$120	\$6,720
24583	109.7 to 114.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	26	SF	\$120	\$3,060
24584	118.8 to 121.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	13	SF	\$120	\$1,500
59433	121.2 to 137.5 feet	Driveway				REF		
24585	125.3 to 132.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	34	SF	\$40	\$1,340
59434	143.8 to 162.3 feet	Driveway				REF		
24588	149.0 to 155.7 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	33	SF	\$40	\$1,340
24589	161.0 to 162.1 feet	Cross Slope (Driveway)	3.0-4.0%	5 ft	6	SF	\$40	\$220
24590	162.1 to 182.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	101	SF	\$40	\$4,020
24592	185.8 to 195.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	48	SF	\$120	\$5,700
24596	199.4 to 200.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	7	SF	\$120	\$780
24597	202.3 to 206.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700
24598	218.6 to 240.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	109	SF	\$120	\$13,020
24602	243.4 to 263.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	99	SF	\$120	\$11,880
24605	265.6 to 274.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	45	SF	\$120	\$5,460
24607	279.1 to 305.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	131	SF	\$120	\$15,720
56292	294.8 to 295.8 feet	Vertical Change	.4	5 ft	5	REF		
TOTAL COST FOR: SW side of 6TH ST Starting at: ROBERTSON BLVD							\$76,220.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261610	6TH ST	TRINITY AVE	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24571	0.2 to 2.5 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	12	SF	\$120	\$1,380
24572	2.5 to 12.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,240
55054	10.4 to 11.4 feet	Vertical Change	.3	5 ft	5	REF		
56290	31.8 to 32.8 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
24575	66.1 to 69.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	16	SF	\$120	\$1,860
55055	69.5 to 70.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
55056	110.5 to 111.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
55057	134.4 to 135.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
59432	140.2 to 160.8 feet	Driveway				REF		
24576	145.3 to 158.3 feet	Cross Slope (Driveway)	9.0-10.0%	5 ft	65	SF	\$40	\$2,600
56291	165.6 to 166.6 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
56765	219.9 to 220.9 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$375
57191	296.6 to 297.6 feet	Vertical Change	.7	5 ft	5	SF	\$75	\$375
TOTAL COST FOR: SW side of 6TH ST Starting at: TRINITY AVE							\$14,705.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261613	6TH ST	ORANGE AVE	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55044	2.4 to 3.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
55045	10.8 to 11.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
55046	41.6 to 42.6 feet	Vertical Change	.3	5 ft	5	REF		
24560	42.4 to 43.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$660
55047	62.2 to 63.2 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
24561	75.4 to 80.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	25	SF	\$120	\$3,000
56287	78.7 to 79.7 feet	Vertical Change	.4	5 ft	5	REF		
59429	83.8 to 104.6 feet	Driveway				REF		
56288	109.3 to 110.3 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
24562	130.9 to 139.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,160
56762	136.5 to 137.5 feet	Vertical Change	.5	5 ft	5	REF		
59430	140.8 to 158.7 feet	Driveway				REF		
55048	165.8 to 166.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
55049	181.3 to 182.3 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
55050	191.5 to 192.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
24565	215.8 to 223.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	39	SF	\$120	\$4,680
56763	221.1 to 222.1 feet	Vertical Change	.5	5 ft	5	REF		
59431	226.0 to 239.5 feet	Driveway				REF		
56764	245.0 to 246.0 feet	Vertical Change	.5	5 ft	5	REF		
24567	245.4 to 253.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	43	SF	\$120	\$5,100
55051	269.3 to 270.3 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
24570	279.1 to 283.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400
55052	279.6 to 280.6 feet	Vertical Change	.3	5 ft	5	REF		
55053	289.8 to 290.8 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375
56289	300.0 to 301.0 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375
TOTAL COST FOR: SW side of 6TH ST Starting at: ORANGE AVE							\$24,750.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261618	6TH ST	HUMBOLDT AVE	ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24501	0.0 to 11.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	51	SF	\$120	\$6,156
55039	12.5 to 13.5 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
24503	14.1 to 17.9 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	17	SF	\$120	\$2,052
56761	17.0 to 18.0 feet	Vertical Change	.5	5 ft	5	REF		
24504	18.3 to 20.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	9	SF	\$120	\$1,080
24505	27.0 to 30.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,782
24507	30.3 to 40.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	47	SF	\$120	\$5,670
55040	37.5 to 38.5 feet	Vertical Change	.3	5 ft	5	REF		
24510	44.6 to 45.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	6	SF	\$120	\$702
55041	47.8 to 48.8 feet	Vertical Change	.3	5 ft	5	REF		
24511	48.6 to 57.3 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	39	SF	\$120	\$4,698
24513	59.8 to 67.2 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	33	SF	\$120	\$3,996
24516	68.2 to 71.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	14	SF	\$120	\$1,620
24518	72.1 to 78.5 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	29	SF	\$120	\$3,456
24520	79.4 to 82.0 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	12	SF	\$120	\$1,404
24521	82.6 to 90.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	35	SF	\$120	\$4,212
55042	89.0 to 90.0 feet	Vertical Change	.3	5 ft	5	REF		
24524	90.4 to 111.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	97	SF	\$120	\$11,610
24531	114.1 to 121.8 feet	Cross Slope (PAR)	5.0-6.0%	5 ft	35	SF	\$120	\$4,158
55043	119.9 to 120.9 feet	Vertical Change	.3	5 ft	5	REF		
24535	121.9 to 137.4 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	70	SF	\$120	\$8,370
59428	136.0 to 155.0 feet	Driveway				REF		
24539	137.4 to 142.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	23	SF	\$40	\$918
24542	154.3 to 156.2 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	9	SF	\$40	\$342
24543	166.8 to 178.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	52	SF	\$120	\$6,210
24547	184.3 to 189.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,754
24548	193.3 to 194.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	5	SF	\$120	\$594
24549	214.8 to 226.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	54	SF	\$120	\$6,534

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	1909261618	6TH ST	HUMBOLDT AVE	ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24550	231.7 to 236.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700
24551	251.0 to 252.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$702
24552	256.4 to 261.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,484
56286	269.1 to 270.1 feet	Vertical Change	.4	5 ft	5	REF		
24553	269.3 to 291.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	101	SF	\$120	\$12,150
TOTAL COST FOR: SW side of 6TH ST Starting at: HUMBOLDT AVE							\$96,691.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261623	6TH ST	HUMBOLDT AVE	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24470	0.0 to 51.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	231	SF	\$120	\$27,756
56282	25.7 to 26.7 feet	Vertical Change	.4	5 ft	5	REF		
59425	50.4 to 73.7 feet	Driveway				REF		
24479	55.2 to 71.3 feet	Cross Slope (Driveway)	14.0-15.0%	5 ft	72	SF	\$40	\$2,898
56283	71.8 to 72.8 feet	Vertical Change	.4	5 ft	5	REF		
24484	75.8 to 84.3 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	38	SF	\$120	\$4,590
24485	84.3 to 118.4 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	153	SF	\$120	\$18,414
55035	105.2 to 106.2 feet	Vertical Change	.3	5 ft	5	REF		
56284	120.6 to 121.6 feet	Vertical Change	.4	5 ft	5	REF		
24496	120.7 to 128.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	34	SF	\$120	\$4,050
59426	126.3 to 158.4 feet	Driveway				REF		
55036	127.1 to 128.1 feet	Vertical Change	.3	5 ft	5	REF		
24497	129.8 to 134.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	21	SF	\$40	\$828
24499	142.3 to 144.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	11	SF	\$40	\$450
56759	156.7 to 157.7 feet	Vertical Change	.5	5 ft	5	REF		
56285	198.5 to 199.5 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$338
55037	208.7 to 209.7 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
24500	222.0 to 225.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,782
59427	229.0 to 244.1 feet	Driveway				REF		
55038	248.2 to 249.2 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$338
56760	293.0 to 294.0 feet	Vertical Change	.5	5 ft	5	SF	\$75	\$338
TOTAL COST FOR: NE side of 6TH ST Starting at: HUMBOLDT AVE							\$62,118.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	1909261626	6TH ST	ORANGE AVE	TRINITY AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
56280	49.1 to 50.1 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
55029	59.4 to 60.4 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
24417	81.4 to 82.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	6	SF	\$120	\$780	
24418	86.2 to 92.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,540	
59422	91.3 to 108.8 feet	Driveway				REF			
24421	94.4 to 97.2 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	14	SF	\$40	\$560	
24422	99.0 to 107.5 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	43	SF	\$40	\$1,700	
24426	107.5 to 110.6 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	16	SF	\$40	\$620	
24427	114.0 to 115.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	10	SF	\$120	\$1,140	
24428	119.8 to 123.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	21	SF	\$120	\$2,460	
24429	137.8 to 141.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	20	SF	\$120	\$2,400	
59423	139.4 to 164.8 feet	Driveway				REF			
24431	141.8 to 145.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	16	SF	\$40	\$640	
24433	145.0 to 150.3 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	27	SF	\$40	\$1,060	
56281	151.1 to 152.1 feet	Vertical Change	.4	5 ft	5	REF			
24436	151.3 to 159.1 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	39	SF	\$40	\$1,560	
24440	159.3 to 161.4 feet	Cross Slope (Driveway)	6.0-7.0%	5 ft	10	SF	\$40	\$420	
24441	161.8 to 163.0 feet	Cross Slope (Driveway)	5.0-6.0%	5 ft	6	SF	\$40	\$240	
24442	164.3 to 236.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	359	SF	\$40	\$14,360	
55030	175.1 to 176.1 feet	Vertical Change	.3	5 ft	5	REF			
55031	185.9 to 186.9 feet	Vertical Change	.3	5 ft	5	REF			
24458	240.6 to 244.2 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	18	SF	\$120	\$2,160	
24459	244.2 to 246.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,260	
59424	247.5 to 263.5 feet	Driveway				REF			
24460	254.8 to 258.0 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	16	SF	\$40	\$640	
24461	264.9 to 306.8 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	210	SF	\$120	\$25,140	
55032	272.7 to 273.7 feet	Vertical Change	.3	5 ft	5	REF			
55033	281.4 to 282.4 feet	Vertical Change	.3	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261626	6TH ST	ORANGE AVE	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55034	300.5 to 301.5 feet	Vertical Change	.3	5 ft	5	REF		
TOTAL COST FOR: NE side of 6TH ST Starting at: ORANGE AVE							\$61,430.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NE	1909261630	6TH ST	TRINITY AVE	ROBERTSON BLVD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
56278	11.8 to 12.8 feet	Vertical Change	.4	5 ft	5	LF	\$75	\$375	
24355	13.7 to 15.1 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	7	SF	\$120	\$840	
55024	29.7 to 30.7 feet	Vertical Change	.3	5 ft	5	LF	\$75	\$375	
24356	34.1 to 37.5 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	17	SF	\$120	\$2,040	
24358	42.2 to 64.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	109	SF	\$120	\$13,080	
24367	66.3 to 80.9 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	73	SF	\$120	\$8,760	
55025	78.9 to 82.2 feet	Vertical Change	.3	5 ft	16	REF			
24372	80.9 to 92.9 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	60	SF	\$120	\$7,200	
24377	93.5 to 95.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	11	SF	\$120	\$1,320	
55027	106.3 to 107.3 feet	Vertical Change	.3	5 ft	5	REF			
24378	106.3 to 109.3 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	15	SF	\$120	\$1,800	
24380	110.9 to 112.8 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	10	SF	\$120	\$1,140	
24381	117.8 to 122.7 feet	Cross Slope (PAR)	3.0-4.0%	5 ft	25	SF	\$120	\$2,940	
24383	122.7 to 149.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	135	SF	\$120	\$16,200	
59419	122.8 to 178.8 feet	Driveway				REF			
56758	131.1 to 132.1 feet	Vertical Change	.5	5 ft	5	REF			
24392	150.9 to 163.0 feet	Cross Slope (Driveway)	4.0-5.0%	5 ft	61	SF	\$40	\$2,420	
57560	154.3 to 155.3 feet	Vertical Change	2.4	5 ft	5	REF			
24396	163.0 to 164.1 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	6	SF	\$40	\$220	
24397	171.7 to 176.8 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	26	SF	\$40	\$1,020	
55028	173.0 to 174.0 feet	Vertical Change	.3	5 ft	5	REF			
57473	180.9 to 181.9 feet	Vertical Change	1.5	5 ft	5	SF	\$75	\$375	
24398	199.1 to 203.6 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	23	SF	\$120	\$2,700	
24399	207.2 to 223.7 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	83	SF	\$120	\$9,900	
24404	223.7 to 227.7 feet	Cross Slope (PAR)	4.0-5.0%	5 ft	20	SF	\$120	\$2,400	
59420	226.7 to 245.8 feet	Driveway				REF			
24406	228.3 to 248.5 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	101	SF	\$40	\$4,040	
56279	257.8 to 258.8 feet	Vertical Change	.4	5 ft	5	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	1909261630	6TH ST	TRINITY AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
24408	258.7 to 271.0 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	62	SF	\$120	\$7,380
24411	284.1 to 290.2 feet	Cross Slope (PAR)	2.0-3.0%	5 ft	30	SF	\$120	\$3,660
59421	295.0 to 305.2 feet	Driveway				REF		
24413	296.1 to 308.4 feet	Cross Slope (Driveway)	2.0-3.0%	5 ft	61	SF	\$40	\$2,460
TOTAL COST FOR: NE side of 6TH ST Starting at: TRINITY AVE							\$92,645.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	5190926244	13TH ST	HUMBOLDT AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28092	0.0 to 6.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,158
TOTAL COST FOR: SW side of 13TH ST Starting at: HUMBOLDT AVE								\$4,158.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	51909231606	SANTA CRUZ BLVD	BLOSSOM DR	CAMELLIA DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28094	0.0 to 38.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	210	SF	\$120	\$25,146
28102	39.3 to 42.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$1,980
28103	53.4 to 63.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	57	SF	\$120	\$6,864
28108	95.5 to 102.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,752
28110	117.8 to 127.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	56	SF	\$120	\$6,666
28112	132.5 to 136.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838
28113	139.0 to 152.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	72	SF	\$120	\$8,646
28116	152.4 to 174.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	123	SF	\$120	\$14,784
TOTAL COST FOR: W side of SANTA CRUZ BLVD Starting at: BLOSSOM DR							\$71,676.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	51909231608	CAMELLIA DR	SANTA CRUZ BLVD	CHESTNUT DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
45375	1.3 to 2.3 feet	Vertical Change	-.5	6 ft	5	SF	\$75	\$413
28120	14.5 to 15.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
50999	16.1 to 17.1 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
28121	21.0 to 22.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
51000	23.0 to 24.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
59592	25.4 to 46.8 feet	Driveway				REF		
51001	26.9 to 27.9 feet	Vertical Change	-.3	6 ft	6	REF		
28122	32.6 to 38.0 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	30	SF	\$40	\$1,188
28124	40.9 to 44.9 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	22	SF	\$40	\$880
59593	57.0 to 78.5 feet	Driveway				REF		
28125	62.8 to 75.8 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	72	SF	\$40	\$2,860
28130	98.8 to 101.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$1,980
28131	119.3 to 122.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376
57538	131.3 to 132.3 feet	Vertical Change	2.1	6 ft	6	SF	\$75	\$413
28132	140.0 to 145.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630
59594	145.8 to 165.6 feet	Driveway				REF		
28135	152.2 to 164.6 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	68	SF	\$40	\$2,728
28137	165.4 to 166.5 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	6	SF	\$40	\$242
28138	172.9 to 175.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782
59595	176.6 to 197.8 feet	Driveway				REF		
28139	183.3 to 191.8 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	47	SF	\$40	\$1,870
28141	195.0 to 198.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	18	SF	\$40	\$726
40824	197.4 to 199.4 feet	Running Slope	5.0-6.0%	6 ft	11	REF		
51002	202.2 to 203.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
28143	208.5 to 212.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838
28144	218.2 to 219.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
TOTAL COST FOR: N side of CAMELLIA DR Starting at: SANTA CRUZ BLVD							\$27,604.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
E	51909231610	CHESTNUT DR	CAMELLIA DR	BLOSSOM DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28145	14.8 to 20.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630
28146	39.6 to 43.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244
28147	51.3 to 53.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
28148	58.8 to 74.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	85	SF	\$120	\$10,230
55324	78.2 to 79.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
28153	81.3 to 103.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	122	SF	\$120	\$14,652
28157	107.2 to 120.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	71	SF	\$120	\$8,514
28159	124.6 to 130.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
55325	156.3 to 157.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: E side of CHESTNUT DR Starting at: CAMELLIA DR							\$44,979.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	51909231612	BLOSSOM DR	CHESTNUT DR	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
51003	5.0 to 6.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
28162	14.6 to 23.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$5,940	
59596	23.5 to 42.9 feet	Driveway				REF			
28164	27.4 to 28.4 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	6	SF	\$40	\$220	
28165	31.7 to 44.5 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	70	SF	\$40	\$2,816	
57360	47.2 to 48.2 feet	Vertical Change	1	6 ft	6	SF	\$75	\$413	
55326	52.3 to 53.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
59597	54.8 to 77.9 feet	Driveway				REF			
28168	62.3 to 72.0 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	53	SF	\$40	\$2,134	
45376	66.5 to 67.5 feet	Vertical Change	-.5	6 ft	6	REF			
28170	72.3 to 74.4 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	12	SF	\$40	\$462	
28171	86.5 to 93.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,818	
28174	100.1 to 104.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772	
28175	109.3 to 112.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112	
51004	140.0 to 141.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
59598	143.3 to 164.5 feet	Driveway				REF			
28176	146.4 to 147.4 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	6	SF	\$40	\$220	
28177	151.3 to 165.4 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	78	SF	\$40	\$3,102	
59599	173.3 to 197.0 feet	Driveway				REF			
28181	179.8 to 197.1 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	95	SF	\$40	\$3,806	
28187	202.3 to 204.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716	
28188	209.1 to 212.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178	
TOTAL COST FOR: S							side of BLOSSOM DR Starting at: CHESTNUT DR	\$33,946.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	51909231615	BLOSSOM DR	SANTA CRUZ BLVD	CHESTNUT DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28189	2.8 to 16.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	75	SF	\$120	\$9,042
59600	33.3 to 55.6 feet	Driveway				REF		
28194	39.5 to 43.3 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	21	SF	\$40	\$836
28195	45.9 to 55.9 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	55	SF	\$40	\$2,200
28198	56.5 to 57.5 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	6	SF	\$40	\$220
59601	64.8 to 86.8 feet	Driveway				REF		
28199	70.3 to 77.9 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	42	SF	\$40	\$1,672
28201	78.7 to 84.8 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	34	SF	\$40	\$1,342
28202	152.4 to 154.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518
59602	153.6 to 173.8 feet	Driveway				REF		
28203	156.9 to 157.9 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	6	SF	\$40	\$220
28204	159.6 to 171.1 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	63	SF	\$40	\$2,530
28208	171.6 to 174.8 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	18	SF	\$40	\$704
55327	182.9 to 183.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
59603	186.8 to 205.0 feet	Driveway				REF		
28209	191.1 to 202.8 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	64	SF	\$40	\$2,574
55328	195.5 to 196.5 feet	Vertical Change	.3	6 ft	6	REF		
51005	207.6 to 208.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
28212	233.3 to 247.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	80	SF	\$120	\$9,570
59604	262.6 to 283.2 feet	Driveway				REF		
28219	270.0 to 274.2 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	23	SF	\$40	\$924
28221	275.1 to 276.1 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	6	SF	\$40	\$220
28222	276.3 to 282.8 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	36	SF	\$40	\$1,430
51006	298.7 to 299.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
59605	301.3 to 319.1 feet	Driveway				REF		
51007	302.0 to 303.0 feet	Vertical Change	-.3	6 ft	6	REF		
28224	306.9 to 320.0 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	72	SF	\$40	\$2,882
55329	312.2 to 313.2 feet	Vertical Change	.3	6 ft	6	REF		
59606	327.1 to 349.4 feet	Driveway				REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	51909231615	BLOSSOM DR	SANTA CRUZ BLVD	CHESTNUT DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28230	332.6 to 347.7 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	83	SF	\$40	\$3,322
55330	339.0 to 340.0 feet	Vertical Change	.3	6 ft	6	REF		
51008	351.6 to 352.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
40825	355.3 to 356.3 feet	Running Slope	5.0-6.0%	6 ft	6	SF	\$120	\$660
TOTAL COST FOR: N side of BLOSSOM DR Starting at: SANTA CRUZ BLVD							\$43,516.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
W	51909231617	CHESTNUT DR	BLOSSOM DR	CAMELLIA DR				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28235	11.5 to 21.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	57	SF	\$120	\$6,798
28238	46.3 to 52.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,356
59607	50.9 to 69.0 feet	Driveway				REF		
28241	57.3 to 63.0 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	31	SF	\$40	\$1,254
47705	62.1 to 63.1 feet	Vertical Change	-.4	6 ft	6	REF		
28243	63.8 to 69.5 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	31	SF	\$40	\$1,254
28245	70.8 to 71.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
59608	81.3 to 103.5 feet	Driveway				REF		
55331	82.0 to 83.0 feet	Vertical Change	.3	6 ft	6	REF		
28246	84.3 to 85.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$220
28247	88.7 to 102.1 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	74	SF	\$40	\$2,948
28253	103.8 to 104.8 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	6	SF	\$40	\$220
28254	105.3 to 107.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
28255	112.2 to 115.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848
51009	164.2 to 165.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
59609	168.4 to 189.6 feet	Driveway				REF		
51010	169.4 to 170.4 feet	Vertical Change	-.3	6 ft	6	REF		
28256	175.8 to 192.3 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	91	SF	\$40	\$3,630
TOTAL COST FOR: W side of CHESTNUT DR Starting at: BLOSSOM DR							\$24,986.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
S	51909231619	CAMELLIA DR	CHESTNUT DR	SANTA CRUZ BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
59610	5.0 to 24.3 feet	Driveway				REF			
28262	9.5 to 11.9 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	13	SF	\$40	\$528	
28264	11.9 to 16.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	27	SF	\$40	\$1,078	
55332	15.8 to 16.8 feet	Vertical Change	.3	6 ft	6	REF			
28266	16.8 to 24.4 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	42	SF	\$40	\$1,672	
28269	24.4 to 26.0 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	9	SF	\$40	\$352	
51011	27.6 to 28.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
56386	51.5 to 52.5 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
59611	61.6 to 83.2 feet	Driveway				REF			
55333	62.2 to 63.2 feet	Vertical Change	.3	6 ft	6	REF			
28270	65.9 to 67.1 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	7	SF	\$40	\$264	
28271	69.7 to 73.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	20	SF	\$40	\$792	
51012	74.5 to 75.5 feet	Vertical Change	-.3	6 ft	6	REF			
28272	76.0 to 85.8 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	54	SF	\$40	\$2,156	
59612	89.1 to 108.9 feet	Driveway				REF			
28275	97.4 to 104.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	38	SF	\$40	\$1,518	
56387	100.3 to 101.3 feet	Vertical Change	.4	6 ft	6	REF			
28279	105.0 to 108.0 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	17	SF	\$40	\$660	
28280	143.9 to 148.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904	
55334	163.6 to 164.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
59613	169.6 to 188.2 feet	Driveway				REF			
28281	173.6 to 189.1 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	85	SF	\$40	\$3,410	
28288	189.1 to 190.5 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	8	SF	\$120	\$924	
56388	194.5 to 195.5 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
51013	198.2 to 199.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
59614	199.9 to 219.4 feet	Driveway				REF			
28289	201.3 to 203.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	12	SF	\$40	\$462	
28291	204.4 to 220.6 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	89	SF	\$40	\$3,564	
55335	211.4 to 212.4 feet	Vertical Change	.3	6 ft	6	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	51909231619	CAMELLIA DR	CHESTNUT DR	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28296	220.6 to 221.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	7	SF	\$120	\$792
28297	264.8 to 272.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,214
51014	284.9 to 288.4 feet	Vertical Change	-.3	6 ft	19	LF	\$75	\$1,444
28299	287.5 to 289.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
59615	288.3 to 311.5 feet	Driveway				REF		
28300	293.4 to 297.2 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	21	SF	\$40	\$836
28302	298.0 to 303.9 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	32	SF	\$40	\$1,298
28304	304.8 to 311.1 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	35	SF	\$40	\$1,386
40826	309.8 to 311.3 feet	Running Slope	5.0-6.0%	6 ft	8	REF		
28306	312.0 to 313.1 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	6	SF	\$40	\$242
59616	318.9 to 370.6 feet	Driveway				REF		
28307	324.4 to 339.4 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	83	SF	\$40	\$3,300
40827	338.8 to 340.1 feet	Running Slope	5.0-6.0%	6 ft	7	REF		
51016	345.2 to 346.2 feet	Vertical Change	-.3	6 ft	6	REF		
28311	345.6 to 349.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	22	SF	\$40	\$880
28312	356.3 to 369.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	74	SF	\$40	\$2,970
TOTAL COST FOR: S side of CAMELLIA DR Starting at: CHESTNUT DR							\$41,830.25	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
W	51909231621	SANTA CRUZ BLVD	CAMELLIA DR	HOWELL RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28316	0.0 to 28.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	156	SF	\$120	\$18,678
28323	28.8 to 39.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	59	SF	\$120	\$7,128
28326	81.8 to 85.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376
55336	105.2 to 106.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
28327	123.8 to 130.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,158
28329	137.2 to 141.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,706
28330	143.7 to 163.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	111	SF	\$120	\$13,266
28335	166.1 to 174.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,742
TOTAL COST FOR: W side of SANTA CRUZ BLVD Starting at: CAMELLIA DR							\$54,466.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
N	51909231625	HOWELL RD	SANTA CRUZ BLVD	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
47706	4.5 to 5.5 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413	
28337	6.4 to 9.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	14	SF	\$120	\$1,716	
28338	9.0 to 26.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	98	SF	\$120	\$11,748	
59617	24.5 to 46.0 feet	Driveway				REF			
28341	30.9 to 43.8 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	71	SF	\$40	\$2,838	
28344	58.2 to 64.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,828	
59618	81.8 to 106.3 feet	Driveway				REF			
51017	82.6 to 83.6 feet	Vertical Change	-.3	6 ft	6	REF			
28346	88.8 to 96.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	41	SF	\$40	\$1,650	
28349	96.3 to 103.2 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	38	SF	\$40	\$1,518	
28351	113.9 to 115.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
59619	114.9 to 136.7 feet	Driveway				REF			
28352	122.0 to 134.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	68	SF	\$40	\$2,706	
28356	137.8 to 139.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
28357	169.9 to 174.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,102	
105	175.1 to 176.1 feet	Continuous Width		6 ft	6	SF	\$120	\$660	
51018	176.3 to 177.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
28358	202.5 to 204.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254	
59620	203.8 to 225.4 feet	Driveway				REF			
28359	209.6 to 214.4 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	26	SF	\$40	\$1,056	
28361	214.4 to 218.5 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	23	SF	\$40	\$902	
28363	219.5 to 223.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	21	SF	\$40	\$836	
28364	234.2 to 236.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386	
59621	234.3 to 254.0 feet	Driveway				REF			
28365	242.5 to 254.0 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	63	SF	\$40	\$2,530	
28368	254.6 to 255.6 feet	Cross Slope (PAR)	7.0-8.0%	6 ft	6	SF	\$120	\$660	
28369	280.1 to 283.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310	
55337	299.4 to 300.4 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
55338	308.6 to 309.6 feet	Vertical Change	.3	6 ft	6	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
N	51909231625	HOWELL RD	SANTA CRUZ BLVD	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28371	309.3 to 311.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,584
28372	322.0 to 326.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
59622	322.9 to 343.9 feet	Driveway				REF		
51019	324.7 to 325.7 feet	Vertical Change	-3	6 ft	6	REF		
28374	329.3 to 335.2 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	32	SF	\$40	\$1,298
28375	340.0 to 344.6 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	25	SF	\$40	\$1,012
28377	344.6 to 345.8 feet	Cross Slope (PAR)	8.0-9.0%	6 ft	7	SF	\$120	\$792
51020	347.3 to 348.3 feet	Vertical Change	-3	6 ft	6	REF		
28378	347.8 to 348.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726
59623	354.6 to 377.5 feet	Driveway				REF		
47707	355.6 to 356.6 feet	Vertical Change	-4	6 ft	6	REF		
28379	358.4 to 359.4 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	6	SF	\$40	\$220
28380	359.8 to 375.5 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	86	SF	\$40	\$3,454
TOTAL COST FOR: N side of HOWELL RD Starting at: SANTA CRUZ BLVD							\$55,643.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
S	51909231630	HOWELL RD	SIDEWALK BEGINS	COTTONWOOD DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
28393	27.1 to 46.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	106	SF	\$120	\$12,738	
28399	46.4 to 65.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	104	SF	\$120	\$12,474	
55339	61.2 to 62.2 feet	Vertical Change	.3	6 ft	6	REF			
59625	64.7 to 83.0 feet	Driveway				REF			
28403	68.7 to 75.3 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	36	SF	\$40	\$1,452	
28407	75.8 to 83.9 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	45	SF	\$40	\$1,782	
28408	87.3 to 89.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716	
28409	92.3 to 103.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	59	SF	\$120	\$7,128	
28412	107.1 to 110.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	19	SF	\$120	\$2,310	
59626	107.2 to 128.3 feet	Driveway				REF			
28414	114.1 to 118.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	23	SF	\$40	\$924	
28415	121.0 to 127.7 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	37	SF	\$40	\$1,474	
28417	131.3 to 153.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	124	SF	\$120	\$14,916	
28420	156.8 to 179.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	124	SF	\$120	\$14,850	
59627	176.6 to 196.3 feet	Driveway				REF			
28425	182.3 to 192.8 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	58	SF	\$40	\$2,310	
28427	192.8 to 195.9 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	17	SF	\$40	\$682	
40829	196.8 to 198.0 feet	Running Slope	6.0-7.0%	6 ft	7	SF	\$120	\$792	
28429	198.6 to 200.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$924	
28430	200.2 to 201.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056	
28431	204.7 to 220.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	85	SF	\$120	\$10,230	
55340	221.8 to 222.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
28434	223.0 to 225.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	12	SF	\$120	\$1,452	
59628	224.9 to 243.1 feet	Driveway				REF			
28435	232.7 to 244.3 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	64	SF	\$40	\$2,552	
28439	247.7 to 259.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	64	SF	\$120	\$7,722	
47708	250.6 to 251.6 feet	Vertical Change	-.4	6 ft	6	REF			

TOTAL COST FOR: S side of HOWELL RD Starting at: SIDEWALK BEGINS \$99,896.50

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	51909231636	HOWELL RD	COTTONWOOD DR	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40830	0.0 to 1.1 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
28442	0.8 to 10.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	54	SF	\$120	\$6,534
59629	10.5 to 30.8 feet	Driveway				REF		
28445	13.9 to 14.9 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	6	SF	\$40	\$220
28446	16.5 to 19.0 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	14	SF	\$40	\$550
28448	19.0 to 25.2 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	34	SF	\$40	\$1,364
28451	25.8 to 30.6 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	26	SF	\$40	\$1,056
28453	37.3 to 56.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	103	SF	\$120	\$12,342
59630	58.1 to 77.1 feet	Driveway				REF		
28457	58.6 to 59.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	7	SF	\$40	\$264
28458	63.0 to 67.8 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	26	SF	\$40	\$1,056
28461	70.1 to 78.5 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	46	SF	\$40	\$1,848
40831	78.5 to 81.1 feet	Running Slope	5.0-6.0%	6 ft	14	REF		
28463	82.3 to 93.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	62	SF	\$120	\$7,392
28465	98.0 to 138.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	225	SF	\$120	\$26,994
106	123.3 to 124.3 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
45377	132.3 to 137.4 feet	Vertical Change	-.5	6 ft	28	REF		
59631	138.6 to 153.6 feet	Driveway				REF		
28472	142.1 to 156.3 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	78	SF	\$40	\$3,124
28477	158.4 to 163.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	29	SF	\$120	\$3,498
28479	165.1 to 179.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	76	SF	\$120	\$9,174
59632	179.8 to 208.3 feet	Driveway				REF		
28482	181.6 to 182.7 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	6	SF	\$40	\$242
28483	184.6 to 199.7 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	83	SF	\$40	\$3,322
28487	199.8 to 210.3 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	58	SF	\$40	\$2,310
40832	211.3 to 212.3 feet	Running Slope	5.0-6.0%	6 ft	6	SF	\$120	\$660
28489	215.3 to 226.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	63	SF	\$120	\$7,590
55341	224.1 to 225.1 feet	Vertical Change	.3	6 ft	6	REF		
28492	232.8 to 236.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	51909231636	HOWELL RD	COTTONWOOD DR	SANTA CRUZ BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28493	239.0 to 242.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,442
28494	249.3 to 260.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	63	SF	\$120	\$7,590
51023	250.1 to 251.1 feet	Vertical Change	-.3	6 ft	6	REF		
59633	257.8 to 278.2 feet	Driveway				REF		
28496	263.9 to 278.9 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	83	SF	\$40	\$3,300
40833	279.1 to 280.5 feet	Running Slope	6.0-7.0%	6 ft	8	SF	\$120	\$924
28499	285.5 to 302.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	96	SF	\$120	\$11,484
56389	300.5 to 301.5 feet	Vertical Change	.4	6 ft	6	REF		
28505	305.4 to 314.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	49	SF	\$120	\$5,874
41271	309.8 to 310.8 feet	Vertical Change	-1.7	6 ft	6	REF		
59634	314.5 to 333.6 feet	Driveway				REF		
28508	320.2 to 326.8 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	36	SF	\$40	\$1,452
47709	323.8 to 324.8 feet	Vertical Change	-.4	6 ft	6	REF		
28511	326.8 to 333.4 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	36	SF	\$40	\$1,452
51024	337.9 to 338.9 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
28513	349.3 to 352.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046
59635	351.4 to 371.3 feet	Driveway				REF		
28515	357.0 to 359.8 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	15	SF	\$40	\$616
28517	359.8 to 364.8 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	28	SF	\$40	\$1,100
28520	367.3 to 370.6 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	18	SF	\$40	\$726
40834	371.1 to 372.8 feet	Running Slope	5.0-6.0%	6 ft	9	REF		
28521	373.9 to 375.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
51025	375.2 to 376.2 feet	Vertical Change	-.3	6 ft	6	REF		
56390	391.4 to 392.4 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
28522	417.4 to 422.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
59636	420.1 to 438.9 feet	Driveway				REF		
28524	426.0 to 438.5 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	69	SF	\$40	\$2,750
28526	438.5 to 440.2 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	9	SF	\$40	\$374
40835	440.1 to 441.3 feet	Running Slope	5.0-6.0%	6 ft	7	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
S	51909231636	HOWELL RD	COTTONWOOD DR	SANTA CRUZ BLVD				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28527	441.8 to 445.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	21	SF	\$120	\$2,574
28529	445.7 to 447.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
59637	456.3 to 487.8 feet	Driveway				REF		
28530	459.1 to 460.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$220
28531	462.5 to 478.1 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	86	SF	\$40	\$3,432
28535	478.1 to 486.0 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	43	SF	\$40	\$1,738
40836	488.3 to 489.3 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
28537	490.6 to 491.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726
28538	494.9 to 511.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	90	SF	\$120	\$10,824
28542	513.5 to 522.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,808
59638	527.8 to 546.1 feet	Driveway				REF		
28544	528.3 to 529.3 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	6	SF	\$40	\$220
28545	532.8 to 546.0 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	73	SF	\$40	\$2,904
51026	537.6 to 538.6 feet	Vertical Change	-.3	6 ft	6	REF		
28550	549.5 to 550.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660
28551	550.5 to 551.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
28552	555.8 to 556.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
59639	563.9 to 581.8 feet	Driveway				REF		
28553	570.3 to 573.6 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	18	SF	\$40	\$726
28555	573.8 to 583.3 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	52	SF	\$40	\$2,090
51027	584.7 to 585.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
28557	586.8 to 591.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
28559	594.0 to 597.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	20	SF	\$120	\$2,442
51028	596.5 to 597.5 feet	Vertical Change	-.3	6 ft	6	REF		
28561	597.9 to 603.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630
28562	605.6 to 610.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	26	SF	\$120	\$3,102
51029	606.6 to 607.6 feet	Vertical Change	-.3	6 ft	6	REF		
28564	611.8 to 624.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	72	SF	\$120	\$8,646

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
S	51909231636	HOWELL RD	COTTONWOOD DR	SANTA CRUZ BLVD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
56391	626.7 to 627.7 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
43520	629.2 to 630.2 feet	Vertical Change	-.6	6 ft	6	SF	\$75	\$413	
59640	632.4 to 649.8 feet	Driveway				REF			
28568	636.8 to 641.2 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	24	SF	\$40	\$968	
28570	641.2 to 644.2 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	17	SF	\$40	\$660	
28571	646.8 to 648.1 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	7	SF	\$40	\$286	
28572	654.3 to 663.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$5,940	
51030	658.6 to 659.6 feet	Vertical Change	-.3	6 ft	6	REF			
47710	662.5 to 663.5 feet	Vertical Change	-.4	6 ft	6	REF			
59641	664.5 to 685.9 feet	Driveway				REF			
28575	670.3 to 683.8 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	74	SF	\$40	\$2,970	
56392	674.2 to 675.2 feet	Vertical Change	.4	6 ft	6	REF			
TOTAL COST FOR: S							<i>side of</i> HOWELL RD	<i>Starting at:</i> COTTONWOOD DR	\$206,607.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	51909231641	HOWELL RD	SANTA CRUZ BLVD	OLEANDER DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28579	6.7 to 13.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,356
55342	14.6 to 15.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
28581	18.9 to 20.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858
59642	19.0 to 47.3 feet	Driveway				REF		
28582	22.4 to 23.5 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	6	SF	\$40	\$242
28583	23.8 to 35.3 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	63	SF	\$40	\$2,530
28585	35.3 to 48.6 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	73	SF	\$40	\$2,926
40837	48.6 to 49.7 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
28590	51.8 to 53.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858
28591	53.1 to 69.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	91	SF	\$120	\$10,890
59643	67.8 to 96.7 feet	Driveway				REF		
28594	71.8 to 75.1 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	18	SF	\$40	\$726
28596	75.1 to 83.8 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	48	SF	\$40	\$1,914
55343	75.7 to 76.7 feet	Vertical Change	.3	6 ft	6	REF		
28598	84.2 to 95.1 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	60	SF	\$40	\$2,398
40838	97.0 to 98.0 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
28600	101.1 to 135.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	188	SF	\$120	\$22,506
51031	103.3 to 104.3 feet	Vertical Change	-.3	6 ft	6	REF		
51032	114.8 to 115.8 feet	Vertical Change	-.3	6 ft	6	REF		
47711	121.3 to 122.3 feet	Vertical Change	-.4	6 ft	6	REF		
55344	127.9 to 128.9 feet	Vertical Change	.3	6 ft	6	REF		
51033	137.1 to 138.1 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
28610	143.6 to 148.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,432
59644	146.0 to 176.4 feet	Driveway				REF		
28613	150.4 to 151.4 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	6	SF	\$40	\$220
28614	151.8 to 154.5 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	15	SF	\$40	\$594
28615	157.4 to 161.4 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	22	SF	\$40	\$880
28617	163.7 to 166.5 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	15	SF	\$40	\$616

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	51909231641	HOWELL RD	SANTA CRUZ BLVD	OLEANDER DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28618	168.8 to 176.7 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	43	SF	\$40	\$1,738
28620	182.6 to 186.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
59645	196.9 to 218.1 feet	Driveway				REF		
28621	202.5 to 204.3 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	10	SF	\$40	\$396
28622	207.8 to 217.0 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	51	SF	\$40	\$2,024
55345	217.8 to 218.8 feet	Vertical Change	.3	6 ft	6	REF		
28624	219.0 to 220.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660
28625	221.5 to 223.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254
28626	227.4 to 234.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,686
28628	247.4 to 249.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
28629	269.6 to 283.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	74	SF	\$120	\$8,844
59646	286.8 to 308.2 feet	Driveway				REF		
28632	287.3 to 288.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	8	SF	\$40	\$308
55346	287.8 to 288.8 feet	Vertical Change	.3	6 ft	6	REF		
28633	292.6 to 306.1 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	74	SF	\$40	\$2,970
28638	309.9 to 321.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	63	SF	\$120	\$7,524
28642	321.9 to 327.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894
59647	326.0 to 354.4 feet	Driveway				REF		
28644	330.3 to 349.7 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	107	SF	\$40	\$4,268
28648	350.3 to 355.2 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	27	SF	\$40	\$1,078
28650	364.5 to 375.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	59	SF	\$120	\$7,062
51034	364.8 to 365.8 feet	Vertical Change	-.3	6 ft	6	REF		
28651	385.3 to 395.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	55	SF	\$120	\$6,600
59648	403.9 to 435.6 feet	Driveway				REF		
28652	404.8 to 406.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	10	SF	\$40	\$396
51035	405.8 to 406.8 feet	Vertical Change	-.3	6 ft	6	REF		
28653	411.0 to 435.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	134	SF	\$40	\$5,346
28659	440.2 to 444.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,706
28661	447.1 to 456.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$5,940

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	51909231641	HOWELL RD	SANTA CRUZ BLVD	OLEANDER DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59649	453.9 to 485.5 feet	Driveway				REF		
28663	459.8 to 465.0 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	29	SF	\$40	\$1,144
28665	466.0 to 476.5 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	58	SF	\$40	\$2,310
28669	478.4 to 483.6 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	29	SF	\$40	\$1,144
56393	485.9 to 486.9 feet	Vertical Change	.4	6 ft	6	REF		
45378	502.4 to 503.5 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$454
28671	526.8 to 544.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	100	SF	\$120	\$11,946
59650	543.2 to 563.5 feet	Driveway				REF		
28676	549.2 to 553.1 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	21	SF	\$40	\$858
28678	554.4 to 563.9 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	52	SF	\$40	\$2,090
28681	568.0 to 583.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	83	SF	\$120	\$9,966
59651	581.3 to 610.7 feet	Driveway				REF		
28684	585.9 to 606.8 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	115	SF	\$40	\$4,598
28691	606.8 to 611.1 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	24	SF	\$40	\$946
28692	613.3 to 614.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660
28693	614.3 to 615.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
28694	621.1 to 623.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782
TOTAL COST FOR: S side of HOWELL RD Starting at: SANTA CRUZ BLVD							\$167,048.75	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	51909231705	VENTURA AVE	6TH ST	5TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
28695	0.0 to 20.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	111	SF	\$120	\$13,332	
40839	1.0 to 2.0 feet	Running Slope	5.0-6.0%	6 ft	6	REF			
28698	23.0 to 31.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	46	SF	\$120	\$5,478	
28699	31.5 to 67.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	196	SF	\$120	\$23,562	
28706	67.2 to 70.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	17	SF	\$120	\$1,980	
28707	72.7 to 76.7 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	22	SF	\$120	\$2,640	
28709	76.7 to 88.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	64	SF	\$120	\$7,656	
28712	89.1 to 91.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782	
59652	90.1 to 112.3 feet	Driveway				REF			
28713	93.6 to 94.7 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	6	SF	\$40	\$242	
40840	94.5 to 96.3 feet	Running Slope	8.0-9.0%	6 ft	10	REF			
57266	94.7 to 95.7 feet	Vertical Change	.8	6 ft	6	REF			
28714	98.8 to 107.6 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	48	SF	\$40	\$1,936	
40841	106.3 to 107.6 feet	Running Slope	5.0-6.0%	6 ft	7	REF			
40842	109.8 to 111.1 feet	Running Slope	8.0-9.0%	6 ft	7	REF			
28717	112.0 to 113.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	7	SF	\$40	\$286	
28718	127.3 to 133.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,290	
28720	153.3 to 200.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	261	SF	\$120	\$31,350	
51037	182.8 to 183.8 feet	Vertical Change	-.3	6 ft	6	REF			
28731	203.6 to 206.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,584	
28732	210.5 to 221.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	62	SF	\$120	\$7,392	
59653	220.8 to 255.8 feet	Driveway				REF			
28733	226.6 to 231.9 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	29	SF	\$40	\$1,166	
28735	237.8 to 240.1 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	13	SF	\$40	\$506	
28736	241.8 to 244.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	17	SF	\$40	\$660	
107	243.0 to 244.0 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
28737	247.6 to 256.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	48	SF	\$40	\$1,914	
28740	259.9 to 281.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	119	SF	\$120	\$14,256	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909231705	VENTURA AVE	6TH ST	5TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28745	281.5 to 283.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	10	SF	\$120	\$1,188
TOTAL COST FOR: SE side of VENTURA AVE Starting at: 6TH ST							\$123,299.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	51909231708	VENTURA AVE	5TH ST	4TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
28746	1.8 to 20.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	103	SF	\$120	\$12,408	
28751	23.8 to 62.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	215	SF	\$120	\$25,806	
59654	63.0 to 80.6 feet	Driveway				REF			
28761	66.8 to 77.3 feet	Cross Slope (Driveway)	>15%	6 ft	58	SF	\$40	\$2,310	
28762	77.8 to 78.8 feet	Cross Slope (Driveway)	13.014	6 ft	6	SF	\$40	\$220	
40843	79.0 to 80.2 feet	Running Slope	7.0-8.0%	6 ft	7	REF			
28763	83.8 to 92.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	45	SF	\$120	\$5,412	
51038	86.4 to 87.4 feet	Vertical Change	-.3	6 ft	6	REF			
28766	92.0 to 93.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254	
59655	93.6 to 111.7 feet	Driveway				REF			
51039	94.5 to 95.5 feet	Vertical Change	-.3	6 ft	6	REF			
28767	99.2 to 109.5 feet	Cross Slope (Driveway)	13.014	6 ft	57	SF	\$40	\$2,266	
56394	109.1 to 110.1 feet	Vertical Change	.4	6 ft	6	REF			
28769	115.1 to 126.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	65	SF	\$120	\$7,788	
28770	130.8 to 134.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376	
28772	136.1 to 142.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	34	SF	\$120	\$4,026	
59656	140.1 to 156.0 feet	Driveway				REF			
47712	142.3 to 143.3 feet	Vertical Change	-.4	6 ft	6	REF			
28774	147.4 to 155.9 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	47	SF	\$40	\$1,870	
40844	156.5 to 158.0 feet	Running Slope	5.0-6.0%	6 ft	8	REF			
28776	159.3 to 163.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772	
28778	165.4 to 176.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	61	SF	\$120	\$7,260	
28781	178.5 to 186.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	45	SF	\$120	\$5,412	
28784	190.8 to 192.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122	
28785	202.9 to 222.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	108	SF	\$120	\$13,002	
55347	206.5 to 207.5 feet	Vertical Change	.3	6 ft	6	REF			
28792	225.8 to 236.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	57	SF	\$120	\$6,798	
28795	241.8 to 245.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909231708	VENTURA AVE	5TH ST	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28796	248.0 to 260.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	68	SF	\$120	\$8,118
28799	266.6 to 280.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	78	SF	\$120	\$9,306
40845	279.8 to 281.2 feet	Running Slope	5.0-6.0%	6 ft	8	REF		
TOTAL COST FOR: SE side of VENTURA AVE Starting at: 5TH ST							\$121,836.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	51909231712	VENTURA AVE	4TH ST	3RD ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
28802	4.3 to 30.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	143	SF	\$120	\$17,160	
108	32.7 to 33.7 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
28808	32.8 to 44.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	64	SF	\$120	\$7,656	
28812	49.0 to 51.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452	
28813	56.1 to 63.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,016	
28814	73.8 to 76.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	15	SF	\$120	\$1,848	
28815	78.8 to 83.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904	
28816	86.1 to 88.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452	
28817	91.2 to 109.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	100	SF	\$120	\$12,012	
28820	113.1 to 115.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	11	SF	\$120	\$1,320	
28821	115.3 to 139.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	133	SF	\$120	\$15,906	
55348	119.7 to 120.7 feet	Vertical Change	.3	6 ft	6	REF			
109	129.1 to 130.1 feet	Continuous Width		6 ft	6	SF	\$120	\$660	
59657	135.4 to 153.3 feet	Driveway				REF			
28824	142.7 to 143.7 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	6	SF	\$40	\$220	
28825	145.3 to 149.7 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	24	SF	\$40	\$968	
28827	150.1 to 152.7 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	14	SF	\$40	\$572	
28828	157.0 to 202.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	249	SF	\$120	\$29,898	
56395	175.0 to 176.0 feet	Vertical Change	.4	6 ft	6	REF			
28840	205.5 to 206.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858	
28841	208.5 to 212.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310	
28843	214.5 to 227.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	74	SF	\$120	\$8,844	
59658	225.4 to 242.3 feet	Driveway				REF			
28847	231.8 to 241.1 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	51	SF	\$40	\$2,046	
57200	232.0 to 233.0 feet	Vertical Change	.7	6 ft	6	REF			
51040	235.8 to 236.8 feet	Vertical Change	-.3	6 ft	6	REF			
28850	245.8 to 250.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,970	
28852	254.1 to 285.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	172	SF	\$120	\$20,658	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
SE	51909231712	VENTURA AVE	4TH ST	3RD ST	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
28861	287.5 to 291.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	21	SF	\$120	\$2,574			
28862	292.1 to 294.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782			
TOTAL COST FOR: SE							<i>side of</i>	VENTURA AVE	<i>Starting at:</i>	4TH ST	\$141,185.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	51909231723	VENTURA AVE	CALAVERAS ST	CIRCLE DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
28863	0.0 to 2.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	12	SF	\$120	\$1,452	
28864	2.4 to 10.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,016	
51041	2.5 to 3.5 feet	Vertical Change	-.3	6 ft	6	REF			
28867	10.7 to 13.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	15	SF	\$120	\$1,782	
28868	16.4 to 37.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	118	SF	\$120	\$14,124	
55349	23.6 to 24.6 feet	Vertical Change	.3	6 ft	6	REF			
51042	31.1 to 32.1 feet	Vertical Change	-.3	6 ft	6	REF			
59659	35.2 to 60.8 feet	Driveway				REF			
55350	37.8 to 38.8 feet	Vertical Change	.3	6 ft	6	REF			
40846	37.9 to 38.9 feet	Running Slope	5.0-6.0%	6 ft	6	REF			
28874	42.3 to 57.3 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	83	SF	\$40	\$3,300	
28877	62.3 to 93.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	174	SF	\$120	\$20,856	
56396	91.2 to 92.2 feet	Vertical Change	.4	6 ft	6	REF			
59660	93.1 to 105.8 feet	Driveway				REF			
110	98.6 to 99.6 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
28885	99.8 to 104.9 feet	Cross Slope (Driveway)	>15%	6 ft	28	SF	\$40	\$1,122	
40847	107.7 to 108.7 feet	Running Slope	8.0-9.0%	6 ft	6	SF	\$120	\$660	
28886	109.6 to 142.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	183	SF	\$120	\$21,978	
28894	145.5 to 156.5 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	61	SF	\$120	\$7,260	
59661	153.5 to 171.3 feet	Driveway				REF			
55351	155.3 to 156.3 feet	Vertical Change	.3	6 ft	6	REF			
28898	159.9 to 163.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	19	SF	\$40	\$748	
28900	163.9 to 167.6 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	20	SF	\$40	\$814	
28902	173.2 to 178.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168	
28905	180.5 to 182.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	13	SF	\$120	\$1,518	
28906	182.8 to 198.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	84	SF	\$120	\$10,032	
28912	202.4 to 218.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	86	SF	\$120	\$10,296	
59662	218.0 to 238.8 feet	Driveway				REF			
28917	222.7 to 235.4 feet	Cross Slope (Driveway)	>15%	6 ft	70	SF	\$40	\$2,794	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909231723	VENTURA AVE	CALAVERAS ST	CIRCLE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
28919	235.4 to 238.3 feet	Cross Slope (Driveway)	13.014	6 ft	16	SF	\$40	\$638
28920	244.0 to 249.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	30	SF	\$120	\$3,564
28923	250.8 to 253.1 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	13	SF	\$120	\$1,518
28924	257.1 to 262.2 feet	Cross Slope (PAR)	7.0-8.0%	6 ft	28	SF	\$120	\$3,366
51043	260.9 to 261.9 feet	Vertical Change	-.3	6 ft	6	REF		
28926	262.2 to 267.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	31	SF	\$120	\$3,696
28928	268.0 to 269.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858
28929	271.0 to 275.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,706
28931	275.5 to 281.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	30	SF	\$120	\$3,630
28934	283.3 to 285.0 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	9	SF	\$120	\$1,122
28935	287.3 to 298.6 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	62	SF	\$120	\$7,458
28940	298.8 to 302.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	22	SF	\$120	\$2,640
28941	303.9 to 305.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$924
28942	313.8 to 333.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	107	SF	\$120	\$12,804
28946	333.2 to 384.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	283	SF	\$120	\$33,924
55352	357.9 to 358.9 feet	Vertical Change	.3	6 ft	6	REF		
55353	383.3 to 384.3 feet	Vertical Change	.3	6 ft	6	REF		
28959	384.6 to 393.1 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	47	SF	\$120	\$5,610
59663	391.3 to 412.4 feet	Driveway				REF		
51044	394.3 to 395.3 feet	Vertical Change	-.3	6 ft	6	REF		
28962	397.9 to 406.2 feet	Cross Slope (Driveway)	13.014	6 ft	46	SF	\$40	\$1,826
55354	401.4 to 402.4 feet	Vertical Change	.3	6 ft	6	REF		
55355	410.3 to 411.3 feet	Vertical Change	.3	6 ft	6	REF		
28965	414.1 to 426.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	69	SF	\$120	\$8,316
59664	426.5 to 448.4 feet	Driveway				REF		
28969	432.8 to 449.2 feet	Cross Slope (Driveway)	13.014	6 ft	90	SF	\$40	\$3,608
28974	465.8 to 478.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	67	SF	\$120	\$8,052
28978	521.8 to 529.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	44	SF	\$120	\$5,280

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909231723	VENTURA AVE	CALAVERAS ST	CIRCLE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59665	530.1 to 547.8 feet	Driveway				REF		
28979	534.2 to 546.9 feet	Cross Slope (Driveway)	>15%	6 ft	70	SF	\$40	\$2,794
28981	556.3 to 566.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	57	SF	\$120	\$6,798
51045	565.8 to 566.8 feet	Vertical Change	-.3	6 ft	6	REF		
28984	574.7 to 588.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	75	SF	\$120	\$9,042
28987	592.3 to 594.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650
28988	632.6 to 636.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310
55356	633.2 to 634.2 feet	Vertical Change	.3	6 ft	6	REF		
59666	636.3 to 658.3 feet	Driveway				REF		
28989	641.8 to 658.6 feet	Cross Slope (Driveway)	13.014	6 ft	92	SF	\$40	\$3,696
28993	664.3 to 671.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	41	SF	\$120	\$4,884
28995	672.3 to 681.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	51	SF	\$120	\$6,138
28998	684.0 to 725.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	230	SF	\$120	\$27,588
59667	724.5 to 752.3 feet	Driveway				REF		
29006	729.3 to 752.6 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	128	SF	\$40	\$5,126
29014	755.5 to 756.5 feet	Cross Slope (PAR)	7.0-8.0%	6 ft	6	SF	\$120	\$660
59668	758.3 to 791.8 feet	Driveway				REF		
29015	760.0 to 766.6 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	36	SF	\$40	\$1,452
29017	770.3 to 786.8 feet	Cross Slope (Driveway)	13.014	6 ft	91	SF	\$40	\$3,630
51046	788.8 to 789.8 feet	Vertical Change	-.3	6 ft	6	REF		
29024	791.9 to 797.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	31	SF	\$40	\$1,254
29026	798.7 to 809.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	57	SF	\$120	\$6,864
55357	806.7 to 807.7 feet	Vertical Change	.3	6 ft	6	REF		
29030	811.4 to 854.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	236	SF	\$120	\$28,314
43521	816.6 to 817.6 feet	Vertical Change	-.6	6 ft	6	REF		
56397	826.6 to 827.6 feet	Vertical Change	.4	6 ft	6	REF		
45379	846.7 to 847.7 feet	Vertical Change	-.5	6 ft	6	REF		
59669	851.9 to 876.1 feet	Driveway				REF		
40848	854.9 to 856.0 feet	Running Slope	6.0-7.0%	6 ft	6	REF		

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909231723	VENTURA AVE	CALAVERAS ST	CIRCLE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56398	856.4 to 857.4 feet	Vertical Change	.4	6 ft	6	REF		
29040	858.9 to 871.8 feet	Cross Slope (Driveway)	>15%	6 ft	71	SF	\$40	\$2,838
29041	879.9 to 889.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	54	SF	\$120	\$6,468
59670	894.2 to 917.0 feet	Driveway				REF		
29044	901.3 to 909.8 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	47	SF	\$40	\$1,870
29046	910.3 to 917.0 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	37	SF	\$40	\$1,474
29048	922.5 to 949.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	149	SF	\$120	\$17,820
29055	949.5 to 956.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,686
29057	956.6 to 978.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	120	SF	\$120	\$14,388
51047	979.2 to 980.2 feet	Vertical Change	-.3	6 ft	6	REF		
29063	980.1 to 982.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452
59671	982.0 to 1006.6 feet	Driveway				REF		
29064	986.0 to 998.1 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	67	SF	\$40	\$2,662
29068	1000.2 to 1008.1 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	43	SF	\$40	\$1,738
40849	1008.1 to 1009.8 feet	Running Slope	5.0-6.0%	6 ft	9	REF		
29072	1020.4 to 1050.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	166	SF	\$120	\$19,866
29080	1057.7 to 1059.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
29081	1064.1 to 1068.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
59672	1108.2 to 1119.1 feet	Driveway				REF		
29082	1117.1 to 1120.8 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	20	SF	\$40	\$814
47713	1122.8 to 1123.8 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
29083	1124.8 to 1127.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716
59673	1125.4 to 1142.4 feet	Driveway				REF		
29085	1133.2 to 1142.3 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	50	SF	\$40	\$2,002
40850	1143.3 to 1145.2 feet	Running Slope	5.0-6.0%	6 ft	10	SF	\$120	\$1,254
29087	1147.2 to 1151.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
29088	1157.5 to 1160.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716
29090	1174.3 to 1186.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	67	SF	\$120	\$8,052
29092	1186.5 to 1188.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	11	SF	\$120	\$1,320

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	51909231723	VENTURA AVE	CALAVERAS ST	CIRCLE DR	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
29093	1190.1 to 1191.1 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	6	SF	\$120	\$660	
29094	1191.1 to 1192.5 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	8	SF	\$120	\$924	
29095	1192.9 to 1197.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	24	SF	\$120	\$2,838	
59674	1195.5 to 1215.8 feet	Driveway				REF			
29096	1201.2 to 1203.0 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	10	SF	\$40	\$396	
29097	1203.3 to 1212.1 feet	Cross Slope (Driveway)	13.014	6 ft	48	SF	\$40	\$1,936	
29101	1217.3 to 1240.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	130	SF	\$120	\$15,576	
29107	1242.3 to 1243.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
29108	1245.4 to 1261.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	86	SF	\$120	\$10,362	
29112	1263.3 to 1311.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	265	SF	\$120	\$31,746	
29122	1316.8 to 1319.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	16	SF	\$120	\$1,914	
29123	1322.4 to 1329.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	40	SF	\$120	\$4,818	
29124	1330.2 to 1337.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,554	
59675	1337.2 to 1356.3 feet	Driveway				REF			
29127	1343.3 to 1351.8 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	47	SF	\$40	\$1,870	
29129	1352.1 to 1354.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	15	SF	\$40	\$594	
29131	1359.8 to 1369.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,336	
29132	1373.6 to 1379.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	33	SF	\$120	\$3,960	
29135	1383.0 to 1388.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,828	
29137	1391.0 to 1405.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	80	SF	\$120	\$9,570	
59676	1406.6 to 1424.0 feet	Driveway				REF			
29142	1413.0 to 1421.8 feet	Cross Slope (Driveway)	>15%	6 ft	48	SF	\$40	\$1,936	
55358	1420.6 to 1421.6 feet	Vertical Change	.3	6 ft	6	REF			
29144	1421.8 to 1423.5 feet	Cross Slope (Driveway)	13.014	6 ft	9	SF	\$40	\$374	
29145	1424.4 to 1426.0 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	9	SF	\$40	\$352	
55359	1424.8 to 1425.8 feet	Vertical Change	.3	6 ft	6	REF			
40851	1425.2 to 1427.8 feet	Running Slope	5.0-6.0%	6 ft	14	REF			
29146	1427.7 to 1428.7 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	6	SF	\$120	\$660	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909231723	VENTURA AVE	CALAVERAS ST	CIRCLE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
29147	1429.5 to 1433.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376
29149	1446.6 to 1448.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254
56399	1452.8 to 1453.8 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
29150	1456.3 to 1464.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	44	SF	\$120	\$5,280
59677	1473.8 to 1494.5 feet	Driveway				REF		
29151	1479.3 to 1483.5 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	23	SF	\$40	\$924
29153	1487.2 to 1493.0 feet	Cross Slope (Driveway)	13.014	6 ft	32	SF	\$40	\$1,276
29156	1496.5 to 1497.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726
29157	1500.3 to 1501.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660
29158	1502.6 to 1503.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
29159	1506.8 to 1511.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	25	SF	\$120	\$2,970
29160	1514.3 to 1525.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	60	SF	\$120	\$7,194
29164	1530.1 to 1544.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	78	SF	\$120	\$9,372
29167	1544.3 to 1548.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	22	SF	\$120	\$2,640
59678	1547.3 to 1560.9 feet	Driveway				REF		
29169	1550.6 to 1551.6 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	6	SF	\$40	\$220
29170	1553.0 to 1556.9 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	21	SF	\$40	\$858
55360	1560.9 to 1561.9 feet	Vertical Change	.3	6 ft	6	REF		
29173	1562.3 to 1583.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	116	SF	\$120	\$13,860
51048	1575.9 to 1576.9 feet	Vertical Change	-.3	6 ft	6	REF		
29181	1583.3 to 1590.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,422
29183	1592.7 to 1596.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	20	SF	\$120	\$2,442
56400	1595.9 to 1596.9 feet	Vertical Change	.4	6 ft	6	REF		
29184	1597.3 to 1602.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168
29186	1605.9 to 1608.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650
29187	1610.7 to 1613.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	17	SF	\$120	\$2,046
29188	1616.6 to 1637.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	115	SF	\$120	\$13,794
55361	1635.9 to 1636.9 feet	Vertical Change	.3	6 ft	6	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909231723	VENTURA AVE	CALAVERAS ST	CIRCLE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
29196	1641.2 to 1652.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	64	SF	\$120	\$7,656
29200	1655.2 to 1663.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,742
59679	1666.9 to 1682.5 feet	Driveway				REF		
29203	1672.8 to 1678.8 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	33	SF	\$40	\$1,320
29205	1680.3 to 1683.8 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	19	SF	\$40	\$770
29206	1685.6 to 1686.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
29207	1689.4 to 1693.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
29209	1693.6 to 1709.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	90	SF	\$120	\$10,758
57067	1705.6 to 1706.6 feet	Vertical Change	.6	6 ft	6	REF		
29211	1712.4 to 1725.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	69	SF	\$120	\$8,316
51049	1715.9 to 1716.9 feet	Vertical Change	-.3	6 ft	6	REF		
29216	1725.5 to 1727.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
55362	1726.0 to 1727.0 feet	Vertical Change	.3	6 ft	6	REF		
59680	1727.8 to 1747.6 feet	Driveway				REF		
51050	1729.1 to 1730.1 feet	Vertical Change	-.3	6 ft	6	REF		
29217	1733.0 to 1734.8 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	10	SF	\$40	\$396
29218	1734.8 to 1736.3 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	8	SF	\$40	\$330
29219	1738.8 to 1747.6 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	48	SF	\$40	\$1,936
51051	1750.8 to 1751.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
29222	1752.9 to 1759.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,422
55363	1756.0 to 1757.0 feet	Vertical Change	.3	6 ft	6	REF		
29223	1775.7 to 1783.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,148
29225	1784.2 to 1788.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	24	SF	\$120	\$2,838
29227	1789.4 to 1806.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	95	SF	\$120	\$11,418
29230	1807.0 to 1814.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	40	SF	\$120	\$4,818
29233	1814.3 to 1819.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168
111	1815.3 to 1816.3 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
29234	1824.0 to 1831.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,752

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909231723	VENTURA AVE	CALAVERAS ST	CIRCLE DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
29236	1831.5 to 1836.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	26	SF	\$120	\$3,168
29238	1836.4 to 1848.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	65	SF	\$120	\$7,788
40852	1847.1 to 1848.6 feet	Running Slope	5.0-6.0%	6 ft	8	REF		
TOTAL COST FOR: NW side of VENTURA AVE Starting at: CALAVERAS ST							\$704,247.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	51909231727	VENTURA AVE	CIRCLE DR	HOSPITAL DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
29243	1.5 to 9.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	43	SF	\$120	\$5,148	
29245	11.8 to 26.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	81	SF	\$120	\$9,702	
57068	12.4 to 13.4 feet	Vertical Change	.6	6 ft	6	REF			
29247	26.5 to 55.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	161	SF	\$120	\$19,338	
29254	61.3 to 70.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$5,940	
29257	72.5 to 74.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,122	
29258	75.6 to 76.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
29259	79.8 to 89.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	56	SF	\$120	\$6,666	
59681	95.3 to 125.6 feet	Driveway				REF			
29261	101.8 to 109.4 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	42	SF	\$40	\$1,672	
29263	110.3 to 124.8 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	80	SF	\$40	\$3,190	
29269	124.8 to 127.4 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	14	SF	\$40	\$572	
55364	132.2 to 133.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
29270	133.4 to 153.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	112	SF	\$120	\$13,398	
29274	156.0 to 188.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	177	SF	\$120	\$21,252	
59682	187.8 to 211.3 feet	Driveway				REF			
55365	189.8 to 190.8 feet	Vertical Change	.3	6 ft	6	REF			
29281	193.6 to 208.5 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	82	SF	\$40	\$3,278	
29286	208.7 to 212.5 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	21	SF	\$40	\$836	
29288	224.8 to 250.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	143	SF	\$120	\$17,160	
29293	254.8 to 258.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310	
29294	262.2 to 271.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,138	
29296	274.8 to 278.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	20	SF	\$120	\$2,442	
29297	280.1 to 354.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	409	SF	\$120	\$49,038	
51052	289.9 to 290.9 feet	Vertical Change	-.3	6 ft	6	REF			
42346	308.8 to 309.8 feet	Vertical Change	-.7	6 ft	6	REF			
51053	331.5 to 332.5 feet	Vertical Change	-.3	6 ft	6	REF			
51054	352.4 to 353.4 feet	Vertical Change	-.3	6 ft	6	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909231727	VENTURA AVE	CIRCLE DR	HOSPITAL DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
29315	357.1 to 375.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	99	SF	\$120	\$11,880
43522	365.0 to 366.0 feet	Vertical Change	-.6	6 ft	6	SF	\$75	\$413
29320	379.3 to 380.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
57069	394.9 to 395.9 feet	Vertical Change	.6	6 ft	6	REF		
29321	395.1 to 396.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	9	SF	\$120	\$1,122
29322	399.8 to 412.3 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	69	SF	\$120	\$8,250
41291	415.1 to 416.1 feet	Vertical Change	-1.6	6 ft	6	SF	\$75	\$413
29326	425.8 to 427.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
29327	431.9 to 434.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	13	SF	\$120	\$1,584
59683	434.9 to 459.6 feet	Driveway				REF		
29328	435.8 to 436.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$242
29329	442.0 to 459.4 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	96	SF	\$40	\$3,828
55366	449.9 to 450.9 feet	Vertical Change	.3	6 ft	6	REF		
29336	460.4 to 461.4 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	6	SF	\$40	\$220
29337	465.3 to 471.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,762
29338	499.5 to 500.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
29339	502.7 to 507.6 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	27	SF	\$120	\$3,234
29341	533.8 to 543.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,072
29343	557.2 to 574.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	94	SF	\$120	\$11,220
29348	577.4 to 579.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,584
29349	589.3 to 618.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	161	SF	\$120	\$19,338
55367	600.8 to 601.8 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: NW side of VENTURA AVE Starting at: CIRCLE DR							\$245,745.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	51909231730	VENTURA AVE	HOSPITAL DR	HOWELL RD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
29357	0.0 to 8.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346	
29359	18.4 to 19.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
47714	22.3 to 23.3 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413	
29360	26.4 to 63.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	203	SF	\$120	\$24,354	
51055	40.6 to 41.6 feet	Vertical Change	-.3	6 ft	6	REF			
59684	61.8 to 112.6 feet	Driveway				REF			
29368	67.3 to 69.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	14	SF	\$40	\$550	
29370	70.2 to 84.5 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	79	SF	\$40	\$3,146	
29374	87.7 to 112.6 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	137	SF	\$40	\$5,478	
29382	112.6 to 114.1 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	8	SF	\$40	\$330	
29383	123.7 to 127.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640	
29384	142.5 to 146.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838	
29385	182.3 to 184.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122	
29386	187.8 to 202.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	81	SF	\$120	\$9,702	
29391	205.3 to 207.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	12	SF	\$120	\$1,452	
29392	207.9 to 224.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	93	SF	\$120	\$11,154	
29395	228.0 to 236.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	49	SF	\$120	\$5,874	
29396	243.3 to 272.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	161	SF	\$120	\$19,272	
29399	273.2 to 283.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	57	SF	\$120	\$6,798	
29404	283.5 to 286.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178	
59685	294.2 to 330.4 feet	Driveway				REF			
29405	302.2 to 309.8 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	42	SF	\$40	\$1,672	
29408	312.0 to 321.9 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	54	SF	\$40	\$2,178	
29411	321.9 to 330.8 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	49	SF	\$40	\$1,958	
56799	335.0 to 336.0 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413	
29414	342.0 to 352.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	55	SF	\$120	\$6,600	
55368	355.3 to 356.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
29415	367.5 to 393.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	141	SF	\$120	\$16,962	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909231730	VENTURA AVE	HOSPITAL DR	HOWELL RD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
29422	397.8 to 404.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,290
55369	428.2 to 429.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
29423	433.7 to 436.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112
29424	450.3 to 459.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	49	SF	\$120	\$5,874
29425	464.8 to 499.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	190	SF	\$120	\$22,770
51056	465.2 to 466.2 feet	Vertical Change	-.3	6 ft	6	REF		
51057	483.4 to 484.4 feet	Vertical Change	-.3	6 ft	6	REF		
TOTAL COST FOR: NW side of VENTURA AVE Starting at: HOSPITAL DR							\$168,960.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	51909231737	VENTURA AVE	HOWELL RD	GILL WAY	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
29428	0.0 to 18.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	100	SF	\$120	\$12,012	
29432	18.4 to 36.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	100	SF	\$120	\$12,012	
29438	38.8 to 42.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	21	SF	\$120	\$2,508	
29440	45.9 to 52.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,158	
29441	56.2 to 58.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518	
29442	61.5 to 65.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	21	SF	\$120	\$2,508	
51058	61.8 to 62.8 feet	Vertical Change	-.3	6 ft	6	REF			
29443	65.7 to 75.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,336	
29445	79.5 to 95.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	87	SF	\$120	\$10,428	
59686	91.8 to 114.0 feet	Driveway				REF			
29451	99.3 to 113.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	77	SF	\$40	\$3,080	
57201	104.4 to 105.4 feet	Vertical Change	.7	6 ft	6	REF			
29453	116.8 to 122.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630	
29456	125.8 to 154.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	155	SF	\$120	\$18,612	
59687	152.3 to 173.2 feet	Driveway				REF			
51059	153.3 to 154.3 feet	Vertical Change	-.3	6 ft	6	REF			
29463	157.9 to 172.1 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	78	SF	\$40	\$3,124	
29469	177.0 to 181.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	24	SF	\$120	\$2,904	
29470	181.6 to 186.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036	
59688	183.8 to 205.5 feet	Driveway				REF			
55370	185.2 to 186.2 feet	Vertical Change	.3	6 ft	6	REF			
29471	189.8 to 205.3 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	85	SF	\$40	\$3,410	
56401	196.5 to 197.5 feet	Vertical Change	.4	6 ft	6	REF			
51060	204.8 to 205.8 feet	Vertical Change	-.3	6 ft	6	REF			
56800	207.4 to 208.4 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413	
29476	208.8 to 210.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$990	
29477	211.7 to 235.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	130	SF	\$120	\$15,642	
51061	221.1 to 222.1 feet	Vertical Change	-.3	6 ft	6	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909231737	VENTURA AVE	HOWELL RD	GILL WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51062	232.2 to 233.2 feet	Vertical Change	-.3	6 ft	6	REF		
29480	242.2 to 250.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,478
29482	252.8 to 264.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	65	SF	\$120	\$7,854
29487	270.5 to 274.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310
59689	272.9 to 297.3 feet	Driveway				REF		
29489	278.2 to 279.9 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	9	SF	\$40	\$374
29490	282.3 to 294.0 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	64	SF	\$40	\$2,574
29494	297.3 to 301.3 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	22	SF	\$40	\$880
29495	301.3 to 308.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,620
112	303.7 to 304.7 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
29498	315.4 to 321.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	33	SF	\$120	\$3,960
29500	324.2 to 334.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	57	SF	\$120	\$6,798
59690	332.4 to 352.9 feet	Driveway				REF		
29503	337.7 to 343.2 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	30	SF	\$40	\$1,210
29505	344.3 to 348.4 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	23	SF	\$40	\$902
29507	349.0 to 351.7 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	15	SF	\$40	\$594
40853	353.4 to 355.0 feet	Running Slope	5.0-6.0%	6 ft	9	REF		
29509	359.3 to 362.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914
59691	364.3 to 385.5 feet	Driveway				REF		
29510	365.6 to 366.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$220
29511	367.5 to 368.5 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	6	SF	\$40	\$220
29512	370.0 to 375.0 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	28	SF	\$40	\$1,100
29514	375.0 to 386.4 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	63	SF	\$40	\$2,508
29517	389.9 to 410.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	113	SF	\$120	\$13,596
29522	410.5 to 415.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	28	SF	\$120	\$3,366
29524	417.1 to 420.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$1,980
29525	422.6 to 455.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	179	SF	\$120	\$21,516
59692	451.1 to 474.8 feet	Driveway				REF		
42347	453.4 to 454.4 feet	Vertical Change	-.7	6 ft	6	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	51909231737	VENTURA AVE	HOWELL RD	GILL WAY					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
29533	458.0 to 473.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	84	SF	\$40	\$3,366	
29535	474.1 to 475.3 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	7	SF	\$40	\$264	
40854	475.3 to 476.3 feet	Running Slope	5.0-6.0%	6 ft	6	REF			
29536	475.4 to 476.5 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	6	SF	\$40	\$242	
29537	477.8 to 482.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036	
47715	479.2 to 480.2 feet	Vertical Change	-.4	6 ft	6	REF			
29539	484.6 to 487.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782	
59693	485.4 to 504.8 feet	Driveway				REF			
29541	490.7 to 506.0 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	84	SF	\$40	\$3,366	
29544	522.6 to 529.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,686	
29545	539.8 to 543.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574	
59694	545.6 to 566.3 feet	Driveway				REF			
57202	546.3 to 547.3 feet	Vertical Change	.7	6 ft	6	REF			
29546	549.8 to 566.6 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	92	SF	\$40	\$3,696	
29551	570.2 to 571.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$792	
29552	571.4 to 577.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894	
29554	580.4 to 595.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	85	SF	\$120	\$10,164	
113	589.3 to 590.3 feet	Continuous Width		6 ft	6	SF	\$120	\$660	
29558	599.8 to 607.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,016	
59695	600.2 to 627.2 feet	Driveway				REF			
55371	606.2 to 607.2 feet	Vertical Change	.3	6 ft	6	REF			
29560	610.8 to 625.6 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	81	SF	\$40	\$3,256	
40855	626.2 to 627.4 feet	Running Slope	5.0-6.0%	6 ft	7	REF			
51063	628.0 to 629.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
29564	629.2 to 632.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848	
29565	634.3 to 635.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$792	
29566	636.0 to 667.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	173	SF	\$120	\$20,790	
29573	672.1 to 712.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	221	SF	\$120	\$26,532	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909231737	VENTURA AVE	HOWELL RD	GILL WAY	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51064	702.0 to 703.0 feet	Vertical Change	-.3	6 ft	6	REF		
29581	712.3 to 721.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	48	SF	\$120	\$5,742
TOTAL COST FOR: NW side of VENTURA AVE Starting at: HOWELL RD							\$293,304.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909231745	VENTURA AVE	15TH ST	14TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
29583	0.2 to 3.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046
59696	69.8 to 84.2 feet	Driveway				REF		
29584	75.8 to 83.1 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	40	SF	\$40	\$1,606
59697	92.2 to 104.1 feet	Driveway				REF		
29587	98.5 to 103.5 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	28	SF	\$40	\$1,100
29590	111.7 to 124.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	68	SF	\$120	\$8,118
114	121.9 to 122.9 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
29594	124.0 to 138.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	82	SF	\$120	\$9,834
51065	142.8 to 143.8 feet	Vertical Change	-3	6 ft	6	LF	\$75	\$413
29596	145.8 to 153.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	44	SF	\$120	\$5,280
29598	154.8 to 160.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,696
59698	160.2 to 182.0 feet	Driveway				REF		
47716	161.1 to 162.1 feet	Vertical Change	-4	6 ft	6	REF		
29599	164.3 to 174.6 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	57	SF	\$40	\$2,266
51066	172.9 to 173.9 feet	Vertical Change	-3	6 ft	6	REF		
29602	176.0 to 181.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	29	SF	\$40	\$1,166
29604	189.7 to 203.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	78	SF	\$120	\$9,306
59699	212.2 to 231.0 feet	Driveway				REF		
51067	212.8 to 213.8 feet	Vertical Change	-3	6 ft	6	REF		
29607	217.0 to 220.4 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	19	SF	\$40	\$748
29609	220.7 to 233.4 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	70	SF	\$40	\$2,794
29612	235.8 to 236.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660
29613	245.5 to 250.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,300
29615	266.3 to 272.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,356
TOTAL COST FOR: SE side of VENTURA AVE Starting at: 15TH ST							\$56,787.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909231748	VENTURA AVE	14TH ST	13TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
29616	0.0 to 1.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,188
29617	1.8 to 6.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168
29618	9.1 to 11.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	13	SF	\$120	\$1,584
29619	14.8 to 18.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	22	SF	\$120	\$2,640
29621	21.7 to 28.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,686
29622	40.2 to 49.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,336
56801	54.1 to 55.1 feet	Vertical Change	.5	6 ft	6	REF		
29624	54.5 to 56.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
29625	67.9 to 71.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244
59700	71.0 to 85.0 feet	Driveway				REF		
45380	71.9 to 72.9 feet	Vertical Change	-.5	6 ft	6	REF		
29626	76.1 to 79.4 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	18	SF	\$40	\$726
29627	82.3 to 85.3 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	17	SF	\$40	\$660
59701	112.5 to 127.6 feet	Driveway				REF		
29629	117.7 to 127.8 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	56	SF	\$40	\$2,222
40856	127.8 to 129.0 feet	Running Slope	5.0-6.0%	6 ft	7	REF		
29633	131.2 to 140.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$5,940
59702	141.1 to 161.3 feet	Driveway				REF		
29636	149.7 to 162.3 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	69	SF	\$40	\$2,772
56802	153.6 to 154.6 feet	Vertical Change	.5	6 ft	6	REF		
29640	162.3 to 163.7 feet	Cross Slope (PAR)	9.0-10.0%	6 ft	8	SF	\$120	\$924
56803	164.8 to 165.8 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
29641	168.9 to 181.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	72	SF	\$120	\$8,580
55372	178.8 to 179.8 feet	Vertical Change	.3	6 ft	6	REF		
29644	188.6 to 192.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
55373	193.8 to 194.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
59703	210.4 to 228.5 feet	Driveway				REF		
29645	215.7 to 228.8 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	72	SF	\$40	\$2,882
47717	243.4 to 244.4 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909231748	VENTURA AVE	14TH ST	13TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
29651	247.3 to 252.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
47718	258.0 to 259.0 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
29652	260.6 to 262.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
29653	264.9 to 272.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	42	SF	\$120	\$5,016
29655	272.5 to 275.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178
TOTAL COST FOR: SE side of VENTURA AVE Starting at: 14TH ST							\$63,844.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909231750	VENTURA AVE	13TH ST	12TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40857	0.0 to 1.0 feet	Running Slope	7.0-8.0%	6 ft	6	SF	\$120	\$660
40858	1.5 to 2.6 feet	Running Slope	5.0-6.0%	6 ft	6	SF	\$120	\$726
29656	2.8 to 11.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,478
56402	12.6 to 13.6 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
29659	16.1 to 18.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	15	SF	\$120	\$1,848
29660	19.2 to 25.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,092
29662	50.0 to 54.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
29664	58.4 to 62.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376
51068	62.6 to 63.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
29665	95.5 to 115.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	109	SF	\$120	\$13,068
56403	103.6 to 104.6 feet	Vertical Change	.4	6 ft	6	REF		
55374	108.3 to 109.3 feet	Vertical Change	.3	6 ft	6	REF		
29670	117.5 to 127.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	54	SF	\$120	\$6,468
59704	126.0 to 140.6 feet	Driveway				REF		
55375	127.8 to 130.5 feet	Vertical Change	.3	6 ft	15	REF		
29674	132.3 to 137.4 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	28	SF	\$40	\$1,122
57361	135.2 to 136.2 feet	Vertical Change	1	6 ft	6	REF		
29677	137.4 to 138.4 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	6	SF	\$40	\$220
29678	143.1 to 152.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,138
29682	157.1 to 164.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	41	SF	\$120	\$4,950
29683	166.7 to 167.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726
29684	168.2 to 177.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$6,006
59705	176.7 to 190.1 feet	Driveway				REF		
29686	181.9 to 186.3 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	24	SF	\$40	\$968
40859	191.4 to 192.4 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
29687	192.1 to 198.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,158
29689	201.9 to 220.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	103	SF	\$120	\$12,408
29692	220.7 to 224.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909231750	VENTURA AVE	13TH ST	12TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59706	224.4 to 234.7 feet	Driveway				REF		
29695	231.9 to 235.6 feet	Cross Slope (Driveway)	13.014	6 ft	20	SF	\$40	\$814
56404	236.2 to 237.2 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
40860	236.5 to 238.3 feet	Running Slope	6.0-7.0%	6 ft	10	SF	\$120	\$1,188
29697	239.9 to 243.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178
29699	247.4 to 255.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,214
29701	258.6 to 265.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,818
29704	269.8 to 281.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	63	SF	\$120	\$7,524
TOTAL COST FOR: SE side of VENTURA AVE Starting at: 13TH ST							\$99,995.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	51909231753	VENTURA AVE	11TH ST	11TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
29706	0.2 to 4.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	24	SF	\$120	\$2,904	
29707	7.6 to 13.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	34	SF	\$120	\$4,092	
29709	14.6 to 25.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	62	SF	\$120	\$7,392	
59707	23.8 to 37.5 feet	Driveway				REF			
29712	29.4 to 38.2 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	48	SF	\$40	\$1,936	
29716	46.8 to 53.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,554	
51069	51.2 to 52.2 feet	Vertical Change	-3	6 ft	6	REF			
59708	65.4 to 80.1 feet	Driveway				REF			
29717	73.1 to 77.9 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	26	SF	\$40	\$1,056	
29719	78.3 to 80.4 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	12	SF	\$40	\$462	
29721	82.7 to 83.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	6	SF	\$120	\$726	
29722	84.3 to 85.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
115	86.9 to 87.9 feet	Continuous Width		6 ft	6	SF	\$120	\$660	
29723	89.4 to 94.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,300	
29725	98.7 to 102.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376	
29726	106.9 to 112.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,432	
59709	116.3 to 133.9 feet	Driveway				REF			
29727	122.3 to 135.4 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	72	SF	\$40	\$2,882	
116	139.8 to 140.8 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
29731	139.9 to 152.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	68	SF	\$120	\$8,184	
29733	155.0 to 156.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,188	
29734	156.8 to 158.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320	
29735	162.5 to 165.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046	
29736	168.1 to 173.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,432	
59710	172.1 to 185.8 feet	Driveway				REF			
29738	178.3 to 185.6 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	40	SF	\$40	\$1,606	
29740	193.8 to 196.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716	
29741	202.7 to 217.9 feet	Cross Slope (PAR)	9.0-10.0%	6 ft	84	SF	\$120	\$10,032	
59711	209.8 to 216.1 feet	Driveway				REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909231753	VENTURA AVE	11TH ST	11TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56805	220.2 to 221.2 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
29745	224.3 to 242.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	102	SF	\$120	\$12,210
55376	240.1 to 241.1 feet	Vertical Change	.3	6 ft	6	REF		
57553	245.8 to 246.8 feet	Vertical Change	2.3	6 ft	6	REF		
29750	246.5 to 276.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	162	SF	\$120	\$19,470
TOTAL COST FOR: SE side of VENTURA AVE Starting at: 11TH ST							\$98,279.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	51909231755	VENTURA AVE	11TH ST	10TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
29760	1.0 to 43.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	235	SF	\$120	\$28,248	
59712	43.8 to 57.6 feet	Driveway				REF			
29770	44.1 to 45.7 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	9	SF	\$40	\$352	
29771	50.0 to 51.6 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	9	SF	\$40	\$352	
29772	53.7 to 58.3 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	25	SF	\$40	\$1,012	
29774	63.3 to 73.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,402	
55377	73.9 to 74.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
29776	75.7 to 77.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$924	
29777	78.8 to 88.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	55	SF	\$120	\$6,600	
59713	89.0 to 102.8 feet	Driveway				REF			
29779	94.2 to 102.3 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	45	SF	\$40	\$1,782	
29783	102.3 to 103.3 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	6	SF	\$40	\$220	
40861	103.6 to 105.1 feet	Running Slope	6.0-7.0%	6 ft	8	SF	\$120	\$990	
29784	107.9 to 143.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	197	SF	\$120	\$23,628	
56405	124.5 to 125.5 feet	Vertical Change	.4	6 ft	6	REF			
59714	143.7 to 155.5 feet	Driveway				REF			
29791	148.3 to 157.0 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	48	SF	\$40	\$1,914	
40862	155.7 to 156.8 feet	Running Slope	5.0-6.0%	6 ft	6	REF			
29795	161.7 to 162.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
29796	166.3 to 213.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	261	SF	\$120	\$31,350	
59715	212.0 to 238.0 feet	Driveway				REF			
29808	215.0 to 216.3 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	7	SF	\$40	\$286	
29809	217.8 to 235.0 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	95	SF	\$40	\$3,784	
55378	230.3 to 231.3 feet	Vertical Change	.3	6 ft	6	REF			
29815	237.1 to 238.4 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	7	SF	\$40	\$286	
56806	241.8 to 242.8 feet	Vertical Change	.5	6 ft	6	REF			
29816	241.9 to 251.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$6,006	
29819	254.2 to 257.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	20	SF	\$120	\$2,376	
29820	260.4 to 285.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	140	SF	\$120	\$16,764	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909231755	VENTURA AVE	11TH ST	10TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55379	285.5 to 286.5 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: SE side of VENTURA AVE Starting at: 11TH ST							\$134,348.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	51909231757	VENTURA AVE	10TH ST	9TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
29828	0.7 to 7.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	37	SF	\$120	\$4,422	
29830	7.4 to 11.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640	
29832	11.6 to 17.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	30	SF	\$120	\$3,564	
29834	18.3 to 24.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,290	
29835	27.3 to 35.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	43	SF	\$120	\$5,148	
29837	35.9 to 37.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
29838	39.7 to 41.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$924	
29839	41.8 to 52.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	61	SF	\$120	\$7,260	
29841	56.5 to 76.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	111	SF	\$120	\$13,332	
29847	76.7 to 81.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,300	
59716	83.4 to 106.8 feet	Driveway				REF			
29848	89.2 to 102.9 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	75	SF	\$40	\$3,014	
29854	102.9 to 106.2 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	18	SF	\$40	\$726	
29855	110.3 to 119.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,072	
29857	133.0 to 148.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	85	SF	\$120	\$10,164	
59717	150.3 to 170.0 feet	Driveway				REF			
29858	150.5 to 151.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	7	SF	\$40	\$286	
29859	155.8 to 170.3 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	80	SF	\$40	\$3,190	
42348	173.1 to 174.1 feet	Vertical Change	-.7	6 ft	6	SF	\$75	\$413	
29865	175.6 to 178.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112	
29866	181.0 to 192.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	62	SF	\$120	\$7,392	
29867	194.8 to 198.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178	
29868	198.5 to 214.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	88	SF	\$120	\$10,560	
56807	213.3 to 214.3 feet	Vertical Change	.5	6 ft	6	REF			
29871	214.5 to 232.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	100	SF	\$120	\$12,012	
117	221.3 to 222.3 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
59718	229.2 to 249.5 feet	Driveway				REF			
29873	238.3 to 249.8 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	63	SF	\$40	\$2,530	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909231757	VENTURA AVE	10TH ST	9TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55380	252.2 to 253.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
29879	261.0 to 264.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112
29881	271.7 to 275.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
55381	272.5 to 273.5 feet	Vertical Change	.3	6 ft	6	REF		
29882	280.3 to 291.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	63	SF	\$120	\$7,590
TOTAL COST FOR: SE side of VENTURA AVE Starting at: 10TH ST							\$119,108.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909231759	VENTURA AVE	9TH ST	8TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
29883	0.0 to 5.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	28	SF	\$120	\$3,300
29884	7.3 to 9.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650
29885	20.5 to 23.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244
29886	27.1 to 32.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	27	SF	\$120	\$3,234
29887	39.6 to 44.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,366
29889	47.1 to 59.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	70	SF	\$120	\$8,448
29890	59.9 to 66.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,620
29893	69.2 to 89.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	111	SF	\$120	\$13,332
45381	77.5 to 78.5 feet	Vertical Change	-5	6 ft	6	REF		
29898	90.0 to 101.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	64	SF	\$120	\$7,722
29902	104.3 to 105.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726
29903	107.4 to 117.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	57	SF	\$120	\$6,864
59719	117.3 to 134.7 feet	Driveway				REF		
51070	119.3 to 120.3 feet	Vertical Change	-.3	6 ft	6	REF		
29907	123.7 to 127.9 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	23	SF	\$40	\$924
29909	128.3 to 134.9 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	36	SF	\$40	\$1,452
40863	138.7 to 139.8 feet	Running Slope	6.0-7.0%	6 ft	6	SF	\$120	\$726
29912	142.1 to 157.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	86	SF	\$120	\$10,362
29917	162.0 to 170.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,478
29919	174.0 to 178.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168
29921	182.2 to 206.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	131	SF	\$120	\$15,708
29927	206.0 to 216.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	60	SF	\$120	\$7,194
29929	216.9 to 223.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224
29930	225.7 to 237.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	66	SF	\$120	\$7,920
29934	238.9 to 243.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,970
29935	249.7 to 278.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	158	SF	\$120	\$19,008
47719	266.5 to 267.5 feet	Vertical Change	-.4	6 ft	6	REF		

TOTAL COST FOR: SE	side of VENTURA AVE Starting at: 9TH ST	\$134,640.00
---------------------------	--	---------------------

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909231801	VENTURA AVE	8TH ST	7TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
29943	1.3 to 3.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
118	3.3 to 4.3 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
40864	4.2 to 6.2 feet	Running Slope	6.0-7.0%	6 ft	11	REF		
29944	5.1 to 6.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	9	SF	\$120	\$1,056
29945	14.1 to 18.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	23	SF	\$120	\$2,706
29947	19.9 to 30.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	59	SF	\$120	\$7,128
29949	32.8 to 39.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	34	SF	\$120	\$4,092
119	37.6 to 38.6 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
29950	39.4 to 58.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	106	SF	\$120	\$12,672
29955	61.8 to 65.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	22	SF	\$120	\$2,640
29956	65.8 to 78.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	72	SF	\$120	\$8,580
29963	81.1 to 92.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	64	SF	\$120	\$7,722
29966	100.8 to 102.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
29967	107.2 to 110.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046
29968	112.6 to 126.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	76	SF	\$120	\$9,174
29973	130.8 to 140.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	53	SF	\$120	\$6,402
29977	141.8 to 147.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,026
29980	148.3 to 163.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	85	SF	\$120	\$10,164
59720	160.8 to 180.1 feet	Driveway				REF		
29984	167.1 to 180.4 feet	Cross Slope (Driveway)	>15%	6 ft	73	SF	\$40	\$2,926
40865	180.2 to 181.6 feet	Running Slope	5.0-6.0%	6 ft	8	REF		
40866	181.6 to 182.7 feet	Running Slope	6.0-7.0%	6 ft	6	SF	\$120	\$726
29985	185.8 to 201.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	85	SF	\$120	\$10,164
29987	204.2 to 218.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	79	SF	\$120	\$9,438
59721	224.2 to 241.8 feet	Driveway				REF		
56406	227.2 to 228.2 feet	Vertical Change	.4	6 ft	6	REF		
29988	230.9 to 239.1 feet	Cross Slope (Driveway)	13.014	6 ft	45	SF	\$40	\$1,804
29990	239.1 to 242.3 feet	Cross Slope (Driveway)	>15%	6 ft	18	SF	\$40	\$704

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909231801	VENTURA AVE	8TH ST	7TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40867	243.5 to 244.8 feet	Running Slope	5.0-6.0%	6 ft	7	SF	\$120	\$858
29991	247.3 to 251.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
29993	252.6 to 256.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	21	SF	\$120	\$2,508
29994	257.2 to 263.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,026
29996	266.3 to 269.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$1,980
29998	271.8 to 273.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
29999	275.7 to 281.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	31	SF	\$120	\$3,762
30000	281.4 to 284.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244
40868	282.7 to 283.7 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
40869	283.7 to 285.1 feet	Running Slope	6.0-7.0%	6 ft	8	REF		
TOTAL COST FOR: SE side of VENTURA AVE Starting at: 8TH ST							\$125,554.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	51909231803	VENTURA AVE	7TH ST	6TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
30001	0.0 to 7.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	42	SF	\$120	\$5,082	
40870	0.0 to 1.3 feet	Running Slope	5.0-6.0%	6 ft	7	REF			
51071	2.6 to 3.6 feet	Vertical Change	-.3	6 ft	6	REF			
30003	7.8 to 10.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848	
30004	13.4 to 20.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,686	
30006	37.2 to 57.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	111	SF	\$120	\$13,266	
51072	42.5 to 43.5 feet	Vertical Change	-.3	6 ft	6	REF			
30012	68.1 to 75.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,752	
30015	75.5 to 84.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	48	SF	\$120	\$5,808	
51073	82.5 to 83.5 feet	Vertical Change	-.3	6 ft	6	REF			
30017	84.3 to 97.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	72	SF	\$120	\$8,580	
30022	101.2 to 108.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	39	SF	\$120	\$4,686	
30027	111.8 to 115.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	18	SF	\$120	\$2,112	
30028	115.3 to 123.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,610	
30030	140.7 to 141.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
30031	144.3 to 145.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858	
30032	150.8 to 170.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	109	SF	\$120	\$13,134	
30037	171.5 to 175.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	22	SF	\$120	\$2,640	
30039	175.5 to 178.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178	
30040	186.4 to 197.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	58	SF	\$120	\$6,996	
30043	199.6 to 209.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	52	SF	\$120	\$6,204	
30045	212.7 to 233.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	113	SF	\$120	\$13,596	
120	224.8 to 225.8 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
30050	235.4 to 259.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	130	SF	\$120	\$15,576	
30057	262.0 to 266.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,970	
30059	268.2 to 275.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	42	SF	\$120	\$5,082	
51074	278.3 to 279.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
30062	279.4 to 287.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	43	SF	\$120	\$5,148	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909231803	VENTURA AVE	7TH ST	6TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
TOTAL COST FOR: SE							<i>side of</i>	\$131,983.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909241013	1ST ST	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30064	0.0 to 2.8 feet	Cross Slope (PAR)	5.0-6.0%	10 ft	28	SF	\$120	\$3,360
30067	9.7 to 11.2 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	15	SF	\$120	\$1,800
30068	15.0 to 34.2 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	192	SF	\$120	\$23,040
41565	15.3 to 16.3 feet	Vertical Change	-1	10 ft	10	REF		
47720	30.7 to 31.7 feet	Vertical Change	-.4	10 ft	10	REF		
59723	33.4 to 88.3 feet	Driveway				REF		
30074	37.1 to 49.3 feet	Cross Slope (Driveway)	7.0-8.0%	10 ft	122	SF	\$40	\$4,880
30077	51.5 to 70.8 feet	Cross Slope (Driveway)	7.0-8.0%	10 ft	193	SF	\$40	\$7,720
57070	65.4 to 66.4 feet	Vertical Change	.6	10 ft	10	REF		
30083	74.5 to 83.4 feet	Cross Slope (Driveway)	7.0-8.0%	10 ft	89	SF	\$40	\$3,560
30086	83.6 to 85.8 feet	Cross Slope (Driveway)	5.0-6.0%	10 ft	22	SF	\$40	\$880
30087	86.8 to 88.6 feet	Cross Slope (Driveway)	6.0-7.0%	10 ft	18	SF	\$40	\$720
30088	89.3 to 90.8 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	15	SF	\$120	\$1,800
30089	91.3 to 116.2 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	249	SF	\$120	\$29,880
41877	91.8 to 92.8 feet	Vertical Change	-.8	10 ft	10	REF		
55382	102.9 to 103.9 feet	Vertical Change	.3	10 ft	10	REF		
45382	113.8 to 114.8 feet	Vertical Change	-.5	10 ft	10	REF		
59724	114.3 to 132.5 feet	Driveway				REF		
30094	118.1 to 119.3 feet	Cross Slope (Driveway)	5.0-6.0%	10 ft	12	SF	\$40	\$480
30095	119.9 to 131.2 feet	Cross Slope (Driveway)	7.0-8.0%	10 ft	113	SF	\$40	\$4,520

TOTAL COST FOR: NE	<i>side of 1ST ST Starting at: SIDEWALK BEGINS</i>	\$82,640.00
---------------------------	--	--------------------

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909241014	1ST ST	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30099	11.1 to 12.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	12	SF	\$120	\$1,440
TOTAL COST FOR: NE side of 1ST ST Starting at: SIDEWALK BEGINS							\$1,440.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241023	SONOMA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59725	4.0 to 25.8 feet	Driveway				REF		
30102	9.5 to 15.5 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	33	SF	\$40	\$1,320
30105	18.0 to 20.8 feet	Cross Slope (Driveway)	13.014	6 ft	15	SF	\$40	\$616
55383	23.9 to 24.9 feet	Vertical Change	.3	6 ft	6	REF		
30106	28.1 to 39.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	64	SF	\$120	\$7,722
55384	38.1 to 39.1 feet	Vertical Change	.3	6 ft	6	REF		
30109	42.1 to 45.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	18	SF	\$120	\$2,178
30110	46.4 to 55.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$5,940
51076	53.3 to 54.3 feet	Vertical Change	-.3	6 ft	6	REF		
TOTAL COST FOR: NW side of SONOMA AVE Starting at: SIDEWALK BEGINS							\$17,776.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241024	SONOMA AVE	3RD ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55385	13.1 to 14.1 feet	Vertical Change	.3	6 ft	6	REF		
30115	18.5 to 19.6 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	6	SF	\$40	\$242
30116	20.2 to 39.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	103	SF	\$40	\$4,136
51077	37.1 to 38.1 feet	Vertical Change	-.3	6 ft	6	REF		
30123	41.3 to 49.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	42	SF	\$120	\$5,082
30126	49.7 to 51.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386
59726	50.9 to 71.5 feet	Driveway				REF		
30127	58.9 to 70.8 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	65	SF	\$40	\$2,618
51078	73.7 to 74.7 feet	Vertical Change	-.3	6 ft	6	REF		
30132	74.0 to 78.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838
121	74.1 to 75.1 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
55386	87.5 to 88.5 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: NW side of SONOMA AVE Starting at: 3RD ST							\$16,813.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	51909241029	SONOMA AVE	4TH ST	5TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
30134	46.7 to 50.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,706	
122	74.3 to 75.3 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
30136	77.9 to 79.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254	
51079	80.1 to 81.1 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
55387	80.2 to 81.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
41341	88.0 to 89.0 feet	Vertical Change	-1.4	6 ft	6	SF	\$75	\$413	
30137	93.0 to 101.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346	
59727	102.3 to 120.1 feet	Driveway				REF			
30141	108.6 to 110.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	12	SF	\$40	\$484	
30142	114.8 to 121.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	35	SF	\$40	\$1,408	
30144	130.1 to 136.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894	
55388	155.2 to 157.9 feet	Vertical Change	.3	6 ft	15	LF	\$75	\$1,114	
30146	157.8 to 160.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	17	SF	\$120	\$1,980	
55389	164.7 to 165.7 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
30147	170.1 to 176.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	34	SF	\$120	\$4,092	
30150	176.3 to 177.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
55390	177.2 to 178.2 feet	Vertical Change	.3	6 ft	6	REF			
30151	182.3 to 187.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564	
30152	191.6 to 195.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,508	
30153	198.7 to 203.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,366	
55391	202.1 to 203.1 feet	Vertical Change	.3	6 ft	6	REF			
30155	207.1 to 208.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,188	
30156	208.9 to 218.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	52	SF	\$120	\$6,270	
47722	210.0 to 211.0 feet	Vertical Change	-.4	6 ft	6	REF			
57071	210.1 to 211.1 feet	Vertical Change	.6	6 ft	6	REF			
55392	213.3 to 214.3 feet	Vertical Change	.3	6 ft	6	REF			
30161	223.4 to 225.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,254	
30162	227.7 to 240.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	69	SF	\$120	\$8,316	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241029	SONOMA AVE	4TH ST	5TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55393	237.7 to 238.7 feet	Vertical Change	.3	6 ft	6	REF		
30167	240.3 to 253.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	72	SF	\$120	\$8,646
30171	257.3 to 258.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
57267	257.8 to 258.8 feet	Vertical Change	.8	6 ft	6	REF		
55394	277.6 to 278.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
41878	283.3 to 284.3 feet	Vertical Change	-.8	6 ft	6	SF	\$75	\$413
56808	285.8 to 286.8 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
30172	298.3 to 299.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
TOTAL COST FOR: NW side of SONOMA AVE Starting at: 4TH ST								\$63,016.25

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241031	SONOMA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59728	2.8 to 18.8 feet	Driveway				REF		
30173	14.8 to 17.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	13	SF	\$40	\$506
30174	28.7 to 35.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224
55396	36.7 to 37.7 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
30176	39.4 to 46.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,422
30179	54.8 to 59.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,366
TOTAL COST FOR: NW side of SONOMA AVE Starting at: SIDEWALK BEGINS							\$12,930.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241035	SONOMA AVE	6TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59729	1.9 to 16.4 feet	Driveway				REF		
30182	21.3 to 23.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
56408	23.0 to 24.0 feet	Vertical Change	.4	6 ft	6	REF		
123	25.8 to 26.8 feet	Continuous Width		6 ft	6	SF	\$120	\$660
30183	26.4 to 35.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	52	SF	\$120	\$6,204
56409	32.8 to 33.8 feet	Vertical Change	.4	6 ft	6	REF		
51081	35.0 to 38.4 feet	Vertical Change	-.3	6 ft	19	REF		
55397	41.8 to 44.9 feet	Vertical Change	.3	6 ft	17	REF		
30187	41.8 to 43.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
56410	48.8 to 49.8 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
41489	52.3 to 53.3 feet	Vertical Change	-1.1	6 ft	6	SF	\$75	\$413
42349	52.5 to 53.5 feet	Vertical Change	-.7	6 ft	6	SF	\$75	\$413
56411	54.8 to 58.3 feet	Vertical Change	.4	6 ft	19	LF	\$75	\$1,444
30188	60.5 to 66.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224
55399	60.7 to 61.7 feet	Vertical Change	.3	6 ft	6	REF		
55400	64.3 to 70.2 feet	Vertical Change	.3	6 ft	32	REF		
30190	69.8 to 75.9 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	34	SF	\$120	\$4,026
51082	72.2 to 73.7 feet	Vertical Change	-.3	6 ft	8	REF		
57673	76.6 to 77.6 feet	Vertical Change	3.6	6 ft	6	SF	\$75	\$413
30194	78.2 to 79.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726
55403	78.8 to 79.8 feet	Vertical Change	.3	6 ft	6	REF		
30195	79.3 to 80.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
55404	84.5 to 85.5 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
30196	87.6 to 92.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	27	SF	\$120	\$3,234
30199	95.8 to 108.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	69	SF	\$120	\$8,316
55405	97.4 to 98.4 feet	Vertical Change	.3	6 ft	6	REF		
124	108.0 to 109.0 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
30205	109.6 to 116.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,290

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241035	SONOMA AVE	6TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40871	120.6 to 121.6 feet	Running Slope	6.0-7.0%	6 ft	6	SF	\$120	\$660
51084	120.9 to 121.9 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
30208	123.7 to 124.9 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	7	SF	\$120	\$792
56413	126.9 to 130.8 feet	Vertical Change	.4	6 ft	21	LF	\$75	\$1,609
30209	130.2 to 132.8 feet	Cross Slope (PAR)	>15%	6 ft	14	SF	\$120	\$1,716
30210	135.8 to 140.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838
56415	143.6 to 144.6 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
59730	147.3 to 157.3 feet	Driveway				REF		
TOTAL COST FOR: NW side of SONOMA AVE Starting at: 6TH ST							\$47,025.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241037	SONOMA AVE	7TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30215	16.0 to 19.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178
59731	18.7 to 33.2 feet	Driveway				REF		
45384	19.1 to 20.1 feet	Vertical Change	-5	6 ft	6	REF		
30216	23.8 to 32.6 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	48	SF	\$40	\$1,936
30220	37.8 to 39.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$792
59732	37.8 to 62.5 feet	Driveway				REF		
47725	38.9 to 39.9 feet	Vertical Change	-4	6 ft	6	REF		
30221	42.5 to 48.9 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	35	SF	\$40	\$1,408
30225	53.4 to 63.6 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	56	SF	\$40	\$2,244
TOTAL COST FOR: NW side of SONOMA AVE Starting at: 7TH ST								\$8,558.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241038	SONOMA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51087	7.2 to 10.5 feet	Vertical Change	-.3	6 ft	18	LF	\$75	\$1,361
56809	9.7 to 14.8 feet	Vertical Change	.5	6 ft	28	SF	\$75	\$2,104
59734	14.6 to 32.9 feet	Driveway				REF		
40872	15.2 to 16.2 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
43523	35.7 to 36.7 feet	Vertical Change	-.6	6 ft	6	SF	\$75	\$413
51089	35.9 to 36.9 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
55407	73.6 to 74.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
30230	74.8 to 76.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
30231	81.8 to 83.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
59735	88.6 to 107.0 feet	Driveway				REF		
30232	93.1 to 106.8 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	75	SF	\$40	\$3,014
TOTAL COST FOR: NW side of SONOMA AVE Starting at: SIDEWALK BEGINS							\$9,762.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241041	SONOMA AVE	SIDEWALK BEGINS	9TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30239	46.8 to 49.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848
51091	47.6 to 48.6 feet	Vertical Change	-.3	6 ft	6	REF		
30241	51.1 to 58.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	42	SF	\$120	\$5,082
30244	60.0 to 75.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	86	SF	\$120	\$10,296
51092	79.7 to 80.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
51093	85.2 to 86.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
47726	105.0 to 106.0 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: NW side of SONOMA AVE Starting at: SIDEWALK BEGINS								\$18,463.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241042	SONOMA AVE	9TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40874	0.0 to 2.3 feet	Running Slope	5.0-6.0%	6 ft	13	SF	\$120	\$1,518
55408	4.8 to 5.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
30251	8.3 to 10.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
30252	12.3 to 20.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346
30255	29.3 to 45.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	88	SF	\$120	\$10,560
30261	47.9 to 57.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,402
30263	61.6 to 63.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452
30264	66.2 to 67.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
56810	72.6 to 73.6 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
40875	73.1 to 74.7 feet	Running Slope	6.0-7.0%	6 ft	9	SF	\$120	\$1,056
47727	77.4 to 78.4 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
55409	79.8 to 80.8 feet	Vertical Change	.3	6 ft	6	REF		
30265	80.1 to 81.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
55410	87.8 to 88.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
51094	89.9 to 90.9 feet	Vertical Change	-.3	6 ft	6	REF		
30266	96.9 to 98.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	9	SF	\$40	\$352
40876	97.2 to 98.3 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
57073	97.3 to 98.3 feet	Vertical Change	.6	6 ft	6	REF		
30267	100.9 to 104.1 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	18	SF	\$40	\$704
55411	101.8 to 102.8 feet	Vertical Change	.3	6 ft	6	REF		
57585	107.4 to 108.4 feet	Vertical Change	2.8	6 ft	6	REF		
30268	109.4 to 110.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
55412	117.4 to 118.4 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
51095	122.7 to 123.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
59737	123.3 to 131.4 feet	Driveway				REF		
30269	128.1 to 136.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	43	SF	\$40	\$1,738
TOTAL COST FOR: NW side of SONOMA AVE Starting at: 9TH ST								\$35,035.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241045	SONOMA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30271	0.3 to 25.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	139	SF	\$120	\$16,698
59738	25.6 to 35.0 feet	Driveway				REF		
30279	30.1 to 36.1 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	33	SF	\$40	\$1,320
TOTAL COST FOR: NW side of SONOMA AVE Starting at: SIDEWALK BEGINS							\$18,018.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241048	SONOMA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59739	0.1 to 17.3 feet	Driveway				REF		
30281	0.5 to 4.3 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	21	SF	\$40	\$836
40877	0.8 to 1.8 feet	Running Slope	6.0-7.0%	6 ft	6	REF		
40878	1.8 to 2.8 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
47728	4.9 to 5.9 feet	Vertical Change	-.4	6 ft	5	REF		
30283	6.5 to 7.8 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	7	SF	\$40	\$286
30284	10.3 to 15.7 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	30	SF	\$40	\$1,188
30286	15.7 to 16.7 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	6	SF	\$40	\$220
125	20.1 to 21.1 feet	Protruding Object		6 ft	5	JOB	\$99	\$99
30287	22.7 to 26.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	22	SF	\$120	\$2,640
30289	29.0 to 30.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	9	SF	\$120	\$1,122
30290	33.6 to 43.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	56	SF	\$120	\$6,666
59740	43.9 to 55.4 feet	Driveway				REF		
55413	44.6 to 45.6 feet	Vertical Change	.3	6 ft	6	REF		
30292	49.6 to 56.4 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	37	SF	\$40	\$1,496
TOTAL COST FOR: NW side of SONOMA AVE Starting at: SIDEWALK BEGINS							\$14,553.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909241051	12TH ST	SIDEWALK BEGINS	SONOMA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30294	0.0 to 7.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	41	SF	\$120	\$4,884
51096	4.8 to 5.8 feet	Vertical Change	-.3	6 ft	6	REF		
30296	8.4 to 14.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,290
30298	18.4 to 29.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	61	SF	\$120	\$7,326
51097	24.9 to 25.9 feet	Vertical Change	-.3	6 ft	6	REF		
30301	30.3 to 73.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	240	SF	\$120	\$28,776
51098	35.1 to 36.1 feet	Vertical Change	-.3	6 ft	6	REF		
30312	78.3 to 83.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	26	SF	\$120	\$3,102
30313	84.4 to 123.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	213	SF	\$120	\$25,542
51099	109.5 to 110.5 feet	Vertical Change	-.3	6 ft	6	REF		
40879	121.4 to 122.5 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
40880	122.5 to 123.6 feet	Running Slope	6.0-7.0%	6 ft	6	REF		

TOTAL COST FOR: SW side of 12TH ST Starting at: SIDEWALK BEGINS \$73,920.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241053	SONOMA AVE	12TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30324	1.1 to 7.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,092
59741	11.9 to 34.5 feet	Driveway				REF		
30325	12.7 to 15.6 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	16	SF	\$40	\$638
30327	19.2 to 34.5 feet	Cross Slope (Driveway)	13.014	6 ft	84	SF	\$40	\$3,366
TOTAL COST FOR: NW side of SONOMA AVE Starting at: 12TH ST								\$8,096.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909241057	14TH ST	VENTURA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40881	0.0 to 1.0 feet	Running Slope	6.0-7.0%	6 ft	6	SF	\$120	\$660
40882	1.0 to 2.2 feet	Running Slope	5.0-6.0%	6 ft	7	SF	\$120	\$792
30331	6.7 to 10.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,706
30332	37.1 to 40.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$1,980
30333	42.7 to 48.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	33	SF	\$120	\$3,960
59742	51.5 to 74.1 feet	Driveway				REF		
30335	52.0 to 54.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	16	SF	\$40	\$638
40883	55.6 to 57.0 feet	Running Slope	5.0-6.0%	6 ft	8	REF		
30336	64.6 to 66.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	8	SF	\$40	\$330
30337	71.8 to 74.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	13	SF	\$40	\$506
TOTAL COST FOR: SW side of 14TH ST Starting at: VENTURA AVE							\$11,572.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241101	SONOMA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30338	0.0 to 33.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	185	SF	\$120	\$22,242
59743	1.1 to 6.7 feet	Driveway				REF		
30347	36.7 to 59.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	124	SF	\$120	\$14,850
59744	54.1 to 64.2 feet	Driveway				REF		
55414	64.1 to 65.1 feet	Vertical Change	.3	6 ft	6	REF		
30352	64.5 to 83.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	103	SF	\$40	\$4,136
30359	85.4 to 94.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	48	SF	\$120	\$5,742
55415	96.5 to 97.5 feet	Vertical Change	.3	6 ft	6	REF		
30362	97.3 to 107.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	57	SF	\$120	\$6,864
41316	109.1 to 110.1 feet	Vertical Change	-1.5	6 ft	6	REF		
30364	109.1 to 118.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	49	SF	\$120	\$5,874
30367	118.3 to 123.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	31	SF	\$120	\$3,696
57074	121.6 to 122.6 feet	Vertical Change	.6	6 ft	6	REF		
30370	126.8 to 133.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,158
59745	133.7 to 142.3 feet	Driveway				REF		
30371	138.3 to 145.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	39	SF	\$40	\$1,562
TOTAL COST FOR: SE side of SONOMA AVE Starting at: SIDEWALK BEGINS							\$69,124.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241105	SONOMA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30378	15.4 to 18.5 feet	Cross Slope (PAR)	10.0-11.0%	6 ft	17	SF	\$120	\$2,046
30379	25.0 to 40.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	85	SF	\$120	\$10,164
55416	36.7 to 37.7 feet	Vertical Change	.3	6 ft	6	REF		
30382	40.6 to 46.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	33	SF	\$120	\$3,960
59747	46.6 to 66.3 feet	Driveway				REF		
30384	50.9 to 52.1 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	7	SF	\$40	\$264
30385	53.7 to 66.8 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	72	SF	\$40	\$2,882
TOTAL COST FOR: SE side of SONOMA AVE Starting at: SIDEWALK BEGINS							\$19,316.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241106	SONOMA AVE	11TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30391	17.8 to 18.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660
30392	21.0 to 25.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	25	SF	\$120	\$3,036
30393	27.2 to 43.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	90	SF	\$120	\$10,758
59748	44.4 to 64.8 feet	Driveway				REF		
56416	45.5 to 46.5 feet	Vertical Change	.4	6 ft	6	REF		
30398	48.9 to 64.3 feet	Cross Slope (Driveway)	>15%	6 ft	85	SF	\$40	\$3,388
55417	65.3 to 66.3 feet	Vertical Change	.3	6 ft	6	REF		
30399	69.8 to 75.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,432
30400	79.9 to 85.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
TOTAL COST FOR: SE side of SONOMA AVE Starting at: 11TH ST							\$24,838.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241108	SONOMA AVE	SIDEWALK BEGINS	10TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30402	0.0 to 1.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$792
40885	22.1 to 24.4 feet	Running Slope	9.0-10.0%	6 ft	13	SF	\$120	\$1,518
TOTAL COST FOR: SE side of SONOMA AVE Starting at: SIDEWALK BEGINS							\$2,310.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241114	SONOMA AVE	9TH ST	805 SONOMA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55418	0.2 to 1.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
40886	0.2 to 1.5 feet	Running Slope	7.0-8.0%	6 ft	7	SF	\$120	\$858
40887	2.3 to 3.3 feet	Running Slope	5.0-6.0%	6 ft	6	SF	\$120	\$660
55419	7.1 to 8.1 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
55420	33.0 to 36.3 feet	Vertical Change	.3	6 ft	18	LF	\$75	\$1,361
30408	47.0 to 49.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,584
59750	82.1 to 88.9 feet	Driveway				REF		
51100	90.9 to 91.9 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
59751	131.3 to 140.3 feet	Driveway				REF		
126	143.7 to 144.7 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
30409	156.8 to 161.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,970
56811	161.3 to 162.3 feet	Vertical Change	.5	6 ft	6	REF		
41428	165.8 to 166.8 feet	Vertical Change	-1.2	6 ft	6	SF	\$75	\$413
30411	172.0 to 174.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	13	SF	\$120	\$1,518
57576	175.0 to 176.0 feet	Vertical Change	2.7	6 ft	6	SF	\$75	\$413
45385	177.6 to 178.6 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413
30412	198.8 to 206.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346
TOTAL COST FOR: SE side of SONOMA AVE Starting at: 9TH ST							\$16,871.25	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241115	SONOMA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30418	20.7 to 21.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
30419	24.3 to 25.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
57075	25.3 to 26.3 feet	Vertical Change	.6	6 ft	6	REF		
30420	31.1 to 42.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	64	SF	\$120	\$7,722
40888	41.6 to 42.8 feet	Running Slope	5.0-6.0%	6 ft	7	REF		
TOTAL COST FOR: SE side of SONOMA AVE Starting at: SIDEWALK BEGINS							\$9,306.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241124	SONOMA AVE	SIDEWALK BEGINS	6TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30422	5.0 to 12.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,148
30424	16.8 to 19.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650
30425	42.9 to 46.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244
59753	90.2 to 109.1 feet	Driveway				REF		
30426	98.9 to 101.5 feet	Cross Slope (Driveway)	>15%	6 ft	14	SF	\$40	\$572
40889	103.3 to 104.7 feet	Running Slope	5.0-6.0%	6 ft	8	REF		
30427	110.6 to 112.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
TOTAL COST FOR: SE side of SONOMA AVE Starting at: SIDEWALK BEGINS							\$10,538.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241130	SONOMA AVE	SIDEWALK BEGINS	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59754	0.0 to 22.3 feet	Driveway				REF		
30428	3.9 to 12.9 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	50	SF	\$40	\$1,980
30431	13.5 to 19.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	32	SF	\$40	\$1,276
56812	19.9 to 23.2 feet	Vertical Change	.5	6 ft	18	REF		
30433	28.8 to 34.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630
127	31.2 to 32.2 feet	Continuous Width		6 ft	6	SF	\$120	\$660
30434	39.8 to 42.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914
30435	69.6 to 73.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
30436	83.5 to 93.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	56	SF	\$120	\$6,666
55423	83.8 to 84.8 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: SE side of SONOMA AVE Starting at: SIDEWALK BEGINS							\$18,700.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241132	SONOMA AVE	4TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30442	20.3 to 21.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,056
30443	28.4 to 37.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	49	SF	\$120	\$5,874
30447	38.5 to 41.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848
30448	44.3 to 51.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,620
59755	48.8 to 68.5 feet	Driveway				REF		
55424	51.9 to 52.9 feet	Vertical Change	.3	6 ft	6	REF		
30450	61.8 to 67.2 feet	Cross Slope (Driveway)	13.014	6 ft	30	SF	\$40	\$1,188
47729	69.3 to 70.3 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
40890	69.3 to 71.1 feet	Running Slope	5.0-6.0%	6 ft	10	SF	\$120	\$1,188
30453	73.2 to 81.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	45	SF	\$120	\$5,346
30455	83.8 to 90.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	36	SF	\$120	\$4,290
30457	97.0 to 136.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	215	SF	\$120	\$25,806
56417	115.5 to 116.5 feet	Vertical Change	.4	6 ft	6	REF		
TOTAL COST FOR: SE side of SONOMA AVE Starting at: 4TH ST							\$51,628.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
S	51909241136	SONOMA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59756	2.4 to 22.3 feet	Driveway				REF		
40891	22.3 to 23.7 feet	Running Slope	5.0-6.0%	6 ft	8	REF		
42350	23.2 to 24.2 feet	Vertical Change	-7	6 ft	6	SF	\$75	\$413
30469	27.1 to 31.3 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	23	SF	\$120	\$2,772
30471	33.0 to 34.6 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	9	SF	\$120	\$1,056
30472	37.1 to 40.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	20	SF	\$120	\$2,442
30474	40.8 to 54.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	75	SF	\$120	\$8,976
41342	42.3 to 43.3 feet	Vertical Change	-1.4	6 ft	6	REF		
30479	54.4 to 56.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254
56418	58.2 to 59.2 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
56419	71.5 to 72.5 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
45386	88.6 to 89.6 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413
51101	102.7 to 103.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
41687	111.4 to 112.4 feet	Vertical Change	-.9	6 ft	6	SF	\$75	\$413
51102	129.6 to 130.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
51103	132.8 to 133.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
51104	151.8 to 152.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
30481	161.7 to 174.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	72	SF	\$120	\$8,646
41566	173.6 to 174.6 feet	Vertical Change	-1	6 ft	6	REF		
30485	174.8 to 185.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	57	SF	\$120	\$6,798
59758	184.1 to 201.9 feet	Driveway				REF		
56420	184.8 to 185.8 feet	Vertical Change	.4	6 ft	6	REF		
30489	186.1 to 187.2 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	6	SF	\$40	\$242
30490	190.5 to 199.6 feet	Cross Slope (Driveway)	>15%	6 ft	50	SF	\$40	\$2,002
30492	199.8 to 202.8 feet	Cross Slope (Driveway)	13.014	6 ft	17	SF	\$40	\$660
40892	203.8 to 205.2 feet	Running Slope	5.0-6.0%	6 ft	8	SF	\$120	\$924
51105	204.6 to 205.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
30494	206.3 to 216.1 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	54	SF	\$120	\$6,468

TOTAL COST FOR: S side of **SONOMA AVE** Starting at: **SIDEWALK BEGINS** **\$46,365.00**

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241139	MONTEREY AVE	SIDEWALK BEGINS	2ND ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30497	0.8 to 10.1 feet	Cross Slope (PAR)	7.0-8.0%	6 ft	51	SF	\$120	\$6,138
30499	11.0 to 12.0 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	6	SF	\$120	\$660
30500	13.4 to 21.4 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	44	SF	\$120	\$5,280
30502	23.4 to 39.9 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	91	SF	\$120	\$10,890
30506	41.0 to 67.1 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	144	SF	\$120	\$17,226
30512	67.8 to 70.6 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	15	SF	\$120	\$1,848
TOTAL COST FOR: NW side of MONTEREY AVE Starting at: SIDEWALK BEGINS							\$42,042.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	51909241142	MONTEREY AVE	2ND ST	3RD ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
30513	3.2 to 23.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	112	SF	\$120	\$13,398	
30518	27.9 to 47.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	109	SF	\$120	\$13,134	
51106	49.3 to 50.3 feet	Vertical Change	-.3	6 ft	6	REF			
30520	49.5 to 54.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,498	
30522	63.4 to 82.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	106	SF	\$120	\$12,738	
51107	74.3 to 75.3 feet	Vertical Change	-.3	6 ft	6	REF			
30526	85.0 to 107.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	124	SF	\$120	\$14,850	
59759	106.0 to 118.1 feet	Driveway				REF			
51108	106.8 to 107.8 feet	Vertical Change	-.3	6 ft	6	REF			
30530	113.4 to 117.8 feet	Cross Slope (Driveway)	13.014	6 ft	24	SF	\$40	\$968	
40893	118.7 to 120.0 feet	Running Slope	5.0-6.0%	6 ft	7	SF	\$120	\$858	
30531	124.0 to 143.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	109	SF	\$120	\$13,068	
30537	146.3 to 158.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	65	SF	\$120	\$7,854	
30540	161.7 to 163.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056	
30541	166.3 to 173.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,818	
59760	181.5 to 192.7 feet	Driveway				REF			
30542	187.8 to 193.8 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	33	SF	\$40	\$1,320	
47730	199.8 to 200.8 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413	
30545	201.2 to 209.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,214	
30547	210.1 to 219.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	51	SF	\$120	\$6,072	
59761	217.3 to 228.3 feet	Driveway				REF			
30550	223.5 to 227.4 feet	Cross Slope (Driveway)	13.014	6 ft	21	SF	\$40	\$858	
40894	229.5 to 230.7 feet	Running Slope	5.0-6.0%	6 ft	7	SF	\$120	\$792	
30552	231.6 to 255.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	131	SF	\$120	\$15,774	
30557	256.1 to 297.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	229	SF	\$120	\$27,522	

TOTAL COST FOR: NW side of MONTEREY AVE Starting at: 2ND ST \$144,204.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	51909241144	MONTEREY AVE	3RD ST	SIDEWALK ENDS				TBD	
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
51109	2.7 to 3.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
56421	2.8 to 3.8 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
55425	15.8 to 16.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
57545	28.2 to 29.2 feet	Vertical Change	2.2	6 ft	6	SF	\$75	\$413	
56813	31.3 to 32.3 feet	Vertical Change	.5	6 ft	5	SF	\$75	\$413	
47731	33.2 to 34.2 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413	
55426	33.6 to 34.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
51110	35.3 to 36.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
55427	36.9 to 40.3 feet	Vertical Change	.3	6 ft	19	LF	\$75	\$1,403	
30567	73.0 to 75.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,584	
51111	79.0 to 80.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
30568	82.8 to 91.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,676	
30572	96.3 to 99.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310	
59762	119.0 to 136.3 feet	Driveway				REF			
30574	131.0 to 138.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	40	SF	\$40	\$1,606	
59763	186.4 to 211.8 feet	Driveway				REF			
55429	212.6 to 213.6 feet	Vertical Change	.3	6 ft	6	REF			
30577	212.9 to 214.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,056	
30578	214.5 to 221.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,620	
30579	225.5 to 235.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	55	SF	\$120	\$6,600	
40896	236.9 to 238.3 feet	Running Slope	5.0-6.0%	6 ft	8	SF	\$120	\$924	
TOTAL COST FOR: NW							side of MONTEREY AVE	Starting at: 3RD ST	\$29,491.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	51909241147	MONTEREY AVE	4TH ST	5TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
30581	5.7 to 25.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	107	SF	\$120	\$12,804	
128	12.0 to 13.0 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
59764	24.8 to 36.7 feet	Driveway				REF			
30585	34.5 to 38.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	23	SF	\$40	\$902	
30587	80.0 to 96.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	90	SF	\$120	\$10,824	
55430	95.8 to 96.8 feet	Vertical Change	.3	6 ft	6	REF			
51112	98.8 to 99.8 feet	Vertical Change	-.3	6 ft	6	REF			
30591	99.3 to 102.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	17	SF	\$120	\$2,046	
56422	102.1 to 103.1 feet	Vertical Change	.4	6 ft	6	REF			
30593	102.8 to 103.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
30594	107.8 to 110.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716	
59765	115.5 to 125.3 feet	Driveway				REF			
51113	115.8 to 116.8 feet	Vertical Change	-.3	6 ft	6	REF			
30595	137.1 to 139.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650	
30596	143.9 to 145.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858	
30597	153.8 to 155.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320	
30598	159.9 to 164.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904	
30600	173.1 to 175.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782	
59766	177.7 to 190.3 feet	Driveway				REF			
57268	178.3 to 179.3 feet	Vertical Change	.8	6 ft	6	REF			
55431	243.9 to 244.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
51114	246.1 to 247.1 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
55432	261.6 to 262.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	

TOTAL COST FOR: NW	<i>side of</i> MONTEREY AVE	<i>Starting at:</i> 4TH ST	\$38,802.50
---------------------------	------------------------------------	-----------------------------------	--------------------

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241149	MONTEREY AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30602	0.5 to 32.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	177	SF	\$120	\$21,252
51115	25.6 to 26.6 feet	Vertical Change	-.3	6 ft	6	REF		
51116	35.6 to 36.6 feet	Vertical Change	-.3	6 ft	6	REF		
30615	35.6 to 45.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,336
30618	47.6 to 56.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	51	SF	\$120	\$6,072
55433	55.6 to 56.6 feet	Vertical Change	.3	6 ft	6	REF		
30621	56.8 to 60.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112
59767	61.4 to 92.1 feet	Driveway				REF		
30625	74.0 to 90.3 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	90	SF	\$40	\$3,586
47732	93.0 to 94.0 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: NW side of MONTEREY AVE Starting at: SIDEWALK BEGINS							\$39,770.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority		
NW	51909241152	MONTEREY AVE	6TH ST	7TH ST					TBD		
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
51118	9.2 to 10.2 feet	Vertical Change	-.3	6 ft	5	LF	\$75	\$413			
41567	20.8 to 21.8 feet	Vertical Change	-1	6 ft	6	SF	\$75	\$413			
30630	26.4 to 33.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,554			
47733	30.8 to 31.8 feet	Vertical Change	-.4	6 ft	6	REF					
30631	36.0 to 38.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320			
30632	40.7 to 45.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,366			
45387	46.6 to 47.6 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413			
30634	52.7 to 54.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320			
30635	63.1 to 72.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,402			
51119	71.6 to 72.6 feet	Vertical Change	-.3	6 ft	6	REF					
59768	96.2 to 109.4 feet	Driveway				REF					
55434	97.3 to 98.3 feet	Vertical Change	.3	6 ft	6	REF					
30638	97.4 to 118.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	113	SF	\$40	\$4,532			
59769	151.3 to 162.2 feet	Driveway				REF					
51120	167.8 to 168.8 feet	Vertical Change	-.3	6 ft	6	REF					
30641	168.8 to 181.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	67	SF	\$120	\$8,052			
47734	187.9 to 188.9 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413			
51121	202.7 to 203.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413			
59770	221.6 to 232.4 feet	Driveway				REF					
59771	251.5 to 261.9 feet	Driveway				REF					
TOTAL COST FOR: NW							<i>side of</i>	MONTEREY AVE	<i>Starting at:</i>	6TH ST	\$31,608.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241154	MONTEREY AVE	SIDEWALK BEGINS	8TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40898	0.2 to 1.6 feet	Running Slope	5.0-6.0%	6 ft	8	SF	\$120	\$924
51122	7.3 to 8.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
40899	10.7 to 12.0 feet	Running Slope	5.0-6.0%	6 ft	7	SF	\$120	\$858
TOTAL COST FOR: NW side of MONTEREY AVE Starting at: SIDEWALK BEGINS							\$2,194.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241156	MONTEREY AVE	SIDEWALK BEGINS	9TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30643	0.0 to 3.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244
45388	6.4 to 7.4 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413
129	34.4 to 35.4 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
30644	42.3 to 47.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
59772	46.3 to 61.1 feet	Driveway				REF		
51123	46.6 to 48.0 feet	Vertical Change	-.3	6 ft	8	REF		
56423	47.7 to 48.7 feet	Vertical Change	.4	6 ft	6	REF		
55435	54.2 to 55.2 feet	Vertical Change	.3	6 ft	6	REF		
30646	58.2 to 59.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	8	SF	\$40	\$330
57322	59.2 to 60.2 feet	Vertical Change	.9	6 ft	6	REF		
30647	60.9 to 81.1 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	111	SF	\$40	\$4,444
30653	81.1 to 83.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386
45389	81.8 to 82.8 feet	Vertical Change	-.5	6 ft	6	REF		
30654	95.3 to 103.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	46	SF	\$120	\$5,478
30658	110.9 to 114.1 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	18	SF	\$120	\$2,112
57566	113.3 to 114.3 feet	Vertical Change	2.5	6 ft	6	REF		
30660	114.1 to 116.7 feet	Cross Slope (PAR)	8.0-9.0%	6 ft	14	SF	\$120	\$1,716
30662	116.7 to 121.3 feet	Cross Slope (PAR)	10.0-11.0%	6 ft	25	SF	\$120	\$3,036
47735	122.3 to 123.3 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
30664	197.3 to 208.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	59	SF	\$120	\$7,128
30668	208.1 to 248.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	224	SF	\$120	\$26,862
51125	222.2 to 223.2 feet	Vertical Change	-.3	6 ft	6	REF		
30679	248.8 to 251.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$1,980
30681	254.4 to 255.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
30682	261.1 to 265.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
30683	268.4 to 272.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838
30685	297.6 to 300.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782
TOTAL COST FOR: NW side of MONTEREY AVE Starting at: SIDEWALK BEGINS							\$69,190.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority		
NW	51909241200	MONTEREY AVE	10TH ST	SIDEWALK ENDS					TBD		
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
30686	0.0 to 9.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	54	SF	\$120	\$6,468			
51126	6.4 to 7.4 feet	Vertical Change	-.3	6 ft	6	REF					
30689	13.9 to 20.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	35	SF	\$120	\$4,158			
30691	22.6 to 48.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	142	SF	\$120	\$17,094			
30698	50.8 to 54.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310			
59773	54.8 to 70.3 feet	Driveway				REF					
40900	70.9 to 72.2 feet	Running Slope	6.0-7.0%	6 ft	7	SF	\$120	\$858			
55436	71.3 to 72.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413			
30702	74.8 to 76.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858			
30703	76.1 to 86.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	55	SF	\$120	\$6,600			
30706	86.1 to 92.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	34	SF	\$120	\$4,026			
59774	93.2 to 107.0 feet	Driveway				REF					
30707	98.7 to 100.3 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	9	SF	\$40	\$352			
30708	103.0 to 104.1 feet	Cross Slope (Driveway)	13.014	6 ft	6	SF	\$40	\$242			
30709	105.0 to 107.8 feet	Cross Slope (Driveway)	>15%	6 ft	15	SF	\$40	\$616			
TOTAL COST FOR: NW							<i>side of</i>	MONTEREY AVE	<i>Starting at:</i>	10TH ST	\$43,994.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241202	MONTEREY AVE	SIDEWALK BEGINS	11TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30710	27.9 to 29.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
30711	31.1 to 33.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	13	SF	\$120	\$1,518
59775	31.8 to 63.3 feet	Driveway				REF		
55437	34.3 to 35.3 feet	Vertical Change	.3	6 ft	6	REF		
40901	35.1 to 36.3 feet	Running Slope	5.0-6.0%	6 ft	7	REF		
30713	36.9 to 61.4 feet	Cross Slope (Driveway)	>15%	6 ft	135	SF	\$40	\$5,390
40902	38.2 to 40.1 feet	Running Slope	6.0-7.0%	6 ft	10	REF		
55438	66.6 to 67.6 feet	Vertical Change	.3	6 ft	6	REF		
30716	67.4 to 74.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	38	SF	\$120	\$4,554
30718	76.8 to 83.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	38	SF	\$120	\$4,554
55439	81.2 to 82.2 feet	Vertical Change	.3	6 ft	6	REF		
30721	85.8 to 95.5 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	53	SF	\$120	\$6,402
30724	96.0 to 97.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$990
30725	98.3 to 99.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
TOTAL COST FOR: NW side of MONTEREY AVE Starting at: SIDEWALK BEGINS							\$25,124.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241203	MONTEREY AVE	11TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30726	3.0 to 7.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	26	SF	\$120	\$3,102
30728	8.3 to 17.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,808
30729	30.2 to 31.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
59776	37.6 to 51.9 feet	Driveway				REF		
55440	39.3 to 40.3 feet	Vertical Change	.3	6 ft	6	REF		
30730	46.3 to 49.6 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	18	SF	\$40	\$726
40903	50.5 to 51.9 feet	Running Slope	5.0-6.0%	6 ft	8	REF		
30732	55.3 to 58.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	19	SF	\$120	\$2,310
30735	71.7 to 75.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	21	SF	\$120	\$2,508
30737	75.5 to 81.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894
30740	84.6 to 87.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	18	SF	\$120	\$2,112
TOTAL COST FOR: NW side of MONTEREY AVE Starting at: 11TH ST							\$21,516.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241211	MONTEREY AVE	SIDEWALK BEGINS	12TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30741	0.0 to 15.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	87	SF	\$120	\$10,428
30745	18.3 to 30.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	68	SF	\$120	\$8,118
59777	30.3 to 56.7 feet	Driveway				REF		
30749	36.0 to 42.4 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	35	SF	\$40	\$1,408
30752	47.3 to 48.4 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	6	SF	\$40	\$242
30753	53.7 to 56.8 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	17	SF	\$40	\$682
30754	58.3 to 59.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	6	SF	\$120	\$660
30755	61.0 to 62.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
30756	72.5 to 78.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,828
TOTAL COST FOR: NW side of MONTEREY AVE Starting at: SIDEWALK BEGINS							\$26,092.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241213	MONTEREY AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30760	16.3 to 18.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,188
30761	20.2 to 25.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	29	SF	\$120	\$3,432
30762	28.2 to 46.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	99	SF	\$120	\$11,880
30766	51.1 to 58.0 feet	Cross Slope (PAR)	14.0-15.0%	6 ft	38	SF	\$120	\$4,554
TOTAL COST FOR: NW side of MONTEREY AVE Starting at: SIDEWALK BEGINS							\$21,054.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241215	MONTEREY AVE	SIDEWALK BEGINS	1308 MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56424	4.3 to 5.3 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
30769	13.0 to 14.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
TOTAL COST FOR: NW side of MONTEREY AVE Starting at: SIDEWALK BEGINS								\$1,204.50

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241218	MONTEREY AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59780	0.3 to 17.3 feet	Driveway				REF		
57269	19.3 to 20.3 feet	Vertical Change	.8	6 ft	6	SF	\$75	\$413
40905	19.8 to 21.8 feet	Running Slope	5.0-6.0%	6 ft	11	SF	\$120	\$1,320
51127	21.0 to 22.0 feet	Vertical Change	-.3	6 ft	6	REF		
30777	21.9 to 29.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	43	SF	\$120	\$5,214
56425	31.0 to 32.0 feet	Vertical Change	.4	6 ft	6	REF		
30780	31.0 to 37.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,422
55441	36.1 to 37.1 feet	Vertical Change	.3	6 ft	6	REF		
30783	40.7 to 43.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	13	SF	\$120	\$1,518
30784	44.5 to 69.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	140	SF	\$120	\$16,764
55442	46.1 to 47.1 feet	Vertical Change	.3	6 ft	6	REF		
51128	61.1 to 62.1 feet	Vertical Change	-.3	6 ft	6	REF		
59781	67.3 to 85.8 feet	Driveway				REF		
30788	73.5 to 76.8 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	18	SF	\$40	\$726
30790	79.2 to 85.3 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	34	SF	\$40	\$1,342
40906	87.4 to 88.4 feet	Running Slope	5.0-6.0%	6 ft	6	SF	\$120	\$660
45390	87.5 to 88.5 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413
30792	92.3 to 94.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452
30793	102.8 to 104.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
30794	108.0 to 118.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	59	SF	\$120	\$7,128
45391	118.2 to 119.2 feet	Vertical Change	-.5	6 ft	6	REF		
56426	118.6 to 119.6 feet	Vertical Change	.4	6 ft	6	REF		
30797	121.3 to 122.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
59782	123.7 to 132.7 feet	Driveway				REF		
30798	128.1 to 131.4 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	18	SF	\$40	\$726
30800	131.4 to 134.3 feet	Cross Slope (Driveway)	13.014	6 ft	16	SF	\$40	\$638
TOTAL COST FOR: NW side of MONTEREY AVE Starting at: SIDEWALK BEGINS							\$44,517.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241220	MONTEREY AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40908	12.8 to 13.8 feet	Running Slope	6.0-7.0%	6 ft	6	REF		
30803	13.6 to 15.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
30804	19.8 to 23.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	18	SF	\$120	\$2,112
30806	23.4 to 32.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$5,940
59784	42.4 to 57.9 feet	Driveway				REF		
51129	43.8 to 44.8 feet	Vertical Change	-3	6 ft	6	REF		
30811	47.2 to 56.4 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	51	SF	\$40	\$2,024
40909	57.6 to 58.6 feet	Running Slope	8.0-9.0%	6 ft	6	REF		
30814	64.9 to 70.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,366
30815	75.3 to 81.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224
57362	87.4 to 88.4 feet	Vertical Change	1	6 ft	6	SF	\$75	\$413
30816	91.6 to 101.6 feet	Cross Slope (PAR)	13.014	6 ft	55	SF	\$120	\$6,600
30821	103.2 to 107.5 feet	Cross Slope (PAR)	>15%	6 ft	24	SF	\$120	\$2,838
TOTAL COST FOR: NW side of MONTEREY AVE Starting at: SIDEWALK BEGINS							\$28,638.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
SE	51909241221	MONTEREY AVE	SIDEWALK BEGINS	14TH ST	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
47736	23.8 to 24.8 feet	Vertical Change	-4	6 ft	6	REF					
30827	24.7 to 25.7 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	6	SF	\$120	\$660			
30828	27.5 to 42.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	85	SF	\$120	\$10,164			
TOTAL COST FOR: SE							<i>side of</i>	MONTEREY AVE	<i>Starting at:</i>	SIDEWALK BEGINS	\$10,824.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909241226	14TH ST	MONTEREY AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30831	5.9 to 11.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
47737	16.8 to 17.8 feet	Vertical Change	-4	6 ft	6	LF	\$75	\$413
47738	27.3 to 28.3 feet	Vertical Change	-4	6 ft	6	LF	\$75	\$413
30833	33.3 to 34.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
30834	41.3 to 42.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
30835	63.3 to 64.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
30836	95.8 to 101.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
47739	98.8 to 99.8 feet	Vertical Change	-4	6 ft	6	REF		
30838	122.3 to 125.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310
TOTAL COST FOR: NE side of 14TH ST Starting at: MONTEREY AVE							\$13,035.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	51909241229	LAKE AVE	SIDEWALK BEGINS	15TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
30839	0.0 to 11.7 feet	Cross Slope (PAR)	14.0-15.0%	6 ft	64	SF	\$120	\$7,722	
59786	17.3 to 42.6 feet	Driveway				REF			
30842	24.0 to 30.3 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	35	SF	\$40	\$1,386	
30845	33.0 to 38.4 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	30	SF	\$40	\$1,188	
30847	41.2 to 42.2 feet	Cross Slope (Driveway)	13.014	6 ft	6	SF	\$40	\$220	
40910	43.2 to 44.3 feet	Running Slope	5.0-6.0%	6 ft	6	REF			
30848	50.5 to 57.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	40	SF	\$120	\$4,818	
30850	57.8 to 65.6 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	43	SF	\$120	\$5,148	
43524	62.1 to 63.1 feet	Vertical Change	-.6	6 ft	6	REF			
30852	65.8 to 66.8 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	6	SF	\$120	\$660	
30853	69.2 to 79.3 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	56	SF	\$120	\$6,666	
51130	78.4 to 79.4 feet	Vertical Change	-.3	6 ft	6	REF			
30857	80.2 to 95.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	86	SF	\$120	\$10,296	
55444	92.7 to 93.7 feet	Vertical Change	.3	6 ft	6	REF			
59787	95.5 to 108.3 feet	Driveway				REF			
30861	100.3 to 108.5 feet	Cross Slope (Driveway)	13.014	6 ft	45	SF	\$40	\$1,804	
40911	108.2 to 110.9 feet	Running Slope	6.0-7.0%	6 ft	15	REF			
30864	117.4 to 119.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188	
57518	117.5 to 118.5 feet	Vertical Change	1.9	6 ft	6	REF			
30865	121.7 to 127.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	30	SF	\$120	\$3,564	
59788	127.1 to 139.9 feet	Driveway				REF			
30867	133.9 to 138.6 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	26	SF	\$40	\$1,034	
30869	143.8 to 155.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	62	SF	\$120	\$7,458	
51131	158.0 to 159.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
55445	166.8 to 167.8 feet	Vertical Change	.3	6 ft	6	REF			
30871	167.3 to 183.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	91	SF	\$120	\$10,890	
56427	186.8 to 187.8 feet	Vertical Change	.4	6 ft	6	REF			
30875	186.8 to 187.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241229	LAKE AVE	SIDEWALK BEGINS	15TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57076	190.4 to 191.4 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413
30876	193.8 to 204.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	58	SF	\$120	\$6,930
TOTAL COST FOR: NW side of LAKE AVE Starting at: SIDEWALK BEGINS							\$72,457.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241231	LAKE AVE	15TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30879	6.5 to 10.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,508
30880	15.4 to 45.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	163	SF	\$120	\$19,536
30888	45.8 to 78.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	179	SF	\$120	\$21,450
TOTAL COST FOR: SE side of LAKE AVE Starting at: 15TH ST							\$43,494.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241232	LAKE AVE	SIDEWALK BEGINS	15TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40912	0.0 to 1.5 feet	Running Slope	5.0-6.0%	6 ft	8	SF	\$120	\$990
59789	19.9 to 35.4 feet	Driveway				REF		
56428	20.1 to 21.1 feet	Vertical Change	.4	6 ft	5	REF		
30895	25.4 to 27.1 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	9	SF	\$40	\$374
30896	27.3 to 34.7 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	41	SF	\$40	\$1,628
40913	34.6 to 35.7 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
59790	48.2 to 72.2 feet	Driveway				REF		
30898	54.4 to 71.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	96	SF	\$40	\$3,828
40914	71.7 to 74.0 feet	Running Slope	6.0-7.0%	6 ft	13	REF		
30903	76.6 to 77.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
30904	92.5 to 106.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	76	SF	\$120	\$9,174
30906	120.3 to 123.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310
30908	127.5 to 129.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
30909	134.9 to 143.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346
TOTAL COST FOR: SE side of LAKE AVE Starting at: SIDEWALK BEGINS							\$25,762.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909241233	14TH ST	LAKE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30911	0.0 to 18.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	103	SF	\$120	\$12,408
30915	21.7 to 23.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
30916	25.8 to 32.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,290
30917	34.6 to 64.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	163	SF	\$120	\$19,602
59791	61.8 to 76.6 feet	Driveway				REF		
47740	63.9 to 64.9 feet	Vertical Change	-4	6 ft	6	REF		
30923	67.7 to 68.7 feet	Cross Slope (Driveway)	>15%	6 ft	6	SF	\$40	\$220
30924	70.9 to 76.3 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	30	SF	\$40	\$1,188
40915	76.9 to 79.0 feet	Running Slope	5.0-6.0%	6 ft	12	REF		
30926	104.3 to 107.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$1,980
30927	110.0 to 113.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,508
30928	116.1 to 128.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	69	SF	\$120	\$8,250
30933	128.6 to 137.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	47	SF	\$120	\$5,676
30937	138.0 to 141.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
TOTAL COST FOR: NE side of 14TH ST Starting at: LAKE AVE							\$59,884.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909241235	14TH ST	SIDEWALK BEGINS	RIVERSIDE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30939	0.0 to 20.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	115	SF	\$120	\$13,794
30945	29.2 to 35.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,828
30947	35.0 to 38.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	21	SF	\$120	\$2,508
30949	43.8 to 62.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	103	SF	\$120	\$12,408
30954	72.1 to 89.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	97	SF	\$120	\$11,682
55446	76.7 to 77.7 feet	Vertical Change	.3	6 ft	6	REF		
51132	85.7 to 86.7 feet	Vertical Change	-.3	6 ft	6	REF		
55447	104.8 to 105.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
30959	127.7 to 132.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
TOTAL COST FOR: NE side of 14TH ST Starting at: SIDEWALK BEGINS							\$47,668.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241239	MONTEREY AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59793	44.8 to 66.5 feet	Driveway				REF		
30964	49.9 to 54.3 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	24	SF	\$40	\$968
30966	54.3 to 59.0 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	26	SF	\$40	\$1,034
30969	59.9 to 66.2 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	35	SF	\$40	\$1,386
40917	66.7 to 68.8 feet	Running Slope	7.0-8.0%	6 ft	12	SF	\$120	\$1,386
59794	95.5 to 111.4 feet	Driveway				REF		
30971	99.2 to 101.8 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	14	SF	\$40	\$572
30973	102.0 to 110.6 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	47	SF	\$40	\$1,892
30975	110.9 to 112.1 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	7	SF	\$40	\$264
40918	112.5 to 114.0 feet	Running Slope	5.0-6.0%	6 ft	8	SF	\$120	\$990
59795	144.1 to 161.1 feet	Driveway				REF		
30976	148.8 to 149.8 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	6	SF	\$40	\$220
30977	150.3 to 152.6 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	13	SF	\$40	\$506
30978	155.9 to 159.7 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	21	SF	\$40	\$836
30980	161.1 to 162.1 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	6	SF	\$40	\$220
51133	162.8 to 163.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
59796	181.8 to 195.8 feet	Driveway				REF		
30981	188.0 to 195.3 feet	Cross Slope (Driveway)	13.014	6 ft	40	SF	\$40	\$1,606
TOTAL COST FOR: SE side of MONTEREY AVE Starting at: SIDEWALK BEGINS							\$12,292.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909241242	13TH ST	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30983	17.8 to 28.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	58	SF	\$120	\$6,996
59797	28.4 to 47.7 feet	Driveway				REF		
47742	29.1 to 30.1 feet	Vertical Change	-4	6 ft	6	REF		
30989	34.9 to 46.5 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	64	SF	\$40	\$2,552
51135	49.3 to 50.3 feet	Vertical Change	-3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: NE side of 13TH ST Starting at: SIDEWALK BEGINS								\$9,960.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909241243	13TH ST	SIDEWALK BEGINS	LAKE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
30991	0.0 to 5.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894
30993	8.4 to 9.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$924
30994	9.8 to 14.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	27	SF	\$120	\$3,300
30996	17.7 to 25.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,148
31000	28.8 to 30.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,254
31001	30.7 to 54.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	130	SF	\$120	\$15,642
TOTAL COST FOR: NE side of 13TH ST Starting at: SIDEWALK BEGINS							\$30,162.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241244	LAKE AVE	13TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55449	24.7 to 25.7 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: NW side of LAKE AVE Starting at: 13TH ST								\$412.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909241249	13TH ST	RIVERSIDE AVE	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40919	0.0 to 1.2 feet	Running Slope	5.0-6.0%	6 ft	7	REF		
31009	1.0 to 5.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
31011	11.6 to 36.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	137	SF	\$120	\$16,434
31019	48.2 to 54.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,828
31021	57.2 to 61.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904
31023	69.2 to 87.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	100	SF	\$120	\$11,946
31027	99.6 to 113.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	74	SF	\$120	\$8,844
31029	115.2 to 127.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	70	SF	\$120	\$8,382
31035	128.3 to 130.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
31036	133.2 to 137.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
31037	151.4 to 164.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	71	SF	\$120	\$8,514
31041	170.8 to 179.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	50	SF	\$120	\$5,940
31044	179.8 to 187.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,148
31047	189.7 to 201.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	66	SF	\$120	\$7,920
31051	205.6 to 215.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	56	SF	\$120	\$6,666
31054	215.7 to 218.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716
59798	218.8 to 264.3 feet	Driveway				REF		
31056	219.5 to 220.6 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	6	SF	\$40	\$242
31057	220.6 to 222.5 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	10	SF	\$40	\$418
31058	224.8 to 226.6 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	10	SF	\$40	\$396
31059	227.3 to 257.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	167	SF	\$40	\$6,688
31062	259.3 to 262.3 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	17	SF	\$40	\$660
40920	262.7 to 265.5 feet	Running Slope	6.0-7.0%	6 ft	15	REF		
31064	263.7 to 268.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	25	SF	\$40	\$990
55450	264.0 to 265.0 feet	Vertical Change	.3	6 ft	6	REF		
40921	265.5 to 268.6 feet	Running Slope	5.0-6.0%	6 ft	17	SF	\$120	\$2,046
31066	270.6 to 284.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	76	SF	\$120	\$9,174
31073	310.8 to 320.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	52	SF	\$120	\$6,204

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909241249	13TH ST	RIVERSIDE AVE	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56429	314.8 to 315.8 feet	Vertical Change	.4	6 ft	6	REF		
31075	329.0 to 331.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716
51136	355.1 to 356.1 feet	Vertical Change	-.3	6 ft	6	REF		
31078	355.6 to 362.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,290
31080	368.3 to 377.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	52	SF	\$120	\$6,270
51137	380.1 to 381.1 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
31082	392.0 to 406.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	79	SF	\$120	\$9,504
59801	403.3 to 465.7 feet	Driveway				REF		
31087	420.8 to 432.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	65	SF	\$40	\$2,618
31090	435.3 to 437.3 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	11	SF	\$40	\$440
31091	437.3 to 449.5 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	67	SF	\$40	\$2,684
31094	449.5 to 450.5 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	6	SF	\$40	\$220
31095	451.3 to 452.6 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	7	SF	\$40	\$286
31096	452.6 to 454.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	8	SF	\$40	\$330
31097	457.1 to 468.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	64	SF	\$40	\$2,552
40927	459.4 to 461.7 feet	Running Slope	5.0-6.0%	6 ft	13	REF		
31100	470.9 to 480.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,402
31105	483.5 to 492.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	49	SF	\$120	\$5,874
51138	484.8 to 485.8 feet	Vertical Change	-.3	6 ft	6	REF		
45392	493.8 to 494.8 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413
31108	495.2 to 496.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
31109	499.6 to 505.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630
31113	519.6 to 521.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518
31114	524.4 to 525.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$924
56430	525.2 to 526.2 feet	Vertical Change	.4	6 ft	6	REF		
31115	525.8 to 540.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	78	SF	\$120	\$9,372
59802	534.2 to 624.3 feet	Driveway				REF		
40928	538.7 to 541.3 feet	Running Slope	5.0-6.0%	6 ft	14	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909241249	13TH ST	RIVERSIDE AVE	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
31118	543.4 to 546.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	14	SF	\$40	\$572
31120	550.9 to 575.3 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	134	SF	\$40	\$5,368
31127	577.5 to 579.3 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	10	SF	\$40	\$396
31128	580.2 to 582.5 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	13	SF	\$40	\$506
31129	582.5 to 586.3 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	21	SF	\$40	\$836
31131	586.3 to 587.3 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	6	SF	\$40	\$220
31132	587.3 to 606.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	107	SF	\$40	\$4,268
31136	609.6 to 618.9 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	51	SF	\$40	\$2,046
31138	618.9 to 635.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	91	SF	\$40	\$3,652
40929	619.2 to 623.4 feet	Running Slope	5.0-6.0%	6 ft	23	REF		
40931	623.4 to 624.6 feet	Running Slope	6.0-7.0%	6 ft	7	REF		
40932	624.6 to 626.2 feet	Running Slope	5.0-6.0%	6 ft	9	SF	\$120	\$1,056
56814	633.8 to 634.8 feet	Vertical Change	.5	6 ft	6	REF		
31143	635.5 to 637.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	12	SF	\$120	\$1,386
40933	636.0 to 637.2 feet	Running Slope	5.0-6.0%	6 ft	7	REF		
TOTAL COST FOR: NE side of 13TH ST Starting at: RIVERSIDE AVE							\$202,477.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241253	MONTEREY AVE	13TH ST	11TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40934	0.0 to 1.1 feet	Running Slope	6.0-7.0%	6 ft	6	REF		
31144	0.9 to 5.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904
40935	1.1 to 2.3 feet	Running Slope	5.0-6.0%	6 ft	7	REF		
51139	1.3 to 2.3 feet	Vertical Change	-.3	6 ft	5	REF		
31146	7.5 to 13.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894
59803	10.8 to 37.8 feet	Driveway				REF		
51140	11.3 to 12.3 feet	Vertical Change	-.3	6 ft	6	REF		
31149	16.5 to 21.7 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	29	SF	\$40	\$1,144
31152	22.3 to 23.4 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	6	SF	\$40	\$242
31153	27.3 to 29.5 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	12	SF	\$40	\$484
31154	33.2 to 45.3 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	67	SF	\$40	\$2,662
31158	45.3 to 46.3 feet	Cross Slope (PAR)	8.0-9.0%	6 ft	6	SF	\$120	\$660
31159	48.3 to 49.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858
31160	49.6 to 55.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
55451	56.4 to 57.4 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
31162	61.1 to 75.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	81	SF	\$120	\$9,768
31165	77.7 to 83.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	31	SF	\$120	\$3,696
31167	84.8 to 86.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
31168	89.4 to 94.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630
31171	97.3 to 98.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
31172	100.7 to 102.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,254
31173	102.9 to 107.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904
59804	121.3 to 204.6 feet	Driveway				REF		
57077	121.5 to 122.5 feet	Vertical Change	.6	6 ft	6	REF		
31175	123.2 to 124.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	9	SF	\$40	\$374
31176	128.1 to 143.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	83	SF	\$40	\$3,300
31183	146.0 to 176.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	170	SF	\$40	\$6,798
31192	179.5 to 191.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	65	SF	\$40	\$2,618

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241253	MONTEREY AVE	13TH ST	11TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
31197	194.6 to 198.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	21	SF	\$40	\$836
55452	204.5 to 205.5 feet	Vertical Change	.3	6 ft	6	REF		
31198	205.0 to 207.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	12	SF	\$40	\$484
31199	207.8 to 217.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	55	SF	\$120	\$6,600
31202	246.8 to 257.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	57	SF	\$120	\$6,798
31207	260.1 to 261.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
31208	266.8 to 274.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,752
31209	286.9 to 317.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	170	SF	\$120	\$20,394
31221	343.5 to 352.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	48	SF	\$120	\$5,808
31224	352.3 to 379.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	147	SF	\$120	\$17,688
31229	382.3 to 420.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	212	SF	\$120	\$25,410
31243	423.3 to 429.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,828
31245	433.0 to 434.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,056
31246	435.4 to 440.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
31247	447.3 to 450.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848
31248	453.8 to 466.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	69	SF	\$120	\$8,250
31250	469.3 to 474.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168
31251	476.4 to 489.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	74	SF	\$120	\$8,844
59806	482.9 to 566.8 feet	Driveway				REF		
31256	492.4 to 496.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	22	SF	\$40	\$880
31258	498.9 to 510.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	63	SF	\$40	\$2,530
31261	513.3 to 536.8 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	129	SF	\$40	\$5,170
31268	540.3 to 545.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	28	SF	\$40	\$1,100
55453	543.4 to 544.4 feet	Vertical Change	.3	6 ft	6	REF		
31270	547.4 to 555.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	43	SF	\$40	\$1,716
51141	566.6 to 567.6 feet	Vertical Change	-.3	6 ft	6	REF		
51142	580.0 to 581.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
31272	595.8 to 601.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
SE	51909241253	MONTEREY AVE	13TH ST	11TH ST	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
31275	604.2 to 622.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	101	SF	\$120	\$12,078			
51143	614.3 to 615.3 feet	Vertical Change	-3	6 ft	6	REF					
51144	619.3 to 620.3 feet	Vertical Change	-3	6 ft	6	REF					
TOTAL COST FOR: SE							<i>side of</i>	MONTEREY AVE	<i>Starting at:</i>	13TH ST	\$200,783.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241255	MONTEREY AVE	SIDEWALK BEGINS	10TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57456	2.8 to 3.8 feet	Vertical Change	1.4	6 ft	6	SF	\$75	\$413
55454	5.6 to 6.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
57203	8.6 to 9.6 feet	Vertical Change	.7	6 ft	6	SF	\$75	\$413
59807	59.4 to 70.9 feet	Driveway				REF		
31280	93.0 to 95.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
31281	98.2 to 99.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
31282	101.8 to 109.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	44	SF	\$120	\$5,280
31283	117.6 to 120.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046
59808	139.9 to 163.3 feet	Driveway				REF		
31284	177.5 to 193.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	87	SF	\$120	\$10,428
31289	206.2 to 207.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
51145	212.2 to 213.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
31290	217.5 to 218.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	6	SF	\$120	\$660
31291	221.9 to 224.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	14	SF	\$120	\$1,650
TOTAL COST FOR: SE side of MONTEREY AVE Starting at: SIDEWALK BEGINS							\$24,618.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241257	MONTEREY AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59809	0.3 to 15.0 feet	Driveway				REF		
31292	7.0 to 10.5 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	19	SF	\$40	\$770
31294	43.1 to 46.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$1,980
31296	48.3 to 50.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650
59810	51.9 to 61.9 feet	Driveway				REF		
TOTAL COST FOR: SE side of MONTEREY AVE Starting at: SIDEWALK BEGINS							\$4,400.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241258	MONTEREY AVE	SIDEWALK BEGINS	9TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
31297	11.3 to 34.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	130	SF	\$120	\$15,576
56431	23.1 to 24.1 feet	Vertical Change	.4	6 ft	6	REF		
31299	37.6 to 39.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
31300	43.1 to 46.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310
55455	53.1 to 54.1 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
55456	58.2 to 59.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: SE side of MONTEREY AVE Starting at: SIDEWALK BEGINS							\$19,833.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	51909241300	MONTEREY AVE	SIDEWALK BEGINS	8TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
31301	2.9 to 4.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
59811	35.3 to 43.6 feet	Driveway				REF			
56432	37.2 to 38.2 feet	Vertical Change	.4	6 ft	6	REF			
31302	39.0 to 40.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	10	SF	\$40	\$396	
57078	44.7 to 45.7 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413	
31303	46.4 to 52.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224	
56433	56.2 to 57.2 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
31306	62.9 to 64.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254	
51146	65.8 to 66.8 feet	Vertical Change	-.3	6 ft	6	REF			
31307	66.3 to 67.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	8	SF	\$120	\$990	
55457	68.6 to 69.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
31308	70.4 to 79.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	47	SF	\$120	\$5,676	
55458	80.8 to 81.8 feet	Vertical Change	.3	6 ft	6	REF			
31312	81.2 to 82.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858	
31313	82.5 to 83.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
59812	84.0 to 90.5 feet	Driveway				REF			
56434	86.4 to 87.4 feet	Vertical Change	.4	6 ft	6	REF			
51147	106.7 to 107.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
31314	109.0 to 116.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,148	
59813	135.2 to 142.8 feet	Driveway				REF			
55459	136.5 to 137.5 feet	Vertical Change	.3	6 ft	6	REF			
31317	136.8 to 138.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	8	SF	\$40	\$330	
31318	141.4 to 157.9 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	91	SF	\$40	\$3,630	
31324	159.5 to 174.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	85	SF	\$120	\$10,164	
55460	166.6 to 167.6 feet	Vertical Change	.3	6 ft	6	REF			
31329	179.6 to 184.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,102	
59814	185.5 to 194.2 feet	Driveway				REF			
31330	187.0 to 196.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	54	SF	\$40	\$2,156	
55461	195.4 to 196.4 feet	Vertical Change	.3	6 ft	6	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
SE	51909241300	MONTEREY AVE	SIDEWALK BEGINS	8TH ST	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
56815	208.2 to 209.2 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413			
31332	242.8 to 244.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254			
56435	245.6 to 246.6 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413			
TOTAL COST FOR: SE							<i>side of</i>	MONTEREY AVE	<i>Starting at:</i>	SIDEWALK BEGINS	\$43,505.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	51909241302	MONTEREY AVE	8TH ST	7TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
31333	4.4 to 6.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386	
31334	30.8 to 37.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,488	
31338	41.1 to 43.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716	
31339	46.1 to 49.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,442	
55462	77.5 to 78.5 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
55463	84.9 to 85.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
31340	96.6 to 100.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244	
31341	107.0 to 108.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
59815	142.0 to 168.1 feet	Driveway				REF			
31342	146.9 to 148.0 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	6	SF	\$40	\$242	
31343	148.5 to 149.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$242	
55464	155.2 to 156.2 feet	Vertical Change	.3	6 ft	6	REF			
31344	159.3 to 184.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	137	SF	\$40	\$5,478	
51148	186.3 to 187.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
59816	205.8 to 224.1 feet	Driveway				REF			
31348	207.4 to 216.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	51	SF	\$40	\$2,024	
31351	218.7 to 225.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	36	SF	\$40	\$1,452	
31354	225.3 to 243.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	99	SF	\$120	\$11,880	
31358	243.6 to 255.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	63	SF	\$120	\$7,524	
56816	252.7 to 253.7 feet	Vertical Change	.5	6 ft	6	REF			
31360	257.3 to 265.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	47	SF	\$120	\$5,610	
56436	266.0 to 268.9 feet	Vertical Change	.4	6 ft	16	REF			
31363	267.0 to 268.2 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	7	SF	\$120	\$792	
57539	269.6 to 270.6 feet	Vertical Change	2.1	6 ft	6	REF			
31364	269.8 to 275.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,026	
31367	276.9 to 279.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	13	SF	\$120	\$1,584	
47743	278.0 to 279.0 feet	Vertical Change	-.4	6 ft	6	REF			
56437	279.8 to 280.8 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241302	MONTEREY AVE	8TH ST	7TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47744	281.7 to 282.7 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
31369	284.3 to 290.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,762
57079	286.8 to 287.8 feet	Vertical Change	.6	6 ft	6	REF		
55466	288.7 to 289.7 feet	Vertical Change	.3	6 ft	6	REF		
57204	290.4 to 291.4 feet	Vertical Change	.7	6 ft	6	SF	\$75	\$413
31371	294.4 to 295.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
40939	306.2 to 307.4 feet	Running Slope	6.0-7.0%	6 ft	7	SF	\$120	\$792
TOTAL COST FOR: SE side of MONTEREY AVE Starting at: 8TH ST							\$61,611.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	51909241305	MONTEREY AVE	7TH ST	6TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
31372	12.6 to 14.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
55467	31.3 to 32.3 feet	Vertical Change	.3	6 ft	5	LF	\$75	\$413	
59817	35.0 to 59.8 feet	Driveway				REF			
31373	52.4 to 59.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	40	SF	\$40	\$1,606	
45393	66.5 to 67.5 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413	
31376	71.8 to 75.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	19	SF	\$120	\$2,310	
31378	76.3 to 77.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
55468	86.4 to 87.4 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
31379	91.6 to 93.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320	
51149	98.8 to 99.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
59818	100.9 to 113.2 feet	Driveway				REF			
31380	108.3 to 118.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	56	SF	\$40	\$2,222	
55469	123.4 to 124.4 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
31383	129.7 to 138.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$6,006	
31386	167.3 to 172.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,102	
59819	186.1 to 196.6 feet	Driveway				REF			
55470	186.5 to 187.5 feet	Vertical Change	.3	6 ft	6	REF			
59820	208.3 to 219.7 feet	Driveway				REF			
31389	219.9 to 229.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	50	SF	\$40	\$2,002	
31392	231.8 to 239.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	41	SF	\$120	\$4,950	
31395	239.3 to 247.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,082	
56817	246.0 to 247.0 feet	Vertical Change	.5	6 ft	6	REF			
31397	247.8 to 249.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	11	SF	\$120	\$1,320	
31398	252.2 to 257.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	27	SF	\$120	\$3,234	
31400	257.3 to 260.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310	
51150	263.2 to 264.2 feet	Vertical Change	-.3	6 ft	6	REF			
31401	264.0 to 268.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838	
57484	266.4 to 267.4 feet	Vertical Change	1.6	6 ft	6	REF			
51151	276.4 to 277.4 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241305	MONTEREY AVE	7TH ST	6TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
31402	288.4 to 290.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
TOTAL COST FOR: SE side of MONTEREY AVE Starting at: 7TH ST							\$43,417.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	51909241307	MONTEREY AVE	6TH ST	5TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
40940	0.0 to 1.1 feet	Running Slope	6.0-7.0%	6 ft	6	SF	\$120	\$726	
31403	4.2 to 8.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,102	
31404	17.3 to 18.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
31405	37.8 to 40.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650	
56438	52.0 to 53.0 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
31407	57.3 to 63.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894	
31409	68.8 to 70.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320	
31410	75.8 to 94.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	104	SF	\$120	\$12,474	
55471	81.8 to 82.8 feet	Vertical Change	.3	6 ft	6	REF			
51152	91.9 to 92.9 feet	Vertical Change	-.3	6 ft	6	REF			
55472	102.0 to 103.0 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
31414	109.8 to 118.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$5,940	
31417	121.0 to 122.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
31418	128.5 to 129.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
31419	140.9 to 147.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,488	
31422	156.5 to 167.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	59	SF	\$120	\$7,128	
47745	162.0 to 163.0 feet	Vertical Change	-.4	6 ft	6	REF			
51153	222.0 to 223.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
59821	229.3 to 250.3 feet	Driveway				REF			
31426	233.8 to 235.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	7	SF	\$40	\$286	
31427	235.7 to 242.8 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	39	SF	\$40	\$1,562	
31431	242.8 to 245.3 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	14	SF	\$40	\$550	
40941	249.5 to 251.3 feet	Running Slope	5.0-6.0%	6 ft	10	REF			
31432	254.6 to 255.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
31433	258.9 to 284.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	142	SF	\$120	\$17,094	
55473	259.4 to 260.4 feet	Vertical Change	.3	6 ft	6	REF			
56439	269.5 to 270.5 feet	Vertical Change	.4	6 ft	6	REF			
56440	276.6 to 277.6 feet	Vertical Change	.4	6 ft	6	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241307	MONTEREY AVE	6TH ST	5TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
TOTAL COST FOR: SE							<i>side of</i>	\$64,619.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241308	MONTEREY AVE	5TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
31440	0.1 to 6.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	59	SF	\$120	\$7,080
51154	2.6 to 3.6 feet	Vertical Change	-.3	10 ft	10	REF		
31441	9.8 to 12.4 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	26	SF	\$120	\$3,120
31443	20.7 to 34.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	140	SF	\$120	\$16,800
31449	41.7 to 45.5 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	38	SF	\$120	\$4,560
31451	47.8 to 60.1 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	123	SF	\$120	\$14,760
56441	61.6 to 62.6 feet	Vertical Change	.4	10 ft	10	LF	\$75	\$750
47746	64.0 to 65.0 feet	Vertical Change	-.4	10 ft	10	LF	\$75	\$750
59822	73.9 to 84.0 feet	Driveway				REF		
57080	75.1 to 76.1 feet	Vertical Change	.6	10 ft	10	REF		
31456	79.4 to 85.0 feet	Cross Slope (Driveway)	9.0-10.0%	10 ft	56	SF	\$40	\$2,240
TOTAL COST FOR: SE side of MONTEREY AVE Starting at: 5TH ST							\$50,060.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241311	MONTEREY AVE	SIDEWALK BEGINS	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59823	0.5 to 18.7 feet	Driveway				REF		
31459	2.9 to 4.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	11	SF	\$40	\$440
55474	71.3 to 72.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
31460	74.8 to 76.2 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	8	SF	\$120	\$924
31461	77.3 to 79.2 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	10	SF	\$120	\$1,254
45394	79.8 to 80.8 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413
31462	86.3 to 88.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452
31463	94.0 to 109.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	84	SF	\$120	\$10,098
31466	111.5 to 126.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	80	SF	\$120	\$9,570
130	123.7 to 124.7 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
40942	134.8 to 136.6 feet	Running Slope	5.0-6.0%	6 ft	10	SF	\$120	\$1,188
31468	135.1 to 136.3 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	7	SF	\$120	\$792
31469	138.8 to 143.8 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	28	SF	\$120	\$3,300
51155	144.5 to 145.5 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
31470	149.0 to 157.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	49	SF	\$120	\$5,874
31473	160.3 to 169.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	49	SF	\$120	\$5,940
TOTAL COST FOR: SE side of MONTEREY AVE Starting at: SIDEWALK BEGINS							\$42,168.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241313	MONTEREY AVE	4TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51156	1.0 to 2.0 feet	Vertical Change	-.3	6 ft	6	REF		
31477	1.3 to 5.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	22	SF	\$120	\$2,640
131	3.3 to 4.3 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
55475	6.0 to 7.0 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
31479	10.7 to 18.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	43	SF	\$120	\$5,148
56818	20.6 to 21.6 feet	Vertical Change	.5	6 ft	6	REF		
31482	20.9 to 26.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	30	SF	\$120	\$3,564
31484	26.3 to 45.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	103	SF	\$120	\$12,342
56442	46.1 to 47.1 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
51157	53.6 to 54.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
47747	72.8 to 73.8 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
132	81.8 to 82.8 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
31490	82.9 to 99.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	89	SF	\$120	\$10,692
31493	103.1 to 108.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
59824	130.5 to 139.8 feet	Driveway				REF		
31495	152.3 to 183.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	169	SF	\$120	\$20,328
59825	183.3 to 195.0 feet	Driveway				REF		
31501	186.1 to 192.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	34	SF	\$40	\$1,342
TOTAL COST FOR: SE side of MONTEREY AVE Starting at: 4TH ST							\$61,468.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	51909241316	MONTEREY AVE	SIDEWALK BEGINS	2ND ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
31504	1.0 to 27.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	144	SF	\$120	\$17,226	
59826	25.5 to 44.3 feet	Driveway				REF			
31509	32.2 to 39.0 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	37	SF	\$40	\$1,496	
31513	39.4 to 41.5 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	12	SF	\$40	\$462	
31514	47.3 to 49.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122	
31515	52.2 to 56.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640	
31517	59.9 to 67.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,752	
31518	83.5 to 90.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,686	
31521	94.0 to 97.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	21	SF	\$120	\$2,508	
31523	97.8 to 107.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	52	SF	\$120	\$6,270	
59827	109.1 to 145.0 feet	Driveway				REF			
31526	110.3 to 111.6 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	7	SF	\$40	\$286	
31527	115.4 to 116.8 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	8	SF	\$40	\$308	
31528	117.3 to 122.0 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	26	SF	\$40	\$1,034	
31530	122.2 to 125.8 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	20	SF	\$40	\$792	
40943	128.6 to 130.8 feet	Running Slope	5.0-6.0%	6 ft	12	REF			
31532	130.7 to 133.7 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	17	SF	\$40	\$660	
31534	133.8 to 144.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	57	SF	\$40	\$2,266	
TOTAL COST FOR: SE							side of MONTEREY AVE	Starting at: SIDEWALK BEGINS	\$46,508.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909241321	2ND ST	SIDEWALK BEGINS	LAKE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
31536	0.0 to 4.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168
59828	8.4 to 20.7 feet	Driveway				REF		
31537	55.8 to 58.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	13	SF	\$120	\$1,584
31538	58.4 to 60.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
TOTAL COST FOR: SW side of 2ND ST Starting at: SIDEWALK BEGINS								\$5,940.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
SW	51909241323	LAKE AVE	2ND ST	SIDEWALK ENDS				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40944	0.0 to 1.5 feet	Running Slope	5.0-6.0%	6 ft	8	SF	\$120	\$990
31539	19.8 to 21.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
51158	20.2 to 21.2 feet	Vertical Change	-.3	6 ft	6	REF		
31540	24.3 to 28.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	25	SF	\$120	\$2,970
31541	34.2 to 41.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	37	SF	\$120	\$4,488
31542	41.0 to 46.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,762
31544	47.6 to 56.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	47	SF	\$120	\$5,610
55476	48.4 to 49.4 feet	Vertical Change	.3	6 ft	6	REF		
31548	56.1 to 57.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
59829	60.5 to 77.7 feet	Driveway				REF		
TOTAL COST FOR: SW							<i>side of LAKE AVE Starting at: 2ND ST</i>	\$20,064.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241327	LAKE AVE	3RD ST	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40945	0.7 to 1.7 feet	Running Slope	7.0-8.0%	6 ft	6	SF	\$120	\$660
31549	6.3 to 7.3 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	6	SF	\$120	\$660
31550	8.3 to 11.5 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	18	SF	\$120	\$2,112
31552	24.2 to 32.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346
56443	32.2 to 33.2 feet	Vertical Change	.4	6 ft	6	REF		
31554	33.0 to 34.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	8	SF	\$120	\$990
31555	38.7 to 39.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
59830	42.5 to 56.2 feet	Driveway				REF		
31556	97.5 to 101.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310
31558	103.2 to 118.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	86	SF	\$120	\$10,362
59831	107.6 to 119.4 feet	Driveway				REF		
51159	117.4 to 118.4 feet	Vertical Change	-.3	6 ft	6	REF		
31560	121.0 to 138.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	97	SF	\$120	\$11,682
31565	149.2 to 172.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	130	SF	\$120	\$15,642
47748	172.3 to 173.3 feet	Vertical Change	-.4	6 ft	6	REF		
55477	209.9 to 210.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
31571	227.3 to 235.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,610
31574	247.9 to 250.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$1,980
31575	261.3 to 274.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	75	SF	\$120	\$8,976
TOTAL COST FOR: NW side of LAKE AVE Starting at: 3RD ST								\$67,468.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241329	LAKE AVE	5TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40946	0.0 to 1.3 feet	Running Slope	5.0-6.0%	6 ft	7	SF	\$120	\$858
59832	27.8 to 38.9 feet	Driveway				REF		
55478	59.8 to 60.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
59833	80.3 to 91.9 feet	Driveway				REF		
55479	85.1 to 86.1 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: SE side of LAKE AVE Starting at: 5TH ST							\$1,270.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241331	LAKE AVE	SIDEWALK BEGINS	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
31580	13.9 to 18.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,970
56819	19.8 to 20.8 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
31582	25.5 to 40.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	85	SF	\$120	\$10,164
56820	26.1 to 27.1 feet	Vertical Change	.5	6 ft	6	REF		
31585	43.9 to 47.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178
31586	50.3 to 52.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518
55480	51.4 to 52.4 feet	Vertical Change	.3	6 ft	6	REF		
55481	63.6 to 64.6 feet	Vertical Change	.3	6 ft	5	LF	\$75	\$413
TOTAL COST FOR: SE side of LAKE AVE Starting at: SIDEWALK BEGINS							\$17,655.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	51909241334	LAKE AVE	4TH ST	3RD ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
55482	8.5 to 9.5 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
31587	12.2 to 14.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782	
51160	16.5 to 17.5 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
31588	33.7 to 37.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,706	
56821	43.5 to 44.5 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413	
51161	93.7 to 94.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
51162	98.3 to 99.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
31589	101.3 to 102.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
59834	105.3 to 113.4 feet	Driveway				REF			
55483	107.3 to 108.3 feet	Vertical Change	.3	6 ft	6	REF			
31590	108.5 to 128.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	110	SF	\$40	\$4,400	
59835	123.4 to 134.8 feet	Driveway				REF			
31593	133.3 to 139.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	34	SF	\$40	\$1,364	
55484	157.5 to 158.5 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
133	166.5 to 167.5 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
56444	167.3 to 168.3 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
40947	167.3 to 168.3 feet	Running Slope	5.0-6.0%	6 ft	6	SF	\$120	\$660	
40948	168.3 to 169.8 feet	Running Slope	6.0-7.0%	6 ft	8	SF	\$120	\$990	
31595	172.0 to 174.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	13	SF	\$120	\$1,584	
40949	172.1 to 173.9 feet	Running Slope	6.0-7.0%	6 ft	10	REF			
55485	174.9 to 175.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
40950	178.6 to 180.9 feet	Running Slope	8.0-9.0%	6 ft	13	SF	\$120	\$1,518	
31596	183.8 to 184.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
59836	207.1 to 214.6 feet	Driveway				REF			
31597	218.5 to 228.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	55	SF	\$120	\$6,600	
56445	227.9 to 228.9 feet	Vertical Change	.4	6 ft	6	REF			
31600	233.2 to 274.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	226	SF	\$120	\$27,126	
31609	281.1 to 299.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	100	SF	\$120	\$12,012	

TOTAL COST FOR: SE side of LAKE AVE Starting at: 4TH ST**\$65,593.00**

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241337	LAKE AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
31614	1.0 to 26.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	139	SF	\$120	\$16,698
57442	3.9 to 4.9 feet	Vertical Change	1.3	6 ft	6	REF		
43525	18.9 to 19.9 feet	Vertical Change	-.6	6 ft	6	REF		
41688	36.3 to 37.3 feet	Vertical Change	-.9	6 ft	6	SF	\$75	\$413
55486	39.3 to 40.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
31619	42.2 to 50.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,412
TOTAL COST FOR: SE side of LAKE AVE Starting at: SIDEWALK BEGINS								\$22,935.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909241339	1ST ST	SIDEWALK BEGINS	RIVERSIDE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40952	1.3 to 2.3 feet	Running Slope	5.0-6.0%	6 ft	5	SF	\$120	\$660
31621	18.4 to 26.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	44	SF	\$120	\$5,280
59837	26.1 to 50.4 feet	Driveway				REF		
31623	30.5 to 39.7 feet	Cross Slope (Driveway)	>15%	6 ft	51	SF	\$40	\$2,024
31624	41.8 to 48.3 feet	Cross Slope (Driveway)	>15%	6 ft	36	SF	\$40	\$1,430
31625	52.3 to 53.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	7	SF	\$120	\$858
31626	55.7 to 90.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	193	SF	\$120	\$23,166
31634	90.8 to 94.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178
31635	100.5 to 110.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	55	SF	\$120	\$6,600
31637	113.1 to 114.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
51163	130.3 to 131.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: SW side of 1ST ST Starting at: SIDEWALK BEGINS							\$43,532.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
NW	51909241349	RIVERSIDE AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
31638	0.0 to 1.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,188			
55487	2.3 to 3.3 feet	Vertical Change	.3	6 ft	6	REF					
31639	3.2 to 11.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,676			
57081	5.6 to 6.6 feet	Vertical Change	.6	6 ft	6	REF					
45395	9.1 to 10.1 feet	Vertical Change	-.5	6 ft	6	REF					
31643	13.9 to 19.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	33	SF	\$120	\$3,960			
59838	29.3 to 41.2 feet	Driveway				REF					
31644	35.8 to 40.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	28	SF	\$40	\$1,100			
59839	44.8 to 60.0 feet	Driveway				REF					
TOTAL COST FOR: NW							<i>side of</i>	RIVERSIDE AVE	<i>Starting at:</i>	SIDEWALK BEGINS	\$11,924.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241350	RIVERSIDE AVE	SIDEWALK BEGINS	2ND ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40953	0.0 to 1.4 feet	Running Slope	5.0-6.0%	6 ft	8	SF	\$120	\$924
55488	23.0 to 24.0 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
57643	44.8 to 45.8 feet	Vertical Change	3.4	6 ft	6	SF	\$75	\$413
45396	55.8 to 56.8 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413
31646	89.9 to 95.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894
TOTAL COST FOR: NW side of RIVERSIDE AVE Starting at: SIDEWALK BEGINS								\$6,055.50

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	51909241353	RIVERSIDE AVE	2ND ST	3RD ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
40954	0.0 to 1.0 feet	Running Slope	6.0-7.0%	6 ft	6	SF	\$120	\$660	
40955	1.0 to 3.3 feet	Running Slope	5.0-6.0%	6 ft	13	SF	\$120	\$1,518	
31648	5.3 to 8.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046	
31649	12.9 to 29.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	90	SF	\$120	\$10,758	
31653	42.1 to 46.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772	
57562	54.6 to 55.6 feet	Vertical Change	2.4	6 ft	6	SF	\$75	\$413	
31655	84.3 to 90.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,356	
59841	85.1 to 98.3 feet	Driveway				REF			
55489	90.9 to 91.9 feet	Vertical Change	.3	6 ft	6	REF			
31657	93.0 to 104.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	62	SF	\$40	\$2,486	
59842	109.1 to 150.8 feet	Driveway				REF			
31661	110.1 to 112.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	12	SF	\$40	\$484	
31662	116.2 to 131.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	86	SF	\$40	\$3,432	
31666	131.8 to 168.3 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	201	SF	\$40	\$8,030	
51164	150.5 to 151.5 feet	Vertical Change	-.3	6 ft	6	REF			
47749	156.1 to 157.1 feet	Vertical Change	-.4	6 ft	6	REF			
31676	168.3 to 169.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
31677	172.3 to 184.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	68	SF	\$120	\$8,184	
59843	184.4 to 198.1 feet	Driveway				REF			
31680	190.0 to 196.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	37	SF	\$40	\$1,496	
31681	199.0 to 220.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	119	SF	\$120	\$14,256	
59844	207.6 to 236.2 feet	Driveway				REF			
31687	223.2 to 243.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	113	SF	\$40	\$4,532	
31693	245.9 to 266.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	113	SF	\$120	\$13,530	
31697	266.4 to 268.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650	
51165	271.4 to 272.4 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
31698	273.8 to 275.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320	
31699	281.5 to 290.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,742	
31702	291.2 to 297.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	34	SF	\$120	\$4,026	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241353	RIVERSIDE AVE	2ND ST	3RD ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51166	291.3 to 292.3 feet	Vertical Change	-.3	6 ft	6	REF		
47750	296.3 to 297.3 feet	Vertical Change	-.4	6 ft	6	REF		
31706	297.3 to 298.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
TOTAL COST FOR: NW side of RIVERSIDE AVE Starting at: 2ND ST							\$93,819.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241355	RIVERSIDE AVE	3RD ST	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
31707	0.0 to 15.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	87	SF	\$120	\$10,428
40956	0.0 to 1.1 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
56822	6.4 to 7.4 feet	Vertical Change	.5	6 ft	6	REF		
31711	18.3 to 24.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	31	SF	\$120	\$3,762
31714	27.0 to 42.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	83	SF	\$120	\$9,966
31716	42.3 to 44.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518
47751	46.8 to 47.8 feet	Vertical Change	-.4	6 ft	6	REF		
31717	47.7 to 50.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	13	SF	\$120	\$1,518
59845	51.5 to 70.2 feet	Driveway				REF		
31718	54.0 to 80.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	145	SF	\$40	\$5,786
55490	72.0 to 73.0 feet	Vertical Change	.3	6 ft	6	REF		
31727	84.0 to 93.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$6,006
51167	89.7 to 90.7 feet	Vertical Change	-.3	6 ft	6	REF		
31731	97.2 to 117.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	111	SF	\$120	\$13,266
31735	137.1 to 141.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168
55491	137.3 to 138.3 feet	Vertical Change	.3	6 ft	6	REF		
59846	149.2 to 166.5 feet	Driveway				REF		
31736	153.7 to 194.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	224	SF	\$40	\$8,976
31747	196.9 to 223.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	147	SF	\$120	\$17,688
31753	226.5 to 245.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	102	SF	\$120	\$12,276
59847	228.5 to 237.8 feet	Driveway				REF		
55492	239.7 to 240.7 feet	Vertical Change	.3	6 ft	6	REF		
31758	249.0 to 251.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452
31759	254.4 to 257.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244
31760	293.4 to 296.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	18	SF	\$120	\$2,178
55493	294.9 to 295.9 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: NW side of RIVERSIDE AVE Starting at: 3RD ST							\$100,232.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	51909241357	RIVERSIDE AVE	4TH ST	5TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
40957	1.3 to 2.7 feet	Running Slope	6.0-7.0%	6 ft	8	SF	\$120	\$924	
31762	35.9 to 39.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112	
31763	42.4 to 56.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	79	SF	\$120	\$9,438	
59848	52.3 to 66.2 feet	Driveway				REF			
56823	54.1 to 55.1 feet	Vertical Change	.5	6 ft	6	REF			
31768	59.7 to 61.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	10	SF	\$40	\$396	
55494	79.2 to 80.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
59849	103.9 to 119.3 feet	Driveway				REF			
31769	113.6 to 123.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	52	SF	\$40	\$2,068	
31772	129.3 to 130.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056	
31773	136.2 to 139.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112	
31774	147.4 to 149.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,188	
31775	149.2 to 150.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
59850	154.2 to 201.0 feet	Driveway				REF			
31776	159.9 to 164.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	23	SF	\$40	\$902	
31777	168.0 to 170.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	15	SF	\$40	\$594	
31778	174.3 to 210.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	200	SF	\$40	\$8,008	
59851	203.9 to 211.8 feet	Driveway				REF			
31784	223.3 to 226.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112	
31785	254.3 to 255.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
31786	261.2 to 262.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
31787	264.8 to 278.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	77	SF	\$120	\$9,240	
31789	283.3 to 288.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,366	
31791	295.0 to 297.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,584	
TOTAL COST FOR: NW							side of RIVERSIDE AVE	Starting at: 4TH ST	\$47,822.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	51909241400	RIVERSIDE AVE	5TH ST	6TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
31792	0.1 to 24.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	133	SF	\$120	\$15,972	
51168	2.7 to 3.7 feet	Vertical Change	-.3	6 ft	6	REF			
55495	3.0 to 7.9 feet	Vertical Change	.3	6 ft	27	REF			
134	6.0 to 7.0 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
51169	10.2 to 11.2 feet	Vertical Change	-.3	6 ft	6	REF			
31801	26.6 to 28.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,122	
31802	32.4 to 40.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	45	SF	\$120	\$5,346	
57577	41.2 to 42.2 feet	Vertical Change	2.7	6 ft	6	SF	\$75	\$413	
59852	45.3 to 66.6 feet	Driveway				REF			
31805	49.8 to 52.6 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	15	SF	\$40	\$616	
31807	52.6 to 60.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	42	SF	\$40	\$1,694	
31810	60.5 to 62.4 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	10	SF	\$40	\$418	
31811	62.7 to 64.8 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	12	SF	\$40	\$462	
40958	64.2 to 66.2 feet	Running Slope	6.0-7.0%	6 ft	11	REF			
31813	65.8 to 66.9 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	6	SF	\$40	\$242	
31814	68.2 to 77.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,138	
31816	83.1 to 85.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518	
31817	89.8 to 96.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224	
47752	92.8 to 93.8 feet	Vertical Change	-.4	6 ft	6	REF			
31819	100.7 to 101.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$792	
31820	105.8 to 111.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	33	SF	\$120	\$3,960	
55498	113.6 to 114.6 feet	Vertical Change	.3	6 ft	6	REF			
31823	114.1 to 116.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	15	SF	\$120	\$1,782	
31824	117.8 to 124.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,422	
31826	124.5 to 131.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	39	SF	\$120	\$4,620	
59853	130.6 to 141.4 feet	Driveway				REF			
40959	141.0 to 142.2 feet	Running Slope	5.0-6.0%	6 ft	7	REF			
31828	143.2 to 148.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	26	SF	\$120	\$3,168	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241400	RIVERSIDE AVE	5TH ST	6TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59854	145.4 to 161.8 feet	Driveway				REF		
55499	148.4 to 149.4 feet	Vertical Change	.3	6 ft	6	REF		
31830	155.0 to 159.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	24	SF	\$40	\$946
55500	160.7 to 161.7 feet	Vertical Change	.3	6 ft	6	REF		
31833	163.5 to 169.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	35	SF	\$120	\$4,158
51170	173.0 to 174.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
31834	177.8 to 194.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	94	SF	\$120	\$11,286
59855	193.5 to 205.3 feet	Driveway				REF		
31838	199.7 to 204.0 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	24	SF	\$40	\$946
40960	206.1 to 207.7 feet	Running Slope	5.0-6.0%	6 ft	9	SF	\$120	\$1,056
31839	210.8 to 216.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,432
56446	215.6 to 216.6 feet	Vertical Change	.4	6 ft	6	REF		
31842	231.5 to 234.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716
31843	249.4 to 258.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,072
31846	264.9 to 267.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	16	SF	\$120	\$1,914
31848	269.1 to 281.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	67	SF	\$120	\$8,052
31853	283.4 to 284.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$924
TOTAL COST FOR: NW side of RIVERSIDE AVE Starting at: 5TH ST							\$97,922.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241404	LAKE AVE	6TH ST	7TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
45397	0.1 to 1.1 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413
56824	0.4 to 1.4 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
59856	0.8 to 10.8 feet	Driveway				REF		
45398	12.6 to 13.6 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413
55501	31.8 to 32.8 feet	Vertical Change	.3	6 ft	5	LF	\$75	\$413
57586	40.9 to 41.9 feet	Vertical Change	2.8	6 ft	6	SF	\$75	\$413
55502	105.8 to 106.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
31854	118.4 to 131.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	74	SF	\$120	\$8,844
55503	124.8 to 125.8 feet	Vertical Change	.3	6 ft	6	REF		
59857	127.3 to 142.1 feet	Driveway				REF		
51171	134.3 to 135.3 feet	Vertical Change	-.3	6 ft	6	REF		
31856	134.3 to 140.8 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	36	SF	\$40	\$1,430
31858	140.8 to 143.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	15	SF	\$40	\$594
31859	145.8 to 159.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	74	SF	\$120	\$8,910
59858	152.1 to 156.1 feet	Driveway				REF		
31861	163.0 to 171.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	47	SF	\$120	\$5,676
55504	174.0 to 175.0 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
31864	177.8 to 180.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782
45399	177.9 to 178.9 feet	Vertical Change	-.5	6 ft	6	REF		
55505	195.9 to 196.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
59859	232.3 to 241.3 feet	Driveway				REF		
31865	240.5 to 241.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$220
51172	246.8 to 247.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
59860	249.7 to 263.3 feet	Driveway				REF		
31866	252.8 to 253.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$220
40961	294.3 to 295.3 feet	Running Slope	5.0-6.0%	6 ft	6	SF	\$120	\$660
TOTAL COST FOR: NW side of LAKE AVE Starting at: 6TH ST							\$32,048.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
NW	51909241406	LAKE AVE	7TH ST	8TH ST				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
31867	99.3 to 101.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452
59861	101.3 to 110.5 feet	Driveway				REF		
31868	104.8 to 127.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	127	SF	\$40	\$5,060
55506	112.4 to 113.4 feet	Vertical Change	.3	6 ft	6	REF		
31875	164.9 to 177.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	68	SF	\$120	\$8,184
59862	183.0 to 197.8 feet	Driveway				REF		
31878	202.1 to 208.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,356
59863	202.8 to 210.7 feet	Driveway				REF		
41568	213.4 to 214.4 feet	Vertical Change	-1	6 ft	6	SF	\$75	\$413
47753	220.9 to 221.9 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
135	249.3 to 250.3 feet	Continuous Width		6 ft	6	SF	\$120	\$660
56447	256.0 to 257.0 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
47754	257.7 to 258.7 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
56825	257.8 to 260.8 feet	Vertical Change	.5	6 ft	17	SF	\$75	\$1,238
31879	259.0 to 260.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
31880	263.2 to 264.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
55508	266.3 to 267.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
55509	269.4 to 270.4 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
57611	276.6 to 277.6 feet	Vertical Change	3	6 ft	6	SF	\$75	\$413
56826	281.8 to 288.0 feet	Vertical Change	.5	6 ft	34	SF	\$75	\$2,558
55512	291.0 to 292.0 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
55513	294.2 to 295.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
40962	294.8 to 296.2 feet	Running Slope	5.0-6.0%	6 ft	8	SF	\$120	\$924
TOTAL COST FOR: NW							<i>side of LAKE AVE Starting at: 7TH ST</i>	\$29,727.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241409	LAKE AVE	8TH ST	9TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
31881	60.0 to 68.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,544
59864	86.7 to 104.4 feet	Driveway				REF		
57363	89.8 to 90.8 feet	Vertical Change	1	6 ft	6	REF		
31886	92.8 to 99.4 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	36	SF	\$40	\$1,452
45400	101.8 to 103.0 feet	Vertical Change	-.5	6 ft	7	REF		
31889	110.3 to 112.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	13	SF	\$120	\$1,518
59865	110.8 to 128.5 feet	Driveway				REF		
31890	112.6 to 115.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	15	SF	\$40	\$594
55514	130.0 to 131.0 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
31892	133.0 to 141.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,742
55515	177.5 to 178.5 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
31894	182.0 to 192.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	57	SF	\$120	\$6,798
136	240.5 to 241.5 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
31895	248.4 to 255.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,422
31897	259.8 to 261.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
40963	299.0 to 301.4 feet	Running Slope	6.0-7.0%	6 ft	13	SF	\$120	\$1,584
TOTAL COST FOR: NW side of LAKE AVE Starting at: 8TH ST								\$29,502.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241411	LAKE AVE	9TH ST	10TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40965	0.0 to 3.9 feet	Running Slope	8.0-9.0%	6 ft	21	SF	\$120	\$2,574
40966	4.5 to 5.7 feet	Running Slope	6.0-7.0%	6 ft	7	SF	\$120	\$792
55516	9.8 to 10.8 feet	Vertical Change	.3	6 ft	5	LF	\$75	\$413
31898	11.0 to 23.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	69	SF	\$120	\$8,250
43526	23.7 to 24.7 feet	Vertical Change	-.6	6 ft	6	REF		
31902	23.8 to 30.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	36	SF	\$120	\$4,356
137	27.7 to 28.7 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
31905	31.2 to 38.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,016
31908	41.5 to 48.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,422
31911	48.2 to 55.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	37	SF	\$120	\$4,488
31915	56.6 to 61.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,432
31917	64.3 to 99.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	193	SF	\$120	\$23,166
56448	90.8 to 91.8 feet	Vertical Change	.4	6 ft	6	REF		
55517	129.6 to 130.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
59866	141.3 to 151.9 feet	Driveway				REF		
59867	181.9 to 191.8 feet	Driveway				REF		
59868	234.9 to 278.6 feet	Driveway				REF		
55518	259.8 to 260.8 feet	Vertical Change	.3	6 ft	6	REF		
31929	268.8 to 270.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	9	SF	\$40	\$374
31930	277.8 to 284.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	38	SF	\$40	\$1,518
40967	294.3 to 295.9 feet	Running Slope	5.0-6.0%	6 ft	9	SF	\$120	\$1,056
TOTAL COST FOR: NW side of LAKE AVE Starting at: 9TH ST							\$60,368.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241413	LAKE AVE	10TH ST	11TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40968	0.0 to 1.6 feet	Running Slope	6.0-7.0%	6 ft	9	SF	\$120	\$1,056
31933	22.6 to 35.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	73	SF	\$120	\$8,778
31938	39.4 to 40.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726
31939	42.9 to 45.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	12	SF	\$120	\$1,386
31940	48.1 to 49.2 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	6	SF	\$120	\$726
31941	50.5 to 51.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
59869	51.1 to 62.3 feet	Driveway				REF		
31942	61.4 to 65.2 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	21	SF	\$40	\$836
31945	65.2 to 71.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894
31948	71.4 to 74.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	15	SF	\$120	\$1,782
55519	71.7 to 72.7 feet	Vertical Change	.3	6 ft	6	REF		
31949	76.4 to 100.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	131	SF	\$120	\$15,708
31958	101.3 to 121.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	109	SF	\$120	\$13,068
31965	121.1 to 122.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
59870	122.8 to 138.3 feet	Driveway				REF		
59871	150.2 to 161.8 feet	Driveway				REF		
56449	151.8 to 152.8 feet	Vertical Change	.4	6 ft	6	REF		
31966	153.1 to 154.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	7	SF	\$40	\$264
31967	168.1 to 192.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	136	SF	\$120	\$16,368
59872	198.8 to 210.5 feet	Driveway				REF		
31973	218.5 to 224.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,158
55520	235.2 to 236.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
51173	236.8 to 237.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
56450	239.0 to 243.8 feet	Vertical Change	.4	6 ft	26	LF	\$75	\$1,980
57417	244.6 to 245.6 feet	Vertical Change	1.2	6 ft	6	SF	\$75	\$413
31976	246.7 to 248.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
51174	247.2 to 248.2 feet	Vertical Change	-.3	6 ft	6	REF		
59873	247.2 to 258.8 feet	Driveway				REF		
51175	251.5 to 252.5 feet	Vertical Change	-.3	6 ft	6	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241413	LAKE AVE	10TH ST	11TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55523	253.3 to 254.3 feet	Vertical Change	.3	6 ft	6	REF		
31977	253.4 to 256.5 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	17	SF	\$40	\$682
57205	261.8 to 262.8 feet	Vertical Change	.7	6 ft	6	SF	\$75	\$413
TOTAL COST FOR: NW side of LAKE AVE Starting at: 10TH ST							\$75,702.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241415	LAKE AVE	11TH ST	10TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40969	0.0 to 1.5 feet	Running Slope	6.0-7.0%	6 ft	8	SF	\$120	\$990
40970	1.5 to 2.6 feet	Running Slope	5.0-6.0%	6 ft	6	SF	\$120	\$726
56451	28.7 to 29.7 feet	Vertical Change	.4	6 ft	6	REF		
31978	29.0 to 36.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,752
59874	37.2 to 53.0 feet	Driveway				REF		
56452	38.1 to 39.1 feet	Vertical Change	.4	6 ft	6	REF		
31979	41.7 to 47.4 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	31	SF	\$40	\$1,254
31982	47.4 to 50.8 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	19	SF	\$40	\$748
31984	54.2 to 61.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	42	SF	\$120	\$5,082
59875	59.8 to 89.1 feet	Driveway				REF		
31987	68.8 to 87.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	102	SF	\$40	\$4,070
40971	89.8 to 92.2 feet	Running Slope	5.0-6.0%	6 ft	13	SF	\$120	\$1,584
31992	90.7 to 106.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	89	SF	\$120	\$10,626
31996	110.6 to 116.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894
31998	116.5 to 124.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	43	SF	\$120	\$5,148
32001	128.7 to 133.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	27	SF	\$120	\$3,234
32003	135.1 to 136.3 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	7	SF	\$120	\$792
32004	136.3 to 137.3 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	6	SF	\$120	\$660
59876	139.6 to 152.8 feet	Driveway				REF		
40972	140.7 to 141.8 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
42351	140.9 to 141.9 feet	Vertical Change	-.7	6 ft	6	REF		
47756	141.0 to 142.0 feet	Vertical Change	-.4	6 ft	6	REF		
32005	142.3 to 144.8 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	14	SF	\$40	\$550
45401	146.0 to 147.0 feet	Vertical Change	-.5	6 ft	6	REF		
32006	150.5 to 153.3 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	15	SF	\$40	\$616
47757	152.8 to 153.8 feet	Vertical Change	-.4	6 ft	6	REF		
32008	159.7 to 162.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	15	SF	\$120	\$1,848
55524	161.5 to 162.5 feet	Vertical Change	.3	6 ft	6	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241415	LAKE AVE	11TH ST	10TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32010	162.5 to 169.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,356
32014	208.9 to 210.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
32015	224.1 to 225.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
32016	230.1 to 231.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
32017	276.6 to 282.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
TOTAL COST FOR: SE side of LAKE AVE Starting at: 11TH ST							\$57,596.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241417	LAKE AVE	10TH ST	9TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59877	11.1 to 29.7 feet	Driveway				REF		
32018	11.2 to 13.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	11	SF	\$40	\$440
56453	24.1 to 25.1 feet	Vertical Change	.4	6 ft	6	REF		
57631	103.3 to 104.3 feet	Vertical Change	3.3	6 ft	6	SF	\$75	\$413
59878	103.8 to 114.1 feet	Driveway				REF		
138	146.4 to 147.4 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
56454	149.3 to 150.3 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
56827	158.1 to 159.1 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
32019	169.2 to 171.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,584
55525	182.7 to 183.7 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
32021	183.8 to 189.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,762
51176	190.2 to 191.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
59879	192.4 to 195.5 feet	Driveway				REF		
32023	194.3 to 195.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	8	SF	\$40	\$308
55526	199.1 to 200.1 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
59880	208.8 to 225.1 feet	Driveway				REF		
51177	227.8 to 228.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
57443	229.5 to 230.5 feet	Vertical Change	1.3	6 ft	6	SF	\$75	\$413
32024	232.5 to 244.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	68	SF	\$120	\$8,118
55527	237.5 to 238.5 feet	Vertical Change	.3	6 ft	6	REF		
32027	254.6 to 256.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
32028	264.2 to 265.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
57587	271.4 to 272.4 feet	Vertical Change	2.8	6 ft	6	SF	\$75	\$413
32029	282.1 to 284.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	15	SF	\$120	\$1,782
32030	286.1 to 287.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
56828	288.1 to 289.1 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
TOTAL COST FOR: SE side of LAKE AVE Starting at: 10TH ST							\$23,716.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	51909241420	LAKE AVE	9TH ST	8TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
32031	0.3 to 4.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,442	
59881	5.1 to 21.8 feet	Driveway				REF			
32032	17.0 to 19.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	14	SF	\$40	\$550	
32033	25.8 to 41.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	87	SF	\$120	\$10,494	
32038	41.7 to 43.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254	
32039	58.2 to 59.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
32040	63.0 to 78.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	83	SF	\$120	\$9,900	
56829	78.3 to 81.0 feet	Vertical Change	.5	6 ft	15	SF	\$75	\$1,114	
59882	79.3 to 106.1 feet	Driveway				REF			
32044	82.5 to 83.8 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	7	SF	\$40	\$286	
32045	85.2 to 87.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	14	SF	\$40	\$572	
56455	89.6 to 90.6 feet	Vertical Change	.4	6 ft	6	REF			
32046	98.6 to 103.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	28	SF	\$40	\$1,122	
55529	103.3 to 104.3 feet	Vertical Change	.3	6 ft	6	REF			
32048	109.2 to 112.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	17	SF	\$120	\$2,046	
32050	114.2 to 117.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112	
32051	123.8 to 137.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	76	SF	\$120	\$9,174	
55530	142.8 to 143.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
32055	147.8 to 164.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	93	SF	\$120	\$11,154	
55531	160.2 to 161.2 feet	Vertical Change	.3	6 ft	6	REF			
32059	167.2 to 172.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	28	SF	\$120	\$3,366	
56830	173.0 to 174.0 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413	
59883	175.2 to 188.1 feet	Driveway				REF			
32061	197.1 to 201.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	24	SF	\$120	\$2,838	
32064	203.1 to 204.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	9	SF	\$120	\$1,122	
32065	205.4 to 209.3 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	21	SF	\$120	\$2,574	
32066	209.3 to 210.7 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	8	SF	\$120	\$924	
59884	215.6 to 238.9 feet	Driveway				REF			
56831	241.5 to 242.5 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241420	LAKE AVE	9TH ST	8TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32067	242.7 to 244.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	12	SF	\$120	\$1,386
41689	243.2 to 244.2 feet	Vertical Change	-.9	6 ft	6	REF		
32068	251.3 to 253.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716
32069	256.5 to 257.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
57418	289.0 to 290.0 feet	Vertical Change	1.2	6 ft	6	SF	\$75	\$413
TOTAL COST FOR: SE side of LAKE AVE Starting at: 9TH ST							\$69,379.75	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241424	LAKE AVE	8TH ST	7TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59885	20.3 to 56.0 feet	Driveway				REF		
32070	50.9 to 52.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	8	SF	\$40	\$308
32071	55.1 to 58.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	19	SF	\$40	\$748
40973	57.5 to 58.7 feet	Running Slope	5.0-6.0%	6 ft	7	REF		
45402	80.6 to 81.9 feet	Vertical Change	-.5	6 ft	7	SF	\$75	\$536
32073	91.7 to 99.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,818
32076	108.8 to 110.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
32077	111.8 to 113.3 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	8	SF	\$120	\$990
59886	116.8 to 133.1 feet	Driveway				REF		
32078	139.6 to 145.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	31	SF	\$120	\$3,696
32081	145.2 to 148.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046
32083	173.0 to 174.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
59887	180.7 to 191.0 feet	Driveway				REF		
32084	186.0 to 189.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	19	SF	\$40	\$748
32086	202.7 to 209.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,554
32089	248.6 to 250.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
56832	249.4 to 250.4 feet	Vertical Change	.5	6 ft	6	REF		
32090	254.5 to 258.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640
TOTAL COST FOR: SE side of LAKE AVE Starting at: 8TH ST							\$23,724.25	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241426	LAKE AVE	7TH ST	6TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40974	0.3 to 2.0 feet	Running Slope	5.0-6.0%	6 ft	9	SF	\$120	\$1,122
56456	9.1 to 10.1 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
55532	16.3 to 17.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
56833	20.1 to 21.1 feet	Vertical Change	.5	6 ft	5	SF	\$75	\$413
55533	29.8 to 30.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
51178	43.3 to 44.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
55534	46.1 to 47.1 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
56457	50.2 to 51.2 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
56834	71.8 to 72.8 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
57444	73.9 to 74.9 feet	Vertical Change	1.3	6 ft	6	SF	\$75	\$413
59888	76.1 to 86.2 feet	Driveway				REF		
32092	82.5 to 84.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	10	SF	\$40	\$396
32093	91.4 to 93.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,254
32094	93.8 to 107.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	73	SF	\$120	\$8,712
32098	119.0 to 125.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,092
59889	126.0 to 136.6 feet	Driveway				REF		
32101	129.2 to 138.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	53	SF	\$40	\$2,112
32103	184.9 to 186.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
59890	194.1 to 208.6 feet	Driveway				REF		
55535	195.1 to 196.1 feet	Vertical Change	.3	6 ft	6	REF		
32104	205.1 to 208.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	20	SF	\$40	\$814
32106	212.6 to 225.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	70	SF	\$120	\$8,448
55536	250.1 to 251.1 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
55537	259.8 to 260.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: SE side of LAKE AVE Starting at: 7TH ST							\$32,345.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241431	RIVERSIDE AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32109	0.0 to 5.0 feet	Cross Slope (PAR)	11.0-12.0%	6 ft	28	SF	\$120	\$3,300
32112	12.6 to 15.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782
59892	14.2 to 35.7 feet	Driveway				REF		
55538	15.3 to 16.3 feet	Vertical Change	.3	6 ft	6	REF		
32114	19.4 to 33.4 feet	Cross Slope (Driveway)	>15%	6 ft	77	SF	\$40	\$3,080
51179	35.8 to 36.8 feet	Vertical Change	-.3	6 ft	6	REF		
32118	38.9 to 47.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	46	SF	\$120	\$5,544
32121	52.8 to 57.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	28	SF	\$120	\$3,366
51180	56.8 to 57.8 feet	Vertical Change	-.3	6 ft	6	REF		
32122	57.9 to 63.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894
59893	63.4 to 79.1 feet	Driveway				REF		
40976	63.8 to 66.3 feet	Running Slope	6.0-7.0%	6 ft	14	REF		
55539	65.5 to 66.5 feet	Vertical Change	.3	6 ft	6	REF		
32124	68.7 to 80.1 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	63	SF	\$40	\$2,508
TOTAL COST FOR: NW side of RIVERSIDE AVE Starting at: SIDEWALK BEGINS							\$23,474.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241433	RIVERSIDE AVE	SIDEWALK BEGINS	7TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59895	23.2 to 37.0 feet	Driveway				REF		
32133	28.0 to 37.8 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	54	SF	\$40	\$2,156
57364	30.8 to 31.8 feet	Vertical Change	1	6 ft	6	REF		
40978	37.9 to 39.5 feet	Running Slope	7.0-8.0%	6 ft	9	SF	\$120	\$1,056
32136	54.0 to 58.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
32137	62.5 to 65.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$1,980
32138	67.7 to 75.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,016
51181	89.9 to 92.9 feet	Vertical Change	-3	6 ft	17	REF		
32140	90.8 to 92.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
TOTAL COST FOR: NW side of RIVERSIDE AVE Starting at: SIDEWALK BEGINS							\$14,234.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241434	RIVERSIDE AVE	7TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51183	0.1 to 1.1 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
59896	12.3 to 20.3 feet	Driveway				REF		
56458	26.2 to 27.2 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
57390	30.3 to 31.3 feet	Vertical Change	1.1	6 ft	6	SF	\$75	\$413
32141	35.3 to 44.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$5,940
56459	37.8 to 40.5 feet	Vertical Change	.4	6 ft	15	REF		
32143	48.9 to 87.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	210	SF	\$120	\$25,212
59897	57.8 to 69.5 feet	Driveway				REF		
57082	92.7 to 93.7 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413
59898	104.0 to 116.4 feet	Driveway				REF		
40979	116.5 to 118.1 feet	Running Slope	5.0-6.0%	6 ft	9	REF		
TOTAL COST FOR: NW side of RIVERSIDE AVE Starting at: 7TH ST							\$32,802.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	51909241438	RIVERSIDE AVE	8TH ST	9TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
55540	8.8 to 9.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
32155	12.8 to 20.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,818	
51184	21.5 to 22.5 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
32157	30.5 to 33.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112	
55541	33.5 to 34.5 feet	Vertical Change	.3	6 ft	6	REF			
32158	47.3 to 61.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	76	SF	\$120	\$9,108	
51185	71.3 to 72.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
32160	72.4 to 78.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,026	
32163	93.3 to 94.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858	
51186	96.2 to 97.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
56461	98.2 to 99.2 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
57206	101.5 to 102.5 feet	Vertical Change	.7	6 ft	6	SF	\$75	\$413	
32164	102.9 to 104.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
56836	107.7 to 108.7 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413	
55542	129.3 to 130.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
59899	132.8 to 143.1 feet	Driveway				REF			
56462	132.9 to 133.9 feet	Vertical Change	.4	6 ft	6	REF			
32165	134.5 to 136.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	12	SF	\$40	\$484	
56463	141.9 to 142.9 feet	Vertical Change	.4	6 ft	6	REF			
32166	148.0 to 149.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
32167	152.8 to 161.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,610	
32171	166.4 to 172.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	35	SF	\$120	\$4,224	
32174	172.8 to 183.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	57	SF	\$120	\$6,864	
59900	179.4 to 192.9 feet	Driveway				REF			
32179	183.2 to 185.8 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	14	SF	\$40	\$572	
32180	188.3 to 189.8 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	8	SF	\$40	\$330	
32181	190.3 to 196.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	34	SF	\$40	\$1,364	
32183	202.9 to 226.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	130	SF	\$120	\$15,642	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241438	RIVERSIDE AVE	8TH ST	9TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32190	239.9 to 241.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
32191	243.1 to 245.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518
32192	255.4 to 271.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	86	SF	\$120	\$10,362
51187	256.4 to 257.4 feet	Vertical Change	-3	6 ft	6	REF		
32195	289.8 to 294.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904
TOTAL COST FOR: NW side of RIVERSIDE AVE Starting at: 8TH ST							\$76,406.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241440	RIVERSIDE AVE	SIDEWALK BEGINS	10TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32196	0.0 to 2.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518
59901	17.5 to 40.7 feet	Driveway				REF		
32197	23.5 to 28.4 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	27	SF	\$40	\$1,078
32200	30.1 to 38.5 feet	Cross Slope (Driveway)	13.014	6 ft	46	SF	\$40	\$1,848
32204	38.5 to 39.8 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	7	SF	\$40	\$286
45403	41.8 to 42.8 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413
32205	43.3 to 45.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650
TOTAL COST FOR: NW side of RIVERSIDE AVE Starting at: SIDEWALK BEGINS								\$6,792.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241441	RIVERSIDE AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32206	0.0 to 17.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	96	SF	\$120	\$11,484
32212	17.7 to 19.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	10	SF	\$120	\$1,254
59902	18.8 to 33.2 feet	Driveway				REF		
32213	22.1 to 23.3 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	7	SF	\$40	\$264
32214	23.7 to 24.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	6	SF	\$40	\$242
32215	26.5 to 33.9 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	41	SF	\$40	\$1,628
TOTAL COST FOR: NW side of RIVERSIDE AVE Starting at: SIDEWALK BEGINS							\$14,872.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	51909241445	RIVERSIDE AVE	11TH ST	13TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
51188	5.0 to 6.0 feet	Vertical Change	-.3	6 ft	6	REF			
32218	5.6 to 7.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990	
55543	12.7 to 13.7 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
32219	16.2 to 78.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	342	SF	\$120	\$40,986	
56464	21.5 to 22.5 feet	Vertical Change	.4	6 ft	6	REF			
55544	36.6 to 37.6 feet	Vertical Change	.3	6 ft	6	REF			
32235	81.1 to 100.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	108	SF	\$120	\$12,936	
55545	91.7 to 92.7 feet	Vertical Change	.3	6 ft	6	REF			
32239	102.8 to 152.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	271	SF	\$120	\$32,472	
32250	152.0 to 158.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	33	SF	\$120	\$3,960	
32252	158.0 to 164.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,488	
32254	165.9 to 174.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	45	SF	\$120	\$5,412	
32257	176.5 to 190.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	78	SF	\$120	\$9,372	
32260	194.3 to 206.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	67	SF	\$120	\$8,052	
32263	206.5 to 214.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346	
32266	221.6 to 225.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	22	SF	\$120	\$2,640	
32269	227.5 to 249.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	122	SF	\$120	\$14,652	
32275	250.5 to 260.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	55	SF	\$120	\$6,600	
32278	266.8 to 272.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	30	SF	\$120	\$3,630	
32280	272.6 to 279.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,290	
32282	279.1 to 287.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	43	SF	\$120	\$5,214	
32284	288.5 to 291.8 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	18	SF	\$120	\$2,178	
32286	293.4 to 299.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	32	SF	\$120	\$3,828	
32289	303.1 to 318.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	82	SF	\$120	\$9,834	
32295	322.8 to 327.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,300	
32296	330.6 to 338.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	45	SF	\$120	\$5,412	
32298	338.8 to 371.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	182	SF	\$120	\$21,780	
32309	371.8 to 374.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	14	SF	\$120	\$1,650	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241445	RIVERSIDE AVE	11TH ST	13TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32310	376.0 to 397.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	116	SF	\$120	\$13,926
32316	400.8 to 424.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	132	SF	\$120	\$15,840
32321	426.2 to 434.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	44	SF	\$120	\$5,280
32324	434.2 to 438.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
32326	440.8 to 444.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	21	SF	\$120	\$2,508
32328	445.0 to 450.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,828
32330	453.8 to 471.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	97	SF	\$120	\$11,616
32334	471.4 to 477.2 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	32	SF	\$120	\$3,828
59903	477.0 to 509.8 feet	Driveway				REF		
32336	477.2 to 478.7 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	8	SF	\$40	\$330
32337	482.5 to 484.3 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	10	SF	\$40	\$396
32338	512.8 to 529.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	91	SF	\$120	\$10,956
32344	530.6 to 535.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
32345	543.8 to 572.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	157	SF	\$120	\$18,876
59904	576.3 to 602.9 feet	Driveway				REF		
32353	581.3 to 594.1 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	70	SF	\$40	\$2,816
32358	594.1 to 603.8 feet	Cross Slope (Driveway)	13.014	6 ft	53	SF	\$40	\$2,134
32361	606.8 to 614.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	44	SF	\$120	\$5,280
32363	618.1 to 624.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	35	SF	\$120	\$4,224
40980	622.5 to 623.8 feet	Running Slope	6.0-7.0%	6 ft	7	REF		

TOTAL COST FOR: NW	<i>side of RIVERSIDE AVE Starting at: 11TH ST</i>	\$316,882.50
---------------------------	---	---------------------

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241447	RIVERSIDE AVE	13TH ST	14TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32365	0.0 to 1.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$792
32366	3.4 to 6.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	15	SF	\$120	\$1,848
32368	7.9 to 53.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	253	SF	\$120	\$30,360
32377	56.7 to 62.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630
32378	67.2 to 74.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	41	SF	\$120	\$4,884
32379	91.1 to 94.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178
32380	101.7 to 119.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	98	SF	\$120	\$11,814
32386	119.6 to 125.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	35	SF	\$120	\$4,158
32389	125.9 to 127.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
59905	129.1 to 151.3 feet	Driveway				REF		
32390	132.4 to 133.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$242
32391	136.2 to 139.7 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	19	SF	\$40	\$770
32393	141.1 to 142.1 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	6	SF	\$40	\$220
32394	142.3 to 145.2 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	16	SF	\$40	\$638
32395	146.4 to 151.8 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	30	SF	\$40	\$1,188
32398	153.4 to 154.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
32399	165.1 to 178.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	74	SF	\$120	\$8,910
32402	184.8 to 204.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	108	SF	\$120	\$13,002
32408	206.8 to 224.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	99	SF	\$120	\$11,880
55546	207.6 to 208.6 feet	Vertical Change	.3	6 ft	6	REF		
32411	231.4 to 250.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	106	SF	\$120	\$12,672
32415	258.5 to 262.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904
32416	275.1 to 277.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452
51189	277.6 to 278.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: NW side of RIVERSIDE AVE Starting at: 13TH ST							\$115,802.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	51909241450	RIVERSIDE AVE	14TH ST	15TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
59906	0.0 to 12.5 feet	Driveway				REF			
32417	0.8 to 1.8 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	6	SF	\$40	\$220	
32418	4.3 to 10.9 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	36	SF	\$40	\$1,452	
32420	10.9 to 12.5 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	9	SF	\$40	\$352	
40981	13.1 to 14.9 feet	Running Slope	6.0-7.0%	6 ft	10	SF	\$120	\$1,188	
55547	15.9 to 16.9 feet	Vertical Change	.3	6 ft	5	REF			
32421	16.6 to 33.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	95	SF	\$120	\$11,352	
32424	37.7 to 43.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894	
59907	43.3 to 58.0 feet	Driveway				REF			
32426	48.0 to 55.8 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	43	SF	\$40	\$1,716	
40982	56.8 to 57.9 feet	Running Slope	5.0-6.0%	6 ft	6	REF			
32429	59.3 to 95.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	198	SF	\$120	\$23,760	
55548	61.1 to 62.1 feet	Vertical Change	.3	6 ft	6	REF			
32437	95.3 to 109.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	79	SF	\$120	\$9,504	
32440	113.3 to 129.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	89	SF	\$120	\$10,626	
59908	129.3 to 158.0 feet	Driveway				REF			
32444	135.8 to 142.3 feet	Cross Slope (Driveway)	>15%	6 ft	36	SF	\$40	\$1,430	
32446	143.8 to 156.7 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	71	SF	\$40	\$2,838	
32450	160.1 to 169.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$5,940	
32452	171.2 to 172.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726	
32453	174.9 to 176.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,254	
32454	177.3 to 191.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	75	SF	\$120	\$9,042	
32457	193.7 to 196.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914	
57569	194.9 to 195.9 feet	Vertical Change	2.6	6 ft	6	REF			
32458	200.1 to 210.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	55	SF	\$120	\$6,600	
55549	210.2 to 211.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
32461	216.3 to 251.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	192	SF	\$120	\$23,034	
59909	253.0 to 272.4 feet	Driveway				REF			
55550	254.0 to 255.0 feet	Vertical Change	.3	6 ft	6	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241450	RIVERSIDE AVE	14TH ST	15TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32468	256.8 to 270.8 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	77	SF	\$40	\$3,080
55551	271.9 to 272.9 feet	Vertical Change	.3	6 ft	6	REF		
32472	277.3 to 280.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	19	SF	\$120	\$2,244
TOTAL COST FOR: NW side of RIVERSIDE AVE Starting at: 14TH ST							\$122,578.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241451	RIVERSIDE AVE	15TH ST	14TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32473	0.0 to 24.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	136	SF	\$120	\$16,302
32476	27.3 to 28.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
32477	32.1 to 46.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	77	SF	\$120	\$9,240
32482	48.8 to 56.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,016
32485	56.4 to 80.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	132	SF	\$120	\$15,840
59910	80.3 to 101.8 feet	Driveway				REF		
57271	80.6 to 81.6 feet	Vertical Change	.8	6 ft	6	REF		
32490	85.3 to 88.5 feet	Cross Slope (Driveway)	13.014	6 ft	18	SF	\$40	\$704
32492	88.5 to 102.5 feet	Cross Slope (Driveway)	>15%	6 ft	77	SF	\$40	\$3,080
32493	107.0 to 109.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	13	SF	\$120	\$1,584
TOTAL COST FOR: SE side of RIVERSIDE AVE Starting at: 15TH ST							\$52,624.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241453	RIVERSIDE AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59911	23.7 to 42.1 feet	Driveway				REF		
32495	29.1 to 34.1 feet	Cross Slope (Driveway)	13.014	6 ft	28	SF	\$40	\$1,100
32497	39.0 to 41.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	15	SF	\$40	\$616
32498	45.6 to 46.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	7	SF	\$120	\$792
59912	45.8 to 56.8 feet	Driveway				REF		
56465	46.4 to 47.4 feet	Vertical Change	.4	6 ft	6	REF		
32499	49.8 to 51.3 feet	Cross Slope (Driveway)	13.014	6 ft	8	SF	\$40	\$330
32500	53.9 to 57.6 feet	Cross Slope (Driveway)	>15%	6 ft	20	SF	\$40	\$814
TOTAL COST FOR: SE side of RIVERSIDE AVE Starting at: SIDEWALK BEGINS								\$3,652.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
SE	51909241456	RIVERSIDE AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
40983	0.0 to 1.2 feet	Running Slope	6.0-7.0%	6 ft	7	SF	\$120	\$792			
40984	1.2 to 2.5 feet	Running Slope	5.0-6.0%	6 ft	7	SF	\$120	\$858			
32501	4.1 to 10.5 feet	Cross Slope (PAR)	>15%	6 ft	35	SF	\$120	\$4,224			
59913	6.6 to 23.7 feet	Driveway				REF					
32504	11.1 to 13.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	15	SF	\$40	\$594			
32506	15.3 to 21.0 feet	Cross Slope (Driveway)	>15%	6 ft	31	SF	\$40	\$1,254			
40985	21.8 to 22.8 feet	Running Slope	5.0-6.0%	6 ft	6	REF					
40986	22.8 to 25.8 feet	Running Slope	6.0-7.0%	6 ft	17	REF					
51190	25.2 to 26.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413			
40988	25.8 to 26.8 feet	Running Slope	5.0-6.0%	6 ft	6	SF	\$120	\$660			
51191	30.3 to 31.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413			
59914	46.7 to 57.8 feet	Driveway				REF					
32507	47.2 to 48.2 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	6	SF	\$40	\$220			
32508	53.2 to 57.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	25	SF	\$40	\$1,012			
TOTAL COST FOR: SE							<i>side of</i>	RIVERSIDE AVE	<i>Starting at:</i>	SIDEWALK BEGINS	\$10,439.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241458	RIVERSIDE AVE	SIDEWALK BEGINS	10TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32511	23.5 to 28.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168
59916	38.9 to 61.9 feet	Driveway				REF		
32513	48.8 to 49.9 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	6	SF	\$40	\$242
32514	52.5 to 53.6 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	6	SF	\$40	\$242
32515	60.8 to 62.0 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	7	SF	\$40	\$264
56466	61.8 to 62.8 feet	Vertical Change	.4	6 ft	6	REF		
32516	64.3 to 66.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	14	SF	\$120	\$1,650
59917	79.5 to 97.0 feet	Driveway				REF		
32517	105.3 to 106.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
51192	107.6 to 108.6 feet	Vertical Change	-.3	6 ft	6	REF		
32518	108.6 to 111.9 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	18	SF	\$120	\$2,178
32520	115.0 to 117.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914
57632	118.6 to 119.6 feet	Vertical Change	3.3	6 ft	6	SF	\$75	\$413
32522	124.9 to 126.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
32523	134.2 to 144.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	55	SF	\$120	\$6,600
47759	137.8 to 138.8 feet	Vertical Change	-.4	6 ft	6	REF		
57083	154.8 to 155.8 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413
32527	157.0 to 158.0 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	6	SF	\$120	\$660
55552	159.6 to 160.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
51193	171.6 to 172.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: SE side of RIVERSIDE AVE Starting at: SIDEWALK BEGINS							\$20,218.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241503	RIVERSIDE AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32529	8.8 to 15.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,620
56837	18.7 to 19.7 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
32531	22.9 to 26.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178
32532	29.2 to 32.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046
TOTAL COST FOR: SE side of RIVERSIDE AVE Starting at: SIDEWALK BEGINS								\$9,256.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241505	RIVERSIDE AVE	8TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32536	9.8 to 11.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$990
32537	11.3 to 12.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
51194	29.8 to 30.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
59919	59.5 to 69.3 feet	Driveway				REF		
56467	98.6 to 99.6 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
32538	108.3 to 109.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
51195	128.7 to 129.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
59920	140.6 to 153.7 feet	Driveway				REF		
51196	144.0 to 145.0 feet	Vertical Change	-.3	6 ft	6	REF		
32539	149.3 to 154.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	26	SF	\$40	\$1,034
55553	155.6 to 156.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
32541	163.8 to 165.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
59921	185.8 to 200.6 feet	Driveway				REF		
32542	190.1 to 197.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	41	SF	\$40	\$1,650
TOTAL COST FOR: SE side of RIVERSIDE AVE Starting at: 8TH ST								\$7,700.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241507	RIVERSIDE AVE	SIDEWALK BEGINS	7TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32545	0.0 to 1.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	10	SF	\$120	\$1,200
59922	0.8 to 17.7 feet	Driveway				REF		
55554	22.8 to 23.8 feet	Vertical Change	.3	10 ft	10	LF	\$75	\$750
32546	28.8 to 31.9 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	31	SF	\$120	\$3,720
TOTAL COST FOR: SE side of RIVERSIDE AVE Starting at: SIDEWALK BEGINS								\$5,670.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241508	RIVERSIDE AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32548	12.7 to 18.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,696
57485	15.1 to 16.1 feet	Vertical Change	1.6	6 ft	6	REF		
32549	22.3 to 23.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
32550	28.4 to 36.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,478
32552	44.8 to 76.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	173	SF	\$120	\$20,790
59923	76.1 to 90.7 feet	Driveway				REF		
55555	76.5 to 77.5 feet	Vertical Change	.3	6 ft	6	REF		
32559	80.5 to 88.1 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	42	SF	\$40	\$1,672
32561	91.3 to 114.9 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	130	SF	\$40	\$5,192
59924	114.2 to 132.1 feet	Driveway				REF		
32567	119.9 to 121.8 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	10	SF	\$40	\$418
56468	124.4 to 125.4 feet	Vertical Change	.4	6 ft	6	REF		
32568	125.8 to 129.8 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	22	SF	\$40	\$880
32570	129.8 to 134.1 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	24	SF	\$40	\$946
40990	134.7 to 136.0 feet	Running Slope	7.0-8.0%	6 ft	7	REF		
32572	136.0 to 140.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
59925	142.7 to 162.1 feet	Driveway				REF		
32574	146.8 to 155.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	50	SF	\$40	\$1,980
32576	157.3 to 160.9 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	20	SF	\$40	\$792
40991	161.8 to 162.9 feet	Running Slope	6.0-7.0%	6 ft	6	REF		
32578	164.5 to 188.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	134	SF	\$120	\$16,038
56469	187.4 to 188.4 feet	Vertical Change	.4	6 ft	6	REF		
TOTAL COST FOR: SE side of RIVERSIDE AVE Starting at: SIDEWALK BEGINS							\$61,314.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241509	RIVERSIDE AVE	SIDEWALK BEGINS	6TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51197	14.3 to 15.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
32586	24.4 to 26.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,254
45404	26.1 to 27.3 feet	Vertical Change	-.5	6 ft	7	REF		
32587	27.1 to 28.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
TOTAL COST FOR: SE side of RIVERSIDE AVE Starting at: SIDEWALK BEGINS							\$2,458.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	51909241512	RIVERSIDE AVE	6TH ST	5TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
32588	1.0 to 3.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518	
32589	5.8 to 6.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
55557	12.3 to 13.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
55558	28.6 to 29.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
32590	50.0 to 93.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	240	SF	\$120	\$28,842	
45405	81.6 to 82.6 feet	Vertical Change	-.5	6 ft	6	REF			
57084	92.3 to 93.3 feet	Vertical Change	.6	6 ft	6	REF			
55559	93.9 to 94.9 feet	Vertical Change	.3	6 ft	6	REF			
32599	94.5 to 97.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	16	SF	\$120	\$1,914	
59927	96.3 to 105.4 feet	Driveway				REF			
32600	108.2 to 109.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122	
56471	111.2 to 112.2 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
55560	118.3 to 119.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
32601	122.5 to 129.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,488	
59928	146.4 to 159.8 feet	Driveway				REF			
59929	175.2 to 187.8 feet	Driveway				REF			
32604	192.7 to 195.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848	
32606	197.8 to 207.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,402	
59930	199.4 to 235.3 feet	Driveway				REF			
55561	201.4 to 202.4 feet	Vertical Change	.3	6 ft	6	REF			
32608	216.7 to 222.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	30	SF	\$40	\$1,210	
51199	224.3 to 225.3 feet	Vertical Change	-.3	6 ft	6	REF			
32609	227.5 to 234.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	41	SF	\$40	\$1,628	
55562	227.8 to 228.8 feet	Vertical Change	.3	6 ft	6	REF			
41569	236.3 to 237.3 feet	Vertical Change	-1	6 ft	6	SF	\$75	\$413	
32611	239.7 to 243.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	23	SF	\$120	\$2,772	
32613	244.3 to 250.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,356	
41317	247.4 to 248.4 feet	Vertical Change	-1.5	6 ft	6	REF			
43527	259.2 to 260.2 feet	Vertical Change	-.6	6 ft	6	SF	\$75	\$413	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
SE	51909241512	RIVERSIDE AVE	6TH ST	5TH ST	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
56838	262.8 to 263.8 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413			
32616	266.7 to 272.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	31	SF	\$120	\$3,696			
32619	272.3 to 275.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914			
32621	282.7 to 285.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914			
TOTAL COST FOR: SE							<i>side of</i>	RIVERSIDE AVE	<i>Starting at:</i>	6TH ST	\$67,171.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	51909241514	RIVERSIDE AVE	5TH ST	4TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
41879	20.4 to 21.4 feet	Vertical Change	-.8	6 ft	6	SF	\$75	\$413	
32623	34.3 to 39.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,300	
59931	43.9 to 54.3 feet	Driveway				REF			
45406	45.5 to 46.5 feet	Vertical Change	-.5	6 ft	6	REF			
32625	45.5 to 48.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	18	SF	\$40	\$726	
32627	57.2 to 58.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
32628	94.8 to 108.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	77	SF	\$120	\$9,240	
59932	129.7 to 141.8 feet	Driveway				REF			
51200	145.7 to 146.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
32630	201.3 to 202.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
59933	229.7 to 246.0 feet	Driveway				REF			
32631	264.3 to 271.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,554	
59934	273.4 to 283.7 feet	Driveway				REF			
32634	275.3 to 277.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	11	SF	\$40	\$440	
32635	292.2 to 295.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178	
TOTAL COST FOR: SE							side of RIVERSIDE AVE Starting at: 5TH ST	\$22,649.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241517	RIVERSIDE AVE	4TH ST	3RD ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40993	0.1 to 1.5 feet	Running Slope	5.0-6.0%	6 ft	8	SF	\$120	\$924
56839	12.5 to 13.5 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
32637	56.8 to 57.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
59935	77.8 to 96.7 feet	Driveway				REF		
57365	101.6 to 102.6 feet	Vertical Change	1	6 ft	6	SF	\$75	\$413
32638	106.6 to 112.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,026
47760	110.1 to 111.1 feet	Vertical Change	-.4	6 ft	6	REF		
55563	142.8 to 143.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
59936	153.5 to 163.8 feet	Driveway				REF		
32640	171.8 to 192.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	112	SF	\$120	\$13,398
32645	193.8 to 198.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	23	SF	\$120	\$2,772
47761	198.3 to 199.3 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
57207	223.4 to 224.4 feet	Vertical Change	.7	6 ft	6	SF	\$75	\$413
47762	237.7 to 238.7 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
32646	239.9 to 245.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
32648	247.5 to 250.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244
55564	248.5 to 249.5 feet	Vertical Change	.3	6 ft	6	REF		
51201	265.4 to 266.4 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
32649	294.3 to 295.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
TOTAL COST FOR: SE side of RIVERSIDE AVE Starting at: 4TH ST							\$31,135.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241518	RIVERSIDE AVE	3RD ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
47763	2.8 to 6.3 feet	Vertical Change	-.4	6 ft	19	LF	\$75	\$1,444
32650	9.1 to 13.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	23	SF	\$120	\$2,772
32651	14.0 to 36.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	124	SF	\$120	\$14,850
55565	15.3 to 16.3 feet	Vertical Change	.3	6 ft	6	REF		
45407	35.4 to 36.4 feet	Vertical Change	-.5	6 ft	6	REF		
32659	38.8 to 42.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	18	SF	\$120	\$2,178
32660	42.1 to 43.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
51203	42.5 to 43.5 feet	Vertical Change	-.3	6 ft	6	REF		
TOTAL COST FOR: SE <i>side of RIVERSIDE AVE Starting at: 3RD ST</i>							\$22,035.75	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
SE	51909241520	RIVERSIDE AVE	SIDEWALK BEGINS	2ND ST	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
32661	0.0 to 1.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	7	SF	\$120	\$858			
32662	3.3 to 69.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	361	SF	\$120	\$43,362			
57540	48.8 to 49.8 feet	Vertical Change	2.1	6 ft	6	REF					
TOTAL COST FOR: SE							<i>side of</i>	RIVERSIDE AVE	<i>Starting at:</i>	SIDEWALK BEGINS	\$44,220.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241522	RIVERSIDE AVE	2ND ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32680	8.8 to 11.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,584
32682	15.3 to 21.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,290
59937	21.2 to 41.1 feet	Driveway				REF		
32683	28.7 to 39.4 feet	Cross Slope (Driveway)	>15%	6 ft	59	SF	\$40	\$2,354
40994	39.5 to 41.3 feet	Running Slope	5.0-6.0%	6 ft	10	REF		
56472	44.2 to 45.2 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
32686	47.1 to 53.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224
32687	57.5 to 90.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	179	SF	\$120	\$21,450
TOTAL COST FOR: SE side of RIVERSIDE AVE Starting at: 2ND ST							\$34,314.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	51909241524	RIVERSIDE AVE	SIDEWALK BEGINS	KINGS AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
32694	0.0 to 3.3 feet	Cross Slope (PAR)	12.0-13.0%	6 ft	18	SF	\$120	\$2,178	
32698	15.3 to 16.3 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	6	SF	\$120	\$660	
40995	17.1 to 19.9 feet	Running Slope	5.0-6.0%	6 ft	15	SF	\$120	\$1,848	
32699	19.4 to 22.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	16	SF	\$120	\$1,914	
32700	25.1 to 30.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	31	SF	\$120	\$3,762	
32701	31.7 to 38.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224	
32703	44.4 to 50.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224	
32705	54.4 to 73.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	105	SF	\$120	\$12,606	
51206	65.8 to 66.8 feet	Vertical Change	-.3	6 ft	6	REF			
32710	74.8 to 79.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	25	SF	\$120	\$2,970	
51207	80.5 to 81.5 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
32711	84.0 to 89.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	29	SF	\$120	\$3,432	
32713	92.4 to 101.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	52	SF	\$120	\$6,270	
32715	101.9 to 108.6 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	37	SF	\$120	\$4,422	
32717	109.6 to 127.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	99	SF	\$120	\$11,880	
51208	124.7 to 125.7 feet	Vertical Change	-.3	6 ft	6	REF			
32722	130.1 to 139.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	51	SF	\$120	\$6,138	
32725	141.9 to 154.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	70	SF	\$120	\$8,382	
TOTAL COST FOR: SW							<i>side of RIVERSIDE AVE Starting at: SIDEWALK BEGINS</i>	\$75,322.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909241529	KINGS AVE	1ST ST	FRONT ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32727	0.0 to 2.6 feet	Cross Slope (PAR)	2.0-3.0%	15 ft	39	SF	\$120	\$4,680
40997	0.0 to 1.3 feet	Running Slope	5.0-6.0%	15 ft	20	REF		
32728	13.8 to 14.9 feet	Cross Slope (PAR)	2.0-3.0%	15 ft	17	SF	\$120	\$1,980
59939	25.3 to 58.4 feet	Driveway				REF		
32729	61.3 to 62.3 feet	Cross Slope (PAR)	2.0-3.0%	15 ft	15	SF	\$120	\$1,800
32730	68.9 to 70.3 feet	Cross Slope (PAR)	2.0-3.0%	15 ft	21	SF	\$120	\$2,520
32731	79.6 to 81.3 feet	Cross Slope (PAR)	2.0-3.0%	15 ft	26	SF	\$120	\$3,060
32732	92.8 to 101.3 feet	Cross Slope (PAR)	2.0-3.0%	15 ft	128	SF	\$120	\$15,300
32735	118.2 to 124.2 feet	Cross Slope (PAR)	2.0-3.0%	15 ft	90	SF	\$120	\$10,800
59940	134.8 to 164.3 feet	Driveway				REF		
139	167.3 to 168.3 feet	Protruding Object		15 ft	15	JOB	\$99	\$99
55566	180.8 to 181.8 feet	Vertical Change	.3	15 ft	15	LF	\$75	\$1,125
59941	187.8 to 213.5 feet	Driveway				REF		
32737	194.0 to 195.4 feet	Cross Slope (Driveway)	5.0-6.0%	15 ft	21	SF	\$40	\$840
32738	195.4 to 205.3 feet	Cross Slope (Driveway)	6.0-7.0%	15 ft	149	SF	\$40	\$5,940
32741	205.3 to 214.3 feet	Cross Slope (Driveway)	5.0-6.0%	15 ft	135	SF	\$40	\$5,400
32743	217.3 to 224.0 feet	Cross Slope (PAR)	2.0-3.0%	15 ft	101	SF	\$120	\$12,060
32747	247.1 to 252.4 feet	Cross Slope (PAR)	2.0-3.0%	15 ft	80	SF	\$120	\$9,540
32748	277.6 to 284.6 feet	Cross Slope (PAR)	2.0-3.0%	15 ft	105	SF	\$120	\$12,600
32749	293.0 to 298.5 feet	Cross Slope (PAR)	2.0-3.0%	15 ft	83	SF	\$120	\$9,900
41388	296.8 to 297.8 feet	Vertical Change	-1.3	15 ft	15	REF		
40998	296.8 to 297.9 feet	Running Slope	6.0-7.0%	15 ft	16	REF		
TOTAL COST FOR: SE side of KINGS AVE Starting at: 1ST ST							\$97,644.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
N	51909241543	ROBERTSON BLVD	SIDEWALK BEGINS	SIDEWALK ENDS				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
40999	0.8 to 1.8 feet	Running Slope	12.013	6 ft	6	SF	\$120	\$660
41000	2.8 to 6.8 feet	Running Slope	9.0-10.0%	6 ft	22	SF	\$120	\$2,640
32752	13.3 to 14.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
32753	20.8 to 28.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,148
32756	31.8 to 38.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,620
32759	41.6 to 44.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716
32760	48.3 to 49.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
32761	53.5 to 62.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,138
32763	69.3 to 75.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894
32764	95.8 to 101.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	33	SF	\$120	\$3,960
32765	105.2 to 111.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,158
32766	113.7 to 115.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
32767	123.7 to 135.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	65	SF	\$120	\$7,854
32771	159.0 to 161.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848
32772	167.7 to 179.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	64	SF	\$120	\$7,656
140	189.5 to 190.5 feet	Continuous Width		6 ft	6	SF	\$120	\$660
32775	194.3 to 195.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
32776	199.1 to 207.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,412
32779	234.8 to 239.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
55567	244.8 to 245.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
41002	246.7 to 247.8 feet	Running Slope	8.0-9.0%	6 ft	6	SF	\$120	\$726
41003	248.6 to 250.3 feet	Running Slope	10.0-11.0%	6 ft	9	SF	\$120	\$1,122
41004	251.4 to 255.5 feet	Running Slope	13.0-14.0%	6 ft	23	SF	\$120	\$2,706

TOTAL COST FOR: N side of ROBERTSON BLVD Starting at: SIDEWALK BEGINS \$67,666.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241552	KINGS AVE	FRONT ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41006	0.0 to 1.8 feet	Running Slope	5.0-6.0%	15 ft	27	SF	\$120	\$3,240
32780	4.8 to 26.6 feet	Cross Slope (PAR)	2.0-3.0%	15 ft	327	SF	\$120	\$39,240
59942	24.8 to 43.7 feet	Driveway				REF		
32786	28.1 to 29.3 feet	Cross Slope (Driveway)	7.0-8.0%	15 ft	18	SF	\$40	\$720
32787	32.2 to 41.4 feet	Cross Slope (Driveway)	10.0-11.0%	15 ft	138	SF	\$40	\$5,520
32791	48.0 to 49.2 feet	Cross Slope (PAR)	3.0-4.0%	15 ft	18	SF	\$120	\$2,160
32792	49.6 to 59.5 feet	Cross Slope (PAR)	2.0-3.0%	15 ft	149	SF	\$120	\$17,820
32795	61.9 to 63.1 feet	Cross Slope (PAR)	4.0-5.0%	15 ft	18	SF	\$120	\$2,160
41007	62.5 to 63.8 feet	Running Slope	5.0-6.0%	15 ft	20	REF		
TOTAL COST FOR: NW side of KINGS AVE Starting at: FRONT ST							\$70,860.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909241553	KINGS AVE	SIDEWALK BEGINS	1ST ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32796	0.0 to 1.3 feet	Cross Slope (PAR)	6.0-7.0%	15 ft	20	SF	\$120	\$2,340
59943	1.8 to 29.9 feet	Driveway				REF		
32797	5.8 to 15.2 feet	Cross Slope (Driveway)	8.0-9.0%	15 ft	141	SF	\$40	\$5,640
32800	17.8 to 20.2 feet	Cross Slope (Driveway)	8.0-9.0%	15 ft	36	SF	\$40	\$1,440
32801	23.0 to 24.2 feet	Cross Slope (Driveway)	7.0-8.0%	15 ft	18	SF	\$40	\$720
32802	27.1 to 30.2 feet	Cross Slope (Driveway)	8.0-9.0%	15 ft	47	SF	\$40	\$1,860
32803	35.4 to 36.5 feet	Cross Slope (PAR)	2.0-3.0%	15 ft	17	SF	\$120	\$1,980
59944	43.0 to 80.0 feet	Driveway				REF		
32804	48.3 to 66.4 feet	Cross Slope (Driveway)	8.0-9.0%	15 ft	272	SF	\$40	\$10,860
32810	67.8 to 70.6 feet	Cross Slope (Driveway)	6.0-7.0%	15 ft	42	SF	\$40	\$1,680
32812	70.6 to 81.8 feet	Cross Slope (Driveway)	8.0-9.0%	15 ft	168	SF	\$40	\$6,720
41008	81.0 to 84.2 feet	Running Slope	5.0-6.0%	15 ft	48	REF		
59945	86.2 to 104.4 feet	Driveway				REF		
32817	87.0 to 88.8 feet	Cross Slope (Driveway)	2.0-3.0%	15 ft	27	SF	\$40	\$1,080
32818	89.8 to 99.4 feet	Cross Slope (Driveway)	6.0-7.0%	15 ft	144	SF	\$40	\$5,760
32822	99.4 to 103.4 feet	Cross Slope (Driveway)	8.0-9.0%	15 ft	60	SF	\$40	\$2,400
32824	104.8 to 105.8 feet	Cross Slope (PAR)	4.0-5.0%	15 ft	15	SF	\$120	\$1,800
51209	105.0 to 106.0 feet	Vertical Change	-.3	15 ft	15	REF		
32825	106.5 to 120.0 feet	Cross Slope (PAR)	2.0-3.0%	15 ft	203	SF	\$120	\$24,300
55568	124.8 to 125.8 feet	Vertical Change	.3	15 ft	15	LF	\$75	\$1,125
32829	133.7 to 137.4 feet	Cross Slope (PAR)	2.0-3.0%	15 ft	56	SF	\$120	\$6,660
41010	139.5 to 140.8 feet	Running Slope	5.0-6.0%	15 ft	20	SF	\$120	\$2,340
TOTAL COST FOR: NW side of KINGS AVE Starting at: SIDEWALK BEGINS							\$78,705.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	51909251014	KINGS AVE	3RD ST	4TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
32891	0.7 to 3.6 feet	Cross Slope (PAR)	7.0-8.0%	6 ft	16	SF	\$120	\$1,914	
32832	3.5 to 4.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	7	SF	\$120	\$858	
32833	6.0 to 7.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726	
32893	6.2 to 12.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,422	
32894	7.8 to 11.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	23	SF	\$120	\$2,706	
32896	13.4 to 20.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,620	
32837	20.3 to 25.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	29	SF	\$120	\$3,432	
32840	25.6 to 27.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122	
32841	35.3 to 48.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	74	SF	\$120	\$8,910	
32902	37.0 to 48.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	64	SF	\$120	\$7,656	
57644	46.6 to 47.6 feet	Vertical Change	3.4	6 ft	6	REF			
32843	50.8 to 56.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,498	
55574	57.9 to 60.6 feet	Vertical Change	.3	6 ft	15	LF	\$75	\$1,114	
41011	57.9 to 59.3 feet	Running Slope	5.0-6.0%	6 ft	8	SF	\$120	\$924	
32907	61.2 to 62.2 feet	Cross Slope (PAR)	8.0-9.0%	6 ft	6	SF	\$120	\$660	
42352	61.8 to 63.3 feet	Vertical Change	-.7	6 ft	8	REF			
32908	66.8 to 73.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,554	
55570	69.3 to 70.3 feet	Vertical Change	.3	6 ft	6	REF			
32847	70.8 to 74.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	18	SF	\$120	\$2,112	
32849	74.2 to 78.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,102	
32911	74.8 to 76.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
56473	75.9 to 76.9 feet	Vertical Change	.4	6 ft	6	REF			
32912	79.3 to 84.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	28	SF	\$120	\$3,366	
32913	81.3 to 82.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056	
57660	83.8 to 92.8 feet	Vertical Change	3.5	6 ft	50	SF	\$75	\$3,713	
32851	96.8 to 98.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	12	SF	\$120	\$1,386	
57675	97.1 to 98.1 feet	Vertical Change	3.6	6 ft	6	REF			
57597	99.8 to 100.8 feet	Vertical Change	2.9	6 ft	6	SF	\$75	\$413	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909251014	KINGS AVE	3RD ST	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57676	102.4 to 103.4 feet	Vertical Change	3.6	6 ft	6	REF		
32852	102.8 to 107.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	25	SF	\$120	\$2,970
55571	103.7 to 104.7 feet	Vertical Change	.3	6 ft	6	REF		
57619	105.1 to 106.1 feet	Vertical Change	3.1	6 ft	6	REF		
32917	105.5 to 110.4 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	27	SF	\$120	\$3,234
57662	107.8 to 108.8 feet	Vertical Change	3.5	6 ft	6	REF		
32856	110.4 to 111.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660
59946	112.8 to 143.5 feet	Driveway				REF		
32857	113.3 to 116.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	19	SF	\$40	\$770
59947	113.3 to 143.8 feet	Driveway				REF		
32859	129.2 to 133.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	23	SF	\$40	\$902
32921	153.2 to 157.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
55575	155.8 to 156.8 feet	Vertical Change	.3	6 ft	6	REF		
32861	163.8 to 173.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,138
32923	165.5 to 170.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,432
32863	175.1 to 178.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$1,980
55572	179.5 to 180.5 feet	Vertical Change	.3	6 ft	6	REF		
32864	180.3 to 189.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,336
32866	184.8 to 193.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,742
32869	191.3 to 197.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	33	SF	\$120	\$3,960
32929	193.6 to 215.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	118	SF	\$120	\$14,190
32930	199.8 to 209.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,402
32934	214.1 to 228.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	81	SF	\$120	\$9,768
32873	225.1 to 226.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$792
141	225.1 to 226.1 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
32874	227.6 to 236.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,138
32938	229.6 to 241.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	63	SF	\$120	\$7,590
45408	244.0 to 245.0 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909251014	KINGS AVE	3RD ST	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32943	246.5 to 251.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168
57633	246.7 to 247.7 feet	Vertical Change	3.3	6 ft	6	REF		
55573	250.7 to 251.7 feet	Vertical Change	.3	6 ft	6	REF		
57645	252.0 to 255.7 feet	Vertical Change	3.4	6 ft	20	REF		
32878	252.6 to 269.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	91	SF	\$120	\$10,890
55576	271.1 to 272.1 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
57663	273.3 to 274.3 feet	Vertical Change	3.5	6 ft	6	SF	\$75	\$413
32886	274.8 to 290.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	86	SF	\$120	\$10,296
57664	281.3 to 282.3 feet	Vertical Change	3.5	6 ft	6	REF		
143	289.1 to 290.1 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
57678	289.3 to 293.0 feet	Vertical Change	3.6	6 ft	20	REF		
142	294.0 to 295.0 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
57208	295.7 to 296.7 feet	Vertical Change	.7	6 ft	6	SF	\$75	\$413
47764	295.9 to 296.9 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: NW side of KINGS AVE Starting at: 3RD ST							\$173,478.25	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	51909251019	KINGS AVE	4TH ST	5TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
32950	1.3 to 14.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	73	SF	\$120	\$8,778	
32955	16.5 to 19.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244	
32956	23.3 to 28.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630	
32957	31.0 to 34.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112	
32959	34.5 to 36.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	8	SF	\$120	\$990	
32960	39.9 to 61.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	121	SF	\$120	\$14,520	
59948	48.4 to 58.0 feet	Driveway				REF			
55577	96.3 to 97.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
59949	100.6 to 110.2 feet	Driveway				REF			
56840	139.8 to 140.8 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413	
59950	147.3 to 158.8 feet	Driveway				REF			
32967	152.5 to 155.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	16	SF	\$40	\$638	
32968	159.6 to 160.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$792	
32969	163.5 to 167.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	23	SF	\$120	\$2,772	
32971	170.9 to 178.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,818	
32974	180.3 to 184.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904	
59951	194.5 to 206.9 feet	Driveway				REF			
57570	219.8 to 220.8 feet	Vertical Change	2.6	6 ft	6	SF	\$75	\$413	
32977	225.6 to 226.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
32978	229.3 to 238.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$6,006	
32981	251.8 to 256.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904	
32983	258.3 to 260.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	14	SF	\$120	\$1,650	
32985	262.8 to 266.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112	
32987	268.3 to 270.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386	
32988	279.3 to 282.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782	
32990	287.6 to 290.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112	
41012	290.7 to 291.9 feet	Running Slope	6.0-7.0%	6 ft	7	REF			

TOTAL COST FOR: NW side of KINGS AVE Starting at: 4TH ST \$64,047.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909251021	KINGS AVE	5TH ST	6TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
32991	0.0 to 18.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	102	SF	\$120	\$12,210
55578	17.2 to 18.2 feet	Vertical Change	.3	6 ft	6	REF		
32998	20.9 to 33.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	68	SF	\$120	\$8,118
33003	36.3 to 42.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	33	SF	\$120	\$3,960
33005	47.0 to 61.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	82	SF	\$120	\$9,834
59952	56.8 to 84.3 feet	Driveway				REF		
33010	68.8 to 70.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	9	SF	\$40	\$374
33011	87.5 to 89.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518
59953	96.8 to 116.0 feet	Driveway				REF		
33012	105.6 to 116.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	57	SF	\$40	\$2,288
33014	120.3 to 146.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	141	SF	\$120	\$16,962
33025	157.6 to 164.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,686
59954	179.8 to 191.3 feet	Driveway				REF		
51210	180.7 to 181.7 feet	Vertical Change	-.3	6 ft	6	REF		
33027	181.5 to 194.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	71	SF	\$40	\$2,838
33033	197.3 to 199.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,584
33034	208.3 to 214.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,092
33037	230.7 to 235.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,102
33039	244.1 to 255.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	63	SF	\$120	\$7,590
144	246.3 to 247.3 feet	Continuous Width		6 ft	6	SF	\$120	\$660
33044	265.9 to 268.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650
33045	270.7 to 274.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,508
33046	278.6 to 287.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,742
TOTAL COST FOR: NW side of KINGS AVE Starting at: 5TH ST							\$89,716.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	51909251024	KINGS AVE	6TH ST	7TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
33049	0.0 to 2.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	14	SF	\$120	\$1,716	
33051	4.0 to 11.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,016	
59955	14.1 to 25.1 feet	Driveway				REF			
33054	24.4 to 26.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	9	SF	\$40	\$352	
51211	26.9 to 27.9 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
33055	31.8 to 37.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	30	SF	\$120	\$3,630	
33058	37.3 to 64.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	151	SF	\$120	\$18,084	
56841	48.1 to 49.1 feet	Vertical Change	.5	6 ft	6	REF			
33069	68.5 to 69.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
33070	74.2 to 77.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046	
33071	81.5 to 89.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	41	SF	\$120	\$4,950	
33073	94.4 to 96.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650	
59956	96.9 to 119.5 feet	Driveway				REF			
47765	100.3 to 101.3 feet	Vertical Change	-.4	6 ft	6	REF			
33074	145.7 to 148.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650	
41570	149.1 to 150.1 feet	Vertical Change	-1	6 ft	6	REF			
33075	149.1 to 150.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	7	SF	\$120	\$792	
33076	160.7 to 164.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,442	
55579	169.5 to 170.5 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
59957	195.6 to 204.8 feet	Driveway				REF			
55580	201.8 to 202.8 feet	Vertical Change	.3	6 ft	6	REF			
33077	202.4 to 204.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	14	SF	\$40	\$550	
55581	205.6 to 206.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
51212	212.1 to 215.3 feet	Vertical Change	-.3	6 ft	18	LF	\$75	\$1,320	
33078	215.4 to 216.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
33079	219.1 to 223.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	22	SF	\$120	\$2,640	
51213	219.3 to 220.3 feet	Vertical Change	-.3	6 ft	6	REF			
33080	223.6 to 241.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	97	SF	\$120	\$11,616	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909251024	KINGS AVE	6TH ST	7TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55582	234.7 to 235.7 feet	Vertical Change	.3	6 ft	6	REF		
55583	244.2 to 245.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
57474	246.0 to 247.0 feet	Vertical Change	1.5	6 ft	6	SF	\$75	\$413
57085	248.4 to 255.8 feet	Vertical Change	.6	6 ft	41	SF	\$75	\$3,053
55584	256.9 to 257.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
33085	268.2 to 270.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518
33086	277.4 to 278.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
33087	295.1 to 296.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
41013	298.3 to 299.4 feet	Running Slope	6.0-7.0%	6 ft	6	SF	\$120	\$726
TOTAL COST FOR: NW side of KINGS AVE Starting at: 6TH ST							\$69,327.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NW	51909251026	KINGS AVE	7TH ST	8TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
57457	12.8 to 13.8 feet	Vertical Change	1.4	6 ft	6	SF	\$75	\$413	
57612	17.6 to 18.6 feet	Vertical Change	3	6 ft	6	SF	\$75	\$413	
33088	29.9 to 31.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188	
33089	34.9 to 39.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,300	
55585	61.3 to 62.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
33091	63.4 to 64.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
57419	71.2 to 72.2 feet	Vertical Change	1.2	6 ft	6	SF	\$75	\$413	
59958	83.6 to 93.8 feet	Driveway				REF			
33092	90.8 to 95.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	24	SF	\$40	\$968	
33094	97.3 to 99.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386	
33095	113.9 to 114.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
59959	115.0 to 142.4 feet	Driveway				REF			
33096	123.3 to 130.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	39	SF	\$40	\$1,540	
33100	137.4 to 146.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	48	SF	\$40	\$1,936	
145	143.9 to 144.9 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
33104	153.3 to 154.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858	
33105	161.3 to 162.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990	
33106	167.8 to 173.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,498	
33109	190.7 to 195.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036	
33110	206.6 to 207.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
55586	210.2 to 211.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
51214	214.6 to 215.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
59960	232.8 to 242.0 feet	Driveway				REF			
33111	240.0 to 242.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	13	SF	\$40	\$506	
51215	254.1 to 255.1 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
51216	260.8 to 261.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
51217	267.2 to 268.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
33112	293.5 to 296.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650	

TOTAL COST FOR: NW side of KINGS AVE Starting at: 7TH ST**\$26,911.50**

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909251029	KINGS AVE	8TH ST	9TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
33113	26.8 to 46.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	107	SF	\$120	\$12,804
33120	47.7 to 48.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
33121	52.2 to 60.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,412
33125	79.7 to 89.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	55	SF	\$120	\$6,600
33128	139.0 to 148.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,138
33131	156.7 to 158.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
33132	170.5 to 178.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	46	SF	\$120	\$5,544
55587	172.0 to 173.0 feet	Vertical Change	.3	6 ft	6	REF		
56476	179.3 to 180.3 feet	Vertical Change	.4	6 ft	6	REF		
33135	179.8 to 181.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386
56842	184.2 to 185.2 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
45409	187.3 to 188.3 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413
59961	189.0 to 201.7 feet	Driveway				REF		
33136	192.3 to 194.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	10	SF	\$40	\$418
33137	205.8 to 212.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224
59962	208.3 to 240.6 feet	Driveway				REF		
57086	212.2 to 213.2 feet	Vertical Change	.6	6 ft	6	REF		
33140	225.6 to 229.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	22	SF	\$40	\$880
33142	233.4 to 235.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	10	SF	\$40	\$396
57679	247.2 to 248.2 feet	Vertical Change	3.6	6 ft	6	SF	\$75	\$413
57272	261.1 to 262.1 feet	Vertical Change	.8	6 ft	6	SF	\$75	\$413
41014	261.2 to 262.3 feet	Running Slope	8.0-9.0%	6 ft	6	SF	\$120	\$726
33143	263.9 to 265.0 feet	Cross Slope (PAR)	8.0-9.0%	6 ft	6	SF	\$120	\$726
41343	264.0 to 265.0 feet	Vertical Change	-1.4	6 ft	6	REF		
33144	268.0 to 269.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
33145	274.4 to 275.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
57087	285.1 to 286.1 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413
45410	288.3 to 289.3 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413

TOTAL COST FOR: NW	<i>side of</i> KINGS AVE	<i>Starting at:</i> 8TH ST	\$51,425.00
---------------------------	---------------------------------	-----------------------------------	--------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	51909251032	KINGS AVE	9TH ST	10TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
55588	20.8 to 21.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
47768	67.3 to 68.3 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413	
33146	75.3 to 78.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178	
59963	92.5 to 113.7 feet	Driveway				REF			
33148	103.4 to 107.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	24	SF	\$40	\$946	
55589	120.0 to 121.0 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
33150	123.0 to 124.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990	
146	123.3 to 124.3 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
55590	128.3 to 129.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
55591	138.8 to 139.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
57088	146.8 to 147.8 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413	
56843	150.1 to 151.1 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413	
59964	153.9 to 167.7 feet	Driveway				REF			
33151	166.4 to 169.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	14	SF	\$40	\$572	
56477	200.8 to 201.8 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
33152	201.9 to 206.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,970	
59965	206.9 to 216.8 feet	Driveway				REF			
43528	210.9 to 212.2 feet	Vertical Change	-.6	6 ft	7	REF			
33154	211.4 to 215.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	20	SF	\$40	\$814	
56478	213.0 to 214.0 feet	Vertical Change	.4	6 ft	6	REF			
45411	216.8 to 218.0 feet	Vertical Change	-.5	6 ft	7	REF			
33155	218.2 to 219.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
33156	220.5 to 221.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	6	SF	\$120	\$726	
55592	221.5 to 222.5 feet	Vertical Change	.3	6 ft	6	REF			
147	221.7 to 222.7 feet	Continuous Width		6 ft	6	SF	\$120	\$660	
45413	223.3 to 224.3 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413	
33157	227.9 to 229.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726	
57519	230.5 to 231.5 feet	Vertical Change	1.9	6 ft	6	SF	\$75	\$413	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909251032	KINGS AVE	9TH ST	10TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55593	233.3 to 234.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
148	234.5 to 235.5 feet	Continuous Width		6 ft	6	SF	\$120	\$660
47770	235.1 to 236.1 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
55594	235.3 to 236.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
55595	238.4 to 239.4 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
56479	241.9 to 242.9 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
33158	247.9 to 249.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
56480	258.4 to 259.4 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
33159	289.5 to 296.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,620
33162	299.7 to 303.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640
51218	300.9 to 301.9 feet	Vertical Change	-.3	6 ft	6	REF		
TOTAL COST FOR: NW side of KINGS AVE Starting at: 9TH ST								\$26,983.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909251035	KINGS AVE	SIDEWALK BEGINS	11TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55596	1.8 to 2.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
33164	9.8 to 18.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,742
55597	21.7 to 22.7 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
56844	34.8 to 35.8 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
59966	46.6 to 59.8 feet	Driveway				REF		
47771	65.5 to 66.5 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
55598	71.9 to 72.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
33167	89.8 to 94.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,300
TOTAL COST FOR: NW side of KINGS AVE Starting at: SIDEWALK BEGINS							\$11,104.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909251036	KINGS AVE	11TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
33169	5.4 to 6.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
55599	10.6 to 11.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
33170	18.3 to 26.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346
33172	48.8 to 51.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914
33174	53.0 to 57.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	26	SF	\$120	\$3,102
59967	60.8 to 80.6 feet	Driveway				REF		
33177	61.2 to 62.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$242
33178	65.0 to 66.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$242
59968	89.8 to 105.3 feet	Driveway				REF		
56845	90.1 to 91.1 feet	Vertical Change	.5	6 ft	6	REF		
51219	92.3 to 93.3 feet	Vertical Change	-.3	6 ft	6	REF		
33179	139.3 to 141.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
59969	140.2 to 150.8 feet	Driveway				REF		
TOTAL COST FOR: NW side of KINGS AVE Starting at: 11TH ST							\$13,304.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority		
NW	51909251038	KINGS AVE	SIDEWALK BEGINS	SIDEWALK ENDS					TBD		
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
33180	0.0 to 1.0 feet	Cross Slope (PAR)	7.0-8.0%	6 ft	6	SF	\$120	\$660			
33182	9.4 to 11.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518			
33184	25.0 to 39.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	81	SF	\$120	\$9,768			
59971	41.3 to 52.5 feet	Driveway				REF					
41490	42.0 to 43.0 feet	Vertical Change	-1.1	6 ft	6	REF					
51220	42.3 to 43.3 feet	Vertical Change	-.3	6 ft	6	REF					
41015	43.1 to 45.1 feet	Running Slope	5.0-6.0%	6 ft	11	REF					
33189	44.8 to 46.1 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	7	SF	\$40	\$286			
33190	46.8 to 52.8 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	33	SF	\$40	\$1,320			
41016	50.8 to 52.8 feet	Running Slope	5.0-6.0%	6 ft	11	REF					
TOTAL COST FOR: NW							<i>side of</i>	KINGS AVE	<i>Starting at:</i>	SIDEWALK BEGINS	\$13,552.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909251040	KINGS AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59972	0.6 to 6.6 feet	Driveway				REF		
43530	9.8 to 10.8 feet	Vertical Change	-6	6 ft	5	SF	\$75	\$413
33197	19.2 to 20.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
33198	25.7 to 42.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	91	SF	\$120	\$10,956
59973	38.6 to 57.9 feet	Driveway				REF		
41017	41.6 to 42.8 feet	Running Slope	5.0-6.0%	6 ft	7	REF		
33204	45.7 to 48.3 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	14	SF	\$40	\$572
33206	51.7 to 59.0 feet	Cross Slope (Driveway)	13.014	6 ft	40	SF	\$40	\$1,606
TOTAL COST FOR: NW side of KINGS AVE Starting at: SIDEWALK BEGINS							\$14,272.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909251044	KINGS AVE	13TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
149	14.9 to 15.9 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
33210	25.0 to 26.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
33211	30.3 to 36.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224
59974	44.5 to 55.1 feet	Driveway				REF		
51221	46.5 to 47.5 feet	Vertical Change	-.3	6 ft	6	REF		
33213	54.3 to 55.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	8	SF	\$40	\$308
33214	60.7 to 61.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
33215	110.1 to 111.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
59975	130.3 to 141.6 feet	Driveway				REF		
33216	139.7 to 144.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	24	SF	\$40	\$946
33217	150.0 to 154.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,706
33219	161.3 to 194.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	184	SF	\$120	\$22,110
59976	180.9 to 190.8 feet	Driveway				REF		
33230	225.5 to 238.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	73	SF	\$120	\$8,778
59977	230.8 to 252.3 feet	Driveway				REF		
33234	243.3 to 244.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	8	SF	\$40	\$330
TOTAL COST FOR: NW side of KINGS AVE Starting at: 13TH ST							\$41,679.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909251046	KINGS AVE	13TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
59978	0.0 to 2.7 feet	Driveway				REF		
33235	22.3 to 23.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
33236	27.2 to 35.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,742
59979	48.3 to 55.8 feet	Driveway				REF		
33237	61.6 to 68.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,554
33239	70.7 to 72.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
57598	78.8 to 79.8 feet	Vertical Change	2.9	6 ft	6	SF	\$75	\$413
51223	83.0 to 84.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
33240	84.3 to 85.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
33241	88.8 to 104.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	88	SF	\$120	\$10,560
57571	92.3 to 93.3 feet	Vertical Change	2.6	6 ft	6	REF		
59980	94.2 to 107.8 feet	Driveway				REF		
47772	95.6 to 96.6 feet	Vertical Change	-.4	6 ft	6	REF		
33244	105.5 to 113.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	46	SF	\$40	\$1,826
57578	105.8 to 106.8 feet	Vertical Change	2.7	6 ft	6	REF		
51224	113.8 to 114.8 feet	Vertical Change	-.3	6 ft	6	REF		
47773	121.7 to 122.7 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
57680	140.2 to 141.2 feet	Vertical Change	3.6	6 ft	6	SF	\$75	\$413
33248	145.6 to 147.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452
33249	151.1 to 174.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	126	SF	\$120	\$15,114
57681	166.8 to 167.8 feet	Vertical Change	3.6	6 ft	6	REF		
59981	170.0 to 184.8 feet	Driveway				REF		
51225	170.6 to 171.6 feet	Vertical Change	-.3	6 ft	6	REF		
57666	174.8 to 175.8 feet	Vertical Change	3.5	6 ft	6	REF		
33256	175.2 to 183.8 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	47	SF	\$40	\$1,892
57646	180.3 to 181.3 feet	Vertical Change	3.4	6 ft	6	REF		
51226	183.0 to 184.0 feet	Vertical Change	-.3	6 ft	6	REF		
33259	183.8 to 192.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	48	SF	\$40	\$1,914
57613	185.6 to 186.6 feet	Vertical Change	3	6 ft	6	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909251046	KINGS AVE	13TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
33262	199.3 to 201.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	14	SF	\$120	\$1,650
33264	204.3 to 207.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	15	SF	\$120	\$1,782
33265	207.0 to 208.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
55600	210.7 to 211.7 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
51227	225.6 to 226.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
59982	232.8 to 243.5 feet	Driveway				REF		
57366	234.6 to 235.6 feet	Vertical Change	1	6 ft	6	REF		
51228	242.1 to 243.1 feet	Vertical Change	-.3	6 ft	6	REF		
TOTAL COST FOR: NW side of KINGS AVE Starting at: 13TH ST							\$52,723.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251051	15TH ST	KINGS AVE	RIVERSIDE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51229	0.2 to 1.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
33266	15.6 to 19.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
150	20.3 to 21.3 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
47774	48.3 to 49.3 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
59983	82.0 to 102.3 feet	Driveway				REF		
33267	88.3 to 100.2 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	65	SF	\$40	\$2,618
33270	121.5 to 126.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,366
59984	132.3 to 157.2 feet	Driveway				REF		
33271	132.5 to 134.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	12	SF	\$40	\$484
33272	139.7 to 144.2 feet	Cross Slope (Driveway)	13.014	6 ft	25	SF	\$40	\$990
33274	146.4 to 150.4 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	22	SF	\$40	\$880
33276	150.4 to 156.6 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	34	SF	\$40	\$1,364
41019	158.5 to 159.6 feet	Running Slope	6.0-7.0%	6 ft	6	SF	\$120	\$726
33279	161.7 to 162.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660
33280	162.7 to 168.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,762
33283	175.2 to 187.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	67	SF	\$120	\$7,986
33287	189.7 to 198.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$6,006
59985	199.1 to 232.0 feet	Driveway				REF		
33288	205.1 to 213.3 feet	Cross Slope (Driveway)	13.014	6 ft	45	SF	\$40	\$1,804
33292	215.8 to 230.2 feet	Cross Slope (Driveway)	13.014	6 ft	79	SF	\$40	\$3,168
51230	243.6 to 244.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
56846	276.8 to 277.8 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
51231	287.3 to 288.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413

TOTAL COST FOR: NE	<i>side of 15TH ST Starting at: KINGS AVE</i>	\$38,747.50
---------------------------	---	--------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	51909251054	15TH ST	RIVERSIDE AVE	LAKE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
33296	0.0 to 5.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	30	SF	\$120	\$3,630	
33299	22.9 to 24.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990	
33300	47.5 to 84.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	203	SF	\$120	\$24,354	
33310	88.2 to 95.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,488	
51232	92.4 to 93.4 feet	Vertical Change	-.3	6 ft	6	REF			
33312	96.3 to 99.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	18	SF	\$120	\$2,112	
59986	98.5 to 119.6 feet	Driveway				REF			
33313	105.3 to 112.7 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	41	SF	\$40	\$1,628	
33315	114.8 to 118.8 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	22	SF	\$40	\$880	
51233	120.0 to 121.0 feet	Vertical Change	-.3	6 ft	6	REF			
41020	122.0 to 123.5 feet	Running Slope	7.0-8.0%	6 ft	8	REF			
33316	122.2 to 132.0 feet	Cross Slope (PAR)	7.0-8.0%	6 ft	54	SF	\$120	\$6,468	
59987	131.1 to 151.9 feet	Driveway				REF			
41491	132.7 to 133.7 feet	Vertical Change	-1.1	6 ft	6	REF			
33319	135.1 to 136.2 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	6	SF	\$40	\$242	
33320	139.1 to 151.4 feet	Cross Slope (Driveway)	13.014	6 ft	68	SF	\$40	\$2,706	
41021	152.2 to 153.6 feet	Running Slope	6.0-7.0%	6 ft	8	REF			
33325	161.1 to 194.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	185	SF	\$120	\$22,176	
56847	185.1 to 186.1 feet	Vertical Change	.5	6 ft	6	REF			
33333	196.8 to 206.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	54	SF	\$120	\$6,468	
33338	207.4 to 215.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	44	SF	\$120	\$5,280	
33341	216.9 to 225.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,676	
33344	226.3 to 251.4 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	138	SF	\$120	\$16,566	
55601	254.0 to 255.0 feet	Vertical Change	.3	6 ft	6	REF			
33349	254.0 to 255.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858	
33350	257.5 to 277.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	112	SF	\$120	\$13,464	
59988	275.8 to 293.5 feet	Driveway				REF			
41022	278.6 to 279.9 feet	Running Slope	5.0-6.0%	6 ft	7	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251054	15TH ST	RIVERSIDE AVE	LAKE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
33356	282.8 to 291.4 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	47	SF	\$40	\$1,892
TOTAL COST FOR: NE side of 15TH ST Starting at: RIVERSIDE AVE							\$119,878.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	51909251056	15TH ST	LAKE AVE	MONTEREY AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
33359	3.2 to 4.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
33360	27.3 to 28.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
55602	29.8 to 30.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
33361	30.9 to 40.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,072	
59989	38.8 to 59.3 feet	Driveway				REF			
33364	44.4 to 52.6 feet	Cross Slope (Driveway)	13.014	6 ft	45	SF	\$40	\$1,804	
33367	54.1 to 56.3 feet	Cross Slope (Driveway)	>15%	6 ft	12	SF	\$40	\$484	
41023	59.5 to 60.5 feet	Running Slope	5.0-6.0%	6 ft	6	SF	\$120	\$660	
33369	61.9 to 65.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	19	SF	\$120	\$2,244	
59990	65.8 to 88.2 feet	Driveway				REF			
56481	66.9 to 67.9 feet	Vertical Change	.4	6 ft	6	REF			
33371	70.9 to 78.9 feet	Cross Slope (Driveway)	>15%	6 ft	44	SF	\$40	\$1,760	
51234	79.0 to 80.0 feet	Vertical Change	-.3	6 ft	6	REF			
33373	79.3 to 84.2 feet	Cross Slope (Driveway)	13.014	6 ft	27	SF	\$40	\$1,078	
33375	84.5 to 87.6 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	17	SF	\$40	\$682	
33377	91.1 to 96.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,432	
33378	98.7 to 108.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,138	
51235	104.5 to 105.5 feet	Vertical Change	-.3	6 ft	6	REF			
33382	111.0 to 114.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	20	SF	\$120	\$2,442	
33384	117.8 to 132.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	78	SF	\$120	\$9,372	
151	125.0 to 126.0 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
59991	129.7 to 153.3 feet	Driveway				REF			
33387	136.9 to 148.0 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	61	SF	\$40	\$2,442	
33392	148.7 to 150.4 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	9	SF	\$40	\$374	
33393	150.9 to 151.9 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	6	SF	\$40	\$220	
41024	151.5 to 152.9 feet	Running Slope	6.0-7.0%	6 ft	8	REF			
33394	155.8 to 159.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	18	SF	\$120	\$2,112	
33396	162.0 to 166.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	24	SF	\$120	\$2,838	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251056	15TH ST	LAKE AVE	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
33398	169.8 to 171.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
33399	176.3 to 183.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	37	SF	\$120	\$4,422
33401	184.3 to 185.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
59992	184.8 to 210.4 feet	Driveway				REF		
33402	186.7 to 187.8 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	6	SF	\$40	\$242
33403	189.6 to 194.8 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	29	SF	\$40	\$1,144
33405	194.8 to 208.8 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	77	SF	\$40	\$3,080
41025	208.7 to 209.7 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
33409	212.3 to 213.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
33410	217.4 to 250.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	180	SF	\$120	\$21,582
33418	252.8 to 283.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	171	SF	\$120	\$20,460
TOTAL COST FOR: NE side of 15TH ST Starting at: LAKE AVE							\$100,083.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251103	13TH ST	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
33426	11.0 to 25.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	78	SF	\$120	\$9,306
33430	50.3 to 52.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452
55603	51.3 to 52.3 feet	Vertical Change	.3	6 ft	6	REF		
33431	57.0 to 60.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178
TOTAL COST FOR: NE side of 13TH ST Starting at: SIDEWALK BEGINS							\$12,936.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251106	13TH ST	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
33433	12.6 to 14.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	11	SF	\$120	\$1,320
33434	14.8 to 21.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,092
33436	23.4 to 42.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	104	SF	\$120	\$12,474
55604	37.4 to 38.4 feet	Vertical Change	.3	6 ft	6	REF		
152	42.1 to 43.1 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
59993	44.6 to 59.7 feet	Driveway				REF		
33442	50.2 to 51.4 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	7	SF	\$40	\$264
33443	51.8 to 59.3 feet	Cross Slope (Driveway)	13.014	6 ft	41	SF	\$40	\$1,650
33445	59.8 to 61.0 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	7	SF	\$40	\$264
41026	62.2 to 63.3 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
33446	63.0 to 64.1 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	6	SF	\$120	\$726
33447	64.8 to 67.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	17	SF	\$120	\$2,046
59994	69.3 to 90.5 feet	Driveway				REF		
33448	74.8 to 91.3 feet	Cross Slope (Driveway)	>15%	6 ft	91	SF	\$40	\$3,630
TOTAL COST FOR: NE side of 13TH ST Starting at: SIDEWALK BEGINS								\$26,565.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251116	15TH ST	MONTEREY AVE	SONOMA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
33450	3.2 to 21.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	102	SF	\$120	\$12,276
55605	22.8 to 23.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
33452	29.7 to 39.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	56	SF	\$120	\$6,666
33455	42.3 to 59.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	94	SF	\$120	\$11,286
59995	60.9 to 78.7 feet	Driveway				REF		
33457	66.3 to 73.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	39	SF	\$40	\$1,540
33459	74.0 to 76.8 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	15	SF	\$40	\$616
33460	85.3 to 95.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	58	SF	\$120	\$6,930
33461	112.0 to 130.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	100	SF	\$120	\$11,946
55606	129.1 to 130.1 feet	Vertical Change	.3	6 ft	6	REF		
59996	129.9 to 151.8 feet	Driveway				REF		
33465	134.4 to 148.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	79	SF	\$40	\$3,168
33470	160.8 to 180.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	110	SF	\$120	\$13,200
33475	183.6 to 186.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650
33476	190.4 to 194.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376
33478	196.1 to 207.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	61	SF	\$120	\$7,326
59997	205.8 to 225.8 feet	Driveway				REF		
33481	211.8 to 224.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	72	SF	\$40	\$2,860
33484	228.8 to 233.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	24	SF	\$120	\$2,904
33485	234.3 to 238.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
33487	238.3 to 239.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	7	SF	\$120	\$792
33488	242.0 to 272.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	168	SF	\$120	\$20,130
51237	252.7 to 253.7 feet	Vertical Change	-.3	6 ft	6	REF		
33498	276.3 to 283.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	40	SF	\$120	\$4,752
51238	280.7 to 281.7 feet	Vertical Change	-.3	6 ft	6	REF		
TOTAL COST FOR: NE side of 15TH ST Starting at: MONTEREY AVE							\$113,404.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251121	15TH ST	SONOMA AVE	VENTURA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41027	0.0 to 1.3 feet	Running Slope	5.0-6.0%	6 ft	7	REF		
33500	0.5 to 2.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	12	SF	\$120	\$1,386
33501	3.0 to 25.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	121	SF	\$120	\$14,520
55607	11.4 to 12.4 feet	Vertical Change	.3	6 ft	6	REF		
33507	30.7 to 37.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,356
55608	41.8 to 42.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
33510	52.8 to 55.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716
33511	58.4 to 59.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
59998	62.0 to 72.7 feet	Driveway				REF		
33512	63.1 to 64.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$242
33513	69.2 to 73.3 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	23	SF	\$40	\$902
33515	80.2 to 83.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376
55609	82.1 to 83.1 feet	Vertical Change	.3	6 ft	6	REF		
33517	83.8 to 95.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	62	SF	\$120	\$7,458
33521	95.1 to 108.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	76	SF	\$120	\$9,108
51239	102.0 to 103.0 feet	Vertical Change	-.3	6 ft	6	REF		
33525	115.2 to 120.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,366
55610	117.0 to 118.0 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
33527	121.0 to 126.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	30	SF	\$120	\$3,630
59999	131.0 to 155.6 feet	Driveway				REF		
33529	131.5 to 133.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	9	SF	\$40	\$352
33530	136.5 to 137.8 feet	Cross Slope (Driveway)	13.014	6 ft	7	SF	\$40	\$286
33531	138.8 to 142.3 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	19	SF	\$40	\$770
33533	142.8 to 150.6 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	43	SF	\$40	\$1,716
33537	150.6 to 153.4 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	15	SF	\$40	\$616
41028	154.5 to 155.8 feet	Running Slope	7.0-8.0%	6 ft	7	REF		
33539	159.5 to 160.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
33540	162.8 to 165.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251121	15TH ST	SONOMA AVE	VENTURA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
33541	167.8 to 170.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782
33542	173.1 to 174.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
33543	178.1 to 191.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	74	SF	\$120	\$8,910
33546	195.4 to 199.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
33547	202.3 to 204.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386
60000	204.6 to 231.6 feet	Driveway				REF		
33548	211.0 to 220.2 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	51	SF	\$40	\$2,024
33552	220.2 to 228.8 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	47	SF	\$40	\$1,892
41029	230.8 to 232.1 feet	Running Slope	7.0-8.0%	6 ft	7	REF		
33556	234.2 to 235.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
56848	236.4 to 237.4 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
33557	237.9 to 246.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,676
45414	240.8 to 241.8 feet	Vertical Change	-.5	6 ft	6	REF		
33561	248.9 to 281.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	179	SF	\$120	\$21,450
51240	258.2 to 259.2 feet	Vertical Change	-.3	6 ft	6	REF		
55611	268.1 to 269.1 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: NE side of 15TH ST Starting at: SONOMA AVE							\$104,879.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Year to be Completed				Priority
SW	51909251129	15TH ST	VENTURA AVE	DEFENDER ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
60001	1.2 to 35.8 feet	Driveway				REF			
33570	8.5 to 14.7 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	34	SF	\$40	\$1,364	
33572	18.1 to 31.2 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	72	SF	\$40	\$2,882	
33576	31.9 to 33.3 feet	Cross Slope (Driveway)	13.014	6 ft	8	SF	\$40	\$308	
33577	36.8 to 38.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$792	
33578	39.3 to 42.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$1,980	
33585	60.7 to 62.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056	
33586	64.8 to 67.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782	
33587	70.3 to 83.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	73	SF	\$120	\$8,778	
33592	86.3 to 92.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	33	SF	\$120	\$3,960	
33594	94.9 to 144.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	273	SF	\$120	\$32,736	
33609	147.6 to 148.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
33610	153.3 to 155.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320	
33611	157.6 to 159.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188	
33612	161.5 to 164.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178	
33613	167.2 to 181.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	80	SF	\$120	\$9,636	
33619	191.0 to 200.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	54	SF	\$120	\$6,468	
33623	204.6 to 208.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310	
33624	211.6 to 213.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386	
33625	219.4 to 229.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	54	SF	\$120	\$6,534	
47775	219.9 to 220.9 feet	Vertical Change	-4	6 ft	6	REF			
33627	233.8 to 235.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858	
33628	236.3 to 243.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	41	SF	\$120	\$4,950	
33631	248.5 to 257.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	48	SF	\$120	\$5,742	
33634	258.1 to 263.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564	
33636	270.1 to 271.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122	
33637	277.4 to 287.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	56	SF	\$120	\$6,666	
33640	289.6 to 291.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251129	15TH ST	VENTURA AVE	DEFENDER ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
33641	304.9 to 306.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
51242	308.6 to 309.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
33642	322.8 to 331.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,676
33645	339.5 to 341.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,122
33646	342.8 to 349.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,092
33651	365.0 to 367.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	15	SF	\$120	\$1,848
60004	365.1 to 401.0 feet	Driveway				REF		
33653	371.5 to 377.5 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	33	SF	\$40	\$1,320
33657	377.8 to 396.4 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	102	SF	\$40	\$4,092
33661	397.7 to 399.8 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	12	SF	\$40	\$462
33662	403.0 to 411.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	47	SF	\$120	\$5,610
33665	412.4 to 416.8 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	24	SF	\$120	\$2,904
33666	417.2 to 425.5 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	46	SF	\$120	\$5,478
33669	425.5 to 434.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	48	SF	\$120	\$5,808
33672	434.3 to 436.0 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	9	SF	\$120	\$1,122
33673	436.0 to 440.3 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	24	SF	\$120	\$2,838
33674	440.3 to 442.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	14	SF	\$120	\$1,650
41881	442.9 to 443.9 feet	Vertical Change	-.8	6 ft	6	SF	\$75	\$413
33676	445.3 to 446.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
33677	449.8 to 455.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	30	SF	\$120	\$3,630
33679	455.8 to 466.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	61	SF	\$120	\$7,326
33684	469.7 to 471.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,056
33685	472.4 to 477.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
51243	472.6 to 473.6 feet	Vertical Change	-.3	6 ft	6	REF		
33687	477.0 to 491.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	79	SF	\$120	\$9,438
57647	494.2 to 495.2 feet	Vertical Change	3.4	6 ft	6	SF	\$75	\$413
33691	496.7 to 501.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,970
33693	501.2 to 503.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	12	SF	\$120	\$1,452

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251129	15TH ST	VENTURA AVE	DEFENDER ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
33694	505.9 to 525.3 feet	Cross Slope (PAR)	7.0-8.0%	6 ft	107	SF	\$120	\$12,804
51244	526.2 to 527.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
33700	532.0 to 541.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,402
33704	549.3 to 560.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	59	SF	\$120	\$7,062
33708	561.5 to 562.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	7	SF	\$120	\$858
33709	566.9 to 570.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	22	SF	\$120	\$2,640
51245	569.6 to 570.6 feet	Vertical Change	-.3	6 ft	6	REF		
33711	571.1 to 586.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	85	SF	\$120	\$10,164
60005	588.7 to 613.1 feet	Driveway				REF		
33715	600.8 to 607.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	36	SF	\$40	\$1,430
33718	626.6 to 628.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$990
33719	630.5 to 639.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$6,006
33722	657.6 to 667.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	55	SF	\$120	\$6,600
33726	686.8 to 702.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	86	SF	\$120	\$10,362
33736	722.8 to 781.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	323	SF	\$120	\$38,742
51246	763.6 to 764.6 feet	Vertical Change	-.3	6 ft	6	REF		
33753	784.3 to 789.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,696
33755	791.5 to 796.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	29	SF	\$120	\$3,498
33757	800.3 to 805.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	26	SF	\$120	\$3,102
33759	805.6 to 807.0 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	8	SF	\$120	\$924
33760	828.0 to 829.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
33761	832.2 to 845.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	74	SF	\$120	\$8,910
33764	850.1 to 851.3 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	7	SF	\$120	\$792
33765	852.1 to 853.3 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	7	SF	\$120	\$792
33766	853.6 to 859.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	32	SF	\$120	\$3,828
33769	860.8 to 869.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,808
33773	872.8 to 874.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
33774	878.2 to 883.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,696

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SW	51909251129	15TH ST	VENTURA AVE	DEFENDER ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
33776	887.5 to 889.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,122	
33777	890.5 to 901.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	58	SF	\$120	\$6,930	
60007	899.2 to 930.4 feet	Driveway				REF			
33782	907.3 to 910.8 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	19	SF	\$40	\$770	
33784	910.8 to 917.6 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	37	SF	\$40	\$1,496	
33787	917.6 to 919.6 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	11	SF	\$40	\$440	
33788	920.0 to 928.2 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	45	SF	\$40	\$1,804	
33792	937.8 to 939.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
33793	942.3 to 951.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,742	
33798	953.2 to 964.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	61	SF	\$120	\$7,326	
33800	967.5 to 979.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	68	SF	\$120	\$8,118	
153	973.8 to 974.8 feet	Continuous Width		6 ft	6	SF	\$120	\$660	
33804	981.7 to 986.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	27	SF	\$120	\$3,234	
33806	987.5 to 991.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310	
33808	1015.0 to 1017.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518	
33809	1029.4 to 1036.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,422	
33810	1039.3 to 1045.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,356	
33812	1049.6 to 1053.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244	
56482	1049.8 to 1050.8 feet	Vertical Change	.4	6 ft	6	REF			
33814	1055.8 to 1058.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	17	SF	\$120	\$1,980	
60008	1062.8 to 1081.2 feet	Driveway				REF			
33816	1068.4 to 1079.8 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	63	SF	\$40	\$2,508	
33822	1083.3 to 1087.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	23	SF	\$120	\$2,706	
60009	1087.3 to 1100.9 feet	Driveway				REF			
33825	1092.6 to 1099.8 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	40	SF	\$40	\$1,584	
55612	1101.4 to 1102.4 feet	Vertical Change	.3	6 ft	6	REF			
33827	1103.2 to 1105.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320	
33828	1114.3 to 1118.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,442	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251129	15TH ST	VENTURA AVE	DEFENDER ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
33835	1135.7 to 1137.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	11	SF	\$120	\$1,320
60011	1138.1 to 1165.2 feet	Driveway				REF		
33836	1143.1 to 1148.1 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	28	SF	\$40	\$1,100
33837	1150.2 to 1153.6 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	19	SF	\$40	\$748
33839	1155.8 to 1162.4 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	36	SF	\$40	\$1,452
33841	1178.3 to 1184.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,356
33844	1189.3 to 1203.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	75	SF	\$120	\$9,042
33848	1206.7 to 1214.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	43	SF	\$120	\$5,148
60012	1215.6 to 1233.7 feet	Driveway				REF		
33851	1215.9 to 1217.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	8	SF	\$40	\$308
33852	1220.8 to 1232.5 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	64	SF	\$40	\$2,574
33855	1237.8 to 1244.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,290
33859	1252.0 to 1253.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254
55613	1257.9 to 1258.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: SW side of 15TH ST Starting at: VENTURA AVE							\$426,420.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	51909251134	15TH ST	DEFENDER ST	ROBERTSON BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
33860	1.1 to 4.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046	
33862	11.9 to 19.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,082	
47776	22.8 to 23.8 feet	Vertical Change	-4	6 ft	6	LF	\$75	\$413	
33865	25.5 to 31.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630	
55614	36.8 to 37.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
33868	39.1 to 42.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,442	
60013	41.8 to 58.5 feet	Driveway				REF			
33870	47.6 to 57.3 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	53	SF	\$40	\$2,134	
41030	58.6 to 59.8 feet	Running Slope	5.0-6.0%	6 ft	7	SF	\$120	\$792	
33874	61.8 to 74.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	68	SF	\$120	\$8,184	
33878	76.6 to 88.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	64	SF	\$120	\$7,656	
33882	88.6 to 89.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
60014	91.7 to 105.3 feet	Driveway				REF			
33883	95.4 to 102.1 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	37	SF	\$40	\$1,474	
33884	106.7 to 107.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
33885	110.0 to 135.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	140	SF	\$120	\$16,830	
60015	138.0 to 155.4 feet	Driveway				REF			
33892	142.6 to 146.5 feet	Cross Slope (Driveway)	13.014	6 ft	21	SF	\$40	\$858	
51247	146.8 to 147.8 feet	Vertical Change	-3	6 ft	6	REF			
33894	147.0 to 154.8 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	43	SF	\$40	\$1,716	
55615	153.5 to 154.5 feet	Vertical Change	.3	6 ft	6	REF			
45415	155.6 to 156.7 feet	Vertical Change	-5	6 ft	6	SF	\$75	\$454	
154	157.6 to 158.6 feet	Continuous Width		6 ft	6	SF	\$120	\$660	
33897	158.2 to 162.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904	
60016	164.6 to 185.8 feet	Driveway				REF			
33898	165.0 to 166.0 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	6	SF	\$40	\$220	
41031	166.3 to 167.3 feet	Running Slope	5.0-6.0%	6 ft	6	REF			
33899	169.6 to 173.4 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	21	SF	\$40	\$836	
33901	174.0 to 183.3 feet	Cross Slope (Driveway)	13.014	6 ft	51	SF	\$40	\$2,046	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251134	15TH ST	DEFENDER ST	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41032	184.8 to 185.8 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
41033	185.8 to 187.2 feet	Running Slope	6.0-7.0%	6 ft	8	REF		
41034	187.2 to 188.3 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
33904	187.3 to 188.3 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	6	SF	\$120	\$660
33905	189.9 to 192.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	12	SF	\$120	\$1,452
33906	193.3 to 216.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	125	SF	\$120	\$14,982
51249	197.5 to 198.5 feet	Vertical Change	-.3	6 ft	6	REF		
33910	218.8 to 274.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	307	SF	\$120	\$36,828
60017	276.9 to 294.1 feet	Driveway				REF		
33925	283.3 to 288.2 feet	Cross Slope (Driveway)	>15%	6 ft	27	SF	\$40	\$1,078
33927	290.7 to 292.8 feet	Cross Slope (Driveway)	13.014	6 ft	12	SF	\$40	\$462
41035	294.0 to 295.3 feet	Running Slope	6.0-7.0%	6 ft	7	REF		
51250	294.4 to 295.4 feet	Vertical Change	-.3	6 ft	6	REF		
33929	298.3 to 305.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	41	SF	\$120	\$4,950
47777	307.6 to 308.6 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
60018	309.3 to 334.3 feet	Driveway				REF		
33931	312.3 to 313.4 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	6	SF	\$40	\$242
33932	317.0 to 335.4 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	101	SF	\$40	\$4,048
33939	339.2 to 352.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	74	SF	\$120	\$8,844
33944	355.4 to 356.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726
33945	356.5 to 385.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	159	SF	\$120	\$19,074
33956	388.5 to 393.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,300
60019	392.0 to 408.0 feet	Driveway				REF		
33958	397.5 to 401.9 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	24	SF	\$40	\$968
33960	401.9 to 404.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	16	SF	\$40	\$638
33961	409.3 to 414.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	30	SF	\$120	\$3,630
51251	453.5 to 454.5 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
55616	483.5 to 484.5 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251134	15TH ST	DEFENDER ST	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
33964	484.6 to 485.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
60020	487.0 to 506.9 feet	Driveway				REF		
33965	490.6 to 494.5 feet	Cross Slope (Driveway)	13.014	6 ft	21	SF	\$40	\$858
56849	495.7 to 496.7 feet	Vertical Change	.5	6 ft	6	REF		
33966	497.7 to 501.4 feet	Cross Slope (Driveway)	13.014	6 ft	20	SF	\$40	\$814
57667	497.8 to 498.8 feet	Vertical Change	3.5	6 ft	6	REF		
33968	501.4 to 506.7 feet	Cross Slope (Driveway)	>15%	6 ft	29	SF	\$40	\$1,166
33970	515.8 to 520.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	23	SF	\$120	\$2,772
33972	522.0 to 523.6 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	9	SF	\$120	\$1,056
60021	524.0 to 570.7 feet	Driveway				REF		
33973	525.3 to 527.0 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	9	SF	\$40	\$374
33974	581.9 to 583.1 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	7	SF	\$120	\$792
33975	590.2 to 593.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	18	SF	\$120	\$2,178
33977	594.8 to 606.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	65	SF	\$120	\$7,854
33980	612.8 to 615.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914
33982	621.1 to 626.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,762
60022	646.3 to 682.3 feet	Driveway				REF		
33984	652.2 to 669.5 feet	Cross Slope (Driveway)	13.014	6 ft	95	SF	\$40	\$3,806
33990	672.3 to 681.3 feet	Cross Slope (Driveway)	13.014	6 ft	50	SF	\$40	\$1,980
33993	686.3 to 705.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	105	SF	\$120	\$12,606
33999	707.5 to 712.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	27	SF	\$120	\$3,234
60023	711.0 to 726.3 feet	Driveway				REF		
34000	717.2 to 721.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	25	SF	\$40	\$1,012
34002	721.8 to 723.3 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	8	SF	\$40	\$330
34003	729.0 to 751.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	125	SF	\$120	\$15,048
34011	754.8 to 758.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	21	SF	\$120	\$2,508
34012	759.0 to 763.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838
34014	764.3 to 774.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	56	SF	\$120	\$6,666
60024	773.8 to 795.2 feet	Driveway				REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251134	15TH ST	DEFENDER ST	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34018	779.9 to 794.3 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	79	SF	\$40	\$3,168
57572	780.8 to 781.8 feet	Vertical Change	2.6	6 ft	6	REF		
41036	794.7 to 795.8 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
34022	800.7 to 819.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	106	SF	\$120	\$12,672
60025	819.6 to 849.8 feet	Driveway				REF		
57599	821.2 to 822.2 feet	Vertical Change	2.9	6 ft	6	REF		
34026	824.0 to 825.3 feet	Cross Slope (Driveway)	>15%	6 ft	7	SF	\$40	\$286
34027	828.1 to 834.0 feet	Cross Slope (Driveway)	13.014	6 ft	32	SF	\$40	\$1,298
34030	835.0 to 849.8 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	81	SF	\$40	\$3,256
34037	853.8 to 856.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518
34038	861.5 to 864.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	17	SF	\$120	\$1,980
34039	865.9 to 867.2 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	7	SF	\$120	\$858
TOTAL COST FOR: SW side of 15TH ST Starting at: DEFENDER ST								\$264,492.25

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SW	51909251138	15TH ST	ROBERTSON BLVD	KINGS AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
34040	0.0 to 16.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	90	SF	\$120	\$10,758	
34045	20.2 to 36.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	91	SF	\$120	\$10,956	
34051	36.8 to 50.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	75	SF	\$120	\$9,042	
60026	48.8 to 66.4 feet	Driveway				REF			
34057	55.7 to 59.6 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	21	SF	\$40	\$858	
34059	62.0 to 64.3 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	13	SF	\$40	\$506	
34061	71.2 to 73.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782	
34063	73.9 to 80.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	37	SF	\$120	\$4,488	
45416	80.0 to 81.3 feet	Vertical Change	-.5	6 ft	7	REF			
56483	80.8 to 81.8 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
34067	84.0 to 93.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	54	SF	\$120	\$6,534	
34071	97.4 to 99.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,122	
60027	98.5 to 124.8 feet	Driveway				REF			
34072	103.8 to 112.4 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	47	SF	\$40	\$1,892	
34075	114.9 to 123.6 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	48	SF	\$40	\$1,914	
34077	127.0 to 139.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	66	SF	\$120	\$7,920	
34080	139.2 to 141.9 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	15	SF	\$120	\$1,782	
60028	140.8 to 161.8 feet	Driveway				REF			
34082	147.5 to 148.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$220	
34083	163.1 to 166.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112	
34085	169.3 to 170.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	7	SF	\$120	\$858	
34086	174.3 to 180.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	35	SF	\$120	\$4,158	
34088	182.3 to 197.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	85	SF	\$120	\$10,230	
51252	199.7 to 200.7 feet	Vertical Change	-.3	6 ft	6	REF			
34092	200.6 to 208.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	41	SF	\$120	\$4,884	
34094	208.2 to 218.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	56	SF	\$120	\$6,666	
34096	218.3 to 219.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	9	SF	\$120	\$1,056	
60029	220.8 to 240.3 feet	Driveway				REF			
34097	224.4 to 229.3 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	27	SF	\$40	\$1,078	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251138	15TH ST	ROBERTSON BLVD	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34099	231.5 to 239.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	43	SF	\$40	\$1,716
57273	245.0 to 246.0 feet	Vertical Change	.8	6 ft	6	SF	\$75	\$413
34102	247.6 to 253.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630
34103	256.9 to 260.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640
51253	266.3 to 267.3 feet	Vertical Change	-.3	6 ft	6	REF		
34105	267.3 to 268.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
34106	272.8 to 275.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650
34107	279.9 to 285.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
34108	290.0 to 295.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,762
34111	295.7 to 300.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	28	SF	\$120	\$3,366
TOTAL COST FOR: SW side of 15TH ST Starting at: ROBERTSON BLVD							\$112,629.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909251141	KINGS AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56484	16.5 to 17.5 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
34114	23.3 to 30.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,752
155	27.4 to 28.4 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
34116	38.9 to 45.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224
60031	47.9 to 64.4 feet	Driveway				REF		
34118	49.0 to 54.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	29	SF	\$40	\$1,144
34121	56.8 to 65.8 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	50	SF	\$40	\$1,980
TOTAL COST FOR: SE side of KINGS AVE Starting at: SIDEWALK BEGINS							\$12,611.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909251143	KINGS AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60032	0.0 to 4.8 feet	Driveway				REF		
60033	35.0 to 49.8 feet	Driveway				REF		
56485	35.2 to 36.2 feet	Vertical Change	.4	6 ft	6	REF		
156	51.0 to 52.0 feet	Continuous Width		6 ft	6	SF	\$120	\$660
34125	62.8 to 67.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
34127	71.8 to 76.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904
34128	78.9 to 83.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
60034	93.6 to 102.1 feet	Driveway				REF		
34129	117.5 to 121.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838
34130	131.6 to 135.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,442
60035	144.1 to 152.2 feet	Driveway				REF		
TOTAL COST FOR: SE side of KINGS AVE Starting at: SIDEWALK BEGINS							\$14,652.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251151	13TH ST	SIDEWALK BEGINS	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60036	0.4 to 27.6 feet	Driveway				REF		
34132	1.3 to 2.3 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	5	SF	\$40	\$220
34133	5.8 to 9.6 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	21	SF	\$40	\$836
55618	12.3 to 13.3 feet	Vertical Change	.3	6 ft	6	REF		
34135	15.7 to 25.9 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	56	SF	\$40	\$2,244
41037	29.6 to 30.8 feet	Running Slope	6.0-7.0%	6 ft	7	SF	\$120	\$792
41038	30.8 to 31.8 feet	Running Slope	5.0-6.0%	6 ft	6	SF	\$120	\$660
34138	33.5 to 52.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	103	SF	\$120	\$12,408
34144	56.8 to 59.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914
34145	62.1 to 66.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,706
34148	66.9 to 72.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	29	SF	\$120	\$3,432
34150	74.3 to 80.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	31	SF	\$120	\$3,762
60037	79.7 to 111.7 feet	Driveway				REF		
34151	80.0 to 81.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	10	SF	\$40	\$396
34152	88.3 to 110.0 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	119	SF	\$40	\$4,774
34159	113.7 to 117.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	23	SF	\$120	\$2,772
34161	119.8 to 127.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,752
34164	127.0 to 134.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	42	SF	\$120	\$5,016
34166	135.7 to 144.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$6,006
TOTAL COST FOR: SW side of 13TH ST Starting at: SIDEWALK BEGINS							\$52,690.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SW	51909251154	13TH ST	KINGS AVE	ROBERTSON BLVD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
34169	6.4 to 14.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,148	
157	10.3 to 11.3 feet	Continuous Width		6 ft	6	SF	\$120	\$660	
34172	16.6 to 20.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772	
34173	23.4 to 33.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	55	SF	\$120	\$6,600	
34178	37.1 to 41.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640	
34180	44.1 to 49.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,762	
51254	48.4 to 49.4 feet	Vertical Change	-.3	6 ft	6	REF			
60038	76.8 to 91.4 feet	Driveway				REF			
34182	81.8 to 84.1 feet	Cross Slope (Driveway)	>15%	6 ft	13	SF	\$40	\$506	
34184	86.3 to 87.3 feet	Cross Slope (Driveway)	13.014	6 ft	6	SF	\$40	\$220	
34185	91.6 to 92.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
41039	92.6 to 94.5 feet	Running Slope	5.0-6.0%	6 ft	10	REF			
34186	95.2 to 104.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,808	
60039	103.4 to 129.4 feet	Driveway				REF			
34187	110.3 to 116.7 feet	Cross Slope (Driveway)	>15%	6 ft	35	SF	\$40	\$1,408	
34189	119.1 to 123.5 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	24	SF	\$40	\$968	
34191	126.1 to 127.2 feet	Cross Slope (Driveway)	13.014	6 ft	6	SF	\$40	\$242	
57089	131.1 to 132.1 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413	
34192	139.6 to 141.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188	
34193	146.6 to 151.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,970	
60040	149.9 to 165.6 feet	Driveway				REF			
34195	180.0 to 183.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	21	SF	\$120	\$2,574	
34197	183.9 to 192.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,742	
34198	199.7 to 211.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	67	SF	\$120	\$7,986	
34201	212.8 to 217.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	28	SF	\$120	\$3,300	
34203	217.8 to 225.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,818	
34205	227.6 to 231.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310	
34206	239.3 to 242.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251154	13TH ST	KINGS AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34207	257.6 to 263.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	33	SF	\$120	\$3,960
34208	268.6 to 273.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,498
34210	281.4 to 305.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	134	SF	\$120	\$16,104
47779	304.8 to 305.8 feet	Vertical Change	-4	6 ft	6	REF		
TOTAL COST FOR: SW side of 13TH ST Starting at: KINGS AVE							\$88,632.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909251157	KINGS AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60041	0.6 to 16.8 feet	Driveway				REF		
51256	19.1 to 20.1 feet	Vertical Change	-3	6 ft	6	LF	\$75	\$413
34217	20.5 to 26.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	34	SF	\$120	\$4,026
34220	26.9 to 31.6 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	26	SF	\$120	\$3,102
34222	36.4 to 47.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	62	SF	\$120	\$7,392
60042	45.6 to 57.0 feet	Driveway				REF		
34226	51.4 to 58.8 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	41	SF	\$40	\$1,628
TOTAL COST FOR: SE side of KINGS AVE Starting at: SIDEWALK BEGINS							\$16,560.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
SE	51909251159	KINGS AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
60043	30.0 to 45.8 feet	Driveway				REF					
51257	30.2 to 31.2 feet	Vertical Change	-3	6 ft	6	REF					
34228	35.6 to 41.6 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	33	SF	\$40	\$1,320			
34230	42.5 to 44.0 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	8	SF	\$40	\$330			
41040	44.0 to 45.2 feet	Running Slope	9.0-10.0%	6 ft	7	REF					
60044	48.3 to 68.6 feet	Driveway				REF					
34231	48.7 to 49.7 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	6	SF	\$40	\$220			
34232	54.2 to 65.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	61	SF	\$40	\$2,442			
34234	66.1 to 67.2 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	6	SF	\$40	\$242			
41041	67.1 to 68.1 feet	Running Slope	9.0-10.0%	6 ft	6	REF					
34235	68.3 to 69.3 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	6	SF	\$40	\$220			
34236	69.3 to 70.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	8	SF	\$40	\$308			
TOTAL COST FOR: SE							<i>side of</i>	KINGS AVE	<i>Starting at:</i>	SIDEWALK BEGINS	\$5,082.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909251200	KINGS AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60045	0.0 to 19.1 feet	Driveway				REF		
41042	19.2 to 20.2 feet	Running Slope	7.0-8.0%	6 ft	6	REF		
34241	20.3 to 42.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	119	SF	\$120	\$14,322
34244	46.8 to 48.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,056
34245	49.2 to 57.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346
51258	58.0 to 59.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
47780	68.0 to 69.0 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
34248	72.4 to 77.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630
60046	76.5 to 108.7 feet	Driveway				REF		
41184	78.6 to 79.6 feet	Vertical Change	-2.9	6 ft	6	REF		
34249	81.3 to 107.4 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	144	SF	\$40	\$5,742
55619	97.5 to 98.5 feet	Vertical Change	.3	6 ft	6	REF		
41043	106.1 to 107.1 feet	Running Slope	6.0-7.0%	6 ft	6	REF		
47781	107.7 to 108.7 feet	Vertical Change	-.4	6 ft	6	REF		
34258	112.4 to 119.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	38	SF	\$120	\$4,554
55620	117.9 to 118.9 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: SE side of KINGS AVE Starting at: SIDEWALK BEGINS							\$35,475.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	51909251204	11TH ST	KINGS AVE	ROBERTSON BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
34260	0.9 to 9.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	46	SF	\$120	\$5,544	
34262	14.2 to 19.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	30	SF	\$120	\$3,630	
34264	20.3 to 21.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
34265	24.2 to 75.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	281	SF	\$120	\$33,726	
51259	38.6 to 39.6 feet	Vertical Change	-3	6 ft	6	REF			
34276	78.0 to 96.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	103	SF	\$120	\$12,408	
34280	98.3 to 110.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	69	SF	\$120	\$8,250	
34282	111.1 to 116.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	28	SF	\$120	\$3,300	
34284	118.2 to 128.2 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	55	SF	\$120	\$6,600	
60047	129.8 to 158.2 feet	Driveway				REF			
34287	160.9 to 165.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	27	SF	\$120	\$3,234	
34288	184.8 to 188.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310	
34290	188.5 to 194.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	32	SF	\$120	\$3,828	
34292	198.9 to 204.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	32	SF	\$120	\$3,894	
34294	206.9 to 208.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858	
34295	209.2 to 220.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	61	SF	\$120	\$7,326	
34298	242.3 to 243.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990	
34299	246.6 to 247.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858	
60048	251.7 to 289.1 feet	Driveway				REF			
34300	257.7 to 259.1 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	8	SF	\$40	\$308	
34301	260.5 to 262.4 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	10	SF	\$40	\$418	
34302	267.3 to 268.5 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	7	SF	\$40	\$264	
51260	268.3 to 269.3 feet	Vertical Change	-3	6 ft	6	REF			
34303	271.9 to 273.2 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	7	SF	\$40	\$286	
34304	275.0 to 276.9 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	10	SF	\$40	\$418	
47782	276.3 to 277.3 feet	Vertical Change	-4	6 ft	6	REF			
34305	282.7 to 283.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$242	
TOTAL COST FOR: SW side of 11TH ST Starting at: KINGS AVE								\$99,484.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251205	11TH ST	ROBERTSON BLVD	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34310	16.7 to 28.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	64	SF	\$120	\$7,656
56486	28.0 to 29.0 feet	Vertical Change	.4	6 ft	6	REF		
34314	28.3 to 29.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
34315	31.5 to 43.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	64	SF	\$120	\$7,722
34322	44.2 to 62.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	100	SF	\$120	\$12,012
56850	68.4 to 69.4 feet	Vertical Change	.5	6 ft	6	REF		
34329	68.4 to 70.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	12	SF	\$120	\$1,386
34330	74.7 to 81.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	35	SF	\$120	\$4,158
55622	77.6 to 78.6 feet	Vertical Change	.3	6 ft	6	REF		
34332	84.2 to 91.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	39	SF	\$120	\$4,686
34335	94.0 to 102.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	47	SF	\$120	\$5,676
158	96.1 to 97.1 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
34339	107.8 to 109.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
34340	112.0 to 123.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	65	SF	\$120	\$7,788
34343	127.3 to 130.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	18	SF	\$120	\$2,178
34344	133.3 to 134.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
TOTAL COST FOR: NE side of 11TH ST Starting at: ROBERTSON BLVD							\$56,265.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251208	11TH ST	KINGS AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34348	16.3 to 20.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
43531	19.8 to 20.8 feet	Vertical Change	-.6	6 ft	6	REF		
51261	41.0 to 42.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
60049	79.2 to 97.6 feet	Driveway				REF		
55623	81.3 to 82.3 feet	Vertical Change	.3	6 ft	6	REF		
34350	86.6 to 92.1 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	30	SF	\$40	\$1,210
51262	107.9 to 108.9 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
34352	117.4 to 118.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
60050	117.7 to 133.6 feet	Driveway				REF		
34353	124.1 to 130.2 feet	Cross Slope (Driveway)	>15%	6 ft	34	SF	\$40	\$1,342
45418	131.8 to 132.8 feet	Vertical Change	-.5	6 ft	6	REF		
51263	135.9 to 136.9 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: NE							<i>side of 11TH ST Starting at: KINGS AVE</i>	\$7,221.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251212	11TH ST	RIVERSIDE AVE	LAKE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
159	25.1 to 26.1 feet	Continuous Width		6 ft	6	SF	\$120	\$660
60051	76.8 to 92.0 feet	Driveway				REF		
34354	127.8 to 128.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
60052	134.4 to 153.8 feet	Driveway				REF		
60053	158.8 to 173.3 feet	Driveway				REF		
41044	175.0 to 176.2 feet	Running Slope	6.0-7.0%	6 ft	7	SF	\$120	\$792
55624	272.8 to 273.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: NE side of 11TH ST Starting at: RIVERSIDE AVE								\$2,590.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251217	11TH ST	LAKE AVE	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34355	13.9 to 18.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
57614	40.7 to 41.7 feet	Vertical Change	3	6 ft	5	SF	\$75	\$413
60054	49.5 to 102.3 feet	Driveway				REF		
51264	49.8 to 50.8 feet	Vertical Change	-.3	6 ft	6	REF		
51265	57.8 to 58.8 feet	Vertical Change	-.3	6 ft	6	REF		
51266	111.3 to 112.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
60055	124.9 to 158.3 feet	Driveway				REF		
41045	151.4 to 153.0 feet	Running Slope	5.0-6.0%	6 ft	9	REF		
34356	158.6 to 159.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
47783	159.2 to 160.2 feet	Vertical Change	-.4	6 ft	6	REF		
160	170.5 to 171.5 feet	Continuous Width		6 ft	6	SF	\$120	\$660
34357	190.8 to 194.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640
34359	214.7 to 217.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046
34360	231.1 to 233.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254
34361	271.4 to 275.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,508
51267	274.7 to 275.7 feet	Vertical Change	-.3	6 ft	6	REF		
TOTAL COST FOR: NE side of 11TH ST Starting at: LAKE AVE							\$13,563.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251219	11TH ST	MONTEREY AVE	530 11TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
161	2.4 to 3.4 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
57554	8.3 to 9.3 feet	Vertical Change	2.3	6 ft	6	SF	\$75	\$413
51268	18.2 to 19.2 feet	Vertical Change	-3	6 ft	6	LF	\$75	\$413
34362	42.4 to 45.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848
60056	61.0 to 66.1 feet	Driveway				REF		
TOTAL COST FOR: NE side of 11TH ST Starting at: MONTEREY AVE							\$2,772.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251220	11TH ST	530 11TH ST	SONOMA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
45419	29.3 to 30.3 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413
162	39.7 to 40.7 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
60057	42.7 to 67.3 feet	Driveway				REF		
34363	63.8 to 67.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	23	SF	\$40	\$902
51269	65.7 to 66.7 feet	Vertical Change	-.3	6 ft	6	REF		
56487	68.1 to 69.1 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
163	68.3 to 69.3 feet	Continuous Width		6 ft	6	SF	\$120	\$660
41046	69.1 to 70.1 feet	Running Slope	5.0-6.0%	6 ft	6	SF	\$120	\$660
57445	71.0 to 72.0 feet	Vertical Change	1.3	6 ft	6	SF	\$75	\$413
34365	77.8 to 88.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	61	SF	\$120	\$7,260
51270	81.8 to 82.8 feet	Vertical Change	-.3	6 ft	6	REF		
34370	89.2 to 104.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	85	SF	\$120	\$10,164
55625	95.8 to 96.8 feet	Vertical Change	.3	6 ft	6	REF		
34377	107.0 to 111.9 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	27	SF	\$120	\$3,234
34379	115.6 to 142.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	150	SF	\$120	\$18,018
55626	137.8 to 138.8 feet	Vertical Change	.3	6 ft	6	REF		
34388	142.9 to 183.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	226	SF	\$120	\$27,060
34399	188.4 to 200.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	66	SF	\$120	\$7,920
41047	199.0 to 200.2 feet	Running Slope	6.0-7.0%	6 ft	7	REF		
TOTAL COST FOR: NE side of 11TH ST Starting at: 530 11TH ST							\$77,214.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251224	11TH ST	VENTURA AVE	SONOMA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34400	41.6 to 45.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244
34401	47.6 to 51.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	23	SF	\$40	\$924
60058	57.2 to 86.3 feet	Driveway				REF		
34402	88.7 to 89.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
34403	121.9 to 125.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	20	SF	\$120	\$2,376
34405	125.5 to 126.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
60059	128.3 to 149.4 feet	Driveway				REF		
47784	129.8 to 130.8 feet	Vertical Change	-.4	6 ft	6	REF		
60060	153.8 to 171.6 feet	Driveway				REF		
56851	179.2 to 180.2 feet	Vertical Change	.5	6 ft	6	REF		
34406	179.5 to 181.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254
56852	183.8 to 184.8 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
34407	273.9 to 275.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
TOTAL COST FOR: SW side of 11TH ST Starting at: VENTURA AVE								\$9,586.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251228	11TH ST	SONOMA AVE	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60061	46.8 to 68.0 feet	Driveway				REF		
60062	130.4 to 152.3 feet	Driveway				REF		
57391	143.7 to 144.7 feet	Vertical Change	1.1	6 ft	6	REF		
55627	186.6 to 187.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
60063	198.5 to 224.8 feet	Driveway				REF		
47785	200.3 to 201.3 feet	Vertical Change	-.4	6 ft	6	REF		
34408	212.5 to 220.8 feet	Cross Slope (Driveway)	>15%	6 ft	46	SF	\$40	\$1,826
60064	241.6 to 257.1 feet	Driveway				REF		
34409	250.6 to 252.4 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	10	SF	\$40	\$396
TOTAL COST FOR: SW side of 11TH ST Starting at: SONOMA AVE								\$2,634.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251231	11TH ST	MONTEREY AVE	RIVERSIDE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34410	0.3 to 10.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	56	SF	\$120	\$6,666
56488	1.5 to 2.5 feet	Vertical Change	.4	6 ft	6	REF		
34414	15.8 to 19.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376
34417	27.7 to 43.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	87	SF	\$120	\$10,428
60065	43.3 to 91.6 feet	Driveway				REF		
34421	44.4 to 46.2 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	10	SF	\$40	\$396
51271	52.8 to 53.8 feet	Vertical Change	-.3	6 ft	6	REF		
34422	95.3 to 117.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	122	SF	\$120	\$14,652
56489	97.4 to 98.4 feet	Vertical Change	.4	6 ft	6	REF		
34429	118.2 to 123.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	27	SF	\$120	\$3,234
34431	125.1 to 127.3 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	12	SF	\$120	\$1,452
34432	128.6 to 145.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	94	SF	\$120	\$11,286
34438	148.3 to 159.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	61	SF	\$120	\$7,326
34442	162.0 to 165.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112
34443	181.0 to 185.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640
34445	189.5 to 213.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	132	SF	\$120	\$15,840
34452	221.1 to 225.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
34454	228.8 to 238.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,402
34457	246.5 to 263.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	95	SF	\$120	\$11,352
34460	264.1 to 269.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	31	SF	\$120	\$3,762
34464	271.8 to 273.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386
34465	276.3 to 281.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,300
41053	307.4 to 309.2 feet	Running Slope	5.0-6.0%	6 ft	10	REF		
34469	308.1 to 363.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	304	SF	\$120	\$36,432
34482	364.4 to 383.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	105	SF	\$120	\$12,540
34490	388.3 to 417.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	158	SF	\$120	\$18,942
60067	413.9 to 482.0 feet	Driveway				REF		
34500	421.7 to 429.4 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	42	SF	\$40	\$1,694

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251231	11TH ST	MONTEREY AVE	RIVERSIDE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34502	429.4 to 452.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	129	SF	\$40	\$5,148
34508	453.5 to 456.0 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	14	SF	\$40	\$550
34509	460.3 to 479.1 feet	Cross Slope (Driveway)	>15%	6 ft	103	SF	\$40	\$4,136
34512	483.8 to 511.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	153	SF	\$120	\$18,414
34518	511.7 to 514.2 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	14	SF	\$120	\$1,650
34520	514.5 to 515.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858
34521	515.8 to 521.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
34524	526.8 to 536.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	55	SF	\$120	\$6,600
34527	536.8 to 585.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	267	SF	\$120	\$32,010
51272	570.1 to 571.1 feet	Vertical Change	-.3	6 ft	6	REF		
34538	589.8 to 605.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	88	SF	\$120	\$10,560
34542	606.6 to 615.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	51	SF	\$120	\$6,072
34544	616.0 to 617.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
34545	619.8 to 640.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	112	SF	\$120	\$13,464
55628	629.5 to 630.5 feet	Vertical Change	.3	6 ft	6	REF		
47786	632.3 to 633.3 feet	Vertical Change	-.4	6 ft	6	REF		
TOTAL COST FOR: SW side of 11TH ST Starting at: MONTEREY AVE							\$281,006.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251237	11TH ST	RIVERSIDE AVE	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34549	0.5 to 12.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	63	SF	\$120	\$7,590
34553	15.7 to 22.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	35	SF	\$120	\$4,224
34555	27.2 to 31.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	26	SF	\$120	\$3,102
34556	32.1 to 36.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,706
34558	36.2 to 40.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	25	SF	\$120	\$2,970
34560	41.3 to 42.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
60068	49.3 to 66.0 feet	Driveway				REF		
34561	56.7 to 58.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	7	SF	\$40	\$286
34562	69.6 to 89.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	109	SF	\$120	\$13,068
34564	90.6 to 103.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	69	SF	\$120	\$8,316
34569	103.9 to 107.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
60069	104.3 to 120.9 feet	Driveway				REF		
60070	131.9 to 149.8 feet	Driveway				REF		
34570	143.5 to 147.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	24	SF	\$40	\$946
34571	165.0 to 202.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	206	SF	\$120	\$24,684
34582	205.2 to 209.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	24	SF	\$120	\$2,838
34583	210.2 to 218.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	44	SF	\$120	\$5,280
34585	221.7 to 222.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
34586	226.5 to 238.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	64	SF	\$120	\$7,722
34589	245.2 to 255.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	59	SF	\$120	\$7,062
34593	259.3 to 261.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,188
34594	262.2 to 266.2 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	22	SF	\$120	\$2,640
34597	266.2 to 281.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	83	SF	\$120	\$9,966
34602	283.9 to 288.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,970
TOTAL COST FOR: SW side of 11TH ST Starting at: RIVERSIDE AVE							\$111,650.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251242	10TH ST	KINGS AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34603	0.9 to 4.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
164	55.8 to 56.8 feet	Continuous Width		6 ft	6	SF	\$120	\$660
34605	57.8 to 63.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,696
34606	77.2 to 84.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,016
34609	87.0 to 93.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	33	SF	\$120	\$3,960
34610	95.7 to 99.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,508
34611	114.4 to 117.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914
60071	118.3 to 132.5 feet	Driveway				REF		
34613	119.9 to 128.0 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	45	SF	\$40	\$1,782
55629	126.0 to 129.8 feet	Vertical Change	.3	6 ft	21	REF		
34616	129.7 to 132.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	16	SF	\$40	\$638
57486	130.6 to 131.6 feet	Vertical Change	1.6	6 ft	6	REF		
56490	133.1 to 135.8 feet	Vertical Change	.4	6 ft	15	LF	\$75	\$1,114
TOTAL COST FOR: NE side of 10TH ST Starting at: KINGS AVE							\$23,861.75	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251246	10TH ST	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60072	0.1 to 16.3 feet	Driveway				REF		
34617	1.3 to 9.3 feet	Cross Slope (Driveway)	14.0-15.0%	10 ft	80	SF	\$40	\$3,200
57274	2.3 to 3.3 feet	Vertical Change	.8	10 ft	10	REF		
34620	11.6 to 12.7 feet	Cross Slope (Driveway)	13.014	10 ft	11	SF	\$40	\$440
34621	18.4 to 20.1 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	17	SF	\$120	\$2,040
51273	37.9 to 38.9 feet	Vertical Change	-.3	10 ft	10	LF	\$75	\$750
TOTAL COST FOR: NE side of 10TH ST Starting at: SIDEWALK BEGINS								\$6,430.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251252	10TH ST	SIDEWALK BEGINS	LAKE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34622	3.8 to 12.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$5,940
34626	16.2 to 18.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	12	SF	\$120	\$1,386
60073	16.2 to 33.4 feet	Driveway				REF		
34627	19.3 to 21.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	14	SF	\$40	\$550
34628	36.2 to 79.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	240	SF	\$120	\$28,776
34641	82.8 to 112.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	162	SF	\$120	\$19,470
41054	93.1 to 94.2 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
34650	116.3 to 117.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
47787	124.2 to 125.2 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
47788	132.5 to 133.5 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
34651	133.6 to 135.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
41055	133.9 to 134.9 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
TOTAL COST FOR: NE side of 10TH ST Starting at: SIDEWALK BEGINS							\$58,597.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251306	10TH ST	LAKE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34652	5.8 to 7.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
34653	9.8 to 30.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	115	SF	\$120	\$13,794
55632	11.1 to 12.1 feet	Vertical Change	.3	6 ft	6	REF		
34660	32.8 to 35.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	13	SF	\$120	\$1,518
34661	35.4 to 36.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
34662	45.1 to 46.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
34663	50.0 to 55.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,498
34666	73.8 to 76.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914
34668	80.0 to 93.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	73	SF	\$120	\$8,778
56491	94.9 to 95.9 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
34673	96.2 to 106.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	57	SF	\$120	\$6,864
34675	108.0 to 109.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	8	SF	\$120	\$924
34676	111.9 to 124.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	72	SF	\$120	\$8,580
55633	125.2 to 126.2 feet	Vertical Change	.3	6 ft	6	REF		
34681	125.4 to 127.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	9	SF	\$120	\$1,056
34682	129.0 to 134.3 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	29	SF	\$120	\$3,498
TOTAL COST FOR: NE side of 10TH ST Starting at: LAKE AVE							\$53,740.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251308	10TH ST	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60074	0.3 to 12.0 feet	Driveway				REF		
34683	3.0 to 12.8 feet	Cross Slope (Driveway)	>15%	6 ft	54	SF	\$40	\$2,156
51274	18.3 to 19.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
55634	49.3 to 50.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: NE side of 10TH ST Starting at: SIDEWALK BEGINS								\$2,981.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251312	10TH ST	VENTURA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51275	0.7 to 1.7 feet	Vertical Change	-.3	6 ft	6	REF		
34684	1.1 to 4.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	16	SF	\$40	\$660
34686	4.1 to 6.0 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	10	SF	\$40	\$418
34687	9.4 to 14.3 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	27	SF	\$40	\$1,078
56492	11.8 to 12.8 feet	Vertical Change	.4	6 ft	6	REF		
34689	17.0 to 20.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	18	SF	\$120	\$2,178
34691	20.3 to 33.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	71	SF	\$120	\$8,580
34694	34.9 to 65.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	169	SF	\$120	\$20,262
56493	52.6 to 53.6 feet	Vertical Change	.4	6 ft	6	REF		
34702	68.0 to 73.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	32	SF	\$120	\$3,828
165	69.1 to 70.1 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
34704	77.4 to 90.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	71	SF	\$120	\$8,514
56494	85.5 to 86.5 feet	Vertical Change	.4	6 ft	6	REF		
34708	91.8 to 94.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,584
34709	96.4 to 108.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	67	SF	\$120	\$7,986
166	114.1 to 115.1 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
34712	115.3 to 130.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	85	SF	\$120	\$10,230
57528	115.4 to 116.4 feet	Vertical Change	2	6 ft	6	REF		
55635	123.8 to 129.3 feet	Vertical Change	.3	6 ft	30	REF		
55637	131.4 to 132.4 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
60075	131.6 to 149.8 feet	Driveway				REF		
55638	135.0 to 136.0 feet	Vertical Change	.3	6 ft	6	REF		
57090	136.8 to 137.8 feet	Vertical Change	.6	6 ft	6	REF		
34715	139.5 to 146.4 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	38	SF	\$40	\$1,518
51276	144.0 to 145.0 feet	Vertical Change	-.3	6 ft	6	REF		
34717	148.5 to 150.9 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	13	SF	\$40	\$528
TOTAL COST FOR: SW side of 10TH ST Starting at: VENTURA AVE							\$67,974.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251313	10TH ST	SONOMA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34718	0.5 to 7.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,554
51277	1.8 to 2.8 feet	Vertical Change	-.3	6 ft	6	REF		
55639	6.9 to 7.9 feet	Vertical Change	.3	6 ft	6	REF		
47789	11.8 to 12.8 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
34721	13.0 to 43.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	168	SF	\$120	\$20,196
51278	16.9 to 17.9 feet	Vertical Change	-.3	6 ft	6	REF		
51279	21.9 to 22.9 feet	Vertical Change	-.3	6 ft	6	REF		
51280	27.0 to 28.0 feet	Vertical Change	-.3	6 ft	6	REF		
51281	32.1 to 33.1 feet	Vertical Change	-.3	6 ft	6	REF		
43532	37.1 to 38.1 feet	Vertical Change	-.6	6 ft	6	REF		
51282	42.2 to 43.2 feet	Vertical Change	-.3	6 ft	6	REF		
TOTAL COST FOR: SW side of 10TH ST Starting at: SONOMA AVE							\$25,162.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
SW	51909251316	10TH ST	MONTEREY AVE	SIDEWALK ENDS				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34730	4.1 to 8.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
34732	10.5 to 12.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
34733	16.3 to 23.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,488
60076	21.7 to 47.8 feet	Driveway				REF		
55640	23.3 to 24.3 feet	Vertical Change	.3	6 ft	6	REF		
34734	26.6 to 30.3 feet	Cross Slope (Driveway)	13.014	6 ft	20	SF	\$40	\$814
34737	32.5 to 44.0 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	63	SF	\$40	\$2,530
41056	47.3 to 48.6 feet	Running Slope	6.0-7.0%	6 ft	7	REF		
41057	49.7 to 51.1 feet	Running Slope	5.0-6.0%	6 ft	8	SF	\$120	\$924
57275	51.2 to 52.2 feet	Vertical Change	.8	6 ft	6	SF	\$75	\$413
34741	53.7 to 65.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	64	SF	\$120	\$7,656
34744	69.0 to 74.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,432
47790	73.6 to 74.6 feet	Vertical Change	-.4	6 ft	6	REF		
34745	79.3 to 90.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	62	SF	\$120	\$7,392
47791	96.2 to 97.2 feet	Vertical Change	-.4	6 ft	6	REF		
34746	96.5 to 100.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376
34748	114.5 to 116.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518
55641	118.8 to 119.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
34749	122.9 to 126.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310
51283	128.7 to 129.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413

TOTAL COST FOR: SW side of 10TH ST Starting at: MONTEREY AVE \$38,637.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251317	10TH ST	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34750	0.0 to 1.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
60077	0.3 to 21.9 feet	Driveway				REF		
47792	0.6 to 1.6 feet	Vertical Change	-.4	6 ft	6	REF		
34751	4.7 to 20.9 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	89	SF	\$40	\$3,564
41058	21.6 to 22.8 feet	Running Slope	5.0-6.0%	6 ft	7	REF		
47793	22.8 to 23.8 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
34756	24.2 to 31.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	41	SF	\$120	\$4,884
34757	31.6 to 60.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	158	SF	\$120	\$18,942
TOTAL COST FOR: SW side of 10TH ST Starting at: SIDEWALK BEGINS							\$28,528.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251323	10TH ST	SIDEWALK BEGINS	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34763	0.4 to 4.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838
56496	6.2 to 7.2 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
56497	16.4 to 17.4 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
51284	28.5 to 29.8 feet	Vertical Change	-.3	6 ft	7	LF	\$75	\$536
60078	51.5 to 82.3 feet	Driveway				REF		
41059	83.9 to 85.6 feet	Running Slope	5.0-6.0%	6 ft	9	SF	\$120	\$1,122
34764	86.3 to 87.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$990
34765	91.4 to 98.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,752
34768	108.3 to 110.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650
34769	114.6 to 117.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046
56853	116.3 to 117.3 feet	Vertical Change	.5	6 ft	6	REF		
34771	129.8 to 135.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630
TOTAL COST FOR: SW side of 10TH ST Starting at: SIDEWALK BEGINS							\$18,389.25	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251325	10TH ST	ROBERTSON BLVD	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34772	6.1 to 13.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,620
56498	28.5 to 29.5 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
34774	37.2 to 43.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,158
34777	47.2 to 49.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	11	SF	\$120	\$1,320
34778	50.6 to 54.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,706
56499	71.5 to 72.5 feet	Vertical Change	.4	6 ft	6	REF		
34780	72.3 to 74.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650
34782	97.2 to 104.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	41	SF	\$120	\$4,950
34785	104.7 to 126.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	118	SF	\$120	\$14,190
34794	126.2 to 128.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386
34795	133.4 to 139.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894
60079	134.9 to 156.1 feet	Driveway				REF		
34798	152.7 to 153.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	7	SF	\$40	\$264
34799	163.2 to 167.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
34801	181.0 to 184.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178
34802	186.4 to 208.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	120	SF	\$120	\$14,454
34806	211.4 to 218.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	41	SF	\$120	\$4,950
34807	227.9 to 234.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224
34808	238.1 to 242.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,970
34810	261.5 to 266.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
34812	277.8 to 282.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,102
34813	288.2 to 294.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,828
TOTAL COST FOR: NE side of 10TH ST Starting at: ROBERTSON BLVD							\$81,394.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909251329	KINGS AVE	10TH ST	9TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34814	0.3 to 2.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452
51285	3.4 to 4.4 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
34815	8.5 to 14.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	32	SF	\$120	\$3,828
34817	15.7 to 16.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
34818	21.9 to 61.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	215	SF	\$120	\$25,806
167	41.9 to 42.9 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
60080	54.7 to 64.3 feet	Driveway				REF		
55642	83.2 to 84.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
34822	122.0 to 132.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	60	SF	\$120	\$7,194
34824	144.3 to 153.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	52	SF	\$120	\$6,270
34827	161.9 to 166.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,300
60081	164.3 to 173.8 feet	Driveway				REF		
56854	170.7 to 171.7 feet	Vertical Change	.5	6 ft	6	REF		
34828	180.0 to 183.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
60082	184.6 to 196.0 feet	Driveway				REF		
34830	188.0 to 193.9 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	32	SF	\$40	\$1,298
34833	194.1 to 196.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	14	SF	\$40	\$550
55643	236.6 to 237.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
34834	244.2 to 252.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,742
57210	246.3 to 247.3 feet	Vertical Change	.7	6 ft	6	REF		
34837	260.9 to 264.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640
34838	272.2 to 274.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
34839	276.4 to 280.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
34840	283.3 to 288.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630
TOTAL COST FOR: SE side of KINGS AVE Starting at: 10TH ST							\$70,438.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SW	51909251331	9TH ST	KINGS AVE	ROBERTSON BLVD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
34842	0.4 to 5.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	28	SF	\$120	\$3,300	
168	0.8 to 1.8 feet	Continuous Width		6 ft	6	SF	\$120	\$660	
34844	5.4 to 12.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,422	
57648	6.4 to 7.4 feet	Vertical Change	3.4	6 ft	6	REF			
55644	13.9 to 14.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
34846	16.5 to 33.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	93	SF	\$120	\$11,154	
60083	40.2 to 50.8 feet	Driveway				REF			
34850	51.3 to 55.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	23	SF	\$40	\$902	
41429	56.3 to 57.3 feet	Vertical Change	-1.2	6 ft	6	SF	\$75	\$413	
47795	56.5 to 58.0 feet	Vertical Change	-.4	6 ft	8	LF	\$75	\$619	
34851	61.2 to 68.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,082	
34852	72.2 to 73.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858	
34853	76.5 to 84.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,148	
51286	111.5 to 112.5 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
34856	113.4 to 118.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	26	SF	\$120	\$3,102	
34859	121.0 to 122.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,056	
34860	124.0 to 126.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848	
60084	136.3 to 153.7 feet	Driveway				REF			
56500	136.5 to 144.0 feet	Vertical Change	.4	6 ft	41	REF			
34862	137.8 to 139.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	10	SF	\$40	\$396	
34863	146.4 to 147.4 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	6	SF	\$40	\$220	
34864	152.0 to 155.3 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	18	SF	\$40	\$726	
34866	156.1 to 160.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	26	SF	\$120	\$3,102	
60085	163.4 to 180.8 feet	Driveway				REF			
34869	164.1 to 165.4 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	7	SF	\$40	\$286	
34870	169.6 to 179.3 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	53	SF	\$40	\$2,134	
34873	184.3 to 208.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	135	SF	\$120	\$16,236	
34879	214.1 to 222.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346	
60086	220.0 to 236.0 feet	Driveway				REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251331	9TH ST	KINGS AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34881	225.9 to 234.9 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	50	SF	\$40	\$1,980
34884	240.0 to 262.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	124	SF	\$120	\$14,850
34891	267.6 to 283.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	87	SF	\$120	\$10,494
TOTAL COST FOR: SW side of 9TH ST Starting at: KINGS AVE							\$95,158.25	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251333	9TH ST	ROBERTSON BLVD	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34896	4.1 to 12.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,214
47796	4.8 to 5.8 feet	Vertical Change	-.4	6 ft	6	REF		
51287	14.7 to 15.7 feet	Vertical Change	-.3	6 ft	6	REF		
34899	15.5 to 19.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
34900	28.3 to 29.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
34901	34.3 to 38.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640
43533	44.9 to 45.9 feet	Vertical Change	-.6	6 ft	6	SF	\$75	\$413
34902	64.9 to 68.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
34903	72.4 to 74.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
55647	74.9 to 75.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
34904	80.8 to 87.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,356
41571	84.9 to 85.9 feet	Vertical Change	-1	6 ft	6	REF		
34906	90.7 to 96.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	31	SF	\$120	\$3,696
51288	95.0 to 96.0 feet	Vertical Change	-.3	6 ft	6	REF		
34909	96.3 to 104.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,214
34912	106.6 to 111.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,102
51289	115.1 to 116.1 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
34913	131.2 to 133.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650
60087	132.4 to 155.4 feet	Driveway				REF		
34914	136.4 to 137.7 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	7	SF	\$40	\$286
34915	138.3 to 139.3 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	6	SF	\$40	\$220
34916	140.8 to 143.6 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	15	SF	\$40	\$616
34918	143.9 to 151.9 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	44	SF	\$40	\$1,760
34919	153.4 to 156.7 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	18	SF	\$40	\$726
34920	157.4 to 158.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$792
34921	158.8 to 171.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	71	SF	\$120	\$8,580
60088	175.6 to 203.4 feet	Driveway				REF		
34925	179.9 to 181.0 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	6	SF	\$40	\$242

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251333	9TH ST	ROBERTSON BLVD	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34926	182.5 to 187.8 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	29	SF	\$40	\$1,166
55648	184.3 to 185.3 feet	Vertical Change	.3	6 ft	6	REF		
34928	190.5 to 200.2 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	53	SF	\$40	\$2,134
41060	202.7 to 204.3 feet	Running Slope	5.0-6.0%	6 ft	9	REF		
56855	206.8 to 207.8 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
34930	209.9 to 232.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	126	SF	\$120	\$15,114
34932	233.6 to 241.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	44	SF	\$120	\$5,280
34936	241.6 to 242.8 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	7	SF	\$120	\$792
34937	242.8 to 248.7 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	32	SF	\$120	\$3,894
60089	244.4 to 283.1 feet	Driveway				REF		
34940	277.9 to 279.8 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	10	SF	\$40	\$418
34941	280.0 to 281.3 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	7	SF	\$40	\$286
56856	281.4 to 282.4 feet	Vertical Change	.5	6 ft	6	REF		
34942	282.8 to 283.8 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	6	SF	\$40	\$220
34943	283.8 to 290.1 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	35	SF	\$120	\$4,158
55649	287.1 to 291.1 feet	Vertical Change	.3	6 ft	22	REF		
TOTAL COST FOR: NE side of 9TH ST Starting at: ROBERTSON BLVD							\$81,202.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
NE	51909251336	9TH ST	KINGS AVE	SIDEWALK ENDS				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34946	0.0 to 2.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518
56502	2.5 to 3.5 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
57211	4.6 to 5.6 feet	Vertical Change	.7	6 ft	6	SF	\$75	\$413
34947	19.3 to 35.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	91	SF	\$120	\$10,890
57212	23.6 to 24.6 feet	Vertical Change	.7	6 ft	6	REF		
34951	38.5 to 40.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	12	SF	\$120	\$1,386
34952	40.8 to 44.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310
34953	48.3 to 59.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	61	SF	\$120	\$7,260
34959	64.0 to 68.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	26	SF	\$120	\$3,102
55651	71.8 to 72.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
34960	77.6 to 89.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	66	SF	\$120	\$7,920
34961	102.8 to 104.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
34962	113.1 to 121.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,412
55652	122.9 to 123.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: NE							<i>side of 9TH ST Starting at: KINGS AVE</i>	\$42,438.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251340	9TH ST	SIDEWALK BEGINS	LAKE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34964	0.3 to 3.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$1,980
34965	4.4 to 17.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	74	SF	\$120	\$8,844
34971	19.0 to 28.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	52	SF	\$120	\$6,204
34974	42.3 to 47.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
55653	45.3 to 46.3 feet	Vertical Change	.3	6 ft	6	REF		
34976	51.1 to 53.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650
34977	56.1 to 91.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	196	SF	\$120	\$23,496
51290	66.8 to 67.8 feet	Vertical Change	-.3	6 ft	6	REF		
60090	88.9 to 112.3 feet	Driveway				REF		
55654	90.8 to 91.8 feet	Vertical Change	.3	6 ft	6	REF		
34983	96.2 to 105.7 feet	Cross Slope (Driveway)	>15%	6 ft	52	SF	\$40	\$2,090
34986	105.7 to 108.5 feet	Cross Slope (Driveway)	13.014	6 ft	15	SF	\$40	\$616
41061	111.3 to 112.9 feet	Running Slope	6.0-7.0%	6 ft	9	REF		
56857	111.8 to 112.8 feet	Vertical Change	.5	6 ft	6	REF		
34987	113.4 to 121.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,016
34989	121.5 to 129.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	45	SF	\$120	\$5,346
TOTAL COST FOR: NE side of 9TH ST Starting at: SIDEWALK BEGINS							\$58,806.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251341	9TH ST	LAKE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
34990	2.2 to 17.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	86	SF	\$120	\$10,296
55655	22.2 to 23.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
34993	23.9 to 31.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,752
34995	37.3 to 39.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386
34996	43.6 to 45.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452
56503	47.3 to 48.3 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
34997	55.9 to 60.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904
60091	79.3 to 97.0 feet	Driveway				REF		
47797	97.4 to 98.4 feet	Vertical Change	-.4	6 ft	6	REF		
TOTAL COST FOR: NE side of 9TH ST Starting at: LAKE AVE							\$21,615.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251344	9TH ST	MONTEREY AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56858	23.6 to 24.6 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
55656	56.8 to 57.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
56859	67.6 to 68.6 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
57392	73.3 to 74.3 feet	Vertical Change	1.1	6 ft	6	SF	\$75	\$413
43534	75.8 to 76.8 feet	Vertical Change	-.6	6 ft	6	SF	\$75	\$413
60092	87.5 to 102.9 feet	Driveway				REF		
34999	97.4 to 98.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	8	SF	\$40	\$308
TOTAL COST FOR: NE side of 9TH ST Starting at: MONTEREY AVE								\$2,370.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251346	9TH ST	SIDEWALK BEGINS	SONOMA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35000	0.5 to 2.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,056
35001	4.1 to 5.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
35002	11.3 to 14.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310
35005	22.8 to 26.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,706
35007	29.3 to 37.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,214
60093	36.0 to 53.3 feet	Driveway				REF		
35008	40.8 to 48.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	41	SF	\$40	\$1,650
35010	58.7 to 62.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
51291	75.0 to 76.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
35011	76.8 to 78.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386
55657	95.3 to 96.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
51292	105.7 to 106.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
43535	105.8 to 106.8 feet	Vertical Change	-.6	6 ft	6	SF	\$75	\$413
51293	106.0 to 107.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
56504	108.7 to 109.7 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
51294	128.7 to 129.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: NE side of 9TH ST Starting at: SIDEWALK BEGINS							\$20,839.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251347	9TH ST	SONOMA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35012	0.0 to 4.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168
41062	0.0 to 2.1 feet	Running Slope	9.0-10.0%	6 ft	12	REF		
56860	4.6 to 5.6 feet	Vertical Change	.5	6 ft	6	REF		
57213	22.2 to 23.2 feet	Vertical Change	.7	6 ft	6	SF	\$75	\$413
35013	55.5 to 63.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,016
55658	64.8 to 65.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
35015	121.1 to 134.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	73	SF	\$120	\$8,712
TOTAL COST FOR: NE side of 9TH ST Starting at: SONOMA AVE							\$17,721.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251348	9TH ST	SIDEWALK BEGINS	VENTURA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60094	15.4 to 37.9 feet	Driveway				REF		
35018	16.1 to 18.4 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	23	SF	\$40	\$920
35019	42.9 to 51.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	84	SF	\$120	\$10,080
60095	43.8 to 64.7 feet	Driveway				REF		
35023	56.3 to 59.8 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	35	SF	\$40	\$1,400
35024	69.2 to 85.2 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	160	SF	\$120	\$19,200
35026	99.8 to 103.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	40	SF	\$120	\$4,800
35027	111.0 to 125.2 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	142	SF	\$120	\$17,040
TOTAL COST FOR: NE side of 9TH ST Starting at: SIDEWALK BEGINS							\$53,440.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251350	9TH ST	VENTURA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41063	0.0 to 2.1 feet	Running Slope	5.0-6.0%	6 ft	12	SF	\$120	\$1,386
56861	2.7 to 3.7 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
35030	10.0 to 29.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	107	SF	\$120	\$12,870
56505	11.8 to 12.8 feet	Vertical Change	.4	6 ft	6	REF		
60096	11.8 to 25.2 feet	Driveway				REF		
35036	33.8 to 66.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	180	SF	\$120	\$21,582
60097	63.7 to 95.4 feet	Driveway				REF		
35047	113.3 to 129.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	88	SF	\$120	\$10,560
TOTAL COST FOR: SW side of 9TH ST Starting at: VENTURA AVE							\$46,810.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251351	9TH ST	SIDEWALK BEGINS	SONOMA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41064	0.0 to 1.5 feet	Running Slope	5.0-6.0%	6 ft	8	SF	\$120	\$990
57615	15.8 to 16.8 feet	Vertical Change	3	6 ft	6	SF	\$75	\$413
60098	18.7 to 38.9 feet	Driveway				REF		
35051	26.8 to 36.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	53	SF	\$40	\$2,134
47798	71.2 to 72.2 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
57091	78.4 to 79.4 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413
35054	83.8 to 102.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	102	SF	\$120	\$12,276
56506	103.7 to 104.7 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
35061	130.6 to 134.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	19	SF	\$120	\$2,244

TOTAL COST FOR: SW side of 9TH ST Starting at: SIDEWALK BEGINS \$19,294.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251354	9TH ST	MONTEREY AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55659	9.5 to 10.5 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
55660	19.4 to 20.4 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
56507	24.4 to 25.4 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
60099	38.8 to 65.4 feet	Driveway				REF		
51295	39.3 to 40.3 feet	Vertical Change	-.3	6 ft	6	REF		
35062	45.7 to 51.3 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	31	SF	\$40	\$1,232
35065	53.2 to 58.4 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	29	SF	\$40	\$1,144
35067	63.2 to 65.9 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	15	SF	\$40	\$594
45423	71.7 to 72.7 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413
51296	82.3 to 83.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
51297	92.8 to 93.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
51298	97.8 to 98.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
35069	101.3 to 111.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	56	SF	\$120	\$6,732
55661	108.5 to 109.5 feet	Vertical Change	.3	6 ft	6	REF		
60100	111.5 to 125.9 feet	Driveway				REF		
TOTAL COST FOR: SW side of 9TH ST Starting at: MONTEREY AVE							\$12,589.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251356	9TH ST	SIDEWALK BEGINS	LAKE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35070	0.0 to 3.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	18	SF	\$120	\$2,178
55662	0.2 to 1.2 feet	Vertical Change	.3	6 ft	6	REF		
60101	1.5 to 16.4 feet	Driveway				REF		
35071	5.0 to 7.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	12	SF	\$40	\$462
35072	15.3 to 17.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	14	SF	\$40	\$550
55663	18.2 to 19.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
35074	24.6 to 29.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,498
35076	32.8 to 37.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	28	SF	\$120	\$3,300
35077	40.3 to 43.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310
35078	45.1 to 57.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	68	SF	\$120	\$8,118
TOTAL COST FOR: SW side of 9TH ST Starting at: SIDEWALK BEGINS							\$20,828.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251357	9TH ST	LAKE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56508	0.5 to 1.5 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
57446	2.2 to 3.2 feet	Vertical Change	1.3	6 ft	5	SF	\$75	\$413
35080	9.8 to 14.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904
56509	13.8 to 14.8 feet	Vertical Change	.4	6 ft	6	REF		
56862	26.6 to 27.6 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
169	49.3 to 50.3 feet	Continuous Width		6 ft	6	SF	\$120	\$660
55664	56.7 to 57.7 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
55665	79.0 to 81.9 feet	Vertical Change	.3	6 ft	16	LF	\$75	\$1,196
35081	81.6 to 82.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
55667	84.3 to 85.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
60102	91.8 to 108.9 feet	Driveway				REF		
57214	100.8 to 101.8 feet	Vertical Change	.7	6 ft	6	REF		
35082	101.4 to 104.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	14	SF	\$40	\$572
56510	114.3 to 115.3 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
35083	131.8 to 136.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
55668	135.5 to 136.5 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: SW side of 9TH ST Starting at: LAKE AVE							\$11,701.25	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251401	9TH ST	RIVERSIDE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35084	0.0 to 1.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$990
41572	2.9 to 3.9 feet	Vertical Change	-1	6 ft	6	SF	\$75	\$413
51299	4.9 to 5.9 feet	Vertical Change	-.3	6 ft	5	LF	\$75	\$413
57092	5.3 to 6.3 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413
60103	17.5 to 25.8 feet	Driveway				REF		
55669	27.4 to 28.4 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
60104	48.8 to 55.1 feet	Driveway				REF		
51300	62.6 to 63.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
60105	76.1 to 84.8 feet	Driveway				REF		
51301	97.6 to 98.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
60106	106.3 to 114.6 feet	Driveway				REF		
35085	107.6 to 114.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	40	SF	\$40	\$1,606
56511	120.3 to 121.3 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413

TOTAL COST FOR: SW	<i>side of 9TH ST Starting at: RIVERSIDE AVE</i>	\$5,483.50
---------------------------	--	-------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	51909251404	KINGS AVE	9TH ST	8TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
35088	1.1 to 3.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452	
41318	4.9 to 5.9 feet	Vertical Change	-1.5	6 ft	5	SF	\$75	\$413	
55670	5.3 to 6.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
35089	12.5 to 21.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	48	SF	\$120	\$5,808	
35091	24.3 to 34.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	55	SF	\$120	\$6,600	
43536	31.5 to 32.5 feet	Vertical Change	-.6	6 ft	6	REF			
35094	36.4 to 45.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	52	SF	\$120	\$6,270	
56863	39.4 to 40.4 feet	Vertical Change	.5	6 ft	6	REF			
35097	49.0 to 64.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	84	SF	\$120	\$10,098	
57215	49.4 to 50.4 feet	Vertical Change	.7	6 ft	6	REF			
35102	64.3 to 70.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,290	
35104	71.8 to 86.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	80	SF	\$120	\$9,636	
35111	86.6 to 87.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
41242	86.9 to 87.9 feet	Vertical Change	-1.9	6 ft	6	REF			
60107	88.3 to 101.8 feet	Driveway				REF			
35112	107.2 to 110.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376	
45424	111.7 to 112.7 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413	
35113	116.3 to 120.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,970	
56512	126.7 to 127.7 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
35115	128.7 to 129.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
35116	134.3 to 136.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320	
51302	143.7 to 144.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
60108	145.3 to 149.2 feet	Driveway				REF			
35117	161.4 to 162.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
56513	171.2 to 172.2 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
35118	180.3 to 181.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	9	SF	\$120	\$1,056	
42354	181.4 to 182.4 feet	Vertical Change	-.7	6 ft	6	REF			
51303	183.8 to 184.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909251404	KINGS AVE	9TH ST	8TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56514	210.8 to 211.8 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
55671	218.4 to 219.4 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
55672	225.7 to 226.7 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
56864	235.8 to 236.8 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
56515	243.3 to 244.3 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
47799	270.8 to 271.8 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: SE side of KINGS AVE Starting at: 9TH ST							\$59,482.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	51909251406	8TH ST	KINGS AVE	ROBERTSON BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
55673	13.6 to 14.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
55674	23.5 to 24.5 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
55675	47.8 to 48.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
55676	57.8 to 58.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
55677	65.7 to 66.7 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
57093	73.5 to 74.5 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413	
43537	88.0 to 89.0 feet	Vertical Change	-.6	6 ft	6	SF	\$75	\$413	
57323	88.1 to 89.1 feet	Vertical Change	.9	6 ft	6	SF	\$75	\$413	
57094	93.2 to 94.2 feet	Vertical Change	.6	6 ft	6	REF			
35119	94.0 to 95.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858	
55678	97.8 to 98.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
60109	99.4 to 116.4 feet	Driveway				REF			
56516	102.5 to 103.5 feet	Vertical Change	.4	6 ft	6	REF			
35120	121.6 to 125.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772	
56517	125.7 to 126.7 feet	Vertical Change	.4	6 ft	6	REF			
55679	135.1 to 136.1 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
60110	135.5 to 157.2 feet	Driveway				REF			
35121	153.8 to 156.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	15	SF	\$40	\$616	
35123	157.6 to 161.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	21	SF	\$120	\$2,508	
35125	161.4 to 162.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
60111	162.8 to 176.1 feet	Driveway				REF			
45425	163.3 to 164.3 feet	Vertical Change	-.5	6 ft	5	REF			
55680	175.9 to 176.9 feet	Vertical Change	.3	6 ft	6	REF			
35126	179.8 to 181.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
35127	186.8 to 188.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254	
51304	198.4 to 199.4 feet	Vertical Change	-.3	6 ft	6	REF			
35128	199.1 to 200.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990	
35129	207.9 to 235.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	150	SF	\$120	\$18,018	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251406	8TH ST	KINGS AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57095	218.4 to 219.4 feet	Vertical Change	.6	6 ft	6	REF		
35137	235.2 to 240.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,300
35140	256.2 to 266.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	59	SF	\$120	\$7,062
35144	268.8 to 292.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	130	SF	\$120	\$15,576
41065	293.5 to 294.8 feet	Running Slope	5.0-6.0%	6 ft	7	SF	\$120	\$858
41066	294.8 to 296.8 feet	Running Slope	6.0-7.0%	6 ft	11	SF	\$120	\$1,320
TOTAL COST FOR: SW side of 8TH ST Starting at: KINGS AVE							\$60,841.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251409	8TH ST	ROBERTSON BLVD	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51305	4.0 to 5.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
35148	12.3 to 13.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
35149	25.3 to 28.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376
35150	35.0 to 54.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	109	SF	\$120	\$13,068
35157	60.9 to 73.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	70	SF	\$120	\$8,448
35161	78.5 to 82.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640
35163	85.7 to 87.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452
35164	98.8 to 116.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	97	SF	\$120	\$11,682
170	132.1 to 133.1 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
60112	134.8 to 154.9 feet	Driveway				REF		
35166	142.5 to 172.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	165	SF	\$40	\$6,600
51306	144.3 to 145.3 feet	Vertical Change	-.3	6 ft	6	REF		
171	223.8 to 224.8 feet	Continuous Width		6 ft	6	SF	\$120	\$660
35176	243.1 to 249.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224
TOTAL COST FOR: NE side of 8TH ST Starting at: ROBERTSON BLVD							\$52,387.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909251410	KINGS AVE	8TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35178	8.3 to 9.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
35179	21.5 to 23.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,584
60113	52.6 to 79.9 feet	Driveway				REF		
TOTAL COST FOR: SE side of KINGS AVE Starting at: 8TH ST							\$2,574.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251414	8TH ST	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35180	0.3 to 6.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	33	SF	\$120	\$3,960
60114	3.8 to 12.8 feet	Driveway				REF		
35181	28.1 to 38.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	58	SF	\$120	\$6,930
55681	35.1 to 36.1 feet	Vertical Change	.3	6 ft	6	REF		
60115	43.2 to 60.6 feet	Driveway				REF		
56518	68.9 to 71.9 feet	Vertical Change	.4	6 ft	17	LF	\$75	\$1,238
TOTAL COST FOR: NE side of 8TH ST Starting at: SIDEWALK BEGINS							\$12,127.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251418	8TH ST	SIDEWALK BEGINS	LAKE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35186	0.0 to 1.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660
60116	1.1 to 30.6 feet	Driveway				REF		
35187	5.8 to 28.1 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	123	SF	\$40	\$4,906
55683	16.4 to 17.4 feet	Vertical Change	.3	6 ft	6	REF		
35193	28.1 to 29.1 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	6	SF	\$40	\$220
41067	30.4 to 32.2 feet	Running Slope	6.0-7.0%	6 ft	10	REF		
35194	100.6 to 109.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	49	SF	\$120	\$5,874
57668	120.5 to 121.5 feet	Vertical Change	3.5	6 ft	6	SF	\$75	\$413
35196	123.1 to 127.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640
TOTAL COST FOR: NE side of 8TH ST Starting at: SIDEWALK BEGINS							\$14,712.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251419	8TH ST	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35197	0.0 to 4.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	24	SF	\$120	\$2,838
35198	7.1 to 14.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	42	SF	\$120	\$5,082
35200	15.3 to 16.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
35201	24.3 to 60.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	201	SF	\$120	\$24,156
60117	28.7 to 37.9 feet	Driveway				REF		
55684	41.6 to 42.6 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: NE side of 8TH ST Starting at: SIDEWALK BEGINS							\$33,132.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251421	8TH ST	MONTEREY AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35213	0.0 to 8.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,676
55685	2.8 to 3.8 feet	Vertical Change	.3	6 ft	6	REF		
35216	9.6 to 15.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	35	SF	\$120	\$4,158
56519	9.8 to 10.8 feet	Vertical Change	.4	6 ft	5	REF		
35218	20.2 to 22.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	15	SF	\$120	\$1,782
35219	22.9 to 24.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254
35220	30.4 to 40.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	55	SF	\$40	\$2,200
51307	37.6 to 38.6 feet	Vertical Change	-.3	6 ft	6	REF		
35224	51.4 to 54.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$1,980
35225	69.5 to 70.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
35226	76.5 to 92.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	86	SF	\$120	\$10,296
35229	95.7 to 105.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,138
35231	111.1 to 112.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
35232	118.1 to 122.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
35233	128.3 to 135.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,488
TOTAL COST FOR: NE side of 8TH ST Starting at: MONTEREY AVE							\$42,130.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251425	8TH ST	VENTURA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35234	0.8 to 4.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178
35235	50.1 to 54.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838
60118	68.3 to 90.1 feet	Driveway				REF		
35237	74.9 to 79.0 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	23	SF	\$40	\$902
35239	80.8 to 82.8 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	11	SF	\$40	\$440
35240	84.8 to 85.9 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	6	SF	\$40	\$242
35241	85.9 to 87.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	10	SF	\$40	\$418
TOTAL COST FOR: SW side of 8TH ST Starting at: VENTURA AVE							\$7,018.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251431	8TH ST	SIDEWALK BEGINS	RIVERSIDE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35242	0.0 to 1.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
60119	0.9 to 25.3 feet	Driveway				REF		
35243	4.1 to 27.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	129	SF	\$40	\$5,148
51308	27.2 to 28.2 feet	Vertical Change	-.3	6 ft	6	REF		
35250	33.2 to 42.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$6,006
56865	35.4 to 38.2 feet	Vertical Change	.5	6 ft	15	REF		
56520	42.0 to 43.0 feet	Vertical Change	.4	6 ft	6	REF		
51309	43.7 to 44.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
55687	45.4 to 46.4 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
35253	59.0 to 62.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178
35255	80.5 to 85.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
55688	89.9 to 90.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
56521	97.3 to 98.3 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
35256	101.2 to 122.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	117	SF	\$120	\$13,992
56522	114.6 to 115.6 feet	Vertical Change	.4	6 ft	6	REF		
55689	119.5 to 120.5 feet	Vertical Change	.3	6 ft	6	REF		
56523	124.9 to 125.9 feet	Vertical Change	.4	6 ft	6	REF		
35261	125.5 to 126.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858
55690	129.8 to 130.8 feet	Vertical Change	.3	6 ft	6	REF		
35262	129.8 to 132.7 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	16	SF	\$120	\$1,914
55691	134.1 to 135.1 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: SW side of 8TH ST Starting at: SIDEWALK BEGINS							\$36,052.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251432	8TH ST	RIVERSIDE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35264	15.0 to 48.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	185	SF	\$120	\$22,242
35275	57.5 to 60.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848
35276	63.6 to 84.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	116	SF	\$120	\$13,926
60120	85.4 to 103.1 feet	Driveway				REF		
35283	87.7 to 98.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	59	SF	\$40	\$2,354
35286	121.3 to 130.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,808
35288	130.3 to 139.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	52	SF	\$120	\$6,270
35292	139.8 to 158.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	105	SF	\$120	\$12,540
60121	145.3 to 175.8 feet	Driveway				REF		
55692	157.3 to 158.3 feet	Vertical Change	.3	6 ft	6	REF		
35297	164.1 to 169.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	29	SF	\$40	\$1,166
35299	171.6 to 172.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	7	SF	\$40	\$286
56524	171.7 to 172.7 feet	Vertical Change	.4	6 ft	6	REF		
56525	174.9 to 175.9 feet	Vertical Change	.4	6 ft	6	REF		
TOTAL COST FOR: SW side of 8TH ST Starting at: RIVERSIDE AVE							\$66,440.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251437	7TH ST	KINGS AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35300	0.0 to 3.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178
57502	23.6 to 24.6 feet	Vertical Change	1.7	6 ft	6	SF	\$75	\$413
35301	100.4 to 110.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	55	SF	\$120	\$6,600
55693	108.1 to 109.1 feet	Vertical Change	.3	6 ft	6	REF		
55694	114.8 to 115.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
35303	116.1 to 118.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386
57096	124.9 to 125.9 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413
TOTAL COST FOR: SW side of 7TH ST Starting at: KINGS AVE								\$11,401.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251439	7TH ST	SIDEWALK BEGINS	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35304	0.0 to 12.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	71	SF	\$120	\$8,514
60122	0.5 to 12.0 feet	Driveway				REF		
35307	14.5 to 17.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046
35308	21.0 to 31.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	57	SF	\$120	\$6,864
60123	28.5 to 44.8 feet	Driveway				REF		
35311	36.7 to 41.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	28	SF	\$40	\$1,122
51310	88.9 to 89.9 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
51311	108.0 to 109.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
55695	114.2 to 115.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
35313	117.7 to 122.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,366
TOTAL COST FOR: SW side of 7TH ST Starting at: SIDEWALK BEGINS							\$23,149.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	51909251442	7TH ST	ROBERTSON BLVD	KINGS AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
41068	0.0 to 1.1 feet	Running Slope	5.0-6.0%	6 ft	6	SF	\$120	\$726	
51312	8.9 to 9.9 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
35314	12.3 to 21.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,808	
51313	14.1 to 15.1 feet	Vertical Change	-.3	6 ft	6	REF			
35317	21.8 to 23.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	10	SF	\$120	\$1,254	
35318	25.9 to 30.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	28	SF	\$120	\$3,300	
55696	27.6 to 28.6 feet	Vertical Change	.3	6 ft	6	REF			
47800	32.2 to 33.2 feet	Vertical Change	-.4	6 ft	6	REF			
35320	33.0 to 38.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	30	SF	\$120	\$3,564	
55697	37.0 to 38.0 feet	Vertical Change	.3	6 ft	6	REF			
35322	41.3 to 52.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	61	SF	\$120	\$7,260	
56866	51.2 to 52.2 feet	Vertical Change	.5	6 ft	6	REF			
57520	53.3 to 54.3 feet	Vertical Change	1.9	6 ft	6	SF	\$75	\$413	
35325	56.0 to 61.8 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	32	SF	\$120	\$3,828	
47801	61.2 to 62.2 feet	Vertical Change	-.4	6 ft	6	REF			
35328	62.6 to 69.6 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	38	SF	\$120	\$4,620	
51314	66.2 to 67.2 feet	Vertical Change	-.3	6 ft	6	REF			
35330	69.6 to 74.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	26	SF	\$120	\$3,102	
55698	71.3 to 72.3 feet	Vertical Change	.3	6 ft	6	REF			
51315	76.3 to 77.3 feet	Vertical Change	-.3	6 ft	6	REF			
35331	76.8 to 80.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178	
56526	81.4 to 82.4 feet	Vertical Change	.4	6 ft	5	LF	\$75	\$413	
55699	86.2 to 87.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
35333	91.4 to 93.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254	
56527	91.6 to 92.6 feet	Vertical Change	.4	6 ft	6	REF			
35334	95.6 to 99.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376	
51316	96.7 to 97.7 feet	Vertical Change	-.3	6 ft	6	REF			
51317	101.6 to 102.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NE	51909251442	7TH ST	ROBERTSON BLVD	KINGS AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
57097	104.3 to 105.3 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413	
55700	106.6 to 107.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
47802	111.9 to 112.9 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413	
35335	118.6 to 143.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	136	SF	\$120	\$16,302	
55701	127.3 to 128.3 feet	Vertical Change	.3	6 ft	6	REF			
45426	132.2 to 133.2 feet	Vertical Change	-.5	6 ft	6	REF			
47803	137.2 to 138.2 feet	Vertical Change	-.4	6 ft	6	REF			
51318	142.1 to 143.1 feet	Vertical Change	-.3	6 ft	6	REF			
35339	144.3 to 148.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	24	SF	\$120	\$2,904	
35341	148.7 to 168.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	111	SF	\$120	\$13,266	
55702	167.2 to 168.2 feet	Vertical Change	.3	6 ft	6	REF			
35348	173.3 to 174.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$990	
56528	177.2 to 178.2 feet	Vertical Change	.4	6 ft	6	REF			
35349	178.2 to 191.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	74	SF	\$120	\$8,910	
55703	182.9 to 183.9 feet	Vertical Change	.3	6 ft	6	REF			
35355	195.1 to 200.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,828	
47804	202.1 to 203.1 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413	
35357	206.3 to 211.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168	
35358	215.5 to 219.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640	
35360	222.6 to 224.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,122	
35361	226.5 to 227.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	7	SF	\$120	\$858	
55704	227.1 to 228.1 feet	Vertical Change	.3	6 ft	6	REF			
35362	227.8 to 234.0 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	34	SF	\$120	\$4,092	
35364	234.9 to 245.3 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	57	SF	\$120	\$6,864	
47805	238.8 to 239.8 feet	Vertical Change	-.4	6 ft	6	REF			
55705	244.0 to 245.0 feet	Vertical Change	.3	6 ft	6	REF			
35368	245.8 to 247.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$792	
35369	247.8 to 253.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251442	7TH ST	ROBERTSON BLVD	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55706	248.8 to 249.8 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: NE side of 7TH ST Starting at: ROBERTSON BLVD							\$112,348.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	51909251444	KINGS AVE	7TH ST	6TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
51319	4.8 to 5.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
55707	13.8 to 14.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
56529	41.1 to 42.1 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
35372	44.1 to 50.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	34	SF	\$120	\$4,092	
55708	46.3 to 47.3 feet	Vertical Change	.3	6 ft	6	REF			
35373	51.1 to 62.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	64	SF	\$120	\$7,656	
55709	56.6 to 57.6 feet	Vertical Change	.3	6 ft	6	REF			
51320	66.8 to 67.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
35377	69.8 to 93.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	129	SF	\$120	\$15,510	
51321	72.0 to 73.0 feet	Vertical Change	-.3	6 ft	6	REF			
55710	82.3 to 83.3 feet	Vertical Change	.3	6 ft	6	REF			
56530	87.5 to 88.5 feet	Vertical Change	.4	6 ft	6	REF			
35382	100.3 to 105.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	27	SF	\$120	\$3,234	
51322	102.9 to 103.9 feet	Vertical Change	-.3	6 ft	6	REF			
55711	108.0 to 109.0 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
35383	109.1 to 112.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310	
35384	117.4 to 124.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	41	SF	\$120	\$4,884	
51323	122.9 to 123.9 feet	Vertical Change	-.3	6 ft	6	REF			
51324	127.8 to 128.8 feet	Vertical Change	-.3	6 ft	6	REF			
35385	128.4 to 131.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244	
55712	137.6 to 138.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
35387	140.4 to 161.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	118	SF	\$120	\$14,124	
55713	142.4 to 143.4 feet	Vertical Change	.3	6 ft	6	REF			
55714	152.4 to 153.4 feet	Vertical Change	.3	6 ft	6	REF			
55715	155.5 to 158.3 feet	Vertical Change	.3	6 ft	15	REF			
51325	167.3 to 168.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
35391	176.3 to 181.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,102	
35393	181.0 to 188.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	40	SF	\$120	\$4,752	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909251444	KINGS AVE	7TH ST	6TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35395	189.3 to 211.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	123	SF	\$120	\$14,784
51326	204.4 to 205.4 feet	Vertical Change	-.3	6 ft	6	REF		
35400	211.9 to 215.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	20	SF	\$120	\$2,376
35402	215.7 to 226.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	61	SF	\$120	\$7,326
51327	219.4 to 220.4 feet	Vertical Change	-.3	6 ft	6	REF		
35405	229.1 to 233.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838
35406	241.7 to 274.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	183	SF	\$120	\$21,912
55717	244.9 to 245.9 feet	Vertical Change	.3	6 ft	6	REF		
51328	249.9 to 250.9 feet	Vertical Change	-.3	6 ft	6	REF		
51329	255.0 to 256.0 feet	Vertical Change	-.3	6 ft	6	REF		
57098	260.0 to 261.0 feet	Vertical Change	.6	6 ft	6	REF		
51330	270.3 to 271.3 feet	Vertical Change	-.3	6 ft	6	REF		
56867	275.5 to 276.5 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
47806	285.3 to 286.3 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
55718	290.9 to 291.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: SE side of KINGS AVE Starting at: 7TH ST							\$115,269.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	51909251446	6TH ST	KINGS AVE	ROBERTSON BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
51331	4.9 to 5.9 feet	Vertical Change	-.3	6 ft	5	LF	\$75	\$413	
35417	13.8 to 16.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716	
51332	14.7 to 15.7 feet	Vertical Change	-.3	6 ft	6	REF			
55719	22.1 to 23.1 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
51333	25.9 to 26.9 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
51334	32.9 to 33.9 feet	Vertical Change	-.3	6 ft	6	REF			
51335	48.9 to 51.8 feet	Vertical Change	-.3	6 ft	16	LF	\$75	\$1,196	
35418	50.2 to 71.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	118	SF	\$120	\$14,124	
35424	73.7 to 79.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,762	
35427	87.9 to 98.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	57	SF	\$120	\$6,798	
51337	94.6 to 95.6 feet	Vertical Change	-.3	6 ft	6	REF			
45427	100.8 to 101.8 feet	Vertical Change	-.5	6 ft	6	REF			
35430	101.3 to 130.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	158	SF	\$120	\$18,942	
35437	141.4 to 152.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	62	SF	\$120	\$7,392	
47807	164.9 to 165.9 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413	
55720	169.8 to 170.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
35440	173.3 to 174.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$990	
35441	174.8 to 179.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838	
35443	201.8 to 205.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	20	SF	\$120	\$2,376	
35445	207.3 to 208.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056	
35446	230.8 to 236.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630	
35449	240.3 to 251.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	63	SF	\$120	\$7,590	
41344	254.1 to 255.1 feet	Vertical Change	-1.4	6 ft	6	SF	\$75	\$413	
35453	259.0 to 260.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
TOTAL COST FOR: SW side of 6TH ST Starting at: KINGS AVE							\$75,677.25		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251447	6TH ST	ROBERTSON BLVD	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35454	0.0 to 7.8 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	78	SF	\$120	\$9,360
35456	10.9 to 35.5 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	246	SF	\$120	\$29,520
60124	12.9 to 31.7 feet	Driveway				REF		
35461	37.7 to 47.8 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	101	SF	\$120	\$12,120
35463	47.8 to 51.6 feet	Cross Slope (PAR)	5.0-6.0%	10 ft	38	SF	\$120	\$4,560
35465	51.6 to 53.9 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	23	SF	\$120	\$2,760
35466	53.9 to 57.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	39	SF	\$120	\$4,680
35467	64.0 to 74.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	106	SF	\$120	\$12,720
35471	75.4 to 83.0 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	76	SF	\$120	\$9,120
35474	83.0 to 85.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	27	SF	\$120	\$3,240
41233	86.3 to 87.3 feet	Vertical Change	-2	10 ft	10	SF	\$75	\$750
60125	89.2 to 108.8 feet	Driveway				REF		
35475	89.4 to 93.8 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	44	SF	\$40	\$1,760
57099	91.8 to 92.8 feet	Vertical Change	.6	10 ft	10	REF		
35477	97.4 to 109.9 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	125	SF	\$40	\$5,000
35483	110.1 to 123.7 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	136	SF	\$120	\$16,320
35489	128.3 to 139.3 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	110	SF	\$120	\$13,200
60126	133.0 to 153.5 feet	Driveway				REF		
35493	150.3 to 154.4 feet	Cross Slope (Driveway)	3.0-4.0%	10 ft	41	SF	\$40	\$1,640
TOTAL COST FOR: NE side of 6TH ST Starting at: ROBERTSON BLVD							\$126,750.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	51909251450	KINGS AVE	6TH ST	5TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
35494	0.6 to 2.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	13	SF	\$120	\$1,518	
35495	3.3 to 6.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112	
35496	10.1 to 13.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914	
35497	15.6 to 19.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376	
60127	15.9 to 31.5 feet	Driveway				REF			
35499	23.3 to 30.9 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	42	SF	\$40	\$1,672	
35502	33.2 to 34.2 feet	Cross Slope (PAR)	8.0-9.0%	6 ft	6	SF	\$120	\$660	
35503	36.7 to 37.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726	
35504	38.3 to 45.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,620	
60128	43.7 to 61.3 feet	Driveway				REF			
35506	49.0 to 59.6 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	58	SF	\$40	\$2,332	
35511	64.4 to 66.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	14	SF	\$120	\$1,650	
35512	66.9 to 94.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	150	SF	\$120	\$18,018	
47808	80.9 to 81.9 feet	Vertical Change	-.4	6 ft	6	REF			
60129	87.6 to 138.0 feet	Driveway				REF			
35520	99.3 to 101.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	13	SF	\$40	\$506	
35521	106.5 to 108.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	10	SF	\$40	\$396	
35522	115.3 to 116.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$220	
35523	129.8 to 137.6 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	43	SF	\$40	\$1,716	
47809	139.3 to 140.3 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413	
172	142.2 to 143.2 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
35525	143.4 to 144.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660	
35526	144.7 to 182.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	210	SF	\$120	\$25,212	
55721	150.3 to 151.3 feet	Vertical Change	.3	6 ft	6	REF			
51338	152.8 to 153.8 feet	Vertical Change	-.3	6 ft	6	REF			
57458	173.2 to 174.2 feet	Vertical Change	1.4	6 ft	6	REF			
35535	185.5 to 214.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	162	SF	\$120	\$19,404	
57276	185.7 to 186.7 feet	Vertical Change	.8	6 ft	6	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909251450	KINGS AVE	6TH ST	5TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56531	189.8 to 190.8 feet	Vertical Change	.4	6 ft	6	REF		
55722	203.2 to 204.2 feet	Vertical Change	.3	6 ft	6	REF		
173	204.8 to 205.8 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
51339	213.8 to 214.8 feet	Vertical Change	-.3	6 ft	6	REF		
35541	219.4 to 232.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	73	SF	\$120	\$8,712
35544	234.0 to 236.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848
60130	234.3 to 269.3 feet	Driveway				REF		
35546	241.6 to 247.3 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	31	SF	\$40	\$1,254
35549	247.3 to 253.8 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	36	SF	\$40	\$1,430
55723	253.8 to 254.8 feet	Vertical Change	.3	6 ft	6	REF		
35551	253.8 to 258.2 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	24	SF	\$40	\$968
35553	259.8 to 266.7 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	38	SF	\$40	\$1,518
35555	266.7 to 267.8 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	6	SF	\$40	\$242
35556	270.8 to 271.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
35557	281.0 to 282.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
TOTAL COST FOR: SE side of KINGS AVE Starting at: 6TH ST							\$103,878.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251452	5TH ST	KINGS AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35558	1.2 to 2.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	15	SF	\$120	\$1,800
35559	6.3 to 8.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	24	SF	\$120	\$2,880
35560	12.3 to 16.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	37	SF	\$120	\$4,440
35562	21.9 to 50.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	284	SF	\$120	\$34,080
43538	43.4 to 44.5 feet	Vertical Change	-.6	10 ft	11	REF		
35569	53.1 to 72.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	189	SF	\$120	\$22,680
56868	57.8 to 58.8 feet	Vertical Change	.5	10 ft	10	REF		
55724	67.3 to 68.3 feet	Vertical Change	.3	10 ft	10	REF		
55725	72.9 to 73.9 feet	Vertical Change	.3	10 ft	10	LF	\$75	\$750
35572	74.3 to 76.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	17	SF	\$120	\$2,040
35573	84.1 to 91.5 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	74	SF	\$120	\$8,880
35577	93.7 to 97.3 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	36	SF	\$120	\$4,320
35578	99.0 to 102.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	36	SF	\$120	\$4,320
35580	107.7 to 112.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	51	SF	\$120	\$6,120
35581	116.5 to 125.5 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	90	SF	\$120	\$10,800
35585	128.0 to 135.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	73	SF	\$120	\$8,760
60131	137.3 to 157.3 feet	Driveway				REF		
35588	141.8 to 142.8 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	10	SF	\$40	\$400
35589	147.4 to 148.4 feet	Cross Slope (Driveway)	3.0-4.0%	10 ft	10	SF	\$40	\$400
35590	148.4 to 152.6 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	42	SF	\$40	\$1,680
35592	153.0 to 155.1 feet	Cross Slope (Driveway)	4.0-5.0%	10 ft	21	SF	\$40	\$840
41069	156.0 to 158.3 feet	Running Slope	5.0-6.0%	10 ft	23	REF		
35593	188.9 to 194.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	54	SF	\$120	\$6,480
60132	198.0 to 216.0 feet	Driveway				REF		
35594	204.6 to 213.3 feet	Cross Slope (Driveway)	8.0-9.0%	10 ft	87	SF	\$40	\$3,480
35598	223.3 to 224.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	13	SF	\$120	\$1,560
35599	268.5 to 271.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	33	SF	\$120	\$3,960
35600	275.8 to 297.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	220	SF	\$120	\$26,400

TOTAL COST FOR: SW side of 5TH ST Starting at: KINGS AVE \$157,070.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251455	5TH ST	ROBERTSON BLVD	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51340	2.3 to 3.3 feet	Vertical Change	-.3	10 ft	10	REF		
35603	3.1 to 5.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	27	SF	\$120	\$3,240
55726	5.2 to 6.2 feet	Vertical Change	.3	10 ft	10	REF		
35604	8.0 to 16.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	87	SF	\$120	\$10,440
35608	20.3 to 21.7 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	14	SF	\$120	\$1,680
35609	27.8 to 30.1 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	23	SF	\$120	\$2,760
35610	35.8 to 50.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	148	SF	\$120	\$17,760
35615	63.0 to 75.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	127	SF	\$120	\$15,240
35617	86.3 to 87.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	10	SF	\$120	\$1,200
60133	135.1 to 153.8 feet	Driveway				REF		
35618	139.8 to 143.9 feet	Cross Slope (Driveway)	3.0-4.0%	10 ft	41	SF	\$40	\$1,640
35620	144.9 to 146.2 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	13	SF	\$40	\$520
35621	152.0 to 154.0 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	20	SF	\$40	\$800
41070	154.9 to 156.1 feet	Running Slope	5.0-6.0%	10 ft	12	SF	\$120	\$1,440
35622	179.6 to 200.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	210	SF	\$120	\$25,200
35627	204.1 to 247.5 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	434	SF	\$120	\$52,080
35638	249.4 to 254.3 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	49	SF	\$120	\$5,880
55727	257.1 to 258.1 feet	Vertical Change	.3	10 ft	10	REF		
35640	257.3 to 289.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	325	SF	\$120	\$39,000
45428	277.2 to 278.2 feet	Vertical Change	-.5	10 ft	10	REF		
35648	292.5 to 296.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	38	SF	\$120	\$4,560
TOTAL COST FOR: NE side of 5TH ST Starting at: ROBERTSON BLVD							\$183,440.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909251501	KINGS AVE	5TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35649	0.0 to 18.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	104	SF	\$120	\$12,474
55728	13.9 to 14.9 feet	Vertical Change	.3	6 ft	6	REF		
35651	41.9 to 45.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
35652	50.2 to 56.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,026
35654	75.3 to 78.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376
35656	100.8 to 103.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518
174	103.4 to 104.4 feet	Continuous Width		6 ft	6	SF	\$120	\$660
56532	107.7 to 110.5 feet	Vertical Change	.4	6 ft	15	REF		
35657	107.7 to 109.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386
55730	117.8 to 118.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
35659	138.4 to 146.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,214
56869	143.8 to 147.5 feet	Vertical Change	.5	6 ft	20	REF		
60134	147.8 to 163.2 feet	Driveway				REF		
35662	155.1 to 172.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	97	SF	\$40	\$3,872
57100	155.8 to 156.8 feet	Vertical Change	.6	6 ft	6	REF		
55732	165.6 to 168.3 feet	Vertical Change	.3	6 ft	15	REF		
55734	170.9 to 171.9 feet	Vertical Change	.3	6 ft	6	REF		
55735	182.7 to 186.1 feet	Vertical Change	.3	6 ft	19	LF	\$75	\$1,403
35668	184.3 to 186.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
57541	190.4 to 191.4 feet	Vertical Change	2.1	6 ft	6	SF	\$75	\$413

TOTAL COST FOR: SE	<i>side of</i> KINGS AVE	<i>Starting at:</i> 5TH ST	\$37,515.50
---------------------------	---------------------------------	-----------------------------------	--------------------

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251503	4TH ST	KINGS AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60135	2.4 to 18.2 feet	Driveway				REF		
35669	10.5 to 19.4 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	89	SF	\$40	\$3,560
35671	22.3 to 25.2 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	29	SF	\$120	\$3,480
35672	37.6 to 41.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	37	SF	\$120	\$4,440
51341	38.5 to 39.5 feet	Vertical Change	-.3	10 ft	10	REF		
60136	57.3 to 73.2 feet	Driveway				REF		
55737	58.8 to 59.8 feet	Vertical Change	.3	10 ft	10	REF		
35674	61.4 to 71.3 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	99	SF	\$40	\$3,960
35676	75.6 to 76.9 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	13	SF	\$120	\$1,560
60137	82.9 to 94.9 feet	Driveway				REF		
35677	92.6 to 96.1 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	35	SF	\$40	\$1,400
35678	116.6 to 120.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	37	SF	\$120	\$4,440
35680	143.1 to 156.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	136	SF	\$120	\$16,320
175	144.8 to 145.8 feet	Protruding Object		10 ft	10	JOB	\$99	\$99
60138	147.8 to 189.8 feet	Driveway				REF		
56533	149.8 to 150.8 feet	Vertical Change	.4	10 ft	10	REF		
55738	161.5 to 162.5 feet	Vertical Change	.3	10 ft	10	REF		
35683	175.3 to 184.3 feet	Cross Slope (Driveway)	7.0-8.0%	10 ft	90	SF	\$40	\$3,600
47810	188.9 to 189.9 feet	Vertical Change	-.4	10 ft	10	REF		
35686	212.4 to 218.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	62	SF	\$120	\$7,440
35688	223.9 to 229.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	51	SF	\$120	\$6,120
35690	239.1 to 246.4 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	73	SF	\$120	\$8,760
35692	275.6 to 283.4 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	78	SF	\$120	\$9,360
35694	288.6 to 290.4 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	18	SF	\$120	\$2,160
35695	294.3 to 307.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	127	SF	\$120	\$15,240
TOTAL COST FOR: SW side of 4TH ST Starting at: KINGS AVE								\$91,939.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251505	4TH ST	ROBERTSON BLVD	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35698	0.0 to 9.3 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	93	SF	\$120	\$11,160
35700	9.7 to 10.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	11	SF	\$120	\$1,320
55739	11.5 to 12.5 feet	Vertical Change	.3	10 ft	10	LF	\$75	\$750
35701	14.2 to 30.1 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	159	SF	\$120	\$19,080
35704	30.1 to 31.1 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	10	SF	\$120	\$1,200
35705	33.5 to 36.9 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	34	SF	\$120	\$4,080
35706	36.9 to 49.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	129	SF	\$120	\$15,480
35707	55.8 to 69.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	135	SF	\$120	\$16,200
47811	66.7 to 67.7 feet	Vertical Change	-.4	10 ft	10	REF		
35711	77.2 to 109.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	325	SF	\$120	\$39,000
41690	90.0 to 91.0 feet	Vertical Change	-.9	10 ft	10	REF		
51342	105.8 to 106.8 feet	Vertical Change	-.3	10 ft	10	REF		
35717	124.6 to 125.9 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	13	SF	\$120	\$1,560
60139	135.6 to 155.8 feet	Driveway				REF		
35718	136.8 to 138.4 feet	Cross Slope (Driveway)	3.0-4.0%	10 ft	16	SF	\$40	\$640
35719	143.2 to 145.8 feet	Cross Slope (Driveway)	9.0-10.0%	10 ft	26	SF	\$40	\$1,040
35721	145.8 to 155.5 feet	Cross Slope (Driveway)	7.0-8.0%	10 ft	97	SF	\$40	\$3,880
TOTAL COST FOR: NE side of 4TH ST Starting at: ROBERTSON BLVD							\$115,390.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909251508	KINGS AVE	SIDEWALK BEGINS	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60140	0.5 to 18.8 feet	Driveway				REF		
35726	3.1 to 4.9 feet	Cross Slope (Driveway)	13.014	10 ft	18	SF	\$40	\$720
35727	7.4 to 14.8 feet	Cross Slope (Driveway)	11.0-12.0%	10 ft	74	SF	\$40	\$2,960
41071	17.5 to 19.1 feet	Running Slope	7.0-8.0%	10 ft	16	REF		
51343	20.9 to 21.9 feet	Vertical Change	-.3	10 ft	10	LF	\$75	\$750
35730	26.3 to 28.3 feet	Cross Slope (PAR)	5.0-6.0%	10 ft	20	SF	\$120	\$2,400
35731	28.3 to 29.4 feet	Cross Slope (PAR)	6.0-7.0%	10 ft	11	SF	\$120	\$1,320
35732	29.8 to 31.9 feet	Cross Slope (PAR)	5.0-6.0%	10 ft	21	SF	\$120	\$2,520
55740	31.8 to 32.8 feet	Vertical Change	.3	10 ft	10	REF		
35733	34.1 to 42.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	82	SF	\$120	\$9,840
35734	45.3 to 52.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	67	SF	\$120	\$8,040
35735	53.8 to 63.1 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	93	SF	\$120	\$11,160
35738	63.1 to 64.1 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	10	SF	\$120	\$1,200
60141	63.3 to 86.3 feet	Driveway				REF		
35739	68.3 to 69.4 feet	Cross Slope (Driveway)	9.0-10.0%	10 ft	11	SF	\$40	\$440
35740	71.8 to 84.2 feet	Cross Slope (Driveway)	10.0-11.0%	10 ft	124	SF	\$40	\$4,960
35745	91.8 to 95.4 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	36	SF	\$120	\$4,320
35747	96.4 to 100.4 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	40	SF	\$120	\$4,800
176	97.6 to 98.6 feet	Protruding Object		10 ft	10	JOB	\$99	\$990
41243	103.9 to 104.9 feet	Vertical Change	-1.9	10 ft	10	SF	\$75	\$750
41882	104.2 to 105.2 feet	Vertical Change	-.8	10 ft	10	SF	\$75	\$750
35748	110.3 to 118.1 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	78	SF	\$120	\$9,360
60142	114.8 to 156.7 feet	Driveway				REF		
35752	121.9 to 151.6 feet	Cross Slope (Driveway)	12.0-13.0%	10 ft	297	SF	\$40	\$11,880
35761	153.7 to 156.1 feet	Cross Slope (Driveway)	12.0-13.0%	10 ft	24	SF	\$40	\$960
35763	156.1 to 157.1 feet	Cross Slope (Driveway)	10.0-11.0%	10 ft	10	SF	\$40	\$400
35764	158.9 to 160.3 feet	Cross Slope (PAR)	6.0-7.0%	10 ft	14	SF	\$120	\$1,680
35765	161.3 to 164.1 feet	Cross Slope (PAR)	5.0-6.0%	10 ft	28	SF	\$120	\$3,360

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909251508	KINGS AVE	SIDEWALK BEGINS	4TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35767	165.2 to 166.3 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	11	SF	\$120	\$1,320
35768	167.3 to 170.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	30	SF	\$120	\$3,600
55741	178.8 to 179.8 feet	Vertical Change	.3	10 ft	10	LF	\$75	\$750
35769	192.5 to 197.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	48	SF	\$120	\$5,760
51344	206.0 to 207.0 feet	Vertical Change	-.3	10 ft	10	LF	\$75	\$750
TOTAL COST FOR: SE side of KINGS AVE Starting at: SIDEWALK BEGINS							\$96,849.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251510	4TH ST	KINGS AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35770	0.0 to 3.3 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	33	SF	\$120	\$3,960
41072	0.0 to 1.4 feet	Running Slope	5.0-6.0%	10 ft	14	REF		
35772	3.5 to 5.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	21	SF	\$120	\$2,520
55742	7.3 to 8.3 feet	Vertical Change	.3	10 ft	10	LF	\$75	\$750
35773	11.3 to 13.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	25	SF	\$120	\$3,000
35775	51.6 to 52.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	12	SF	\$120	\$1,440
35776	73.3 to 76.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	35	SF	\$120	\$4,200
35777	92.3 to 96.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	43	SF	\$120	\$5,160
35779	106.6 to 114.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	77	SF	\$120	\$9,240
35782	121.2 to 128.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	75	SF	\$120	\$9,000
35784	131.0 to 132.0 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	10	SF	\$120	\$1,200
35785	132.3 to 133.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	15	SF	\$120	\$1,800
60143	138.2 to 158.0 feet	Driveway				REF		
35786	141.8 to 145.7 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	39	SF	\$40	\$1,560
35788	163.8 to 178.9 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	151	SF	\$120	\$18,120
35793	182.4 to 189.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	73	SF	\$120	\$8,760
35795	194.3 to 201.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	73	SF	\$120	\$8,760
35797	215.7 to 235.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	201	SF	\$120	\$24,120
35804	239.9 to 243.9 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	40	SF	\$120	\$4,800
35806	247.8 to 250.4 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	26	SF	\$120	\$3,120
35807	252.5 to 256.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	35	SF	\$120	\$4,200
35808	260.8 to 264.6 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	38	SF	\$120	\$4,560
35810	266.6 to 276.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	94	SF	\$120	\$11,280
35814	282.8 to 297.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	148	SF	\$120	\$17,760
TOTAL COST FOR: SW side of 4TH ST Starting at: KINGS AVE							\$149,310.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251512	4TH ST	ROBERTSON BLVD	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35818	0.1 to 1.2 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	11	SF	\$120	\$1,320
35819	6.0 to 14.4 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	84	SF	\$120	\$10,080
35824	21.3 to 23.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	17	SF	\$120	\$2,040
35825	31.7 to 32.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	10	SF	\$120	\$1,200
35826	43.5 to 50.5 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	70	SF	\$120	\$8,400
35829	62.8 to 64.1 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	13	SF	\$120	\$1,560
35830	70.7 to 74.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	36	SF	\$120	\$4,320
51345	85.3 to 86.6 feet	Vertical Change	-3	10 ft	13	LF	\$75	\$975
35832	97.2 to 107.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	98	SF	\$120	\$11,760
60144	100.6 to 122.5 feet	Driveway				REF		
35834	127.7 to 133.5 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	58	SF	\$120	\$6,960
60145	133.7 to 153.4 feet	Driveway				REF		
35837	169.6 to 180.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	111	SF	\$120	\$13,320
35840	229.6 to 237.9 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	83	SF	\$120	\$9,960
60146	241.1 to 267.3 feet	Driveway				REF		
35842	248.5 to 251.3 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	28	SF	\$40	\$1,120
35843	256.1 to 261.9 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	58	SF	\$40	\$2,320
35846	281.0 to 284.4 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	34	SF	\$120	\$4,080
35847	287.8 to 290.1 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	23	SF	\$120	\$2,760
35848	295.8 to 297.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	12	SF	\$120	\$1,440
TOTAL COST FOR: NE side of 4TH ST Starting at: ROBERTSON BLVD							\$83,615.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority
SE	51909251515	KINGS AVE	4TH ST	3RD ST				TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35849	1.2 to 6.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	54	SF	\$120	\$6,480
51346	1.7 to 2.7 feet	Vertical Change	-.3	10 ft	10	REF		
60147	2.7 to 24.6 feet	Driveway				REF		
35850	12.3 to 15.8 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	35	SF	\$40	\$1,400
35851	18.4 to 36.5 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	181	SF	\$40	\$7,240
35855	36.5 to 40.7 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	42	SF	\$120	\$5,040
35857	43.8 to 44.9 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	11	SF	\$120	\$1,320
35858	44.9 to 53.2 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	83	SF	\$120	\$9,960
35862	56.0 to 60.4 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	44	SF	\$120	\$5,280
35864	61.1 to 67.1 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	60	SF	\$120	\$7,200
35865	77.3 to 137.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	605	SF	\$120	\$72,600
35877	140.5 to 156.4 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	159	SF	\$120	\$19,080
35881	164.3 to 170.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	65	SF	\$120	\$7,800
35882	174.5 to 188.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	138	SF	\$120	\$16,560
51347	194.7 to 195.7 feet	Vertical Change	-.3	10 ft	10	REF		
35885	195.4 to 199.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	44	SF	\$120	\$5,280
35887	203.4 to 212.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	93	SF	\$120	\$11,160
35889	232.8 to 235.9 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	31	SF	\$120	\$3,720
55743	254.1 to 255.1 feet	Vertical Change	.3	10 ft	10	LF	\$75	\$750
55744	284.3 to 285.3 feet	Vertical Change	.3	10 ft	10	LF	\$75	\$750

TOTAL COST FOR: SE	<i>side of</i> KINGS AVE	<i>Starting at:</i> 4TH ST	\$181,620.00
---------------------------	---------------------------------	-----------------------------------	---------------------

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251517	3RD ST	KINGS AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51348	33.2 to 34.2 feet	Vertical Change	-.3	10 ft	10	LF	\$75	\$750
47813	42.2 to 43.2 feet	Vertical Change	-.4	10 ft	10	LF	\$75	\$750
60148	72.0 to 142.7 feet	Driveway				REF		
56870	120.6 to 121.6 feet	Vertical Change	.5	10 ft	10	REF		
35891	123.7 to 124.9 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	12	SF	\$40	\$480
35892	130.7 to 131.9 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	12	SF	\$40	\$480
51349	144.6 to 145.6 feet	Vertical Change	-.3	10 ft	10	LF	\$75	\$750
35893	147.3 to 166.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	194	SF	\$120	\$23,280
60149	152.0 to 160.8 feet	Driveway				REF		
45429	172.6 to 173.9 feet	Vertical Change	-.5	10 ft	13	SF	\$75	\$975
35900	178.8 to 181.4 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	26	SF	\$120	\$3,120
35901	194.3 to 197.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	30	SF	\$120	\$3,600
60150	201.8 to 216.8 feet	Driveway				REF		
35902	203.6 to 204.9 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	13	SF	\$40	\$520
35903	208.3 to 217.6 feet	Cross Slope (Driveway)	7.0-8.0%	10 ft	93	SF	\$40	\$3,720
35907	218.1 to 219.2 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	11	SF	\$120	\$1,320
35908	219.8 to 221.1 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	13	SF	\$120	\$1,560
35909	239.5 to 242.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	25	SF	\$120	\$3,000
35910	244.3 to 248.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	37	SF	\$120	\$4,440
35912	251.5 to 257.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	55	SF	\$120	\$6,600
35914	259.5 to 265.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	61	SF	\$120	\$7,320
35916	268.5 to 273.3 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	48	SF	\$120	\$5,760
35918	276.0 to 283.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	73	SF	\$120	\$8,760
35921	286.2 to 303.5 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	173	SF	\$120	\$20,760
TOTAL COST FOR: SW side of 3RD ST Starting at: KINGS AVE							\$97,945.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251518	3RD ST	ROBERTSON BLVD	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
35926	0.0 to 2.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	28	SF	\$120	\$3,360
60151	1.5 to 46.5 feet	Driveway				REF		
35927	8.1 to 12.1 feet	Cross Slope (Driveway)	9.0-10.0%	10 ft	40	SF	\$40	\$1,600
35929	14.7 to 19.4 feet	Cross Slope (Driveway)	10.0-11.0%	10 ft	47	SF	\$40	\$1,880
35932	20.9 to 30.9 feet	Cross Slope (Driveway)	8.0-9.0%	10 ft	100	SF	\$40	\$4,000
35935	33.3 to 47.3 feet	Cross Slope (Driveway)	8.0-9.0%	10 ft	140	SF	\$40	\$5,600
35938	64.7 to 74.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	96	SF	\$120	\$11,520
TOTAL COST FOR: NE side of 3RD ST Starting at: ROBERTSON BLVD							\$27,960.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	51909251520	3RD ST	SIDEWALK BEGINS	KINGS AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
35939	5.3 to 7.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122	
35940	14.0 to 15.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
35941	32.8 to 35.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650	
45431	38.6 to 39.6 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413	
35943	59.5 to 65.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	32	SF	\$120	\$3,828	
35946	66.6 to 69.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716	
35948	74.4 to 78.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772	
45432	83.3 to 84.3 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413	
35950	85.3 to 86.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990	
56534	90.1 to 91.1 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
43540	93.0 to 94.0 feet	Vertical Change	-.6	6 ft	6	REF			
35951	93.1 to 94.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
35952	96.3 to 97.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726	
35953	97.8 to 98.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
35954	103.8 to 111.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	41	SF	\$120	\$4,884	
35957	119.4 to 122.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244	
177	126.2 to 127.2 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
35960	128.9 to 130.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
51350	135.0 to 136.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
35961	136.8 to 144.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	41	SF	\$120	\$4,950	
55745	138.2 to 139.2 feet	Vertical Change	.3	6 ft	6	REF			
51351	140.1 to 141.1 feet	Vertical Change	-.3	6 ft	6	REF			

TOTAL COST FOR: NE	<i>side of 3RD ST</i>	Starting at: SIDEWALK BEGINS	\$29,733.00
---------------------------	-----------------------	-------------------------------------	--------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SE	51909251524	KINGS AVE	2ND ST	1ST ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
55746	6.9 to 7.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
51352	20.4 to 21.4 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
35964	31.9 to 34.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,584	
35965	37.3 to 39.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122	
35966	39.9 to 46.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	36	SF	\$120	\$4,356	
35970	50.0 to 52.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	14	SF	\$120	\$1,716	
35972	57.8 to 58.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660	
35973	59.8 to 65.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	33	SF	\$120	\$3,960	
35976	74.9 to 76.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
51353	90.8 to 91.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
35977	101.3 to 110.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$6,006	
35980	112.7 to 115.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782	
35981	121.5 to 125.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	20	SF	\$120	\$2,442	
35983	133.9 to 134.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
51354	135.6 to 139.0 feet	Vertical Change	-.3	6 ft	19	LF	\$75	\$1,403	
35984	137.3 to 140.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178	
35986	144.0 to 154.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	57	SF	\$120	\$6,798	
35990	156.8 to 157.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	6	SF	\$120	\$660	
178	160.2 to 161.2 feet	Continuous Width		6 ft	6	SF	\$120	\$660	
55747	160.6 to 161.6 feet	Vertical Change	.3	6 ft	6	REF			
35991	160.6 to 161.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
55748	195.6 to 196.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
35992	206.1 to 212.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	32	SF	\$120	\$3,894	
179	208.0 to 209.0 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
35995	213.4 to 217.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772	
47814	231.2 to 232.2 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413	
35997	236.2 to 243.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,686	
36000	259.8 to 262.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909251524	KINGS AVE	2ND ST	1ST ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55749	265.6 to 266.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
36002	284.2 to 293.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,808
TOTAL COST FOR: SE side of KINGS AVE Starting at: 2ND ST							\$59,152.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909251526	1ST ST	KINGS AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
36004	0.2 to 7.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,686
56535	9.3 to 10.3 feet	Vertical Change	.4	6 ft	5	LF	\$75	\$413
51356	11.0 to 12.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
36007	15.1 to 16.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
55750	35.5 to 36.5 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
56536	39.4 to 40.4 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
51357	46.1 to 47.1 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
36008	83.2 to 86.1 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	16	SF	\$120	\$1,914
47815	85.6 to 86.6 feet	Vertical Change	-.4	6 ft	6	REF		
56537	113.7 to 114.7 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
180	128.1 to 129.1 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
51358	129.0 to 130.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
60152	134.0 to 155.6 feet	Driveway				REF		
36010	138.7 to 140.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	8	SF	\$40	\$308
36011	154.7 to 162.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	45	SF	\$40	\$1,782
36014	166.1 to 185.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	106	SF	\$120	\$12,672
60153	180.8 to 206.0 feet	Driveway				REF		
36018	193.8 to 209.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	85	SF	\$40	\$3,410
36022	212.8 to 271.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	325	SF	\$120	\$38,940
36036	279.7 to 293.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	78	SF	\$120	\$9,372
41073	294.1 to 295.9 feet	Running Slope	5.0-6.0%	6 ft	10	SF	\$120	\$1,188
TOTAL COST FOR: SW side of 1ST ST Starting at: KINGS AVE							\$78,380.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909251528	1ST ST	ROBERTSON BLVD	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
36040	0.9 to 7.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	64	SF	\$120	\$7,680
36042	14.1 to 18.7 feet	Cross Slope (PAR)	5.0-6.0%	10 ft	46	SF	\$120	\$5,520
60154	17.5 to 40.7 feet	Driveway				REF		
36044	18.7 to 20.2 feet	Cross Slope (Driveway)	6.0-7.0%	10 ft	15	SF	\$40	\$600
36045	45.6 to 48.9 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	33	SF	\$120	\$3,960
36047	75.9 to 84.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	89	SF	\$120	\$10,680
36052	102.5 to 104.4 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	19	SF	\$120	\$2,280
56871	138.3 to 139.3 feet	Vertical Change	.5	10 ft	10	SF	\$75	\$750
55751	148.3 to 149.3 feet	Vertical Change	.3	10 ft	10	LF	\$75	\$750
55752	255.8 to 256.8 feet	Vertical Change	.3	10 ft	10	LF	\$75	\$750
36053	266.0 to 267.1 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	11	SF	\$120	\$1,320
36054	274.2 to 278.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	44	SF	\$120	\$5,280
TOTAL COST FOR: NE side of 1ST ST Starting at: ROBERTSON BLVD							\$39,570.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909251530	KINGS AVE	1ST ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51359	3.2 to 4.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
36057	12.2 to 25.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	72	SF	\$120	\$8,580
55753	40.8 to 41.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
36059	78.3 to 96.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	101	SF	\$120	\$12,144
36064	103.6 to 113.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	52	SF	\$120	\$6,204
36065	122.1 to 129.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,082
36067	153.2 to 162.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,138
36069	167.3 to 184.6 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	95	SF	\$120	\$11,418
47816	181.8 to 182.8 feet	Vertical Change	-.4	6 ft	6	REF		
36073	185.8 to 194.2 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	46	SF	\$120	\$5,544
36076	194.9 to 196.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$924
TOTAL COST FOR: NW side of KINGS AVE Starting at: 1ST ST								\$56,859.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name				Priority	
NW	51909251532	KINGS AVE	2ND ST	3RD ST				TBD	
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
36077	81.8 to 106.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	136	SF	\$120	\$16,368	
55754	83.0 to 84.0 feet	Vertical Change	.3	6 ft	6	REF			
55755	96.9 to 97.9 feet	Vertical Change	.3	6 ft	6	REF			
36085	110.7 to 137.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	149	SF	\$120	\$17,886	
36092	139.9 to 142.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	13	SF	\$120	\$1,584	
36093	142.8 to 147.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838	
36094	148.9 to 160.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	61	SF	\$120	\$7,326	
36097	160.0 to 164.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838	
60155	164.3 to 193.3 feet	Driveway				REF			
51360	164.8 to 165.8 feet	Vertical Change	-.3	6 ft	6	REF			
36098	190.4 to 199.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	52	SF	\$40	\$2,068	
36100	201.9 to 203.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858	
51361	203.2 to 204.2 feet	Vertical Change	-.3	6 ft	6	REF			
36101	203.2 to 204.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122	
36102	207.0 to 219.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	69	SF	\$120	\$8,316	
36104	220.3 to 251.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	169	SF	\$120	\$20,328	
36110	252.5 to 254.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254	
47817	253.9 to 254.9 feet	Vertical Change	-.4	6 ft	6	REF			
36111	257.4 to 268.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	61	SF	\$120	\$7,326	
60156	269.1 to 288.1 feet	Driveway				REF			
36113	289.8 to 300.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	58	SF	\$120	\$6,930	
55756	297.3 to 298.3 feet	Vertical Change	.3	6 ft	6	REF			
41074	298.5 to 299.8 feet	Running Slope	5.0-6.0%	6 ft	7	REF			
TOTAL COST FOR: NW							<i>side of</i> KINGS AVE	<i>Starting at:</i> 2ND ST	\$97,042.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NE	51909261005	5TH ST	KINGS AVE	RIVERSIDE AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
36115	0.8 to 1.9 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	6	SF	\$120	\$726	
36116	3.9 to 5.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$792	
36117	5.1 to 6.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056	
36118	14.2 to 41.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	148	SF	\$120	\$17,754	
55757	32.3 to 33.3 feet	Vertical Change	.3	6 ft	6	REF			
36129	45.2 to 47.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	10	SF	\$120	\$1,254	
36130	54.7 to 56.1 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	8	SF	\$120	\$924	
36131	58.1 to 66.2 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	45	SF	\$120	\$5,346	
56538	62.2 to 63.2 feet	Vertical Change	.4	6 ft	6	REF			
36135	66.4 to 71.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	25	SF	\$120	\$3,036	
36137	72.3 to 78.4 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	34	SF	\$120	\$4,026	
36140	79.3 to 99.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	112	SF	\$120	\$13,398	
36145	101.2 to 102.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
36146	105.1 to 109.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,970	
36148	109.6 to 112.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	18	SF	\$120	\$2,112	
36150	115.2 to 118.7 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	19	SF	\$120	\$2,310	
60157	119.1 to 155.3 feet	Driveway				REF			
36152	123.4 to 125.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	10	SF	\$40	\$418	
36153	136.9 to 144.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	41	SF	\$40	\$1,628	
57367	146.0 to 147.0 feet	Vertical Change	1	6 ft	6	REF			
36155	148.8 to 175.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	148	SF	\$40	\$5,918	
36163	178.3 to 182.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640	
36165	194.3 to 197.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	17	SF	\$120	\$2,046	
36167	200.9 to 207.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	37	SF	\$120	\$4,422	
181	204.9 to 205.9 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
36170	213.2 to 217.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,102	
51362	217.9 to 218.9 feet	Vertical Change	-.3	6 ft	6	REF			
36171	231.6 to 244.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	68	SF	\$120	\$8,184	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261005	5TH ST	KINGS AVE	RIVERSIDE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
36176	248.4 to 253.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,102
36178	271.1 to 275.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,970
55758	276.0 to 277.0 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
36179	277.9 to 281.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244
TOTAL COST FOR: NE side of 5TH ST Starting at: KINGS AVE							\$93,615.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	51909261007	5TH ST	RIVERSIDE AVE	LAKE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
36185	2.6 to 14.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	67	SF	\$120	\$7,986	
55759	5.8 to 6.8 feet	Vertical Change	.3	6 ft	6	REF			
36189	38.8 to 41.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650	
36191	43.8 to 50.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,356	
57682	50.1 to 51.1 feet	Vertical Change	3.6	6 ft	6	REF			
36194	50.4 to 54.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	23	SF	\$120	\$2,706	
56872	53.1 to 54.1 feet	Vertical Change	.5	6 ft	6	REF			
60158	57.3 to 66.3 feet	Driveway				REF			
36196	67.0 to 74.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,148	
60159	75.1 to 89.2 feet	Driveway				REF			
47818	75.4 to 76.4 feet	Vertical Change	-.4	6 ft	6	REF			
36200	92.0 to 93.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	10	SF	\$120	\$1,188	
36201	95.3 to 96.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
36202	110.2 to 111.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
55760	111.7 to 112.7 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
36203	117.8 to 118.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
36204	124.1 to 127.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244	
60160	130.7 to 153.2 feet	Driveway				REF			
47819	131.3 to 132.3 feet	Vertical Change	-.4	6 ft	6	REF			
36205	139.6 to 152.7 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	72	SF	\$40	\$2,882	
36210	158.3 to 164.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,290	
36213	164.8 to 192.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	150	SF	\$120	\$18,018	
60161	191.3 to 202.9 feet	Driveway				REF			
36219	199.0 to 204.1 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	28	SF	\$40	\$1,122	
36220	209.4 to 212.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310	
36222	213.7 to 220.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	39	SF	\$120	\$4,686	
36225	223.8 to 224.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660	
36226	226.7 to 238.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	62	SF	\$120	\$7,458	
36229	273.6 to 281.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	44	SF	\$120	\$5,280	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261007	5TH ST	RIVERSIDE AVE	LAKE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41244	282.0 to 283.0 feet	Vertical Change	-1.9	6 ft	6	SF	\$75	\$413
36230	285.1 to 286.6 feet	Cross Slope (PAR)	>15%	6 ft	8	SF	\$120	\$990
57277	287.0 to 288.0 feet	Vertical Change	.8	6 ft	6	SF	\$75	\$413
36231	290.3 to 291.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	8	SF	\$120	\$990
55761	290.7 to 291.7 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: NE side of 5TH ST Starting at: RIVERSIDE AVE							\$77,511.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NE	51909261009	5TH ST	LAKE AVE	MONTEREY AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
36232	1.1 to 4.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,980	
56873	5.8 to 6.8 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413	
36234	7.1 to 11.4 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	24	SF	\$120	\$2,838	
36236	13.5 to 30.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	92	SF	\$120	\$11,022	
47820	27.2 to 28.2 feet	Vertical Change	-.4	6 ft	6	REF			
36239	32.8 to 45.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	69	SF	\$120	\$8,250	
51363	46.5 to 47.5 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
36241	50.0 to 60.8 feet	Cross Slope (PAR)	7.0-8.0%	6 ft	59	SF	\$120	\$7,128	
36243	63.0 to 67.3 feet	Cross Slope (PAR)	7.0-8.0%	6 ft	24	SF	\$120	\$2,838	
51364	65.9 to 66.9 feet	Vertical Change	-.3	6 ft	6	REF			
36245	67.3 to 80.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	74	SF	\$120	\$8,910	
56874	67.8 to 68.8 feet	Vertical Change	.5	6 ft	6	REF			
45433	82.1 to 83.1 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413	
36248	83.8 to 84.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
60162	86.3 to 109.3 feet	Driveway				REF			
36249	88.5 to 91.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	15	SF	\$40	\$594	
36250	103.6 to 109.4 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	32	SF	\$40	\$1,276	
36252	111.9 to 114.0 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	12	SF	\$120	\$1,386	
36253	114.8 to 123.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	48	SF	\$120	\$5,808	
36257	124.3 to 131.3 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	39	SF	\$120	\$4,620	
36260	132.1 to 134.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	12	SF	\$120	\$1,452	
60163	134.5 to 154.4 feet	Driveway				REF			
36261	135.0 to 136.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	7	SF	\$40	\$286	
36262	141.0 to 142.3 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	7	SF	\$40	\$286	
36263	142.8 to 146.4 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	20	SF	\$40	\$792	
36265	146.4 to 149.6 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	18	SF	\$40	\$704	
36267	153.4 to 154.5 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	6	SF	\$40	\$242	
36268	157.6 to 160.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261009	5TH ST	LAKE AVE	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60164	159.0 to 176.3 feet	Driveway				REF		
36269	165.5 to 169.3 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	21	SF	\$40	\$836
36271	169.3 to 171.1 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	10	SF	\$40	\$396
36272	171.8 to 176.3 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	25	SF	\$40	\$990
36275	176.3 to 177.6 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	7	SF	\$40	\$286
36276	196.8 to 202.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	31	SF	\$120	\$3,762
60165	203.5 to 223.4 feet	Driveway				REF		
36278	204.9 to 207.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	13	SF	\$40	\$528
55762	220.7 to 221.7 feet	Vertical Change	.3	6 ft	6	REF		
36279	224.9 to 226.3 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	8	SF	\$120	\$924
36280	226.3 to 227.5 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	7	SF	\$120	\$792
36281	231.1 to 233.2 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	12	SF	\$120	\$1,386
36282	235.6 to 244.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	48	SF	\$120	\$5,742
36285	252.9 to 283.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	170	SF	\$120	\$20,460
36293	283.9 to 292.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	45	SF	\$120	\$5,412
56539	290.6 to 291.6 feet	Vertical Change	.4	6 ft	6	REF		
36296	292.8 to 295.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046
TOTAL COST FOR: NE side of 5TH ST Starting at: LAKE AVE							\$108,047.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	51909261011	5TH ST	MONTEREY AVE	SONOMA AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
51365	0.9 to 1.9 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
51366	14.8 to 15.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
36298	18.9 to 22.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376	
182	22.8 to 23.8 feet	Continuous Width		6 ft	6	SF	\$120	\$660	
36299	27.6 to 30.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112	
57368	34.6 to 35.6 feet	Vertical Change	1	6 ft	6	SF	\$75	\$413	
36300	36.3 to 40.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640	
36303	49.5 to 55.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894	
51367	68.0 to 69.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
56540	77.0 to 78.0 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
36305	80.8 to 81.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
60166	81.2 to 109.0 feet	Driveway				REF			
36306	88.4 to 98.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	54	SF	\$40	\$2,178	
36310	99.2 to 103.3 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	23	SF	\$40	\$902	
36312	116.2 to 117.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	9	SF	\$120	\$1,056	
36313	119.2 to 120.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726	
36314	122.3 to 131.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,138	
60167	135.3 to 159.5 feet	Driveway				REF			
36317	142.4 to 147.2 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	26	SF	\$40	\$1,056	
36319	149.0 to 151.1 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	12	SF	\$40	\$462	
36320	152.1 to 158.0 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	32	SF	\$40	\$1,298	
41075	158.5 to 159.9 feet	Running Slope	6.0-7.0%	6 ft	8	REF			
36321	164.8 to 168.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310	
36323	169.2 to 171.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	13	SF	\$120	\$1,584	
36324	174.5 to 176.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,122	
60168	177.8 to 228.2 feet	Driveway				REF			
36325	178.4 to 180.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	13	SF	\$40	\$528	
36326	190.9 to 193.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	16	SF	\$40	\$638	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261011	5TH ST	MONTEREY AVE	SONOMA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
36327	198.0 to 205.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	39	SF	\$40	\$1,540
36329	213.9 to 219.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	32	SF	\$40	\$1,298
36330	237.4 to 241.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	24	SF	\$120	\$2,838
36332	245.6 to 248.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	17	SF	\$120	\$2,046
36334	249.4 to 257.0 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	42	SF	\$120	\$5,016
36336	257.0 to 267.3 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	57	SF	\$120	\$6,798
36340	267.3 to 272.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	27	SF	\$120	\$3,234
56541	269.8 to 270.8 feet	Vertical Change	.4	6 ft	6	REF		
36342	277.8 to 281.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,508
36344	285.2 to 295.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	54	SF	\$120	\$6,468
TOTAL COST FOR: NE side of 5TH ST Starting at: MONTEREY AVE							\$66,214.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	51909261013	5TH ST	SONOMA AVE	VENTURA AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
36347	2.7 to 3.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
36348	8.6 to 14.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,828	
55763	19.2 to 20.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
51368	26.7 to 27.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
36350	35.1 to 36.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990	
36351	58.4 to 60.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386	
36352	70.2 to 71.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
56542	74.0 to 75.0 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
36353	75.3 to 79.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	22	SF	\$120	\$2,640	
36355	80.6 to 87.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224	
51369	82.6 to 83.6 feet	Vertical Change	-.3	6 ft	6	REF			
56543	91.5 to 92.5 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
57278	93.2 to 94.2 feet	Vertical Change	.8	6 ft	6	SF	\$75	\$413	
56544	95.8 to 96.8 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
36357	108.5 to 124.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	90	SF	\$120	\$10,758	
51370	111.8 to 112.8 feet	Vertical Change	-.3	6 ft	6	REF			
56875	114.0 to 115.0 feet	Vertical Change	.5	6 ft	6	REF			
60169	116.6 to 132.0 feet	Driveway				REF			
36361	132.3 to 147.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	85	SF	\$40	\$3,388	
51371	133.9 to 134.9 feet	Vertical Change	-.3	6 ft	6	REF			
60170	137.8 to 155.4 feet	Driveway				REF			
36366	149.0 to 150.6 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	9	SF	\$40	\$352	
36367	151.4 to 152.5 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	6	SF	\$40	\$242	
36368	153.6 to 154.8 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	7	SF	\$40	\$264	
36369	158.5 to 164.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	35	SF	\$120	\$4,224	
36371	167.7 to 171.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	23	SF	\$120	\$2,706	
36373	171.8 to 180.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$6,006	
36376	186.1 to 190.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261013	5TH ST	SONOMA AVE	VENTURA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56545	186.7 to 187.7 feet	Vertical Change	.4	6 ft	6	REF		
36377	195.3 to 206.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	64	SF	\$120	\$7,656
36381	214.3 to 218.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838
36382	232.8 to 241.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,412
55764	245.3 to 246.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
36385	260.6 to 266.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	31	SF	\$120	\$3,762
45434	264.7 to 265.7 feet	Vertical Change	-.5	6 ft	6	REF		
36386	268.5 to 276.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	45	SF	\$120	\$5,412
36390	278.0 to 282.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168
36392	283.6 to 285.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	9	SF	\$120	\$1,056
47821	284.3 to 285.3 feet	Vertical Change	-.4	6 ft	6	REF		
TOTAL COST FOR: NE side of 5TH ST Starting at: SONOMA AVE							\$77,225.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261015	5TH ST	VENTURA AVE	SONOMA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
36393	0.0 to 5.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,498
36394	10.8 to 16.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,026
36395	33.3 to 34.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
36396	38.9 to 47.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	49	SF	\$120	\$5,874
55765	53.4 to 54.4 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
36399	55.3 to 58.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244
36401	61.8 to 80.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	102	SF	\$120	\$12,210
60171	78.9 to 102.8 feet	Driveway				REF		
36405	84.0 to 85.1 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	6	SF	\$40	\$242
36406	90.9 to 96.4 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	30	SF	\$40	\$1,210
36408	108.8 to 112.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112
36409	115.6 to 119.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
60172	127.7 to 146.1 feet	Driveway				REF		
36411	133.2 to 143.8 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	58	SF	\$40	\$2,332
36415	145.0 to 146.0 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	6	SF	\$40	\$220
36416	173.4 to 180.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,554
56546	178.6 to 179.6 feet	Vertical Change	.4	6 ft	6	REF		
36417	191.8 to 193.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
60173	196.0 to 213.3 feet	Driveway				REF		
57101	206.0 to 207.0 feet	Vertical Change	.6	6 ft	6	REF		
60174	221.9 to 234.6 feet	Driveway				REF		
36418	228.4 to 231.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	16	SF	\$40	\$638
36419	245.8 to 251.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	30	SF	\$120	\$3,630
36421	252.1 to 271.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	108	SF	\$120	\$13,002
47822	252.7 to 253.7 feet	Vertical Change	-.4	6 ft	6	REF		
36429	271.8 to 280.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	46	SF	\$120	\$5,544
TOTAL COST FOR: SW side of 5TH ST Starting at: VENTURA AVE							\$66,302.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261017	5TH ST	SONOMA AVE	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57216	34.8 to 35.8 feet	Vertical Change	.7	6 ft	6	SF	\$75	\$413
36432	43.5 to 48.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
36434	55.7 to 62.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,620
36436	67.4 to 76.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$6,006
55766	74.7 to 75.7 feet	Vertical Change	.3	6 ft	6	REF		
36439	79.2 to 87.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,742
36442	90.6 to 93.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178
55767	94.9 to 95.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
36443	104.9 to 121.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	90	SF	\$120	\$10,758
55768	114.9 to 115.9 feet	Vertical Change	.3	6 ft	6	REF		
36447	122.1 to 125.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	17	SF	\$120	\$2,046
51372	122.8 to 123.8 feet	Vertical Change	-.3	6 ft	6	REF		
36449	128.0 to 136.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,808
60175	134.3 to 154.8 feet	Driveway				REF		
36453	140.1 to 142.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	12	SF	\$40	\$484
36455	149.8 to 152.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	12	SF	\$40	\$484
36457	152.7 to 155.0 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	13	SF	\$40	\$506
36459	157.8 to 159.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
55769	163.3 to 169.5 feet	Vertical Change	.3	6 ft	34	LF	\$75	\$2,558
36460	170.0 to 171.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
51373	170.2 to 171.2 feet	Vertical Change	-.3	6 ft	6	REF		
36461	172.7 to 173.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	6	SF	\$120	\$726
55772	173.4 to 174.4 feet	Vertical Change	.3	6 ft	6	REF		
36462	174.0 to 175.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
36463	179.8 to 184.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	28	SF	\$120	\$3,300
36465	184.8 to 187.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	17	SF	\$120	\$1,980
60176	190.3 to 224.1 feet	Driveway				REF		
55773	191.9 to 192.9 feet	Vertical Change	.3	6 ft	6	REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261017	5TH ST	SONOMA AVE	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57393	198.6 to 199.6 feet	Vertical Change	1.1	6 ft	6	REF		
36467	203.5 to 214.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	59	SF	\$40	\$2,354
51374	209.6 to 210.6 feet	Vertical Change	-.3	6 ft	6	REF		
55774	214.9 to 215.9 feet	Vertical Change	.3	6 ft	6	REF		
42355	216.6 to 217.8 feet	Vertical Change	-.7	6 ft	7	REF		
56547	216.9 to 217.9 feet	Vertical Change	.4	6 ft	6	REF		
36472	217.3 to 218.8 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	8	SF	\$40	\$330
36473	224.1 to 225.8 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	9	SF	\$40	\$374
36474	226.8 to 231.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	24	SF	\$120	\$2,838
36476	233.6 to 239.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	30	SF	\$120	\$3,630
36478	239.3 to 246.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,620
55775	240.1 to 241.1 feet	Vertical Change	.3	6 ft	6	REF		
56548	247.3 to 248.3 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
36481	253.3 to 264.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	63	SF	\$120	\$7,590
36484	291.8 to 296.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
55776	293.7 to 294.7 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: SW side of 5TH ST Starting at: SONOMA AVE							\$78,815.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	51909261021	5TH ST	MONTEREY AVE	RIVERSIDE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
56877	0.4 to 1.4 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413	
36485	2.8 to 6.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,706	
36487	17.1 to 56.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	218	SF	\$120	\$26,202	
36501	61.2 to 63.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	12	SF	\$120	\$1,452	
36502	73.8 to 74.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
51375	90.6 to 91.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
36503	94.9 to 120.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	141	SF	\$120	\$16,896	
36508	132.2 to 136.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574	
36509	138.2 to 162.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	135	SF	\$120	\$16,170	
51376	192.6 to 193.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
36513	194.3 to 198.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904	
36514	208.9 to 210.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320	
36515	213.5 to 217.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,442	
36516	226.4 to 231.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	27	SF	\$120	\$3,234	
51377	231.6 to 232.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
57542	233.5 to 234.5 feet	Vertical Change	2.1	6 ft	6	SF	\$75	\$413	
36517	240.8 to 244.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112	
51378	276.3 to 277.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
36518	312.6 to 335.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	126	SF	\$120	\$15,180	
55777	329.0 to 330.0 feet	Vertical Change	.3	6 ft	6	REF			
55778	343.8 to 344.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
51379	399.0 to 400.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
36523	417.3 to 418.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
36524	422.8 to 444.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	118	SF	\$120	\$14,190	
60177	426.5 to 449.3 feet	Driveway				REF			
56549	438.8 to 439.8 feet	Vertical Change	.4	6 ft	6	REF			
36529	454.5 to 458.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772	
60178	492.2 to 509.2 feet	Driveway				REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261021	5TH ST	MONTEREY AVE	RIVERSIDE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
36531	495.9 to 502.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	35	SF	\$40	\$1,408
36533	513.2 to 523.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	58	SF	\$120	\$6,996
60179	514.5 to 537.8 feet	Driveway				REF		
36536	532.2 to 536.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	26	SF	\$40	\$1,034
36538	539.3 to 556.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	92	SF	\$120	\$11,022
36544	574.8 to 576.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
36545	585.5 to 586.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
36546	598.3 to 601.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376
36548	605.8 to 613.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346
36550	616.1 to 629.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	76	SF	\$120	\$9,108
36554	633.6 to 635.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
36555	638.5 to 639.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$924
36556	644.0 to 648.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
55779	650.6 to 651.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: SW side of 5TH ST Starting at: MONTEREY AVE							\$159,670.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261023	5TH ST	RIVERSIDE AVE	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
36557	0.0 to 4.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838
36558	33.3 to 42.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,808
51380	40.8 to 41.8 feet	Vertical Change	-3	6 ft	6	REF		
36562	47.8 to 52.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
36564	52.0 to 54.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	12	SF	\$120	\$1,452
36565	56.7 to 61.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
36567	63.4 to 66.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	18	SF	\$120	\$2,178
36569	67.0 to 78.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	61	SF	\$120	\$7,326
60180	68.5 to 85.4 feet	Driveway				REF		
55780	70.4 to 71.4 feet	Vertical Change	.3	6 ft	6	REF		
36573	81.8 to 83.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	7	SF	\$40	\$286
36574	95.4 to 105.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	58	SF	\$120	\$6,930
36577	108.9 to 119.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	58	SF	\$120	\$6,930
36579	123.2 to 135.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	70	SF	\$120	\$8,382
60181	134.5 to 153.4 feet	Driveway				REF		
36582	146.7 to 150.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	20	SF	\$40	\$792
36584	163.0 to 166.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178
60182	163.9 to 181.4 feet	Driveway				REF		
36585	172.3 to 181.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	48	SF	\$40	\$1,914
36587	182.0 to 193.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	63	SF	\$120	\$7,590
36591	196.0 to 198.3 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	13	SF	\$120	\$1,518
36592	201.2 to 223.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	124	SF	\$120	\$14,916
36600	227.7 to 228.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
36601	235.3 to 244.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	51	SF	\$120	\$6,072
36604	246.6 to 256.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	54	SF	\$120	\$6,468
51381	249.0 to 250.0 feet	Vertical Change	-3	6 ft	6	LF	\$75	\$413
36607	256.9 to 272.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	84	SF	\$120	\$10,032
36613	273.8 to 290.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	90	SF	\$120	\$10,824

TOTAL COST FOR: SW side of 5TH ST Starting at: RIVERSIDE AVE \$111,314.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261032	2ND ST	SIDEWALK BEGINS	RIVERSIDE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60183	0.3 to 16.4 feet	Driveway				REF		
36623	1.3 to 2.5 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	7	SF	\$40	\$264
36624	4.7 to 5.8 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	6	SF	\$40	\$242
36625	6.5 to 10.1 feet	Cross Slope (Driveway)	13.014	6 ft	20	SF	\$40	\$792
41076	15.6 to 17.2 feet	Running Slope	8.0-9.0%	6 ft	9	REF		
36627	27.5 to 40.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	70	SF	\$120	\$8,448
36629	46.4 to 49.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	19	SF	\$120	\$2,244
36631	49.8 to 55.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	33	SF	\$120	\$3,960
36634	57.8 to 63.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	30	SF	\$120	\$3,630
TOTAL COST FOR: NE side of 2ND ST Starting at: SIDEWALK BEGINS							\$19,580.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261033	2ND ST	RIVERSIDE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
36636	18.0 to 34.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	92	SF	\$120	\$11,022
36641	37.0 to 55.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	102	SF	\$120	\$12,210
36645	57.0 to 62.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
36647	64.8 to 66.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
36648	70.3 to 71.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660
36649	71.8 to 89.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	95	SF	\$120	\$11,418
60184	85.8 to 99.4 feet	Driveway				REF		
55781	87.6 to 88.6 feet	Vertical Change	.3	6 ft	6	REF		
36658	99.2 to 101.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	13	SF	\$40	\$528
36659	103.8 to 112.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	46	SF	\$120	\$5,544
36662	112.2 to 126.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	77	SF	\$120	\$9,240
36666	130.1 to 135.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,432
57683	132.0 to 133.0 feet	Vertical Change	3.6	6 ft	6	REF		
TOTAL COST FOR: NE side of 2ND ST Starting at: RIVERSIDE AVE							\$58,542.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261038	2ND ST	MONTEREY AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
36668	0.0 to 17.7 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	177	SF	\$120	\$21,240
51382	0.2 to 1.2 feet	Vertical Change	-.3	10 ft	10	REF		
36674	20.7 to 27.3 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	66	SF	\$120	\$7,920
36676	28.1 to 31.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	35	SF	\$120	\$4,200
36678	31.8 to 35.3 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	35	SF	\$120	\$4,200
36679	38.8 to 41.8 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	30	SF	\$120	\$3,600
36681	41.8 to 43.0 feet	Cross Slope (PAR)	5.0-6.0%	10 ft	12	SF	\$120	\$1,440
36682	43.0 to 51.5 feet	Cross Slope (PAR)	6.0-7.0%	10 ft	85	SF	\$120	\$10,200
60185	47.7 to 65.8 feet	Driveway				REF		
36685	51.5 to 57.5 feet	Cross Slope (Driveway)	5.0-6.0%	10 ft	60	SF	\$40	\$2,400
36688	57.5 to 71.8 feet	Cross Slope (Driveway)	3.0-4.0%	10 ft	143	SF	\$40	\$5,720
36690	72.3 to 74.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	20	SF	\$120	\$2,400
36691	80.1 to 87.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	69	SF	\$120	\$8,280
60186	81.3 to 91.7 feet	Driveway				REF		
57324	108.8 to 109.8 feet	Vertical Change	.9	10 ft	10	SF	\$75	\$750
36693	114.1 to 115.8 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	17	SF	\$120	\$2,040
36694	135.9 to 137.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	18	SF	\$120	\$2,160
TOTAL COST FOR: NE side of 2ND ST Starting at: MONTEREY AVE							\$76,550.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261040	2ND ST	SIDEWALK BEGINS	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
36695	7.5 to 24.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	94	SF	\$120	\$11,286
45435	19.3 to 20.3 feet	Vertical Change	-.5	6 ft	6	REF		
36700	28.7 to 36.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,016
36703	38.6 to 42.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	20	SF	\$120	\$2,442
36704	42.5 to 49.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,752
60187	48.4 to 59.8 feet	Driveway				REF		
36707	51.8 to 52.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$242
36708	62.9 to 66.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046
36709	69.1 to 103.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	188	SF	\$120	\$22,572
36713	105.4 to 111.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,762
36714	113.3 to 121.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,148
36716	126.9 to 128.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
36717	134.3 to 142.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,478
TOTAL COST FOR: SW side of 2ND ST Starting at: SIDEWALK BEGINS							\$63,866.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261041	2ND ST	MONTEREY AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
183	15.3 to 16.3 feet	Continuous Width		6 ft	6	SF	\$120	\$660
TOTAL COST FOR: SW side of 2ND ST Starting at: MONTEREY AVE								\$660.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261043	2ND ST	SIDEWALK BEGINS	LAKE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
36723	29.3 to 33.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640
36725	39.0 to 44.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630
36727	45.5 to 46.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	6	SF	\$120	\$726
36728	49.4 to 51.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	13	SF	\$120	\$1,518
36729	51.7 to 52.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
36730	62.0 to 63.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
TOTAL COST FOR: SW side of 2ND ST Starting at: SIDEWALK BEGINS								\$10,230.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261046	2ND ST	MONTEREY AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
36731	0.9 to 2.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
36732	12.7 to 20.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346
184	14.8 to 15.8 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
36737	31.1 to 39.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,808
56550	38.2 to 41.0 feet	Vertical Change	.4	6 ft	15	REF		
36741	39.9 to 44.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	24	SF	\$120	\$2,838
41077	41.8 to 42.8 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
36743	45.8 to 54.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,412
36747	59.0 to 60.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
36748	62.9 to 71.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,412
36752	73.7 to 79.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,696
55783	81.8 to 82.8 feet	Vertical Change	.3	6 ft	6	REF		
36754	82.3 to 84.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	12	SF	\$120	\$1,386
60189	85.1 to 116.0 feet	Driveway				REF		
36755	86.6 to 119.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	183	SF	\$40	\$7,304
51383	114.3 to 115.3 feet	Vertical Change	-.3	6 ft	6	REF		
36769	119.8 to 123.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	21	SF	\$120	\$2,508
36771	123.6 to 135.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	67	SF	\$120	\$7,986
TOTAL COST FOR: SW side of 2ND ST Starting at: MONTEREY AVE							\$49,775.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261047	2ND ST	SIDEWALK BEGINS	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
36774	1.6 to 36.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	194	SF	\$120	\$23,232
55784	23.1 to 24.1 feet	Vertical Change	.3	6 ft	6	REF		
36781	38.2 to 66.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	157	SF	\$120	\$18,810
36790	69.2 to 78.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,402
36791	87.0 to 90.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112
36793	94.9 to 103.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,676
51384	98.4 to 99.4 feet	Vertical Change	-.3	6 ft	6	REF		
36797	103.5 to 105.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	13	SF	\$120	\$1,518
36799	105.8 to 130.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	138	SF	\$120	\$16,566
51385	123.4 to 124.4 feet	Vertical Change	-.3	6 ft	6	REF		
36806	134.2 to 141.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,686
56551	136.0 to 137.0 feet	Vertical Change	.4	6 ft	6	REF		

TOTAL COST FOR: SW side of 2ND ST Starting at: SIDEWALK BEGINS \$79,002.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261053	2ND ST	KINGS AVE	RIVERSIDE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
36807	3.5 to 11.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346
36808	14.8 to 16.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
185	15.3 to 16.3 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
57325	18.1 to 19.1 feet	Vertical Change	.9	6 ft	6	SF	\$75	\$413
36809	19.3 to 22.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782
41170	23.2 to 24.2 feet	Vertical Change	-3.6	6 ft	6	SF	\$75	\$413
36811	27.4 to 28.7 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	7	SF	\$120	\$858
36812	28.7 to 29.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	6	SF	\$120	\$726
51386	50.6 to 51.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
36813	53.9 to 59.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,828
36814	65.4 to 73.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,214
57103	75.7 to 76.7 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413
36817	79.4 to 85.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,762
45436	85.7 to 86.7 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413
36821	89.5 to 95.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,026
36824	95.6 to 96.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	7	SF	\$120	\$858
36825	100.7 to 108.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,082
47824	100.8 to 101.8 feet	Vertical Change	-.4	6 ft	6	REF		
36829	108.4 to 110.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	10	SF	\$120	\$1,188
60190	109.8 to 126.8 feet	Driveway				REF		
56878	110.2 to 111.2 feet	Vertical Change	.5	6 ft	6	REF		
36830	110.8 to 112.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	7	SF	\$40	\$286
41078	111.4 to 112.8 feet	Running Slope	5.0-6.0%	6 ft	8	REF		
36831	118.8 to 123.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	27	SF	\$40	\$1,078
36834	123.7 to 133.7 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	55	SF	\$40	\$2,200
60191	133.3 to 150.5 feet	Driveway				REF		
36838	133.8 to 139.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	33	SF	\$40	\$1,320
60192	156.2 to 166.5 feet	Driveway				REF		

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261053	2ND ST	KINGS AVE	RIVERSIDE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
36840	158.7 to 162.6 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	21	SF	\$40	\$858
36841	162.6 to 163.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	7	SF	\$40	\$264
60193	168.7 to 190.6 feet	Driveway				REF		
36842	168.8 to 174.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	31	SF	\$40	\$1,254
57649	172.9 to 173.9 feet	Vertical Change	3.4	6 ft	6	REF		
56879	201.2 to 202.2 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
36844	237.3 to 238.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
45437	257.0 to 258.0 feet	Vertical Change	-.5	6 ft	6	REF		
36845	257.0 to 285.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	156	SF	\$120	\$18,744
36851	285.4 to 289.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	25	SF	\$120	\$2,970
36853	289.9 to 291.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254
TOTAL COST FOR: NE side of 2ND ST Starting at: KINGS AVE							\$67,584.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NE	51909261055	2ND ST	RIVERSIDE AVE	LAKE AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
36858	34.3 to 44.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	58	SF	\$120	\$6,930	
51388	44.2 to 45.2 feet	Vertical Change	-3	6 ft	6	REF			
36862	63.1 to 64.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122	
36863	71.3 to 96.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	137	SF	\$120	\$16,434	
60194	92.4 to 127.8 feet	Driveway				REF			
36871	108.8 to 115.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	36	SF	\$40	\$1,452	
36874	121.5 to 130.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	47	SF	\$40	\$1,870	
36878	130.0 to 131.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	6	SF	\$120	\$660	
36879	133.2 to 136.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	19	SF	\$120	\$2,244	
60195	133.6 to 155.7 feet	Driveway				REF			
36881	136.6 to 138.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	8	SF	\$40	\$308	
36882	150.0 to 153.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	17	SF	\$40	\$660	
36884	157.6 to 160.7 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	17	SF	\$120	\$2,046	
47825	158.4 to 159.4 feet	Vertical Change	-4	6 ft	6	REF			
36885	161.3 to 166.9 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	31	SF	\$120	\$3,696	
36888	166.9 to 168.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$990	
36889	169.0 to 173.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168	
36891	188.5 to 189.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858	
36892	230.1 to 231.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122	
36893	241.0 to 242.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254	
36894	246.3 to 248.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188	
36895	251.3 to 254.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914	
36896	260.0 to 272.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	68	SF	\$120	\$8,184	
47826	271.0 to 272.0 feet	Vertical Change	-4	6 ft	6	REF			
36901	276.3 to 277.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858	
36902	279.3 to 281.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320	

TOTAL COST FOR: NE side of 2ND ST Starting at: RIVERSIDE AVE \$58,278.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261058	3RD ST	LAKE AVE	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60196	1.3 to 20.0 feet	Driveway				REF		
36903	7.7 to 14.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	37	SF	\$40	\$1,496
36905	18.9 to 24.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	31	SF	\$40	\$1,232
36907	27.3 to 40.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	70	SF	\$120	\$8,448
36911	43.6 to 54.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	62	SF	\$120	\$7,392
36916	55.8 to 56.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	6	SF	\$120	\$660
36917	58.7 to 61.8 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	17	SF	\$120	\$2,046
60197	63.1 to 83.0 feet	Driveway				REF		
43541	64.5 to 65.5 feet	Vertical Change	-.6	6 ft	6	REF		
36919	65.3 to 66.8 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	8	SF	\$40	\$330
36920	69.6 to 76.4 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	37	SF	\$40	\$1,496
57511	76.3 to 77.3 feet	Vertical Change	1.8	6 ft	6	REF		
36923	76.8 to 78.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	7	SF	\$40	\$286
55785	92.8 to 93.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
36924	95.2 to 105.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	59	SF	\$120	\$7,062
36928	123.3 to 166.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	237	SF	\$120	\$28,380
60198	132.5 to 150.7 feet	Driveway				REF		
60199	157.1 to 172.5 feet	Driveway				REF		
36940	171.8 to 174.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	17	SF	\$40	\$660
36941	184.4 to 189.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,102
36942	191.3 to 213.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	124	SF	\$120	\$14,850
36949	216.4 to 222.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224
36951	223.8 to 229.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	30	SF	\$120	\$3,630
60200	227.2 to 239.4 feet	Driveway				REF		
36955	229.3 to 240.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	61	SF	\$40	\$2,420
51389	254.3 to 255.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
36958	256.3 to 257.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
56552	261.8 to 262.8 feet	Vertical Change	.4	6 ft	6	REF		
36959	261.9 to 263.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261058	3RD ST	LAKE AVE	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
36960	266.6 to 273.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,752
55786	276.8 to 277.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
36963	278.9 to 290.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	61	SF	\$120	\$7,326
51390	279.2 to 280.2 feet	Vertical Change	-.3	6 ft	6	REF		
36967	290.3 to 291.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
TOTAL COST FOR: NE side of 3RD ST Starting at: LAKE AVE							\$103,471.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261100	3RD ST	MONTEREY AVE	SONOMA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
36968	0.0 to 6.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	34	SF	\$120	\$4,026
60201	0.8 to 11.0 feet	Driveway				REF		
51391	2.9 to 3.9 feet	Vertical Change	-.3	6 ft	6	REF		
36970	6.7 to 11.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	25	SF	\$40	\$990
36972	14.1 to 30.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	89	SF	\$120	\$10,692
36975	47.3 to 56.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	52	SF	\$120	\$6,270
36977	75.8 to 90.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	81	SF	\$120	\$9,768
36981	107.0 to 119.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	69	SF	\$120	\$8,250
60202	122.0 to 131.3 feet	Driveway				REF		
36985	129.8 to 139.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	54	SF	\$40	\$2,178
60203	135.9 to 157.5 feet	Driveway				REF		
57279	153.8 to 154.8 feet	Vertical Change	.8	6 ft	6	REF		
36988	157.2 to 158.2 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	6	SF	\$40	\$220
36989	158.2 to 159.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	7	SF	\$40	\$286
55787	162.0 to 163.0 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
36990	163.2 to 164.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$792
36991	168.2 to 182.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	76	SF	\$120	\$9,174
36995	183.7 to 243.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	329	SF	\$120	\$39,468
55788	237.3 to 238.3 feet	Vertical Change	.3	6 ft	6	REF		
37007	246.5 to 252.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	31	SF	\$120	\$3,762
37008	252.2 to 262.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	58	SF	\$120	\$6,930
37012	273.3 to 277.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,706
41573	276.6 to 277.6 feet	Vertical Change	-1	6 ft	6	REF		
37014	279.8 to 290.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	56	SF	\$120	\$6,732
37015	292.2 to 295.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244
TOTAL COST FOR: NE side of 3RD ST Starting at: MONTEREY AVE							\$114,900.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE /	51909261103	3RD ST	SONOMA AVE	CALAVERAS ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
37016	3.3 to 11.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,544	
37019	14.0 to 17.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376	
51392	14.3 to 15.3 feet	Vertical Change	-.3	6 ft	6	REF			
47827	21.8 to 22.8 feet	Vertical Change	-.4	6 ft	6	REF			
37020	22.5 to 29.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,356	
37022	32.6 to 45.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	70	SF	\$120	\$8,382	
37024	48.4 to 63.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	85	SF	\$120	\$10,164	
37028	67.2 to 71.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	25	SF	\$120	\$2,970	
37029	73.6 to 80.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,620	
37032	82.8 to 94.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	64	SF	\$120	\$7,722	
60204	91.8 to 114.6 feet	Driveway				REF			
37035	97.6 to 99.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	9	SF	\$40	\$352	
37036	114.3 to 141.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	147	SF	\$40	\$5,874	
60205	139.3 to 155.0 feet	Driveway				REF			
57546	140.2 to 141.2 feet	Vertical Change	2.2	6 ft	6	REF			
37044	143.8 to 144.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$242	
37045	154.3 to 155.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$220	
55789	160.6 to 161.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
60206	172.6 to 185.7 feet	Driveway				REF			
37046	224.0 to 233.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,138	
186	245.8 to 246.8 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
60207	261.8 to 275.9 feet	Driveway				REF			
37049	262.0 to 267.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	29	SF	\$40	\$1,144	
37051	271.8 to 278.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	37	SF	\$40	\$1,474	
60208	288.8 to 303.8 feet	Driveway				REF			
51393	290.2 to 291.2 feet	Vertical Change	-.3	6 ft	6	REF			
41691	310.8 to 311.8 feet	Vertical Change	-.9	6 ft	6	SF	\$75	\$413	
37054	312.9 to 316.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	21	SF	\$120	\$2,574	
43542	313.3 to 314.3 feet	Vertical Change	-.6	6 ft	6	REF			

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE /	51909261103	3RD ST	SONOMA AVE	CALAVERAS ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37057	317.8 to 322.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,300
37058	325.2 to 329.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
57104	325.9 to 326.9 feet	Vertical Change	.6	6 ft	6	REF		
51394	338.6 to 339.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
37060	344.8 to 346.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
37061	359.5 to 363.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
51395	361.5 to 362.5 feet	Vertical Change	-.3	6 ft	6	REF		
37063	381.0 to 385.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,706
55790	383.1 to 384.1 feet	Vertical Change	.3	6 ft	6	REF		
37064	389.0 to 399.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	55	SF	\$120	\$6,600
60209	404.2 to 435.9 feet	Driveway				REF		
41079	405.8 to 407.1 feet	Running Slope	5.0-6.0%	6 ft	7	REF		
37065	407.7 to 410.2 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	14	SF	\$40	\$550
37066	416.3 to 428.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	67	SF	\$40	\$2,684
37070	431.3 to 432.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	7	SF	\$40	\$286
41080	435.8 to 437.8 feet	Running Slope	6.0-7.0%	6 ft	11	REF		
41081	437.8 to 439.1 feet	Running Slope	5.0-6.0%	6 ft	7	SF	\$120	\$858
37071	445.8 to 447.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
37072	450.1 to 451.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660
37073	451.1 to 454.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,508
60210	455.1 to 470.5 feet	Driveway				REF		
57447	458.4 to 459.4 feet	Vertical Change	1.3	6 ft	6	REF		
37075	460.6 to 467.3 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	37	SF	\$40	\$1,474
56553	468.0 to 469.0 feet	Vertical Change	.4	6 ft	6	REF		
37077	471.8 to 476.7 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	27	SF	\$120	\$3,234
55791	474.4 to 475.4 feet	Vertical Change	.3	6 ft	6	REF		
37079	476.8 to 485.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	48	SF	\$120	\$5,742
57635	477.3 to 478.3 feet	Vertical Change	3.3	6 ft	6	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority
NE /	51909261103	3RD ST	SONOMA AVE	CALAVERAS ST	TBD

ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55792	480.3 to 481.3 feet	Vertical Change	.3	6 ft	6	REF		

TOTAL COST FOR: NE / side of 3RD ST Starting at: SONOMA AVE \$103,746.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261107	3RD ST	655 3RD ST	SONOMA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37082	0.0 to 17.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	98	SF	\$120	\$11,748
187	8.3 to 9.3 feet	Continuous Width		6 ft	6	SF	\$120	\$660
55793	14.7 to 15.7 feet	Vertical Change	.3	6 ft	6	REF		
37086	18.3 to 23.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,366
60211	32.2 to 48.4 feet	Driveway				REF		
41082	34.2 to 35.3 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
37088	37.2 to 46.8 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	53	SF	\$40	\$2,112
41083	46.2 to 47.3 feet	Running Slope	8.0-9.0%	6 ft	6	REF		
37093	53.7 to 59.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,762
37095	63.3 to 80.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	96	SF	\$120	\$11,550
55794	75.3 to 76.3 feet	Vertical Change	.3	6 ft	6	REF		
37100	86.1 to 90.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,970
37102	94.3 to 101.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,016
37104	127.2 to 128.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$990
60212	134.4 to 153.1 feet	Driveway				REF		
37105	158.1 to 169.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	61	SF	\$120	\$7,260
56554	163.4 to 164.4 feet	Vertical Change	.4	6 ft	6	REF		
51396	165.8 to 166.8 feet	Vertical Change	-.3	6 ft	6	REF		
56880	168.5 to 169.5 feet	Vertical Change	.5	6 ft	6	REF		
37109	171.8 to 184.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	70	SF	\$120	\$8,382
37115	185.7 to 195.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	55	SF	\$120	\$6,600
51397	188.5 to 189.5 feet	Vertical Change	-.3	6 ft	6	REF		
37117	197.3 to 202.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	30	SF	\$120	\$3,564
37118	206.1 to 216.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	57	SF	\$120	\$6,864
37120	218.7 to 220.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,122
57588	220.1 to 221.1 feet	Vertical Change	2.8	6 ft	6	REF		
37121	223.8 to 225.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,056
37122	225.4 to 228.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261107	3RD ST	655 3RD ST	SONOMA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60213	229.3 to 240.8 feet	Driveway				REF		
37123	232.4 to 243.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	59	SF	\$40	\$2,354
37126	256.0 to 264.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,478
55795	286.8 to 287.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
37129	287.9 to 289.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254
51398	290.0 to 291.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: SW side of 3RD ST Starting at: 655 3RD ST							\$88,847.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	51909261117	3RD ST	MONTEREY AVE	LAKE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
60214	9.2 to 15.6 feet	Driveway				REF			
37134	28.0 to 47.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	106	SF	\$120	\$12,672	
37142	54.1 to 55.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122	
60215	56.0 to 66.8 feet	Driveway				REF			
37143	61.3 to 88.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	149	SF	\$40	\$5,962	
60216	81.0 to 95.6 feet	Driveway				REF			
37152	121.0 to 122.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
37153	129.6 to 131.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386	
60217	136.3 to 155.7 feet	Driveway				REF			
37154	146.4 to 152.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	36	SF	\$40	\$1,430	
37156	154.5 to 155.8 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	7	SF	\$40	\$286	
37157	155.8 to 157.0 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	7	SF	\$40	\$264	
37158	163.7 to 176.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	70	SF	\$120	\$8,382	
37162	180.9 to 188.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	42	SF	\$120	\$5,016	
37164	188.5 to 215.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	148	SF	\$120	\$17,754	
47828	196.8 to 197.8 feet	Vertical Change	-.4	6 ft	6	REF			
47829	216.4 to 217.4 feet	Vertical Change	-.4	6 ft	6	REF			
37169	217.4 to 219.8 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	13	SF	\$120	\$1,584	
37171	221.5 to 223.6 feet	Cross Slope (PAR)	8.0-9.0%	6 ft	12	SF	\$120	\$1,386	
51399	226.2 to 227.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
60218	228.8 to 241.5 feet	Driveway				REF			
37172	234.4 to 239.3 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	27	SF	\$40	\$1,078	
55796	236.3 to 237.3 feet	Vertical Change	.3	6 ft	6	REF			
37174	250.0 to 252.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	13	SF	\$120	\$1,584	
37175	252.4 to 261.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,138	
37177	265.5 to 268.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	14	SF	\$120	\$1,716	
37178	268.4 to 269.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
37179	274.5 to 288.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	78	SF	\$120	\$9,372	
42357	274.8 to 275.8 feet	Vertical Change	-.7	6 ft	6	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261117	3RD ST	MONTEREY AVE	LAKE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37182	293.2 to 294.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
TOTAL COST FOR: SW side of 3RD ST Starting at: MONTEREY AVE							\$80,250.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261120	3RD ST	LAKE AVE	RIVERSIDE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37183	1.1 to 3.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
37184	14.0 to 15.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
37185	24.7 to 28.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,706
37187	35.8 to 44.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,808
51400	66.3 to 67.3 feet	Vertical Change	-3	6 ft	6	LF	\$75	\$413
37189	102.3 to 113.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	60	SF	\$120	\$7,194
37192	122.3 to 124.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
60219	137.2 to 152.8 feet	Driveway				REF		
37193	140.4 to 148.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	43	SF	\$40	\$1,738
37197	151.2 to 155.1 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	21	SF	\$40	\$858
37198	155.1 to 157.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782
60220	161.5 to 176.9 feet	Driveway				REF		
37199	171.3 to 172.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$220
37200	185.3 to 187.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386
188	206.0 to 207.0 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
37201	245.9 to 247.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
51401	284.8 to 285.8 feet	Vertical Change	-3	6 ft	6	LF	\$75	\$413
47830	289.9 to 290.9 feet	Vertical Change	-4	6 ft	6	LF	\$75	\$413

TOTAL COST FOR: SW	<i>side of 3RD ST Starting at: LAKE AVE</i>	\$27,846.50
---------------------------	---	--------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261123	3RD ST	RIVERSIDE AVE	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51402	14.2 to 15.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
55797	25.1 to 26.1 feet	Vertical Change	.3	6 ft	6	REF		
37202	25.1 to 28.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,442
55798	28.7 to 29.7 feet	Vertical Change	.3	6 ft	6	REF		
37204	34.9 to 36.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
57326	45.8 to 46.8 feet	Vertical Change	.9	6 ft	6	SF	\$75	\$413
37205	62.7 to 71.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,610
37208	77.4 to 80.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	19	SF	\$120	\$2,244
37210	80.8 to 89.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$5,940
37213	94.3 to 95.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
37214	97.8 to 125.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	151	SF	\$120	\$18,150
47831	121.1 to 122.1 feet	Vertical Change	-.4	6 ft	6	REF		
37224	125.3 to 129.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	22	SF	\$120	\$2,640
57487	129.0 to 130.0 feet	Vertical Change	1.6	6 ft	6	REF		
37226	129.3 to 130.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
60221	133.4 to 158.2 feet	Driveway				REF		
37227	134.6 to 136.7 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	12	SF	\$40	\$462
55799	134.9 to 135.9 feet	Vertical Change	.3	6 ft	6	REF		
37228	136.7 to 138.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	7	SF	\$40	\$286
37229	141.9 to 144.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	14	SF	\$40	\$572
37230	157.8 to 159.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	10	SF	\$40	\$418
37231	162.9 to 163.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	6	SF	\$120	\$660
37232	167.5 to 169.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	13	SF	\$120	\$1,518
37233	170.6 to 171.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858
37234	171.9 to 172.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
37235	182.5 to 189.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,488
37237	191.5 to 194.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	15	SF	\$120	\$1,848
37238	196.5 to 198.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,188

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261123	3RD ST	RIVERSIDE AVE	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37239	204.8 to 206.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386
37240	212.2 to 219.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	41	SF	\$120	\$4,884
37242	226.3 to 230.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838
37243	242.8 to 247.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168
37244	257.8 to 264.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	39	SF	\$120	\$4,686
37245	265.8 to 275.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	54	SF	\$120	\$6,468
37247	286.1 to 297.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	63	SF	\$120	\$7,590
TOTAL COST FOR: SW side of 3RD ST Starting at: RIVERSIDE AVE								\$84,139.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261127	4TH ST	KINGS AVE	RIVERSIDE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37249	0.0 to 15.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	87	SF	\$120	\$10,428
189	2.4 to 3.4 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
55800	16.3 to 17.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
37253	19.3 to 28.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	50	SF	\$120	\$6,006
37254	34.4 to 63.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	158	SF	\$120	\$19,008
55801	37.4 to 38.4 feet	Vertical Change	.3	6 ft	6	REF		
57600	53.0 to 54.0 feet	Vertical Change	2.9	6 ft	6	REF		
37259	63.5 to 70.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,686
51403	71.2 to 72.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
37261	74.8 to 83.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,544
47832	85.7 to 86.7 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
37264	101.2 to 104.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112
37265	107.5 to 132.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	138	SF	\$120	\$16,566
45438	115.8 to 116.8 feet	Vertical Change	-.5	6 ft	6	REF		
45439	124.3 to 125.3 feet	Vertical Change	-.5	6 ft	6	REF		
60222	132.8 to 175.7 feet	Driveway				REF		
55802	134.0 to 135.0 feet	Vertical Change	.3	6 ft	6	REF		
37270	140.0 to 141.0 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	6	SF	\$40	\$220
37271	143.0 to 144.0 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	6	SF	\$40	\$220
37272	146.2 to 149.7 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	19	SF	\$40	\$770
37274	149.7 to 151.6 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	10	SF	\$40	\$418
37275	151.6 to 154.4 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	15	SF	\$40	\$616
37277	156.5 to 157.5 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	6	SF	\$40	\$220
37278	158.9 to 168.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	55	SF	\$40	\$2,200
56881	222.3 to 223.3 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
55803	230.4 to 231.4 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
45440	265.0 to 266.0 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413
37281	275.1 to 280.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261127	4TH ST	KINGS AVE	RIVERSIDE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37284	283.3 to 287.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640
56882	297.8 to 298.8 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
41084	305.1 to 307.2 feet	Running Slope	5.0-6.0%	6 ft	12	SF	\$120	\$1,386
TOTAL COST FOR: NE side of 4TH ST Starting at: KINGS AVE							\$79,590.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261128	4TH ST	RIVERSIDE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41085	0.2 to 1.9 feet	Running Slope	5.0-6.0%	6 ft	9	REF		
37285	0.8 to 2.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
57369	2.1 to 3.1 feet	Vertical Change	1	6 ft	6	SF	\$75	\$413
37286	7.4 to 9.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452
37287	13.0 to 16.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	21	SF	\$120	\$2,508
37288	21.0 to 28.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	43	SF	\$120	\$5,214
51404	21.2 to 22.2 feet	Vertical Change	-.3	6 ft	6	REF		
37290	29.4 to 39.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	55	SF	\$120	\$6,600
37293	50.8 to 55.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838
55804	66.2 to 67.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
37294	104.8 to 107.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$1,980
37295	115.9 to 128.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	69	SF	\$120	\$8,250
60223	115.9 to 141.8 feet	Driveway				REF		
37298	130.8 to 133.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	15	SF	\$40	\$594
37299	142.3 to 145.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	19	SF	\$40	\$770
TOTAL COST FOR: NE side of 4TH ST Starting at: RIVERSIDE AVE							\$31,823.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261132	4TH ST	LAKE AVE	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37300	0.0 to 4.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640
190	2.0 to 3.0 feet	Continuous Width		6 ft	6	SF	\$120	\$660
37302	9.8 to 14.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904
191	12.9 to 13.9 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
37305	16.3 to 20.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
55805	20.8 to 21.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
37307	39.1 to 42.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376
37308	67.4 to 77.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	57	SF	\$120	\$6,864
60224	67.9 to 80.8 feet	Driveway				REF		
192	88.3 to 89.3 feet	Continuous Width		6 ft	6	SF	\$120	\$660
56555	89.3 to 90.3 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
37312	111.0 to 119.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346
37313	125.4 to 127.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254
60225	135.8 to 155.5 feet	Driveway				REF		
37314	137.3 to 141.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	21	SF	\$40	\$858
37316	158.8 to 160.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
37317	167.9 to 170.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914
57280	180.3 to 181.3 feet	Vertical Change	.8	6 ft	6	SF	\$75	\$413
37318	186.3 to 191.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,102
37319	194.9 to 198.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,442
60226	196.7 to 219.4 feet	Driveway				REF		
37321	262.0 to 264.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
56883	262.5 to 263.5 feet	Vertical Change	.5	6 ft	6	REF		
37322	266.7 to 268.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
TOTAL COST FOR: NE side of 4TH ST Starting at: LAKE AVE							\$38,032.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261135	4TH ST	SIDEWALK BEGINS	SONOMA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60227	0.4 to 15.1 feet	Driveway				REF		
37323	7.2 to 25.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	98	SF	\$40	\$3,916
37327	27.1 to 35.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,742
37329	38.2 to 45.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,016
60228	42.5 to 54.8 feet	Driveway				REF		
56556	56.3 to 57.3 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
37333	62.1 to 64.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650
193	74.6 to 75.6 feet	Continuous Width		6 ft	6	SF	\$120	\$660
37334	76.5 to 80.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
57105	83.2 to 84.2 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413
37335	87.5 to 96.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,742
37337	107.9 to 109.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
37338	120.7 to 124.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376
55806	136.7 to 137.7 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: NE side of 4TH ST Starting at: SIDEWALK BEGINS							\$29,903.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261139	4TH ST	SONOMA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37339	5.0 to 7.1 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	21	SF	\$120	\$2,520
37340	10.8 to 12.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	15	SF	\$120	\$1,800
37341	26.9 to 30.4 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	35	SF	\$120	\$4,200
37343	34.1 to 37.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	32	SF	\$120	\$3,840
55807	46.3 to 47.3 feet	Vertical Change	.3	10 ft	10	LF	\$75	\$750
37344	47.5 to 48.9 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	14	SF	\$120	\$1,680
37345	58.0 to 68.7 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	107	SF	\$120	\$12,840
60229	85.4 to 104.3 feet	Driveway				REF		
51405	139.4 to 140.4 feet	Vertical Change	-.3	10 ft	10	REF		
37347	140.0 to 145.3 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	53	SF	\$120	\$6,360
TOTAL COST FOR: NE side of 4TH ST Starting at: SONOMA AVE							\$33,990.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261141	4TH ST	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41086	0.0 to 1.0 feet	Running Slope	5.0-6.0%	10 ft	10	SF	\$120	\$1,200
37349	20.1 to 25.1 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	50	SF	\$120	\$6,000
37351	25.1 to 29.0 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	39	SF	\$120	\$4,680
37352	31.4 to 32.4 feet	Cross Slope (PAR)	4.0-5.0%	10 ft	10	SF	\$120	\$1,200
60230	32.1 to 48.3 feet	Driveway				REF		
51406	33.5 to 34.5 feet	Vertical Change	-.3	10 ft	10	REF		
37353	36.9 to 49.3 feet	Cross Slope (Driveway)	>15%	10 ft	124	SF	\$40	\$4,960
TOTAL COST FOR: SW side of 4TH ST Starting at: SIDEWALK BEGINS							\$18,040.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261142	4TH ST	SIDEWALK BEGINS	SONOMA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37354	0.4 to 4.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	42	SF	\$120	\$5,040
60231	39.8 to 61.0 feet	Driveway				REF		
37355	54.0 to 57.4 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	34	SF	\$40	\$1,360
37357	60.6 to 62.4 feet	Cross Slope (Driveway)	2.0-3.0%	10 ft	18	SF	\$40	\$720
51407	66.3 to 67.3 feet	Vertical Change	-.3	10 ft	10	LF	\$75	\$750
37358	116.9 to 123.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	67	SF	\$120	\$8,040
42358	126.3 to 127.3 feet	Vertical Change	-.7	10 ft	10	SF	\$75	\$750
56884	131.4 to 132.4 feet	Vertical Change	.5	10 ft	10	SF	\$75	\$750
37360	134.8 to 136.6 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	18	SF	\$120	\$2,160
41087	134.8 to 136.0 feet	Running Slope	5.0-6.0%	10 ft	12	REF		
TOTAL COST FOR: SW side of 4TH ST Starting at: SIDEWALK BEGINS							\$19,570.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261144	4TH ST	SONOMA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37361	5.4 to 9.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904
37362	13.3 to 37.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	134	SF	\$120	\$16,104
56557	28.7 to 29.7 feet	Vertical Change	.4	6 ft	6	REF		
37369	42.8 to 44.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	9	SF	\$120	\$1,056
37370	45.9 to 64.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	103	SF	\$120	\$12,342
56558	61.1 to 62.1 feet	Vertical Change	.4	6 ft	6	REF		
56885	67.9 to 68.9 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
51408	79.3 to 82.3 feet	Vertical Change	-.3	6 ft	17	LF	\$75	\$1,238
37375	86.1 to 90.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640
57106	94.1 to 95.1 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413
37377	101.9 to 113.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	63	SF	\$120	\$7,524
37381	116.2 to 129.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	75	SF	\$120	\$9,042
57107	119.3 to 120.3 feet	Vertical Change	.6	6 ft	6	REF		
55808	122.3 to 123.3 feet	Vertical Change	.3	6 ft	6	REF		
37385	134.1 to 140.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,092
56559	137.7 to 138.7 feet	Vertical Change	.4	6 ft	6	REF		
TOTAL COST FOR: SW side of 4TH ST Starting at: SONOMA AVE							\$57,766.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261145	4TH ST	SIDEWALK BEGINS	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37388	0.0 to 3.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,508
41088	0.1 to 1.6 feet	Running Slope	5.0-6.0%	6 ft	8	REF		
60232	0.8 to 16.7 feet	Driveway				REF		
47834	26.5 to 27.5 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
47835	31.7 to 32.7 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
43543	40.8 to 41.8 feet	Vertical Change	-.6	6 ft	6	SF	\$75	\$413
37389	110.7 to 119.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	48	SF	\$120	\$5,742
37393	128.3 to 130.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452
55809	128.8 to 129.8 feet	Vertical Change	.3	6 ft	6	REF		
37395	132.6 to 135.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	14	SF	\$120	\$1,716
TOTAL COST FOR: SW side of 4TH ST Starting at: SIDEWALK BEGINS							\$12,655.50	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261148	4TH ST	MONTEREY AVE	LAKE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55810	33.6 to 34.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
55811	46.2 to 49.5 feet	Vertical Change	.3	6 ft	18	LF	\$75	\$1,361
37399	50.8 to 51.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726
37400	53.9 to 55.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
41091	56.1 to 57.2 feet	Running Slope	5.0-6.0%	6 ft	6	SF	\$120	\$726
55812	58.3 to 59.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
37401	96.8 to 108.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	63	SF	\$120	\$7,524
41492	108.3 to 109.3 feet	Vertical Change	-1.1	6 ft	6	SF	\$75	\$413
37405	109.5 to 111.3 feet	Cross Slope (PAR)	7.0-8.0%	6 ft	10	SF	\$120	\$1,188
51410	110.9 to 112.2 feet	Vertical Change	-.3	6 ft	7	REF		
60233	114.7 to 133.7 feet	Driveway				REF		
37406	115.2 to 117.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	10	SF	\$40	\$418
55813	120.7 to 121.7 feet	Vertical Change	.3	6 ft	6	REF		
37407	138.1 to 143.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,366
60234	138.9 to 175.7 feet	Driveway				REF		
57475	140.2 to 141.2 feet	Vertical Change	1.5	6 ft	6	REF		
55814	155.3 to 156.3 feet	Vertical Change	.3	6 ft	6	REF		
37409	177.2 to 187.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	56	SF	\$120	\$6,666
37412	196.2 to 252.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	309	SF	\$120	\$37,026
56886	221.4 to 222.4 feet	Vertical Change	.5	6 ft	6	REF		
57327	238.3 to 239.3 feet	Vertical Change	.9	6 ft	6	REF		
37430	258.3 to 273.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	83	SF	\$120	\$9,966
56887	266.3 to 267.3 feet	Vertical Change	.5	6 ft	6	REF		
37434	278.3 to 279.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
56562	281.6 to 282.6 feet	Vertical Change	.4	6 ft	6	REF		
37435	282.0 to 283.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,188
57650	283.3 to 284.3 feet	Vertical Change	3.4	6 ft	6	REF		
37436	287.3 to 295.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,544

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261148	4TH ST	MONTEREY AVE	LAKE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
56888	296.7 to 297.7 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
37437	297.8 to 299.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
51412	298.4 to 299.4 feet	Vertical Change	-.3	6 ft	6	REF		
TOTAL COST FOR: SW side of 4TH ST Starting at: MONTEREY AVE							\$80,319.25	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261150	4TH ST	LAKE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37438	0.0 to 2.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	13	SF	\$120	\$1,518
37439	3.3 to 15.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	69	SF	\$120	\$8,316
51413	12.4 to 13.4 feet	Vertical Change	-.3	6 ft	6	REF		
37442	18.3 to 19.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726
37443	19.4 to 29.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	57	SF	\$120	\$6,798
55815	27.3 to 28.3 feet	Vertical Change	.3	6 ft	6	REF		
37448	31.8 to 85.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	297	SF	\$120	\$35,640
57108	38.3 to 39.3 feet	Vertical Change	.6	6 ft	6	REF		
60235	74.7 to 88.3 feet	Driveway				REF		
37457	88.8 to 91.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716
37458	94.2 to 107.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	73	SF	\$120	\$8,712
37462	110.6 to 113.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	18	SF	\$120	\$2,178
37463	113.9 to 130.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	92	SF	\$120	\$11,022
37467	135.8 to 137.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
TOTAL COST FOR: SW side of 4TH ST Starting at: LAKE AVE							\$77,616.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261153	4TH ST	RIVERSIDE AVE	KINGS AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37468	0.0 to 1.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660
37469	1.7 to 3.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386
37470	6.0 to 8.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518
37471	12.6 to 34.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	120	SF	\$120	\$14,388
37478	35.9 to 50.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	78	SF	\$120	\$9,372
37481	53.4 to 55.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,584
37482	60.9 to 64.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
37483	73.3 to 87.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	76	SF	\$120	\$9,108
57555	97.4 to 98.4 feet	Vertical Change	2.3	6 ft	6	SF	\$75	\$413
37486	100.5 to 104.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904
60236	114.8 to 131.3 feet	Driveway				REF		
60237	136.2 to 154.0 feet	Driveway				REF		
37487	164.8 to 171.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,620
60238	167.7 to 176.5 feet	Driveway				REF		
37489	175.3 to 178.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	20	SF	\$40	\$792
37491	182.5 to 191.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$6,006
37494	202.6 to 204.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254
37495	209.1 to 226.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	97	SF	\$120	\$11,616
37499	235.1 to 240.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,762
60239	235.3 to 252.7 feet	Driveway				REF		
37500	250.8 to 269.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	101	SF	\$40	\$4,026
37507	273.5 to 296.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	124	SF	\$120	\$14,916
TOTAL COST FOR: SW side of 4TH ST Starting at: RIVERSIDE AVE							\$90,898.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NE	51909261159	6TH ST	KINGS AVE	RIVERSIDE AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
37514	6.8 to 9.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$1,980	
37516	12.0 to 13.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
37517	29.5 to 32.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650	
37519	40.5 to 41.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858	
194	43.2 to 44.2 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
37520	61.2 to 65.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640	
37522	67.7 to 70.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848	
55816	71.6 to 72.6 feet	Vertical Change	.3	6 ft	6	REF			
37523	72.6 to 75.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,112	
37525	84.5 to 88.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,508	
57688	98.3 to 99.3 feet	Vertical Change	3.7	6 ft	6	SF	\$75	\$413	
57547	103.9 to 104.9 feet	Vertical Change	2.2	6 ft	6	SF	\$75	\$413	
37526	121.9 to 123.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
37527	126.3 to 129.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782	
37528	133.5 to 135.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518	
60240	136.5 to 154.2 feet	Driveway				REF			
37530	138.6 to 144.2 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	31	SF	\$40	\$1,232	
37533	147.8 to 153.2 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	30	SF	\$40	\$1,188	
37535	154.4 to 158.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	20	SF	\$40	\$792	
60241	160.3 to 169.2 feet	Driveway				REF			
195	195.6 to 196.6 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
57684	224.3 to 225.3 feet	Vertical Change	3.6	6 ft	6	SF	\$75	\$413	
55817	229.6 to 230.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
37537	271.3 to 272.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
37538	275.8 to 277.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$792	
37539	277.0 to 283.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	33	SF	\$120	\$3,960	
TOTAL COST FOR: NE side of 6TH ST Starting at: KINGS AVE								\$29,018.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261201	6TH ST	RIVERSIDE AVE	330 6TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37543	2.4 to 10.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,544
37546	10.8 to 14.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	20	SF	\$120	\$2,442
37548	17.3 to 18.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,056
37549	18.9 to 27.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346
37552	27.0 to 33.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	35	SF	\$120	\$4,224
37554	34.7 to 97.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	344	SF	\$120	\$41,316
56563	103.6 to 104.6 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
37573	106.8 to 109.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046
TOTAL COST FOR: NE side of 6TH ST Starting at: RIVERSIDE AVE							\$62,386.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261204	6TH ST	330 6TH ST	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60242	7.8 to 32.3 feet	Driveway				REF		
37574	8.0 to 11.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	20	SF	\$40	\$792
55818	14.2 to 15.2 feet	Vertical Change	.3	6 ft	6	REF		
37576	17.4 to 18.8 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	8	SF	\$40	\$308
37577	19.8 to 27.2 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	41	SF	\$40	\$1,628
37580	27.2 to 29.9 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	15	SF	\$40	\$594
41092	32.2 to 33.3 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
37582	39.8 to 52.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	71	SF	\$120	\$8,514
51414	47.9 to 48.9 feet	Vertical Change	-.3	6 ft	6	REF		
37587	55.8 to 64.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	48	SF	\$120	\$5,742
37589	64.8 to 66.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254
37590	70.6 to 72.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
55819	88.9 to 89.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
51415	91.3 to 92.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
37591	92.5 to 93.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
37592	96.3 to 97.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$924
37593	100.8 to 115.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	79	SF	\$120	\$9,504
55820	114.3 to 115.3 feet	Vertical Change	.3	6 ft	6	REF		
37596	123.6 to 125.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,122
37597	125.3 to 132.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	41	SF	\$120	\$4,950
37600	136.2 to 143.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,082
37602	153.3 to 157.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
37603	160.3 to 168.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	46	SF	\$120	\$5,544
37606	169.3 to 175.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,158
37608	180.8 to 190.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	56	SF	\$120	\$6,666
37612	193.2 to 202.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	52	SF	\$120	\$6,270
37613	207.8 to 213.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630
51416	224.5 to 225.5 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261204	6TH ST	330 6TH ST	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37614	240.7 to 252.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	63	SF	\$120	\$7,590
60243	241.8 to 260.5 feet	Driveway				REF		
37618	253.0 to 257.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	26	SF	\$40	\$1,056
37620	262.5 to 277.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	81	SF	\$120	\$9,702
37624	277.8 to 286.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,610
37627	287.3 to 290.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	18	SF	\$120	\$2,178
60244	291.3 to 314.2 feet	Driveway				REF		
37629	297.4 to 312.2 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	81	SF	\$40	\$3,256
55821	315.2 to 316.2 feet	Vertical Change	.3	6 ft	6	REF		
37634	315.2 to 321.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	36	SF	\$120	\$4,356
55822	322.3 to 323.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
37637	325.2 to 329.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	26	SF	\$120	\$3,102
37638	330.8 to 333.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650
37639	336.6 to 340.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,442
37640	342.7 to 368.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	141	SF	\$120	\$16,896
56564	362.4 to 363.4 feet	Vertical Change	.4	6 ft	6	REF		
37647	372.3 to 383.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	63	SF	\$120	\$7,590
55823	382.3 to 383.3 feet	Vertical Change	.3	6 ft	6	REF		
56565	392.4 to 393.4 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
37651	395.8 to 439.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	242	SF	\$120	\$29,040
51417	402.4 to 403.4 feet	Vertical Change	-.3	6 ft	6	REF		
56566	422.1 to 423.1 feet	Vertical Change	.4	6 ft	6	REF		
51418	439.3 to 440.3 feet	Vertical Change	-.3	6 ft	6	REF		
37665	442.9 to 456.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	76	SF	\$120	\$9,174
55824	448.6 to 449.6 feet	Vertical Change	.3	6 ft	6	REF		
37669	457.3 to 476.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	106	SF	\$120	\$12,672
51419	458.8 to 459.8 feet	Vertical Change	-.3	6 ft	6	REF		
55825	469.2 to 470.2 feet	Vertical Change	.3	6 ft	6	REF		

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261204	6TH ST	330 6TH ST	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37676	479.0 to 503.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	133	SF	\$120	\$15,906
56567	500.8 to 501.8 feet	Vertical Change	.4	6 ft	6	REF		
55826	516.6 to 517.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
37683	521.9 to 527.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	30	SF	\$120	\$3,564
51420	526.5 to 527.5 feet	Vertical Change	-.3	6 ft	6	REF		
TOTAL COST FOR: NE side of 6TH ST Starting at: 330 6TH ST							\$210,023.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	51909261209	6TH ST	VENTURA AVE	SONOMA AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
37684	0.0 to 3.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	17	SF	\$120	\$1,980	
37685	5.0 to 6.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254	
37686	9.3 to 15.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	33	SF	\$120	\$3,960	
37690	17.7 to 18.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726	
37691	21.3 to 27.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	33	SF	\$120	\$3,960	
37693	27.6 to 32.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	26	SF	\$120	\$3,102	
37694	34.1 to 47.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	71	SF	\$120	\$8,514	
37698	49.9 to 54.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	27	SF	\$120	\$3,234	
37701	54.8 to 64.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	52	SF	\$120	\$6,204	
37705	65.2 to 66.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
51421	67.9 to 68.9 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
37706	69.3 to 73.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574	
37708	78.8 to 80.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188	
37709	82.8 to 84.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,254	
37710	87.5 to 90.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848	
37711	92.6 to 100.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,214	
37714	101.8 to 122.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	116	SF	\$120	\$13,860	
37722	122.8 to 124.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
55827	123.9 to 124.9 feet	Vertical Change	.3	6 ft	6	REF			
60245	125.3 to 144.6 feet	Driveway				REF			
37723	128.0 to 131.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	21	SF	\$40	\$858	
51422	138.8 to 139.8 feet	Vertical Change	-.3	6 ft	6	REF			
37725	146.1 to 147.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990	
37726	149.7 to 158.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	47	SF	\$120	\$5,676	
37727	158.3 to 165.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,016	
37731	173.8 to 175.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122	
37732	179.0 to 184.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	32	SF	\$120	\$3,894	
37734	184.9 to 187.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261209	6TH ST	VENTURA AVE	SONOMA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37735	225.9 to 247.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	116	SF	\$120	\$13,926
55828	248.5 to 249.5 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
37743	263.3 to 283.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	112	SF	\$120	\$13,464
TOTAL COST FOR: SW side of 6TH ST Starting at: VENTURA AVE							\$107,481.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261211	6TH ST	LAKE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51423	5.8 to 6.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
37749	56.7 to 59.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716
37750	125.3 to 132.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,554
56568	131.0 to 132.0 feet	Vertical Change	.4	6 ft	6	REF		
37752	138.7 to 140.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
TOTAL COST FOR: SW side of 6TH ST Starting at: LAKE AVE								\$7,738.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261213	6TH ST	SIDEWALK BEGINS	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60246	1.9 to 23.7 feet	Driveway				REF		
37753	8.2 to 9.2 feet	Cross Slope (Driveway)	2.0-3.0%	12 ft	12	SF	\$40	\$480
37754	19.7 to 25.0 feet	Cross Slope (Driveway)	2.0-3.0%	12 ft	64	SF	\$40	\$2,544
37756	27.2 to 38.3 feet	Cross Slope (PAR)	3.0-4.0%	12 ft	133	SF	\$120	\$15,984
60247	35.0 to 50.3 feet	Driveway				REF		
42359	35.8 to 36.8 feet	Vertical Change	-7	12 ft	12	REF		
37762	40.2 to 42.2 feet	Cross Slope (Driveway)	5.0-6.0%	12 ft	24	SF	\$40	\$960
37764	77.8 to 85.1 feet	Cross Slope (PAR)	2.0-3.0%	12 ft	88	SF	\$120	\$10,512
47836	80.8 to 81.8 feet	Vertical Change	-4	12 ft	12	REF		
41883	109.2 to 110.2 feet	Vertical Change	-8	12 ft	12	SF	\$75	\$900
57420	137.3 to 138.3 feet	Vertical Change	1.2	12 ft	12	SF	\$75	\$900
TOTAL COST FOR: SW side of 6TH ST Starting at: SIDEWALK BEGINS							\$32,280.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	51909261216	6TH ST	MONTEREY AVE	LAKE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
196	6.6 to 7.6 feet	Continuous Width		12 ft	12	SF	\$120	\$1,440	
37771	26.1 to 30.3 feet	Cross Slope (PAR)	2.0-3.0%	12 ft	50	SF	\$120	\$6,048	
57579	30.4 to 31.4 feet	Vertical Change	2.7	12 ft	12	SF	\$75	\$900	
57529	34.3 to 35.3 feet	Vertical Change	2	12 ft	12	SF	\$75	\$900	
57503	39.2 to 40.2 feet	Vertical Change	1.7	12 ft	12	SF	\$75	\$900	
37773	44.9 to 46.5 feet	Cross Slope (PAR)	3.0-4.0%	12 ft	19	SF	\$120	\$2,304	
60248	46.8 to 59.5 feet	Driveway				REF			
37774	52.8 to 54.6 feet	Cross Slope (Driveway)	3.0-4.0%	12 ft	22	SF	\$40	\$864	
37775	54.6 to 57.7 feet	Cross Slope (Driveway)	2.0-3.0%	12 ft	37	SF	\$40	\$1,488	
60249	63.8 to 75.8 feet	Driveway				REF			
37777	73.8 to 75.3 feet	Cross Slope (Driveway)	2.0-3.0%	12 ft	18	SF	\$40	\$720	
37778	80.1 to 83.6 feet	Cross Slope (PAR)	3.0-4.0%	12 ft	42	SF	\$120	\$5,040	
37780	83.8 to 96.4 feet	Cross Slope (PAR)	2.0-3.0%	12 ft	151	SF	\$120	\$18,144	
37785	119.2 to 126.7 feet	Cross Slope (PAR)	2.0-3.0%	12 ft	90	SF	\$120	\$10,800	
60250	133.9 to 155.6 feet	Driveway				REF			
56569	135.3 to 136.3 feet	Vertical Change	.4	12 ft	12	REF			
37788	139.3 to 144.7 feet	Cross Slope (Driveway)	2.0-3.0%	12 ft	65	SF	\$40	\$2,592	
37790	144.9 to 148.8 feet	Cross Slope (Driveway)	4.0-5.0%	12 ft	47	SF	\$40	\$1,872	
37792	148.9 to 154.4 feet	Cross Slope (Driveway)	6.0-7.0%	12 ft	66	SF	\$40	\$2,640	
37794	160.1 to 165.3 feet	Cross Slope (PAR)	2.0-3.0%	12 ft	62	SF	\$120	\$7,488	
37796	166.1 to 186.8 feet	Cross Slope (PAR)	4.0-5.0%	12 ft	248	SF	\$120	\$29,808	
37803	186.8 to 191.5 feet	Cross Slope (PAR)	2.0-3.0%	12 ft	56	SF	\$120	\$6,768	
37804	195.3 to 206.6 feet	Cross Slope (PAR)	2.0-3.0%	12 ft	136	SF	\$120	\$16,272	
197	199.0 to 200.0 feet	Continuous Width		12 ft	12	SF	\$120	\$1,440	
37808	210.3 to 211.9 feet	Cross Slope (PAR)	2.0-3.0%	12 ft	19	SF	\$120	\$2,304	
37809	214.6 to 215.8 feet	Cross Slope (PAR)	3.0-4.0%	12 ft	14	SF	\$120	\$1,728	
37810	218.3 to 225.1 feet	Cross Slope (PAR)	2.0-3.0%	12 ft	82	SF	\$120	\$9,792	
55830	221.8 to 222.8 feet	Vertical Change	.3	12 ft	12	REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261216	6TH ST	MONTEREY AVE	LAKE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37813	229.3 to 231.7 feet	Cross Slope (PAR)	2.0-3.0%	12 ft	29	SF	\$120	\$3,456
37814	236.3 to 239.3 feet	Cross Slope (PAR)	2.0-3.0%	12 ft	36	SF	\$120	\$4,320
55831	239.1 to 240.1 feet	Vertical Change	.3	12 ft	12	REF		
37816	245.1 to 250.2 feet	Cross Slope (PAR)	2.0-3.0%	12 ft	61	SF	\$120	\$7,344
55832	251.3 to 252.3 feet	Vertical Change	.3	12 ft	12	REF		
37818	252.3 to 253.8 feet	Cross Slope (PAR)	2.0-3.0%	12 ft	18	SF	\$120	\$2,160
37819	258.5 to 292.3 feet	Cross Slope (PAR)	2.0-3.0%	12 ft	406	SF	\$120	\$48,672
TOTAL COST FOR: SW side of 6TH ST Starting at: MONTEREY AVE							\$198,204.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261218	6TH ST	LAKE AVE	RIVERSIDE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37826	0.0 to 11.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	63	SF	\$120	\$7,590
55833	10.3 to 11.3 feet	Vertical Change	.3	6 ft	6	REF		
37828	14.2 to 17.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046
57109	19.8 to 20.8 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413
37829	22.8 to 33.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	57	SF	\$120	\$6,798
60251	32.4 to 49.5 feet	Driveway				REF		
37833	38.7 to 42.0 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	18	SF	\$40	\$726
37835	42.6 to 47.6 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	28	SF	\$40	\$1,100
37838	49.3 to 58.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	52	SF	\$40	\$2,090
37842	62.4 to 65.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	16	SF	\$120	\$1,914
37843	67.1 to 89.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	122	SF	\$120	\$14,652
37849	110.8 to 133.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	126	SF	\$120	\$15,114
60252	133.2 to 150.1 feet	Driveway				REF		
37855	148.0 to 149.6 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	9	SF	\$40	\$352
56570	148.2 to 149.2 feet	Vertical Change	.4	6 ft	6	REF		
37856	151.9 to 157.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	28	SF	\$120	\$3,366
60253	159.9 to 182.6 feet	Driveway				REF		
37859	166.4 to 178.5 feet	Cross Slope (Driveway)	13.014	6 ft	67	SF	\$40	\$2,662
41094	182.3 to 183.8 feet	Running Slope	5.0-6.0%	6 ft	8	REF		
37863	195.5 to 199.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904
37864	208.7 to 215.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224
37866	222.2 to 237.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	83	SF	\$120	\$9,900
37870	249.3 to 269.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	113	SF	\$120	\$13,530
37874	273.3 to 276.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376
TOTAL COST FOR: SW side of 6TH ST Starting at: LAKE AVE							\$91,756.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261219	6TH ST	RIVERSIDE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51424	30.1 to 31.1 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
55834	32.3 to 33.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
37875	47.5 to 53.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,828
37877	57.6 to 59.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254
37878	67.3 to 68.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
37879	77.7 to 78.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
37880	95.6 to 98.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,584
37881	105.7 to 108.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914
60254	108.2 to 127.8 feet	Driveway				REF		
41095	109.5 to 111.0 feet	Running Slope	5.0-6.0%	6 ft	8	REF		
37882	112.2 to 113.4 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	7	SF	\$40	\$264
37883	116.8 to 124.2 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	41	SF	\$40	\$1,628
37886	124.2 to 125.3 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	6	SF	\$40	\$242
TOTAL COST FOR: SW side of 6TH ST Starting at: RIVERSIDE AVE							\$12,925.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261224	6TH ST	SIDEWALK BEGINS	RIVERSIDE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37887	0.1 to 28.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	155	SF	\$120	\$18,612
56889	4.0 to 5.0 feet	Vertical Change	.5	6 ft	6	REF		
51425	27.7 to 28.7 feet	Vertical Change	-.3	6 ft	6	REF		
60255	27.9 to 52.5 feet	Driveway				REF		
37893	33.2 to 52.9 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	108	SF	\$40	\$4,334
41096	53.3 to 55.9 feet	Running Slope	6.0-7.0%	6 ft	14	SF	\$120	\$1,716
37897	56.7 to 74.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	97	SF	\$120	\$11,682
37898	74.7 to 90.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	87	SF	\$120	\$10,494
37900	93.2 to 97.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
37901	101.1 to 134.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	185	SF	\$120	\$22,242
55835	136.0 to 137.0 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
37908	139.5 to 140.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660
TOTAL COST FOR: NE side of 6TH ST Starting at: SIDEWALK BEGINS							\$73,188.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261226	6TH ST	RIVERSIDE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37909	15.3 to 45.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	168	SF	\$120	\$20,196
51426	31.4 to 32.4 feet	Vertical Change	-.3	6 ft	6	REF		
37915	49.1 to 50.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
55836	57.7 to 58.7 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
37916	60.2 to 66.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,092
37917	70.9 to 74.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
55837	78.9 to 79.9 feet	Vertical Change	.3	6 ft	6	REF		
37918	79.2 to 87.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,148
60256	86.3 to 107.5 feet	Driveway				REF		
37919	91.6 to 108.7 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	94	SF	\$40	\$3,762
41097	108.8 to 110.4 feet	Running Slope	5.0-6.0%	6 ft	9	SF	\$120	\$1,056
57282	109.8 to 110.8 feet	Vertical Change	.8	6 ft	6	SF	\$75	\$413
198	111.9 to 112.9 feet	Continuous Width		6 ft	6	SF	\$120	\$660
37924	138.1 to 141.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376
TOTAL COST FOR: NE side of 6TH ST Starting at: RIVERSIDE AVE							\$41,877.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261229	6TH ST	SIDEWALK BEGINS	MONTEREY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
57110	21.7 to 22.7 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413
37926	23.0 to 25.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386
51427	30.8 to 31.8 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
60257	38.0 to 56.4 feet	Driveway				REF		
55838	38.9 to 39.9 feet	Vertical Change	.3	6 ft	6	REF		
37927	39.7 to 42.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	15	SF	\$40	\$616
37928	46.1 to 59.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	75	SF	\$40	\$3,014
51428	57.6 to 58.7 feet	Vertical Change	-.3	6 ft	6	REF		
37930	65.8 to 73.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	44	SF	\$120	\$5,280
37933	78.3 to 81.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046
37934	84.2 to 99.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	81	SF	\$120	\$9,768
37937	102.1 to 103.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
55839	107.8 to 108.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
51430	118.3 to 119.3 feet	Vertical Change	-.3	6 ft	6	REF		
37938	118.8 to 120.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
37939	123.2 to 128.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	29	SF	\$120	\$3,498
37941	128.5 to 142.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	78	SF	\$120	\$9,372
51431	134.4 to 135.4 feet	Vertical Change	-.3	6 ft	6	REF		
51432	139.5 to 140.5 feet	Vertical Change	-.3	6 ft	6	REF		
TOTAL COST FOR: NE side of 6TH ST Starting at: SIDEWALK BEGINS							\$37,933.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261231	6TH ST	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37946	3.0 to 6.2 feet	Cross Slope (PAR)	3.0-4.0%	10 ft	32	SF	\$120	\$3,840
37947	6.2 to 7.2 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	10	SF	\$120	\$1,200
57217	9.4 to 10.4 feet	Vertical Change	.7	10 ft	10	SF	\$75	\$750
37948	10.9 to 13.0 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	21	SF	\$120	\$2,520
56571	22.7 to 23.7 feet	Vertical Change	.4	10 ft	10	LF	\$75	\$750
37949	28.3 to 31.4 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	31	SF	\$120	\$3,720
60258	34.1 to 46.3 feet	Driveway				REF		
60259	64.8 to 76.8 feet	Driveway				REF		
60260	94.6 to 120.3 feet	Driveway				REF		
37950	133.2 to 136.9 feet	Cross Slope (PAR)	2.0-3.0%	10 ft	37	SF	\$120	\$4,440
TOTAL COST FOR: NE side of 6TH ST Starting at: SIDEWALK BEGINS							\$17,220.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261232	7TH ST	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37951	0.0 to 3.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244
37953	8.2 to 13.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,432
37954	16.6 to 40.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	133	SF	\$120	\$15,972
55840	21.3 to 22.3 feet	Vertical Change	.3	6 ft	6	REF		
55841	31.3 to 32.3 feet	Vertical Change	.3	6 ft	5	REF		
TOTAL COST FOR: NE side of 7TH ST Starting at: SIDEWALK BEGINS							\$21,648.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261234	7TH ST	SIDEWALK BEGINS	VENTURA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37962	0.0 to 5.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,432
41098	0.0 to 1.0 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
51433	3.6 to 4.6 feet	Vertical Change	-.3	6 ft	5	REF		
37964	8.4 to 20.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	68	SF	\$120	\$8,184
51434	18.8 to 19.8 feet	Vertical Change	-.3	6 ft	6	REF		
37969	23.8 to 27.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,508
55842	28.8 to 29.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
37970	31.6 to 40.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,072
55843	48.9 to 49.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
51435	58.8 to 59.8 feet	Vertical Change	-.3	6 ft	6	REF		
37973	59.6 to 60.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
55844	85.4 to 86.4 feet	Vertical Change	.3	6 ft	6	REF		
37974	85.8 to 88.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782
55845	88.9 to 89.9 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
41099	121.9 to 123.4 feet	Running Slope	5.0-6.0%	6 ft	8	SF	\$120	\$990
TOTAL COST FOR: NE side of 7TH ST Starting at: SIDEWALK BEGINS								\$24,931.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261236	7TH ST	SIDEWALK BEGINS	SONOMA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41100	0.1 to 1.5 feet	Running Slope	5.0-6.0%	6 ft	8	SF	\$120	\$924
37975	2.3 to 21.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	106	SF	\$120	\$12,738
37983	31.7 to 37.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,026
37987	40.8 to 63.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	127	SF	\$120	\$15,246
37991	73.2 to 74.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
37992	102.1 to 118.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	90	SF	\$120	\$10,758
45441	121.1 to 122.1 feet	Vertical Change	-.5	6 ft	6	REF		
37994	121.3 to 123.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	14	SF	\$120	\$1,716
37995	124.6 to 130.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,092
TOTAL COST FOR: SW side of 7TH ST Starting at: SIDEWALK BEGINS							\$50,160.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261239	7TH ST	SONOMA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
37996	3.9 to 18.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	80	SF	\$120	\$9,636
38001	26.3 to 30.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
47838	35.7 to 36.7 feet	Vertical Change	-4	6 ft	6	LF	\$75	\$413
38002	49.3 to 59.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,402
60261	54.8 to 67.3 feet	Driveway				REF		
51436	60.8 to 61.8 feet	Vertical Change	-3	6 ft	6	REF		
38005	71.5 to 87.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	88	SF	\$120	\$10,560
38010	96.8 to 106.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,072
38013	110.1 to 120.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	59	SF	\$120	\$7,062
43544	114.3 to 115.3 feet	Vertical Change	-6	6 ft	6	REF		
38018	122.9 to 132.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	54	SF	\$120	\$6,534
51437	128.2 to 129.2 feet	Vertical Change	-3	6 ft	6	REF		
TOTAL COST FOR: SW side of 7TH ST Starting at: SONOMA AVE							\$49,450.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261241	7TH ST	SIDEWALK BEGINS	RIVERSIDE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38021	0.8 to 7.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	35	SF	\$120	\$4,224
60262	2.5 to 16.7 feet	Driveway				REF		
55846	6.0 to 7.0 feet	Vertical Change	.3	6 ft	6	REF		
38025	9.8 to 13.7 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	21	SF	\$40	\$858
57111	14.1 to 15.1 feet	Vertical Change	.6	6 ft	6	REF		
55847	15.8 to 16.8 feet	Vertical Change	.3	6 ft	6	REF		
55848	50.4 to 51.4 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
38027	56.3 to 59.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914
55849	58.7 to 61.6 feet	Vertical Change	.3	6 ft	16	REF		
199	65.2 to 66.2 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
55850	72.6 to 73.6 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
38028	78.1 to 82.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,102
56573	89.3 to 90.3 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
38030	97.0 to 98.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
55851	100.3 to 101.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
38031	102.0 to 103.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
38032	106.4 to 107.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
57112	109.7 to 116.2 feet	Vertical Change	.6	6 ft	36	SF	\$75	\$2,681
38033	114.3 to 118.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904
57488	116.9 to 117.9 feet	Vertical Change	1.6	6 ft	6	REF		
57113	119.0 to 120.0 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413
TOTAL COST FOR: SW side of 7TH ST Starting at: SIDEWALK BEGINS							\$20,748.75	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261243	7TH ST	RIVERSIDE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38035	0.0 to 1.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
38036	27.1 to 29.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716
38037	70.3 to 73.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848
38038	85.7 to 98.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	69	SF	\$120	\$8,316
38039	101.4 to 112.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	60	SF	\$120	\$7,194
38041	114.6 to 137.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	128	SF	\$120	\$15,312
60263	122.8 to 134.9 feet	Driveway				REF		
TOTAL COST FOR: SW side of 7TH ST Starting at: RIVERSIDE AVE							\$35,244.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	51909261244	7TH ST	SIDEWALK BEGINS	KINGS AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
57114	9.3 to 10.3 feet	Vertical Change	.6	6 ft	5	SF	\$75	\$413	
38048	17.1 to 28.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	63	SF	\$120	\$7,590	
200	22.0 to 23.0 feet	Continuous Width		6 ft	6	SF	\$120	\$660	
57283	32.7 to 33.7 feet	Vertical Change	.8	6 ft	6	SF	\$75	\$413	
38053	37.2 to 43.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,158	
57394	42.3 to 43.3 feet	Vertical Change	1.1	6 ft	6	REF			
57625	48.9 to 49.9 feet	Vertical Change	3.2	6 ft	6	SF	\$75	\$413	
38055	63.5 to 69.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,828	
38057	90.9 to 92.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726	
38058	92.0 to 96.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838	
38059	98.4 to 100.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518	
38060	109.3 to 120.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	63	SF	\$120	\$7,524	
57685	116.4 to 117.4 feet	Vertical Change	3.6	6 ft	6	REF			
45442	120.1 to 121.1 feet	Vertical Change	-.5	6 ft	6	REF			
38065	125.3 to 131.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224	
TOTAL COST FOR: SW							<i>side of 7TH ST Starting at: SIDEWALK BEGINS</i>	\$34,303.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261322	12TH ST	SIDEWALK BEGINS	ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
201	39.5 to 40.5 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
51438	59.6 to 60.6 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
38066	80.1 to 81.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
38067	85.4 to 93.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,544
38069	112.2 to 125.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	75	SF	\$120	\$8,976
38074	128.3 to 129.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
TOTAL COST FOR: SW side of 12TH ST Starting at: SIDEWALK BEGINS								\$16,417.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909261325	ALAMEDA AVE	12TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38075	6.2 to 10.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
60265	8.4 to 33.8 feet	Driveway				REF		
38077	14.4 to 18.1 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	20	SF	\$40	\$814
38079	20.8 to 25.6 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	26	SF	\$40	\$1,056
38081	25.6 to 27.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	12	SF	\$40	\$484
38082	28.8 to 32.3 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	19	SF	\$40	\$770
TOTAL COST FOR: NW side of ALAMEDA AVE Starting at: 12TH ST								\$5,896.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909261326	ALAMEDA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51439	8.9 to 9.9 feet	Vertical Change	-.3	6 ft	6	REF		
60266	23.0 to 44.3 feet	Driveway				REF		
38084	31.1 to 43.6 feet	Cross Slope (Driveway)	13.014	6 ft	69	SF	\$40	\$2,750
51440	33.7 to 34.7 feet	Vertical Change	-.3	6 ft	6	REF		
TOTAL COST FOR: NW side of ALAMEDA AVE Starting at: SIDEWALK BEGINS								\$2,750.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909261328	ALAMEDA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38089	0.0 to 9.2 feet	Cross Slope (PAR)	>15%	6 ft	51	SF	\$120	\$6,072
38091	9.4 to 18.0 feet	Cross Slope (PAR)	13.014	6 ft	47	SF	\$120	\$5,676
41102	19.5 to 20.9 feet	Running Slope	9.0-10.0%	6 ft	8	SF	\$120	\$924
55852	22.4 to 23.4 feet	Vertical Change	.3	6 ft	6	REF		
38094	23.1 to 24.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	9	SF	\$40	\$352
38095	38.7 to 43.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	27	SF	\$40	\$1,078
TOTAL COST FOR: NW side of ALAMEDA AVE Starting at: SIDEWALK BEGINS							\$14,102.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909261329	ALAMEDA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60267	0.5 to 11.3 feet	Driveway				REF		
38097	0.6 to 2.2 feet	Cross Slope (Driveway)	13.014	6 ft	9	SF	\$40	\$352
38098	2.8 to 5.8 feet	Cross Slope (Driveway)	>15%	6 ft	17	SF	\$40	\$660
38100	5.8 to 7.9 feet	Cross Slope (Driveway)	13.014	6 ft	12	SF	\$40	\$462
38101	13.4 to 35.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	124	SF	\$120	\$14,850
38106	36.7 to 50.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	74	SF	\$120	\$8,910
60268	50.7 to 63.2 feet	Driveway				REF		
57601	53.5 to 54.5 feet	Vertical Change	2.9	6 ft	6	REF		
38108	55.3 to 61.7 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	35	SF	\$40	\$1,408
TOTAL COST FOR: NW side of ALAMEDA AVE Starting at: SIDEWALK BEGINS							\$26,642.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
NW	51909261330	ALAMEDA AVE	14TH ST	SIDEWALK ENDS	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
38111	0.8 to 8.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	41	SF	\$120	\$4,884			
38114	9.3 to 29.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	113	SF	\$120	\$13,530			
60269	25.8 to 41.8 feet	Driveway				REF					
55853	28.3 to 29.3 feet	Vertical Change	.3	6 ft	6	REF					
38122	33.5 to 40.3 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	37	SF	\$40	\$1,496			
41103	40.9 to 42.3 feet	Running Slope	5.0-6.0%	6 ft	8	REF					
38123	43.7 to 46.6 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	16	SF	\$120	\$1,914			
60270	44.5 to 55.8 feet	Driveway				REF					
38125	49.9 to 57.7 feet	Cross Slope (Driveway)	>15%	6 ft	43	SF	\$40	\$1,716			
TOTAL COST FOR: NW							<i>side of</i>	ALAMEDA AVE	<i>Starting at:</i>	14TH ST	\$23,540.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909261332	ALAMEDA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38128	18.2 to 21.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376
41574	22.6 to 23.6 feet	Vertical Change	-1	6 ft	6	SF	\$75	\$413
60272	22.6 to 44.1 feet	Driveway				REF		
55854	22.7 to 23.7 feet	Vertical Change	.3	6 ft	6	REF		
38129	27.3 to 42.4 feet	Cross Slope (Driveway)	>15%	6 ft	83	SF	\$40	\$3,322
TOTAL COST FOR: NW side of ALAMEDA AVE Starting at: SIDEWALK BEGINS								\$6,110.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
SE	51909261334	ALAMEDA AVE	15TH ST	SIDEWALK ENDS	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
38131	14.7 to 19.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838			
60273	17.6 to 33.8 feet	Driveway				REF					
38133	23.3 to 24.5 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	7	SF	\$40	\$264			
38134	26.9 to 28.2 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	7	SF	\$40	\$286			
38135	40.3 to 55.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	84	SF	\$120	\$10,032			
38140	58.4 to 68.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	56	SF	\$120	\$6,732			
60274	68.2 to 83.0 feet	Driveway				REF					
41104	70.8 to 72.0 feet	Running Slope	5.0-6.0%	6 ft	7	REF					
57115	74.8 to 75.8 feet	Vertical Change	.6	6 ft	6	REF					
38142	74.9 to 81.4 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	36	SF	\$40	\$1,430			
57636	77.4 to 78.4 feet	Vertical Change	3.3	6 ft	6	REF					
56577	79.8 to 80.8 feet	Vertical Change	.4	6 ft	6	REF					
TOTAL COST FOR: SE							<i>side of</i>	ALAMEDA AVE	<i>Starting at:</i>	15TH ST	\$21,582.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority						
SE	51909261335	ALAMEDA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD						
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total			
38144	9.8 to 15.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894			
43545	18.3 to 19.3 feet	Vertical Change	-.6	6 ft	6	SF	\$75	\$413			
38145	21.8 to 26.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,300			
57460	27.4 to 28.4 feet	Vertical Change	1.4	6 ft	6	SF	\$75	\$413			
60275	27.4 to 45.8 feet	Driveway				REF					
38146	33.1 to 35.4 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	13	SF	\$40	\$506			
38148	35.6 to 40.2 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	25	SF	\$40	\$1,012			
38150	44.2 to 46.8 feet	Cross Slope (Driveway)	>15%	6 ft	14	SF	\$40	\$572			
TOTAL COST FOR: SE							<i>side of</i>	ALAMEDA AVE	<i>Starting at:</i>	SIDEWALK BEGINS	\$10,109.00

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909261338	ALAMEDA AVE	14TH ST	13TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
51441	1.3 to 2.3 feet	Vertical Change	-.3	6 ft	5	REF		
38151	1.8 to 4.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	14	SF	\$120	\$1,650
38152	4.8 to 7.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518
38153	29.0 to 30.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
202	30.3 to 31.3 feet	Continuous Width		6 ft	6	SF	\$120	\$660
60276	31.5 to 44.8 feet	Driveway				REF		
41105	32.6 to 35.0 feet	Running Slope	5.0-6.0%	6 ft	13	REF		
55855	33.8 to 34.8 feet	Vertical Change	.3	6 ft	6	REF		
38154	37.5 to 41.4 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	21	SF	\$40	\$858
51442	43.5 to 44.5 feet	Vertical Change	-.3	6 ft	6	REF		
41107	43.6 to 44.9 feet	Running Slope	8.0-9.0%	6 ft	7	REF		
60277	45.4 to 62.7 feet	Driveway				REF		
57370	46.3 to 47.3 feet	Vertical Change	1	6 ft	6	REF		
38156	50.8 to 62.4 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	64	SF	\$40	\$2,552
57395	61.6 to 62.6 feet	Vertical Change	1.1	6 ft	6	REF		
41108	61.8 to 62.8 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
41109	63.3 to 64.5 feet	Running Slope	6.0-7.0%	6 ft	7	REF		
38161	66.6 to 70.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
56578	69.0 to 70.0 feet	Vertical Change	.4	6 ft	6	REF		
38163	75.1 to 76.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726
38164	76.6 to 80.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244
38166	82.3 to 83.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$792
38167	86.2 to 95.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	52	SF	\$120	\$6,204
47840	93.8 to 94.8 feet	Vertical Change	-.4	6 ft	6	REF		
60278	98.4 to 121.1 feet	Driveway				REF		
38170	113.0 to 120.1 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	39	SF	\$40	\$1,562
41110	120.8 to 122.8 feet	Running Slope	5.0-6.0%	6 ft	11	REF		
38172	124.5 to 136.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	65	SF	\$120	\$7,788

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909261338	ALAMEDA AVE	14TH ST	13TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38175	138.6 to 140.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	11	SF	\$120	\$1,320
38176	141.0 to 165.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	135	SF	\$120	\$16,170
60279	163.8 to 185.8 feet	Driveway				REF		
38182	170.1 to 186.5 feet	Cross Slope (Driveway)	13.014	6 ft	90	SF	\$40	\$3,608
38186	191.6 to 197.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,894
60280	196.8 to 211.9 feet	Driveway				REF		
38188	202.1 to 208.4 feet	Cross Slope (Driveway)	13.014	6 ft	35	SF	\$40	\$1,386
57421	203.0 to 204.0 feet	Vertical Change	1.2	6 ft	6	REF		
38191	216.3 to 218.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
38192	225.1 to 227.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	12	SF	\$120	\$1,386
38193	229.2 to 243.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	78	SF	\$120	\$9,306
38194	246.8 to 251.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,970
38196	272.0 to 275.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046
38197	278.8 to 284.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,026
TOTAL COST FOR: SE side of ALAMEDA AVE Starting at: 14TH ST							\$77,220.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	51909261340	ALAMEDA AVE	13TH ST	12TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
56579	36.0 to 37.0 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
56580	40.6 to 41.6 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
38198	44.3 to 45.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
41111	48.3 to 49.8 feet	Running Slope	6.0-7.0%	6 ft	8	REF			
38199	49.8 to 52.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518	
57556	53.3 to 54.3 feet	Vertical Change	2.3	6 ft	6	SF	\$75	\$413	
51443	55.2 to 56.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
57530	60.0 to 61.0 feet	Vertical Change	2	6 ft	6	SF	\$75	\$413	
38201	62.3 to 71.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	48	SF	\$120	\$5,742	
38206	73.3 to 76.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	19	SF	\$120	\$2,310	
60281	77.8 to 94.3 feet	Driveway				REF			
57328	80.6 to 81.6 feet	Vertical Change	.9	6 ft	6	REF			
38208	83.9 to 90.0 feet	Cross Slope (Driveway)	13.014	6 ft	34	SF	\$40	\$1,342	
47841	92.7 to 93.7 feet	Vertical Change	-.4	6 ft	6	REF			
60282	97.9 to 124.3 feet	Driveway				REF			
38211	103.3 to 121.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	102	SF	\$40	\$4,070	
41112	122.3 to 124.0 feet	Running Slope	5.0-6.0%	6 ft	9	REF			
38217	125.9 to 132.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	35	SF	\$120	\$4,158	
38218	135.3 to 149.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	78	SF	\$120	\$9,306	
38221	152.4 to 154.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650	
38222	160.8 to 163.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716	
38223	166.7 to 174.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	44	SF	\$120	\$5,280	
203	198.6 to 199.6 feet	Continuous Width		6 ft	6	SF	\$120	\$660	
38224	201.0 to 202.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
41113	201.7 to 202.9 feet	Running Slope	5.0-6.0%	6 ft	7	REF			
57602	205.0 to 206.0 feet	Vertical Change	2.9	6 ft	6	SF	\$75	\$413	
38225	207.8 to 211.3 feet	Cross Slope (PAR)	14.0-15.0%	6 ft	19	SF	\$120	\$2,310	
38227	212.3 to 215.6 feet	Cross Slope (PAR)	11.0-12.0%	6 ft	18	SF	\$120	\$2,178	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909261340	ALAMEDA AVE	13TH ST	12TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41114	217.0 to 218.0 feet	Running Slope	6.0-7.0%	6 ft	6	SF	\$120	\$660
38228	224.8 to 228.5 feet	Cross Slope (PAR)	12.0-13.0%	6 ft	20	SF	\$120	\$2,442
56890	226.5 to 227.5 feet	Vertical Change	.5	6 ft	6	REF		
38230	230.9 to 236.3 feet	Cross Slope (PAR)	13.014	6 ft	30	SF	\$120	\$3,564
38232	236.3 to 238.6 feet	Cross Slope (PAR)	>15%	6 ft	13	SF	\$120	\$1,518
TOTAL COST FOR: SE side of ALAMEDA AVE Starting at: 13TH ST							\$54,285.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	51909261344	COLUSA AVE	SIDEWALK BEGINS	13TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
38233	0.0 to 9.9 feet	Cross Slope (PAR)	>15%	6 ft	54	SF	\$120	\$6,534	
60283	1.7 to 14.8 feet	Driveway				REF			
38236	9.9 to 11.1 feet	Cross Slope (Driveway)	13.014	6 ft	7	SF	\$40	\$264	
51444	13.3 to 14.3 feet	Vertical Change	-.3	6 ft	6	REF			
38237	36.3 to 40.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640	
60284	38.8 to 53.8 feet	Driveway				REF			
38239	46.3 to 49.4 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	17	SF	\$40	\$682	
38241	49.4 to 50.4 feet	Cross Slope (Driveway)	13.014	6 ft	6	SF	\$40	\$220	
38242	51.6 to 52.6 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	6	SF	\$40	\$220	
38243	57.7 to 64.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	35	SF	\$120	\$4,224	
60285	64.3 to 78.1 feet	Driveway				REF			
38246	70.2 to 75.3 feet	Cross Slope (Driveway)	13.014	6 ft	28	SF	\$40	\$1,122	
41115	77.3 to 78.3 feet	Running Slope	5.0-6.0%	6 ft	6	REF			
38248	79.1 to 83.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904	
56581	83.7 to 84.7 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
38249	93.3 to 96.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178	
57329	94.4 to 95.4 feet	Vertical Change	.9	6 ft	6	REF			
56582	107.9 to 108.9 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413	
38251	117.0 to 123.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,290	
38252	127.4 to 132.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630	
38253	135.3 to 139.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	24	SF	\$120	\$2,838	
60286	137.9 to 155.7 feet	Driveway				REF			
45443	138.7 to 139.7 feet	Vertical Change	-.5	6 ft	6	REF			
38256	143.3 to 150.4 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	39	SF	\$40	\$1,562	
41116	153.9 to 155.3 feet	Running Slope	5.0-6.0%	6 ft	8	REF			
38260	154.8 to 155.8 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	6	SF	\$40	\$220	
38261	157.8 to 163.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564	
204	159.1 to 160.1 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
51445	159.8 to 160.8 feet	Vertical Change	-.3	6 ft	6	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909261344	COLUSA AVE	SIDEWALK BEGINS	13TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38262	177.0 to 186.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,138
41117	189.0 to 190.3 feet	Running Slope	5.0-6.0%	6 ft	7	SF	\$120	\$858
56891	189.7 to 190.7 feet	Vertical Change	.5	6 ft	6	SF	\$75	\$413
60287	190.3 to 200.7 feet	Driveway				REF		
38263	195.1 to 202.6 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	41	SF	\$40	\$1,650
45444	203.1 to 204.1 feet	Vertical Change	-.5	6 ft	6	SF	\$75	\$413
57396	204.9 to 205.9 feet	Vertical Change	1.1	6 ft	6	REF		
38266	205.3 to 206.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	6	SF	\$120	\$726
60288	207.8 to 220.3 feet	Driveway				REF		
57330	208.9 to 209.9 feet	Vertical Change	.9	6 ft	6	REF		
38267	209.8 to 216.9 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	39	SF	\$40	\$1,562
38271	238.3 to 242.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
38273	244.8 to 257.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	72	SF	\$120	\$8,580
56892	249.0 to 250.0 feet	Vertical Change	.5	6 ft	6	REF		
TOTAL COST FOR: NW side of COLUSA AVE Starting at: SIDEWALK BEGINS							\$61,127.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909261346	COLUSA AVE	13TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38279	10.4 to 14.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
38280	16.8 to 18.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
38281	21.6 to 29.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346
38282	38.0 to 39.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
TOTAL COST FOR: NW side of COLUSA AVE Starting at: 13TH ST								\$9,900.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909261347	COLUSA AVE	13TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60289	0.9 to 23.0 feet	Driveway				REF		
38286	9.5 to 12.0 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	14	SF	\$40	\$550
38287	14.2 to 19.0 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	26	SF	\$40	\$1,056
56893	18.3 to 19.3 feet	Vertical Change	.5	6 ft	6	REF		
41118	22.4 to 23.4 feet	Running Slope	8.0-9.0%	6 ft	6	REF		
38289	23.1 to 24.2 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	6	SF	\$40	\$242
38290	44.5 to 53.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,072
60290	52.4 to 74.0 feet	Driveway				REF		
38292	59.7 to 70.7 feet	Cross Slope (Driveway)	13.014	6 ft	61	SF	\$40	\$2,420
38294	70.7 to 74.3 feet	Cross Slope (Driveway)	>15%	6 ft	20	SF	\$40	\$792
TOTAL COST FOR: NW side of COLUSA AVE Starting at: 13TH ST							\$11,132.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909261348	COLUSA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38303	26.3 to 30.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	23	SF	\$120	\$2,706
38304	30.4 to 48.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	97	SF	\$120	\$11,682
55856	33.8 to 34.8 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: NW side of COLUSA AVE Starting at: SIDEWALK BEGINS							\$14,388.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909261350	COLUSA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60292	1.7 to 28.8 feet	Driveway				REF		
38311	27.4 to 30.3 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	16	SF	\$40	\$638
38312	30.5 to 49.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	104	SF	\$120	\$12,474
55857	49.7 to 50.7 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
57651	59.1 to 60.1 feet	Vertical Change	3.4	6 ft	6	SF	\$75	\$413
38316	63.8 to 70.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,620
55858	69.4 to 70.4 feet	Vertical Change	.3	6 ft	6	REF		
38318	70.8 to 78.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	41	SF	\$120	\$4,950
60293	76.5 to 93.1 feet	Driveway				REF		
38321	81.6 to 89.7 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	45	SF	\$40	\$1,782
38324	97.0 to 153.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	310	SF	\$120	\$37,158
55859	121.2 to 122.2 feet	Vertical Change	.3	6 ft	6	REF		
38337	154.8 to 157.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	17	SF	\$120	\$1,980
55860	162.3 to 163.3 feet	Vertical Change	.3	6 ft	6	REF		
38338	163.2 to 179.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	89	SF	\$120	\$10,626
55861	176.1 to 177.1 feet	Vertical Change	.3	6 ft	6	REF		
38346	179.8 to 181.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	11	SF	\$120	\$1,320
38347	183.8 to 185.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	11	SF	\$120	\$1,320
55862	184.0 to 185.0 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: NW side of COLUSA AVE Starting at: SIDEWALK BEGINS							\$77,693.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	51909261352	COLUSA AVE	SIDEWALK BEGINS	14TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
38348	0.7 to 3.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650	
56584	6.8 to 9.5 feet	Vertical Change	.4	6 ft	15	LF	\$75	\$1,114	
60294	13.8 to 45.3 feet	Driveway				REF			
38349	14.0 to 15.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$220	
38350	18.4 to 26.6 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	45	SF	\$40	\$1,804	
38353	28.0 to 42.8 feet	Cross Slope (Driveway)	13.014	6 ft	81	SF	\$40	\$3,256	
41119	45.0 to 46.8 feet	Running Slope	5.0-6.0%	6 ft	10	REF			
38357	49.3 to 52.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310	
60295	52.8 to 69.8 feet	Driveway				REF			
56894	54.3 to 55.3 feet	Vertical Change	.5	6 ft	6	REF			
38358	58.2 to 59.8 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	9	SF	\$40	\$352	
38359	61.9 to 68.2 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	35	SF	\$40	\$1,386	
38361	71.3 to 72.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
38362	82.8 to 91.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,610	
38364	96.7 to 102.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,828	
38366	102.5 to 113.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	60	SF	\$120	\$7,194	
38370	113.4 to 126.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	69	SF	\$120	\$8,316	
60296	124.9 to 139.0 feet	Driveway				REF			
38371	129.4 to 130.7 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	7	SF	\$40	\$286	
38372	133.9 to 138.8 feet	Cross Slope (Driveway)	13.014	6 ft	27	SF	\$40	\$1,078	
38374	142.7 to 144.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,122	
38375	144.9 to 146.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924	
38376	156.5 to 192.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	196	SF	\$120	\$23,562	
TOTAL COST FOR: SE							<i>side of COLUSA AVE Starting at: SIDEWALK BEGINS</i>	\$64,671.75	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909261356	COLUSA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41120	13.2 to 14.8 feet	Running Slope	7.0-8.0%	6 ft	9	SF	\$120	\$1,056
41186	17.1 to 18.1 feet	Vertical Change	-2.8	6 ft	6	SF	\$75	\$413
51447	24.4 to 25.4 feet	Vertical Change	-.3	6 ft	6	REF		
38386	25.1 to 31.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,092
56585	39.5 to 42.8 feet	Vertical Change	.4	6 ft	18	LF	\$75	\$1,361
38389	41.3 to 43.3 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	11	SF	\$120	\$1,320
TOTAL COST FOR: SE side of COLUSA AVE Starting at: SIDEWALK BEGINS								\$8,241.75

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	51909261403	COLUSA AVE	13TH ST	12TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
38390	0.0 to 41.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	228	SF	\$120	\$27,390	
41121	0.0 to 1.3 feet	Running Slope	5.0-6.0%	6 ft	7	REF			
56895	9.4 to 10.4 feet	Vertical Change	.5	6 ft	6	REF			
38400	45.9 to 49.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	17	SF	\$120	\$2,046	
60298	48.8 to 62.9 feet	Driveway				REF			
38401	53.6 to 60.8 feet	Cross Slope (Driveway)	>15%	6 ft	40	SF	\$40	\$1,584	
41122	59.9 to 61.9 feet	Running Slope	5.0-6.0%	6 ft	11	REF			
38402	64.5 to 82.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	97	SF	\$120	\$11,616	
60299	80.5 to 95.5 feet	Driveway				REF			
38409	85.9 to 90.8 feet	Cross Slope (Driveway)	13.014	6 ft	27	SF	\$40	\$1,078	
38411	91.1 to 92.8 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	9	SF	\$40	\$374	
56587	92.8 to 93.8 feet	Vertical Change	.4	6 ft	6	REF			
47842	96.5 to 97.5 feet	Vertical Change	-.4	6 ft	6	REF			
55864	96.8 to 97.8 feet	Vertical Change	.3	6 ft	6	REF			
38412	97.0 to 101.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	27	SF	\$120	\$3,234	
41884	99.7 to 100.7 feet	Vertical Change	-.8	6 ft	6	REF			
47843	101.4 to 104.2 feet	Vertical Change	-.4	6 ft	15	REF			
38414	101.9 to 110.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	49	SF	\$120	\$5,874	
55865	105.6 to 106.6 feet	Vertical Change	.3	6 ft	6	REF			
51449	108.2 to 109.2 feet	Vertical Change	-.3	6 ft	6	REF			
43546	110.7 to 111.7 feet	Vertical Change	-.6	6 ft	6	REF			
38418	111.1 to 117.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,026	
55866	114.1 to 115.1 feet	Vertical Change	.3	6 ft	6	REF			
38420	119.3 to 120.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858	
56588	119.9 to 120.9 feet	Vertical Change	.4	6 ft	6	REF			
38421	121.8 to 129.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,214	
51450	122.4 to 123.4 feet	Vertical Change	-.3	6 ft	6	REF			
51451	127.2 to 128.2 feet	Vertical Change	-.3	6 ft	5	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909261403	COLUSA AVE	13TH ST	12TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60300	129.5 to 143.8 feet	Driveway				REF		
57116	131.8 to 132.8 feet	Vertical Change	.6	6 ft	6	REF		
38422	133.4 to 141.5 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	45	SF	\$40	\$1,782
51452	140.4 to 141.4 feet	Vertical Change	-.3	6 ft	6	REF		
38425	147.3 to 154.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	39	SF	\$120	\$4,686
60301	153.8 to 172.8 feet	Driveway				REF		
38428	160.3 to 164.0 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	20	SF	\$40	\$814
38429	164.8 to 173.7 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	49	SF	\$40	\$1,958
41123	173.3 to 174.9 feet	Running Slope	5.0-6.0%	6 ft	9	REF		
38434	180.6 to 183.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716
56589	185.8 to 186.8 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
55867	190.1 to 191.1 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
38435	191.2 to 194.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,376
56590	193.5 to 197.3 feet	Vertical Change	.4	6 ft	21	REF		
51453	213.3 to 214.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
60302	214.3 to 233.8 feet	Driveway				REF		
38437	220.8 to 230.4 feet	Cross Slope (Driveway)	>15%	6 ft	53	SF	\$40	\$2,112
55868	231.3 to 232.3 feet	Vertical Change	.3	6 ft	6	REF		
41124	232.7 to 233.7 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
38439	234.7 to 239.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	25	SF	\$120	\$3,036
38441	239.3 to 254.5 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	84	SF	\$120	\$10,032
38446	256.9 to 281.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	133	SF	\$120	\$15,972
55869	257.5 to 258.5 feet	Vertical Change	.3	6 ft	6	REF		
60303	279.1 to 295.3 feet	Driveway				REF		
38452	285.3 to 290.6 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	29	SF	\$40	\$1,166
56591	288.8 to 289.8 feet	Vertical Change	.4	6 ft	6	REF		
38454	291.3 to 292.7 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	8	SF	\$40	\$308

TOTAL COST FOR: SE side of COLUSA AVE Starting at: 13TH ST \$110,489.50

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261406	12TH ST	COLUSA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60304	15.1 to 33.1 feet	Driveway				REF		
38456	21.1 to 30.1 feet	Cross Slope (Driveway)	13.014	6 ft	50	SF	\$40	\$1,980
41125	30.7 to 32.4 feet	Running Slope	6.0-7.0%	6 ft	9	REF		
55870	31.3 to 32.3 feet	Vertical Change	.3	6 ft	5	REF		
38459	34.6 to 38.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,442
38460	51.0 to 56.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,498
57284	51.3 to 52.3 feet	Vertical Change	.8	6 ft	6	REF		
205	59.8 to 60.8 feet	Continuous Width		6 ft	6	SF	\$120	\$660
38462	63.1 to 65.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
56592	63.3 to 64.3 feet	Vertical Change	.4	6 ft	6	REF		
41292	65.0 to 66.3 feet	Vertical Change	-1.6	6 ft	7	REF		
41575	65.4 to 66.4 feet	Vertical Change	-1	6 ft	6	SF	\$75	\$413
55871	67.1 to 69.8 feet	Vertical Change	.3	6 ft	15	LF	\$75	\$1,114
38463	68.8 to 69.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
57285	70.5 to 71.5 feet	Vertical Change	.8	6 ft	6	SF	\$75	\$413
41255	72.2 to 73.2 feet	Vertical Change	-1.8	6 ft	6	SF	\$75	\$413
38464	77.0 to 81.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838
60305	78.1 to 113.3 feet	Driveway				REF		
38466	85.3 to 86.4 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	6	SF	\$40	\$242
38467	87.2 to 96.5 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	51	SF	\$40	\$2,046
38471	96.5 to 107.7 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	62	SF	\$40	\$2,464
38475	108.8 to 110.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	11	SF	\$40	\$440
41126	112.7 to 114.2 feet	Running Slope	6.0-7.0%	6 ft	8	REF		
TOTAL COST FOR: SW side of 12TH ST Starting at: COLUSA AVE							\$21,007.25	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261417	12TH ST	HUMBOLDT AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38477	16.3 to 41.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	138	SF	\$120	\$16,566
38481	45.8 to 57.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	67	SF	\$120	\$7,986
60306	56.1 to 80.3 feet	Driveway				REF		
38483	62.7 to 78.4 feet	Cross Slope (Driveway)	13.014	6 ft	86	SF	\$40	\$3,454
51454	74.3 to 75.3 feet	Vertical Change	-.3	6 ft	6	REF		
41127	79.8 to 80.8 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
38487	89.3 to 113.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	132	SF	\$120	\$15,840
55872	100.1 to 101.1 feet	Vertical Change	.3	6 ft	6	REF		
38493	115.9 to 129.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	75	SF	\$120	\$8,976
TOTAL COST FOR: NE side of 12TH ST Starting at: HUMBOLDT AVE							\$52,822.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NE	51909261425	13TH ST	ORANGE AVE	ROBERTSON BLVD	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
38496	0.8 to 3.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518	
38498	3.3 to 45.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	233	SF	\$120	\$27,918	
38509	45.8 to 55.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,138	
38511	55.6 to 61.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	34	SF	\$120	\$4,092	
38513	64.8 to 67.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	15	SF	\$120	\$1,848	
38515	68.1 to 105.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	207	SF	\$120	\$24,816	
38523	105.7 to 115.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	53	SF	\$120	\$6,336	
55873	117.1 to 118.1 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
38526	119.3 to 152.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	184	SF	\$120	\$22,044	
38538	153.2 to 161.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,676	
38542	162.8 to 173.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	59	SF	\$120	\$7,062	
38545	173.5 to 185.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	67	SF	\$120	\$7,986	
38549	188.3 to 189.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858	
38550	190.2 to 211.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	116	SF	\$120	\$13,860	
38555	211.2 to 213.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	12	SF	\$120	\$1,452	
38556	216.5 to 236.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	107	SF	\$120	\$12,870	
38562	240.6 to 249.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	51	SF	\$120	\$6,072	
38565	251.8 to 289.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	205	SF	\$120	\$24,618	
206	284.8 to 285.8 feet	Continuous Width		6 ft	6	SF	\$120	\$660	
41128	289.6 to 290.7 feet	Running Slope	8.0-9.0%	6 ft	6	REF			
41129	306.2 to 309.6 feet	Running Slope	5.0-6.0%	6 ft	19	REF			
38577	307.1 to 308.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
51455	327.3 to 328.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
38579	388.6 to 393.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,366	
60309	391.1 to 418.3 feet	Driveway				REF			
38580	397.9 to 413.1 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	84	SF	\$40	\$3,344	
38584	419.0 to 424.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,432	
38585	426.8 to 437.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	57	SF	\$120	\$6,864	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261425	13TH ST	ORANGE AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38587	440.2 to 495.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	302	SF	\$120	\$36,234
38597	497.8 to 512.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	80	SF	\$120	\$9,636
51456	504.7 to 505.7 feet	Vertical Change	-.3	6 ft	6	REF		
38600	513.6 to 527.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	78	SF	\$120	\$9,306
45445	524.3 to 525.3 feet	Vertical Change	-.5	6 ft	6	REF		
38604	528.8 to 562.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	185	SF	\$120	\$22,242
38611	563.3 to 567.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
38612	571.7 to 578.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	36	SF	\$120	\$4,356
38615	580.9 to 586.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	32	SF	\$120	\$3,894
38617	590.8 to 597.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	38	SF	\$120	\$4,554
56593	596.1 to 597.1 feet	Vertical Change	.4	6 ft	6	REF		
38619	597.9 to 621.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	130	SF	\$120	\$15,576
38623	625.3 to 650.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	138	SF	\$120	\$16,566
38627	655.2 to 660.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,498
55874	658.9 to 659.9 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: NE side of 13TH ST Starting at: ORANGE AVE							\$323,345.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261427	13TH ST	ROBERTSON BLVD	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38628	0.0 to 3.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178
38629	8.7 to 10.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
38630	12.8 to 24.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	66	SF	\$120	\$7,920
38633	28.4 to 43.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	84	SF	\$120	\$10,032
38639	46.8 to 54.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,818
38640	57.3 to 93.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	197	SF	\$120	\$23,628
38648	96.4 to 131.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	195	SF	\$120	\$23,430
60310	131.8 to 154.3 feet	Driveway				REF		
38654	133.4 to 135.7 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	13	SF	\$40	\$506
38656	141.8 to 145.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	22	SF	\$40	\$880
51457	150.3 to 151.3 feet	Vertical Change	-.3	6 ft	6	REF		
38658	154.4 to 155.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$242
38659	156.3 to 192.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	199	SF	\$120	\$23,826
38668	193.6 to 204.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	58	SF	\$120	\$6,996
51458	201.0 to 202.0 feet	Vertical Change	-.3	6 ft	6	REF		
38673	208.8 to 217.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,544
38675	220.6 to 238.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	100	SF	\$120	\$12,012
38678	238.8 to 240.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
38679	248.8 to 250.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$990
38680	252.3 to 265.5 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	73	SF	\$120	\$8,712
38684	265.5 to 271.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	31	SF	\$120	\$3,696
38685	272.6 to 280.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,082
56897	278.8 to 279.8 feet	Vertical Change	.5	6 ft	6	REF		
38688	282.6 to 286.6 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	22	SF	\$120	\$2,640
TOTAL COST FOR: SW side of 13TH ST Starting at: ROBERTSON BLVD							\$145,178.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909261429	TRINITY AVE	13TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38690	8.3 to 15.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,620
38691	21.5 to 24.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848
38693	29.8 to 44.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	80	SF	\$120	\$9,570
38697	46.0 to 47.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	7	SF	\$120	\$858
38698	50.6 to 52.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
38699	58.5 to 63.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
60311	60.8 to 80.9 feet	Driveway				REF		
38700	70.0 to 78.4 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	46	SF	\$40	\$1,848
38703	81.6 to 82.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	6	SF	\$120	\$660
TOTAL COST FOR: NW side of TRINITY AVE Starting at: 13TH ST							\$23,496.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	51909261430	TRINITY AVE	SIDEWALK BEGINS	SIDEWALK ENDS					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
38704	0.8 to 6.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,026	
38706	9.3 to 14.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	27	SF	\$120	\$3,300	
38708	17.5 to 30.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	71	SF	\$120	\$8,514	
60312	28.3 to 44.5 feet	Driveway				REF			
38712	34.2 to 35.2 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	6	SF	\$40	\$220	
38713	37.5 to 41.8 feet	Cross Slope (Driveway)	>15%	6 ft	24	SF	\$40	\$946	
TOTAL COST FOR: NW side of TRINITY AVE Starting at: SIDEWALK BEGINS								\$17,006.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909261431	TRINITY AVE	14TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38714	0.8 to 9.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	50	SF	\$120	\$5,940
38716	12.8 to 35.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	123	SF	\$120	\$14,784
TOTAL COST FOR: NW side of TRINITY AVE Starting at: 14TH ST							\$20,724.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909261433	TRINITY AVE	SIDEWALK BEGINS	15TH ST	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38720	0.4 to 2.6 feet	Cross Slope (PAR)	13.014	6 ft	12	SF	\$120	\$1,452
60313	1.7 to 11.8 feet	Driveway				REF		
38721	5.7 to 9.1 feet	Cross Slope (Driveway)	13.014	6 ft	19	SF	\$40	\$748
47844	14.4 to 15.4 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
38723	16.9 to 19.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518
55875	36.4 to 37.4 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
38724	41.8 to 42.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
55876	46.8 to 47.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
55877	56.2 to 57.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
57219	72.4 to 73.4 feet	Vertical Change	.7	6 ft	6	SF	\$75	\$413
60314	84.8 to 95.8 feet	Driveway				REF		
38725	88.4 to 91.3 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	16	SF	\$40	\$638
38727	91.3 to 92.8 feet	Cross Slope (Driveway)	13.014	6 ft	8	SF	\$40	\$330
38728	98.5 to 99.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
60315	99.3 to 117.4 feet	Driveway				REF		
38729	104.1 to 113.7 feet	Cross Slope (Driveway)	>15%	6 ft	53	SF	\$40	\$2,112
47845	115.9 to 116.9 feet	Vertical Change	-.4	6 ft	6	REF		
38730	118.0 to 123.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	28	SF	\$120	\$3,366
38732	123.3 to 124.6 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	7	SF	\$120	\$858
38733	126.9 to 149.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	125	SF	\$120	\$14,982
47846	142.0 to 143.0 feet	Vertical Change	-.4	6 ft	6	REF		
51459	147.0 to 148.0 feet	Vertical Change	-.3	6 ft	6	REF		
55878	152.0 to 153.0 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
38739	153.3 to 167.0 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	75	SF	\$120	\$9,042
55879	167.3 to 168.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
38744	169.7 to 177.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	45	SF	\$120	\$5,346
51460	181.9 to 182.9 feet	Vertical Change	-.3	6 ft	6	REF		
38746	182.4 to 185.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914

TOTAL COST FOR: NW side of TRINITY AVE Starting at: SIDEWALK BEGINS \$46,645.50

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SE	51909261435	TRINITY AVE	15TH ST	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38747	0.6 to 3.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178
55880	1.4 to 2.4 feet	Vertical Change	.3	6 ft	6	REF		
38748	12.6 to 26.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	76	SF	\$120	\$9,174
38754	38.8 to 53.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	81	SF	\$120	\$9,768
38757	60.1 to 62.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386
38758	64.3 to 77.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	70	SF	\$120	\$8,382
38760	79.4 to 81.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	11	SF	\$120	\$1,320
38761	82.2 to 87.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,300
51461	91.0 to 92.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
38763	104.3 to 116.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	64	SF	\$120	\$7,722
60316	113.8 to 130.3 feet	Driveway				REF		
38766	120.7 to 126.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	34	SF	\$40	\$1,342
55881	129.3 to 130.3 feet	Vertical Change	.3	6 ft	6	REF		
38767	178.0 to 179.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792
57118	178.3 to 179.3 feet	Vertical Change	.6	6 ft	6	REF		
60317	179.1 to 190.2 feet	Driveway				REF		
38768	183.0 to 190.3 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	40	SF	\$40	\$1,606
TOTAL COST FOR: SE side of TRINITY AVE Starting at: 15TH ST							\$47,382.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
SE	51909261437	TRINITY AVE	14TH ST	13TH ST	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
38770	0.0 to 22.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	123	SF	\$120	\$14,784	
207	3.1 to 4.1 feet	Protruding Object		6 ft	5	JOB	\$99	\$99	
38778	25.1 to 36.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	60	SF	\$120	\$7,194	
38782	36.8 to 40.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	21	SF	\$120	\$2,574	
38784	40.7 to 47.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,554	
55882	66.3 to 67.3 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
57422	68.2 to 69.2 feet	Vertical Change	1.2	6 ft	6	REF			
38785	69.1 to 71.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,254	
60318	69.5 to 83.7 feet	Driveway				REF			
38786	74.5 to 80.6 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	34	SF	\$40	\$1,342	
38790	80.6 to 84.3 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	20	SF	\$40	\$814	
51462	89.3 to 90.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
55883	89.8 to 90.8 feet	Vertical Change	.3	6 ft	6	REF			
38792	90.5 to 92.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,188	
38793	94.6 to 121.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	150	SF	\$120	\$17,952	
56898	117.9 to 118.9 feet	Vertical Change	.5	6 ft	6	REF			
60319	121.1 to 136.8 feet	Driveway				REF			
38799	124.8 to 135.3 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	58	SF	\$40	\$2,310	
38803	139.8 to 143.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244	
55884	140.0 to 141.0 feet	Vertical Change	.3	6 ft	6	REF			
38804	147.2 to 154.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,752	
38807	158.8 to 162.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,706	
38808	170.8 to 176.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,696	
51463	179.7 to 180.7 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
60320	182.8 to 198.8 feet	Driveway				REF			
38810	189.1 to 193.7 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	25	SF	\$40	\$1,012	
38813	211.3 to 216.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	27	SF	\$120	\$3,234	
38815	239.3 to 279.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	221	SF	\$120	\$26,532	

TOTAL COST FOR: SE side of TRINITY AVE Starting at: 14TH ST \$99,478.50

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261441	13TH ST	TRINITY AVE	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38823	0.1 to 4.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
208	2.7 to 3.7 feet	Continuous Width		6 ft	6	SF	\$120	\$660
57669	8.3 to 9.3 feet	Vertical Change	3.5	6 ft	6	SF	\$75	\$413
38824	16.1 to 22.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,092
38826	25.8 to 49.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	131	SF	\$120	\$15,708
38833	50.3 to 53.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	17	SF	\$120	\$1,980
209	56.0 to 57.0 feet	Continuous Width		6 ft	6	SF	\$120	\$660
38834	56.8 to 66.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	54	SF	\$120	\$6,534
38837	66.7 to 74.3 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	42	SF	\$120	\$5,016
38839	74.3 to 78.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	25	SF	\$120	\$3,036
38840	78.9 to 83.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
60321	81.8 to 106.5 feet	Driveway				REF		
38841	87.3 to 103.5 feet	Cross Slope (Driveway)	>15%	6 ft	89	SF	\$40	\$3,564
38842	107.8 to 122.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	82	SF	\$120	\$9,834
38844	122.7 to 127.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	24	SF	\$120	\$2,904
60322	126.9 to 148.0 feet	Driveway				REF		
41131	128.5 to 129.5 feet	Running Slope	5.0-6.0%	6 ft	6	REF		
38847	130.7 to 131.8 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	6	SF	\$40	\$242
38848	136.0 to 137.3 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	7	SF	\$40	\$286
38849	138.4 to 139.6 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	7	SF	\$40	\$264
38850	139.6 to 144.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	25	SF	\$40	\$990
38852	144.1 to 146.6 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	14	SF	\$40	\$550
38854	146.6 to 147.9 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	7	SF	\$40	\$286
38855	160.8 to 169.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,676
55885	163.6 to 164.6 feet	Vertical Change	.3	6 ft	6	REF		
38858	169.9 to 173.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	19	SF	\$120	\$2,244
51464	173.7 to 174.7 feet	Vertical Change	-.3	6 ft	6	REF		
38859	174.1 to 176.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261441	13TH ST	TRINITY AVE	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60323	175.1 to 202.8 feet	Driveway				REF		
51465	189.3 to 190.3 feet	Vertical Change	-3	6 ft	6	REF		
38860	195.9 to 197.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	10	SF	\$40	\$396
38861	203.8 to 205.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
45446	204.4 to 205.4 feet	Vertical Change	-5	6 ft	6	REF		
38862	207.8 to 214.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	36	SF	\$120	\$4,356
38866	215.1 to 224.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,402
51466	217.3 to 218.3 feet	Vertical Change	-3	6 ft	6	REF		
56594	227.2 to 228.2 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
38869	232.9 to 239.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,092
45447	237.1 to 238.1 feet	Vertical Change	-5	6 ft	6	REF		
47847	247.2 to 248.2 feet	Vertical Change	-4	6 ft	6	LF	\$75	\$413
51467	259.7 to 260.7 feet	Vertical Change	-3	6 ft	6	LF	\$75	\$413
38870	265.3 to 267.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,584
38872	270.3 to 279.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	51	SF	\$120	\$6,138
56595	279.6 to 280.6 feet	Vertical Change	.4	6 ft	6	REF		
TOTAL COST FOR: SW side of 13TH ST Starting at: TRINITY AVE							\$97,658.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261443	13TH ST	SIDEWALK BEGINS	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60324	0.3 to 18.1 feet	Driveway				REF		
38875	2.3 to 12.4 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	56	SF	\$40	\$2,222
38879	15.7 to 17.0 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	7	SF	\$40	\$286
41132	16.1 to 19.1 feet	Running Slope	5.0-6.0%	6 ft	17	REF		
38880	31.6 to 43.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	67	SF	\$120	\$8,052
47848	39.3 to 40.3 feet	Vertical Change	-.4	6 ft	6	REF		
38886	55.8 to 65.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	55	SF	\$120	\$6,600
38889	68.8 to 72.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640
38891	76.8 to 81.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
38893	86.8 to 88.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,122
38894	88.5 to 122.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	189	SF	\$120	\$22,638
38901	138.2 to 147.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,336
TOTAL COST FOR: SW side of 13TH ST Starting at: SIDEWALK BEGINS							\$52,932.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261447	13TH ST	ALAMEDA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38903	0.0 to 5.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,696
38904	13.6 to 19.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,092
55886	20.2 to 21.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
38906	22.0 to 23.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	10	SF	\$120	\$1,188
38907	25.9 to 27.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
38908	31.1 to 62.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	172	SF	\$120	\$20,658
60325	62.7 to 79.4 feet	Driveway				REF		
38914	69.1 to 75.8 feet	Cross Slope (Driveway)	13.014	6 ft	37	SF	\$40	\$1,474
38917	79.9 to 83.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310
56596	84.6 to 85.6 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
38918	88.4 to 107.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	103	SF	\$120	\$12,342
38924	107.7 to 130.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	124	SF	\$120	\$14,916
51468	128.3 to 129.3 feet	Vertical Change	-.3	6 ft	6	REF		
38930	132.1 to 136.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904
TOTAL COST FOR: SW side of 13TH ST Starting at: ALAMEDA AVE							\$65,395.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261448	13TH ST	SIDEWALK BEGINS	COLUSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38932	0.0 to 3.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	17	SF	\$120	\$2,046
38934	3.1 to 21.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	101	SF	\$120	\$12,078
38938	22.6 to 29.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	40	SF	\$120	\$4,752
38941	29.8 to 31.4 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	9	SF	\$120	\$1,056
38942	33.5 to 35.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	13	SF	\$120	\$1,518
38944	35.8 to 39.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310
38946	42.1 to 51.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	53	SF	\$120	\$6,402
38948	55.5 to 89.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	189	SF	\$120	\$22,638
38954	89.8 to 98.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	46	SF	\$120	\$5,544
60326	97.3 to 118.3 feet	Driveway				REF		
38956	101.5 to 110.0 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	47	SF	\$40	\$1,870
38961	110.5 to 111.8 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	7	SF	\$40	\$286
38962	115.3 to 121.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	35	SF	\$40	\$1,386
TOTAL COST FOR: SW side of 13TH ST Starting at: SIDEWALK BEGINS							\$61,886.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261449	13TH ST	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38963	1.8 to 9.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	41	SF	\$120	\$4,950
38966	12.0 to 25.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	74	SF	\$120	\$8,844
57220	15.7 to 16.7 feet	Vertical Change	.7	6 ft	6	REF		
55887	25.6 to 26.6 feet	Vertical Change	.3	6 ft	6	REF		
38971	25.7 to 27.0 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	7	SF	\$120	\$858
38972	29.3 to 32.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	19	SF	\$120	\$2,310
38973	32.8 to 39.5 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	37	SF	\$120	\$4,422
38976	39.5 to 41.1 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	9	SF	\$120	\$1,056
51469	40.3 to 41.3 feet	Vertical Change	-.3	6 ft	6	REF		
60327	40.3 to 54.7 feet	Driveway				REF		
56899	40.8 to 41.8 feet	Vertical Change	.5	6 ft	6	REF		
38977	45.7 to 52.8 feet	Cross Slope (Driveway)	>15%	6 ft	39	SF	\$40	\$1,562
38978	56.3 to 62.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	33	SF	\$120	\$3,960
55888	59.8 to 60.8 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: SW side of 13TH ST Starting at: SIDEWALK BEGINS							\$27,962.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NW	51909261451	MARIPOSA AVE	SIDEWALK BEGINS	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
38980	1.9 to 14.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	71	SF	\$120	\$8,514
47849	12.0 to 13.0 feet	Vertical Change	-.4	6 ft	6	REF		
38984	18.2 to 26.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,676
60328	25.3 to 42.5 feet	Driveway				REF		
55889	26.1 to 27.1 feet	Vertical Change	.3	6 ft	6	REF		
38987	31.3 to 42.1 feet	Cross Slope (Driveway)	13.014	6 ft	59	SF	\$40	\$2,376
57286	40.8 to 41.8 feet	Vertical Change	.8	6 ft	6	REF		
38992	45.5 to 46.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726
38993	47.4 to 50.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848
41134	52.8 to 54.0 feet	Running Slope	8.0-9.0%	6 ft	7	SF	\$120	\$792
55890	54.2 to 55.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
60329	54.2 to 69.0 feet	Driveway				REF		
38994	56.9 to 66.2 feet	Cross Slope (Driveway)	>15%	6 ft	51	SF	\$40	\$2,046
57603	58.0 to 59.0 feet	Vertical Change	2.9	6 ft	6	REF		
57652	63.3 to 64.3 feet	Vertical Change	3.4	6 ft	6	REF		
57567	66.1 to 67.1 feet	Vertical Change	2.5	6 ft	6	REF		
41135	66.2 to 68.6 feet	Running Slope	7.0-8.0%	6 ft	13	REF		
38995	70.4 to 86.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	87	SF	\$120	\$10,494
47850	71.1 to 72.1 feet	Vertical Change	-.4	6 ft	6	REF		
55891	85.8 to 89.6 feet	Vertical Change	.3	6 ft	21	REF		
38999	86.3 to 94.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	47	SF	\$120	\$5,610
55893	92.5 to 93.5 feet	Vertical Change	.3	6 ft	6	REF		
56597	95.6 to 96.6 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: NW side of MARIPOSA AVE Starting at: SIDEWALK BEGINS							\$38,907.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261455	14TH ST	COLUSA AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39002	1.5 to 47.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	252	SF	\$120	\$30,228
39013	51.1 to 55.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838
39015	55.4 to 60.4 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	28	SF	\$40	\$1,100
60330	58.9 to 89.3 feet	Driveway				REF		
55894	60.0 to 61.0 feet	Vertical Change	.3	6 ft	6	REF		
39017	65.6 to 73.9 feet	Cross Slope (Driveway)	>15%	6 ft	46	SF	\$40	\$1,826
39019	73.9 to 81.3 feet	Cross Slope (Driveway)	13.014	6 ft	41	SF	\$40	\$1,628
55895	76.9 to 77.9 feet	Vertical Change	.3	6 ft	6	REF		
39022	81.9 to 87.5 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	31	SF	\$40	\$1,232
55896	87.5 to 90.9 feet	Vertical Change	.3	6 ft	19	REF		
39024	87.5 to 93.0 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	30	SF	\$40	\$1,210
41137	87.8 to 88.8 feet	Running Slope	6.0-7.0%	6 ft	6	REF		
41138	89.4 to 92.1 feet	Running Slope	5.0-6.0%	6 ft	15	REF		
56598	93.3 to 94.3 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
210	96.4 to 97.4 feet	Protruding Object		6 ft	6	JOB	\$99	\$99
56599	105.4 to 108.3 feet	Vertical Change	.4	6 ft	16	LF	\$75	\$1,196
51470	111.2 to 112.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
39027	114.9 to 116.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
56600	116.8 to 117.8 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
39028	122.1 to 128.8 feet	Cross Slope (PAR)	9.0-10.0%	6 ft	37	SF	\$120	\$4,422
51471	129.0 to 130.3 feet	Vertical Change	-.3	6 ft	7	LF	\$75	\$536
41140	138.3 to 140.3 feet	Running Slope	5.0-6.0%	6 ft	11	SF	\$120	\$1,320
TOTAL COST FOR: SW side of 14TH ST Starting at: COLUSA AVE							\$49,599.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261456	14TH ST	SIDEWALK BEGINS	MARIPOSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39031	3.8 to 5.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	11	SF	\$120	\$1,320
39032	15.4 to 26.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	60	SF	\$120	\$7,194
55899	27.7 to 28.7 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
39035	30.9 to 41.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	56	SF	\$120	\$6,666
57686	38.1 to 39.1 feet	Vertical Change	3.6	6 ft	6	REF		
57423	41.9 to 42.9 feet	Vertical Change	1.2	6 ft	6	SF	\$75	\$413
39038	44.6 to 95.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	281	SF	\$120	\$33,660
45448	57.7 to 58.7 feet	Vertical Change	-.5	6 ft	6	REF		
57653	80.9 to 81.9 feet	Vertical Change	3.4	6 ft	6	REF		
39047	98.1 to 102.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772
39048	108.3 to 116.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,478
39050	120.6 to 132.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	64	SF	\$120	\$7,656
41885	129.7 to 130.7 feet	Vertical Change	-.8	6 ft	6	REF		
56900	132.1 to 135.3 feet	Vertical Change	.5	6 ft	18	REF		
39053	133.0 to 137.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	26	SF	\$120	\$3,102
51472	136.0 to 137.0 feet	Vertical Change	-.3	6 ft	6	REF		
41141	137.5 to 138.8 feet	Running Slope	5.0-6.0%	6 ft	7	REF		
TOTAL COST FOR: SW side of 14TH ST Starting at: SIDEWALK BEGINS							\$68,673.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NW	51909261458	MARIPOSA AVE	14TH ST	15TH ST					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
39054	0.8 to 9.9 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	50	SF	\$120	\$6,006	
57221	4.3 to 5.3 feet	Vertical Change	.7	6 ft	6	SF	\$75	\$413	
39058	10.3 to 13.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	15	SF	\$120	\$1,848	
51473	10.4 to 11.4 feet	Vertical Change	-.3	6 ft	6	REF			
56902	18.9 to 19.9 feet	Vertical Change	.5	6 ft	6	REF			
39060	19.4 to 30.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	62	SF	\$120	\$7,392	
60331	29.5 to 43.4 feet	Driveway				REF			
39065	36.7 to 39.7 feet	Cross Slope (Driveway)	13.014	6 ft	17	SF	\$40	\$660	
39067	39.7 to 40.9 feet	Cross Slope (Driveway)	>15%	6 ft	7	SF	\$40	\$264	
39068	46.0 to 71.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	141	SF	\$120	\$16,962	
39074	72.4 to 74.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518	
41886	76.1 to 77.1 feet	Vertical Change	-.8	6 ft	6	SF	\$75	\$413	
39075	80.9 to 83.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386	
39076	101.3 to 105.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640	
39077	129.5 to 131.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,386	
39078	136.8 to 139.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518	
39079	149.2 to 153.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,508	
39081	160.2 to 178.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	103	SF	\$120	\$12,342	
60332	178.3 to 198.7 feet	Driveway				REF			
39084	182.4 to 196.6 feet	Cross Slope (Driveway)	>15%	6 ft	78	SF	\$40	\$3,124	
39085	208.2 to 210.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782	
39086	215.8 to 218.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716	
39088	218.4 to 233.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	85	SF	\$120	\$10,164	
39090	233.8 to 274.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	226	SF	\$120	\$27,060	
55900	248.3 to 251.1 feet	Vertical Change	.3	6 ft	15	REF			
39099	276.3 to 282.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	34	SF	\$120	\$4,092	
39101	282.5 to 285.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178	
47852	284.6 to 285.6 feet	Vertical Change	-.4	6 ft	6	REF			

TOTAL COST FOR: NW side of MARIPOSA AVE Starting at: 14TH ST \$107,371.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261504	13TH ST	SIDEWALK BEGINS	COLUSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55901	0.1 to 1.1 feet	Vertical Change	.3	6 ft	6	REF		
39103	0.2 to 13.9 feet	Cross Slope (PAR)	14.0-15.0%	6 ft	75	SF	\$120	\$9,042
60333	3.3 to 14.9 feet	Driveway				REF		
41142	15.4 to 16.6 feet	Running Slope	5.0-6.0%	6 ft	7	REF		
211	16.2 to 17.2 feet	Continuous Width		6 ft	6	SF	\$120	\$660
41143	16.6 to 17.7 feet	Running Slope	6.0-7.0%	6 ft	6	SF	\$120	\$726
39106	26.0 to 27.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660
39107	29.5 to 41.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	68	SF	\$120	\$8,184
55902	32.7 to 33.7 feet	Vertical Change	.3	6 ft	6	REF		
39112	43.3 to 87.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	244	SF	\$120	\$29,238
39121	91.0 to 126.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	194	SF	\$120	\$23,232
39127	128.3 to 130.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	12	SF	\$120	\$1,452
39128	130.5 to 135.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,300
39129	143.8 to 150.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,488
60334	147.3 to 156.9 feet	Driveway				REF		
39131	154.2 to 155.5 feet	Cross Slope (Driveway)	13.014	6 ft	7	SF	\$40	\$286
TOTAL COST FOR: NE side of 13TH ST Starting at: SIDEWALK BEGINS							\$81,268.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	51909261506	13TH ST	COLUSA AVE	ALAMEDA AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
39132	0.0 to 6.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,554	
56602	6.1 to 7.1 feet	Vertical Change	.4	6 ft	6	REF			
39135	10.3 to 51.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	228	SF	\$120	\$27,390	
56903	12.0 to 13.0 feet	Vertical Change	.5	6 ft	6	REF			
55903	16.3 to 17.3 feet	Vertical Change	.3	6 ft	6	REF			
55904	26.4 to 27.4 feet	Vertical Change	.3	6 ft	6	REF			
51474	30.4 to 31.4 feet	Vertical Change	-.3	6 ft	6	REF			
212	42.6 to 43.6 feet	Protruding Object		6 ft	6	JOB	\$99	\$99	
55905	53.5 to 54.5 feet	Vertical Change	.3	6 ft	6	REF			
39142	54.4 to 74.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	108	SF	\$120	\$13,002	
51475	64.3 to 65.3 feet	Vertical Change	-.3	6 ft	6	REF			
43547	79.2 to 80.2 feet	Vertical Change	-.6	6 ft	6	REF			
39147	79.7 to 82.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518	
39148	84.8 to 90.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,432	
51476	89.5 to 90.5 feet	Vertical Change	-.3	6 ft	6	REF			
60335	90.0 to 107.5 feet	Driveway				REF			
39151	99.9 to 105.0 feet	Cross Slope (Driveway)	13.014	6 ft	28	SF	\$40	\$1,122	
47853	106.9 to 107.9 feet	Vertical Change	-.4	6 ft	6	REF			
39153	112.8 to 115.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	14	SF	\$120	\$1,716	
56603	118.2 to 119.2 feet	Vertical Change	.4	6 ft	6	REF			
39154	119.0 to 121.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	16	SF	\$120	\$1,914	
39156	123.3 to 140.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	97	SF	\$120	\$11,616	
60336	140.9 to 161.7 feet	Driveway				REF			
51477	141.3 to 142.3 feet	Vertical Change	-.3	6 ft	6	REF			
55906	141.5 to 142.5 feet	Vertical Change	.3	6 ft	6	REF			
51478	143.4 to 144.4 feet	Vertical Change	-.3	6 ft	6	REF			
39157	143.6 to 144.6 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	6	SF	\$40	\$220	
39158	146.9 to 148.2 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	7	SF	\$40	\$286	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261506	13TH ST	COLUSA AVE	ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39159	148.7 to 151.8 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	17	SF	\$40	\$682
51479	151.9 to 152.9 feet	Vertical Change	-.3	6 ft	6	REF		
39161	155.4 to 158.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	17	SF	\$40	\$682
55907	157.0 to 161.8 feet	Vertical Change	.3	6 ft	26	REF		
51480	167.2 to 168.2 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
56604	167.3 to 168.3 feet	Vertical Change	.4	6 ft	6	LF	\$75	\$413
39163	179.4 to 188.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	49	SF	\$120	\$5,874
39166	194.9 to 197.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716
60337	198.7 to 231.9 feet	Driveway				REF		
41144	200.2 to 201.8 feet	Running Slope	7.0-8.0%	6 ft	9	REF		
57504	201.3 to 202.3 feet	Vertical Change	1.7	6 ft	6	REF		
39167	202.5 to 203.6 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	6	SF	\$40	\$242
39168	205.2 to 218.8 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	75	SF	\$40	\$2,992
39174	220.9 to 228.2 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	40	SF	\$40	\$1,606
39176	244.4 to 251.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	41	SF	\$120	\$4,950
39177	258.5 to 261.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,244
55910	277.0 to 278.0 feet	Vertical Change	.3	6 ft	6	REF		
39178	277.6 to 284.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,422
51481	287.3 to 288.3 feet	Vertical Change	-.3	6 ft	6	REF		
39180	288.2 to 289.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
39181	298.6 to 303.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,168
55911	301.3 to 302.3 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: NE side of 13TH ST Starting at: COLUSA AVE							\$97,328.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261514	14TH ST	SIDEWALK BEGINS	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39182	0.0 to 6.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	38	SF	\$120	\$4,554
39184	6.9 to 8.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858
55912	10.0 to 11.0 feet	Vertical Change	.3	6 ft	6	REF		
39185	10.8 to 11.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726
39186	13.7 to 17.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640
39188	17.7 to 41.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	131	SF	\$120	\$15,708
60338	45.3 to 70.3 feet	Driveway				REF		
56605	46.5 to 47.5 feet	Vertical Change	.4	6 ft	6	REF		
39192	50.3 to 66.1 feet	Cross Slope (Driveway)	>15%	6 ft	87	SF	\$40	\$3,476
45449	68.3 to 69.3 feet	Vertical Change	-.5	6 ft	6	REF		
39198	71.1 to 94.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	127	SF	\$120	\$15,180
39203	94.1 to 106.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	70	SF	\$120	\$8,382
55913	100.8 to 101.8 feet	Vertical Change	.3	6 ft	6	REF		
39207	107.1 to 111.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	23	SF	\$120	\$2,706
55914	107.8 to 108.8 feet	Vertical Change	.3	6 ft	6	REF		
39209	111.2 to 112.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
39210	115.1 to 116.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726
39211	118.4 to 121.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	19	SF	\$120	\$2,310
47854	125.0 to 126.0 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
55915	126.8 to 127.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
41145	129.3 to 131.1 feet	Running Slope	5.0-6.0%	6 ft	10	SF	\$120	\$1,188
TOTAL COST FOR: NE side of 14TH ST Starting at: SIDEWALK BEGINS							\$60,335.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261516	14TH ST	SIDEWALK BEGINS	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39212	0.0 to 1.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
39213	6.5 to 16.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	54	SF	\$120	\$6,468
39216	104.3 to 106.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,584
39217	110.3 to 111.8 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	8	SF	\$120	\$990
39218	113.3 to 114.6 feet	Cross Slope (PAR)	8.0-9.0%	6 ft	7	SF	\$120	\$858
39219	115.9 to 117.3 feet	Cross Slope (PAR)	10.0-11.0%	6 ft	8	SF	\$120	\$924
55916	116.2 to 117.2 feet	Vertical Change	.3	6 ft	6	REF		
39220	119.8 to 124.5 feet	Cross Slope (PAR)	12.0-13.0%	6 ft	26	SF	\$120	\$3,102
39222	124.8 to 128.8 feet	Cross Slope (PAR)	10.0-11.0%	6 ft	22	SF	\$120	\$2,640
TOTAL COST FOR: NE side of 14TH ST Starting at: SIDEWALK BEGINS							\$17,754.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261518	14TH ST	SIDEWALK BEGINS	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39224	5.1 to 7.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	15	SF	\$120	\$1,782
39226	9.1 to 16.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	41	SF	\$120	\$4,950
39228	20.2 to 45.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	138	SF	\$120	\$16,500
60339	42.6 to 64.3 feet	Driveway				REF		
39238	48.3 to 53.6 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	29	SF	\$40	\$1,166
39241	53.6 to 63.1 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	52	SF	\$40	\$2,090
47855	64.6 to 65.6 feet	Vertical Change	-.4	6 ft	6	LF	\$75	\$413
39244	65.8 to 66.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726
39245	69.1 to 75.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,092
39248	78.2 to 83.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	31	SF	\$120	\$3,696
39251	83.8 to 100.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	93	SF	\$120	\$11,154
39255	103.4 to 128.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	139	SF	\$120	\$16,632
55917	104.8 to 105.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
56606	124.8 to 125.8 feet	Vertical Change	.4	6 ft	6	REF		
TOTAL COST FOR: SW side of 14TH ST Starting at: SIDEWALK BEGINS								\$63,613.00

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261530	14TH ST	ORANGE AVE	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39261	0.0 to 2.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,782
39263	12.1 to 29.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	95	SF	\$120	\$11,418
39268	44.3 to 52.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	44	SF	\$120	\$5,280
39272	58.0 to 68.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	58	SF	\$120	\$6,930
39274	76.7 to 79.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,716
47856	79.8 to 80.8 feet	Vertical Change	-4	6 ft	6	LF	\$75	\$413
39276	94.4 to 120.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	142	SF	\$120	\$17,094
43548	119.9 to 120.9 feet	Vertical Change	-6	6 ft	6	REF		
TOTAL COST FOR: SW side of 14TH ST Starting at: ORANGE AVE							\$44,632.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261532	14TH ST	SIDEWALK BEGINS	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
55918	12.4 to 13.4 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
39279	25.8 to 39.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	77	SF	\$120	\$9,240
39282	44.0 to 48.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838
57397	54.6 to 55.6 feet	Vertical Change	1.1	6 ft	6	SF	\$75	\$413
60340	54.6 to 76.6 feet	Driveway				REF		
39284	59.7 to 74.6 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	82	SF	\$40	\$3,278
45450	75.0 to 76.0 feet	Vertical Change	-.5	6 ft	6	REF		
39287	89.1 to 93.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036
39288	121.0 to 128.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,148
TOTAL COST FOR: SW side of 14TH ST Starting at: SIDEWALK BEGINS							\$24,365.00	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261533	14TH ST	SIDEWALK BEGINS	ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39290	0.0 to 3.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,508
213	4.1 to 5.1 feet	Continuous Width		6 ft	6	SF	\$120	\$660
39291	5.9 to 7.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$924
39292	14.0 to 19.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,432
57461	18.1 to 19.1 feet	Vertical Change	1.4	6 ft	6	REF		
51482	21.3 to 22.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
43549	23.3 to 24.3 feet	Vertical Change	-.6	6 ft	6	SF	\$75	\$413
39294	28.7 to 81.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	289	SF	\$120	\$34,716
51483	72.3 to 73.3 feet	Vertical Change	-.3	6 ft	6	REF		
57637	83.8 to 84.8 feet	Vertical Change	3.3	6 ft	6	SF	\$75	\$413
39304	85.8 to 86.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660
39305	99.6 to 101.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452
51484	102.5 to 103.5 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
39306	126.0 to 127.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
39307	135.8 to 139.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	18	SF	\$120	\$2,178
55919	139.2 to 140.2 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
TOTAL COST FOR: SW side of 14TH ST Starting at: SIDEWALK BEGINS							\$49,780.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261536	14TH ST	SIDEWALK BEGINS	ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39308	0.0 to 3.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	21	SF	\$120	\$2,508
39309	6.2 to 9.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	17	SF	\$120	\$2,046
39311	11.8 to 17.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	32	SF	\$120	\$3,894
55920	15.7 to 16.7 feet	Vertical Change	.3	6 ft	6	REF		
39313	17.7 to 34.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	91	SF	\$120	\$10,890
56607	25.8 to 26.8 feet	Vertical Change	.4	6 ft	6	REF		
39318	37.5 to 39.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	8	SF	\$120	\$990
55921	39.8 to 40.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
39319	42.4 to 64.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	123	SF	\$120	\$14,718
45451	69.8 to 70.8 feet	Vertical Change	-.5	6 ft	6	REF		
39324	70.3 to 71.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$990
39325	74.5 to 90.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	85	SF	\$120	\$10,230
56608	79.8 to 80.8 feet	Vertical Change	.4	6 ft	6	REF		
60341	92.1 to 116.5 feet	Driveway				REF		
39329	92.8 to 94.1 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	7	SF	\$40	\$286
56904	93.7 to 94.7 feet	Vertical Change	.5	6 ft	6	REF		
39330	98.0 to 113.3 feet	Cross Slope (Driveway)	>15%	6 ft	84	SF	\$40	\$3,366
41146	114.8 to 116.7 feet	Running Slope	5.0-6.0%	6 ft	10	REF		
39331	120.5 to 126.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,158
39333	126.9 to 136.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	54	SF	\$120	\$6,468
TOTAL COST FOR: NE side of 14TH ST Starting at: SIDEWALK BEGINS								\$60,956.50

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261542	15TH ST	ORANGE AVE	TRINITY AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39337	0.1 to 6.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,026
47857	3.6 to 4.6 feet	Vertical Change	-.4	6 ft	5	REF		
51485	7.4 to 8.4 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
39339	40.8 to 51.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	61	SF	\$120	\$7,260
39341	57.4 to 64.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	38	SF	\$120	\$4,554
39343	86.0 to 90.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	26	SF	\$120	\$3,102
39344	94.6 to 98.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574
60342	97.3 to 119.8 feet	Driveway				REF		
39346	102.4 to 108.7 feet	Cross Slope (Driveway)	13.014	6 ft	35	SF	\$40	\$1,386
39349	110.8 to 117.2 feet	Cross Slope (Driveway)	13.014	6 ft	35	SF	\$40	\$1,408
39350	125.8 to 134.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,676
60343	133.9 to 155.8 feet	Driveway				REF		
39354	138.1 to 139.4 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	7	SF	\$40	\$286
39355	140.2 to 147.9 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	42	SF	\$40	\$1,694
39357	148.8 to 151.8 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	17	SF	\$40	\$660
51486	195.3 to 196.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
39359	210.1 to 221.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	61	SF	\$120	\$7,326
55922	260.1 to 261.1 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413
39363	286.6 to 288.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452
57616	288.3 to 289.3 feet	Vertical Change	3	6 ft	6	REF		

TOTAL COST FOR: NE	<i>side of 15TH ST Starting at: ORANGE AVE</i>	\$42,641.50
---------------------------	--	--------------------

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	51909261544	15TH ST	TRINITY AVE	ROBERTSON BLVD					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
47858	0.6 to 1.6 feet	Vertical Change	-.4	6 ft	6	REF			
39364	0.8 to 6.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,762	
39366	6.5 to 10.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	22	SF	\$120	\$2,640	
39368	13.1 to 14.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$792	
39369	14.6 to 18.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,442	
60344	33.4 to 56.9 feet	Driveway				REF			
57222	35.3 to 36.3 feet	Vertical Change	.7	6 ft	6	REF			
39371	40.4 to 54.2 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	76	SF	\$40	\$3,036	
51487	46.4 to 47.4 feet	Vertical Change	-.3	6 ft	6	REF			
45452	55.8 to 56.8 feet	Vertical Change	-.5	6 ft	6	REF			
51488	62.1 to 63.1 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413	
60345	67.9 to 87.7 feet	Driveway				REF			
51489	69.5 to 70.5 feet	Vertical Change	-.3	6 ft	6	REF			
39373	76.2 to 82.3 feet	Cross Slope (Driveway)	6.0-7.0%	6 ft	34	SF	\$40	\$1,342	
41147	88.3 to 90.0 feet	Running Slope	6.0-7.0%	6 ft	9	REF			
60346	116.8 to 132.9 feet	Driveway				REF			
51490	118.3 to 119.3 feet	Vertical Change	-.3	6 ft	6	REF			
39376	119.6 to 120.8 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	7	SF	\$40	\$264	
39377	123.3 to 125.9 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	14	SF	\$40	\$572	
39378	125.9 to 131.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	33	SF	\$40	\$1,320	
41148	127.3 to 128.8 feet	Running Slope	5.0-6.0%	6 ft	8	REF			
45453	131.5 to 138.2 feet	Vertical Change	-.5	6 ft	37	REF			
41149	131.8 to 133.3 feet	Running Slope	6.0-7.0%	6 ft	8	REF			
60347	135.1 to 163.4 feet	Driveway				REF			
41150	158.6 to 165.6 feet	Running Slope	5.0-6.0%	6 ft	39	REF			
39381	163.7 to 168.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$3,036	
55923	167.2 to 168.2 feet	Vertical Change	.3	6 ft	6	REF			
39383	173.6 to 176.2 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	14	SF	\$120	\$1,716	
47859	174.5 to 175.5 feet	Vertical Change	-.4	6 ft	6	REF			

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261544	15TH ST	TRINITY AVE	ROBERTSON BLVD	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39385	178.7 to 195.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	92	SF	\$120	\$11,088
55924	182.0 to 183.0 feet	Vertical Change	.3	6 ft	6	REF		
39390	195.5 to 207.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	68	SF	\$120	\$8,118
47860	202.0 to 203.0 feet	Vertical Change	-.4	6 ft	6	REF		
39392	207.8 to 214.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	39	SF	\$120	\$4,620
47861	212.1 to 213.1 feet	Vertical Change	-.4	6 ft	6	REF		
39394	214.8 to 222.1 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	40	SF	\$120	\$4,818
60348	219.9 to 253.4 feet	Driveway				REF		
39398	224.1 to 225.2 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	6	SF	\$40	\$242
55925	233.3 to 234.3 feet	Vertical Change	.3	6 ft	6	REF		
56609	242.8 to 243.8 feet	Vertical Change	.4	6 ft	6	REF		
39399	247.9 to 250.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	14	SF	\$40	\$550
39401	250.4 to 252.8 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	13	SF	\$40	\$528
39403	255.4 to 267.5 feet	Cross Slope (PAR)	7.0-8.0%	6 ft	67	SF	\$120	\$7,986
39409	267.5 to 269.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	13	SF	\$120	\$1,518
TOTAL COST FOR: NE side of 15TH ST Starting at: TRINITY AVE							\$60,802.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	51909261547	15TH ST	ROBERTSON BLVD	ROOSEVELT DR					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
39410	0.8 to 2.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	8	SF	\$120	\$990	
39411	7.8 to 11.6 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	21	SF	\$120	\$2,508	
39413	16.1 to 20.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	25	SF	\$120	\$3,036	
39415	21.2 to 30.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	49	SF	\$120	\$5,874	
39416	35.3 to 37.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	14	SF	\$120	\$1,650	
60349	70.0 to 111.9 feet	Driveway				REF			
39417	71.8 to 73.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	8	SF	\$40	\$308	
39418	78.8 to 81.1 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	13	SF	\$40	\$506	
39419	85.0 to 102.9 feet	Cross Slope (Driveway)	13.014	6 ft	98	SF	\$40	\$3,938	
39426	102.9 to 108.5 feet	Cross Slope (Driveway)	>15%	6 ft	31	SF	\$40	\$1,232	
39427	182.6 to 193.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	61	SF	\$120	\$7,326	
39430	195.8 to 199.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640	
39431	206.3 to 207.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
39432	222.8 to 224.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122	
55926	256.7 to 257.7 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
39433	259.8 to 279.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	107	SF	\$120	\$12,870	
42360	279.8 to 280.8 feet	Vertical Change	-.7	6 ft	6	SF	\$75	\$413	
60350	279.9 to 318.0 feet	Driveway				REF			
39438	284.8 to 316.5 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	174	SF	\$40	\$6,974	
55927	288.5 to 289.5 feet	Vertical Change	.3	6 ft	6	REF			
41153	317.7 to 319.0 feet	Running Slope	6.0-7.0%	6 ft	7	REF			
43550	318.1 to 321.7 feet	Vertical Change	-.6	6 ft	20	REF			
57119	323.0 to 324.0 feet	Vertical Change	.6	6 ft	6	SF	\$75	\$413	
41154	324.3 to 325.3 feet	Running Slope	6.0-7.0%	6 ft	6	SF	\$120	\$660	
39448	326.0 to 328.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	13	SF	\$120	\$1,518	
39449	331.1 to 332.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$792	
60351	340.0 to 362.0 feet	Driveway				REF			
39450	343.8 to 346.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	14	SF	\$40	\$572	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261547	15TH ST	ROBERTSON BLVD	ROOSEVELT DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39451	348.6 to 361.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	68	SF	\$40	\$2,728
39456	361.4 to 365.5 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	23	SF	\$40	\$902
39458	365.5 to 377.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	65	SF	\$120	\$7,788
39462	377.8 to 383.4 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	31	SF	\$120	\$3,696
39463	388.7 to 402.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	78	SF	\$120	\$9,372
39466	404.0 to 409.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	32	SF	\$120	\$3,828
39469	409.8 to 432.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	126	SF	\$120	\$15,114
60352	418.3 to 438.1 feet	Driveway				REF		
39476	437.7 to 447.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	53	SF	\$40	\$2,112
39480	450.0 to 451.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$660
39481	454.3 to 458.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	22	SF	\$120	\$2,640
39483	458.3 to 463.2 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	27	SF	\$120	\$3,234
39486	465.4 to 467.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	13	SF	\$120	\$1,584
TOTAL COST FOR: SW side of 15TH ST Starting at: ROBERTSON BLVD							\$110,071.50	

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
SW	51909261549	15TH ST	ROOSEVELT DR	HOOVER AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
39487	0.8 to 7.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,158	
39490	7.8 to 15.8 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	44	SF	\$120	\$5,280	
39493	18.6 to 20.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	11	SF	\$120	\$1,320	
39494	21.6 to 23.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188	
39495	26.2 to 33.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,686	
39497	38.1 to 46.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	45	SF	\$120	\$5,412	
39500	46.3 to 52.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,026	
39502	56.3 to 57.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$990	
60353	61.4 to 80.5 feet	Driveway				REF			
39503	65.0 to 73.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	45	SF	\$40	\$1,804	
42362	68.7 to 69.7 feet	Vertical Change	-.7	6 ft	6	REF			
39506	75.5 to 94.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	104	SF	\$40	\$4,158	
39517	110.1 to 111.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
39518	114.8 to 119.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	25	SF	\$120	\$2,970	
39520	120.2 to 121.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$660	
39521	123.8 to 129.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,432	
39524	132.6 to 141.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	49	SF	\$120	\$5,874	
39527	145.3 to 149.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838	
39529	152.8 to 158.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	32	SF	\$120	\$3,828	
39532	159.0 to 168.9 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	54	SF	\$120	\$6,534	
39536	168.9 to 176.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	43	SF	\$120	\$5,214	
39540	181.3 to 182.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858	
39541	185.4 to 188.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	17	SF	\$120	\$2,046	
39543	189.8 to 194.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	25	SF	\$120	\$2,970	
39545	194.5 to 202.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	45	SF	\$120	\$5,412	
39548	202.7 to 212.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	54	SF	\$120	\$6,468	
60355	206.8 to 244.6 feet	Driveway				REF			
39552	218.7 to 223.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	27	SF	\$40	\$1,078	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261549	15TH ST	ROOSEVELT DR	HOOVER AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39554	224.4 to 228.7 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	24	SF	\$40	\$946
39556	229.3 to 237.5 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	45	SF	\$40	\$1,804
39557	248.7 to 250.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122
39558	257.5 to 267.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	56	SF	\$120	\$6,666
39562	269.9 to 271.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,056
39563	273.8 to 290.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	91	SF	\$120	\$10,890
TOTAL COST FOR: SW side of 15TH ST Starting at: ROOSEVELT DR								\$106,414.00

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261551	15TH ST	HOOVER AVE	COOLIDGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39567	2.0 to 3.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	10	SF	\$120	\$1,188
56610	2.3 to 3.3 feet	Vertical Change	.4	6 ft	6	REF		
39568	10.7 to 31.4 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	114	SF	\$120	\$13,662
39575	32.0 to 52.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	113	SF	\$120	\$13,530
39582	65.3 to 70.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,630
39583	73.9 to 84.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	58	SF	\$120	\$6,930
60356	85.1 to 130.7 feet	Driveway				REF		
39585	87.3 to 91.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	22	SF	\$40	\$880
39587	93.5 to 119.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	145	SF	\$40	\$5,808
39596	120.9 to 135.4 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	80	SF	\$40	\$3,190
39604	150.3 to 167.5 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	95	SF	\$120	\$11,352
39609	168.8 to 205.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	201	SF	\$120	\$24,090
60358	203.3 to 234.0 feet	Driveway				REF		
39617	208.0 to 211.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	19	SF	\$40	\$748
57620	214.3 to 215.3 feet	Vertical Change	3.1	6 ft	6	REF		
39618	214.7 to 238.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	129	SF	\$40	\$5,148
39625	279.4 to 286.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	39	SF	\$120	\$4,620
TOTAL COST FOR: SW side of 15TH ST Starting at: HOOVER AVE							\$94,776.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261553	15TH ST	COOLIDGE AVE	HARDING AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39627	0.3 to 17.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	94	SF	\$120	\$11,286
39629	17.7 to 25.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	42	SF	\$120	\$5,016
60359	20.2 to 74.8 feet	Driveway				REF		
39632	26.9 to 28.6 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	9	SF	\$40	\$374
39633	30.9 to 36.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	30	SF	\$40	\$1,188
55928	32.3 to 33.3 feet	Vertical Change	.3	6 ft	6	REF		
39635	43.2 to 45.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	15	SF	\$40	\$594
39636	52.3 to 60.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	44	SF	\$40	\$1,760
51493	64.0 to 65.0 feet	Vertical Change	-.3	6 ft	6	REF		
39639	67.7 to 72.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	25	SF	\$40	\$990
39640	79.9 to 98.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	100	SF	\$120	\$12,012
39645	100.9 to 108.7 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	43	SF	\$120	\$5,148
39648	108.8 to 114.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	30	SF	\$120	\$3,564
39649	118.1 to 126.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,676
39652	138.3 to 145.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,818
39654	145.8 to 157.1 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	62	SF	\$120	\$7,458
60360	147.9 to 158.8 feet	Driveway				REF		
39656	158.3 to 161.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	17	SF	\$40	\$660
60361	163.5 to 184.0 feet	Driveway				REF		
39657	163.9 to 166.9 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	17	SF	\$40	\$660
39659	175.0 to 193.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	99	SF	\$40	\$3,960
60362	187.0 to 214.8 feet	Driveway				REF		
39664	210.1 to 225.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	82	SF	\$40	\$3,278
39668	231.4 to 232.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726
39669	236.1 to 239.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	20	SF	\$120	\$2,442
TOTAL COST FOR: SW side of 15TH ST Starting at: COOLIDGE AVE							\$71,610.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261554	15TH ST	HARDING AVE	TRUMAN DR	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60363	5.4 to 32.5 feet	Driveway				REF		
39670	8.0 to 9.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$242
39671	15.4 to 27.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	65	SF	\$40	\$2,596
39674	30.1 to 39.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	49	SF	\$40	\$1,958
60364	50.0 to 119.3 feet	Driveway				REF		
39677	52.9 to 54.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	10	SF	\$40	\$418
39678	62.1 to 68.0 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	32	SF	\$40	\$1,298
39681	113.9 to 117.4 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	19	SF	\$40	\$770
TOTAL COST FOR: SW side of 15TH ST Starting at: HARDING AVE							\$7,282.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
SW	51909261556	RD 15 1/2	TRUMAN DR	SIDEWALK ENDS	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
41430	1.6 to 2.6 feet	Vertical Change	-1.2	6 ft	6	REF		
39683	1.9 to 14.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	70	SF	\$120	\$8,382
39686	17.4 to 20.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	14	SF	\$120	\$1,716
39688	21.3 to 34.7 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	74	SF	\$120	\$8,844
60365	25.3 to 77.8 feet	Driveway				REF		
39691	35.1 to 38.3 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	18	SF	\$40	\$704
39693	38.7 to 45.9 feet	Cross Slope (Driveway)	5.0-6.0%	6 ft	40	SF	\$40	\$1,584
39695	47.9 to 65.1 feet	Cross Slope (Driveway)	3.0-4.0%	6 ft	95	SF	\$40	\$3,784
39700	65.6 to 83.3 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	97	SF	\$40	\$3,894
39706	90.3 to 96.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	35	SF	\$120	\$4,224
39707	100.5 to 110.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	54	SF	\$120	\$6,468
51494	118.0 to 119.0 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
39710	126.6 to 130.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640
39712	132.7 to 138.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	34	SF	\$120	\$4,026
51495	155.3 to 156.3 feet	Vertical Change	-.3	6 ft	6	LF	\$75	\$413
60366	173.3 to 203.1 feet	Driveway				REF		
39713	173.6 to 179.8 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	34	SF	\$40	\$1,364
39714	193.8 to 199.7 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	32	SF	\$40	\$1,298
47862	194.3 to 195.3 feet	Vertical Change	-.4	6 ft	6	REF		
39715	202.5 to 218.2 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	86	SF	\$40	\$3,454
39716	228.1 to 234.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,422
TOTAL COST FOR: SW side of RD 15 1/2 Starting at: TRUMAN DR							\$57,629.00	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	51909261558	RD 15 1/2	MARIPOSA AVE	COLUSA AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
39717	0.0 to 14.9 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	82	SF	\$120	\$9,834	
39722	15.8 to 17.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	9	SF	\$120	\$1,122	
39723	25.4 to 28.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	16	SF	\$120	\$1,914	
39724	31.1 to 43.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	70	SF	\$120	\$8,382	
55929	43.1 to 44.1 feet	Vertical Change	.3	6 ft	6	REF			
39726	49.0 to 57.7 feet	Cross Slope (PAR)	10.0-11.0%	6 ft	48	SF	\$120	\$5,742	
60367	52.3 to 57.9 feet	Driveway				REF			
41155	56.8 to 59.3 feet	Running Slope	6.0-7.0%	6 ft	14	REF			
39728	63.4 to 67.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	23	SF	\$120	\$2,772	
60368	76.2 to 92.0 feet	Driveway				REF			
39729	81.8 to 87.4 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	31	SF	\$40	\$1,232	
39731	93.0 to 115.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	122	SF	\$120	\$14,586	
39740	117.4 to 118.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$792	
39741	120.2 to 127.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,082	
39743	130.2 to 131.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	6	SF	\$120	\$726	
60369	130.3 to 154.3 feet	Driveway				REF			
55930	130.5 to 131.5 feet	Vertical Change	.3	6 ft	6	REF			
39744	138.8 to 147.4 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	47	SF	\$40	\$1,892	
39747	151.3 to 152.4 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	6	SF	\$40	\$242	
39748	155.5 to 157.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	11	SF	\$120	\$1,320	
39749	159.8 to 161.2 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	8	SF	\$120	\$924	
39750	162.7 to 170.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,016	
39754	176.2 to 180.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574	
60370	206.4 to 224.8 feet	Driveway				REF			
39756	207.0 to 208.1 feet	Cross Slope (Driveway)	2.0-3.0%	6 ft	6	SF	\$40	\$242	
39757	212.5 to 221.6 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	50	SF	\$40	\$2,002	
39761	226.5 to 229.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	15	SF	\$120	\$1,848	
39762	231.8 to 236.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	28	SF	\$120	\$3,300	
39765	241.3 to 245.7 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261558	RD 15 1/2	MARIPOSA AVE	COLUSA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39766	248.4 to 256.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	47	SF	\$120	\$5,610
55931	255.3 to 256.3 feet	Vertical Change	.3	6 ft	6	REF		
39768	259.8 to 280.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	116	SF	\$120	\$13,926
57223	266.3 to 267.3 feet	Vertical Change	.7	6 ft	6	REF		
39776	284.3 to 286.8 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	14	SF	\$120	\$1,650
55932	286.8 to 287.8 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: NE side of RD 15 1/2 Starting at: MARIPOSA AVE							\$95,634.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority				
NE	51909261600	15TH ST	COLUSA AVE	ALAMEDA AVE	TBD				
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
39778	3.6 to 7.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,838	
214	4.7 to 5.7 feet	Continuous Width		6 ft	6	SF	\$120	\$660	
39779	10.0 to 13.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	19	SF	\$120	\$2,310	
39781	19.2 to 20.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	7	SF	\$120	\$858	
39782	22.7 to 25.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	14	SF	\$120	\$1,716	
39784	25.9 to 31.1 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	29	SF	\$120	\$3,432	
39787	31.1 to 36.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	29	SF	\$120	\$3,432	
39790	36.3 to 42.1 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	32	SF	\$120	\$3,828	
39791	43.8 to 47.1 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	18	SF	\$120	\$2,178	
39792	47.4 to 50.8 feet	Cross Slope (PAR)	5.0-6.0%	6 ft	19	SF	\$120	\$2,244	
39794	50.8 to 52.5 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	9	SF	\$120	\$1,122	
60371	53.3 to 73.6 feet	Driveway				REF			
39795	59.0 to 70.3 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	62	SF	\$40	\$2,486	
39798	75.3 to 76.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
60372	82.3 to 103.5 feet	Driveway				REF			
39799	88.2 to 91.8 feet	Cross Slope (Driveway)	14.0-15.0%	6 ft	20	SF	\$40	\$792	
39801	91.8 to 94.6 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	15	SF	\$40	\$616	
39802	97.1 to 101.1 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	22	SF	\$40	\$880	
39804	105.8 to 109.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	22	SF	\$120	\$2,640	
39805	127.2 to 131.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,574	
60373	133.6 to 157.2 feet	Driveway				REF			
39806	137.9 to 139.2 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	7	SF	\$40	\$286	
39807	141.1 to 150.8 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	53	SF	\$40	\$2,134	
39811	151.3 to 153.8 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	14	SF	\$40	\$550	
39812	167.4 to 175.0 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,016	
39815	189.3 to 190.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	6	SF	\$120	\$726	
39816	196.6 to 206.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	52	SF	\$120	\$6,270	
55933	206.8 to 207.8 feet	Vertical Change	.3	6 ft	6	LF	\$75	\$413	
60374	207.8 to 221.8 feet	Driveway				REF			

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261600	15TH ST	COLUSA AVE	ALAMEDA AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39819	211.1 to 218.3 feet	Cross Slope (Driveway)	>15%	6 ft	40	SF	\$40	\$1,584
39820	233.2 to 244.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	62	SF	\$120	\$7,458
39822	251.3 to 259.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	46	SF	\$120	\$5,478
39825	265.3 to 290.5 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	139	SF	\$120	\$16,632
51496	289.8 to 290.8 feet	Vertical Change	-.3	6 ft	6	REF		
TOTAL COST FOR: NE side of 15TH ST Starting at: COLUSA AVE							\$81,878.50	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261602	15TH ST	ALAMEDA AVE	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39832	0.8 to 8.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	40	SF	\$120	\$4,818
55934	4.7 to 5.7 feet	Vertical Change	.3	6 ft	6	REF		
39835	10.8 to 33.1 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	123	SF	\$120	\$14,718
56611	11.7 to 15.3 feet	Vertical Change	.4	6 ft	20	REF		
57505	29.0 to 30.0 feet	Vertical Change	1.7	6 ft	6	REF		
39841	36.0 to 37.3 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	7	SF	\$120	\$858
39842	38.8 to 42.6 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	21	SF	\$120	\$2,508
42363	46.6 to 47.6 feet	Vertical Change	-.7	6 ft	6	REF		
39844	47.4 to 68.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	115	SF	\$120	\$13,794
56612	58.8 to 59.8 feet	Vertical Change	.4	6 ft	6	REF		
55936	62.8 to 63.8 feet	Vertical Change	.3	6 ft	6	REF		
60375	67.8 to 84.7 feet	Driveway				REF		
56613	68.2 to 69.2 feet	Vertical Change	.4	6 ft	6	REF		
39851	74.7 to 80.3 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	31	SF	\$40	\$1,232
56614	76.0 to 77.0 feet	Vertical Change	.4	6 ft	6	REF		
39853	80.3 to 81.7 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	8	SF	\$40	\$308
39854	88.5 to 98.0 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	52	SF	\$120	\$6,270
39859	98.8 to 106.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	42	SF	\$120	\$5,016
39860	109.3 to 134.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	141	SF	\$120	\$16,896
47863	112.8 to 113.8 feet	Vertical Change	-.4	6 ft	6	REF		
57371	118.7 to 119.7 feet	Vertical Change	1	6 ft	6	REF		
60376	133.9 to 157.3 feet	Driveway				REF		
39868	140.7 to 152.8 feet	Cross Slope (Driveway)	9.0-10.0%	6 ft	67	SF	\$40	\$2,662
39872	159.1 to 173.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	78	SF	\$120	\$9,306
39875	175.6 to 215.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	222	SF	\$120	\$26,598
39885	219.2 to 221.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	12	SF	\$120	\$1,452
39886	227.7 to 237.1 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	52	SF	\$120	\$6,204
39888	242.0 to 249.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	41	SF	\$120	\$4,884

Funding Source: **TBD**Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261602	15TH ST	ALAMEDA AVE	HUMBOLDT AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
60377	257.6 to 280.3 feet	Driveway				REF		
39890	263.8 to 275.4 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	64	SF	\$40	\$2,552
39894	276.3 to 277.7 feet	Cross Slope (Driveway)	8.0-9.0%	6 ft	8	SF	\$40	\$308
39895	279.5 to 280.5 feet	Cross Slope (Driveway)	4.0-5.0%	6 ft	6	SF	\$40	\$220
39896	281.0 to 286.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,432
39898	286.2 to 291.3 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	28	SF	\$120	\$3,366
55937	290.3 to 291.3 feet	Vertical Change	.3	6 ft	6	REF		
TOTAL COST FOR: NE side of 15TH ST Starting at: ALAMEDA AVE							\$127,402.00	

Funding Source: TBD

Year to be Completed TBD

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name					Priority
NE	51909261604	15TH ST	HUMBOLDT AVE	ORANGE AVE					TBD
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total	
39899	0.0 to 5.3 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	29	SF	\$120	\$3,498	
41157	0.4 to 1.8 feet	Running Slope	5.0-6.0%	6 ft	8	REF			
39901	14.7 to 20.4 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	31	SF	\$120	\$3,762	
56905	19.3 to 20.3 feet	Vertical Change	.5	6 ft	6	REF			
39903	23.4 to 49.6 feet	Cross Slope (PAR)	3.0-4.0%	6 ft	144	SF	\$120	\$17,292	
57224	23.6 to 24.6 feet	Vertical Change	.7	6 ft	6	REF			
39910	49.8 to 70.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	116	SF	\$120	\$13,860	
60378	67.8 to 88.8 feet	Driveway				REF			
39916	74.2 to 78.6 feet	Cross Slope (Driveway)	12.0-13.0%	6 ft	24	SF	\$40	\$968	
39918	80.3 to 86.3 feet	Cross Slope (Driveway)	10.0-11.0%	6 ft	33	SF	\$40	\$1,320	
41158	90.5 to 92.9 feet	Running Slope	5.0-6.0%	6 ft	13	SF	\$120	\$1,584	
39921	97.2 to 103.9 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	37	SF	\$120	\$4,422	
39923	106.0 to 117.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	62	SF	\$120	\$7,392	
39926	119.8 to 135.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	85	SF	\$120	\$10,164	
60379	133.9 to 156.8 feet	Driveway				REF			
39930	138.7 to 146.3 feet	Cross Slope (Driveway)	>15%	6 ft	42	SF	\$40	\$1,672	
39934	146.3 to 154.4 feet	Cross Slope (Driveway)	13.014	6 ft	45	SF	\$40	\$1,782	
39936	158.8 to 163.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	24	SF	\$120	\$2,904	
41159	160.1 to 161.3 feet	Running Slope	5.0-6.0%	6 ft	7	REF			
39938	164.3 to 169.7 feet	Cross Slope (PAR)	4.0-5.0%	6 ft	30	SF	\$120	\$3,564	
39940	170.8 to 182.4 feet	Cross Slope (PAR)	6.0-7.0%	6 ft	64	SF	\$120	\$7,656	
60380	184.9 to 229.8 feet	Driveway				REF			
39943	185.8 to 187.8 feet	Cross Slope (Driveway)	7.0-8.0%	6 ft	11	SF	\$40	\$440	
39944	190.9 to 206.0 feet	Cross Slope (Driveway)	>15%	6 ft	83	SF	\$40	\$3,322	
39947	206.0 to 218.1 feet	Cross Slope (Driveway)	13.014	6 ft	67	SF	\$40	\$2,662	
39952	218.1 to 219.5 feet	Cross Slope (Driveway)	11.0-12.0%	6 ft	8	SF	\$40	\$308	
39953	221.1 to 226.3 feet	Cross Slope (Driveway)	13.014	6 ft	29	SF	\$40	\$1,144	
39955	251.8 to 265.8 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	77	SF	\$120	\$9,240	

Funding Source: **TBD**

Year to be Completed **TBD**

Street Side	Run ID	Survey Street Name	Starting Street Name	End Street Name	Priority			
NE	51909261604	15TH ST	HUMBOLDT AVE	ORANGE AVE	TBD			
ID	Dist. from Corner	Barrier Type	As-is Measurement/Notes	Sidewalk Width	Qty	Unit	Cost	Total
39958	275.3 to 291.2 feet	Cross Slope (PAR)	2.0-3.0%	6 ft	87	SF	\$120	\$10,494
41160	289.5 to 290.8 feet	Running Slope	5.0-6.0%	6 ft	7	REF		
41161	290.8 to 291.8 feet	Running Slope	6.0-7.0%	6 ft	6	REF		
TOTAL COST FOR: NE side of 15TH ST Starting at: HUMBOLDT AVE							\$109,450.00	

Total Cost for County Sidewalks: \$99,502,998.38